

Survey Sheet of Pump Station

Survey Date: 25/08/09

Surveyor: Mr. Odean Samuels, Mr. Kristoffer Henry

Items		Specification
Name of Pump Station		Marine Park Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Aegean Ave.
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	152.4 mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / <u>Steel</u> / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units 1 units in service 1	
	1 Units out of service	
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	
	Bore diameter of pump unit	
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Pump Operation	Operation Hour	24 hours
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequency:)
	Repair / replacement of pump unit	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, in which year: 2009)
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequency: monthly)	
Present Issue		
<p>As with many other facilities only Maintenance poses a real problem where it is seen that only one pumping unit is in operable condition and the electricals concerning the generator needs a thorough inspection.</p>		

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)




General over view of the facility at Marine Park



Building which houses the electrical facilities



Picture displaying the general piping network at




Picture depicts that actual electrical wiring and instruments are in place and in operable condition at the marine park



The facilities for the back up generator



inlet pipe takes up waste from outside well directly below



Survey Sheet of Pump Station

Survey Date: 25/08/09

Surveyor: Mr. Odean Samuels, Mr. Kristoffer Henry

Items		Specification
Name of Pump Station		Marine Park Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Aegean Ave.
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	152.4 mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / <u>Steel</u> / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units 1 units in service 1	
	1 Units out of service	
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	
	Bore diameter of pump unit	
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Pump Operation	Operation Hour	24 hours
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequency:)
	Repair / replacement of pump unit	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, in which year: 2009)
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequency: monthly)	
Present Issue		
<p>As with many other facilities only Maintenance poses a real problem where it is seen that only one pumping unit is in operable condition and the electricals concerning the generator needs a thorough inspection.</p>		

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)




General over view of the facility at Marine Park



Building which houses the electrical facilities



Picture displaying the general piping network at




Picture depicts that actual electrical wiring and instruments are in place and in operable condition at the marine park



The facilities for the back up generator



inlet pipe takes up waste from outside well directly below



Survey Sheet of Pump Station

Survey Date: 25/08/2009

Surveyor: Mr. Odean Samuels, Mr. Kristoffer Henry

Items		Specification	
Name of Pump Station		Caymanas Garden D Pump Station	
Construction Year / Month		year :	month :
Location (name of street / avenue)		Ironside Drive	
Design capacity		m ³ /min	
Amount of electricity consumption		kWh/day	
Inlet Sewer	Diameter of inlet pi	101.6 mm	by Gravity / Pressure
	Material of pipe	Reinforced Concrete / <u>Steel</u> / Cast Iron / PVC / GRP / PE(HDPE)	
	Invert level of inlet pipe	m MSL	
Pump Unit	Number of units 2 units in service 1		
	1 Units out of service		
	Type of pump	Self Priming Centrifugal Pump	
	Manufacturer of pump / Model	(Name: Gorman Rupp)	
	Bore diameter of pump unit	101.6	
	Design capacity per unit (m ³ /min)		
	Design head of pump (m)		
	Back up generator	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Pump Operation	Operation Hour	24 hours	
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed	
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method	
	On - Off level	1st pump start level	m MSL
		2nd pump start level	m MSL
		3rd pump start level	m MSL
		Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Out of Service	
		(If yes, how frequently: inspected daily by NWC's mobile maintenance team)	
	Repair / replacement of pump unit	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
		(If yes, in which year:)	
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	(If yes, how frequently: Monthly)		
Present Issue			
<p>General issues as with all pumping station is that a lack of electrical maintenance is carried out hence there is currently no generator, even though the necessary facilities are in place for the standby generator.</p> <p>The level of security at the site can be improved, also the general condition of the compound can be improved .</p>			

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)



General building containing the
electricals and the generator



Electrical panels and controls



this depicts the back up
generator and its physical





picture depicting the wet well
and its screens which are
currently blocked and is in need



Eastern view of the piping
network and the general
environs



western view



Survey Sheet of Pump Station

Survey Date: 25/08/2009

Surveyor: Mr. Odean Samuels, Mr. Kristoffer Henry

Items		Specification
Name of Pump Station		West Bay A Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Coral Way
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	101.6 mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / Steel / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units 1 units in service 1	
	1 Units out of service	
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	(Name: Gorman Rupp)
	Bore diameter of pump unit	101.6
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Pump Operation	Operation Hour	24 hours
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequently: inspected daily by NWC's mobile maintenance team)
	Repair / replacement of pump unit	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, in which year: 2009)
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequently: Monthly)	
Present Issue		
<p>General issues as with all pumping station is that a lack of electrical maintenance is carried out hence there is currently no standby generator, even though the necessary facilities are in place for the standby generator. Also the motor of the pump is due for replacement.</p>		

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)



West Bay pumping station general
over view.




pumping units at the station



covered well which contains the
automatic level switch



pumping units
inlet



Survey Sheet of Pump Station

Survey Date: 25/08/2009

Surveyor: Mr. Odean Samuels, Mr. Kristoffer Henry

Items		Specification	
Name of Pump Station		Edgewater Pump Station 2	
Construction Year / Month		year :	month :
Location (name of street / avenue)		Debbie Avenue/ N.Edgewater Avenue	
Design capacity		m ³ /min	
Amount of electricity consumption		kWh/day	
Inlet Sewer	Diameter of inlet pipe	152.4 mm	by Gravity / Pressure
	Material of pipe	Reinforced Concrete / Steel / Cast Iron / PVC / GRP / PE(HDPE)	
	Invert level of inlet pipe	m MSL	
Pump Unit	Number of units 1 units in service 2		
	0 Units out of service		
	Type of pump	Self Priming Centrifugal Pump	
	Manufacturer of pump / Model	(name: Gorman Rupp)	
	Bore diameter of pump unit	152.4	
	Design capacity per unit (m ³ /min)		
	Design head of pump (m)		
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	(Out of Service)
Pump Operation	Operation Hour	24 hours	
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed	
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method	
	On - Off level 1st pump start level	m MSL	
	2nd pump start level	m MSL	
	3rd pump start level	m MSL	
	Pump stop level	m MSL	
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		(If yes, how frequently: inspected daily by NWC's mobile maintenance team)	
	Repair / replacement of pump unit	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		(If yes, in which year: 2008)	
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	(If yes, how frequently: approximately twice every month.)		
Present Issue			
General issues as with all pumping station is that a lack of electrical maintenance is carried out hence there is currently no standby generator, even though the necessary facilities are in place for the standby generator.			

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)



General over view at the
Edgewater Pumping Station



General piping network at the
pumping facilities



well and the automatic level
switches




Access way to the wet well and
vents at the Edgewater pump
station



general over view of the
condition of the back up
generator and the electrical
panel



Picture depicting the general
condition of the pump driving
motor



Survey Sheet of Pump Station		
Survey Date: 24-Aug-09		Surveyor: K.Henry, A.Acosta, O.Samuel
Items		Specification
Name of Pump Station		Bridgeport Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Eberle Drive/Gibson Road
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	150mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / Steel / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units 1 units in service	One
	Units out of service	One
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	Gorman Rupp
	Bore diameter of pump unit	6"
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <u>Out of Service</u>
Pump Operation	Operation Hour	24 hrs
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequently: Daily
	Repair / replacement of pump unit	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		(If yes, in which year:
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequently: Three times per year.	
Present Issue		


Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)



general over view at the
Bridge Port station




the wet well condition
(showing the type of influent)



The motor that drives the
Pump at the B.port Lift
station



general piping network at the
facility



Survey Sheet of Pump Station

Survey Date: 24-Aug-09

Surveyor: K.Henry, A.Acosta, O.Samuel

Items		Specification
Name of Pump Station		Portmore Mall Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Portmore Parkway
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	150mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / <u>Steel</u> / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units 1 units in service	One
	Units out of service	One
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	Gorman Rupp
	Bore diameter of pump unit	6"
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Out of Service
Pump Operation	Operation Hour	24 hrs
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequently: Daily
	Repair / replacement of pump unit	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		(If yes, in which year:
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequently: Three times per year.	
Present Issue		
<p>The actual inlet pipe diameter at the facility is too small for the quantity and type of waste that this station handles. The Portmore Mall area is a commercial area where lots of oils and grease are deposited into the pipes, which poses a lot of maintenance problems. It is seen that when the grease solidifies this reduces the effective diameter of the pipes, which in turn reduces the intake rate of the pump forcing the pump to work for longer periods.</p>		

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)



general over-view of the
Portmore mall facility.




general layout and condition of
the piping network at this station



Motor condition at the station
that drive the pump



wet well at the facility covered
with solidified grease



Survey Sheet of Pump Station

Survey Date: 25/08/2009

Surveyor: Mr. Odean Samuels, Mr. Kristoffer Henry

Items		Specification
Name of Pump Station		Cumberland Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Portmore Lane/Farm Way
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	76.2 mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / Steel / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units 1 units in service 1	
	0 Units out of service	
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	(Name: Gorman Rupp)
	Bore diameter of pump unit	76.2
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (Out of Service)
Pump Operation	Operation Hour	24 hours
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequently: inspected daily by NWC's mobile maintenance team)
	Repair / replacement of pump unit	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		(If yes, in which year:)
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequently: Monthly)	
Present Issue		
<p>The present issue that this pump station faces is its lack of a back-up generator facility.</p> <p>Also the screen that should be associated with the pump is currently out of service.</p>		

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)


Other (generator etc)



Building housing all the electrical, which should facilitate the back up generator



Condition of Back up generator and the other electrical facilities




Piping leaving out the Cumberland pumping station building



General piping layout at the Cumberland pumping station



Outside cover to wet well of the Cumberland Pumping



Survey Sheet of Pump Station

Survey Date: 25-Aug-09

Surveyor: K.Henry, A.Acosta, O.Samuel

Items		Specification
Name of Pump Station		Passagefort # 3 Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		London Avenue
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	152.4 mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / <u>Steel</u> / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units units in service	One
	Units out of service	One
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	Gorman Rupp
	Bore diameter of pump unit	
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <u>Out of Service</u>
Pump Operation	Operation Hour	24 hrs
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequenc: Daily
	Repair / replacement of pump unit	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		(If yes, in which year:
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequenc: Monthly	
Present Issue		
<p>The major issue that this pump station faces is the fact there is the necessary infrastructure in place for a stand by generator however the unit is out of service.</p>		

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)



General over view of the facility at Passage fort 3




The facilities for the back up generator



Picture displaying the general piping network at the pumping station below the entrance level



Picture displaying the Pumping unit at the pumping station below the entrance level



Survey Sheet of Pump Station

Survey Date: 25-Aug-09

Surveyor: K.Henry, A.Acosta, O.Samuel

Items		Specification
Name of Pump Station		Passagefort # 2 Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Palmetto West
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diameter of inlet pipe	76.2 mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / <u>Steel</u> / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units units in service 1	One
	0 Units out of service	One
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	Gorman Rupp
	Bore diameter of pump unit	
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Pump Operation	Operation Hour	24 hrs
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level 1st pump start level	m MSL
	2nd pump start level	m MSL
	3rd pump start level	m MSL
	Pump stop level	m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequently: Daily)
	Repair / replacement of pump unit	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		(If yes, in which year:)
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequently: Monthly)	
Present Issue		
<p>The major issue that this pump station faces is the fact there isn't necessary infrastructure in place for a stand-by ge</p>		

Photographs

General view of PS (2~3 shots)

Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)




General over view of the facility at Passage Fort 2



Picture depicts that actual electrical wiring and instruments are in place and in operable condition




Both pictures displaying the general piping network at the pumping station



Survey Sheet of Pump Station

Survey Date: 25-Aug-09

Surveyor: K.Henry, A.Acosta, O.Samuel

Items		Specification
Name of Pump Station		Passagefort # 1 Pump Station
Construction Year / Month		year : month :
Location (name of street / avenue)		Palmetto West/ Dawkins Drive
Design capacity		m ³ /min
Amount of electricity consumption		kWh/day
Inlet Sewer	Diamete of inlet pipe	100mm by Gravity / Pressure
	Material of pipe	Reinforced Concrete / <u>Steel</u> / Cast Iron / PVC / GRP / PE(HDPE)
	Invert level of inlet pipe	m MSL
Pump Unit	Number of units units in service	One
	Units out of service	One
	Type of pump	Self Priming Centrifugal Pump
	Manufacturer of pump / Model	Gorman Rupp
	Bore diameter of pump unit	
	Design capacity per unit (m ³ /min)	
	Design head of pump (m)	
	Back up generator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Out of Service
Pump Operation	Operation Hour	24 hrs
	Control Method	<input checked="" type="checkbox"/> by Unit / <input type="checkbox"/> by Speed
	Mode of control	<input checked="" type="checkbox"/> Automatic level switch / <input type="checkbox"/> Other method
	On - Off level	1st pump start level m MSL
		2nd pump start level m MSL
		3rd pump start level m MSL
		Pump stop level m MSL
Maintenance Record	Regular Maintenance / Inspection	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		(If yes, how frequenc: Daily
	Repair / replacement of pump unit	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
		(If yes, in which year:
	Replacement of consumable parts	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	(If yes, how frequenc: Monthly	
Present Issue		
		

Photographs

General view of PS (2~3 shots)


Pump unit (general, front view, side view, tag)

Control panel (general view of control room, front view on panel)

Other (generator etc)



General over view of the facility at Passage fort 1



Picture displaying the general piping network at the pumping station



The motor which drives the pump unit



The facilities for the back up generator