


THE PEOPLE'S REPUBLIC OF BANGLADESH
DETAILS DESIGN REPORT
ON
THE TELEVISION STUDIO CONSTRUCTION PROJECT

VOLUME V


MARCH 1978

JAPAN INTERNATIONAL COOPERATION AGENCY



THE PEOPLE'S REPUBLIC OF BANGLADESH
DETAILS DESIGN REPORT
ON
THE TELEVISION STUDIO CONSTRUCTION PROJECT

VOLUME V



MARCH 1978

JAPAN INTERNATIONAL COOPERATION AGENCY

国際協力事業団

受入 月日 '84. 5. 16	101
	79
登録No. 04785	SDS

CALCULATION SHEET

INDEX

1. Calculation Sheet of Structure1
2. Calculation Sheet of Acoustics163
3. Calculation Sheet of Ventilation177
and Air Conditioning

1. Calculation Sheet of Structure

STRUCTURAL ANALYSIS
ON
CONSTRUCTION PROJECT
OF B.T.V. HALL IN DACCA

CONTENTS

1 —	GENERAL	3
2 —	STRESS ANALYSIS	18
3 —	DESIGN OF FOUNDATION	77
4 —	/ BEAM	93
5 —	/ COLUMN	104
6 —	/ SUB-MEMBER	107
7 —	/ STEEL WORK	125
8 —	CHECK OF EXISTING PART	151

(TOTAL-161 P)

I - GENERAL

GENERAL NOTE

NAME OF BUILDING : B. T. V. HALL

LOCATION : DACCA , BANGLADESH

USE : AUDITORIUM

SCALE : 4F

TOTAL FLOOR AREA 3,924 m²
(EXTENSION PART 2,360 m²)

STRUCTURE : REINFORCED CONCRETE CONSTRUCTION
& STEEL CONSTRUCTION FOR PROCEMIUM FRAME

MATERIAL : CONCRETE PILE Fc 210 (3,000 P.S.I.)
GENERAL Fc 180 (2,600 P.S.I.)

: REINFORCEMENT

Ms Bar ($\frac{1}{4}$ " ~ 1")
J.I.S. SD30 (D10.13)
J.I.S. SD35 (D16 ~ 25)

: STEEL M/S Steel
SM50A
SS 41

: HITENSION BOLT F10T


FOUNDATION : CAST IN SITU ----- INDEPENDENT FOOTING

*


FOUNDATION IS DESIGNED BY M/S . BEAM, SUB BEAM, CANTILEVER & UNDER GROUND STRUCTURES ARE DESIGNED BY D-BAR. FOUNDATION BEAM, COLUMN, SLAB, WALL AND PROCEMIUM FRAME ARE DESIGNED IN 2 CASES,

FRAME MEMBER'S $Q_T = Q_L + 1.5 Q_E$ (Shear in Seismic Loading,)


PLAN GROUND F.




KEY PLAN GROUND F.





PLAN - FIRST F.




KEY PLAN - FIRST F.




PLAN SECOND. F.





KEY PLAN - SECOND F.



PLAN - THIRD F.




KEY PLAN - THIRD F.,




M3F


PLAN - ROOF F.




PLAN - FOURTH F.




KEY PLAN - ROOF F.



KEY PLAN - FOURTH F.



Section



ALLOWABLE STRESS INTENSITY

[kg/cm²]

STRESS MATERIAL		SUSTAINED LOADING							WELDING		TEMPORARY LOADING
		TENSION	COMPRESSION	SHEAR	POSITION Fc	TOP BAR	IN GENERAL	BUTT		FILLET	
								IN GENERAL	SHEAR		
CONCRETE	Fc 150 (2,600 PSI)	/	60	/	/	/	/	/	/	/	x 2.0
		/	/	6	/	/	/	/	/	/	x 1.5
	Fc 210 (3,000 PSI)	/	70	/	/	/	/	/	/	/	x 2.0
		/	/	7	/	/	/	/	/	/	x 1.5
REINFORCEMENT	M/S * (15 kip/in ²) (16 ")	1,265	1,125	1,265	/	/	/	/	/	/	x 1.33
	BAR	/	/	/	Fc 180	7.2	10.8	/	/	/	x 1.5
		/	/	/	∅ 210	8.4	12.6	/	/	/	x 1.5
	SD30	2,000	2,000	2,000	/	/	/	/	/	/	
		/	/	/	Fc 180	12.0	18.0	/	/	/	x 1.5
		/	/	/	∅ 210	14.0	21.0	/	/	/	x 1.5
	SD35	2,200	2,200	(2,000)	/	/	/	/	/	/	3,500 (3,000)
		/	/	/	Fc 180	12.0	18.0	/	/	/	x 1.5
	/	/	/	∅ 210	14.0	21.0	/	/	/	x 1.5	
STEEL	M/S ** STEEL	1,265 (12 kip/in ²) (14 ")	1,125 (16 ")	944 (12 ")	/	/	/	/	/	800 (11.4 kip/in ²)	x 1.33
	SS41	1,600	1,600	900	/	/	/	1,400	800	800	x 1.5
	SM50A	2,200	2,200	1,300	/	/	/	2,200	1,300	1,300	x 1.5

* Reinforcing No 1 grade

** It = "SANJUKTA" It (weldable quality)

[1 psi = 0.001 kip/in² = 0.0703 kg/cm²]

M/S BAR 'S DATA

Dia	ϕ cm	α cm ²	ρ g/cm	MAX LENGTH m (')	UNIT WEIGHT kg/m
1/4"	0.635	0.317	1.995		0.249
(5/16")	(0.794)	(0.495)	(2.494)		
3/8"	0.953	0.713	2.992	12.192 (40')	0.559
1/2"	1.270	1.267	3.990	"	0.994
5/8"	1.588	1.979	4.987	10.668 (35')	1.574
3/4"	1.905	2.850	5.985	"	2.237
7/8"	2.223	3.879	6.982	8.839 (29')	3.045
1"	2.540	5.067	7.980	"	3.978
1 1/4"	3.175	7.917	9.975	"	6.215

M/S STEEL'S DATA

L MAX LENGTH
26' = 7924.8

"	M/M	A cm ²	W kg/m
$\frac{3}{4}'' \times \frac{3}{4}'' \times \frac{1}{8}''$	19 x 19 x 3		0.80
$1'' \times 1'' \times \frac{1}{8}''$	25 x 25 x 3	1.548	1.22
$1\frac{1}{2}'' \times 1\frac{1}{2}'' \times \frac{1}{8}''$	38 x 38 x 3		1.80
$\times \frac{3}{16}''$	$\times 5$	3.419	2.68
$\times \frac{1}{4}''$	$\times 6$	4.482	3.49
$2'' \times 2'' \times \frac{1}{4}''$	51 x 51 x 6	6.065	4.76
$2\frac{1}{2}'' \times 2\frac{1}{2}'' \times \frac{1}{4}''$	64 x 64 x 6	7.613	5.98
$3'' \times 3'' \times \frac{3}{8}''$	76 x 76 x 10	13.484	10.58

M/S FE UNIT
8' x 4' = 24364 x 1219.2

"	M/M	W kg/m ²
$\frac{1}{8}$	3.18	24.9
$\frac{3}{16}$	4.76	37.4
$\frac{1}{4}$	6.35	49.8
$\frac{3}{8}$	9.53	74.8
$\frac{1}{2}$	12.70	99.7
$\frac{3}{4}$	19.05	149.5
1	25.4	199.3

FB (FLAT IRON BAR) MAX LENGTH
30' = 9144.0

"	M/M	A cm ²	W kg/m
$\frac{3}{4}'' \times \frac{1}{8}''$	19 x 3	0.60	0.47
$\times \frac{3}{16}''$	$\times 5$	0.91	0.71
$\times \frac{1}{4}''$	$\times 6$	1.21	0.95
$1'' \times \frac{1}{8}''$	25 x 3	0.81	0.63
$\times \frac{3}{16}''$	$\times 5$	1.21	0.95
$\times \frac{1}{4}''$	$\times 6$	1.61	1.27
$1\frac{1}{2}'' \times \frac{3}{16}''$	38 x 5	1.81	1.42
$\times \frac{1}{4}''$	$\times 6$	2.42	1.90
$2'' \times \frac{1}{4}''$	51 x 6	3.23	2.53

2-STRESS ANALYSIS

Stiffness Ratio

(IN FINAL REPORT, SOME MEMBER'S SIZE CHANGED TO QM UNIT ROUND NUMBER SIZE)

Column

	x10 ⁴ J	Pc				
		Story Height	4	3	2	1
2' □ 2'	115.08	289.56	393.24	338.28	320.04	512.70
3' □ 2'	388.39	0.40	0.29	0.34	0.36	0.22
2' □ 3'	172.62	1.34	0.99	1.15	1.21	0.75
3' □ 3'	582.59	0.60	0.44	0.51	0.54	0.33
		2.01	1.52	1.72	1.82	1.13

Beam

	x10 ⁴			Pc													
	J	φ	φJ	SPAN	426.92	528.32	629.92	731.92	833.12	944.48	1016.48	1122.00	1235.00	1307.60	1410.56	1515.36	
1'-6" I 1'-2"	28.73	1.58	45.37	0.10										0.07	0.07	0.07	
		1.58	52.39	0.12	0.10	0.08								0.08	0.09	0.08	
2' I 1'-2"	64.13	(1.0)	(67.13)	0.24	0.19	0.16	0.14	0.12	(0.09)	[0.12]	(0.09)			0.16	0.17	0.15	(0.07)
		1.5	100.69	0.26	0.23	0.19	0.17	0.15	0.13	0.21	0.16	0.19	0.20	0.18	0.15	0.12	
2'-6" I 1'-2"	131.11	1.5	196.67	0.46	0.37	0.31	0.27	0.24	0.21	0.34	0.26	0.31	0.32	0.29	0.29	0.20	
		1.8	236.60	0.55	0.45	0.37	0.32	0.28	0.25	0.41	0.31	0.37	0.39	0.35	0.35	0.24	
3' I 1'-2"	226.56	(1.0)	226.56	0.74	0.60	0.50	0.43	0.38	0.34	[0.14]	(0.30)			0.50	0.52	0.47	(0.24)
		1.4	312.19	0.90	0.73	0.61	0.53	0.46	0.41	0.55	0.42	0.50	0.52	0.47	0.38	0.33	
		1.7	385.15	0.90	0.73	0.61	0.53	0.46	0.41	0.67	0.51	0.61	0.63	0.57	0.39		
2' I 1'-2"	67.13	1.0	67.13						0.07	[0.02]						0.07	
										0.12	0.09						
5' I 1'-2"	1048.90	1.0	1048.90							[0.45]							
										1.81							
4' I 1'-2"	537.04	1.0	537.04	1.26	1.02	0.85	0.73	0.64	0.57	0.93	0.70	0.85	0.88	0.80	0.55		

Coefficient for T-Section's Geometrical Moment of Inertia

b	D	Type	t	t/D	ba = 0.18	B	B/b	β							
38.46 (1'-2")	45.72 (1'-6")	□	12.7 (5")	0.28	60.95	96.72	2.71	1.78							
		⌣	•	•	•	152.03	4.43	1.5							
35.56 (1'-2")	60.86 (2'-0")	□	•	0.21	•	96.72	2.71	1.5							
		⌣	•	•	•	152.03	4.43	1.5							
•	76.20 (2'-6")	□	•	0.17	•	96.72	2.71	1.5							
		⌣	•	•	•	152.03	4.43	1.5							
•	91.44 (3'-0")	□	•	0.14	•	96.72	2.71	1.4							
		⌣	•	•	•	152.03	4.43	1.7							

J : Geometrical Moment of T-Section (⌣)

J_b : " of Usual Section (□)

$$J = \phi J_b = \phi \frac{bD^3}{12}$$

$$\phi = 4d - 3\frac{\beta^2}{\gamma}$$


$$d = 1 + (b_1 - 1)t_1^3$$

$$\beta = 1 + (b_1 - 1)t_1^2$$

$$\gamma = 1 + (b_1 - 1)t_1$$


$$b_1 = \frac{B}{b}$$

$$t_1 = \frac{t}{D}$$



Span Length — MM

(Clear Span)




Stiffness Ratio Chart




Bearing Wall

← Same to Right Side


(b) FRAME




(c) FRAME





(A) FRAME




(B) FRAME










17 FRAME





18 FRAME








Live Load
PLAN GROUND F.




Index	Kg/m^2
S : Live Load for Slab and Subbeam.	
V : Vertical Load	
H : Seismic Force	

$1 \text{ P.S.F.} = 4.88266 \text{ Kg/m}^2$
 $(0.20481 \text{ P.S.F.} = 1 \text{ Kg/m}^2)$


Live Load —
PLAN - FIRST F.




Live Load ———
 PLAN SECOND. F.




Live Load —
 PLAN - THIRD F.



Live Load —
PLAN - ROOF F






Live Load —
PLAN - FOURTH F









Unit Load


Floor		Dead Load		Live Load		Kg/m ²
						Total Load
Roof		Water Roof	300	S	90	740
		RC 5" Ceiling	305 35	V H	70 30	720 680
			650			
Flys		Steel Frame	100	S	500	600
				V H	500 250	600 350
			100			
Gallery Ropping Space		Finish	60	S	180	590
		RC 5" Ceiling	305 45	V H	130 60	540 470
			410			
Mezzanine Roof				S	90	500
				V H	70 30	480 440
			410			
Air Sub Com. Com -Room 3-2F ~ 1F		Finish 6"	64-365	S	350	760 1060
		RC 5" Ceiling	305 50	V H	250 150	660 ~ 960 560 860
			410-710			
Lighting Room		Finish	60	S	350	550
		Steel Frame Ceiling	100 40	V H	250 150	450 350
			200			
Rack Room		same to IF		S	400	1110
		Air com -Room		V H	300 200	1010 910
			710			
Office		same to gallery		S	300	710
				V H	180 80	590 490
			410			

		Dead Load		Live Load		kg/m ² Total Load
Corridor		Same to Gallery		S	360	770
				V	330	740
			410	H	210	620
Stair case		410X2		S	360	1180
				V	330	1150
			820	H	210	1030
Toilet		Finish RC 5" ceiling	200	S	360	910
			305	V	330	880
			45	H	210	760
			550			
Stage		Finish RC 5"	65	S	360	730
			305	V	330	700
			370	H	210	630

(IN FINAL REPORT, SOME BEAM AND COLUMN SIZE CHANGED,)

Beam

	T/m			E/clear span					
	Skeleton	Finish	Σ						
1.6'  1-2'	0.390	0.018	0.406						
2'  1-2'	0.412	0.024	0.436						
2.6'  1-2'	0.742	0.064	0.806	Sec FOLLOWING P.					
3'  1-2'	0.672	0.079	0.751						
7'  1-2'	1.293	0.152	1.445						
4'  1-2'	1.041	—	1.041						



Beam Weight / Clear Span



Column

	t/m			t/story					
	Ske Incon	Finish	Σ	Story	4F	3F	2F	1F	GF
				Height	3,810	3,043	3,225	3,000	6,121
3' □ 3'	2.006	0.183	2.189		0.3	0.7	0.3	7.0	4.0
				4.7	7.3	6.8	7.2	10.4	7.0
3' □ 2'	1.333	0.152	1.485		5.9	4.7	5.2	4.9	6.4
				7.0	7.3	5.0	5.1	7.4	4.7
2' □ 2'	0.272	0.051	0.323		2.6	2.9	3.2	3.0	5.5
				1.3	2.3	2.1	2.1	4.8	2.7

Wall

	t/m ²			t/clear height - ft					
	Ske Incon	Finish	Σ	Story	4F	3F	2F	1F	GF
				Height	2,898	3,962	3,382	3,000	4,202
				Net Height	Under Beam	Under Slab			
					2,304	3,352	2,742	2,700	4,202
					~	~	~	~	~
					2,768	3,838	3,228	3,073	4,521
5' + 6'	0.203 + 0.256	0.050	0.619		1.43	2.03	1.70	1.60	2.25
					~	~	~	~	~
					1.71	2.37	2.00	1.90	2.70
6'	0.256	0.100	0.456		1.05	1.76	1.25	1.21	2.00
					~	~	~	~	~
					1.25	1.79	1.50	1.43	2.11
				Parapet					
				0.50					

Unit Area — 1:12



Detail of Vertical Load for Column

(ct.)

		(b) (1)	(b) (2)	(c) (1)	(c) (2)
4	S				
	B				
	C				
	W				
3	S				
	B				
	C				
	W				
2	S	0.96 x 0.4	0.1	x 15.1	13.5
	B	1.1 + 0.4	1.5	1.1 + 1.0	2.1
	C	1.3	1.3	1.3 + 1.3	3.1
	W		1.6		1.6
1	S	13.0	13.0	20.3	20.3
	B	1.1 + 0.4	1.5	1.1 + 1.0	2.1
	C	1.3	1.3	1.3 + 1.3	3.1
	W	1.02 x 4.7	0.7	x 3.2	0.9
5	S	36.2	23.2	43.0	27.7
	B	1.1 + 0.4	1.5	1.1 + 1.0	2.1
	C	1.3	1.3	1.3 + 1.3	3.1
	W	1.76 x 4.7	0.3	x 3.2	0.6
6	S	61.7	24.7	57.7	27.9
	B	1.1 + 0.4	1.5	1.1 + 1.0	2.1
	C	1.3	1.3	1.3 + 1.3	3.1
	W	1.76 x 4.7	0.3	x 3.2	0.6
F	S	1.4	1.4	1.4	1.4
	B	2.3	2.3	2.3	2.3
	C	2.7	2.7	2.7	2.7
	W	2.60 x 4.7	2.2	x 3.2	0.3
Σ	S	20.7	18.8	29.8	14.9
	B				
	C				
	W				

		② ①	② ②	③ ①	③ ②
A	S				
	D				
	C				
	W				
B	S				
	D				
	C				
	W				
Z	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W		1.6		1.6
I	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.1	3.3 + 2.6	5.9
	W	1.02 x 5.5	10.2	-	3.1
G	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	4.4	3.3 + 2.6	5.9
	W	1.75 x 5.5	9.7	-	4.4
F	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W	1.43 x 2.3	3.3	x 2.2	11.7
E	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W	2.50 x 5.5	13.8	-	4.4
D	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W	2.11 -		x 5.9	12.4
C	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W	1.75 x 5.5	9.7	-	4.4
B	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W	1.43 x 2.3	3.3	x 2.2	11.7
A	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W	1.43 x 2.3	3.3	x 2.2	11.7
Z	S	0.96 x 17.0	17.1	11 23.3	21.0
	D	1.4 + 1.1	2.5	1.4 + 2.1	3.5
	C	3.3	3.3	3.3 + 2.6	5.9
	W	1.43 x 2.3	3.3	x 2.2	11.7

		(1) (-)	(2) (0)	(3) (-)	(4) (0)
4	S				
	D				
	C				
	W				
3	S				
	D				
	C				
	W				
2	S	0.96 X 20.1	23.1	X 20.1	25.5
	D	2.1 + 1.7	3.6	2.1 + 2.5	4.6
	C	3.3	3.3	3.3 + 2.6	5.9
	W		1.6		1.6
1	S	31.6	31.6	47.7	47.7
	D	0.96 X 20.1	23.1	X 20.1	25.5
	C	2.1 + 1.7	3.6	2.1 + 2.5	4.6
	W	1.55 X 5.5	10.2	-	-
G	S	0.96 X 20.1	23.1	X 20.1	25.5
	D	2.1 + 1.7	3.6	2.1 + 2.5	4.6
	C	3.3	3.3	3.3 + 2.6	5.9
	W	1.55 X 5.5	10.2	-	-
F	S	127.5	54.1	101.0	93.4
	D	2.6	2.6	2.6	2.6
	C	4.3	4.3	4.3	4.3
	W	2.60 X 5.5	14.3	-	-
Σ		2.11 X 10.4	21.9	X 10.7	29.9
Σ		137.5	45.0	107.7	97.7


		(1) (1)	(2) (2)	(3) (3)	(4) (4)	(5) (5)	(6) (6)
4	S	0.72 x 20.7	17.6	x 0.5	0.5	x 0.5	4.4
	B	3.3	3.3	11.0	11.0	6.5	
	C	0.5 + 3.7	0.2	8.3 + 11.0	15.0	0.0 + 5.5	14.3
	W		1.3		4.2		4.2
	T	29.7	25.9	95.6	95.6	71.4	71.4
3	S	0.43 x 20.7	11.0	x 23.7	11.0	x 0.6	27.0
	B	3.3	3.3	10.2	10.2	6.9	6.9
	C	3.5 + 3.7	0.2	3.7 + 3.7	7.2	2.3	2.3
	W	2.11 x 9.0	3.3	x 15.7	23.1	x 15.3	23.3
	T	1.02 -	19.0	x 4.6	7.9	-	-
T	74.7	44.6	210.5	113.7	157.9	87.5	
2	S	0.96 x 14.0	13.4	x 21.7	27.0	0.72 x 10.2	13.1
	B	0.43 x 14.0	6.7	x 21.7	10.2		
	C	0.96 x 24.3	23.5	x 23.4	23.0		
	W	6.0 + 1.9	7.9	10.2 + 1.9	12.1	7.5	5.5
	T	7.2 + 3.7	10.9	7.2 + 17.7	15.9	3.5 + 14.4	17.9
T	159.1	80.6	323.6	113.1	232.4	73.5	
1	S	0.96 x 33.5	37.0	x 33.5	37.0	0.60 x 15.2	10.7
	B	3.3 + 0.9	4.2	13.3 + 0.9	8.7	x 10.4	7.6
	C	9.3 + 3.7	5.0	5.3 + 3.7	4.2	-	-
	W	1.87 x 7.6	3.1	-	7.2	-	7.2
	T	1.50 x 8.2	12.3	x 7.6	11.4	-	-
T	228.3	79.7	401.3	77.7	255.1	23.7	
9	S	1.01 x 14.0	14.1	0.96 x 21.7	20.8	-	0.72 x 17.3
	B	2.7 + 0.9	3.6	2.7 + 1.9	4.6	-	2.3
	C	4.6	4.6	1.9 + 1.4	3.3	-	3.5 + 3.7
	W	1.96 x 7.6	13.4	-	10.9	-	10.5
	T	1.43 x 7.8	11.2	x 6.7	9.6	-	x 4.6
T	225.1	91.3	450.1	48.8	266.6	10.5	
F	S	40.0	40.0				
	B	3.5	3.5	12.3	12.3	11.6	2.8
	C	6.0	6.0	6.0	6.0	3.6	3.6
	W	2.60 x 7.6	2.9	-	7.0	-	7.0
	T	2.11 -	20.0	-	-	-	x 4.6
T	373.4	72.4	675.4	273	222.8	22.2	
						103.9	21.3

		① ②		③ ④		⑤ ⑥		⑦ ⑧	
4	S	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04
	B	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	C	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0
	W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	T	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	S	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04
	B	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	C	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0
	W	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0
	T	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2	S	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04
	B	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	C	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0
	W	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0
	T	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1	S	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04	0.02 X 2.00	0.04
	B	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	C	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0
	W	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0
	T	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
0	S	-	0.0	-	0.0	-	0.0	-	0.0
	B	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	C	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0	0.0 + 0.0	0.0
	W	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0	0.0 X 0.0	0.0
	T	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
F	S	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
	B	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
	C	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5
	W	2.0 X 0.0	2.0	2.0 X 0.0	2.0	2.0 X 0.0	2.0	2.0 X 0.0	2.0
	T	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1

		(V) (5)	○ ○	○ ○	○ ○		
4	S	X	X				
	B						
	C						
	W						
Z							
3	S	X	X				
	B						
	C						
	W						
Z							
2	S	0.72 X 21.3	15.3				
	B	2.7	2.7				
	C	3.5 + 1.7	5.2				
	W		1.6				
Z		24.8	24.8				
1	S	0.60 X 21.3	12.8				
	B	2.1	2.1				
	C	2.8	2.8				
	W	1.84 X 8.1	15.0				
Z		63.6	63.6				
G	S	0.72 X 15.8	11.4				
	B	2.1 + 2.3	4.4				
	C	3.7 + 3.7	7.2				
	W	1.76 X 8.1	14.3				
Z		105.3	105.3				
E	S						
	B	2.8	2.8				
	C	3.6	3.6				
	W	2.60 X 8.1	21.1				
Z		184.2	184.2				
				(NOTE) SOME SMALL DIFFERENCE ARE IN THE CONTENTS OF COLUMN AXIAL FORCE LIST WITH ACTURAL FINAL PLAN.			


VERTICAL LOAD
KEY PLAN - ROOF, F = FOURTH F. COLUMN

(ct)




VERTICAL LOAD
KEY PLAN - FOURTH, F = THIRD F. COLUMN

(ct)




**VERTICAL LOAD
KEY PLAN - THIRD F., - SECOND F. COLUMN** (ct)




VERTICAL LOAD
KEY PLAN - SECOND. F. = FIRST F. COLUMN

(ct)




VERTICAL LOAD
KEY PLAN · FIRST F = GROUND F. COLUMN

ct)











**VERTICAL-LOAD
KEY PLAN GROUND. F. - FOUNDATION (ct)**






CM₀Q OF BEAM

(Calculated by Computer)

	LOAD	C	M ₀	Q
		[tm]	[t]	[t]
3 - 2 0	R_x 3.05 R_y 5.28 u 0.72 R 5.28 f 0.61 			
		5.8	8.9	5.7
2 - 2 0	R_x 3.05 R_y 5.28 u 0.66 R 5.28 f 0.61 			
		5.4	8.4	5.4
1 - 2 0	R_x 3.05 R_y 5.28 u 0.59 R 5.28 f 0.61 			
		5.0	7.7	5.0
4 - 2 0	R 5.28 f 1.04 			
		2.4	3.6	2.7
3 - 2 0	R_x 3.05 R_y 6.30 u 0.72 R 6.30 f 0.61 			
		8.5	13.1	7.2
2 - 2 0	R_x 3.05 R_y 6.30 u 0.66 R 6.30 f 0.61 			
		8.0	12.2	6.7
1 - 2 0	R_x 3.05 R_y 6.30 u 0.59 R 6.30 f 0.61 			
		7.4	11.3	6.2
4 - 2 0	R 6.30 f 1.04 			
		3.4	5.2	3.3






	LOAD				C		M ₀		Q	
1203	Cx 2.07 Cy 7.32 L 7.32	u v	0.57 0.51							
					11.0		17.9			0.6
1202	Cx 2.07 Cy 7.32 L 7.32	u v	0.65 0.61							
					11.0		16.0			0.1
1201	Cx 2.07 Cy 7.32 L 7.32 P 2.05	u v P	0.65 0.61 1.95							
					15.0		22.6			10.7
					6.1		9.3			2.7
					19.7		32.4			13.4
1204										
			1.04 1.04 1.04							
					4.6		7.0			2.3
					8.1		10.2			2.7
					12.7		18.2			5.0
1203		u v P	0.72 0.73 0.61 0.55		15.0		20.3			8.0
					13.5		21.1			8.4
					27.5		41.4			16.4
1202										
					13.0		22.6			7.4
					12.7		19.7			5.7
					27.3		42.3			13.1
1201										
					15.0		20.3			8.0
					13.5		21.1			8.4
					27.5		41.4			16.4
1204			1.04 1.04 1.04							
					6.0		9.1			4.3
					16.4		23.8			6.7
					27.4		42.9			11.0

LOAD		C		M _i		Q			
0	1	T _E	T _O	T _E	T _O	T _E	T _O		
	W	0.72							
	P	0.75	36.7	32.8	(46.1)	57.2	27.8	17.0	
	W	0.54							
	P	0.75	30.7	27.3	(38.6)	47.6	19.2	14.3	
	W1	0.66	34.7	30.9	(43.6)	54.0	21.6	16.1	
	W2	0.72	19.6	17.7	(24.8)	30.7	11.9	9.0	
	P1	0.75							
	P2	0.44	54.3	48.6	(68.4)	84.7	33.5	25.1	
	W1	0.66	34.7	30.9	(43.6)	54.0	21.6	16.1	
	W2	0.66	18.2	16.4	(23.0)	28.5	11.1	8.3	
	P1	0.75							
	P2	0.44	52.9	47.3	(66.6)	82.5	32.7	24.4	
	W	0.99							
	P	0.75 0.76+0.44 =2.20	42.9	37.6	(53.7)	65.7	26.9	19.6	
	W	1.04							
	P			7.7		11.6		4.9	
		$P_1 = \{132 \times (8.38 + 19.86)\} + \{6.43 \times 4.19\} + \{0.75\} = 74.3 \text{ [T]}$ $P_2 = \{132 \times 4.19\} + \{6.43 \times 2.90\} = 24.2 \text{ [T]}$							
	W	1.32 0.72+0.60							
	P	6.43 0.75	590.2			964.9		141.4	

	LOAD		C	M.	Q		
G ₁ 4-20	2x 2.01 2y 0.75 24 	0.92					
	2 0.62 2 2 0.75/2 P	0.98 0.95					
			20.9	37.9	12.7		
G ₂ 4-20	— 2 0.62 2	0.98					
			3.6	1.4	2.9		
G ₃ 4-20	— 2 0.62 2	0.98					
			3.6	5.4	2.9		
G ₄ 4-20	— 2 0.62 2	1.04					
			4.0	7.5	4.0		
G							
G ₅ 4-20		0.92	7	5.2	9.2	3.0	
		0.92		4.4	6.6	3.9	
		0.61					
		0.94					
G ₆ 4-20	,	0.66	7	4.8	8.4	3.5	
		0.66		3.4	5.2	3.0	
		0.39					
		0.39					
G				8.2	13.6	6.5	
G ₇ 4-20		1.04					
			3.5	5.3	3.3		

LOAD				C	M _o	Q
C' 20' d'		W ₁	0.72	4.3	4.6	4.0
		W ₂	0.72	4.0	6.1	3.7
		T	0.61			
		P	0.44			
			9.3	15.7	7.7	
C' 20' d'	.	W ₁	0.66	4.9	8.8	3.6
		W ₂	0.66	3.2	4.8	2.9
		T	0.39			
		P	0.39			
			8.1	12.6	6.5	
C' 20' d'	.	W ₁	0.89	4.5	8.2	3.4
		W ₂	0.89	2.6	5.5	2.4
		T	0.61			
		P	0.44			
			8.1	13.7	6.8	
C' 20' d'		T	1.04			
				3.2	4.8	3.2
C' 20' d'		W ₁	0.72	8.4	15.7	6.0
		W ₂	0.72	4.0	6.1	3.7
		T	0.61			
		P	0.44			
			12.4	21.8	9.7	
C' 20' d'	.	W ₁	0.66	7.7	14.3	5.5
		W ₂	0.66	3.2	4.8	2.9
		T	0.39			
		P	0.39			
			10.9	19.1	8.4	
C' 20' d'	.	W ₁	0.96	10.8	20.1	7.7
		W ₂	0.96	4.7	7.1	4.3
		T	0.61			
		P	0.44			
			15.5	27.2	12.0	
C' 20' d'		T	1.04			
				3.2	4.8	3.2

LOAD			C	M.	Q	
G ₁	 $0.71 + 0.60 = 1.31$ 1.33 q P	M ₁	1.33			
		M ₂	1.33			
		F	0.61	18.6	24.0	12.1
G ₂	 0.66 q P	M ₁	0.66			
		M ₂	0.66			
		F	0.39	8.1	12.5	6.3
G ₁	 0.96 q P	M ₁	0.96			
		M ₂	0.96			
		F	0.61	12.0	18.4	9.4
G ₁	 1.04 q P	F	1.04			
				3.9	5.9	3.5
G ₂	 0.92 q P	M _{max}	0.92	7.5	12.1	7.9
		F	0.48	11.4	17.4	6.0
				5.9	8.9	3.7
				24.8	38.4	17.6
G ₂	 0.97 q P	M ₁	0.97			
		M ₂	0.97			
		F	0.55			
				21.7	32.8	12.3
G ₂	 0.60 q P	M	0.60			
		F	0.32 (0.32 + 0.14)			
				28.6	34.8	14.1
G ₁	 1.04 q P	F	1.04			
				8.3	12.4	5.1

	LOAD			C	M _o	Q
3 CG 0' 2"	$P_1 = 0.72 \times 3.1 + 0.34 \times 6.1 =$ $P_2 = 0.72 \times 2.0 + 0.34 \times 2.0 =$ 	6.04 2.22	x 2.0 x 1.0	12.1 2.2		x 1.0 x 1.0 6.1 2.2
				14.3		8.3
2 CG 0' 2"	$P_1 = 0.66 \times 5.1 + 0.34 \times 6.1 =$ $P_2 = \quad \times 2.0 + \quad \times 2.0 =$ 	5.94 2.10	x 2.0 x 1.0	11.9 2.1		x 1.0 x 1.0 4.8 2.1
				13.6		7.9
1 CG 0' 2"	$P_1 = 0.57 \times 5.1 + 0.34 \times 6.1 =$ $P_2 = \quad \times 2.0 + \quad \times 2.0 =$	4.34 1.96	x 2.0 x 1.0	10.8 2.0		x 1.0 x 1.0 5.4 2.0
				12.8		7.4
3 CG 0' 2"	$P_1 = 0.72 \times 3.1 + 0.34 \times 6.1 =$ $P_2 = \quad \times 2.0 + \quad \times 2.0 =$ 	6.38 2.22	x 2.0 x 1.0	12.8 2.2		x 1.0 x 1.0 6.4 2.2
				15.0		8.6
2 CG 0' 2"	$P_1 = 0.66 \times 5.1 + 0.34 \times 6.1 =$ $P_2 = \quad \times 2.0 + \quad \times 2.0 =$	6.06 2.30	x 2.0 x 1.0	12.1 2.3		x 1.0 x 1.0 6.1 2.3
				14.4		8.4
1 CG 0' 2"	$P_1 = 0.72 \times 3.1 + 0.34 \times 6.1 =$ $P_2 = \quad \times 2.0 + \quad \times 2.0 =$	7.68 2.30	x 2.0 x 1.0	15.4 2.7		x 1.0 x 1.0 7.7 2.7
				18.1		10.4
1 CG 4' 2"	$P_1 = 0.72 \times 7.0 + 0.34 \times 4.1 =$ $P_2 = \quad \times 3.1 + \quad \times 3.5 =$ 	5.72 4.86	x 3.5 x 1.5	20.4 5.3		x 1.0 x 1.0 8.7 4.9
				25.7		13.6
CG 4' 2"	$P_1 = 0.57 \times 4.1 + 0.34 \times 5.1 =$ $P_2 = \quad \times 2.0 + \quad \times 2.0 =$ 	4.38 1.56	x 2.0 x 1.0	8.7 1.9		x 1.0 x 1.0 4.9 1.9
				10.6		6.5
CG						

VERTICAL LOAD - STRESS

(A) FRAME

(B) FRAME

3	0.43	0.57	0.57	0.43	CG		
3,282 ²	+2.5 +1.4 -1.6 +2.3	-5.5 +3.3 +2.4 -2.2 -2.3	+5.8 +4.8 +1.9 -2.0 +1.3 +4.0	+3.7 +1.8 -1.5	-14.3		
	(1.4)	7.6 (7.2)		(2.3)			
2	0.45	0.43	0.12	0.12	0.45	0.43	CG
3,200 ⁴	+2.4 +0.4 -1.2 +2.1	-5.4 +2.4 +0.7 -1.2 -2.3	+5.4 +1.0 +0.4 -0.5 +2.3	+3.7 +1.8 -1.5	+2.5 +1.4 -1.3	-13.6	
	(0.3)	5.4 (5.4)		(2.3)			
1	0.21	0.35	0.44	0.21	0.35	0.44	CG
5,197	+1.0 +0.2 -0.4 +0.9	-5.0 +2.2 +0.3 -2.2 -3.0	+3.0 +1.6 -0.2 -0.6 +1.5	+3.7 +1.8 -1.5	+2.5 +1.4 -1.3	-12.8	
	(0.3)	3.7 (5.6)		(0.4)			
4	0.19	0.52	0.52	0.19			
5,197	+0.4 +0.3 -0.1 +1.0	-2.4 +2.0 +1.0 -1.0	+2.4 +1.0 -0.6 +0.6	-0.4 -1.4 -0.4 +0.6			
	(2.7)	3.4 (7.8)					

3	0.48	0.52	0.52	0.48	CG		
3,282 ²	+4.1 +1.4 -1.6 +4.4	-8.8 +4.4 +1.8 -1.8	+8.8 +3.0 +2.2 -1.8 +1.3 +2.4	+2.8 +1.3 -1.7	-14.3		
	(2.6)	5.0 (8.4)		(1.6)			
2	0.44	0.46	0.10	0.10	0.44	0.46	CG
3,200 ⁴	+2.5 +1.4 -1.7 +3.2	-5.0 +2.1 +0.3 -0.4 +4.1	+8.0 +0.4 +2.5 -0.2 -1.8 +2.3	+2.6 +1.4 -1.5	-13.6		
	(2.0)	4.8 (6.8)		(1.5)			
1	0.23	0.33	0.39	0.23	0.33	0.39	CG
5,197	+1.7 +0.7 -0.7 +1.4	-7.4 +2.8 +1.8 -1.3 -4.7	+7.4 +2.1 +1.1 -1.3 +1.2	+2.1 +1.3 -0.9	-12.8		
	(0.6)	3.9 (7.1)		(0.1)			
4	0.21	0.79	0.79	0.21			
5,197	+0.7 +0.9 -0.1 +0.1 +1.7	-3.4 +2.7 +1.4 -1.4 -1.7	+3.4 +1.4 -1.6 +0.5	-0.7 -0.6 -0.4 -0.5			
	(3.3)	4.1 (3.5)					



(F) FRAME

(G) FRAME

3	0.52	0.48	0.48	0.52	CG		
3,382 ²	+6.1 +1.8 -1.3 +6.7	-11.8 +5.7 +0.6 -1.2 -6.7	+11.8 +1.2 +1.3 -2.9 +2.5 +4.3	+1.3 +2.5 -1.8	-14.3		
	(2.2)	7.4 (7.6)		(0.4)			
2	0.35	0.33	0.32	0.35	0.33	0.32	CG
3,200 ⁴	+3.9 +2.0 -2.6 +5.3	-11.0 +3.6 +0.5 -2.4 -1.5	+11.0 +0.3 +0.4 -0.2 -0.4 +1.2	+0.9 +0.7 -0.4	-13.6		
	(0.5)	5.4 (8.6)		(1.3)			
1	0.24	0.40	0.36	0.24	0.40	0.36	CG
5,197	+4.7 +1.4 -0.5 +5.6	-12.7 +7.9 +2.0 -1.3 -0.5 -14.7	+12.7 +2.5 -1.6 -1.0 -0.6 +1.8 -0.6	+2.8 +2.5 -1.1 -0.4	-12.8		
	(2.2)	15.2 (14.1)		(1.5)			
4	0.23	0.77	0.77	0.23			
5,197	+2.7 +2.4 +0.5 +5.6	-11.7 +9.0 -4.3 +1.6	+11.7 +1.0 +4.5 -3.8 +4.4	-2.7 -2.8 -0.9 -4.4			
	(7.7)	16.2 (7.9)					

3	0.55	0.45	0.45	0.55	CG		
3,382 ²	+16.1 +4.8 -1.1 +19.8	-24.2 +13.1 -2.8 -0.9 -14.8	+24.2 +5.6 +2.8 -2.0 +2.1 +26.4 -11.4	+6.9 -2.5 -2.5	-15.0		
	(1.4)	22.3 (11.8)		(5.1)			
2	0.37	0.35	0.28	0.37	0.35	0.28	CG
3,200 ⁴	+10.1 +4.6 -5.1 +14.0	-27.3 +9.6 +7.6 -1.6 -4.6 -25.9	+27.3 +2.1 -5.2 -2.0 +1.8 +21.8 -7.6	-4.0 -2.5 +1.7	-14.4		
	(1.7)	15.5 (18.0)		(6.7)			
1	0.25	0.42	0.33	0.25	0.42	0.33	CG
5,197	+11.6 +2.9 -1.0 +12.7	-47.3 +19.9 +15.6 -4.1 -1.3 -27.1	+47.3 +7.1 -6.1 -2.4 -2.1 +0.8 -9.3	-10.3 -2.1 -1.4	-18.1		
	(4.9)	25.2 (31.8)		(3.6)			
4	0.26	0.74	0.74	0.26			
5,197	+5.8 +5.3 +0.2 +11.9	-22.4 +16.6 -6.8 -11.9	+22.4 +18.5 +8.9 -8.8 +9.3	-4.8 -8.1 -1.4 -9.3			
	(16.4)	37.3 (16.4)					

FRAME



= Bearing wall
(Not to be removed in future)

① FRAME C1)

③	0.48	0.57	0.34	0.31	0.38	0.42	0.18	0.48			
	+4.6 -1.6 +5.9	+4.6 -1.2 +5.9	+4.6 -0.6 +5.9	+4.6 -0.1 +5.9	+4.6 -0.1 +5.9	+4.6 -0.1 +5.9	+4.6 -0.1 +5.9	+4.6 -0.1 +5.9	+4.6 -0.1 +5.9		
3.252	(3.4)	(3.7)	(3.5)	(3.5)	(3.7)	(3.7)	(3.7)	(3.7)			
②	0.28	0.61	0.14	0.09	0.41	0.39	0.11	0.10	0.41	0.39	0.10
	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7	+2.1 -0.3 +1.7
3.200	(0.4)	(0.7)	(0.7)	(0.7)	(0.7)	(0.7)	(0.7)	(0.7)	(0.7)	(0.7)	(0.7)
①			0.23	0.37	0.40	0.29	0.16	0.26	0.29		
			+1.9 -0.1 +1.9	+1.9 -0.1 +1.9	+1.9 -0.1 +1.9	+1.9 -0.1 +1.9	+1.9 -0.1 +1.9	+1.9 -0.1 +1.9	+1.9 -0.1 +1.9	+1.9 -0.1 +1.9	+1.9 -0.1 +1.9
3.147			(0.8)	(0.8)	(0.8)	(0.8)	(0.8)	(0.8)	(0.8)	(0.8)	(0.8)
④	0.14	0.36	0.44	0.11	0.38	0.44	0.12	0.44			
	+0.5 -0.1 +1.8	+0.5 -0.1 +1.8	+0.5 -0.1 +1.8	+0.5 -0.1 +1.8	+0.5 -0.1 +1.8	+0.5 -0.1 +1.8	+0.5 -0.1 +1.8	+0.5 -0.1 +1.8			
3.262	(3.7)	(3.7)	(3.7)	(3.7)	(3.7)	(3.7)	(3.7)				
b											
c											
d											



Ⓞ FRAME (2)

	0.24	0.16	0.16	0.34	
Ⓡ	+7.0	-24.8	+24.8	-20.8	
	+6.3	-2.0	-2.0	-2.3	
	-2.6	-0.7	38.4	+0.7	+7.6
	-23.2	-27.5	19.9	-23.5	-23.6
	(0.2)	(17.6)			(12.0)
	0.39	0.91	0.10	0.10	0.39
Ⓢ	+9.7	+24.8	+24.8	-9.7	-12.6
	+1.8	+10.4	-2.0	+1.2	-5.2
	-2.1	-5.4	-1.1	+1.4	+7.1
	+7.4	+17.6	-25.0	+25.3	-7.4
	(3.3)	(17.6)			(8.0)


0.44	0.10	0.44	0.36	0.32	0.32	0.07	0.43	0.38	0.10	0.11	0.47	0.42
+9.3	+1.4	-12.4	+12.4	+1.0	-15.6	+7.6	+2.0	+2.0	-24.8	+24.8	+0.7	-10.4
+1.4	+0.3	+1.4	+1.2	+1.0	-1.0	+0.8	+4.0	+4.0	+4.0	-0.7	-9.7	-12.6
0	+0.6	+0.6	+0.7	-0.1	+0.4	+0.8	+3.6	+3.6	-2.0	+1.2	-5.2	-7.4
-0.3	-0.2	-0.2	-0.2	-0.1	-0.2	-0.2	-2.3	-2.3	-0.9	+1.4	+5.7	+5.0
+10.2	+0.7	-10.9	21.7	-14.1	-14.4	-16.3	+4.9	+2.5	-26.1	+25.3	-18.6	-10.3
	(0.15)	(0.2)	(17.6)	(17.1)	(17.1)	(17.1)	(17.6)	(17.6)	(17.6)	(17.6)	(17.6)	(17.6)
			9.3	8.7	8.7	8.7	12.9	12.9	12.9	12.9	12.9	12.9
			(0.2)	(0.2)	(0.2)	(0.2)	(0.2)	(0.2)	(0.2)	(0.2)	(0.2)	(0.2)
0.10	0.41	0.39	0.10	0.10	0.41	0.39	0.10	0.01	0.46	0.43	0.14	0.20
+8.1	+0.8	+1.1	-10.9	+10.9	-1.1	-3.1	-3.1	+8.1	+4.7	+4.7	+24.8	+24.8
+0.8	+1.1	+0.2	+0.3	+0.3	-1.1	-0.8	-0.8	+0.2	+7.7	+7.7	+0.7	-6.2
-0.1	-0.4	-0.4	-0.1	19.1	-0.1	0	0	-0.2	-3.3	-3.3	-0.7	-7.2
+9.8	+1.7	+0.7	-10.9	+10.8	-1.0	-0.7	-0.8	+0.2	+1.5	+1.5	+1.0	+1.7
	(1.3)	(1.4)	(1.4)	(1.4)	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)	(1.0)
			8.3	12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9
			(0.4)	(0.4)	(0.4)	(0.4)	(0.4)	(0.4)	(0.4)	(0.4)	(0.4)	(0.4)
0.29	0.16	0.36	0.29	0.30	0.16	0.27	0.27	0.11	0.34	0.45		
+8.1	+2.1	+2.0	-14.8	+14.8	-0.6	-2.0	-2.0	+12.0	+4.1	+4.1		
+2.1	+1.2	+0.6	+0.6	+1.1	+0.6	-0.6	-0.7	-1.2	-4.1	-4.1		
0	0	0	0	0	0	0	0	-0.4	-1.5	-1.5		
+10.2	+1.2	+2.6	-14.0	+16.6	-0.6	-1.6	-1.6	+4.8	+4.7	+4.7		
	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)		
			12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9		
			(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)	(0.3)		
0.46	0.17	0.44	0.46	0.12	0.42	0.28	0.41	0.31	0.48	0.45		
+3.2	0	-3.2	+3.2	+0.1	-5.9	+3.9	+1.8	-8.2	+8.2	+8.2		
0	+0.6	+0.2	+0.2	-0.1	+0.2	+1.2	-2.1	-1.3	-4.5	-4.5		
-0.4	-0.2	-0.2	-0.2	0	+0.2	+0.3	-1.7	-1.3	+0.7	+0.7		
+2.0	+0.6	-2.4	+3.3	-0.2	-3.1	+1.3	+1.7	+1.3	12.4	+1.3		
	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)		
			12.9	12.9	12.9	12.9	12.9	12.9	12.9	12.9		
			(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)	(1.3)		

④ FRAME

③ FRAME



Zoning of Seismic Force Estimation



Seismic Forces are estimated according to divided 3 zones which are illustrated in above fig. Existence of big opening of stage requires such device.

α — zone



			W	K ^K W	Q
R II	S				
	M				
II A	S				
	M				
III O	S	(0.68 × 307.7)	207.2		
	M	17.4 + 32.6 18.6 + 17.3 (3.2 × 12) / 2 [(0.50 × 40.9) + (1.70 × 35.0) + (1.28 × 24.3) + (0.40 × 24.9)] / 2	52.0 35.7 19.2 67.3	0.05	
		$\bar{u} = 388.6 / 307.7 = 1.26 \text{ } \frac{\text{m}}{\text{m}^2}$	388.6	19.2	20.0
II N	S	(0.44 × 347.9) + (0.56 × 307.7)	188.1		
	M	13.0 + 24.7 17.8 + 16.7 (3.0 × 12) / 2 [(1.60 × 29.0) + (1.21 × 62.0)] / 2 19.2 + 47.1	37.7 34.5 18.0 61.3 66.3	*	
		$\bar{u} = 345.9 / 307.7 = 1.29 \text{ } \frac{\text{m}}{\text{m}^2}$	345.9	19.8	40.0
II I	S	(0.91 × 14.3) + (1.03 × 22.7) + (0.86 × 133.4) + (0.62 × 50.5) + (0.49 × 82.5) + (0.76 × 4.3)	226.1		
	M	19.4 + 32.6 19.5 + 16.2 (5.8 × 12) / 2 [(2.66 × 27.0) + (2.00 × 62.0)] / 2 18.0 + 61.3	52.0 35.7 34.8 100.6 79.3	*	
		$\bar{u} = 528.5 / 307.7 = 1.72 \text{ } \frac{\text{m}}{\text{m}^2}$	528.5	26.4	67.0
III O	S	33.3 + 62.9	77.2		
	M	348 + 100.6	135.4	*	
			222.6	11.6	77.0

В — zone

				W	K _W	Q
π ₁₂	Σ	(0.68 × 221.1)	150.3			
	Σ	28.7 + 22.6 7.4 + 26.0 {(8.3 × 2) + (5.9 × 13) + (2.6 × 2)} / 2 {(0.50 × 43.0) + (1.13 × 47.4)} / 2	91.3 33.4 16.3 60.4		0.05	
	Σ	$\bar{u} = 311.7 / 221.1 = 1.41 \text{ t/m}^2$		311.7	14.9	16.0
π ₁₄	Σ	(0.47 × 123.3) + (0.77 × 95.8)	77.4			
	Σ	19.3 + 11.0 9.0 + 12.5 {(6.7 × 2) + (4.7 × 10) + (2.9 × 2)} / 2 {(2.08 × 44.4) + (1.56 × 21.5)} / 2 16.3 + 33.9	30.8 21.8 13.1 62.9 50.2		*	
	Σ	$\bar{u} = 290.9 / 221.1 = 1.28 \text{ t/m}^2$		290.9	13.8	30.0
π ₁₆	Σ	(0.47 × 41.1) + (0.76 × 96.2) + (0.88 × 35.9)	97.5			
	Σ	31.7 + 14.7 9.0 + 19.3 {(7.3 × 2) + (5.2 × 1.5) + (3.2 × 2)} / 2 {(1.50 × 6.8) + (1.10 × 31.1) + (1.28 × 32.0)} / 2 13.1 + 62.9	46.4 28.3 14.4 51.0 76.0		0.05	
	Σ	$\bar{u} = 313.6 / 256.8 = 1.22 \text{ t/m}^2$		313.6	15.7	40.0
π ₁₈	Σ	(0.47 × 41.1) + (0.76 × 131.7) + (0.79 × 35.7)	108.9			
	Σ	16.3 + 13.5 8.0 + 17.0 {(7.0 × 2) + (4.9 × 1.5) + (3.0 × 2)} / 2 {(1.60 × 31.1) + (1.21 × 17.5)} / 2 14.4 + 47.6	29.8 25.0 13.8 35.3 62.0		*	
	Σ	$\bar{u} = 275.0 / 256.8 = 1.07 \text{ t/m}^2$		275.0	13.8	60.0
π ₂₀	Σ	(0.91 × 14.0) + (0.86 × 21.7)	31.4			
	Σ	14.8 + 12.7 1.0 + 4.1 {(14.0 × 2) + (9.4 × 1.5) + (4.8 × 2)} / 2 {(2.66 × 31.1)} / 2 13.8 + 35.5	22.5 5.1 26.9 41.4 49.3		*	
	Σ	$\bar{u} = 176.6 / 246.3 = 0.69 \text{ t/m}^2$		176.6	8.8	69.0
π ₂₂	Σ	28.6 + 25.3	53.9			
	Σ	26.9 + 41.4	68.3		*	
	Σ			122.2	6.1	76.0

α — Zone

			W	K _{KW}	Q
Π ²	S G G S	(0.68 × 124.3)	54.9		
		15.7 + 15.7 4.0 + 14.4 $\{(8.3 \times 2) + (2.9 \times 1.4)\} / 2$ $\{2.90 \times 34.0\} + \{(1.40 \times 28.1)\} / 2$	31.4 18.4 12.7 37.9	0.05	
		$\bar{u} = 185.3 / 128.2 = 1.45 \text{ t/m}^2$	185.3	9.3	18.0
Π ⁴	S G G S	(0.47 × 279.0) + (0.36 × 98.5)	47.2		
		9.2 + 7.5 4.0 + 0.9 $\{(6.7 \times 2) + (4.7 \times 1.7)\} / 2$ $\{(2.00 \times 29.1)\} / 2$ 12.7 + 20.8	14.7 4.9 10.2 30.3 33.5	"	
		$\bar{u} = 140.8 / 128.2 = 1.14 \text{ t/m}^2$	140.8	7.1	18.0
Π ³	S G G S	(0.47 × 41.1) + (0.65 × 79.0)	43.0		
		29.4 + 11.0 7.0 + 6.7 $\{(7.7 \times 2) + (2.7 \times 1.0) + (3.2 \times 2)\} / 2$ $\{(0.70 \times 18.0) + \{(1.00 \times 28.2)\} / 2$ 10.2 + 30.3	40.4 18.7 14.4 31.2 40.5	0.05	
		$\bar{u} = 219.2 / 202.2 = 1.08 \text{ t/m}^2$	219.2	10.7	29.0
Π ²	S G G S	(0.47 × 39.6)	17.7		
		12.7 + 9.5 4.0 + 2.9 $\{(7.0 \times 2) + (4.9 \times 1.7) + (3.0 \times 2)\} / 2$ $\{(1.60 \times 26.2)\} / 2$ 14.4 + 32.3	22.2 4.9 13.8 21.0 36.7	"	
		$\bar{u} = 116.3 / 202.2 = 0.58 \text{ t/m}^2$	116.3	5.8	32.0
Π ¹	S G G S	(0.68 × 32.6) + (0.44 × 12.0)	27.4		
		14.9 + 4.0 5.8 + 9.3 $\{(1.00 \times 2) + (2.4 \times 1.4) + (2.5 \times 2)\} / 2$ $\{(0.50 \times 16.0) + \{(2.66 \times 21.7) + (2.00 \times 9.0)\} / 2$ 13.8 + 21.0	18.9 15.1 26.9 43.5 34.8	"	
		$\bar{u} = 168.6 / 241.2 = 0.70 \text{ t/m}^2$	168.6	8.4	44.0
Π ⁰	S G G S				
		24.8 + 19.0 26.9 + 37.2	43.8 64.1	"	
			107.9	5.4	40.0



Wind Velocity in Dacca by Cyclone

$$\begin{aligned}
 V &= 120 \text{ [miles/hour]} \\
 &= 120 \times 1,609.34 / 3,600 \\
 &= 53.64
 \end{aligned}$$

Velocity Pressure

$$P = \frac{1}{2} \rho V^2$$


(ρ : Density of Air = $\frac{1}{8} \text{ kg} \cdot \text{sec}^2 / \text{m}^4$)

$$\begin{aligned}
 P &= \frac{1}{2} \times \frac{1}{8} \times 53.64^2 \\
 &= 180 \text{ [kg/m}^2\text{]}
 \end{aligned}$$


In this design above value (180 kg/m^2) is applied as the constant wind pressure for wall surface.

Coefficient of wind force

$$C = 0.9$$



$$C \times q$$




Wind Force


Wind Direction	Level	Zone	Surface Area	N	Q		
↔	RF	d					
		$\beta + \gamma$	10.36 x 1.95	20.2	$\times 0.255$ 5.2	5.2	
	4F	d					
		$\beta + \gamma$	10.36 x 2.45	25.5	$\times 0.255$ 9.1	14.3	
	3F	d	34.39 x 2.17	74.6	$\times 0.145$ 10.8	10.8	
		$\beta + \gamma$	10.36 x 1.45 18.41 x 2.17	44.4	$\times 0.145$ 6.4	20.7	
	2F	d	34.39 x 3.28	112.8	$\times 0.145$ 16.4	29.2	
		$\beta + \gamma$	13.41 x 3.28	44.0	$\times 0.145$ 6.4	27.1	
	1F	d	74.39 x 3.90	134.1	$\times 0.145$ 19.4	46.6	
		$\beta + \gamma$	13.41 x 3.90	52.3	$\times 0.145$ 7.6	34.7	
	↕	RF	$\alpha + \beta$	21.34 x 1.95	41.6	$\times 0.255$ 10.6	10.6
			γ	12.04 x 1.95	23.8	$\times 0.145$ 3.4	3.4
4F		$\alpha + \beta$	21.34 x 2.45	52.2	$\times 0.255$ 13.3	29.2	
		γ	12.04 x 2.45	29.7	$\times 0.145$ 4.3	7.4	
3F		$\alpha + \beta$	21.34 x 3.66	78.1	$\times 0.255$ 19.9	49.1	
		γ	12.04 x 1.45 7.47 x 2.17	34.0	$\times 0.145$ 4.9	14.3	
2F		$\alpha + \beta$	21.34 x 3.28	70.0	$\times 0.255$ 17.9	47.0	
		γ	12.04 x 3.28	39.0	$\times 0.145$ 5.7	28.6	
1F		$\alpha + \beta$	21.34 x 3.90	83.2	$\times 0.255$ 21.2	52.2	
		γ	12.04 x 3.90	47.1	$\times 0.145$ 6.8	34.6	

Generally
Seismic Force
> Wind Force


Direction	Level	Zone	Seismic Force	Wind Force	D				Q/ED
					Dc	Dw	Dc : Dw	Z	
↔	R _F	d	/	/					
		β+γ	26.0	82	0	2.00	0 : 100	2.00	13.0
	4 _F	d	/	/					
		β+γ	48.0	143	0	2.00	0 : 100	2.00	24.0
	3 _F	d	20.0	10.8	3.78	2.00	68 : 34	3.78	3.6
		β+γ	77.0	20.7	2.74	20.00	12 : 75	22.74	13.3
	2 _F	d	40.0	27.2	6.00	2.00	78 : 34	6.00	5.0
		β+γ	95.0	29.1	3.16	20.00	14 : 86	23.16	4.1
	1 _F	d	67.0	46.6	5.52	2.00	77 : 23	5.52	7.6
		β+γ	119.0	34.7	3.24	20.00	14 : 86	23.24	4.9
↕	R _F	d+β	16.0	10.6	3.00	5.00	29 : 71	7.00	2.3
		γ	10.0	2.4	0	5.00	0 : 100	5.00	2.0
	4 _F	d+β	34.0	29.2	1.73	5.00	26 : 74	6.73	4.4
		γ	18.0	2.4	0	5.00	0 : 100	5.00	2.6
	3 _F	d+β	66.0	49.1	5.83	15.00	28 : 72	20.83	3.2
		γ	29.0	14.3	1.02	5.00	17 : 83	6.02	4.8
	2 _F	d+β	100.0	68.0	7.14	15.00	32 : 68	20.14	4.4
		γ	35.0	23.6	1.24	5.00	20 : 80	6.24	5.6
	1 _F	d+β	$\frac{136.0}{131.6}$	38.2	4.26	15.00	22 : 78	14.26	6.8
		γ	$\frac{44.0}{37.0}$	34.6	0.66	0	100 : 0	0.66	46.1





D-Value 4th.F.



D-Value 3rd.F.




D-Value 2nd.F.





D-Value
Inflection Point

Frame	Fl	Col	D					Y				Q	h	TM	MU	ML	
			k _c	Σk _b	D			Y ₀	Y ₁	Y ₂₃	ΣY						
0	3	R'	2.01	0.98	0.194	0.088	0.178	1.00	0.00			0.00	2.3	2.978 ⁴	6.7	6.7	0
		L'	"	"	0.98	0.257	0.114	0.173	0.73	0.25		0.25	2.3	4	12.9	9.7	3.2
2	b	b	0.34	0.48	0.662	0.249	0.085	0.33	0.30 - 0.25		0.05	1.1	3.382 ⁴	3.6	3.4	0.2	
		c'	"	0.93	1.368	0.406	0.138	0.54	0.35 - 0.10		0.25	1.7	4	5.8	4.3	1.5	
		d'	"	0.96	1.412	0.414	0.141	0.55	0.35 - 0.10		0.25	1.8	4	6.0	4.5	1.5	
		g'	"	0.91	1.338	0.401	0.136	0.53	0.35 - 0.10		0.25	1.7	4	5.7	4.3	1.4	
		R'	1.72	1.21	0.392	0.150	0.257	1.00	0.40 - 0.15		0.25	3.2	4	10.8	7.6	3.2	
		L'	"	0.98	0.227	0.102	0.175	0.68	0.40		0.40	2.2	4	8.3	5.0	3.3	
1	b	b	0.14	0.93	3.321	0.624	0.087	0.27	0.55	0.10		0.65	1.2	8.377 ⁴	10.2	3.6	6.6
		c'	0.36	0.56	0.778	0.280	0.101	0.49	0.45	0.15 - 0.05		0.55	2.5	3.200 ⁴	7.9	3.6	4.4
		d'	"	0.96	1.333	0.400	0.144	0.78	0.45	0.10 - 0.05		0.50	3.5	4	11.2	5.6	5.6
		g'	"	0.91	1.264	0.387	0.139	0.76	0.45	0.10 - 0.05		0.50	3.4	4	10.9	5.5	5.4
		R'	1.82	0.82	0.225	0.101	0.184	1.00	0.55	-0.15 - 0.05		0.35	4.5	4	14.4	9.4	5.0
		L'	0.70	1.24	0.886	0.307	0.218	0.67	0.65	0.10		0.75	3.0	8.377 ⁴	29.3	6.4	18.9
G	b	b	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
		c'	0.22	2.12	4.818	0.707	0.155	0.45	0.55	0.10		0.65	3.1	5.177	15.8	5.5	10.3
		d'	"	2.54	5.773	0.743	0.163	0.47	0.55	0.10		0.65	3.2	4	16.5	5.7	10.8
		g'	"	2.42	5.500	0.733	0.161	0.46	0.55	0.10		0.65	3.1	4	16.2	5.7	10.5
		R'	1.13	2.00	0.885	0.007	0.347	1.00	0.65	0.20		0.75	6.8	4	35.2	8.8	26.4
4	2	R'	1.72	0.57	0.166	0.077	0.132	0.51	0.55	-0.25 - 0.20		0.10	2.4	3.382 ⁴	9.1	7.3	0.8
		L'	0.70	1.09	0.779	0.280	0.196	0.62	0.65			0.65	3.5	8.377 ⁴	29.3	10.2	19.1
5	G	R'	—	—	—	—	—	—	—	—	—	—	—	—	—	—	
		L'	0.22	0.95	2.159	0.519	0.114	0.33	0.55	-0.20		0.35	18.5	5.177	98.8	62.3	33.5



$$D' = 0.320$$

$$D' = \frac{1}{0.184 \left(\frac{3.200^4}{8.377^4} \right) + \frac{1}{0.164 \left(\frac{5.177^4}{8.377^4} \right)} = 0.320$$





Frame	Fl.	Col.	D					y					Q	h	TM	MU	ML
			k_c	Σk_y	Σk_x	Σk_z	Σk_t	D	Y_0	Y_1	Y_2	ΣY					
c'	2	-1	0.34	0.67	0.935	0.330	0.112	0.42	0.35	-0.20		0.15	1.5	3382 ^B	5.1	4.3	0.8
	1	+	0.36	0.67	0.931	0.318	0.114	0.67	0.45	0.20	-0.05	0.60	3.4	3,200 ^A	10.7	4.3	6.4
	G	+	0.72	1.34	4.114	0.673	0.148	0.78	0.55	0.05		0.60	5.9	5,177	50.7	12.3	18.4
d'	2	-1	0.34	0.67	0.935	0.330	0.112	0.42	0.35	-0.20		0.15	1.3	3382 ^B	4.5	3.8	0.7
	1	+	0.36	0.67	0.931	0.318	0.114	0.67	0.45	0.20	-0.05	0.60	2.9	3,200 ^A	9.3	3.7	0.6
	G	+	0.72	1.34	4.114	0.673	0.148	0.78	0.55	0.05		0.60	5.5	5,177	28.7	11.5	17.2
e'	2	-1	0.34	0.67	0.935	0.330	0.112	0.42	0.35	-0.20		0.10	1.2	3382 ^B	3.9	3.5	0.4
	1	+	0.36	0.67	0.931	0.318	0.114	0.67	0.45	0.20	-0.05	0.60	2.6	3,200 ^A	8.2	3.3	4.9
	G	+	0.72	1.34	4.114	0.673	0.148	0.78	0.55	0.05		0.60	4.2	5,177	26.8	10.7	16.1
f'	2	-1	0.34	0.67	0.935	0.330	0.112	0.42	0.35	-0.20		0.35	1.5	3382 ^B	5.0	3.3	1.7
	1	+	0.36	0.67	0.931	0.318	0.114	0.67	0.45	0.20	-0.05	0.40	3.3	3,200 ^A	10.4	5.2	5.2
	G	+	0.72	1.34	4.114	0.673	0.148	0.78	0.55	0.05		0.60	4.8	5,177	24.8	9.9	14.9
g'	2	-1	0.34	0.67	0.935	0.330	0.112	0.42	0.35	-0.20		0.35	1.3	3382 ^B	4.5	2.9	1.6
	1	+	0.36	0.67	0.931	0.318	0.114	0.67	0.45	0.20	-0.05	0.40	3.0	3,200 ^A	9.4	5.6	3.8
	G	+	0.72	1.34	4.114	0.673	0.148	0.78	0.55	0.05		0.60	4.9	5,177	23.2	9.3	13.9
h'	2	-1	0.34	0.67	0.935	0.330	0.112	0.42	0.35	-0.20		0.25	1.2	3382 ^B	4.1	3.1	1.0
	0'	+	1.72	1.24	0.369	0.196	0.268	1.00	0.40	-0.25		0.75	3.3	1	11.2	9.5	1.7
	4'	+	1.72	1.17	0.340	0.145	0.250	0.93	0.40	-0.25		0.75	3.1	+	10.4	8.8	1.6
	5'	+	0.34	0.67	0.935	0.330	0.112	0.42	0.35	-0.20		0.30	1.5	+	4.9	3.4	1.4
i'	1	-1	0.36	0.67	0.931	0.318	0.114	0.67	0.45	0.20	-0.05	0.40	3.0	3,200 ^A	9.4	5.6	3.8
	0'	+	1.82	+	0.206	0.093	0.170	1.00	0.40	-0.05	0.45	4.1	+	13.1	7.2	5.9	
	4'	+	1.82	0.60	0.165	0.076	0.139	0.82	0.50	-0.05	0.45	3.4	+	10.8	6.0	4.8	
	5'	+	0.36	+	0.933	0.294	0.106	0.62	0.45	-0.05	0.40	2.5	+	8.1	5.8	3.3	
j'	G	-1	0.72	0.67	0.935	0.673	0.148	0.78	0.55	0.05		0.60	2.9	5,177	15.0	6.0	9.0
	0'	+	1.13	+	0.403	0.168	0.189	1.00	0.45	0.10		0.25	4.9	+	25.4	3.8	21.6
	4'	+	1.13	1.00	0.442	0.181	0.205	1.08	0.45	0.10		0.25	4.3	+	23.4	4.1	23.7
	5'	+	0.72	+	2.273	0.532	0.117	0.62	0.55	0.05		0.60	3.0	+	15.7	6.3	9.4

STRESS OF BEARING WALL


Direction	Frame	Fl.	Span	D	STRESS					
					Q	R	M	L	N	ΣN
↔	L'	4'	-1 ~ 4'	1.0	13.0	2895 ⁶	37.6	32.613 ⁶	1.2	1.2
		3	"	"	24.0	3932 ⁴	94.4	"	2.9	41.933
		2	-1 ~ 4'	20.0	66.0	3382 ⁸	223.3	40.233 ⁶	5.9	8.8
		1	"	"	82.0	3200 ⁴	267.4	"	6.5	15.3
	b	2	-1 ~ 0'	2.0	7.2	3382 ⁸	24.4	4.267 ²	5.7	5.7
		1	"	"	10.0	3200 ⁴	32.0	"	4.4	13.2
		6	"	"	15.2	5.177	78.7	"	10.4	31.6
↕	-1	2	b ~ c'	3.0	9.6	3382 ⁸	32.5	6.350	5.1	5.1
		1	"	"	13.4	3200 ⁴	43.2	"	6.8	11.9
		6	"	"	20.4	5.177	105.6	"	16.6	28.5
	4'	4'	b' ~ L'	5.0	11.5	2895 ⁶	33.3	9.753 ⁶	3.4	3.4
		3	"	"	22.5	3932 ⁴	88.4	"	9.1	124.54
		2	f' ~ L'	12.0	38.4	3382 ⁸	129.9	22.44 ²	5.8	58.112
		1	"	"	54.0	3200 ⁴	172.8	"	7.7	13.4-18.9
	4'	4'	b' ~ L'	5.0	10.0	2895 ⁶	29.0	9.753 ⁶	3.0	3.0
		3	"	"	18.0	3.932 ⁸	70.8	"	7.3	10.3
	5'	2	b' ~ L'	5.0	24.0	3382 ⁸	81.2	2.753 ⁶	8.3	8.3
		1	"	"	78.0	3200 ⁴	89.6	"	9.2	17.5

FRAME STRESS FOR SEISMIC FORCE






① 9.448² ② 29.164² ③ 7.628 ④ 12.3 ⑤ 12.3




① 9.448² ② 5.791² ③ 5.791² ④ 7.628 ⑤ 12.3

① FRAME




④ 9,7836 ②

④ FRAME



⑤ 9,7836 ②

⑤ FRAME



⑤ 9,7836 ②

3- DESIGN OF FOUNDATION

Information on Pile - Cast in situ - Works in Dacca

In this project Pile works are used for foundation.

To keep the existing building free from the effect of vibration during piling, cast in situ should be used.


(In previous works, also cast in situ piles were used.)

*

Information on cast in situ which was collected by the 2nd survey team is as follows.


Geological Data


Typical Bore Chart in Dacca



Bore Chart


(According to
"30.7.77 - Preliminary Report"
by "Foundation Consultant, Dacca")






ϕ		n	n''	Usual Design Capacity	L max from G.L.
12"	304 ^{MM}	5 - 5/8" ϕ 4-16 ϕ	1/2" ϕ 6 ϕ @ C' @ 150		20' 24,384 ^{MM}
14	355 ⁶	" "	" "	60 $\frac{t}{\text{ft}}$	" "
16	406 ⁴	6 - 7/8" ϕ 6-16 ϕ	" "	70 "	" "
18	457 ²	6 - 3/4" ϕ 6-19 ϕ	3/8" ϕ 9 ϕ @ C' @ 150	75 "	" "
20	508 ⁸	7 - 3/4" ϕ 7-19 ϕ	" "	80 - 85 "	100' 30,480 ^{MM}
22	559 ⁸	8 - 7/8" ϕ 8-19 ϕ	" "	90 - 95 "	" "
24	609 ⁶	" "	1/2" ϕ 13 ϕ @ C' @ 150	100 - 110 "	120' 36,576 ^{MM}
30	762 ⁸	10 - 7/8" ϕ 10-19 ϕ	" "	105 - 120 "	" "
36	914 ^{MM}	12 - 1" ϕ 12-20 ϕ	" "	130 "	" "
12" ~ 14" = Unusual		Reinf. Ratio 1% $\geq P_g \geq 4\%$		$N \geq 50$ $F_s = 3$	Slender Ratio $80 \geq \frac{L}{\phi}$

Pile layout in Footing





Data on Existing Foundation



$$\begin{aligned}
 l' &= 12' = 304.8 \text{ MM} \\
 l'' &= 25.4 \text{ MM}
 \end{aligned}$$

General Note on Existing Footing and Pile




- Main Reinforcement of Pile
 4-11 ϕ ($\frac{7}{8}$ " ϕ) for 385.6 ϕ (14 ϕ)
 7-11 ϕ ($\frac{7}{8}$ " ϕ) for 406.4 ϕ (16 ϕ)
- Spiral Hoop
 6 ϕ ($\frac{1}{2}$ " ϕ) @ 180 (6") ϕ /c

Bearing Capacity of Pile

385.6 ϕ	40 t / Each
406.4 ϕ	80 t / Each


Data on Existing Footing

F1B




File 4-406.4φ (16"φ)
 Each 16-19φ (3/4"φ) @ 180 (6") %

F2A




File 3-388.6φ (16"φ)
 Each 7-19φ (3/4"φ) @ 180 (6") %

F3B



File 3-406.4φ (16"φ)
 Each 8-19φ (3/4"φ) @ 180 (6") %

F2A



File 2-388.6φ (16"φ)
 8-19φ (3/4"φ)
 12-19φ (3/4"φ)

$$\left(\begin{array}{l} 1' - 12" = 304.8 \text{ MM} \\ 1" = 25.4 \text{ MM} \end{array} \right)$$

Design Capacity of Pile

$$\begin{aligned}
 R &= \frac{1}{3} \left\{ 15 \bar{N}_A P + \left(\frac{N S L^3}{4} + 2 N c L c \right) \psi \right\} - W \\
 &= \frac{1}{3} \left\{ 15 \times 40 \times \frac{\pi \times 0.4064^2}{4} + \left(\frac{2.144 \times 10}{4} + 2 \times 9.144 \times \pi \right) \pi \times 0.4064 \right\} - W \\
 &= \frac{1}{3} \left\{ 77.83 + (18.288 + 91.440) \times 1.276 \right\} - W \\
 &= \frac{1}{3} \left\{ 77.83 + 140.09 \right\} - W \\
 &= 77.64 - W \\
 &\quad \downarrow \\
 &= 70 \text{ t/pile} - \text{Self Load}
 \end{aligned}$$

Footing Dead Load

$$48'' \times 48'' \times 60'' \times 2 \frac{\text{t}}{\text{m}^3} = 1.219^2 \times 1.924 \times 2 = 4.5 \text{ t/pile}$$

Pile Self Load

$$\frac{\pi \times 16''^2}{4} \times 60' \times 2.4 \frac{\text{t}}{\text{m}^3} = \frac{\pi \times 0.4064^2}{4} \times 18.288 \times 2.4 = 5.7 \text{ t/pile}$$


Slender Ratio

$$\frac{60'}{16''} = 43$$


Net Capacity


$$70 - (4.5 + 5.7) \rightarrow 40 \text{ t/pile}$$

DECISION OF PILE NUMBERS




Pile Layout Plan





S = Anchoring 609.6 (2'-0")
 C = Covering 76.2 (3'-0")



6 - 7/8" (16) ϕ
 3/8" (9) ϕ @ 4" (100) ϕ

$$N = 40t$$

$$H = \Sigma N \times E \times 0.005$$

$$= 4004 \times 0.005$$

$$= 229.7t$$

$$\Delta H = 229.7 / 130$$

$$= 1.8t$$

General Note of Material

Cast In Situ
 406 ϕ (16 ϕ) ϕ
 Design Capacity = 40t/pile

Reinforcement

M.S. Bar (F = 33,000 P.S.I.)
 = 2,400 $\frac{lb}{in^2}$

Concrete

Stone Coarse Aggregate
 (28FC = 3,000 P.S.I. = 210 $\frac{lb}{cm^2}$)

Footings

Reinforcement

JIS Standard SD35

Concrete

Brick Coarse Aggregate
 (28FC = 2,600 P.S.I. = 180 $\frac{lb}{cm^2}$)

$$1 \text{ P.S.I.} = 0.07030 \text{ } \frac{lb}{cm^2} = 7.03 \text{ } \frac{lb}{cm^2}$$

Check on Horizontal Load for Pile

Vertical Load

$$N = 40 \text{ t}$$

Horizontal Load

$$SN = 4,894 \text{ t}$$

$$k_H = 0.05 \text{ (Horizontal Load Coefficient)}$$

$$H = 4,894 \times 0.05 = 229.7 \text{ t}$$

$$S_H = 131 \text{ piles}$$

$$\Delta H = 229.7 / 131 = 1.77 \text{ t/pile}$$

$$k_H = 2.00 \quad \text{*} \quad \text{: lateral direction coefficient of ground (t/cm}^3\text{)}$$

(For N Value = 5)

$$D = 40.64 \quad \text{: Diameter of Pile (cm)}$$

$$E = 1.99 \times 10^5 \quad \text{: Young Modulus (t/cm}^2\text{)}$$

$$I = \frac{\pi \times 40.64^4}{64} \quad \text{: Moment of Inertia (cm}^4\text{)}$$

$$= 133,901$$

$$\beta = \sqrt[4]{\frac{k_H \cdot D}{48I}} = 0.004258 \text{ (cm}^{-1}\text{)} \quad \sim \quad l = 60 = 1823.8 \text{ (cm)} \quad \sim \quad \beta l = 9.6$$

PILE TOP Displacement

$$y = 0.5 \times \frac{\Delta H}{E I \beta^3} = 0.5 \times \frac{1770}{1.99 \times 10^5 \times 133,901 \times 0.004258^3}$$

$$= 0.23 \text{ (cm)}$$

Level of Max. Moment

$$z = 0.3 \times \frac{1}{\beta} = 152.2 \text{ (cm)}$$

Max. Moment

$$M = 0.3 \times \frac{\Delta H}{\beta} = 0.3 \times \frac{1.770}{0.004258}$$

$$= 99,908 \text{ (t-cm)}$$

$$= 1.00 \text{ (tm)}$$

*

$$N = 40,000 \text{ (Kg)}$$

$$M = 99,908 \text{ (Kgcm)}$$

$$D = 40.64 \text{ (cm)}$$

$$\frac{N}{D^3} = 24.219$$

$$\frac{M}{D^3} = 1.488$$



According to Circle Column Design Chart

Main Bar $f_c = 140 \rightarrow 120 \text{ (Kg/cm}^2)$
 $r_{fc} = 15 \times 120 = 1800 \text{ ()}$
 $f_t = 2,320 \text{ ()}$



$$\left. \begin{aligned} \frac{N}{D^3 f_c} &= 0.20 \\ \frac{M}{D^3 f_c} &= 0.012 \end{aligned} \right\} P_g = 0\%$$

$$\left. \begin{aligned} \frac{N}{D^3 r_{fc}} &= 0.013 \\ \frac{M}{D^3 r_{fc}} &= 0.0008 \end{aligned} \right\} P_g = 0$$

$$\left. \begin{aligned} \frac{N}{D^3 f_t} &= 0.010 \\ \frac{M}{D^3 f_t} &= 0.0006 \end{aligned} \right\} P_g = 0$$

$$P_{g \text{ min}} = 0.4\% \sim 2.0\%$$

$$a_g = 3.12 \text{ cm}^2 \sim 12.97 \text{ cm}^2$$

Designed _____ $6 - \frac{5}{8} \text{ (16)} \phi$
 $(1.974 \times 6 = 11.84 \text{ cm}^2)$

*

Spiral Tie

$$p_w = 0.2\%$$

$$\frac{3}{8} \text{ (9)} \phi$$


$$a_s = 0.7126 \text{ cm}^2$$

$$P = \frac{0.7126 \times 2}{40.64 \times 0.002}$$

$$= 17.53 \text{ cm}$$

Designed _____ $\frac{3}{8} \text{ (9)} \phi$
 $@ 6" (150)$

Design of Footing



e : Clearance $1,219^2$ (4'-0")

p : Pitch 609^6 (2'-0")

Material

Reinforcement : JIS Standard SD35

f_t (Tension) $2,200 \text{ kg/cm}^2$

f_b (Bond) 18 *

Concrete : 28FC = 2,600 P.S.I. = 180 kg/cm^2

f_s (Shear) 6 kg/cm^2

f_p (Punching) 15 *

MINIMUM Depth for Punching

$$\frac{R}{\pi \psi d} < f_p \sim d > \frac{R}{\pi \psi f_p}$$


$$= \frac{40,000}{\pi \times 40.64 \times 18}$$

$$= 209 \text{ cm}$$

$$\sim$$

$$D = 3'-0"$$

$$= 91.44 \text{ cm}$$



ALLOWABLE STRESS INTENSITY

SD 35

$$f_t = 2.2 \text{ [t/cm}^2\text{]}$$


$$f_b = 19.0 \text{ [t/cm}^2\text{]}$$

Fc 180

$$f_s = 6.0 \text{ "}$$

$$\left[\begin{array}{l} \text{CASE-2} \\ \text{M/S-BAR } f_t = 1.26 \text{ [t/cm}^2\text{]} \\ f_b = 10.8 \text{ [t/cm}^2\text{]} \end{array} \right]$$

F12



$$D \text{ 213.36 } d \text{ 197.2 } j \text{ 172.5 } B \text{ 243.84}$$

$$Q_F = 40 \times 6 = 240 \text{ t}$$

$$M_F = 240 \times (1.219 \times 1.5 - 0.45) = 330.9 \text{ tM}$$

$$Q = 177.3 \text{ GAL } 257.4 \text{ t}$$

$$\alpha = 97.2$$


$$\uparrow 23 \sim 12 - D22 \text{ (@ } 100 \sim 200 \text{)}$$

$$[\varphi 128.8 \sim 64.4, \alpha = 171.6]$$

$$\leftarrow 29 - D16 \text{ (@ } 250 \text{)}$$

$$[29 - 7/8"]$$

F9



$$D \text{ 121.92 } d \text{ 103.8 } j \text{ 90.8 } 2D+A \text{ 268.6}$$

$$Q_F = 40 \times 2 = 80$$

$$M_F = 80 (1.219^2 - 0.30) = 73.5$$

$$Q = 48.9 \text{ GAL } 146.3$$


$$\alpha = 36.8$$

$$[\varphi 81.6, \alpha = 64.0]$$

$$\uparrow 15 - D19 \text{ (@ } 250 \text{)}$$

$$[23 - 3/4"]$$

F8



$$D \text{ 152.40 } d \text{ 136.2 } j \text{ 119.2 } B \text{ 243.84}$$

$$Q_F = 40 \times 4 = 160$$

$$M_F = 160 (1.219 - 0.45) = 123.6$$

$$Q = 74.6 \text{ GAL } 174.4$$

$$\alpha = 46.7$$

$$[\varphi 124.3 \sim 62.2, \alpha = 81.6 \sim 32.3]$$


$$\uparrow 19 - D19 \text{ (@ } 125 \text{)}$$

$$[23 - 7/8"]$$

$$\leftarrow 20 - D16 \text{ (@ } 250 \text{)}$$

$$[20 - 5/8"]$$

F7



D 421.92 d 1038 j 90.8 ZD+a 268.6

$$QF = 40.0 + 2 \times 40.0 \times 0.37$$

$$= 40.0 + 29.6$$

$$= 69.6 \quad \varphi 42.6 \text{ GAL } 146.3$$

$$MF = 40.0 (1.219^2 - 0.3) + 29.6 (0.609^2 - 0.3)$$

$$= 36.8 + 9.2$$

$$= 46.0 \quad \alpha 23.0 \text{ [} \alpha 40.0 \text{]}$$


13 - D19 (@250) [23 - 3/4"]

$$QF = 2 \times 40.0 \times 0.74 = 59.2 \quad \varphi 36.2 \text{ GAL } 146.3$$

$$MF = 59.2 (1.066^2 - 0.3) = 45.4 \quad \alpha 22.7$$

15 - D19 (@250) [\varphi 60.4, \alpha 39.7, 23 - 3/4"]

F6



D 41.44 d 75.24 j 65.8 ZD+a 211.4

$$QF = 2 \times 40.0 = 80.0 \quad \varphi 67.7 \text{ GAL } 83.7$$

$$MF = 80.0 (1.219^2 - 0.3) = 73.7 \quad \alpha 50.8$$


19 - D19 (@125) [\varphi 112.6, \alpha 85.3, 31 - 3/4"]

$$QF = 40.0 \quad \varphi 33.8 \text{ GAL } 83.7$$

$$MF = 40.0 (0.609^2 - 0.3) = 12.9 \quad \alpha 8.7$$

15 - D16 (@250) [\varphi 56.3, \alpha 15.7, 15 - 5/8"]

F5



D 41.44 d 75.24 j 65.8 ZD+a 211.4


$$QF = 2 \times 40.0 = 80.0 \quad \varphi 67.7 \text{ GAL } 83.5$$

$$MF = 80.0 (1.066^2 - 0.3) = 61.3 \quad \alpha 42.3$$

16 - D19 (@150) [\varphi 112.6, \alpha 73.6, 19 - 7/8"]

13 - D16 (@250) [13 - 7/8"]

F4




D 91.44 d 73.34 \bar{z} 64.2 2D+a 207.6

QF = 40.0 Φ 34.6 QAL 80.0
 MF = 40.0 (0.609 - 0.3) = 12.4 α 8.8

4 10-D16 (@250)
 [Φ 17.7, α 15.3, 12-5/8"]

F3




D 91.44 d 71.44 \bar{z} 62.5 B 109.6 min.

QF = 40.0 Φ 35.6 QAL 39.6
 MF = 40.0 (0.7112 - 0.3) = 16.5 α 12.0

* 17-D16 (@150) + 2-D16
 [Φ 19.3, α 20.9, 10-3/4"]

$\alpha = 10.66^\circ$


F1



D 91.44

4 6-D16 (@200)
 [6-5/8"]

4 - DESIGN OF BEAM



BEAM MARK KEYPLAN

	STRESS			C	P _t	γ	st	D			
	V	H	I							GA	a
G 10A	M								35 70 85 14.25 0.8	10.8	
	Q										
G 6B	M								35 70 70 61.25 0.8	9.7	
	Q										
G 10C	M								35 60 55 48.13 0.8	6.6	
	Q										
G 6C	M								35 45 40 35.00 0.8	5.5	
	Q										
G	M										
	Q										
G	M										
	Q										

	STRESS			C	P	T	R	R	SECTION	
	V	H	T							GA
UDR	M								UDR 35 30 25 20	
UDR	M								UDR	
UDR	M	C	23.5	6.7					UDR	
		C	14.9							
UDR	M	C	23.5	6.7					UDR	
		C	17.6	1.4	182	0				
UDR	M								UDR	
UDR	M								UDR	
UDR	M								UDR	

	STRESS			C P t γ at n				SECTION																																																																																																																									
	V	H	T	Q _A	α	ΔQ	PW		φ																																																																																																																								
G ₁	M																																																																																																																																
	Q										G ₂	M										Q								G ₃	B	25.0	0.4				15.3				C	13.3					3.1		D	25.3	4.7				13.3		G ₄	Q	19.6	2.3	18.2	0						M								G ₅	M										Q								G ₆	M										Q								G ₇	M										Q				
G ₂	M																																																																																																																																
	Q										G ₃	B	25.0	0.4				15.3				C	13.3					3.1			D	25.3	4.7				13.3				G ₄	Q	19.6	2.3	18.2	0						M								G ₅	M										Q								G ₆	M										Q								G ₇	M										Q																				
G ₃	B	25.0	0.4				15.3																																																																																																																										
	C	13.3					3.1																																																																																																																										
	D	25.3	4.7				13.3																																																																																																																										
G ₄	Q	19.6	2.3	18.2	0																																																																																																																												
	M										G ₅	M										Q								G ₆	M										Q								G ₇	M										Q																																																																					
G ₅	M																																																																																																																																
	Q										G ₆	M										Q								G ₇	M										Q																																																																																								
G ₆	M																																																																																																																																
	Q										G ₇	M										Q																																																																																																											
G ₇	M																																																																																																																																
	Q																																																																																																																																

	STRESS				C P t r at n				SECTION			
		V	H	T	GA	α	ΔQ	Pw		P		
3 G 1	M	-1	25 44	43 25	23			17		L.R.D.D	35 35 35 0.75	
		C	26 5.0					17				
		0	10.3 11.9	43 25				17				
			72-84	20 13		12.9	0		11.4			
3 G 2	M	-1	67 19.5	33 2.9				14.7		L.R.D.D	35 35 35	
		C	74 22.3					14.7				
		0	14.3 24.4	33 2.9				14.6				
			74-112	47 0.7		12.9	1.38	2.0	0.027	26.9		
3 G 3	M	-1								L.R.D.D	35 35 35 7.5	
		C										
		0										
4 G 3	M	4'	26.7	0.0				16.3		L.R.D.D	35 35 35	
		C	19.7					12.0				
		5'	4.7	3.4				17.4				
			14.9	1.6		14.6	0		16.7			
3 G 4	M	-1								L.R.D.D	40 30 35 0.4	
		C										
		0										
3 G 5	M	b	24	24				15		L.R.D.D	35 35 35 0.75	
		C	14					15				
		f	26	23				15				
			12	0.9		12.9	0		11			

		STRESS			C P _t γ at II				SECTION		
		V	H	T	Q _A	Q _B	Q _C	Q _D		P	
7 G ₃	M	3'	14.4	2.3				10.7		J.D.D. 35 75 70 61.5	
		c	13					6.9			
		2'	16.3	6.1				12.1			
	Q	12.4	1.2								
9 G ₃	M	2'	20.1	4.8				16.0		J.D.D. 35 40 55 44.5 0.4 10.8	
		c	13.4					9.2			
		2'	21.9	9.2				14.6			
	Q	13.8	1.5		15.6	1.47	0	14.4			
4 G ₃	M	/								J.D.D.	
	Q	/									
G	M	/								J.D.D.	
	Q	/									
G	M	/								J.D.D.	
	Q	/									
G	M	/								J.D.D.	
	Q	/									

	STRESS			C	P _t	γ	m	D	SECTION					
	V	H	T							Q _A	α	ΔQ	P _w	ρ
2 G 1	M	-1	45-72	5.1	37			13.0	1.09	0	15.2		b 35 45 40 35	
		C	4.3								3.6			
		0	63-86	5.1	37			14.4	2.17	0	30.4			
	Q	57-68	2.4	1.4			7.4		0		16.4			35
2 G 2	M	-1	75-89	6.7	72			15.1	0.93	0.75	20.3		b 35 75 70 61.25	
		0	15.5							11.5				
		C	113-218	6.7	72			16.2	1.24	0.4	30.4			
	Q	86-120	1.9	1.7			12.7	1.25	1.7	0.0027	24.8			35
2 G 3	M	-1	32.0	6.6				15.0	1.02	0.8	30.4		b 35 90 85 14.38	
		C	37.8							22.9				
		0	32.0	8.9				20.6	1.36	0.9	40.6			
	Q	31.2	4.6				15.6	1.36	10.0	0.0058	35.0			35
2 G 4	M	4'	3.9	7.6	11.5						4.4		b 35 1.4	
		C	2.5							1.5				
		4'	4.9	7.3	7.2					3.8	2.1			
	Q	3.2	2.0	7.2										35
2 G 5	M												b 35	
		Q												
2 G 6	M	b	17.4	3.8									b 35 45 40 35	
		C	5.6							7.3				
		f	8.6	3.6				14.4	1.09	0.4	14.2			
	Q	6.7	1.2				7.4		0		16.0			35

	STRESS			C P _t γ at n				SECTION	
	V	H	T	Q _A	α	ΔQ	P _w		ρ
G ₂ 7	M	10.8	2.6						
	C	8.3							
	E'	8.2	2.1	14.6			14.2		
	Q	5.4	1.2	7.4	1.0	1.0	0.0625	20.0	
G ₂ 8	M	24.7	10.5						
	C	14.5							
	E'	25.2	9.7						
	Q	17.8	2.1	15.6	1.02	0		19.9	
G ₂ 9	M	24.8	11.0						
	C	15.8							
	Q	14.1	1.5	15.6		0		15.8	
G	M	209 Torsion M _T (from CSI) = 0.88 $\frac{1}{2} \times 2.1 \times 36 \text{ m} / 2$ = 2.68 tm $\psi_0 = 2(80 + 32) = 210 \text{ cm}$ $A_0 = 80 \times 28 = 2,240 \text{ cm}^2$							
	Q	$Q_A = \frac{M_T \psi_0}{2 A_0}$ $= \frac{2.68 \times 210}{2 \times 28 \times 2,240}$ $= 7.0 \rightarrow 4-16$ $P_w = \frac{M_T}{2 A_0} + 0.02$ $= \frac{2.68}{2 \times 28 \times 2,240} + 0.02$ $= 0.00296$							
G	M	$Q_A = \frac{M_T \psi_0}{2 A_0}$ $= \frac{2.68 \times 210}{2 \times 28 \times 2,240}$ $= 7.0 \rightarrow 4-16$ $P_w = \frac{M_T}{2 A_0} + 0.02$ $= \frac{2.68}{2 \times 28 \times 2,240} + 0.02$ $= 0.00296$							
	Q	$Q_A = \frac{M_T \psi_0}{2 A_0}$ $= \frac{2.68 \times 210}{2 \times 28 \times 2,240}$ $= 7.0 \rightarrow 4-16$ $P_w = \frac{M_T}{2 A_0} + 0.02$ $= \frac{2.68}{2 \times 28 \times 2,240} + 0.02$ $= 0.00296$							
G	M	$Q_A = \frac{M_T \psi_0}{2 A_0}$ $= \frac{2.68 \times 210}{2 \times 28 \times 2,240}$ $= 7.0 \rightarrow 4-16$ $P_w = \frac{M_T}{2 A_0} + 0.02$ $= \frac{2.68}{2 \times 28 \times 2,240} + 0.02$ $= 0.00296$							
	Q	$Q_A = \frac{M_T \psi_0}{2 A_0}$ $= \frac{2.68 \times 210}{2 \times 28 \times 2,240}$ $= 7.0 \rightarrow 4-16$ $P_w = \frac{M_T}{2 A_0} + 0.02$ $= \frac{2.68}{2 \times 28 \times 2,240} + 0.02$ $= 0.00296$							

	STRESS			C P _t γ at B				SECTION		
	V	H	T	Q _A	α	ΔQ	P _w		ρ	
1-G	M	-1	30.47	12.7	12.7		10.1	J.D.D.	 35	
		C	29	9.2	9.2		8.3			
		0	21.14	18.0	18.0		17.0			
	Q	45.71	19.3	19.3	1.13	1.4	0.0027	21.2	 35	
1-G	M	-1	14.7	21.6	21.6	1.66	0.48	40.6	J.D.D.	 35
		0	15.2	18.7	18.7					
		C	15.2	24.0	24.0	1.66	1.0	40.6		
	Q	14.1	12.4	12.4	1.40	1.17	0.0084	43.5	 35	
1-G	M	-1	31.8	12.6	12.6		14.4	J.D.D.	 35	
		C	28.6	17.4	17.4					
		0	42.4	16.8	16.8	1.02	0.8			30.4
	Q	24.8	17.6	17.6	1.16	4.5	0.0037	28.9	 35	
1-G	M	-1	7.0	15.6	15.6		2.7	J.D.D.	 35	
		C	14	4.3	4.3					
		0	16.2	2.9	2.9					
	Q	5.3	15.6	15.6			0	6.8	 35	
1-G	M	-1	10.2	12.9	12.9		7.0	J.D.D.	 35	
		C	10.2	9.4	9.4					
		0	10.2	9.4	9.4					
	Q	10.2	12.9	12.9			0	10.2	 35	
1-G	M	-1	13.4	11.6	11.6		9.2	J.D.D.	 35	
		C	13.4	9.2	9.2					
		0	13.4	11.2	11.2					
	Q	13.4	11.6	11.6			0	11.6	 35	

() = CASE 2, $M\frac{1}{2}$ -BAR, UNLESS NOTED SAME TO CASE 1

	STRESS			C					SECTION		
	V	H	I	GA	α	ΔQ	Pw	ρ			
1-GT	M	E	1.0-1.7	17.5-16.1	19.4			5.7 (11.2)	b D j	35.56 121.92 111.92 97.73	
		C	9.1		17.4			5.1 (10.6)			
	Q	2.8-3.5	6.1-6.1	20.0	31.3		0	17.0 (15.9)			
2-GT	M	E	5.6-11.9	14.9-13.9	25.8			7.5 (15.5)	b D j	7.5 (15.6)	
		C	16.2		9.3			7.5			
	Q	7.9	4.1-3.3	16.1	31.3		0	17.7 (17.2)			
3-GT	M	-I	6.3	9.0	15.3			7.1 (4.3)	b D j	1.8 (1.6)	
		C	3.9		2.7			9.0 (18.6)			
	Q	9.1	21.6	30.7	31.3		0	3.6 (11.2)			
4-GT	M	4)	3.1	23.3	26.4			11.7 (16.0)	b D j	3.2 (4.6)	
		C	6.9		20.2			7.9 (12.3)			
	Q	1.8	9.4	7.6	31.3		0	11.2 (12.5)			
5-GT	M	b	1.5	6.6	7.1			3.1 (4.1)	b D j	1.2 (2.9)	
		C	2.6		5.1			2.9 (6.0)			
	Q	4.5	5.4	9.9	31.3		0	6.6 (9.6)			
7-GT	M	8)	3.4	3.5	8.9			2.6 (5.7)	b D j	0.7 (1.3)	
		C	1.5		2.1			8.4 (17.7)			
	Q	6.5	15.6	22.1	31.3		0	4.4 (9.6)			







	STRESS			C	P	γ	m	D	SECTION	
	V	H	I							QA
F 8	M	E'	3.1	10.8				4.1 (8.4)	J A D D	
		C	1.1					2.2 (4.4)		
		C'	6.6	18.9	25.4 12.4			0.5 7.4 (15.4) 3.6 (7.2)		
	Q	4.0	3.0	10.0	31.3	0		8.5 (17.0)		
F 9	M	E'	9.9	19.1				7.9 (15.8)	J A D D	
		C	3.6					3.3 (6.6)		
		C'	5.7	19.1	24.8 13.4			3.2 7.7 (15.4) 3.9 (7.8)		
	Q	4.3	1.5	8.3	31.3	0		7.1 (14.2)		
F 10C	M	E	6.6	33.6				11.6 (23.2)	J A D D	
		C	5.8					2.7		
		C'			40.1 26.9					
	Q	5.1	6.9	18.9	31.3	0		16.1 (32.2)		
G	M								J A D D	
	Q									
G	M								J A D D	
	Q									
G	M								J A D D	
	Q									

5. — DESIGN OF COLUMN


() = CASE 2, $\frac{1}{8}$ BAR, UNLESS NOTED SAME TO CASE 1.

		STRESS			N/BD M/902 1/8 in				SECTION	
		V	H	T	QA	ΔQ	Pw	P		
20' c'0'	X	N	39.4	2.0	41.4 37.4	17.3 26.0	0	60	Pg 0.3 Pg 28.8 48.125	
		M	-4.0	4.3	0.0					
		U	-3.6	0.8	2.8 4.4					
	Y	Q	2.3	1.9	5.3	//	0	60		
		N	39.4	0.2	39.6 39.2					
		M	-5.9	4.3	10.2 1.7					
10' c'0'	X	N	80.3	4.4	84.7 77.9	//	0	60		
		M	-3.7	4.3	0.6 8.0					
		U	-4.2	6.4	2.2 10.6					
	Y	Q	2.5	3.4	5.3	//	0	60		
		N	80.3	0.2	80.5 80.1					
		M	1.7	3.6	5.3 1.9					
8' c'0'	X	N	131.5	13.2	144.7 118.3	40.2 32.9	8.2 8.8	60		
		M	-1.5	12.3	10.8 13.8					
		U	-0.6	18.4	17.8 19.0					
	Y	Q	0.4	5.9	12.2	//	0	60		
		N	131.5	2.4	133.9 129.1					
		M	1.9	5.5	7.4 3.6					
20' 8'0'	X	N	70.7	0.7	71.4 70.0	17.3 26.0	0	60		
		M	11.4	2.9	14.3 2.5					
		U	5.8	1.6	7.4 4.2					
	Y	Q	5.1	1.3	7.7	//	//	60		
		N	70.7	0.4	71.1 70.3					
		M	0.3	4.3	4.6 4.0					
10' c'0'	X	N	123.7	2.4	126.0 121.2	34.3	6.4 0.5 18.0 (0.65) (23.4)	60		
		M	7.6	5.6	13.2 2.0					
		U	13.8	3.8	17.6 10.0					
	Y	Q	5.7	3.0	12.7	//	//	60		
		N	123.6	0.1	123.7 123.5					
		M	1.8	5.4	7.3 3.7					
8' c'0'	X	N	182.1	5.5	187.6 176.6	//	//	60		
		M	9.3	9.3	18.6 0					
		U	9.3	13.9	23.2 4.6					
	Y	Q	3.6	4.9	13.4	//	//	60		
		N	182.1	0.9	183.0 181.2					
		M	0.5	5.7	6.2 3.2					
		U	0.2	10.5	10.7 10.3	//	//	60		
		Q	0.1	3.1	6.3					

		STRESS			N/BD M/BD ² Ft at				SECTION		
		V	H	T	Q _A	ΔQ	Pw	φ			
4C (1')	X	N							JOB	 90 60 16-072 (16-7/8")	
		M									
		U									
	Y	N	46.9	0		8.7					60 Pg 0.8 90 Qg 43.2 74.375
		M	25.4	0			5.2	0.12 (0.2) 5.5 (10.8)			
		U	8.7	0		26.8 40.2	0				
4C 8'0"	X	N						JOB	 90 90 20-072 (20-7/8")		
		M									
		U									
	Y	N	96.6	1.4	98.0 98.2	11.9					90 Pg 0.8 90 Qg 64.8 74.375
		M	23.5	6.7	30.2 15.8		3.2			0 (0)	
		U	17.6	0	17.6	48.2 60.2	0				
3C	X	N						JOB	 90 90		
		M									
		U									
	Y	N	210.5	3.7	214.2 206.5						
		M	7.4	12.4	19.8 5.0						
		U	5.5	5.3	10.8 0.2						
2C	X	N						JOB	 90 90		
		M									
		U									
	Y	N	323.6	1.3	324.9 322.3						
		M	19.2	9.5	17.7 0.7						
		U	20.0	1.7	21.7 18.3						
1C	X	N						JOB	 90 90		
		M									
		U									
	Y	N	401.3	5.2	406.5 396.1						
		M	5.9	9.4	17.3 3.4						
		U	5.1	5.0	10.1 0.1						
4C	X	N						JOB	 90 90		
		M									
		U									
	Y	N	450.1	5.6	455.7 445.1	56.2					
		M	13.5	3.8	17.3 9.7		4.3			0 (0)	
		U	9.1	21.6	30.7 12.5						

		STRESS			N/BD M/BD ² Ft at				SECTION			
		V	H	T	GA	ΔQ	Pw	φ				
2C 4'-1	X	N	155.1	5.4	160.5 149.17	44.6 41.6	1.4	0 (0)	B D J	60 " 48.125	0.8 28.8	 60 12-022
		M	0	3.1	3.1							
		L	0	1.0	1.0							
Y	M	N	0	1.2	1.2	17.3 26.0	0		B D J			
		U										
		L										
1C	X	N	234.8	7.0	241.8 227.8				B D J			 60 60
		M										
		L										
Y	M	N							B D J			
		U										
		L										
2C	X	N	286.1	9.1	295.2 277.0	52.0 76.9			B D J			 60 60
		M	1.3	6.0	7.3 4.6		5.4	0 (0)				
		L	2.6	9.0	11.6 6.4		0					
Y	M	N	0.8	2.9	3.7				B D J			
		U										
		L										
2C 4'-5	X	N	24.8	1.6	26.4 23.2				B D J			 60 12-022
		M	9.7	3.4	13.1 6.3							
		L	6.9	1.5	8.4 5.4							
Y	M	N	4.9	1.5	6.4	17.3 26.0	"		B D J			
		U										
		L										
1C	X	N	49.7	3.6	53.3 45.6	13.7 12.7			B D J			 60 60
		M	-5.0	5.8	0.8 10.5		6.6	0.27 0.12				
		L	-14.3	3.3	11.0 17.6		8.1					
Y	M	N	6.0	2.5	8.5	"	"		B D J			
		U										
		L										
2C	X	N	82.6	6.0	88.6 76.6				B D J			 90 60
		M	-8.5	6.3	2.2 14.8							
		L	-1.8	7.4	5.6 11.2							
Y	M	N	2.0	3.0	5.0	"	"		B D J			
		U	82.6	30.3	112.9 52.3	20.9 9.7		12.8	0.38 0.70 (37.8)		20.5 (37.8)	24-7/8"
		L	0	33.5	33.5							
Y	M	N	0	18.5	18.5				B D J			
		U										
		L										

6 - DESIGN OF SUB MEMBER



CANTILEVER & SUBBEAM MARK KEYPLAN





		LOAD				STRESS						SECTION		
RB2	<p> $u = \frac{\text{Reef } 0.72}{\text{Flve } 0.60} = 1.32$ $q = 0.75$ </p>													
		C	$1.32 \times 2 \times 10.9$	28.8	34.7	C	P_2	γ	α	β	37.86		0.25	
		M	$\times 16.6$	43.8	42.7	M	C				31.7		b	25.26
		D	$\times 6.0$	14.8	19.5	D	C/A	α	ΔQ	P_{27}	ρ		d	24.64
		$\times 9.75/2$	5.9							j	24.64			
RB23	<p> $u = 0.72$ $q = 0.61$ </p>													
		C	$0.72 \times 2 \times 14.9$	21.5	26.3	C	P_2	γ	α	β	34.56		0.25	
		M	$\times 22.8$	32.9	40.0	M	C				32.7		b	31.56
		D	$\times 7.9$	11.4	14.4	D	C/A	α	ΔQ	P_{27}	ρ		d	32.46
		$\times 9.75/2$	4.8							j	32.63			
RB21	<p> $u = 0.72$ $q = \frac{0.61 + 0.72 \times 1.75/2}{1.05} = 1.05$ </p>													
		C	$0.72 \times 2 \times 14.9$	10.8	19.1	C	P_2	γ	α	β	25.96		0.25	
		M	$\times 22.8$	14.4	28.9	M	C				19.6		b	25.96
		D	$\times 7.9$	7.7	10.8	D	C/A	α	ΔQ	P_{27}	ρ		d	25.96
		$\times 9.75/2$	8.3							j	25.96			
RB1	<p> $u = 0.72$ $q = 0.39$ </p>													
		C	$0.72 \times 2 \times 1.8$	2.6	3.1	C	P_2	γ	α	β	23.40		(0-40) = 0.19	
		M	$\times 2.9$	4.3	5.1	M	C				6.5		b	25.40
		D	$\times 2.1$	3.0	3.8	D	C/A	α	ΔQ	P_{27}	ρ		d	40.72
		$\times 4.1/2$	0.5							j	24.63			







		LOAD				STRESS						SECTION	
4B2		$w = 0.54$ $q = 0.61$											
		C	0.54×2	$\times 14.9$	16.1	20.9	C	Pt	γ	st	Π	25.46	25
		M		$\times 22.8$	24.6	31.5	M_c	31.5			26.0	b	35.46
		Q		$\times 7.9$	8.5	11.7	Q	QA	α	ΔQ	Pw	ρ	D
			$\times 9.75/2$	3.0		11.7	13.8		0		9.8	d	63.58
												δ	54.63
4B21		$w = 0.54$ $q = 0.61$											
		C	0.54	$\times 14.9$	8.0	12.8	C	Pt	γ	st	Π	25.46	25
		M		$\times 22.8$	12.3	19.7	M_c	19.7			18.9	b	35.46
		Q		$\times 7.9$	4.3	7.3	Q	QA	α	ΔQ	Pw	ρ	D
			$\times 9.75/2$	3.0		7.3	13.8		0		6.2	d	63.58
												δ	54.63
4B1		$w = 0.54$ $q = 0.39$											
		C	0.54	$\times 14.9$	2.6	2.6	C	Pt	γ	st	Π	25.46	25
		M		$\times 22.8$	3.9	3.9	M_c	3.9			4.3	b	35.46
		Q		$\times 7.9$	2.9	2.9	Q	QA	α	ΔQ	Pw	ρ	D
			$\times 9.75/2$	3.0		3.3	6.3				6.6	d	63.58
												δ	54.63
B													
		C					C	Pt	γ	st	Π		
		M					M						
						Q	QA	α	ΔQ	Pw	ρ		




		LOAD				STRESS						SECTION			
3 B34															
		C	0.66 X 2 X 14.9 0.61 X 9.75/2	19.7 4.8	24.5		C	FE	gamma	ME	II				
		M	X 22.8 X 9.75/8	30.1 9.2	39.3	M	C								
		Q	X 7.9 X 9.75/2	10.4 3.0	13.4	Q	QA	alpha	Delta Q	PW	phi				
3 B33															
		C	0.92 X 2 X 6.4 0.61 X 6.71/2	9.1 2.3	11.4		C	FE	gamma	ME	II				
		M	X 10.1 X 6.71/8	14.3 3.4	17.7	M	C								
		Q	X 4.8 X 6.71/2	6.8 2.1	8.9	Q	QA	alpha	Delta Q	PW	phi				
3 B32															
		C	0.66 X 2 X 14.9 1.69 X 9.75/2	9.8 13.4	24.2		C	FE	gamma	ME	II				
		M	X 22.8 X 9.75/8	19.0 22.6	39.6	M	C								
		Q	X 7.9 X 9.75/2	6.2 9.2	13.4	Q	QA	alpha	Delta Q	PW	phi				
3 B31															
		C	0.92 X 2 X 6.4 0.61 X 6.71/2	4.6 2.3	6.9		C	FE	gamma	ME	II				
		M	X 10.1 X 6.71/8	7.3 1.5	8.8	M	C								
		Q	X 4.8 X 6.71/2	3.5 2.0	5.5	Q	QA	alpha	Delta Q	PW	phi				

	LOAD					STRESS						SECTION	
3B ₂₃													
	C	0.02 x 2	x 14.0	20.2	25.0	C	Pt	γ	mt	π	37.56	0.025	
	M		x 21.4	30.8	38.0	M _c	38.0			31.0	b	37.56	
	Q		x 7.8	10.8	13.8	Q	QA	α	ΔQ	Pw	φ	d	68.78
			x 9.95/2	3.0		13.8	13.8	0	0		13.8	δ	44.63
3B ₁₂													
	C	0.02 x 2	x 7.2	10.4	13.5	C	Pt	γ	mt	π	37.56	0.025	
	M		x 11.0	14.8	20.5	M _c	20.5			19.0	b	37.56	
	Q		x 4.8	6.9	9.3	Q	QA	α	ΔQ	Pw	φ	d	60.96
			x 7.82/2	2.4		9.3	12.2	0	0		10.6	δ	48.97
3B ₁₁													
	C	0.02 x 2	x 3.7	5.3	6.5	C	Pt	γ	mt	π	37.48 (1-6)	0.025	
	M		x 5.9	8.4	10.2	M _c	10.2			7.5	b	30.48	
	Q		x 3.8	4.8	6.1	Q	QA	α	ΔQ	Pw	φ	d	60.96
			x 3.79/2	1.3		6.1	9.0	0	0		6.9	δ	48.97
3B ₂													
	C	1.34	x 6.5/2		5.2	C	Pt	γ	mt	π	25.40 (0-10) - 0.19	0.025	
	M		x 1/8		7.7	M _c	5.2			6.6	b	25.40	
	Q		x 6.5/2		4.6	Q	QA	α	ΔQ	Pw	φ	d	45.72
					4.6	7.4	0	0		7.2	δ	34.63	

		LOAD					STRESSES					SECTION	
2 B ₇		$w = 0.66$ $f = 0.39$										END CEINT 	
		C	0.66 X 2 X 7.2 0.39	9.5 2.0	11.4		M	C	P ₁	γ	α ₁		
		M	X 11.0 X 1/8	14.8 3.0	12.5	M _c	17.5						22.3
		Q	X 4.8 X 1.8 1/2	6.3 1.8	7.5	Q	Q _A	α	ΔQ	P _w	φ		10.4
2 B ₃		$w = 0.66$ $f = 0.39$										END CEINT 	
		C	0.66 X 2 X 3.7 0.39	4.9 1.1	6.0		M	C	P ₁	γ	α ₁		
		M	X 5.5 X 1/8	7.7 1.6	7.3	M _c	9.3						11.9
		Q	X 3.3 X 1.1 1/2	4.4 1.1	5.5	Q	Q _A	α	ΔQ	P _w	φ		9.4
2 B ₂	CMQ = 3B ₂₄											END CEINT 	
		C			24.5		M	C	P ₁	γ	α ₁		
		M			37.3	M _c	37.3						30.5
		Q			13.4	Q	Q _A	α	ΔQ	P _w	φ		12.4
2 B ₅	CMQ = 3B ₃₃											END CEINT 	
		C			11.4		M	C	P ₁	γ	α ₁		
		M			17.7	M _c	17.7						22.6
		Q			8.9	Q	Q _A	α	ΔQ	P _w	φ		13.9

	LOAD					STRESS						SECTION		
1B3 														
	C	0.96 x 2	x 6.1	11.7	19.1		M	C	F ₂	γ	INT			
	M		x 6.71/2	7.4	29.3	M _C	29.3					29.2		
	Q		x 9.6	8.8	13.4	Q	Q _A	α	ΔQ	F ₂ γ	φ			
			x 6.71/2	6.6			13.4	10.4	1.0	5.0	0.0049	19.0		
1B3 														
	C	0.96 x 2	x 5.3	10.2	19.8		M	C	F ₂	γ	INT			
	M		x 6.81/2	7.6	29.1	M _C	29.1					29.2		
	Q		x 8.2	15.7	14.4	Q	Q _A	α	ΔQ	F ₂ γ	φ			
			x 6.81/2	6.7			14.4	10.4	1.0	4.0	0.0043	14.0		
1B4 														
	C	0.59 x 2	x 3.7	4.4	8.8		M	C	F ₂	γ	INT			
	M		x 5.7	6.6	13.4	M _C	13.4					12.1		
	Q		x 2.8	6.6	8.4	Q	Q _A	α	ΔQ	F ₂ γ	φ			
			x 5.7/2	2.4			8.4	7.6	1.0	0.8	0.0026	11.2		
1B4 														
	C	0.02 x 2	x 13.0	9.4	18.3		M	C	F ₂	γ	INT			
	M		x 9.73/2	5.9	23.2	M _C	23.2					13.9		
	Q		x 19.8	14.3	8.7	Q	Q _A	α	ΔQ	F ₂ γ	φ			
			x 9.73/2	3.7			8.7	16.2				5.5		

		LOAD				STRESS					SECTION	
FB1		$q \pm B \cdot 1.04 + \frac{W}{2.43 \times 2} = 5.90$ 									 121.92 35.56 D D10-@150 b 35.56 D 121.92 d 111.92 j 97.93	
	C					M	C	Pa	γ	η1		
	M	5.90	$\times \frac{1.82}{2}$	45.1	M _c	45.1						20.3
	D		$\times \frac{1.82}{2}$	23.1	Δ	23.1	20.9	1.44	0			11.2
FB2		$q \pm B \cdot 0.82 + \frac{W}{2.43} = 2.97$ 									 60.96 30.45 D D10-@150 b 30.45 D 60.96 d 50.96 j 44.59	
	C					M	C	Pa	γ	η2		
	M	2.97	$\times \frac{3.05}{2}$	3.9	M _c	3.9						3.6
	D		$\times \frac{3.05}{2}$	4.8	Δ	4.8	8.2		0			4.8
B												
	C					M	C	Pa	γ	η3		
	M											
	D					Δ						
FB1 CASE-2 MS-BAR											 36.48 18.8	
	C					M	C	Pa	γ	η4		
	M											36.48
	D					Δ						18.8



SLAB KEYPLAN

CASE-1 D-BAR (CASE-2 M/S - BAR)

	LOAD			STRESS			D	J	at	φ	SECTION	
R S _{6A}	$\frac{2.895^6}{4.876^8}$ $\mu = 0.74$ $\lambda = 1.7$	X	M	6.20	0.055	0.47	12.7		2.6 (4.4)		D10 @ 200 (1/2") ~	
			Q	2.14	0.52	1.11		8.9	6.9 (11.3)		" @ 200 ~	
			M		0.042	0.26			1.6 (2.5)		" @ 200 ~	
			Q		0.46	0.99		8.1	6.3 (10.3)		" @ 200 ~	
R S _{2A}	$\frac{4.099^4}{4.876^8}$ $\mu = 0.74$ $\lambda = 1.2$ $DZ = \frac{4.099^4}{16+24 \times 1.2} = 9.21$	X	M	12.44	0.056	0.90	12.7		3.9 (6.5)		D10 @ 150 (1/2") ~	
			Q	3.03	0.49	1.49			9.3 (15.5)		" @ 150 ~	
			M		0.037	0.46			2.8 (4.9)		" @ 250 ~	
			Q		0.45	1.37			9.4 (15.7)		" @ 250 ~	
R S ₁₀	$\frac{1.250^6}{9.752^8}$ $\mu = 0.74$ $\lambda = 7.8$	X	M	1.14	0.083	0.10	12.7		0.6 (1.0)		D10 @ 200 (1/2") D.	
			Q	0.93	0.51	0.47			4.4 (7.3)		" @ 200 D.	
			M								" @ 200 D.	
			Q								" @ 200 D.	
S		X	M									
			Q									
			M									
			Q									
4 S ₂	$\frac{4.099^4}{4.876^8}$ $\mu = 0.59$ $\lambda = 1.2$	X	M	9.91	0.086	0.56	12.7		3.1 (5.4)		D10 @ 150 (1/2") ~	
			Q	2.43	0.49	1.19		8.9	7.4 (12.3)		" @ 200 ~	
			M		0.037	0.37			2.3 (4.0)		" @ 200 ~	
			Q		0.45	1.09		8.1	7.5 (12.7)		" @ 200 ~	
4 S ₁₀	$\frac{5.791^2}{3.000}$ $\mu = 0.59$ $\lambda = 2.9$	X	M	2.36	0.093	0.20	12.7		0.1 (0.2)		D10 @ 200 (1/2") D	
			Q	1.18	0.51	0.60			3.7 (6.2)		" @ 200 D	
			M		0.057	0.13			0.8 (1.4)		" @ 200 D	
			Q		0.46	0.54			3.7 (6.2)		" @ 200 D	
S		X	M									
			Q									
			M									
			Q									
S		X	M									
			Q									
			M									
			Q									


LOAD		STRESS			D	J	at	ρ	SECTION	
3 S 2 2A		$u = 0.76$ $\lambda = 1.2$	X	M	12.77	0.056	0.72	12.7	4.0 (7.0)	D10 @ 150 (1/2") ~
			Y	M	3.17	0.49	1.53		8.9	9.6 (16.0)
3 S 3A		$u = 0.74$ $\lambda = 1.3$	X	M	10.74	0.062	0.67	12.7	3.8 (6.6)	D10 @ 150 (1/2") ~
			Y	M	2.82	0.50	1.41		8.1	9.6 (16.0)
3 S 1A		$u = 0.74$ $\lambda = 2.1$	X	M	11.84	0.082	0.97	12.7	5.4 (9.4)	D13 @ 150 (1/2" @ 100)
			Y	M	2.96	0.51	1.51		3.1 (5.4)	9.4 (16.7)
3 S 4A		$u = 0.76$ $\lambda = 2.7$	X	M	7.06	0.053	0.59	12.7	3.3 (5.7)	D10 @ 200 (1/2") ~
			Y	M	2.32	0.51	1.18		2.5 (4.3)	7.4 (12.3)
3 S 5A		$u = 0.76$ $\lambda = 1.3$	X	M	7.66	0.063	0.48	12.7	2.7 (4.7)	D10 @ 150 (1/2") ~
			Y	M	2.41	0.50	1.21		2.0 (3.5)	7.6 (12.7)
3 S 6		$u = 0.76$ $\lambda = 3.4$	X	M	3.04	0.063	0.25	12.7	1.4 (2.4)	D10 @ 200 (1/2") ~
			Y	M	1.52	0.51	0.98		1.0 (1.9)	4.9 (8.7)
2 S 5		$u = 0.76$ $\lambda = 1.1$	X	M	13.12	0.050	0.66	12.7	3.7 (6.4)	D10 @ 150 (1/2") ~
			Y	M	3.28	0.46	1.51		3.4 (5.9)	9.4 (13.7)
2 S 1		$u = 0.74$ $P = 0.20$	X	M	(0.74 0.20)	(1.5 1.5)	1.13	15.2	5.1 (8.9)	D10 @ 100 (1/2" @ 100) @ 200
			Y	M	(0.74 0.20)	(1.5 1.5)	1.31	11.1	5.6 (10.0)	@ 250 D.

	LOAD		STRESS			D	J	at	φ	SECTION
			M	Q						
S ₁	 $u = 1.06$ $\lambda = 1.6$	X	M	17.81	0.078	1.39	12.7		7.8 (13.8)	D13 @ 150 (1/2" @ 100)
		Y	M	4.37	0.51	2.22		8.9		13.9 (23.2)
S ₁	 $u = 1.06$ $\lambda = 1.8$	X	M	16.96	0.081	1.37	12.7		7.7 (13.4)	D13 @ 150 (1/2" @ 100)
		Y	M	4.24	0.51	2.16				6.0 (10.4)
S ₄	 $u = 0.71$ $\lambda = 2.1$	X	M	6.60	0.083	0.55	12.7		3.1 (5.4)	D10 @ 200 (1/2")
		Y	M	2.16	0.51	1.10				6.9 (11.9)
S ₁₀	 $u = 0.74$ $\lambda = 1.6$	X	M	6.66	0.048	0.52	12.7		2.9 (5.0)	D10 @ 200 (1/2")
		Y	M	2.22	0.51	1.13				7.1 (12.5)
S _{10B}		X	M							D13 @ 150 (1/2" @ 100) (200)
		Y	M							
S _T	 $l = 2.0$ $P = 0.4$ $Q = 1.18$	X	M	$M = (0.4 \times 2) + (1.18 \times 2^2 / 2) = 3.16$ $Q = 0.4 + (1.18 \times 2) = 2.76$					at 6.6 (10.4) at 6.4 (10.6)	
		Y	M	$D = 30 \quad \bar{j} = 24$ $2 - D13 (2 - 1/2") / \text{step}$						
S _T		X	M	$M = 3.16 / 2 = 1.58$ $D20 \quad \bar{j} = 15.3$					at 5.2 (8.2)	
		Y	M	$D13 @ 200 (1/2" @ 150)$						

Design of Underground Corridor & Orchestra Pit

Underground Corridor

CASE - 1.



Unit Load [kN/m^2]

Upper Slab

L.L.	300	
D.L.	FINISH	65
	R.C.	360
T.L.	753	425

Lower Slab

L.L.	180	
D.L.	FINISH	100
	R.C.	600
T.L.	880	700

Wall


D.L.	FINISH	50	
	R.C.	480	530
			$\sim 2.26 = 1.26 \text{ t/m}$

Stiffness Ratio

$$\frac{17^3}{227} = 14.9$$

$$\frac{28^3}{227} = 62.5$$

$$\frac{20^3}{281} = 31.9$$



Vertical Load

$$T.L. \quad (0.785 \times 2.47) + (1.36 \times 2) + (0.785 \times 2.07) = 6.48 \text{ t}$$

$$6.48 / 2.47 = 2.62 \text{ t/m}^2$$

< BEARING CAPACITY 11.00 t/m^2
O.K.

$$D.L. \quad (0.425 \times 2.47) + (1.36 \times 2) + (0.70 \times 2.07) = 5.22 \text{ t}$$

$$5.22 / 2.47 = 2.11 \text{ t/m}^2$$

> BUOYANCY 1.80 t/m^2
O.K.

CM-Q

$$f = 0.788 \text{ [t/m]}$$

$$C = 0.788 \times 2.27^2 / 12 = 0.34 \text{ [tM]}$$

$$M_0 = \frac{f \cdot l^2}{8} = 0.31$$

$$Q = \frac{f \cdot l}{2} = 0.89 \text{ [t]}$$

$$f = \frac{2.62}{0.88} = 1.74 \text{ [t/m]}$$

$$C = 1.740 \times 2.27^2 / 12 = 0.85 \text{ [tM]}$$

$$M_0 = \frac{f \cdot l^2}{8} = 1.12$$

$$Q = \frac{f \cdot l}{2} = 1.97 \text{ [t]}$$



$$W_{max} = k_1 \sigma \cdot h + \{k_2 C \sigma - 1\} + 1 \} \sigma'$$

$$= 0.4 \times 1.8 \times (0.3 + 1.02) + \{0.4 (1.8 - 1) + 1\} 1.37$$

$$= 3.11 \text{ [t/m]}$$



$$W = \frac{3.11 \times 2.27}{2} = 3.51 \text{ [t]}$$

$$C = 3.51 \times 2.27 \times 0.067 \sim 0.100 = 0.16 \sim 0.95 \text{ [tM]}$$

$$M_0 = \frac{W \cdot l^2}{8} = 1.26$$

$$Q = 3.5 \times 0.33 \sim 0.67 = 1.3 \sim 2.6 \text{ [t]}$$

Stress Analysis




Member Design

Member	M [tM]	Q [t]	D [cm]	at [cm]	Q [cm]	QAL [t]
Upper Slab	0.42	0.89	15	at 1.9	4.5	0.4
Wall	0.95	2.80	20	at 3.3	10.8	0.6
Lower Slab	0.95	1.97	20	at 2.9	6.5	0.7

D13 - @200
 D18 - @200
 D13 - @200

CASE - 2.



STIFFNESS RATIO

$$\frac{I_h^3}{263} = 12.8$$

$$\frac{2R^2}{263} = 59.4$$

$$\frac{20^3}{251} = 31.9$$



Vertical Load

T.L. $(978 \times 2.52) + (1.36 \times 2) + (938 \times 2.43) = 7.09 \text{ t}$
 $7.09 / 2.86 = 2.48 \text{ t/m}^2$
 $< \text{Bearing Capacity}$

D.L. $(947 \times 2.52) + (1.26 \times 2) + (970 \times 2.43) = 5.62 \text{ t}$
 $5.62 / 2.86 = 1.97 \text{ t/m}^2$
 $> \text{Buoyancy}$

C.M.O



$f = 0.788$

C	$978 \times 2.52^2 / 12 = 0.45$
M ₀	$/ 8 = 0.68$
Q	$\times 2.63 / 2 = 1.03$

$f = 2.48$
 $= 1.60$

C	$1.60 \times 2.63^2 / 12 = 0.92$
M ₀	$/ 8 = 1.38$
Q	$\times 2.63 / 2 = 2.10$

Stress Analysis



Member Design

Upper Slab	M	0.85	D	15	at 3.9
	Q	1.03	j	10.9	φ 5.2 GAL 6.5 D13-@200
Wall	M	0.89	D	20	at 3.1
	Q	2.60	j	14.4	φ 10.0 GAL 8.6 D13-@200
Lower Slab	M	0.89	D	25	at 2.7
	Q	2.10	j	16.2	φ 11.2 GAL 9.7 D13-@200

CASE - B.



Cantilever Type Wall

$$\begin{aligned}
 u_{max} &= 3.11 \text{ [t/m]} \\
 M &= 3.98 \times (0.30 + 2.26) / 3 = 3.40 \text{ [tm/m]} \\
 Q &= 3.11 \times (0.30 + 2.26) / 2 = 3.98 \text{ [t/m]}
 \end{aligned}$$

$$\begin{aligned}
 D \ 20 \ j \ 14.4 & \quad \text{at } 11.8 \\
 \phi \ 15.4 \ \text{GAL } 8.6 & \\
 D15 \ @ \ 150 &
 \end{aligned}$$

Vertical Load

$$\begin{aligned}
 \text{T.L. } & \left. \begin{aligned} 0.785 \times 8.05 \times 4.45 \\ 1.36 \times (7.85 + 4.25) \times 2 \\ 0.88 \times 7.65 \times 4.05 \end{aligned} \right\} = 88.3 \text{ [t]} \\
 & 88.3 / 8.05 \times 4.45 = 2.46 \text{ [t/m}^2\text{]} \\
 & < \text{Bearing Capacity}
 \end{aligned}$$

$$\begin{aligned}
 \text{D.L. } & \left. \begin{aligned} 0.425 \times 8.05 \times 4.45 \\ 1.36 \times (7.85 + 4.25) \times 2 \\ 0.70 \times 7.65 \times 4.05 \end{aligned} \right\} = 69.8 \text{ [t]} \\
 & 69.8 / 8.05 \times 4.45 = 1.95 \text{ [t/m}^2\text{]} \\
 & > \text{Buoyancy}
 \end{aligned}$$

Lower Slab

$$u = 2.46 \text{ [t/m}^2\text{]} \quad l_x = 4.25 \quad l_y = 7.85 \quad \lambda = 1.85 \quad D \ 25 \ j \ 16.2$$

$$\begin{aligned}
 M &= 1.58 \times 4.25^2 \times 0.082 = 2.34 \quad \text{at } 7.2 \\
 Q &= 4.25 \times 0.81 = 3.43 \quad \phi \ 11.8
 \end{aligned}$$

D16 @ 150


Upper Slab

$$u = 0.785 \quad l_x = 3.5 \quad l_y = 4.25 \quad \lambda = 1.2 \quad D \ 15 \ j \ 10.9$$

$$\begin{aligned}
 M &= 0.785 \times 3.5^2 \times 0.064 = 0.62 \quad \text{at } 2.8 \\
 Q &= 3.5 \times 0.49 = 1.35 \quad \phi \ 6.9
 \end{aligned}$$

D13 @ 150

Beam along slab opening



b 20 D40 d35 J 30.6
25 QAL 5.68
4.59

Ba $q = \text{slab } 0.785 \times 1.0 + \text{Beam } 0.10 = 0.885 \text{ [t/m]}$
 $M_0 = 0.885 \times 4.25^2 / 8 = 2.24 \text{ [tm]}$
 $Q = 0.885 \times 4.25 / 2 = 1.99 \text{ [t]}$

at 3.66 2-D16
Q 3.6

Bb $P = 1.99 \text{ (from Ba) [t]}$
 $W = 0.78 \times 4.25^2 / 4 = 3.54 \text{ [t]}$
 $M_0 = 1.99 \times 4.25 / 4 + 3.54 \times 4.25 / 6 = 4.62 \text{ [tm]}$
 $Q = 1.99 / 2 + 3.54 / 2 = 2.77 \text{ [t]}$


at 7.54 2-D25
Q 5.0

Bc = Ba

Staircase

L.L. 180
 D.L. Finish 100
 RC 360 } 450 x 1.5
 T.L. 870

[F8/mm²]




$M = 0.87 \times 1^2 / 2 = 0.44 \text{ [tm]}$ at 0.92 [cm²]
 $Q = 0.87 \times 1 = 0.87 \text{ [t]}$ Q 2.01 [cm]

D 30
 d 24

1-D13/step

Orchestra Pit



Unit Load [kg/m^2]

Upper Slab	L.L.	360	
	D.L.	FINISH 65	} 425
		R.C. 360	
	T.L.	785	

Lower Slab	L.L.	180	
	D.L.	FINISH 100	} 760
		R.C. 600	
	T.L.	880	

Wall	D.L.	FINISH 50 <th rowspan="2">} 530</th>	} 530
		R.C. 480	

$$\sim \begin{aligned} &\times 1.89 = 740 [\text{kg}/\text{m}] \\ &\times 0.76 = 400 [\text{kg}] \end{aligned}$$

Cantilever Slab

$$\begin{aligned} M &= 0.785 \times 1.83^2 / 2 = 0.92 \text{ [tm]} \\ Q &= \times 1.83 = 1.20 \text{ [t]} \end{aligned}$$

$$\begin{aligned} D_{18} & \geq 10.9 \text{ [cm]} \\ \text{or } 4.2 \text{ [cm}^2\text{]} \\ Q & 6.1 \text{ [cm]} \end{aligned}$$

Wall

$$\begin{aligned} w_{\text{max}} &= 0.7 \times 1.8 \times 1.49 = 1.74 \text{ [t/m]} \\ M &= 1.74 \times 1.49^2 / 6 = 0.50 \\ Q &= \times 1.49 / 2 = 1.00 \end{aligned}$$

$$D_{20} \geq 14.4 \text{ [cm]}$$

$$Q \ 3.9 \text{ [cm]}$$

$$\Sigma M = 0.92 + 0.50 = 1.42$$

$$\text{or } 4.9 \text{ [cm}^2\text{]}$$

D18 @ 200

Lower Slab

$$DL = 425 > \text{Buoyancy } 249^{\#}$$

$$[\text{kg}/\text{m}^2]$$


O.K.

7 - DESIGN OF STEEL FRAME

DESIGN OF HARPLE FLOOR BEAM

(C) HARPLE FLOOR (C)

$w =$ D.L. 100
 L.L. 500
 T.L. 600 $[kg/m^2]$



SB13 [-250 x 50 x 4.0 x 9.0]

SB12

$$q = 0.6 \times 1.5 = 0.9 \text{ T/m}$$

$$\text{SPAN} = 7.328 \text{ m}$$

$$J_M = \frac{E \times 0.009 \times 732.8^4}{384 \times 2,100 \times 732.8 / 300} = 6,887.8 \text{ [cm}^4\text{]}$$

$$I = 380 \times 178 \times 7 \times 11 \text{ (} \gamma = 14 \text{)}$$

$$J = 13,600 > 6,887.8$$

O.K.

$$M_0 = 0.9 \times 7.328^2 / 8 = 604 \text{ [tm]}$$

$$r_b = 732.8 / 2 = 366.4, \quad \lambda_b = 4.48, \quad \lambda_b < 50.1, \quad C = 1.0, \quad \eta = 2.33$$

$$f_b = 1.36, \quad 2 \times = 575$$

$$\frac{\theta}{f} = \frac{604}{1115 \times 1.36} = 0.47 < 1.00$$

$$Q = 0.9 \times 7.328 / 2 = 3.3 \text{ [T]}$$

SB11

$$q = 0.6 \times 7.328 / 2 = 2.2 \text{ T/m}$$

$$\text{SPAN} = 6.853 \text{ m}$$


$$J_M = \frac{E \times 0.022 \times 685.3^4}{384 \times 2,100 \times 685.3 / 300} = 11,815.5 \text{ [cm}^4\text{]}$$

$$[-380 \times 100 \times 10.5 \times 16]$$

$$J = 14,500 < 11,815.5$$


O.K.

(2) HANDLE FLOOR (2)




$U = D.L. = 100$
 $L.L. = 500$
 $T.L. = 600$ [100/4]

SB 12 [-250 X 50 X 4.0 X 8.0]
 SB 14
 $f = \alpha \times 1.8 = 0.74/m$
 $SPAN = 2.89m$
 LIKE TO SB 12
 $H = 280 \times 195 \times 7 \times 11$ (C=14)




SUSPENSION BAR

$N = 0.6 \times 2.89m^2 \times 1.8 = 2.6[t]$
 $A_u = 2.6 / 1.0 = 2.6$ [caf]



DESIGN OF SPOT ROOM

(C) CEILING SPOT



LOAD FLOOR

D.L.	FINISH	90
	DECK	15
	FRAME	35
	CEILING	30

WALL
30 [kg/m²]

L.L. 350

T.L.	DECK	135 +	485 [kg/m ²]
	FRAME	170 +	520

DECK ρ 0.485 [t/m]

SPAN 2.35 [m]

$$J_n = \frac{5 \times 0.00485 \times 2.35^3 \times 300}{384 \times 2,100} = 117.8 \text{ [cm}^4\text{]}$$

$$Z_n = \frac{0.485 \times 2.35^2 \times 100}{8 \times 1.4} = 23.9 \text{ [cm}^3\text{]}$$

U=1.2 $J = 136 > 117.8$
 $Z = 25.8 > 23.9$

BEAM ρ (0.52 x 1.3) + (0.03 x 2.4) = 0.748 [t/m]

SPAN 2 m

$$J_n = \frac{5 \times 0.00748 \times 2^3 \times 300}{384 \times 2,100} = 111.3$$

H-150 X 75 X 6 X 7 (Y=8)

$J = 666 > 111.3$

ρ 200, i 1.96, λ 6 102.0, C 1.00, η 5.60
 f 1.58, Z 98.8

$$\frac{f}{\rho} = \frac{0.748 \times 2^2 \times 100}{8} \times \frac{1}{98.8 \times 1.58}$$

$$= 0.27 < 1.00$$



$$M_D = 22 \times 6.883^2 / 8 = 11.8 \text{ [tM]}$$

$$Z_x = 762$$

$$\frac{M}{Z} = \frac{1180}{762 \times 46} = 0.97 < 1.00$$

$$Q = 22 \times 6.883 / 2 = 75 \text{ [t]}$$

FRAME



$$Q = 1.5 \text{ [t]} \\ M_0 = 1.5 \text{ [tm]}$$

$$\delta = \frac{Pa(3l^2 - 4a^2)}{24 EJ} \leq \frac{l}{300}$$

$$\sim J_H > \frac{1.5 \times 100 (3 \times 460^2 - 4 \times 100^2)}{24 \times 2,100 \times (460/100)} = 1,184,5 \text{ [cm}^4\text{]}$$

$$H = 180 \times 180 \times \pi \times 10$$


$$J = 1,640 > 1,184,5$$

$$R_b = 260 \text{ [b]}, 4.12, \lambda_b = 63.1, C = 1.00, \eta = 4.12$$

$$f = 1.43, \sigma_x = 219$$

$$\frac{\sigma}{f} = \frac{180}{219 \times 1.43} = 0.48 < 1.00$$

DESIGN OF SIDE-SPOT ROOM



ROOF AND WALL

$$p = 0.10 \text{ [t/m}^2\text{]} \times 3.0 \text{ [m]} \times 1.5 \text{ [m]} = 0.45 \text{ [t]}$$

FLOOR

$$q = 0.40 \text{ [t/m}^2\text{]} \times 1.5 \text{ [m]} = 0.60 \text{ [t/m]}$$

$$\left[\text{D.L. } 200 + \text{L.L. } 200 = 400 \text{ [kg/m}^3\text{]} \right]$$

$$J_n = \frac{p l^3}{3 E \delta_{cr}} + \frac{q l^4}{8 E \delta_{cr}} \quad \delta_{cr} = \frac{200}{200} = 1 \text{ [cm]}$$

$$= \frac{0.60 \times 200^3}{3 \times 2100 \times 1} + \frac{0.004 \times 200^4}{8 \times 2100 \times 1}$$

$$= 761.9 + 331.0$$

$$= 1,142.9 \text{ [cm}^4\text{]}$$

H-150 x 150 x 7 x 10

$$J = 1,640 > 1,142.9$$


$$M = 0.6 \times 2 + 0.4 \times 2^2/2 = 2.0 \text{ [tm]}$$

$$e_b \cdot 206 \quad i_b \cdot 4.12 \quad \lambda_b \cdot 48.5 \quad f_b \cdot 1.60 \quad C \cdot 1.75 \quad \eta \cdot 4.12$$


$$\frac{\sigma}{f} = \frac{M}{Z \cdot f} = \frac{200}{219 \times 1.6} = 0.57$$

$$M/P_n = 20/70 = 0.29 \text{ [t]}$$

DESIGN OF ENTRANCE CANOPY



key plan



key section

Unit load [t/m²]

D.L.	Roof	0.06	$\left. \begin{array}{l} 0.13 \\ 0.19 \end{array} \right\} 0.03$
	Purlin	0.01	
	Frame	0.06	
	Ceiling	0.06	
W.L.	C	-1.3	$c_f = -0.16$
	f	0.12	

Purlin @ 600 SPAN = 3.000

$$f = 0.13 \times 0.6 = 0.078 \text{ [t/m]}$$

$$J_n = \frac{f \times 0.60078 \times 300^4}{384 \times 2,100} = 39.2 \text{ [cm}^4\text{]}$$

$$Z_n = \frac{0.078 \times 3^2 \times 100}{8} \times \frac{1}{1.4} = 6.3 \text{ [cm}^3\text{]}$$

$$[-100 \times 50 \times 20 - 2.3] \quad J_{n.17} \text{ [cm}^4\text{]} \quad Z_{16.1} \text{ [cm}^3\text{]}$$

Subbeam (SB16A)

$$P = 0.19 \times 2.15 \times 3.0 = 1.23 \text{ [t]}$$




$$M_0 = 1.23 \times 6 / 4 = 1.84 \text{ [tm]}$$

H - 250 x 250 x 9 x 14

lb 300 lb 6.87 lb 43.7 c 1.0 m 4.91 f 1.6 z x 867

$$\frac{M}{f} = \frac{1.84}{967 \times 1.6} = 0.13 < 1.00$$

Cantilever (SB16B)



$$P = 0.19 \times 2.15 \times 3.0 / 2 = 0.61 \text{ [t]}$$

$$q = 0.19 \times 1.5 = 0.29 \text{ [t/m]}$$

$$ME = (0.61 \times 4.27) + (0.29 \times 4.27^2 / 2) = 5.3 \text{ [tm]}$$


$$Q = (0.61) + (0.29 \times 4.27) = 1.8 \text{ [t]}$$

$$q' = 0.19 \times 1.5 = 0.29 \text{ [t/m]}$$

$$M_0 = 0.29 \times 3.17^2 / 2 = 1.4 \text{ [tm]}$$

$$Q = 0.29 \times 3.17 = 0.9 \text{ [t]}$$

$$Q' = 0.9 \pm 5.3 / 3.17 = 2.6 \sim -0.8$$



H-250 x 250 x 9 x 14 (γ=1.6)

z_b 427 z_c 6.57 λ_b 2.2 c 1.75

γ 4.9 f_b 1.6 z_x 867 [cm³]

$$\frac{\sigma}{f} = \frac{ME}{z_x \cdot f_b} = \frac{530}{867 \times 1.60} = 0.38 \leq 1.00$$

$$J = 10,800 \text{ [cm⁴]}$$

$$\delta_0 = \frac{Pl^3}{24J} + \frac{ql^4}{8EJ} = \frac{0.61 \times 4.27^3}{24 \times 2,100 \times 10,800} + \frac{0.0029 \times 4.27^4}{8 \times 2,100 \times 10,800}$$

$$= 0.01 + 0.53$$

$$= 1.24 \text{ [cm]}$$


$$\theta = \frac{M_E l}{4EJ} = \frac{530 \times 315}{4 \times 2,100 \times 10,800} = 0.0018 \text{ [RAD]}$$

$$\delta' = 0.0018 \times 427 = 0.77 \text{ [cm]}$$

$$\delta = 2.03 \text{ [cm]}$$


$$\delta / \text{span} = 1/210$$

cantilever (SB16C)



P_1 SB16B & D 4.4 [t]
 $M_F = 4.4 \times 1.8 = 7.9$ [tm]
 $Q = 4.4$ [t]

P_2 $0.19 \times 2.15 \times 3.0 = 1.2$ [t]
 $M_D = 1.2 \times (1.2 \times 3.0 / 4.2) = 1.0$ [tm]
 $Q = 1.2 \times (3.0 - 1.2 / 4.2) = 0.9 \sim 0.3$ [t] $\sim \pm \frac{7.9}{4.2} = 2.8 \sim -1.6$ [t]



H - 250 x 250 x 9 x 14

$\sigma / f = 7.9 / (867 \times 1.6) = 0.57 \leq 1.0$

$\delta_0 = \frac{4.4 \times 1.8^3}{3 \times 2,100 \times 10,800} = 0.38$ [cm]

$\delta = \frac{7.9 \times 4.2}{4 \times 2,100 \times 10,800} = 0.0037$ [RAD]

$\delta' = 0.0037 \times 180 = 0.66$ [cm]

$\Sigma \delta = 1.04$ [cm]
 $\delta / \text{span} = 1/173$

post (SP11)

$N = 7.2$ [t]

H - 250 x 250 x 9 x 14

$f_c = 390$ $\lambda_y = 62.9$ $\lambda_z = 62$ $f_c = 1.28$ A 92.18

$\sigma / f = 7.2 / (92.18 \times 1.28) = 0.06 < 1.0$

BA 19 x 250 x 250

$\sigma_c = 7,200 / (25 \times 25) = 9.2$ [kg/cm^2]

$M = 9.2 \times 14^2 / 2 = 900$ [kg cm]

$\sigma = 1,600$


$Z_n = 900 / 1,600 = 0.5625$ [cm^3]

$t_n = \sqrt{6 \times 0.5625} = 1.837$ [cm] \rightarrow BA 19


Tie beam (SB17)

[- 250 x 90 x 9 x 13]

DESIGN OF PROCEMIUM FRAME



$\delta = 3.26 \text{ [cm]}$



Stress by DEMOS-E

35 A DEMOS-E 207 5

DEMOS-E PROGRAM AND OUTPUT DATA

/000/ ON

78-01-17, 18:02

/001/ BAT C

* 5-9 3 化 5 5 5 :

ON

-LIB-FRAP-GEN

11

21

1 TTL TR:BTV-TRUSS:

2 GEN1 1,1,15,2,2316,48,745.8

3 CNT1 2100

11-JNT4 1,0,1,6,11

12 1,5,7,9,12,2,7,12

13 1,15,2,24,3,8,13

14 1,1737,36,4,9,14

15 1,2316,48,5,10,15

16 2,0,1,2,3,4,5

17 2,376,8,6,7,8,9,10

18 2,745,8,11,12,13,14,15

21-JNT5 110000,1

22 010000,5

31-SCT2 1,4,50,20,1,1,6

32 2,4,20,20,0,8,1,2

41-MMB4 1,1,1,2,2,3,3,4,4,5,11,12,12,13,13,14,14,15,1,6,6,11,5,10,10,15

42 2,6,7,7,8,8,9,9,10,2,7,12,3,8,8,13,4,9,9,14,2,6,3,7,7,11,6,12,4,10,3,9,9,15,8,14

51-JL3 1,28,5,11,15

52 1,75,3,12,13,14

61-0-G1 1,2,3,4,5,6,3,6,4,6,6,6,7

OFF

-/EGJ

17-18-03-27" BRT "R0245" BSN "R0245" BRT "17-18-03-27"

/002/

TR:0 - 1

***** STRUCTURAL ANALYSIS BY FRAP-GEN. NTT *****

* TITLE TV-TRUSS:

* TYPE OF STRUCTURE PLANE TRUSS + PLATE

* METHOD OF ANALYSIS EXACT SOLUTION

* SHEAR DEFORMATION NON

* TEST VALUES

UNBALANCE FORCE TBL	---	1.00000E-05
ZERO TEST (STIFF.)	---	1.00000E-02
ZERO TEST (LOAD)	---	1.00000E-01
VERTICAL DRCTN COS.	---	1.00000E-03

TR:B - 2

***** JOINT DISPLACEMENT *****

NO	LD	U-X	U-Y
15	1	-3.392E-01	-3.748E-01
14	1	-9.147E-02	-2.449E+00
13	1	1.895E-01	-3.259E+00
12	1	4.705E-01	-2.449E+00
11	1	7.182E-01	-3.748E-01
10	1	-2.438E-01	-2.291E-01
9	1	9.447E-02	-2.212E+00
8	1	1.895E-01	-3.046E+00
7	1	2.845E-01	-2.212E+00
6	1	6.228E-01	-2.291E-01
5	1 SPT	3.790E-01	0.000E+00
4	1	3.790E-01	-2.069E+00
3	1	1.895E-01	-2.877E+00
2	1	9.909E-15	-2.069E+00
1	1 SPT	0.000E+00	0.000E+00

**** MEMBER FORCE (MEMBER AXIS) ****

I-	J	LD	AXIAL	SHEAR-Y	AXIAL	SHEAR-Y
1-	2	1	3.981E-12	0.000E+00	3.981E-12	0.000E+00
1-	6	1	1.414E+02	0.000E+00	-1.414E+02	0.000E+00
2-	3	1	7.614E+01	0.000E+00	7.614E+01	0.000E+00
2-	6	1	9.084E+01	6.040E-14	9.084E+01	2.842E-14
2-	7	1	4.954E+01	0.000E+00	-4.954E+01	0.000E+00
3-	4	1	7.614E+01	0.000E+00	7.614E+01	0.000E+00
3-	7	1	5.342E+01	6.750E-14	5.342E+01	4.619E-14
3-	8	1	5.827E+01	0.000E+00	-5.827E+01	0.000E+00
3-	9	1	5.342E+01	3.553E-15	5.342E+01	0.000E+00
4-	5	1	7.958E-13	0.000E+00	0.000E+00	0.000E+00
4-	9	1	4.954E+01	0.000E+00	-4.954E+01	0.000E+00
4-	10	1	9.084E+01	3.553E-15	9.084E+01	2.487E-14
5-	10	1	1.414E+02	0.000E+00	-1.414E+02	0.000E+00
6-	7	1	7.614E+01	0.000E+00	-7.614E+01	0.000E+00
6-	11	1	9.191E+01	0.000E+00	-9.191E+01	0.000E+00
7-	8	1	2.139E+01	0.000E+00	-2.139E+01	0.000E+00
7-	11	1	1.180E+02	1.776E-14	1.180E+02	6.750E-14
7-	12	1	8.382E+01	0.000E+00	-8.382E+01	0.000E+00
8-	9	1	2.139E+01	0.000E+00	-2.139E+01	0.000E+00
8-	12	1	1.585E+01	9.903E-14	1.585E+01	9.370E-14
8-	13	1	7.530E+01	0.000E+00	-7.530E+01	0.000E+00
8-	14	1	1.585E+01	5.773E-15	-1.585E+01	3.864E-14
9-	10	1	7.614E+01	0.000E+00	-7.614E+01	0.000E+00
9-	14	1	8.382E+01	0.000E+00	-8.382E+01	0.000E+00
9-	15	1	1.180E+02	1.066E-14	1.180E+02	4.263E-14
10-	15	1	9.191E+01	0.000E+00	-9.191E+01	0.000E+00
11-	12	1	9.952E+01	0.000E+00	-9.952E+01	0.000E+00
12-	13	1	1.129E+02	0.000E+00	-1.129E+02	0.000E+00
13-	14	1	1.129E+02	0.000E+00	-1.129E+02	0.000E+00
14-	15	1	9.952E+01	0.000E+00	-9.952E+01	0.000E+00

TR: B - 4

***** SUPPORT REACTION *****

NO	LU	F-X	F-Y
1	1	-3.981E-12	1.414E+02
5	1	0.000E+00	1.414E+02

-P001 M ケイワン カリ-

CASE 1, SMRA + H.T.B. FIOT

H-500 x 200 x 10 x 16 (C_x = 20)

A = 114.2

Web 6-M20 R = 9.42 x 6 = 56.5
 Ae [50 - { 2(1.6+2.0) } + (2.1 x 6)] x 1.0 = 30.2
 Na 30.2 x 2.2 = 66.4 > 56.5
 R 56.5 / 1.6 { 38 - (6 x 2.1) } x 2 = 0.70 → R 9 x 400

Flg Ae { 114.2 - (40.36 x 1.0) - 6(2.1 x 1.0) } / 2 = 30.6
 Na 30.6 x 2.2 = 67.4
 8-M20 R = 9.42 x 8 = 75.4 > 67.4
 R 16 x 200 1.6 { 20 - (2 x 2.1) } x 1.6 = 40.4
 2R5 22 x 176 2.2 { 14 - (2 x 2.1) } x 1.6 = 34.5 } 74.9

Σ Na = 56.5 + (2 x 67.4) = 191.3 > N_{max} 141.4

Between Truss Joint ~ AS R.C.C. Beam

q = 6.43 t/m

M₀ = 6.43 x 5.791² / 8 = 27.0 [tM] at 1.9

Q = " x 5.791 / 2 = 18.6 [t] φ 64

< Q_{AL} 62.1 [t]

D 74.8 j 642.2

Lower Code ~ 2-D20 O.F.

$$H-300 \times 150 \times 6.5 \times 9 \quad (Y=13)$$

$$A = 46.78$$

Web 3-M20 $R = 9.42 \times 3 = 28.3$
 Ae $[30 - \{2(0.9 + 1.3) + (2.1 \times 3)\}] \times 0.65 = 12.5$
 Na $12.5 \times 2.2 = 27.6 < 28.3$
 $R = 27.6 / 1.6 \times \{20 - (2 \times 2.1)\} \times 2 = 0.63 \rightarrow R 9 \times 200$

Flg Ae $\{46.78 - (27.6 \times 0.65) - 4(2.1 \times 0.9)\} / 2 = 11.3$
 Na $11.3 \times 2.2 = 24.8$
 4-M20 $R = 4.71 \times 6 = 28.3 > 24.8$
 $R = 24.8 / 1.6 \times \{15 - (2 \times 2.1)\} = 1.44 \rightarrow R 16 \times 150$

$$\Sigma Na = 27.6 + (2 \times 24.8) = 77.2$$

→ Temporary works use

$$H-200 \times 200 \times 8 \times 12 \quad (Y=13)$$

$$A = 63.53$$

Web 3-M20 $R = 9.42 \times 3 = 28.3$
 Ae $[20 - \{2(1.2 + 1.3) + 2.1\}] \times 0.8 = 10.3$
 Na $10.3 \times 2.2 = 22.7 < 28.3$
 $R = 22.7 / 1.6 \times (10 - 2.1) \times 2 = 0.90 \rightarrow R 9 \times 100$

Flg Ae $\{63.53 - (10.3 \times 0.8) - 4(2.1 \times 1.2)\} / 2 = 20.7$
 Na $20.7 \times 2.2 = 45.6$
 6-M20 $R = 9.42 \times 6 = 56.5 > 45.6$
 $R 9 \times 200 \quad 0.9 \{20 - (2 \times 2.1)\} \times 1.6 = 22.8$
 $2 R 512 \times 80 \quad 1.2 \{1.6 - (2 \times 2.1)\} \times 1.6 = 22.7 \quad 45.5$


$$\Sigma Na = 22.7 + (2 \times 45.5) = 113.7 < N_{max} \cdot 118.0$$


$$\Delta N = 118.0 - 113.7 = 4.3 \quad [t]$$

$$a_s = 4.3 / 22 = 2.0 \quad [cm^2]$$

$$\sim \text{E-D19}$$



STEEL FRAME FRAMING PLAN







② FRAME FRAMING ELEVATION

③ FRAME FRAMING ELEVATION





STEEL FRAME
FRAMING ELEVATION

H-700 x 200 x 10 x 16 (Y=20)




R16 x 200 x 10 x 16
 AS 4-M20
 Double Nut
 ⌀ 200

H-300 x 150 x 6.5 x 9 (Y=13)




R16 x 150 x 6.5 x 9
 A.S. 4-M20
 Double Nut
 ⌀ 200

H-200 x 200 x 8 x 12 (Y=13)




Detail of Beam Joint

Detail of Column Bottom



Typical Welding

Material



H, Rib R 3M50A
 Splice R SS41
 H.T.B. F10T

CASE - 2 M/S STEEL + WELDING


CODE MEMBER

$L-3'' \times 3'' \times \frac{3}{8}''$ $A=13,484 [cm^2]$
 $f_c = 1,269 [t/cm^2]$
 $F = 13,484 \times 1,269 = 17,1 [t]$


FULL STRENGTH
 For 4LS $F = 68,2 [t]$

" 6LS $F = 107,3$


" 8LS $F = 136,5$



SECTION




OVER STRESS



~ 4-D19
 Needed Reinforcement

Member End

4LS - 3" x 3" x 3/8"
 $F = 68.2 \text{ [t]}$




$\mu A = 13.484 \times 4 = 53.936 \text{ [cm}^2]$
 $\mu D = 53.936 / 2.54 = 21.234 \rightarrow 25 \text{ [cm]} = R1$

WELDING ~ FOR 2LS


$R = 0.6 \times 0.7 \times 0.8 = 0.336 \text{ [t/cm]}$
 $\mu l = 13.484 \text{ [cm}^2] \times 1.265 \text{ [t/cm]} / 0.336 \text{ [t/cm]} = \frac{1}{4}$
 $= 50.766 \text{ [cm]} \rightarrow 60 \text{ [cm]}$

6LS - "




$\mu A = 13.484 \times 6 = 80.904 \text{ [cm}^2]$
 $\mu D = 80.904 / 2.54 = 31.852 \rightarrow 40 \text{ [cm]}$

8LS - "




$\mu A = 13.484 \times 8 = 107.872 \text{ [cm}^2]$
 $\mu D = 107.872 / 2.54 = 42.469 \rightarrow 50 \text{ [cm]}$


TIE RE





4LS - 3" x 3" x 3/8" (76x76x10)



2LS - "





6LS - "




MATERIAL
L M/S STEEL
R " (SANJUKTA) W - WELDABLE QUALITY
A.B. M/S BAR
FILLET WELDING $f_e = 0.8 \sqrt{cm} \approx 12 \text{ [KIP/IN}^2]$
DESIGN INTENSITY

W LITE
STEEL FRAME DETAIL
CASE - 2. (M/S - STEEL)



8 - CHECK OF EXISTING PART

STRUCTURAL CHECK OF EXISTING AUDITORIUM



FRAMING PLAN - ROOF

STIFFNESS RATIO

Column

$b = 91.44$

$D = 50.8$

$$k = \frac{91.44 \times 50.8^3}{12} \times \frac{1}{1117} = 892.7$$

Beam

$b = 33.02$

$D = 152.4$

$$b_2 = \{0.5 - 0.6 (a/2)\} a$$

$$= \{0.5 - 0.6 (119.3 / 1917 \sim 2315)\} 119.3$$

$$= 75.0 \sim 86.0$$

$$b = 33.02 + 2 \times 75.0$$

$$= 144$$

$$b/b = 144 / 33.02$$

$$= 4.36$$

$$t/d = 12.7 / 152.4$$

$$= 0.083$$

$\phi = 1.6$

$$k = 1.6 \times \frac{33.02 \times 152.4^3}{12} \times \frac{1}{1517 \sim 2313}$$

$$= 2.578.6 \sim 6.737.4$$

$k' = 9.6 \sim 7.5$
($k_0 = 892.7$)

$0.6 \sim 0.7$



D-Value

k_c	k_b	F	α	D
1.0	9.6	7.6	0.57	0.27
	7.5	7.5	0.54	0.24

$\gamma = 0.48$

UNIT LOAD

FLOOR				Kg/m ²		TOTAL LOAD
	DEAD LOAD			LIVE LOAD		
ROOF		WATER PROOF	275	S	90	780
		RC CEILING	245	V	70	710
			120	H	30	670
			640			
ROOF ABOVE FRONT STAGE			640	S	90	1030
			+	V	70	1010
		STEEL FRAME	50	H	30	845
			690			
LIGHTING ROOM		FINISH	60	S	350	550
		STEEL FRAME	100	V	250	450
		CEILING	40	H	150	350
			200			

BEAM				t/CLEAR SPAN				
b x D	t/m			Σ	R=10.427	11.62		
	SKELE TON	FINISH						
20" x 60"	1.827	-	1.827					
10" x 24"	0.372	-	0.372					
8" x 60"	0.694	-	0.694					
12" x 60"	1.127	-	1.127					

COLUMN				t/CLEAR HEIGHT				
b x D	t/m			Σ	R=10.427	11.62		
	SKELE TON	FINISH						
20" x 36"	1.118	-	1.118					

WALL				t/CLEAR HEIGHT (m)				
b x D	t/m			Σ	NET R=259	629		
	SKELE TON	FINISH						
4 1/2" x 3 1/2" x 1 1/2"	0.183	0.488	0.431					
		+0.060						

VERTICAL LOAD OF COLUMN

MINIMUM (B)

S	$1.01 \times 9.09 \times 3.05 =$	33.0	}	
B	$1.83 \times 2.59 =$	4.7		
	$0.37 \times 2.59 \times 2 =$	1.9		
	$0.69 \times 1.19 \times 3 =$	2.5		
	$1.13 \times 17.66 / 2 =$	10.0		
C	$11.6 =$	11.6		
W	$6.3 \times 2.59 =$	16.3		45.0 [t]

MAXIMUM (B)

S	$0.71 \times 10.61 \times 6.10 =$	46.0	}	
B	$1.83 \times 5.18 =$	9.5		
	$0.37 \times 5.18 \times 2 =$	3.8		
	$0.69 \times 1.19 \times 8 =$	6.6		
	$1.13 \times 20.91 / 2 =$	11.7		
C	$11.6 =$	11.6		
W	$6.3 \times 5.18 =$	32.6		121.8 [t]

C·M₀Q OF BEAM

MINIMUM (B2)

$$f = (1.01 \times 15.24) + (1.13) + (0.69 \times 1.19 \times 3 / 12.17) = 2.80 \text{ [t/m]}$$

C	$2.80 \times 19.17^2 / 12 =$	777.8 [tM]
M ₀	$/ 8 =$	118.6
Q	$\times 19.17 / 2 =$	25.4 [t]

MAXIMUM (B22)

$$f = (1.01 \times 15.24) + (1.13) + (0.69 \times 1.19 \times 4 / 22.99) = 2.81 \text{ [t/m]}$$

C	$2.81 \times 22.99^2 / 12 =$	1237 [tM]
M ₀	$/ 8 =$	185.6
Q	$\times 22.99 / 2 =$	32.3 [t]

SEISMIC FORCE

Total Vertical Load

Floor	$0.945 \times 18.68 \times 6.10$	76.3	} 440.4	} $\Sigma = 1322.5$ [t]
	$0.67 \times 21.22 \times 23.67$	336.6		
	0.35×500	17.5		
Beam	$1.827 \times (30.18 + 29.77)$	109.5	} 642.6	
	$0.372 \times (30.18 - 4.57 + 29.77 - 4.57)$	18.9		
	1.127×401.46	452.4		
	$0.694 \times (1.193^3 \times 73 + 0.432^6 \times 4)$	61.8		
Column	$11.62 \times 12/2$	69.7		
Wall	$6.29 \times (30.18 - 4.57 + 29.77 - 4.57)/2$	149.8		

$$\left(\begin{array}{l} \text{Area} = \left\{ (18.17 + 23.13) / 2 \right\} \times \{ 6.096 \times 5 \} - 0.712^2 = 614.7 \text{ [m}^2\text{]} \\ \text{Average Load} = 1322.5 / 614.7 = 2.15 \text{ [t/m}^2\text{]} \end{array} \right)$$

Coefficient of Horizontal Force = 0.05

Horizontal Force = $1322.5 \times 0.05 = 66.1$ [t]



STRESS FOR VERTICAL LOAD

⊕ FRAME

0.09	0.91	
76.9	-77.8	
+9.2	+70.7	(25.4)
+1.0	+37.7	118.6
+0.4	+21.4	
+0.4	+11.0	
+0.2	+10.0	
+0.1	+4.0	
+0.1	+2.3	
+0.1	+1.1	
+11.7	+11.8	102.8


⊖ FRAME

0.12	0.88	
+14.8	-121.7	
+6.5	+108.9	(32.5)
+3.9	+54.5	195.6
+1.2	+27.0	
+0.7	+10.1	
+0.7	+8.9	
+0.2	+4.5	
+0.2	+2.0	
+26.1	+26.1	142.8




STRESS FOR SEISMIC FORCE

$\bar{Q}_c = 66.1 / 12.0 = 5.5$ (D = 0.84 ~ 0.87, $D_{max} \neq D_{min}$)
 $T_M = 5.5 \times 11.19 = 61.8$ $M_c =$
 $\gamma = 0.88$



ALLOWABLE STRESS OF EXISTING FOOTING = F4B



PILE 4-406.4 ϕ (16 ϕ)

$R_A = \pi s t / p$

vertical Load C. 75.0 ~ 121.9 $\ll \pi \times 4$

MIN $M_A = \frac{75.0}{2} \times 1.21^2 = 44.7 > 59 + 33.8 = 92.7$


MAX $M_A = \frac{121.9}{2} \times 0 = 0 > 12.1 + 33.8 = 45.9$
O.K.

REINFORCEMENT 16-19 ϕ ($\frac{3}{4}$ ϕ) @ 150 (6 ϕ) C/C

$M_A = 16 \times 2.85 \text{ [cm}^2\text{]} \times 2.4 \text{ [t/cm}^2\text{]} \times 0.8 \text{ [m]}$
 $= 37.6 \text{ [tm]}$

$> \frac{121.9}{2} \times \frac{1.21^2}{2} = 37.1$
O.K.

ALLOWABLE STRESS OF EXISTING COLUMN



508
(20°)

Formula on Ultimate Intensity

$$N \leq 0.4bDFc$$

$$M_u = 0.8\alpha x \sigma_y D + 0.5ND \left(1 - \frac{N}{bDFc}\right)$$

$$N > 0.4bDFc$$

$$M_u = 0.8\alpha x \sigma_y D + 0.12b D^3 Fc$$

In this case

$$N = 115.0 \sim 121.3 \text{ [t]}$$

$$0.4bDFc = 0.4 \times 91.44 \times 50.8 \times 150 = 334.45 \text{ [t]} > N$$

$$\begin{aligned} M_u &= 0.8 \times (9 \times 5.07) \times 2.4 \times 50.8 + 0.12 \times 91.44 \times 50.8^2 \times 150 \\ &= 2472.5 + 5,097,032.4 \\ &= 5,099,504.9 \quad \text{[kgcm]} \\ &= 51.0 \quad \text{[tm]} \end{aligned}$$

$$\begin{aligned} M \quad \text{⊕} \quad 11.9 + 23.5 &= 35.3 \\ \text{⊙} \quad 26.1 + 23.5 &= 49.6 \end{aligned} \quad \left. \vphantom{\begin{aligned} M \quad \text{⊕} \quad 11.9 + 23.5 \\ \text{⊙} \quad 26.1 + 23.5 \end{aligned}} \right\} < M_u$$


O.K.

$$QAS = 91.44 \times (50.8 - 5) \times \frac{7}{8} \times 9 = 37.0 \text{ [t]}$$

$$\begin{aligned} > QD \quad \text{⊕} \quad 1.6 + (45 \times 1.5) &= 69 \\ \text{⊙} \quad 3.5 \quad \quad \quad &= 11.8 \end{aligned} \quad \text{[t]}$$

O.K.

はり の 許容 応 力 B2 ~ 22



$$\bar{b} = (30.48 + 21.56) / 2 = 33.02$$

$$D = 192.4$$

$$d = 192.4 - 10 = 182.4$$

$$j = 182.4 \times \frac{17}{8} = 124.6$$

	α	β
$\frac{1}{2}$ (12.5)	1.27	3.99
$\frac{1}{8}$ (3.125)	0.41	0.98

$M_u = 0.9 \alpha \rho_y d \dots \dots \rho_y = (\text{Mild Steel Bar}) = 33,000 \text{ [P.S.I.]} = 2.3 \text{ [%]} \text{ [} \frac{1}{\text{cm}^2} \text{]}$

$Q_{AL} = b_j f_s = 33.02 \times 124.6 \times 6 = 24,77 \text{ [t]}$

St. $\square \frac{3}{8} \text{ @ } 18 \text{ (} 9.5 \phi \text{ @ } 457.2 \text{)} \dots P_{ul} = 0.00041$

$Q_{Ab} = \rho f_b j \dots \dots f_b = 7.2 \sim 10.8 \text{ [F}_3 \text{/cm}^2 \text{]}$

			M	α	β	d	j	M_u	Q_{Ab}
B22	END	TOP	$(2 - \frac{1}{2}) + (3 - \frac{1}{8})$	21.77	3.99	182.4	124.6	54.2	31.3 47.8
		BTM	$(5 - \frac{1}{8})$	32.07				94.5	
	CENT	TOP	$(2 - \frac{1}{2})$	2.53				7.5	
		BTM	$(9 - \frac{1}{8})$	51.30				151.2	
B 14 ~ 21	END	TOP	$(2 - \frac{1}{2}) + (6 - \frac{1}{8})$	41.01	61.84			120.9	51.5 82.3
		BTM	$(8 - \frac{1}{8})$	51.30				151.2	
	CENT	TOP	$(2 - \frac{1}{2})$	2.53				7.5	
		BTM	$(14 - \frac{1}{8})$	89.78				264.6	
B 7 ~ 13	END	TOP	$(2 - \frac{1}{2}) + (4 - \frac{1}{8})$	28.19	43.89			83.1	39.4 59.1
		BTM	$(8 - \frac{1}{8})$	51.30				151.2	
	CENT	TOP	$(2 - \frac{1}{2})$	2.53				7.5	
		BTM	$(12 - \frac{1}{8})$	76.96				226.9	
B 2 ~ 12	END	TOP	$(2 - \frac{1}{2}) + (4 - \frac{1}{8})$	28.19	43.89			83.1	39.4 59.1
		BTM	$(6 - \frac{1}{8})$	38.48				113.4	
	CENT	TOP	$(2 - \frac{1}{2})$	2.53				7.5	
		BTM	$(10 - \frac{1}{8})$	64.3				159.0	

	V	H	T	
32	MS 11.8	27.7	89.8	< 85.1
	C 103.8	0	103.8	< 104.0
	Q 25.4	30.1	29.9	< 24.4 ~ 44.1
33	MS 26.1	29.7	83.8	< 64.2
	C 154.5	0	154.5	* 151.2
	Q 32.3	24.1	34.9	< 31.3 ~ 47.0

O.K.

O.K.

By above investigation

Existing auditorium is safe
for seismic force.

(In long direction, existing walls)
resists for seismic force.

(END)

2. Calculation Sheet of Acoustics

(Calculation Sheets)

ACOUSTICAL DESIGN
OF AUDITORIUM

1. The Acoustical Effects of the Auditorium

The acoustical effects of the auditorium have been so designed as to obtain the planned reverberation time by appropriate combinations of the low-, medium- and high-frequency and extensive frequency band sound absorbing materials. The results of the design calculations are given on pages 1 to 5.

The major design conditions assumed are summarized as below:

- (1) Boards shall be used as a sound reflecting material both at the surface of the side walls and at the surface of the ceiling and sound diffusers shall be provided in the front side walls in consideration of sound diffusion.

These boards can be expected to produce limited sound absorption effects due to resonance absorption in the low frequency.

- (2) To compensate for sound absorption in the low frequency, perforated calcium silicate boards shall be used in the borders of the ceiling and a slit type sound absorbing construction shall be adopted for some parts of the rear ceiling.

- (3) A sound absorbing construction consisting of slits and perforated calcium silicate boards covered with cloth will be adopted as a extensive frequency band sound absorbing material in the rear wall.

- (4) Porous boards shall be employed as a medium and high-frequency sound absorbing material in some parts of the rear side walls.

- (5) Medium- and high-frequency sound absorbing materials will be used in the walls and ceiling of the stage-flys in order to shorten the reverberation time in the auditorium to the required value without using stage sound reflectors.

By selecting and distributing the different types of sound absorbing materials in the auditorium in the manner as noted above, it can be

expected to obtain a reverberation time of 1.1 seconds (500Hz) with stage sound reflectors in use and a reverberation time of about 0.96 seconds without the reflectors when the auditorium is full.

2. Noise Control Design on Air-Conditioning Duct System

The duct system of the air-conditioning unit will be fitted inside with a required number of sound absorbing devices, such as chambers and elbows, to keep the fan noise transmitted through the ducts to levels below the permissible noise levels established according to the use of rooms.

Three to five of the sound absorbing devices will be installed in the air-conditioner room to reduce the fan noise as much as possible before leaving the room. The rest of the devices will be installed in the ceilings of the rooms served by the air-conditioner.

To minimize noises produced by air stream in the duct system, the air velocity in the ducts will be kept to a value lower than the 5 m/sec, and provision is made for installation of a sound absorbing device at the end of the duct system.

Tables five to eleven show the results of calculations made in respect of air-conditioner noises in the measure systems of the auditorium and of the sub-control room. As can be noted the permissible noise level of NC-25 can be expected to be met in the auditorium, the stage and the sub-control room.


戦艦時州の計算表

Table 1

Calculation of Reverberation Time of BTV Hall

Dimension
 I. Design Goal
 II. $V = 1745.3 \text{ m}^3$
 III. $S = 420.6 \text{ m}^2$
 IV. $T = 1.70 \text{ sec}$
 V. $T = 1.89 \text{ m}$ (at Full occupancy, with Stage Sound Reflectors)

A	
B	
C	
D	
天井	



Items	S	S _v	125 Hz		250 Hz		500 Hz		1000 Hz		2000 Hz		4000 Hz		6000 Hz			
			a _v	A _v	u _v	A _v	a _v	A _v	u _v	A _v	a _v	A _v	u _v	A _v	a _v	A _v	u _v	A _v
[1] with Stage Sound Reflectors	1745.3																	
1) when empty			175.304.5	206.357.0	207.360.9	200.349.5	187.326.2	196.344.5	207.362.0	147.137.1	139.115.1	131.108.0	131.108.0	131.108.0	131.108.0	131.108.0	131.108.0	131.108.0
Rev. Time ①			1.58	1.31	1.31	1.36	1.37	1.37	1.37	1.37	1.37	1.37	1.37	1.37	1.37	1.37	1.37	1.37
2) at full occupancy	1745.3		211.368.0	239.416.7	243.424.4	240.418.7	222.395.4	232.405.0	234.408.2	151.1	118.111.1	115.109.8	115.109.8	115.109.8	115.109.8	115.109.8	115.109.8	115.109.8
Rev. Time ②			1.28	1.11	1.09	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11
[2] with Stage Curtains (without Stage Sound Reflectors)	1745.3																	
1) when empty			182.318.3	222.386.6	235.408.3	239.417.2	227.396.7	235.408.2	248.432.5	151.1	118.111.1	113.107.0	113.107.0	113.107.0	113.107.0	113.107.0	113.107.0	113.107.0
Rev. Time ③			1.52	1.21	1.13	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11	1.11
2) at full occupancy	1745.3		219.381.8	255.444.3	271.422.8	279.486.4	267.465.9	271.472.7	274.478.7	151.1	118.111.1	113.107.0	113.107.0	113.107.0	113.107.0	113.107.0	113.107.0	113.107.0
Rev. Time ④			1.23	1.03	0.96	0.93	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98	0.98

() : 60% Relative Humidity NHH (標準)

Table 2

残響時間の計算(2)

NHK 建築

Liquid Absorption Factor I

Item	S	S/S	1.25 Hz		2.5 Hz		5.0 Hz		1000 Hz		2000 Hz		4000 Hz		8000 Hz	
			a.	A.	a.	A.	a.	A.	a.	A.	a.	A.	a.	A.	a.	A.
Floor	106.3		.20	21.3	.15	15.7	.12	12.2	.09	7.6	.07	7.6	.09	7.6	.10	10.6
Fine Carpet (Needle Punt)	85.0		.07	6.0	.07	6.0	.08	6.8	.10	8.5	.20	17.0	.30	25.5	.35	27.8
Carpet Floor (Vin. Tile)	4.8		.12	3.3	.10	6.5	.08	2.4	.04	6.2	.04	6.2	.05	6.2	.05	6.2
Carpet Tiles (46)	26.2		.13	3.4	.21	5.5	.27	7.6	.34	8.9	.32	8.4	.32	8.4	.34	8.9
Audience Seats (531)	302.7		.12	36.3	.20	10.5	.23	27.8	.34	152.9	.32	76.7	.32	76.7	.34	102.9
Auditor. Floor (Vin. Tile)	38.5		.03	1.2	.13	1.2	.14	1.5	.15	1.7	.06	2.3	.06	2.3	.07	2.7
Wall																
Stage Front (Hard Wood)	17.7		.10	1.4	.08	1.1	.15	0.7	.14	0.5	.05	1.7	.05	0.7	.06	0.8
Glass Windows - Minus	3.8		.15	1.3	.06	1.5	.14	0.4	.13	0.3	.02	5.2	.02	0.2	.03	0.3
Doors	13.3		.20	2.7	.15	2.0	.10	1.3	.10	1.3	.10	1.3	.12	1.6	.15	2.0
Plac-out Wall (M.S. Co.)	28.5		.03	1.9	.03	1.9	.03	0.7	.14	1.1	.14	1.1	.15	1.4	.15	1.4
Skirting (Hard Wood)	17.4		.03	1.6	.03	0.6	.14	0.8	.14	0.7	.05	1.0	.05	1.0	.06	1.2
Paints																
Paints - Opening for Loud Speaker	5.3		.20	1.1	.30	1.6	.40	2.1	.45	2.4	.50	2.7	.50	2.7	.55	2.9
Opening for Lighting	16.7		.30	5.0	.35	5.8	.40	6.7	.45	7.5	.50	8.4	.50	8.4	.50	8.4
Lighting Tools	2.3		.15	0.3	.13	0.3	.10	0.2	.09	0.2	.07	0.2	.05	0.1	.05	0.1
Air-ventilator & Nozzle	8.1		.135	10.1	.15	7.3	.155	8.1	.30	6.5	.73	5.9	.70	5.7	.70	5.7
Music																
Music Stage Sound Reflectors	138.2		.20	27.6	.15	20.7	.12	16.6	.06	8.3	.06	8.3	.07	7.7	.08	11.1
Reflector's Gap (Curtain) 46			.30	12.5	.35	14.6	.45	18.7	.60	25.0	.65	27.0	.70	27.1	.70	27.1
Drug-out Opening	2.7		.30	0.9	.35	1.0	.35	1.0	.35	1.0	.35	1.0	.35	1.0	.35	1.0
Total	862.3			133.2		148.0		174.4		156.9		192.2		254.5		291.1

Tsk-3

Sound Absorption Power 2

残響時間の計算(2)

NHK (建築)

Items	S	S/S	1.25Hz		2.50Hz		500Hz		1000Hz		2000Hz		4000Hz		8000Hz	
			a	A	a	A	a	A	a	A	a	A	a	A	a	A
Wall Sound Diffuser (A.C.B. 1.2W / A.S. 700)	28.6		.12	3.4	.10	2.7	.08	2.3	.16	1.7	.06	1.7	.08	2.3	.10	2.7
Asb. Cel. Board t=6 (7 ¹ / ₂ 15 ¹ / ₂) + GW t=50 + A.S. 350	17.4		.60	11.6	.85	16.5	.75	14.6	.85	16.5	.80	15.5	.65	12.6	.55	10.7
Asb. Cel. Board t=12 A.S. 400	20.8		.13	2.7	.11	2.3	.08	1.7	.06	1.2	.06	1.2	.07	1.5	.08	1.7
" " t=24 A.S. 350	89.1		.12	10.7	.10	8.9	.08	7.1	.06	5.3	.06	5.3	.06	5.3	.07	6.2
" " t=24 A.S. 400	73.6		.12	8.8	.10	7.1	.08	5.9	.06	4.4	.06	4.4	.07	5.2	.08	5.9
Other Part of Side Wall (t=24 A.S. 300) 45.7			.12	5.5	.10	4.6	.08	3.7	.06	2.7	.06	2.7	.06	2.7	.07	3.2
Side Wall of Lighting Spec. R (Asbestos Board t=24 A.S. 50)	36.4		.12	4.4	.10	3.6	.08	2.9	.06	2.2	.06	2.2	.06	2.2	.07	2.5
Rear Wall (Steel Rib (22x20, W=60) + A.S. 45 + Cloak + Asb. Board t=6 (9 ¹ / ₂ 15 ¹ / ₂) + GW t=50 + A.S. 150)	58.1		.55	32.0	.75	43.6	.84	48.8	.80	46.5	.70	40.7	.60	34.9	.50	29.1
Ceiling Asb. Flex. B. t=12 + GW t=50 A.S. 300	230.4		.18	41.5	.13	30.0	.10	23.0	.08	18.4	.08	18.4	.09	20.7	.10	23.0
" " t=6 + GW t=50 A.S. 50	46.2		.14	6.5	.12	5.5	.08	3.7	.06	2.8	.07	3.2	.08	3.7	.09	4.2
" " t=6 + GW t=50 A.S. 300	12.5		.20	2.5	.15	1.9	.07	1.1	.07	0.9	.07	0.9	.08	1.0	.10	1.3
" " t=6 SLED (300 + 300, W=100 + GW t=50 A.S. 70)	130.3		.15	19.5	.40	52.1	.42	54.7	.36	46.9	.21	27.4	.25	32.6	.28	36.5
Asb. Flex. B. t=6 + GW t=50 + A.S. 49.7			.22	10.9	.16	8.0	.10	5.0	.08	4.0	.08	4.0	.07	4.5	.10	5.0
Ceiling Boarder (Hard Wood) 13.9			.10	1.4	.08	1.1	.05	0.7	.04	0.6	.05	0.7	.05	0.7	.06	0.8
" " (Asb. C. B. t=6 (9 ¹ / ₂ 15 ¹ / ₂) + GW t=50 + A.S. 75)	28.3		.35	9.9	.80	22.6	.40	11.3	.30	8.5	.20	5.7	.25	7.1	.35	9.9
Total	883.0			171.3		211.0		126.5		112.6		134.0		137.0		142.9

Table 4

残響時間の計算(2)

Total Sound Absorption Power

NHK 建築

Items	S ₁	S ₁ S	125Hz		250Hz		500Hz		1000Hz		2000Hz		4000Hz		8000Hz		
			a.	A.	a.	A.	a.	A.	a.	A.	a.	A.	a.	A.	a.	A.	a.
[1] With Stage Sound Reflectors																	
1) when empty																	
sound absorption power	262.3		132.2	148.0	174.4	186.7	112.2	204.5	217.1								
sound absorption Power 2	883.0		171.3	211.0	126.5	162.6	124.0	157.0	142.9								
	1745.3	①	175.304.5	206.359.0	247.360.7	200.343.5	127.326.2	176.341.5	207.362.0								
2) at Full Occupancy																	
additional sound absorption																	
Power by Audiences (570)		②	11.63.5	10.57.7	11.63.5	12.61.2	12.61.2	11.63.5	12.46.2								
	1745.3	①+②	211.352.0	237.416.7	242.024.4	240.412.7	227.315.4	232.405.0	234.408.2								
[2] With Stage Curtains (Without Stage Sound Reflectors)																	
1) when empty																	
additional sound absorption																	
power by curtains	138.2	③	10.13.8	20.27.6	35.46.4	49.67.7	51.70.5	47.67.7	51.70.5								
	1745.3	①+③	182.372.3	222.386.6	235.401.3	237.417.2	227.376.7	235.407.2	248.432.5								
2) at Full Occupancy																	
	1745.3	①+②	217.381.8	255.444.3	271.472.8	279.486.4	267.465.9	271.472.7	274.482.7								
		①+③															

Table 5 Calculation of Ventilation Noise Insulation (for Fan Noise)

Date :

Building BTV Hall

Room Name Audience Hall Ducting Rout AC-2 (Supply) Type of Fan SF-2 11.0KW

Object of Room : Auditorium

Horsepower of Fan : $HP = 14.7$

Volume of Use : $V = 3291.5 \text{ m}^3$

Power Level of Fan : $PWL = 90 + 10 \log HP = 101.7 \text{ dB}$

Total Surface Area of Room : $S = 1745.3 \text{ m}^2$

Total Amount of Ventilation : $F = 18300 \text{ m}^3$

Mean Absorption Coefficient : $\bar{\alpha} = 0.21$

Amount of Ventilation at Opening : $f = 610 \text{ m}^3$

Absorbing Power : $A = S\bar{\alpha} = 360.7 \text{ m}^2$

Divisional Ratio : $K_b = 10 \log \frac{f}{F} = -14.8 \text{ dB}$

Room Constant : $R = S\bar{\alpha} / (1 - \bar{\alpha}) = 455.1$

Number of Ventilation Opening : $n = 30$

Type of Ventilation Opening : Anemostat

Effective Number of Ventilation Opening : $n_e = 3$

Dimension of Ventilation Opening : $s = 0.0398 \text{ m}^2$

$\gamma_c = 0.14 \sqrt{QR} = 4.2$ $\gamma_{min} = 3.0$

Directivity Factor : $Q = 2$

$SPL_{n_e} = 10 \log \frac{Q}{4\pi R^2} + 10 \log n_e = -12.8$ $SPL_{n-n_e} = 10 \log \frac{4}{R} + 10 \log (n - n_e) = -6.2$ $\Delta L = -6.6 \text{ dB}$

$N_j = \frac{1}{6}$ $N_{D_i} = 0.223$ $N_D = \frac{1}{2}$ $X = 10 \log N_j \cdot N_{D_i} \cdot N_D = -17.3 \text{ dB}$

Radiation Coefficient $K_r = 10 \log \left(\frac{Q}{4\pi R^2} + \frac{4}{R} \right) = -15.8 \text{ dB}$

Noise Criterion Value $NC = 25$ Ventilation Velocity : $V = 4.2 \text{ m}$

	Octave Band Frequency	63	125	250	500	1000	2000	4000	8000	Notes
1	P.W.L. of Fan	96.7	75.7	74.7	73.7	71.7	68.7	63.7	58.7	
2	K_b	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	-14.8	
3	Correction of Other Noise	-	-	-	-	-	-	-	-	
4	Attenuation at Opening	-14.5	-11.5	-5.5	-2.5	-0.5	-	-	-	
5	P.W.L. of Ventilation Open.	67.4	69.4	74.4	76.4	76.4	73.9	68.9	63.9	(1)+(2)-(3)+(4)
6	Permissible Noise SPL	57	47	39	32	28	25	22	21	
7	$-10 \log n_e + X$	-24.1	-24.1	-24.1	-24.1	-24.1	-24.1	-24.1	-24.1	
8	$-K_r$	15.5	15.2	15.2	15.2	15.2	15.2	15.8	15.8	
9	Permissible Band P.W.L. of Noise at Vent. Opening	50.7	40.7	32.7	25.7	21.7	18.7	15.7	14.7	(6)-(7)+(8)
10	Necessary Attenuation - Val(1)	16.7	28.7	41.7	50.7	54.7	55.2	53.2	49.2	(5)-(9)
11	CH ₁ (1.6 x 1.5 x 1.2)	3	6	6.5	7	8	8	7	7	
	CH ₂ (1.5 x 0.75 x 1.6)	3	6	6.5	7	8	8	7	7	
	EL ₁ (0.7 x 0.55)	5	7.5	8.5	12.5	13.5	14	13.5	13.5	
	CH ₃ (0.95 x 0.5 x 1.5)	2	4	5	6	6	6	6	6	
	CH ₄ (1.1 x 0.7 x 0.7)	2	4	5	6	6	6	6	6	
	EL ₂ (0.1 x 0.5)	5	6.5	7	12.5	14.5	15.5	13	12.5	
	EL ₃ (2.25')	1	1	2.5	5.5	15	19	11	14	
	CH ₅ (0.65 x 0.65 x 0.35)	-	-	-	-	-	-	-	-	
	Total	22	38	47	57	65	65	63	63	

Table. 6 Calculation of Ventilation Noise Insulation (for Fan Noise)

Building BTV Hall

Date :

Room Name Audience Hall Ducting Rout AC-2 (Return) Type of Fan (SF-2 11.0 KW / FT-2 5.5 KW)

Object of Room : Auditorium Horsepower of Fan : $HP_1 = 14.7$ $HP_2 = 7.3$
 Volume of Use : $V = 3271.5 \text{ m}^3$ Power Level of Fan : $PWL = 90 + 10 \log HP_1 = 101.7 \text{ dB}$
 $PWL_2 = 90 + 10 \log HP_2 = 96.7 \text{ dB}$
 Total Surface Area of Room : $S = 1745.3 \text{ m}^2$ Total Amount of Ventilation : $F = 19520 \text{ m}^3$
 Mean Absorption Coefficient : $\bar{\alpha} = 0.21$ Amount of Ventilation at Opening : $f = 610 \text{ m}^3$
 Absorbing Power : $A = S\bar{\alpha} = 360.7 \text{ m}^2$ Divisional Ratio : $K_b = 10 \log \frac{f}{A} = -15.1 \text{ dB}$
 Room Constant : $R = S\bar{\alpha} / (1 - \bar{\alpha}) = 455.1 \text{ m}^2$ Number of Ventilation Opening : $N = 3$
 Type of Ventilation Opening : Anemolite Effective Number of Ventilation Opening : $N_e = 3$
 Dimension of Ventilation Opening : $S = 0.0398 \text{ m}^2$ $r_c = 0.14\sqrt{QR} = 4.2 \text{ m}$ $r_{min} = 3.0 \text{ m}$
 Directivity Factor : $Q = 2$

$SPL_{N_e} = 10 \log \frac{Q}{4\pi r_c^2} + 10 \log N_e = -12.8 \text{ dB}$ $SPL_{N-N_e} = 10 \log \frac{Q}{R} + 10 \log (N - N_e) = -6.2 \text{ dB}$ $\Delta L = -6.6 \text{ dB}$
 $N_j = \frac{1}{2}$ $N_{D_i} = 0.268$ $N_D = \frac{1}{2}$ $X = 10 \log N_j \cdot N_{D_i} \cdot N_D = -16.5 \text{ dB}$
 Radiation Coefficient $K_r = 10 \log \left(\frac{Q}{4\pi r_c^2} + \frac{1}{R} \right) = -15.8 \text{ dB}$
 Noise Criterion Value $NC = 25$ Ventilation Velocity : $v = 4.2 \text{ m}$

	Octave Band Frequency	63	125	250	500	1000	2000	4000	8000	Notes
1	PWL of Fan	87.3	87.3	86.0	85.0	83.0	80.1	75.2	70.2	
2	K_b	-15.1	-15.1	-15.1	-15.1	-15.1	-15.1	-15.1	-15.1	
3	Correction of Other Noise	-	-	-	-	-	-	-	-	
4	Attenuation at Opening	-14.5	-11.5	-5.5	-2.5	-0.5	-	-	-	
5	PWL of Ventilation Open.	59.7	60.7	65.4	67.4	67.4	65.0	60.1	55.1	(1)+(2)+(3)+(4)
6	Permissible Noise SPL	57	47	37	32	28	25	22	21	
7	$-10 \log N_e + X$	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	-21.3	
8	$-K_r$	15.8	15.8	15.8	15.8	15.8	15.8	15.8	15.8	
9	Permissible Band PWL of Noise at Vent. Opening	51.5	41.3	33.5	26.5	22.5	19.5	16.5	15.5	(6)+(7)+(8)
10	Necessary Attenuation Value	8.2	19.4	31.9	40.9	44.9	45.5	43.6	39.6	(5)-(9)
11	$CH_1 (1.1 \times 0.9 \times 1.6) \text{ (T)}$	2	4	5	6	6	6	6	6	
	$CH_2 (1.1 \times 0.95 \times 1.6) \text{ (T)}$	2	4	5	6	6	6	6	6	
	$EL_1 (0.6 \times 0.56)$	5	7.5	8.5	12.5	13.5	14	13.5	13.5	
	$CH_3 (1.0 \times 0.9 \times 0.85)$	3	6	6.5	7	8	8	7	7	
	$EL_2 (0.62 \times 0.55) \times 3$	15	22.5	25.5	37.5	40.5	42	40.5	40.5	
	$CH_4 (0.65 \times 0.65 \times 0.35)$	-	-	-	-	-	-	-	-	
	Total	27	44	50.5	69	74	76	73	73	

Table 7 Calculation of Ventilation Noise Insulation (for Fan Noise)

Date :

Building ETV Hill

Room Name Stage

Ducting Route A-1 (1.11)

Type of Fan RT-1 30KW

Object of Room : stage

Horsepower of Fan : $HP = 40$

Volume of Use : $V = 8067 \text{ m}^3$

Power Level of Fan : $PWL = 90 + 10 \log HP = 106.0 \text{ dB}$

Total Surface Area of Room : $S = 1247 \text{ m}^2$

Total Amount of Ventilation : $F = 56000 \text{ m}^3/\text{h}$

Mean Absorption Coefficient : $\bar{\alpha} = 0.40$

Amount of Ventilation at Opening : $f = 1400 \text{ m}^3/\text{h}$

Absorbing Power : $A = S\bar{\alpha} = 1247 \text{ m}^2$

Divisional Ratio : $K_b = 10 \log \frac{f}{F} = -16 \text{ dB}$

Room Constant : $R = S\bar{\alpha}/(1-\bar{\alpha}) = 2077.8 \text{ m}^2$

Number of Ventilation Opening : $N = 40$

Type of Ventilation Opening : Rect

Effective Number of Ventilation Opening : $N_e = 20$

Dimension of Ventilation Opening : $s = 0.5 \text{ m}$

$V_e = 0.14\sqrt{QR} = 9.0 \text{ m}^2$ $\gamma_{\min} = 2.0 \text{ m}$

Directivity Factor : $Q = 2$

$$SPL_{nc} = 10 \log \frac{Q}{4\pi r^2} + 10 \log N_e = -1.0 \text{ dB} \quad SPL_{n-ne} = 10 \log \frac{4}{R} + 10 \log (N - N_e) = -14.2 \text{ dB} \quad \Delta L = 13.2 \text{ dB}$$

$$N_j = \frac{1}{20} \quad N_{di} = 0.684 \quad N_D = \frac{1}{2} \quad X = 10 \log N_j \cdot N_{di} \cdot N_D = -17.7 \text{ dB}$$

$$\text{Radiation Coefficient } K_r = 10 \log \left(\frac{Q}{4\pi r^2} + \frac{4}{R} \right) = -13.8 \text{ dB}$$

$$\text{Noise Criterion Value } NC = 25$$

	Octave Band Frequency	63	125	250	500	1000	2000	4000	8000	Notes
1	PWL of Fan	101.0	100.0	99.0	98.0	96.0	93.0	88.0	83.0	
2	K_b	-16	-16	-16	-16	-16	-16	-16	-16	
3	Correction of Other Noise	-	-	-	-	-	-	-	-	
4	Attenuation at Opening	-6	-3	-1	-	-	-	-	-	
5	PWL of Ventilation Open.	77.0	81.0	82.0	82.0	80.0	77.0	72.0	67.0	(1)+(2)+(3)+(4)
6	Permissible Noise SPL	57	47	37	32	28	25	22	21	
7	$-10 \log N_e + X$	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	-30.7	
8	$-K_r$	13.8	13.8	13.8	13.8	13.8	13.8	13.8	13.8	
9	Permissible Band PWL of Noise at Vent. Opening	40.1	30.1	22.1	15.1	11.1	8.1	5.1	4.1	(6)+(7)+(8)
10	Necessary Attenuation Value	38.9	50.9	59.9	66.9	68.9	68.9	66.9	62.9	(5)-(9)
11	11.1 (3.3x1.7x1.5)	3	6	6.5	7	8	8	7	7	
	EL ₁ (1.2x1.2) x6	36	60	66	84	72	78	84	84	
	EL ₂ (1.2x1.2)	-	-	-	-	-	-	-	-	
	Total	39	66	72.5	91	80	86	91	91	

Table E Calculation of Ventilation Noise Insulation (for Fan Noise)

Date :

Building BTV Hall

Room Name Stage Ducting Rout AC-1 (Return) Type of Fan SF-1 30KW

Object of Room : Stage

Horsepower of Fan : $HP = 40$

Volume of Use : $V = 8067.7 \text{ m}^3$

Power Level of Fan : $PWL = 90 + 10 \log HP = 106.0$

Total Surface Area of Room : $S = 3119.7 \text{ m}^2$ Total Amount of Ventilation : $F = 56000 \text{ m}^3$

Mean Absorption Coefficient : $\bar{\alpha} = 0.40$ Amount of Ventilation at Opening : $f = 24640 \text{ m}^3$

Absorbing Power : $A = S\bar{\alpha} = 1247.7 \text{ m}^2$ Divisional Ratio : $K_b = 10 \log \frac{f}{F} = -3.6 \text{ dB}$

Room Constant : $R = S\bar{\alpha}/(1-\bar{\alpha}) = 2077.8 \text{ m}^2$ Number of Ventilation Opening : $n = 2$

Type of Ventilation Opening :

Effective Number of Ventilation Opening : $n_e = 1$

Dimension of Ventilation Opening : $s = 5.4 \text{ m}^2$ $r_c = 0.14\sqrt{QR} = 9.0 \text{ m}$ $r_{min} = 6.0 \text{ m}$

Directivity Factor : $Q = 2$

$$SPL_{n_e} = 10 \log \frac{Q}{4\pi r_c^2} + 10 \log n_e = -23.5 \text{ dB} \quad SPL_{n-n_e} = 10 \log \frac{f}{R} + 10 \log (n-n_e) = -27.2 \text{ dB} \quad \Delta L = 3.7 \text{ dB}$$

$$N_j = \frac{1}{2} \quad N_{di} = 0.77 \quad N_d = \frac{1}{2} \quad X = 10 \log N_j \cdot N_{di} \cdot N_d = -7.2 \text{ dB}$$

$$\text{Radiation Coefficient } K_r = 10 \log \left(\frac{Q}{4\pi r_c^2} + \frac{f}{R} \right) = -13.8 \text{ dB}$$

$$\text{Noise Criterion Value } NC = 25$$

$$\text{Ventilation Velocity : } v = 1.3 \text{ m}$$

	Octave Band Frequency	63	125	250	500	1000	2000	4000	8000	Notes
1	PWL. of Fan	96.0	95.0	94.0	93.0	91.0	88.0	83.0	78.0	
2	K_b	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	-3.6	
3	Correction of Other Noise	-	-	-	-	-	-	-	-	
4	Attenuation at Opening	-	-	-	-	-	-	-	-	
5	PWL. of Ventilation Open.	92.4	91.4	90.4	89.4	87.4	84.4	79.4	74.4	(1)+(2)+(3)+(4)
6	Permissible Noise SPL.	57	47	37	32	28	25	22	21	
7	$-10 \log n_e + X$	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	-7.2	
8	$-K_r$	13.8	13.8	13.8	13.8	13.8	13.8	13.8	13.8	
9	Permissible Band PWL. of Noise at Vent. Opening	63.6	53.6	45.6	38.6	34.6	31.6	28.6	27.6	(6)+(7)+(8)
10	Necessary Attenuation Value	28.8	37.8	44.8	50.8	52.8	52.8	50.8	46.8	(5)-(9)
11	$CH_1 (3.7 \times 1.7 \times 2.65)$	3	6	6.5	7	8	8	7	7	
	$EL_1 (1.2 \times 1.0) \times 5$	25	45	50	55	60	60	60	60	
	$CH_2 (1.4 \times 1.2 \times 2.2) \text{ I}$	2	4	5	6	6	6	6	6	
	$CH_3 (3.4 \times 2.2 \times 1.5)$	-	-	-	-	-	-	-	-	
	Total	30	55	57	68	74	74	73	73	

Table 7 Calculation of Ventilation Noise Insulation (for Fan Noise)

Building BTV Hall

Date :

Room Name Sub-Cent. Room Ducting Rout A.C. 5 (Supply) Type of Fan BF-5 3.7 Kw

Object of Room : V.A.L. Control

Horsepower of Fan : HP = 4.9

Volume of Use : V = 190.0 m³

Power Level of Fan : PWL = 90 + 10 log HP = 96.9 dB

Total Surface Area of Room : S = 262.8 m² Total Amount of Ventilation : F = 4150 m³

Mean Absorption Coefficient : $\bar{\alpha} = 0.3$ Amount of Ventilation at Opening : f = 635 m³

Absorbing Power : A = S $\bar{\alpha}$ = 78.8 m² Divisional Ratio : $K_b = 10 \log \frac{f}{F} = -8.2$ dB

Room Constant : R = S $\bar{\alpha}$ / (1 - $\bar{\alpha}$) = 112.6 m² Number of Ventilation Opening : N = 4

Type of Ventilation Opening : Annular slot Effective Number of Ventilation Opening : Ne = 2

Dimension of Ventilation Opening : s = 0.03 m $r_c = 0.14 \sqrt{QR} = 2.1$ m $r_{min} = 1.2$ m

Directivity Factor : Q = 2

$SPL_{ne} = 10 \log \frac{Q}{4\pi r_c^2} + 10 \log ne = -6.6$ dB $SPL_{n-ne} = 10 \log \frac{f}{R} + 10 \log (N - ne) = -11.5$ dB $AL = 4.9$ dB

$N_j = \frac{1}{4}$ $N_{di} = 0.61$ $N_d = \frac{1}{3}$ $X = 10 \log N_j \cdot N_{di} \cdot N_d = -12.9$ dB

Radiation Coefficient $K_r = 10 \log (\frac{Q}{4\pi r_c^2} + \frac{1}{R}) = -8.4$ dB

Noise Criterion Value NC = 25 Ventilation Velocity : v = 5.4 m

	Octave Band Frequency	63	125	250	500	1000	2000	4000	8000	Notes
1	PWL of Fan	91.9	90.9	87.9	88.9	86.9	83.9	78.9	73.9	
2	K_b	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	-8.2	
3	Correction of Other Noise	-	-	-	-	-	-	-	-	
4	Attenuation at Opening	-14.5	-11.5	-5.5	-2.5	-0.5	-	-	-	
5	PWL of Ventilation Open.	69.2	71.2	76.2	78.2	78.2	75.7	70.7	65.7	(1)+(2)+(3)+(4)
6	Permissible Noise SPL	57	47	39	32	28	25	22	21	
7	-10 log Ne + X	-15.9	-15.9	-15.9	-15.9	-15.9	-15.9	-15.9	-15.9	
8	-K _r	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	
9	Permissible Band PWL of Noise at Vent. Opening	49.5	39.5	31.5	24.5	20.5	17.5	14.5	13.5	(6)+(7)+(8)
10	Necessary Attenuation Value	19.7	31.7	44.7	53.7	57.7	58.2	56.2	52.2	(9)-(1)
11	CH ₁ (1.0 x 0.8 x 0.8)	3	6	6.5	7	8	8	7	7	
	EL ₁ (0.45 x 0.3) x 2	9	12	16	25	27	26	24	26	
	CH ₂ (1.2 x 0.7 x 0.5)	3	6	6.5	7	8	8	7	7	
	EL ₂ (1.05 x 0.2)	6	7	7	11	14	14	14	14	
	CH ₃ (0.6 x 0.6 x 0.4)	3	6	6.5	7	8	8	7	7	
	Total	24	37	44.5	57	67	64	59	61	

Table 10 Calculation of Ventilation Noise Insulation (for Fan Noise)

Date :

Building BTV Hall

Room Name Sub-Cont. Room Ducting Route A' 5 (Return) Type of Fan SF-5 3.7KW

Object of Room : V.A.L Control

Horsepower of Fan : $HP = 4.9$

Volume of Use : $V = 170.0 \text{ m}^3$

Power Level of Fan : $PWL = 90 + 10 \log HP = 76.7 \text{ dB}$

Total Surface Area of Room : $S = 262.8 \text{ m}^2$ Total Amount of Ventilation : $F = 4150 \text{ m}^3$

Mean Absorption Coefficient : $\bar{\alpha} = 0.3$ Amount of Ventilation at Opening : $f = 3670 \text{ m}^3$

Absorbing Power : $A = S\bar{\alpha} = 78 \text{ m}^2$ Divisional Ratio : $K_b = 10 \log \frac{f}{F} = -0.5 \text{ dB}$

Room Constant : $R = S\bar{\alpha}/1 - \bar{\alpha} = 112.6 \text{ m}^2$ Number of Ventilation Opening : $n = 1$

Type of Ventilation Opening :

Effective Number of Ventilation Opening : $n_e = 1$

Dimension of Ventilation Opening : $s = 0.5 \text{ m}^2$ $r_c = 0.14\sqrt{QR} = 2.1 \text{ m}$ $r_{\min} = 2.1 \text{ m}$

Directivity Factor : $Q = 2$

$$SPL_{n_e} = 10 \log \frac{Q}{4\pi r^2} + 10 \log n_e = \quad SPL_{n-n_e} = 10 \log \frac{f}{R} + 10 \log (n-n_e) = \quad \Delta L =$$

$$N_j = 1 \quad N_{di} = 0.27 \quad N_D = \frac{1}{3} \quad X = 10 \log N_j \cdot N_{di} \cdot N_D = -5.3 \text{ dB}$$

$$\text{Radiation Coefficient } K_r = 10 \log \left(\frac{Q}{4\pi r^2} + \frac{f}{R} \right) = -8.4 \text{ dB}$$

$$\text{Noise Criterion Value } NC = 25 \quad \text{Ventilation Velocity : } v = 2.0 \text{ m}$$

	Octave Band Frequency	63	125	250	500	1000	2000	4000	8000	Notes
1	P.W.L. of Fan	86.7	85.9	84.9	83.9	81.9	78.9	73.9	68.9	
2	K_b	-0.5	-0.5	-0.5	-0.5	-0.5	-0.5	-0.5	-0.5	
3	Correction of Other Noise	-	-	-	-	-	-	-	-	
4	Attenuation at Opening	-6	-3	-1	-	-	-	-	-	
5	P.W.L. of Ventilation Open.	80.4	82.4	83.4	83.4	81.4	78.4	73.4	68.4	(1)+(2)-(3)+(4)
6	Permissible Noise SPL	57	47	39	32	28	25	22	21	
7	$-10 \log n_e + X$	-5.3	-5.3	-5.3	-5.3	-5.3	-5.3	-5.3	-5.3	
8	$-K_r$	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	
9	Permissible Band P.W.L. of Noise at Vent. Opening	60.1	50.1	42.1	35.1	31.1	28.1	25.1	24.1	(6)+(7)+(8)
10	Necessary Attenuation Value	20.3	32.3	41.3	48.3	50.3	50.3	48.3	44.3	(5)-(9)
11	$CH_1 (1.25 \times 1.0 \times 0.8)$	3	6	6.5	7	8	8	7	7	
	$EL_1 (0.45 \times 0.3) \times 2$	9	12	14	25	27	26	24	26	
	$EL_2 (0.45 \times 0.3) \times 2$	9	12	14	25	27	26	24	26	
	$CH_2 (1.25 \times 0.7 \times 0.5)$	3	6	6.5	7	8	8	7	7	
	Total	24	36	41	64	74	68	62	66	

Table 11 Calculation of Ventilation Noise Insulation (for Fan Noise)

Building BTV Hall

Date: _____

Room Name Sub-Cont. Room Ducting Rout Fan Coil Unit Type of Fan _____

Object of Room :

Horsepower of Fan : $HP =$

Volume of Use : $V = 170.0 \text{ m}^3$

Power Level of Fan : $PWL = 90 + 10 \log HP =$

Total Surface Area of Room : $S = 262.8 \text{ m}^2$ Total Amount of Ventilation : $F =$

Mean Absorption Coefficient : $\bar{\alpha} = 0.3$ Amount of Ventilation at Opening : $f =$

Absorbing Power : $A = S\bar{\alpha} = 78.8 \text{ m}^2$ Divisional Ratio : $K_b = 10 \log \frac{f}{F} =$

Room Constant : $R = S\bar{\alpha}/(1-\bar{\alpha}) = 112.6 \text{ m}^2$ Number of Ventilation Opening : $N = 3$

Type of Ventilation Opening :

Effective Number of Ventilation Opening : $N_e = 2$

Dimension of Ventilation Opening : $s = 0.22 \text{ m}$ $\gamma_c = 0.14\sqrt{QR} = 2.1 \text{ m}$ $\gamma_{min} = 1.2 \text{ m}$

Directivity Factor : $Q = 2$

$SPL_{N_e} = 10 \log \frac{Q}{4\pi r^2} + 10 \log N_e = -6.6 \text{ dB}$ $SPL_{N-N_e} = 10 \log \frac{F}{R} + 10 \log (N-N_e) = -14.5 \text{ dB}$ $\Delta L = 7.9 \text{ dB}$

$N_j = \frac{1}{2}$ $N_{di} = \frac{1}{2}$ $N_D = \frac{1}{3}$ $X = 10 \log N_j \cdot N_{di} \cdot N_D = -10.8$

Radiation Coefficient $K_r = 10 \log \left(\frac{Q}{4\pi r^2} + \frac{F}{R} \right) = -8.4 \text{ dB}$

Noise Criterion Value $NC = 25$

	Octave Band Frequency	63	125	250	500	1000	2000	4000	8000	Notes
1	P.W.L. of Fan	48.2 (44.2)	57.2 (48.2)	55.2 (42.2)	52.2 (37.7)	46.7 (33.7)	39.2 (25.7)	31.2 (22.7)	24.7 (21.7)	'High (Low)
2	K_b	-	-	-	-	-	-	-	-	
3	Correction of Other Noise	-	-	-	-	-	-	-	-	
4	Attenuation at Opening	-	-	-	-	-	-	-	-	
5	P.W.L. of Ventilation Open.	48.2 (44.2)	57.2 (48.2)	55.2 (42.2)	52.2 (37.7)	46.7 (33.7)	39.2 (25.7)	31.2 (22.7)	24.7 (21.7)	(1)+(2)+(3)+(4)
6	Permissible Noise SPL	57	47	39	32	28	25	22	21	
7	$-10 \log N_e + X$	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	-13.8	
8	$-K_r$	8.4	8.4	8.4	8.4	8.4	8.4	8.4	8.4	
9	Permissible Band P.W.L. of Noise at Vent. Opening	51.6	41.6	33.6	26.6	22.6	19.6	16.6	15.6	(6)+(7)+(8)
10	Necessary Attenuation Value	-	15.6 (6.6)	21.6 (8.6)	25.6 (11.1)	24.1 (11.1)	19.6 (6.1)	14.6 (6.1)	9.1 (6.1)	(5)-(9)
	CH (2.8 x 0.7 x 0.25)	6	9	12	12	12	12	12	12	
	Necessary to use two absorbent-chambers in case of "High" operation. Sufficient in case of "Low" operation.									
11										

3. Calculation Sheet of Ventilation and Air Conditioning

AIR CONDITION

DESIGN CONDITONS

1. OUTDOOR

D.B	35°C
R.H	90%
i (ENTHALPY)	28.5 Kcal/Kg

2. INDOOR

A) SUB-CONTROL ROOM SYSTEM

D.B	24°C
R.H	55%
i (ENTHALPY)	12.0 Kcal/Kg

B) OTHER SYSTEMS

D.B	26°C
R.H	55%
i (ENTHALPY)	13.3 Kcal/Kg

3. VOLUME OF OUTDOOR AIR

A) STAGE SYSTEM	26 m ³ /Hr · PERSON
B) OTHER ROOM SYSTEMS	15 m ³ /Hr · PERSON

4. CALORIFIC VALUE BY EQUIPMENTS

Calorific value by equipments is estimated at 860 Kcal/Hr for 1 Kw, and that by fluorescent lamp is estimated at 1000 Kcal/Hr for 1 Kw (electric power).

5. CALORIFIC VALUE BY PERSON IN ROOM FOR EACH PERSON

A) ROOM TEMP. ----- 26°C (D.B)

	SENSIBLE HEAT	LATENT HEAT
AUDITORIUM	53 Kcal/Hr	35 Kcal/Hr
ROOM (OFFICE ROOM ETC.)	54	46
CANTEEN	60	78
STAGE	69	144

B) ROOM TEMP. ----- 24°C (D.B)

	SENSIBLE HEAT	LATENT HEAT
SUB-CONTROL ROOM RACK ROOM	60 Kcal/Hr	40 Kcal/Hr

6. EQUIVALENT TEMPERATURE DIFFERENCE

	H	NE	SE	SW	NW
8 o'clock	14.6	8.6	9.4	10.2	9.4
12	15.1	8.6	9.4	10.2	9.3
16	23.1	13.6	14.6	11.3	11.0

7. VALUE OF SOLAR RADIATION THROUGH WINDOWS


	H	NE	SE	SW	NW
8 o'clock	334	334	271	33	33
12	667	38	60	38	38
16	334	33	33	271	334

8. AIR INFILTRATION

ROOM VOLUME	50m ³	100m ³	200m ³	300m ³	400m ³	500m ³	1000m ³
ONE-FACE WALL FACED OUTDOOR AIR	1.2	0.9	0.6	0.5	0.4	0.4	0.3
TWO-FACE WALL FACED OUTDOOR AIR	2.0	1.4	1.0	0.8	0.7	0.6	0.4
THREE-FACE WALL FACED OUTDOOR AIR	2.7	1.9	1.5	1.1	0.9	0.8	0.6
FOUR-FACE WALL FACED OUTDOOR AIR	3.4	2.3	1.6	1.3	1.1	1.0	0.7


9. HEAT TRANSMISSION COEFFICIENT

A) EXTERNAL WALL



r ₀	OUTDOOR			= 0.050
r ₁	BRICK	120 ^{mm}	0.12 / 0.52	= 0.231
r ₂	CONCRETE	150	0.15 / 1.4	= 0.107
r ₃	MORTAR	30	0.03 / 1.2	= 0.025
r ₄	TILE	10	0.01 / 1.1	= 0.009
r _i	INDOOR			= 0.133
				0.555

$$K = 1 / 0.555 = 1.802 \text{ Kcal/m}^2\text{Hr}$$




r ₀	OUTDOOR			= 0.050
r ₁	BRICK	120	0.12 / 0.52	= 0.231
r ₂	CONCRETE	150	0.15 / 1.4	= 0.107
r ₃	CEMENTED CHIP BOARD	30	0.03 / 0.11	= 0.273
r _i	INDOOR			= 0.133
				0.794

$$K = 1 / 0.794 = 1.259$$




r ₀	OUTDOOR			= 0.050
r ₁	CONCRETE	300	0.30 / 1.4	= 0.214
r ₂	MORTAR	30	0.03 / 1.2	= 0.025
r ₃	MARBLE	25	0.025 / 2.4	= 0.011
r _i	INDOOR			= 0.133
				0.433

$$K = 1 / 0.433 = 2.309$$




r ₀	OUTDOOR			0.050
r ₁	MORTAR	25	0.025 / 1.3	= 0.019
r ₂	BRICK	120	0.12 / 0.52	= 0.231
r ₃	CONCRETE	75	0.075 / 1.3	= 0.058
r ₄	BRICK	190	0.19 / 0.52	= 0.366
r ₅	AIR GAP			0.170
r ₆	GLASS WOOL	50	0.05 / 0.036	= 1.389
r ₇	PLASTER BOARD	6	0.006 / 0.13	= 0.046
r ₈	INDOOR			0.133
				2.462

$$K = 1 / 2.462 = 0.406$$



10	OUTDOOR			= 0.050
11	MORTAR	25	0.025 / 1.3	= 0.019
12	CONCRETE	150	0.15 / 1.3	= 0.115
13	MORTAR	25	0.025 / 1.2	= 0.021
14	INDOOR			= 0.133
				<hr/>
				0.338


$$K = 1 / 0.338 = 2.958$$



10	OUTDOOR			= 0.050
11	BRICK	120	0.12 / 0.52	= 0.231
12	CONCRETE	150	0.15 / 1.4	= 0.107
13	MORTAR	30	0.03 / 1.3	= 0.023
14	INDOOR			= 0.133
				<hr/>
				0.544


$$K = 1 / 0.544 = 1.838$$

B) INTERNAL WALL




11	INDOOR			= 0.133
11	MARBLE	25	0.025 / 2.4	= 0.010
12	MORTAR	30	0.03 / 1.2	= 0.025
13	BRICK	120	0.12 / 0.52	= 0.231
1a	AIR GAP			= 0.170
14	BRICK	120	0.12 / 0.52	= 0.231
15	MORTAR	24	0.024 / 1.2	= 0.020
16	TILE	6	0.006 / 1.1	= 0.005
17	INDOOR			= 0.133
				<hr/>
				0.958

$$K = 1 / 0.958 = 1.044$$



11	INDOOR			= 0.133
11	MORTAR	25	0.025 / 1.2	= 0.021
12	CONCRETE	150	0.15 / 1.3	= 0.115
13	MORTAR	25	0.025 / 1.2	= 0.021
14	INDOOR			= 0.133
				<hr/>
				0.423

$$K = 1 / 0.423 = 2.364$$



1	INDOOR			= 0.133
2	PLASTER BOARD	25	0.025 / 0.13	= 0.046
3	GLASS WOOL	150	0.15 / 0.036	= 1.389
3	CONCRETE	25	0.025 / 1.3	= 0.115
1	INDOOR			= 0.133

1.816


$$K = 1 / 1.816 = 0.551$$



1	INDOOR			= 0.133
2	MARBLE	25	0.025 / 2.4	= 0.010
3	MORTAR	30	0.03 / 1.2	= 0.025
3	CONCRETE	150	0.15 / 1.3	= 0.115
4	MORTAR	25	0.025 / 1.2	= 0.021
1	INDOOR			= 0.133

0.437


$$K = 1 / 0.437 = 2.288$$



1	INDOOR			= 0.133
2	GLASS WOOL	50	0.05 / 0.036	= 1.389
3	CONCRETE	150	0.15 / 1.3	= 0.115
3	GLASS WOOL	50	0.05 / 0.036	= 1.389
4	ASBESTUS CEMENT BOARD	8	0.008 / 0.22	= 0.036
1	INDOOR			= 0.133

3.195

$$K = 1 / 3.195 = 0.313$$



1	INDOOR			= 0.133
2	MORTAR	25	0.025 / 1.2	= 0.021
3	CONCRETE	150	0.15 / 1.3	= 0.115
3	GLASS WOOL	50	0.05 / 0.036	= 1.389
4	ASBESTUS CEMENT BOARD	8	0.008 / 0.22	= 0.036
1	INDOOR			= 0.133

1.827


$$K = 1 / 1.827 = 0.547$$



1	INDOOR			= 0.133
2	CONCRETE	150	0.15 / 1.3	= 0.115
3	GLASS WOOL	50	0.05 / 0.036	= 1.389
3	ASBESTUS CEMENT BOARD	8	0.008 / 0.22	= 0.036
1	INDOOR			= 0.133

1.806

$$K = 1 / 1.806 = 0.554$$



1	INDOOR				= 0.133
2	PLASTER BOARD	6	0.006 / 0.13		= 0.046
3	GLASS WOOL	50	0.05 / 0.036		= 1.389
4	AIR GAP				= 0.170
5	CONCRETE	150	0.15 / 1.3		= 0.115
6	GLASS WOOL	50	0.05 / 0.036		= 1.389
7	ASBESTUS CEMENT BOARD	8	0.008 / 0.22		= 0.036
8	INDOOR				= 0.133

3411

$$K = 1 / 3411 = 0.293$$




1	INDOOR				= 0.133
2	GLASS	3	0.003 / 0.88		= 0.004
3	INDOOR				= 0.133

0.270

$$K = 1 / 0.270 = 3.704$$

- DOOR WOOD K = 2.4
- STEEL K = 3.9


C) FLOOR



1	INDOOR				= 0.105
2	TERRAZO BLOCK	30	0.03 / 1.55		= 0.019
3	MORTAR	40	0.04 / 1.2		= 0.033
4	CONCRETE	120	0.12 / 1.3		= 0.032
5	BRICK	120	0.12 / 1.5		= 0.060
6	EARTH	1000	1.0 / 1.5		= 0.667

0.996

$$K = 1 / 0.996 = 1.004 (\nearrow)$$



1	INDOOR				= 0.105
2	CARPET	6	0.006 / 0.045		= 0.133
3	FELT	4	0.004 / 0.042		= 0.095
4	MORTAR	20	0.02 / 1.2		= 0.017
5	CONCRETE	200	0.2 / 1.3		= 0.154
6	BRICK	120	0.12 / 1.5		= 0.080
7	EARTH	1000	1.0 / 1.5		= 0.667

1.251


$$K = 1 / 1.251 = 0.799 (\nearrow)$$



1	INDOOR			= 0.105
2	CARPET	6	0.006 / 0.045	= 0.133
3	FELT	4	0.004 / 0.042	= 0.095
4	MORTAR	20	0.02 / 1.2	= 0.017
5	CONCRETE	200	0.2 / 1.3	= 0.154
	MORTAR	25	0.025 / 1.2	= 0.021
	INDOOR			= 0.105

0.630


$K = 1 / 0.630 = 1.587$ (↑)



1	INDOOR			= 0.105
2	CARPET	6	0.006 / 0.045	= 0.133
3	FELT	4	0.004 / 0.042	= 0.095
4	MORTAR	20	0.02 / 1.2	= 0.017
5	CONCRETE	200	0.2 / 1.3	= 0.154
6	AIR GAP			= 0.170
	PLASTER BOARD	9	0.009 / 0.015	= 0.600
	ROCK WOOL SOUND ABSORBING BOARD	12	0.012 / 0.144	= 0.083
	INDOOR			= 0.105

1.462


$K = 1 / 1.462 = 0.684$ (↑)



1	INDOOR			= 0.105
2	LAMINATED WOOD	24	0.024 / 0.12	= 0.200
3	AIR GAP			= 0.170
4	CONCRETE	120	0.12 / 1.3	= 0.092
	BRICK	120	0.12 / 1.5	= 0.080
	EARTH	1000	1.0 / 1.5	= 0.667

1.314


$K = 1 / 1.314 = 0.761$ (↑)



1	INDOOR			= 0.105
2	TERRAZZO	40	0.04 / 1.2	= 0.033
3	CONCRETE	120	0.12 / 1.3	= 0.092
	BRICK	120	0.12 / 1.5	= 0.080
	EARTH	1000	1.0 / 1.5	= 0.667


0.977

$K = 1 / 0.977 = 1.024$ (↑)



1	INDOOR			= 0,105
2	VINYL TILE	2	0,002 / 0,34	= 0,006
3	BRICK CONCRETE	200	0,2 / 0,7	= 0,286
4	CONCRETE	150	0,15 / 1,3	= 0,115
	ROCK WOOL SOUND ABSORBING BOARD	50	0,05 / 0,144	= 0,347
	INDOOR			= 0,105
				<hr/>
				0,964


$$K = 1 / 0,964 = 1,037 (\uparrow)$$



1	INDOOR			= 0,105
2	VINYL TILE	2	0,002 / 0,34	= 0,006
3	BRICK CONCRETE	200	0,2 / 0,7	= 0,286
4	CONCRETE	150	0,15 / 1,3	= 0,115
	AIR GAP			= 0,170
	PLASTER BOARD	9	0,009 / 0,015	= 0,600
	ROCK WOOL SOUND ABSORBING BOARD	12	0,012 / 0,144	= 0,083
	INDOOR			= 0,105
				<hr/>
				1,470


$$K = 1 / 1,470 = 0,680 (\uparrow)$$

D) CEILING



1	INDOOR			= 0,167
2	VINYL TILE	2	0,002 / 0,34	= 0,006
3	MORTAR	25	0,025 / 1,2	= 0,021
4	CONCRETE	120	0,12 / 1,3	= 0,092
	AIR GAP			= 0,230
	PLASTER BOARD	9	0,009 / 0,015	= 0,600
	ROCK WOOL SOUND ABSORBING BOARD	12	0,012 / 0,144	= 0,083
	INDOOR			= 0,167
				<hr/>
				1,366


$$K = 1 / 1,366 = 0,732 (\uparrow)$$



1	INDOOR			= 0,167
2	TILE	10	0,01 / 1,1	= 0,009
3	MORTAR	30	0,03 / 1,2	= 0,025
4	"	5	0,005 / 0,65	= 0,008
5	BRICK CONCRETE	50	0,05 / 0,7	= 0,071
6	CONCRETE	120	0,12 / 1,3	= 0,092
	AIR GAP			= 0,230
	PLASTER BOARD	9	0,009 / 0,015	= 0,600
	ROCK WOOL SOUND ABSORBING BOARD	12	0,012 / 0,144	= 0,083

Γ_1	INDOOR				= 0,167
					<hr/> 1,452


$$K = 1 / 1,452 = 0,689 \text{ (✓)}$$



Γ_1	INDOOR				= 0,167
Γ_2	MORTAR	30	0,03	/ 1,2	= 0,025
Γ_2	CONCRETE	150	0,15	/ 1,3	= 0,115
Γ_a	AIR GAP				= 0,230
Γ_3	PLASTER BOARD	9	0,009	/ 0,015	= 0,600
Γ_4	ROCK WOOL SOUND ABSORBING BOARD	12	0,012	/ 0,144	= 0,083
Γ_1	INDOOR				<hr/> = 0,167
					1,387


$$K = 1 / 1,387 = 0,721 \text{ (✓)}$$

E) ROOF




Γ_6	OUTDOOR				= 0,050
Γ_1	LIME CONCRETE	76	0,076	/ 1,9	= 0,040
Γ_2	CONCRETE	100	0,1	/ 1,3	= 0,077
Γ_3	CEMENTED CHIP BOARD	30	0,03	/ 1,2	= 0,025
Γ_a	AIR GAP				= 0,230
Γ_4	GLASS WOOL	25	0,025	/ 0,036	= 0,694
Γ_5	PLASTER BOARD	18	0,018	/ 0,015	= 1,200
Γ_a	AIR GAP				= 0,230
Γ_6	ASBESTUS CEMENT FLEXIBLE BOARD	5	0,005	/ 0,25	= 0,020
Γ_7	CROTH	1			= 0
Γ_1	INDOOR				<hr/> = 0,167
					2,733

$$K = 1 / 2,733 = 0,366 \text{ (✓)}$$



Γ_6	OUTDOOR				= 0,050
Γ_1	LIME CONCRETE	76	0,076	/ 1,9	= 0,040
Γ_2	CONCRETE	100	0,1	/ 1,3	= 0,077
Γ_3	CEMENTED CHIP BOARD	30	0,03	/ 1,2	= 0,025
Γ_1	INDOOR				<hr/> = 0,167
					0,359

$$K = 1 / 0,359 = 2,786 \text{ (✓)}$$



π	OUTDOOR			= 0,050
π_2	LIME CONCRETE	76	$0,076 / 1,9$	= 0,040
π_2	CONCRETE	100	$0,1 / 1,3$	= 0,077
π_2	AIR GAP			= 0,230
π_3	PLASTER BOARD	9	$0,009 / 0,015$	= 0,600
π_4	ROCK WOOL SOUND ABSORBING BOARD	12	$0,012 / 0,144$	= 0,083
π	INDOOR			= 0,167
				<hr/>
				1,247

$$K = 1 / 1,247 = 0,802 \text{ (✓)}$$

10. KW. VALUE BY EQUIPMENTS

A) STAG LIGHT

$$270^{\text{Kw}} \times 50\% \text{ (USAGE FACTOR)} = 135^{\text{Kw}}$$

B) LIGHTING ROOM

$$18^{\text{Kw}} \times 70\% = 12,6^{\text{Kw}}$$

{	TO STAGE	$12,6^{\text{Kw}} \times 12\% = 1,5^{\text{Kw}}$
	TO AUDITORIUM	$12,6 \times 13 = 1,6$
	ROOM	$12,6 \times 75 = 9,5$

C) SIDE-SPOT

$$6^{\text{Kw}} \times 70\% = 4,2^{\text{Kw}}$$

{	TO STAGE	$4,2^{\text{Kw}} \times 12\% = 0,5^{\text{Kw}}$
	TO AUDITORIUM	$4,2 \times 13 = 0,6$
	ROOM	$4,2 \times 75 = 3,1$

D) PROJECTION ROOM

$$20^{\text{Kw}} \times 70\% = 14,0^{\text{Kw}}$$

{	TO STAGE	$14,0^{\text{Kw}} \times 12\% = 1,7^{\text{Kw}}$
	TO AUDITORIUM	$14,0 \times 13 = 1,8$
	ROOM	$14,0 \times 75 = 10,5 \rightarrow \times 50\% = 5,3^{\text{Kw}}$


LIGHING LOAD

STAGE	$135 + 1.5 + 0.5 + 1.7$	$= 138.7$ Kw
AUDITORIUM	$1.6 + 0.6 + 1.8$	$= 4.0$
LIGHTING ROOM		$= 9.5$
SIDE-SPOT		$= 3.1$
PROJECTION ROOM		$= 5.3$

II. DESIGN CONDITION LIST

	ROOM NAME	S (m ²)	PERSON		LIGHT (Kw)		STAGE LIGHT (Kw)	OUTDOOR A (m ³ /hr)	
			(P/m ²)	(P)	(Kw/m ²)	(Kw)		(m ³ /P)	(m ³ /hr)
A	FOYER & ENTRANCE	336,85	—	100	0,025	8,5	—	—	1,780
B	CANTEEN	89,33	0,2	18	0,025	2,3	—	15	270
C	OFFICE 2	86,1	0,2	2	0,025	0,2	—	15	30
D	STAGE	70,27	—	25	—	—	138,7	26	650
E	AUDITORIUM	524,81	—	560	0,02	10,5	4,0	15	8,400
F	SUB-CONTROL ROOM	97,53	—	6	0,025	2,5	300	15	90
G	RACK ROOM	28,5	—	1	0,025	0,7	300	15	15
H	STORE 3	12,71	—	1	0,025	0,37	—	15	15
I	V.I.P. ROOM	38,71	0,2	2	0,03	1,2	—	15	120
J	OFFICE 3	17,36	0,2	4	0,025	0,4	—	15	60
K	OFFICE 4	14,88	0,2	4	0,025	0,4	—	15	60
L	LOBBY	69,06	0,2	15	0,02	1,4	—	15	225
M	PROJECTION ROOM	47,85	—	5	0,02	1,0	5,3	15	75
N	LIGHTING ROOM	80,66	—	3	0,02	1,6	9,5	15	45
O	SIDE SPOT 2	6,45	—	2	0,02	0,1	3,1	15	30
P	SIDE SPOT 1	7,01	—	2	0,02	0,2	3,1	15	30
Q	OFFICE 1	9,88	0,2	2	0,025	0,3	—	15	30
R	ARTIST WAITING R.	61,16	—	25	0,025	1,5	—	15	375
S	MAKE UP ROOM (M)	22,32	0,5	12	0,03	0,7	—	15	180
T	MAKE UP ROOM (F)	26,4	0,5	14	0,03	0,8	—	15	210

12. BACK CEILING TEMPERATURE OF AUDITORIUM



$$t_a = \frac{t_i \cdot A_c \cdot K_c + t_o (A_r \cdot K_r + A_g \cdot K_g) + t_e \cdot A_e \cdot K_e + C + 0.3Qt_i}{A_r \cdot K_r + A_c \cdot K_c + A_g \cdot K_g + A_e \cdot K_e + 0.3Q}$$

A_r : ROOF AREA 424.82 m^2

A_c : CEILING AREA 443.22

A_g : EXTERNAL WALL AREA 61.65

A_e : INTERNAL WALL AREA 233.34

K_r : HEAT TRANSMISSION COEFFICIENT OF ROOF $0.403 \text{ kcal/m}^2\text{Hr}$

K_c : _____ OF CEILING 2.825

K_g : _____ OF EXTERNAL WALL

K_e : _____ OF INTERNAL WALL 0.406

C : LIGHTING LOAD $10.5 \text{ Kw} \times 7\% \times 860 = 610 \text{ kcal/Hr}$

Q : VENTILATION VOLUME $18405 \text{ m}^3/\text{Hr}$ (AUDITORIUM INLET

t_o : SURFACE TEMPERATURE OF ROOF $26^\circ\text{C} + 23.1^\circ\text{C} = 49.1^\circ\text{C}$

t_e : TEMPERATURE OF UPPER PART OF STAGE 300

t_i : _____ OF AUDITORIUM 260

$$t_a = \frac{26 \times 443.22 \times 2.825 + 49.1 (424.82 \times 0.403 + 61.65 \times 0.406) + 30 \times 233.34 \times 0.406 + 610 + 0.3 \times 18405 \times 26}{424.82 \times 0.403 + 443.22 \times 2.825 + 61.65 \times 0.406 + 233.34 + 0.3 \times 18405}$$

$$\doteq 26.9^\circ\text{C}$$

13. COOLING LOAD ESTIMATION

ENTRANCE x FOYER (16:00)

A	PART	AREA	m ²	K Kcal/m ² Hr	Δt °C	HG. Kcal/Hr
NE	EXTERNAL WALL	6.2 × 4.6 - 10.14	18.38	2309	13.6	578
NW	"	22.59 × 4.6 - 17.65	86.26	2309	11.0	2,191
SW	"	16.4 × 4.6 - 12.33	63.11	2309	11.3	1,647
SE	"	1.4 × 4.6	6.44	2309	14.6	218
NW	GLASS	6.44 × 2.74	17.65	53	9.0	842
"	(RADIATION)	"	17.65		334.0	5896
NE	"	3.7 × 2.74	10.14	53	9.0	484
"	(RADIATION)	"	10.14		330	335
SW	"	4.5 × 2.74	12.33	53	9.0	589
"	(RADIATION)	"	12.33		271.0	3,342
	INTERNAL WALL	15.5 × 2.8 + 5.7 × 2.4	71.48	1,044	4.5	336
	GLASS	1.6 × 2.4 + 5.7 × 2.8	19.8	3,704	4.5	330
	CEILING		92.8	0,732	4.5	306
	INFILTRATION	300 × 9 × 0.29				783
	PERSON	100 ^P × 54				5,400
	LIGHT	8.5 Kw × 1000				8,500
	OTHER LOAD					3,173
	S.H.					34,950
	PERSON	100 ^P × 46				4,600
	INFILTRATION	300 × 0.0213 × 715				4,569
	OTHER LOAD					911
	L H					10,080

CANTEEN (16:00)

N W	EXTERNAL WALL	14,3×4,6-2392	41,86	1,802	11,0	830
"	GLASS	2,6×2,3×4	23,92	5,3	9,0	1,141
"	"		23,92		334×0,56	4,474
	RADIATION					
	CEILING	$(5,4+7,4) \times 2,1 \times \frac{1}{2}$ $+(1,0+3,1) \times 2,5 \times \frac{1}{2}$	18,57	0,732	4,5	62
	PERSON	18 ^P ×60				1,080
	INFILTRATION	130×9×0,29				340
	LIGHT	23 ^{Kw} ×1,000				2300
	OTHER LOAD					1,059
	S.H.					11,650
	PERSON	18 ^P ×78				1,404
	INFILTRATION	130×0,0213×715				1,980
	OTHER LOAD					336
	L.H.					3,720


OFFICE 2

	INTERNAL WALL	8,6×2,4	20,64	2,288	4,5	213
	PERSON	2 ^P ×54				108
	LIGHT	0,2 ^{Kw} ×1,000				200
	OTHER LOAD					59
	S.H.					580
	PERSON	2 ^P ×46				92
	OTHER LOAD					8
	L.H.					100

STAGE (16:00)

N E	EXTERNAL WALL	16,46×9,8	161,31	1,259	136	2,762
N W	◊	7,62×9,8	74,68	1,259	110	1,035
S E	◊	40,21×9,8	394,35	1,259	146	7,249
S W	◊	4,6×9,8+26×5,2+10,6×20	79,8	1,259	113	1,136
H	ROOF		70,27	2,786	23,1	4,523
	INTERNAL WALL	25,1×4,12+16,1×3,2+21,8×20	204,53	2,364	45	2,176
	PERSON	25 ^P × 69				1,725
	LIGHT	138,7 ^{Kw} × 860				119,282
	OTHER LOAD					13,982
	S.H.					153,870
	PERSON	25 ^P × 144				3,600
	OTHER LOAD					360
	L.H.					3,960

AUDITORIUM



AREA

$$\textcircled{1} (14,2+20,3) \times 6,1 \times \frac{1}{2} + (20,3+21,3) \times 6,1 \times \frac{1}{2} = 232,11 \text{ m}^2$$

$$\textcircled{2} (21,3+22,5) \times 6,1 \times \frac{1}{2} = 133,59 \text{ m}^2$$

$$\textcircled{3} (22,5+23,6) \times 6,1 \times \frac{1}{2} + (5,1+5,4) \times 20 \times \frac{1}{2} + 40 \times 20 = 159,11 \text{ m}^2$$

$$\textcircled{1} + \textcircled{2} + \textcircled{3} = 524,81 \text{ m}^2$$

AUDITORIUM ① (16:00)

S W	EXTERNAL WALL		5,52	0,406	1,13	297
	CEILING		245,79	2,825	1,0	694
	PERSON	210 ^P x 53				11,130
	LIGHT	643 ^{KW} x 1000				6,430
	OTHER LOAD					1,876
	S.H.					20,660
	PERSON	210 ^P x 35				7,350
	OTHER LOAD					740
	L.H.					8,090

AUDITORIUM ② (16:00)

S W	EXTERNAL WALL		2666	0,406	1,13	123
	CEILING		6,142	2,825	1,0	174
	PERSON	175 ^P x 53				9,275
	LIGHT	3,7 ^{KW} x 1000				3,700
	OTHER LOAD					1,333
	S.H.					14,650
	PERSON	175 ^P x 35				6,125
	OTHER LOAD					615
	L.H.					6,740

AUDITORIUM ③ (16:00)

S W	EXTERNAL WALL		3,149	0,406	1,13	145
	CEILING		146,25	2,825	1,0	413
	PERSON	210 ^P x 54				11,340

LIGHT	4.4 Kw x 1000				4,410
OTHER LOAD					1,650
S.H.					18,190
PERSON	210 P x 35				7,350
OTHER LOAD					740
L.H.					8,090

SUB-CONTROL ROOM

INTERNAL WALL	39.5 x 24 - 53	89.5	0.547	55	270
GLASS	5.3 x 1.0	5.3	3,704	55	108
FLOOR		97.53	1,037	55	557
CEILING		97.53	0.721	55	387
PERSON	6 P x 60				360
LIGHT	2.5 Kw x 1000				2,500
EQUIPMENT	30 Kw x 0.8 x 860				20,640
OTHER LOAD					2,488
S.H.					27,310
PERSON	6 P x 40				240
OTHER LOAD					20
L.H.					260

RACK ROOM

INTERNAL WALL	15.4 x 24	3696	0.547	55	112
FLOOR		285	1,037	55	163
CEILING		285	0.721	55	113
PERSON	1 P x 60				60

LIGHT	$0.7Kw \times 1000$				700
EQUIPMENT	$30Kw \times 0.8 \times 860$				20640
OTHER LOAD					2182
S.H.					23970
PERSON	$1P \times 40$				40
OTHER LOAD					10
L.H.					50

STORE 3

INTERNAL WALL	14.6×2.8	4088	0.547	35	123
PERSON	$1P \times 60$				60
LIGHT	$0.37Kw \times 1000$				370
OTHER LOAD					57
S.H.					610
PERSON	$1P \times 78$				78
OTHER LOAD					12
L.H.					90

V.I.P ROOM (8:00)

NE	EXTERNAL WALL	$6.1 \times 3.2 - 7.36$	1216	1.802	86	189
"	GLASS	$2.3 \times 1.6 \times 2$	7.36	53	9.0	351
"	(RADIATION)		7.36		334×0.56	1377
	INTERNAL WALL	13.0×2.4	31.2	2364	4.5	332
	CEILING		38.71	0.721	4.5	126
	INFILTRATION	$85 \times 9 \times 0.29$				222
	PERSON	$8P \times 54$				432

	LIGHT	$1.2^{KW} \times 1000$				1,200
	OTHER LOAD					421
	S.H.					4,650
	INFILTRATION	$85 \times 0.0213 \times 715$				1,295
	PERSON	$8^P \times 46$				368
	OTHER LOAD					167
	L.H.					1,830

OFFICE 3 (8:00)

N E	EXTERNAL WALL	$3.0 \times 3.2 - 3.68$	592	1,838	86	94
	GLASS	23×1.6	368	53	90	176
	"		368		334×0.56	689
	RADIATION					
	INTERNAL WALL	3.1×24	744	2364	45	80
	CEILING		1736	0,721	45	57
	INFILTRATION	$50 \times 3 \times 0.29$				131
	PERSON	$4^P \times 54$				216
	LIGHT	$0.4^{KW} \times 1000$				400
	OTHER LOAD					187
	S.H.					2,030
	INFILTRATION	$50 \times 0.0213 \times 715$				762
	PERSON	$4^P \times 46$				184
	OTHER LOAD					94
	L.H.					1,040

OFFICE 4 (8:00)

N E	EXTERNAL WALL	30×32-368	592	1,838	86	94
"	GLASS	23×16	3,68	53	9.0	176
"	(RADIATION)		3,68		334×0,56	689
	INTERNAL WALL	7.9×24	1896	2364	4,5	202
	CEILING		1488	0,721	4,5	49
	INFILTRATION	45×9×0,29				118
	PERSON	4 ^P ×54				216
	LIGHT	04 ^{Kw} ×1000				400
	OTHER LOAD					196
	S.H.					2,140
	INFILTRATION	45×0,0213×715				686
	PERSON	4 ^P ×46				184
	OTHER LOAD					90
	L.H.					960

LOBBY

	GLASS	7.0×24	168	3,704	4,5	280
	CEILING		69,06	0,721	4,5	224
	PERSON	15 ^P ×54				810
	LIGHT	14 ^{Kw} ×1000				1,400
	OTHER LOAD					276
	S.H.					2,990
	PERSON	15 ^P ×46				690
	OTHER LOAD					70
	L.H.					760

PROJECTION ROOM

	CEILING		363	0,721	4,5	118
	PERSON	5P×54				270
	LIGHT	10Kw×1000				1,000
	EQUIPMENT	53Kw×860				4558
	OTHER LOAD					594
	S.H.					6540
	PERSON	5P×46				230
	OTHER LOAD					20
	L.H.					250

LIGHTING ROOM

S W	EXTERNAL WALL	3,7×34	1258	0,406	1,13	58
H	ROOF		8066	0,403	23,1	751
	INTERNAL WALL	4,0×34	13,6	2,364	4,5	145
	PERSON	3P×54				162
	LIGHT	9,5Kw×860				8,170
	OTHER LOAD					924
	S.H.					10210
	PERSON	3P×46				138
	OTHER LOAD					12
	L.H.					150

SIDE SPOT 2

S W	EXTERNAL WALL	3,7×26	9,62	0,406	1,13	45
	PERSON	2 ^P × 54				108
	LIGHT	3,1 Kw × 860				2666
	OTHER LOAD					281
	S.H.					3,100
	PERSON	3 ^P × 46				92
	OTHER LOAD					8
	L.H.					100

SIDE SPOT 1

	INTERNAL WALL	4,0×26	104	0,547	4,5	26
	PERSON	2 ^P × 54				108
	LIGHT	3,1 Kw × 860				2666
	OTHER LOAD					280
	S.H.					3,080
	PERSON	2 ^P × 46				92
	OTHER LOAD					8
	L.H.					100

OFFICE 1 (8:00)

S E	EXTERNAL WALL	3,8×4,6-3,2	14,28	1,802	94	242
H	ROOF		9,88	0,802	146	116
S E	GLASS	2,0×1,6	3,2	5,3	9,0	153
"	"		3,2		271×0,56	486
	(RADIATION) INTERNAL WALL	6,0×24	15,36	2,364	45	164

INFILTRATION	30x9x0,29				79
PERSON	2Px54				108
LIGHT	0,3KWx1000				300
OTHER LOAD					162
S.H.					1,810
INFILTRATION	30x0,0213x715				457
PERSON	2Px46				92
OTHER LOAD					51
L.H.					600

ARTIST WAITING ROOM

CEILING	61.16-(22x8,2+1,6x2,1)	39,76	0,721	4,5	129
INTERNAL WALL	28,5x2,8	79,8	2,364	4,5	849
PERSON	25Px69				1,725
LIGHT	1,5KWx1000				1,500
OTHER LOAD					427
S.H.					4,630
PERSON	25Px144				3,600
OTHER LOAD					360
L.H.					3,960

MAKE UP ROOM (M)

CEILING	2.1×30	63	0.721	45	21
INTERNAL WALL	8.2×24	1968	2364	45	210
PERSON	12P×54				648
LIGHT	0.7Kw×1000				700
OTHER LOAD					151
S.H.					1730
PERSON	12P×46				552
OTHER LOAD					58
L.H.					610

MAKE UP ROOM (F)

CEILING	2.6×26	676	0.721	45	22
INTERNAL WALL	11.3×24	2712	2364	45	289
PERSON	14P×54				756
LIGHT	0.8Kw×1000				800
OTHER LOAD					183
S.H.					2050
PERSON	14P×46				644
OTHER LOAR					66
L.H.					710

14. STUDY OF AIR HANDLING UNIT

ENTRANCE SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q (m ³ /Hr)	O.A. (m ³ /Hr)	REMARKS
		S.H.	L.H.	T.H.				
FOYER & ENTRANCE	33685	34950	10080	45030		10940	1780	
OFFICE 2	861	580	100	680		210	30	
TOTAL		35530	10180	45710	77.7	11,150	1,810	

$$\text{S.H.F} = \frac{35530}{45710} \times 100 = 77.7 \%$$

APPARATUS DEW POINT 14.5°C

OUTLET TEMPERATURE 17.0°C $i = 9.85 \text{ kcal/kg}$

$$\text{SUPPLY AIR VOLUME} = \frac{35530}{0.29 \times (26 - 15)} = 11,150 \text{ m}^3/\text{Hr}$$

AIR HANDLING UNIT (FACE VELOCITY 2.0~2.5 m/sec) → (AH-23EA)

$$\text{O.A./Q} = \frac{1810}{11,150} \times 100 = 16.2 \%$$

AIR CONDITION AT INLET

$$\text{D.B.} = (26.0 \times 0.838) + (35 \times 0.162) = 27.46^\circ\text{C}$$

$$i = (1.33 \times 0.838) + (28.5 \times 0.162) = 15.76 \text{ kcal/kg}$$

$$\text{COOLING CAPACITY} = 11,150 \times 1.2 \times (15.76 - 9.85) = 80,000 \text{ kcal/Hr}$$

CANTEEN SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q (m ³ /Hr)	O. A. m ³ /Hr	REMARKS
		S H	L H	T H				
CANTEEN	8933	11,650	3,720	15,370	75.7	3,650	270	

$$\text{S.H.F.} = \frac{11,650}{15,370} \times 100 = 75.7 \%$$

APPARATUS DEW POINT 14.1°C

OUTLET TEMPERATURE 15.0°C $i = 9.76 \text{ Kcal/Kg}$

$$\text{SUPPLY AIR VOLUME} = \frac{11,650}{0.29 \times (26 - 15)} = 3,650 \text{ m}^3/\text{Hr}$$

AIR HANDLING UNIT (FACE VELOCITY 20~25 m/sec) → (AH-6EA)

$$\text{O.A./Q} = \frac{270}{3,650} \times 100 = 7.5 \%$$

AIR CONDITION AT INLET

$$\text{D.B.} = (26 \times 0.925) + (35 \times 0.075) = 26.68^\circ\text{C}$$

$$i = (13.3 \times 0.925) + (28.5 \times 0.075) = 14.44 \text{ Kcal/Kg}$$

$$\text{COOLING CAPACITY} = 3,650 \times 1.2 \times (14.44 - 9.76) = 21,000 \text{ Kcal/Hr}$$

STAGE SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q m ³ /Hr	O.A. m ³ /Hr	REMARKS
		S.H.	L.H.	T.H.				
STAGE	7027	153870	3960	157830	97.5	56,000	650	QA ADJUST. 8400 m ³ /Hr

$$\text{S.H.F.} = \frac{153870}{157830} \times 100 = 97.5 \%$$

APPARATUS DEW POINT 16.1 °C

OUTLET TEMPERATURE 16.5 °C $i = 10.9 \text{ Kcal/Kg}$

$$\text{SUPPLY AIR VOLUM} = \frac{153870}{0.29 \times (26 - 16.5)} = 56,000 \text{ m}^3/\text{Hr}$$

AIR HANDLING UNIT (FACE VELOCITY 2.0~2.5 m/sec) → (AH-100EA)

$$\text{O.A./Q} = \frac{650}{56000} \times 100 = 1.1 \%$$

STAGE EXHAUST → 15% (8400 m³/Hr)

AIR CONDITION AT INLET

$$\text{D.B.} = (26 \times 0.85) + (35 \times 0.15) = 27.35 \text{ °C}$$

$$i = (13.3 \times 0.85) + (28.5 \times 0.15) = 15.58 \text{ Kcal/Kg}$$

$$\text{COOLING CAPACITY} = 56000 \times 1.2 \times (15.58 - 10.9) = 315,000 \text{ Kcal/Kg}$$

AUDITORIUM SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q m ³ /Hr	Q.A. m ³ /Hr	REMARKS
		S.H.	L.H.	T.H.				
①	232,11	20,660	8,090	28,750				
②	133,59	14,650	6,740	21,390				
③	159,11	18,190	8,090	26,280				
TOTAL	524,81	53,500	22,920	76,420	700.	18,300	8,400	

$$\text{S.H.F.} = \frac{53500}{76420} \times 100 = 700 \%$$

APPARATUS DEW POINT 13.0°C

OUTLET TEMPERATURE 15.5°C $i = 9.6 \text{ Kcal/Kg}$

SUPPLY AIR VOLUM $\frac{53500}{0.29 \times (26 - 15.5)} \times 1.05 = 18,300 \text{ m}^3/\text{Hr}$

OUTDOOR AIR CONDITION AT INLET (ENTHALPY EXCHANGER)

$$\text{D.B.} = 35 - 8.1 \times 0.79 = 28.7^\circ\text{C}$$

$$i = 28.5 - 15 \times 0.69 = 18.3 \text{ Kcal/Kg}$$

AIR HANDLING UNITE (FACE VELOCITY 2.0~2.5 m/sec) → (AH-35EA)

$$\text{Q.A./Q} = \frac{8400}{18300} \times 100 = 45.9 \%$$

AIR CONDITION AT INLET

$$\text{D.B.} = (26.9 \times 0.541) + (28.7 \times 0.459) = 27.73^\circ\text{C}$$

$$i = (13.5 \times 0.541) + (18.3 \times 0.459) = 15.6 \text{ Kcal/Kg}$$

COOLING CAPACITY $18,300 \times 1.2 \times (15.6 - 9.6) = 132,000 \text{ Kcal/Hr}$

SUB-CONTROL SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q m ³ /Hr	O.A. m ³ /Hr	REMARKS
		S.H.	L.H.	T.H.				
SUB-CON.R.	9753	6670	260	6930		2540	90	EQUIPMENT 20640 Kcal/Hr
RACK ROOM	285	3330	50	3380		1,260	15	20640
STORE 3 (BATTERY R.)	14.7	610	90	700		300 (50)	15	
TOTAL		10610	400	11,010	96.4	4,150	120	QA ADJUST. 300 m ³ /Hr

CALORIFIC VALUE BY EQUIPMENT → FAN COIL UNIT

CALORIFIC VALUE BY OTHERS → AIR HANDLING UNIT

$$\text{S.H.F.} = \frac{10610}{11,010} \times 100 = 96.4\%$$

APPARATUS DEW POINT 14.1 °C

OUTLET TEMPERATURE 15 °C $i = 9.75 \text{ Kcal/Kg}$

SUPPLY AIR VOLUM $\frac{10610}{0.29 \times (24 - 15)} = 4,150 \text{ m}^3/\text{Hr}$

AIR HANDLING UNIT (FACE VELOCITY 20~25 m/sec) → (AH-8EA)

$$\text{O.A./Q} = \frac{120}{4,150} \times 100 = 2.9\% \rightarrow 7\%$$

(VOLUME OF OUTDOOR AIR = VOLUM OF STORE 3 OUTLET AIR 300 m³/Hr)

AIR CONDITION AT INLET

$$\text{D.B.} = (24 \times 0.93) + (35 \times 0.07) = 24.77 \text{ °C}$$

$$i = (12 \times 0.93) + (28.5 \times 0.07) = 13.2 \text{ Kcal/Kg}$$

COOLING CAPACITY $4,150 \times 1.2 \times (13.2 - 9.75) = 17,200 \text{ Kcal/Hr}$

FAN COIL UNIT

CHILLED WATER TEMP. 7~12 °C.

INDOOR CONDITION D.B. 24 °C . WB. 17.8 °C .

FWV-123 S.H. 5800 Kcal/Hr . T.H. 7400 Kcal/Hr . 24 l/min

V.I.P. ROOM SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q (m ³ /Hr)	O. A. (m ³ /Hr)	REMARKS
		S.H.	L.H.	T.H.				
V.I.P. ROOM	3871	4650	1830	6480		1460	120	
OFFICE 3	1736	2030	1040	3070		640	60	
OFFICE 4	1488	2140	960	3100		670	60	
LOBEY	6906	2990	760	3750		930	130	
TOTAL		11810	4590	16400	720	3700	370	

$$\text{S.H.F.} = \frac{11810}{16400} \times 100 = 720\%$$

APPARATUS DEW POINT 13.2°C

OUTLET TEMPERATURE 15°C $i = 9.5 \text{ Kcal/Kg}$

$$\text{SUPPLY AIR VOLUM} = \frac{11810}{0.29 \times (26 - 15)} = 3700 \text{ m}^3/\text{Hr}$$

AIR HANDLING UNIT (FACE VELOCITY 2.0~2.5 m/sec) → (AH-6EA)

$$\text{O.A./Q} = \frac{370}{3700} \times 100 = 10\%$$

AIR CONDITION AT INLET

$$\text{D.B} = (26.0 \times 0.9) + (35.0 \times 0.1) = 26.9^\circ\text{C}$$

$$i = (13.3 \times 0.9) + (28.5 \times 0.1) = 14.82 \text{ Kcal/Kg}$$

$$\text{COOLING CAPACITY} = 3700 \times 1.2 \times (14.82 - 9.5) = 24000 \text{ Kcal/Hr}$$

PROJECTION ROOM SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q m ³ /Hr	O. A. m ³ /Hr	REMARKS
		S.H.	L.H.	T.H.				
PROJECTION ROOM	47,85	6540	250	6790	96,3	2510	75	

$$\text{S.H.F.} = \frac{6540}{6790} \times 100 = 96,3 \%$$

APPARATUS DEW POINT 16°C

OUTLET TEMPERATURE 17°C $i = 10,95 \text{ Kcal/Kg}$

$$\text{SUPPLY AIR VOLUME} = \frac{6540}{0,29 \times (26 - 17)} = 2510 \text{ m}^3/\text{Hr}$$

AIR HANDLING UNIT (FACE VELOCITY 20~25 m/sec) → (AH-4EA)

$$\text{O.A./Q} = \frac{75}{2510} \times 100 = 3 \%$$

AIR CONDITION AT INLET

$$\text{D.B.} = (26,0 \times 0,97) + (35,0 \times 0,03) = 26,27^\circ\text{C}$$

$$i = (13,3 \times 0,97) + (28,5 \times 0,03) = 13,76 \text{ Kcal/Kg}$$

$$\text{COOLING CAPACITY} = 2510 \times 1,2 \times (13,76 - 10,95) = 8,500 \text{ Kcal/Hr}$$

LIGHTING ROOM SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			S.H.F. (%)	Q m ³ /Hr	Q.A. m ³ /Hr	REMARKS
		S. H.	L. H.	T. H.				
LIGHTING ROOM	80,66	10,210	150	10,360		3,700	45	
SIDE SPOT 2	6,45	3,100	100	3,200		1,130	30	
SIDE SPOT 1	7,01	3,080	100	3,180		1,120	30	
TOTAL		16,390	350	16,740	98,0	5,950	105	QA ADJUST. 1,200 m ³ /Hr

$$\text{S.H.F.} = \frac{16390}{16740} \times 100 = 98,0 \%$$

APPARATUS DEW POINT 16,0°C

OUTLET TEMPERATURE 16,5°C $i = 10,9 \text{ Kcal/Kg}$

$$\text{SUPPLY AIR VOLUM} = \frac{16390}{0,29 \times (26 - 16,5)} = 5950 \text{ m}^3/\text{Hr}$$

AIR HANDLING UNIT (FACE VELOCITY 20~25 m/sec) → (AH-10EA)

$$\text{Q.A./Q} = \frac{105}{5950} \times 100 = 1,5 \% \rightarrow 20 \% \quad 1,200 \text{ m}^3/\text{Hr}$$

AIR CONDITION AT INLET

$$\text{D.B.} = (26,0 \times 0,8) + (35,0 \times 0,2) = 27,8 \text{ }^\circ\text{C}$$

$$i = (13,3 \times 0,8) + (28,5 \times 0,2) = 16,34 \text{ Kcal/Hr}$$

$$\text{COOLING CAPACITY} = 5950 \times 1,2 \times (16,34 - 10,9) = 38,900 \text{ Kcal/Hr}$$

EXISTING SYSTEM

ROOM	S (m ²)	COOLING LOAD (Kcal/Hr)			Q (m ³ /Hr)	REMARKS
		S. H.	L. H.	T. H.		
OFFICE 1	9.88	1,810	600	2,410	570	
ARTIST WAIT- ING ROOM	61.16	4,630	3,960	8,590	1,450	
MAKE UP R. (M)	22.32	1,730	610	2,340	540	
MAKEUP R (F)	26.4	2,050	710	2,760	640	

ROOM TEMPERATURE 26°C
 OUTLET TEMPERATURE 15°C } $\Delta t = 11^\circ\text{C}$

$$\text{OFFICE 1} \quad \frac{1810}{0.29 \times 11} = 570 \text{ m}^3/\text{Hr}$$

$$\text{ARTIST W.R.} \quad \frac{4630}{0.29 \times 11} = 1,450$$

$$\text{MAKE UP R.(M)} \quad \frac{1730}{0.29 \times 11} = 540$$

$$\text{" (F)} \quad \frac{2050}{0.29 \times 11} = 640$$

15 LIST OF COOLING CAPACITY

SYSTEM	UNIT	Q'TY	COOLING CAPACITY (Kcal/Hr)	CHILLED WATER FLOW (l/min)	REMARKS
1 ENTRANCE SYSTEM	A.H.U.	1	80000	270	
2 CANTEEN	"	1	21000	80	EXISTING CHILLED WATER PIPE
3 STAGE	"	1	315000	1050	
4 AUDITORIUM	"	1	132000	450	
5 SUB-CONTROL	"	1	17200	60	EXISTING CHILLED WATER PIPE
			34800	150	
6 V.I.P. ROOM	A.H.U.	1	24000	80	"
7 PROJECTION ROOM	"	1	8500	30	
			5000	20	
8 LIGHTING ROOM	A.H.U.	1	38900	130	
9 ORCHESTRA PIT	"	1	3000	10	EXISTING CHILLED WATER PIPE
TOTAL			679400	2330	

679400 Kcal/Hr = 224.7 USRT.

16 CHILLING UNIT

FULL-TIME AIR CONDITIONED ROOMS [SUB-CONTROL SYSTEM
ORCHESTRA SYSTEM

COOLING CAPACITY

SUB-CONTROL S. 52000 Kcal/Hr

ORCHESTRA S. 3000

55000 Kcal/Hr

REFRIGERATION LOAD

PIPE LOSS 20 %

$$55000 \times 1.2 = 66000 \text{ Kcal/Hr}$$

OUTDOOR TEMP. 35°C

→ (UWA 40G)

CHILLED WATER TEMP. 7~12°C

VENTILATION

1. W.C.(1) SYSTEM (NUMBER OF AIR CHANGE 5~10 N/Hr)

$$(M) \quad 8.3^m \times 6.0^m \times 2.3^m \times 7 \text{ N/Hr} = 800 \text{ m}^3/\text{Hr}$$

$$(F) \quad \{3.9 \times 4.0 + (5.2 + 4.9) \times 1.8 \times 1/2\} \times 2.3 \times 7 = 390$$

$$\text{STORE 5} \quad (18.2 + 18.4) \times 2.0 \times 1/2 \times 2.3 \times 5 = 420$$

$$\text{PAWDER R.} \quad 4.35 \times 1.9 \times 2.3 \times 10 = 200$$

$$\text{TOTAL} \quad 1810 \text{ m}^3/\text{Hr}$$

$$\text{FAN (TFU-30)} \times 1810 \text{ m}^3/\text{Hr} \times 20 \text{ mmAq} \times 0.75 \text{ Kw}$$

2. W.C.(2)(3) SYSTEM (5~10 N/Hr)

$$(2) \quad (1.8 + 2.1) \times 2.1 \times 1/2 \times 2.3 \times 5 = 100$$

$$(3) \quad \{2.1 \times 1.0 + (1.6 + 1.9) \times 1.4 \times 1/2\} \times 2.3 \times 10 = 140$$

$$\text{WATTIG R.} \quad 2.1 \times 1.3 \times 2.3 \times 10 = 60$$

$$\text{TOTAL} \quad 300 \text{ m}^3/\text{Hr}$$

$$\text{FAN (TFU-20)} \times 300 \text{ m}^3/\text{Hr} \times 15 \text{ mmAq} \times 0.2 \text{ Kw}$$

3. WASH ROOM SYSTEM (10 N/Hr)

$$(5.0 + 4.0) \times 4.0 \times 1/2 \times 2.3 \times 10 = 450 \text{ m}^3/\text{Hr}$$

$$\text{FAN (TFU-20)} \times 450 \text{ m}^3/\text{Hr} \times 20 \text{ mmAq} \times 0.2 \text{ Kw}$$

4. W.C.(4) SYSTEM (5 N/Hr)

$$\{(4.5 + 4.1) \times 2.2 \times 1/2 - 1.5 \times 0.7\} \times 2.3 \times 5 = 100 \text{ m}^3/\text{Hr}$$

$$\text{FAN (TFU-20)} \times 100 \text{ m}^3/\text{Hr} \times 15 \text{ mmAq} \times 0.2 \text{ Kw}$$

5. PROJECTION ROOM SYSTEM

$$\text{FAN (TFU-20)} \times 285 \text{ m}^3/\text{Hr} \times 15 \text{ mmAq} \times 0.2 \text{ Kw}$$

6. KITCHEN & PANTRE SYSTEM

(KITCHEN 30 N/Hr , STORE 4 5 N/Hr)

$$\text{KITCHEN } \{(3.1+4.2) \times 6.7 \times \frac{1}{2} + 3.1 \times 0.5 \times \frac{1}{2}\} \times 23 \times 30 = 1,700 \text{ m}^3/\text{Hr}$$

$$\left\{ \begin{array}{l} \text{HOOD} \\ \text{INLET} \end{array} \right. \quad 1.0^{\text{m}} \times 0.6^{\text{m}} \times 0.6^{\text{m/sec}} \times 3600^{\text{sec/Hr}} = 1,300 \text{ m}^3/\text{Hr}$$

$$\left\{ \begin{array}{l} \text{HOOD} \\ \text{INLET} \end{array} \right. \quad 1,700 \text{ m}^3/\text{Hr} - 1,300 \text{ m}^3/\text{Hr} = 400 \text{ m}^3/\text{Hr}$$

$$\text{STORE 4} \quad 3.0 \times 2.6 \times 23 \times 5 = 100 \text{ m}^3/\text{Hr}$$

$$\text{TOTAL} \quad 1,800 \text{ m}^3/\text{Hr}$$

$$\text{FAN} \cdot (\text{TFU-301}) \times 1,800 \text{ m}^3/\text{Hr} \times 15^{\text{mmAq}} \times 0.75 \text{ Kw}$$

