

(4)

Nos.	Description of Goods	Quantity	Unit Price	Amount
III.	FEED ADDITIVES			
		kg	yen	yen
1	Vitamin A & B	182.1	450	82,000
2	Vitamin B complex	147.7	400	59,000
3	Minerals	182.1	300	55,000
4	DL Methionin	147.7	900	133,000
5	Lysine	147.7	1,000	147,700
6	Hygromycin	48.1	980	47,000
7	Enramycin	274.8	1,900	522,000
8	Choline Sulphate	274.8	1,600	440,000
9	Virginiamycin	154.8	1,500	232,000
10	Frazoridon	274.8	635	175,000
11	2-Calcium Phosphate	1,477.0	95	140,310
	III. Feed Additives Sub Total			2,033,010

(5)

Nos.	Description of Goods	Quantity	Unit Price	Amount
<u>POULTRY SECTOR</u>				
I. <u>LAYER CHICKS</u>				
1	Breeder chicks, Tester delivered from Shirakawa National Livestock Breeding Station			
		birds		yen
	(1) Tester (female) line 1106	1,000	40	40,000
	(2) P.S. (male) line 62	200	150	30,000
	(1) - (2) * delivery date Dec. 6, 1978			
	(3) P.S. (male) line 11	200	150	30,000
	(4) P.S. (male) line 06	200	150	30,000
	(5) P.S. (female) line 06	1,000	120	120,000
	(3) - (5) * delivery date Dec. 27, 1978			
				<u>250,000</u>
2	Breeder Chicks to be imported from the third countries (USA, Canada, etc.) * procured in Burma			
	(1) Harvard Comet (P.S. male)	250	660	165,000
	(2) Shaver (P.S. male)	250	660	165,000
	(3) Harvard comet (P.S. female)	1,750	660	1,155,000
	(4) Shaver (P.S. female)	1,750	660	1,155,000
	<u>I. Layer Chicks Sub Total</u>			<u>2,890,000</u>

Nos.	Description of Goods	Quantity	Unit Price	Amount
II.	<u>MEDICINE</u>			
1	Sulfa-di-metoxine, Powder 10 %	200 kg	1,200 yen	240,000 yen
2	Sulfa-mono-metoxine, powder 10 %	100	1,800	180,000
3	Chloromycetin, injection 50 mg I.U., 20 ml	100 vial	430	43,000
4	Tyrocin, water soluble 100 g	20 pack	8,000	160,000
5	Tyrocin, injection 12,5 g I.U., 500 ml	120 bottle	3,000	360,000
6	Sulfa-mono-metoxine, injection 200 mg I.U., 100 ml	100 bottle	680	68,000
7	Piperazine, tablet 0.5 g	30,000 tablet	2	60,000
8	Sevin, hydrate 75 %	30 kg	3,000	90,000
9	Sevin, powder 3 %	30 kg	270	81,000
10	Ortho-drugs, 18 L	60 can	4,800	288,000
11	Inverted Soap, 18 L	30 can	6,500	195,000
12	Formalin, 20 L	50 bottle	2,500	12,500
13	Potassium permanganate 25 kg	2 bottle	22,000	44,000
14	Ethanol for disinfection 500 ml	10	400	4,000
15	Wood Tar 500 g	3	400	1,200
	<u>II. Medicine Sub Total</u>			<u>1,826,700</u>

Nos.	Description of Goods	Quantity	Unit Price	Amount
III.	<u>FEED ADDITIVES</u>			
			yen	yen
1	Flazolidone, 10 % 20 kg pack	180 kg	500	90,000
2	Vitamin A.D.E. Compound 20 kg pack	80 kg	400	32,000
3	Vitamin B 20 kg pack	120 kg	350	42,000
4	Minerals 25 kg pack	80 kg	250	20,000
5	Choline Sulphate 20 kg pack	80 kg	350	28,000
6	D.L-Methionin 20 kg pack	200 kg	900	180,000
7	L-Lysine 25 kg pack	150 kg	1,000	150,000
8	Zoalen 25 %	70 kg	1,500	105,000
9	3-calcium Phosphate, 95 %	800 kg	95	76,000
	<u>III. Feed Additives Sub Total</u>			<u>723,000</u>
IV.	<u>BIOLOGICS</u>			
				yen
1	Vaccine for Marek's Disease	37,000 dose		214,600
2	Vaccine for Corryza	12,000 dose		55,200
3	Antigen for pullorum disease	600 ml		120,000
	<u>IV. Biologics Sub Total</u>			<u>389,800</u>

付属資料 2. 豚舎設計図

Pig Sector

1. Boar House (A) 種雄豚舎 (Aタイプ)
2. Boar House (B) 種雄豚舎 (Bタイプ)
3. Dry Sow House 種雌豚舎
4. Finisher House 肥育豚舎
5. Grower House 育成豚舎
6. Weaner House 分娩豚舎

付属資料 3. 鶏舎設計図

Poultry Sector

1. Breeder House 種鶏舎
2. Grower House 育成舎
3. Brooder House 育すう舎
4. Incubator House ふ卵舎

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry, no matter how small, should be recorded to ensure the integrity of the financial statements. This includes not only sales and purchases but also expenses and income. The document provides a detailed list of items that should be tracked, such as inventory levels, accounts payable, and accounts receivable. It also outlines the procedures for recording these transactions, including the use of double-entry bookkeeping and the importance of regular reconciliations.

The second part of the document focuses on the analysis of financial data. It explains how to interpret the various components of the financial statements, such as the balance sheet, income statement, and cash flow statement. It provides a step-by-step guide to calculating key financial ratios and metrics, such as the current ratio, debt-to-equity ratio, and gross profit margin. The document also discusses the significance of these ratios and how they can be used to assess the financial health and performance of the organization.

The third part of the document addresses the issue of budgeting and financial planning. It explains how to develop a realistic budget that takes into account all aspects of the organization's operations, including fixed and variable costs, revenue, and capital expenditures. It provides a detailed framework for monitoring and controlling the budget, including the use of variance analysis and the importance of regular communication and reporting. The document also discusses the role of budgeting in strategic planning and how it can be used to identify areas for improvement and growth.

The fourth part of the document discusses the importance of financial reporting and transparency. It explains how to prepare clear and concise financial statements that provide a true and fair view of the organization's financial position. It also discusses the importance of disclosing all relevant information, including risks and uncertainties, and the role of external auditors in verifying the accuracy of the financial statements. The document provides a detailed guide to the requirements for financial reporting, including the use of standardized accounting principles and the importance of maintaining accurate records.

The fifth part of the document addresses the issue of financial risk management. It explains how to identify and assess the various risks that can affect the organization's financial performance, such as market risk, credit risk, and liquidity risk. It provides a detailed framework for managing these risks, including the use of hedging strategies, credit controls, and liquidity management. The document also discusses the importance of regular risk assessments and the role of senior management in overseeing the risk management process.

The sixth part of the document discusses the importance of financial innovation and technology. It explains how to leverage the latest financial technologies, such as cloud-based accounting systems, data analytics, and artificial intelligence, to improve the efficiency and accuracy of financial operations. It provides a detailed guide to the selection and implementation of these technologies, including the importance of data security and the role of IT support. The document also discusses the importance of staying up-to-date on the latest financial trends and innovations.

The seventh part of the document addresses the issue of financial ethics and compliance. It explains how to ensure that all financial transactions are conducted in accordance with applicable laws and regulations, and that the organization maintains a strong ethical culture. It provides a detailed guide to the requirements for financial ethics and compliance, including the importance of regular training and the role of the board of directors in overseeing the process. The document also discusses the importance of maintaining accurate records and the role of external auditors in verifying the accuracy of the financial statements.

The eighth part of the document discusses the importance of financial communication and stakeholder engagement. It explains how to effectively communicate financial information to all stakeholders, including investors, creditors, and employees. It provides a detailed guide to the development of financial reports and the importance of regular communication and reporting. The document also discusses the importance of maintaining accurate records and the role of external auditors in verifying the accuracy of the financial statements.

The ninth part of the document addresses the issue of financial sustainability and long-term growth. It explains how to develop a sustainable financial strategy that takes into account all aspects of the organization's operations, including fixed and variable costs, revenue, and capital expenditures. It provides a detailed framework for monitoring and controlling the budget, including the use of variance analysis and the importance of regular communication and reporting. The document also discusses the role of budgeting in strategic planning and how it can be used to identify areas for improvement and growth.

The tenth part of the document discusses the importance of financial innovation and technology. It explains how to leverage the latest financial technologies, such as cloud-based accounting systems, data analytics, and artificial intelligence, to improve the efficiency and accuracy of financial operations. It provides a detailed guide to the selection and implementation of these technologies, including the importance of data security and the role of IT support. The document also discusses the importance of staying up-to-date on the latest financial trends and innovations.

付属資料4 帰国後ビルマ側に送付した設計図

5月4日実施協議チームが帰国した後、畜舎等の設計のため、さらに次の設計図 (Floor Plan) を、ビルマ畜産公社関係者に送付した。

第1回 (6月 日)

(1) ふ卵舎 (Incubator House)

軒高、ドアの位置等を手直した設計図

第2回 (6月23日)

(2) 飼料生産施設 (Feed Mill)

(3) 飼料攪拌・粉碎システム (Feed Milling and Crashing System)

(4) 粉碎機据付図面 (Setting Layout and Specification of Feed Crasher)

(5) ケージ式育成舎 (Grower House)

(6) ケージ式成鶏舎 (Layer House)

第3回 (7月6日)

(7) 自家発電機 (Stand-by Power Plant)

第4回 (7月10日)

(8) 豚簡易屠場 (Pig Slaughter House)

第5回 (8月19日)

(9) 全体レイアウト改訂案

(10) 試験研究室 (生化学・栄養)

June 23, 1978

NOTE FOR DESIGN DRAWING OF FEED MILL AND CAGE POULTRY HOUSE

I. Cage Poultry House

1. Brooder House

An ordinary poultry house designed in consultation with Mr. Akiyama, will be used for cage-system brooder house. One unit of brooder and twelve units of brooder battery (for 2 to 8 weeks grower) will be accommodated in one room each.

2. Grower House

One group-battery breeding house will be constructed, on the basis of design attached hereto.

1) Floor level is 40 cm higher than ground level.

2) Bamboo-made curtain procured locally, will be hung inside as sun-shade.

3) Insulator under roof will be attached, if available.

3. Layer House

One layer house will be constructed on the basis of the same design shown in Grower House.

4. Installation (Set-up) of battery instrument

An engineer will be sent to Burma to set up these battery instrument for two weeks.

II. FEED MILL

Layout and design for feed mill are revised as an attached plan

1) Feed Crasher: "Hammer Crasher No. 3"

The crasher will be installed in pit (2300 x 700 x 600^H mm)

Appendix 1. Feed Mill

2. Feed Milling and Crashing System

3. Setting Layout and Specification of Feed Crasher

4. Design of Grower House (Maruto Model)

5. Design of Layer House (Maruto Model)

NOTE FOR STAND-BY POWER PLANT (EMERGENCY ELECTRIC GENERATOR)

1. Floor concrete should be over 600 mm thick.
2. Exhausted pipe should be fixed 500 mm distant from side wall.
3. Eight (8) holes (150 x 400 mm depth) should be made to install anchor bolt of electric generator.
4. Some part (1 - 1.5 square meter open to outside) of side wall (opposite to exhausted pipe) will be made of zig-zag type brick or gallery type door (to be substituted by bamboo-made door)
5. Stand-by power plant will be constructed near to transformer and incubator house. At the same time, noise and vibration will be factors to be considered.

Detailed design of the stand-by power plant draughted by Burmese engineers will be checked in Japan, when the design will be sent to JICA.

Livestock Development Division
JICA

July 6, 1978

NOTE FOR DESIGN FOR PIG SLAUGHTER HOUSE

1. This floor design is drawn by Dr. Oishi, according the existing slaughter house of Ibaraki Branch, Shirakawa National Livestock Breeding Station.
2. The cold room with floor space (12 square meter; 4 x 3 m) accommodate 25 head (liveweight 100 kg) of dressed carcass.
3. A freezer in the cold room has specification of 5000 kcal/h.
4. Waiting yard is fenced with by iron pole (90 cm height). Pig are washed and cooled here by shower.
5. Washing passage for cleaning pigs is equipped with shower instrument.
6. Pigs are slaughtered electrically and bled in the slaughter room.
7. Carcass is hanged by electric hoist and moved by sliding ceiling rail, and soaked into scalding. (hot-water bath)
8. Carcass is soaked in the scalding (63--65°C) in a few minutes, then moved to dehairer.
9. After dehaired in a minute, some hair of carcass is completely taken on gambrelling table. Then, ^(remain) hanging by electric hoist, evisceration is made, weighed by scale, and cut by electric saw in the dressing room. Washed carcass is stocked in the cold room.
10. Hot water is provided through boiler, in addition it is warmed by piped heater in the scalding equipment.
11. Boiler has a specification of 75,000 kcal/h.
12. Specification for hot-water circulation pump are diameter of 50 mm, pumping-up capacity of 150 l/min, and pumping-up height of 4 m.
13. Hot water from boiler is conducted to the evisceration room.
14. Petrol storage tank should be installed for boiler.
15. Each room requires at least two taps (water).
16. Waste disposal facilities are also necessary, such as incinerator for blood, hair and viscera etc. and drying equipment.
17. This design is not ideal one, because of additional construction of scalding facilities. It is desirable that linear processing line is adopted for worker's convenience.

18. This design is just an example of pig slaughter house, as an experiment stage.

Prepared by Livestock Development
Division, JICA

10th July, 1978

COMMENTS ON COMPLEHENSIVE LAYOUT OF 10 MILE FARM

After examining the layout plan, the following comments are made by Dr. Seki.

1. Alteration of housing site

Among housing complex A and B, which are facing a road, housing complex A should be moved to northward in some extent (shown by arrow) and housing complex B should be moved to C area. B area should be categorized as project area, where no housing should be located.

2. Alteration of the site for cage poultry houses

Although two poultry houses (cage grower house type 1, cage layer house 1) are sited in D area, they should be relocated to B area after alteration of the housing site.

3. Relocation poultry houses

Brooding house and grower houses complex are too densely located, therefore these layout arrangement should be simplyfied. To prevent poultry disease effectively in the broiler house area, commercial broiler zone and brooding and grower house (broiler breeder) should be separated with a control zone (dotted red line) between the two area. The control (off limit) zone will be afforested. Fifty-seven (57) broiler houses should be located on the right side of control zone, and its layout should be studied, covering the area pointed by the arrows. Broiler breeder complex should be located on the left side of the control zone, where brooder house for breeder should be sited with proper distances.

Above mentioned comments on layout should be designed with thorough consideration of annual prevailing wind direction.

4. Feed mill facilities

Pathogene is easily invaded to the project site, with raw materials of feed to be transported. For this reason, it will be desirable to install the feed mill facilities in H area near the Farm gate. The existing feed storage could be utilized for feed mill.

Even if the feed mill facilities are to be installed in F area feed storage (P.S) and storage for raw materials (F.S) should be sited vice versa.


5. Location of hatchery and laboratory (biochemistry and nutrition)

The hatchery and laboratory equipment are easily affected by electric black-out, therefore stand-by power plant will be able to supply electricity to both facilities. For this reason. G (hatchery) should be relocated to the laboratory site as same.

COMMENTS ON ELECTRICAL INSTALLATION DESIGN OF HATCHERY

The following comments on hatchery are made by Mr. Akiyama with consultation of a engineer of Showa Hatchery Company.

1. The specification of incubator will be modified to 200-230 voltage, considering smooth operation.
2. Electric wiring of ventilation fan should be connected to an electric controller (stabilizer), enabling one time operation (turn on and off) for ventilation.
3. A plug receptacle should be located on the right side back of incubator house.
4. Switches for ventilators and electric shutter in disinfectant room will be fixed on the wall of egg selection room, since nobody enters into the room during disinfecting and smoking (fumigating).
5. Water supply device and two (2) plug receptacle should be fixed in the egg cooler room (egg storage), because two (2) units of air-conditioners will be installed.
6. The desirable electric wiring in the incubator house will be divided to four (4) lines as follows:
 - 1) one circuit to the hatchers (3) and setters (8) in the northern half of incubator room.
 - 2) one circuit to the hatchers (2) and setters (8) in the southern half of incubator room.
 - 3) One circuit to egg cooler room.
 - 4) one circuit to electric light, ventilators etc.
7. The design of hatchery are drawn satisfactory, based on the revised proposal.



19 August 1978

EXPLANATORY NOTE ON LABORATORY DESIGN (BIOCHEMISTRY AND NUTRITION)

Two alternative design plan for laboratory are made for a reasonable choice of Burmese side.


Plan A (500 square meters) is made with consultation of researchers of Feed Quality Control Laboratory of MAFF.

Plan B (compact size) is made as same as the existing feed analyze laboratory attached to Okazaki National Livestock Breeding Station of MAFF.


The following comments on laboratory Plan A is made by researcher group of FQCL of MAFF.

1. Arrangement order of rooms and placement of tables and cabinet will be re-examined based on actual condition in Burma.
2. It is desirable to install air exhausters at low and high position of each room. Particularly, powerful air exhausters are necessary in draft chamber and ether room.
3. Two (2) gas valves will be installed in draft chamber. Four (4) to six (6) gas valves will be installed in the main laboratory room and equipment room. (It is desirable that these gas valves can be housed in laboratory tables)
4. Electric receptacles (20 Ato 50A) and branch circuit panel (electrical distribution) should be installed in each room.
5. The plug receptacle in ether room should be modified to "anti-explosive type".
6. Water taps (2 to 10) will be fixed in each room. According to regulation in Japan, inner diameter of water tap (ordinary) is 10 to 12 mm and inner diameter of chemical water tap is 8 mm to provide water current of 15 to 20 l per minutes.
7. It should observe electrical regulation in force in Burma concerning voltage, amperage, cycle, transformer, distributor panel and wiring.
8. It is desirable to install regulators for water pressure and gas pressure.
9. Necessary structural arrangement should be made for design of cylinder (gas container room).


INCUBATOR ROOM
FRONT ELEVATION




BACK ELEVATION



INCUBATOR ROOM SIDE SECTION






付属資料 4-1(2) 飼料生産施設


Appendix 1. Feed Mill

Feed Mill



付属資料 4 — (3) 飼料攪拌・粉碎システム

Appendix 2. Feed Milling and Crashing System



(注) 飼料粉碎機（旭式ハンマークラッシャー NO3 型）

1) 粉碎システムの一部変更について

当初案及びリスト価格で指示した粉碎機については、今回メーカー及び本機種を使用中の飼料工場の調査を行った結果、当初考えていた牧場で従来から使用して来た機械と異り、その粉碎システム、レイアウト取扱いについて大幅な変更が必要になった。（別図参照）

主な変更点は次のとおり

(A) 防塵対策

高速回転であるため、当初案では粉碎後の飛散が甚しいために、クラッシャー下部にホッパーを付け、さらにスクリーコンベアによって搬出する。

この場合、ホッパー内の粉塵を除去するためのエア抜きを付け、木綿布による沓過搬出を行う。

(B) 原料投入口の改良

原料のはね返りを防ぐため、上部に大型投入ホッパーをつけ、ダンパーによる投入量の調節を行う。

(C) 台座及びピットの新設

上記改造を行うには台座（60cm）が必要である。この場合地上に設置したのでは、1 m 70 cmの高さになり、原料投入作業が困難になる。ためにピット（2.300 × 700 × 600H）を掘り、粉碎システムをこのピット内に設置する。

(D) 機種の変更


上記の理由により、台座、投入ホッパー、受口ホッパー、コンベア、同モーターなどが新たに必要となり予算的に当初予算より大幅な超過になる。この対策として、4型機を3型機にダウンし、1時間当りの粉碎能力を1,000 kgとした。

見積金額 863,500 円（当初案 650,000 円）

ハンマークラッシャー	450,000
台 座	100,000
投入ホッパー	30,000
スクリーウ（クロスオーガー）	120,000
モーター 10hp	39,500
モーター 2hp	24,000
荷造、運賃	100,000

付属資料 4 — (4) 粉碎机据付図面


Appendix 3. Setting Layout and Specification of Feed Crasher



付属資料 4-1(5) ケージ式育成舎

Appendix 4. Design of Grower House

MARUTO's Grower House (Layer House)



(注) ㊦式ケージ養鶏システム

1) 育すう施設について(給温バッテリー 廃温バッテリー)

餌付後8週令までの育すう期の施設については、当初㊦式育すう鶏舎を設置することを考えたが㊦式養鶏法発明者の辻一夫氏と話合った結果、ビルマ側建設予定の育すう舎をそのまま使い、餌付から2週令までの給温育すう器1台を1室に、2週令から8週令までの廃温育すうバッテリー12台は1室に6台ずつ、計2室に收容することとする。

結果的には㊦式育すう鶏舎の新設は不要である。給温は石油ヒーター式(日本ではプロパン)に改造する。

2) 育成施設について(㊦式大すう群飼ケージ)

㊦式大すう舎については別紙設計図により1棟を設置する。

ビルマの気象条件を考え床面の高さを通常より20cm高くし、地上高から40cm高とする。

上部空間のカーテンはとりやめ、現地で生産されているアンペラ材をひな群を移動收容後、1~2週間吊り下げ直射日光の射入をさけることとする。

屋根材は現地生産のスレートとし、下地材(断熱材)は入手できれば入れるが、なければスレートのむき出しでもよい。


屋根モニター部の幅は通常60cmであるが、現地の多雨性を考え10cm伸ばし70cmとした。

3) 産卵施設について(㊦式産卵ケージ)


通常は幅24.25cmケージの2羽飼いであるが、現地の気象条件を考え1羽飼いとし、別紙設計図により、間口3m、長さ36mの㊦式産卵鶏舎(構造は大すう舎と同じ、吊下げケージのみ異なる)1棟を設置する。

4) 育すう器具、ケージの組立てについて

㊦式バッテリー育すう器具及び大すうケージ、産卵ケージは分解して荷造輸送する。現地での組立て、ケージのセッティング、㊦式養鶏法の技術指導については、経験者(豊橋飼料養鶏試験場長菅沼氏)を7~10日ていど現地に派遣することを考えている。



付属資料4-(7) 豚簡易屠場




- Necessary Equipment
- 1. Electric Chain Block 3 Units
 - 2. Electric Saw 1.
 - 3. Electric Slaughter Instrument
 - 4. Hook and Trolley for hanging carcass
 - 5. Dressing Swords
 - 6. Ventillation Fan

FLOOR DESIGN OF PIG SLAUGHTER HOUSE, IBARAKI BRANCH, SHIRAKAWA
NATIONAL LIVESTOCK BREEDING STATION


SCALE 1/50

JULY, 1978
JICA TOKYO



付屬資料4—(8) 試驗研究室(飼料分析 生化学)

PLAN A. FLOOR PLAN OF LABORATORY (BIOCHEMISTRY AND NUTRITION)





Laboratory Floor		575 m ²
1	gas analysing room	50
2	smashing room	25
3	diagnostic room	25
4	main laboratory	150
5	chemical store room	46
6	gas cylinder room	4
7	main equipment room	100
8	balance room	25
9	ether room	50
10	passage	75

総面積 500 m²

1. 各室の配置順及び実験台、戸棚等の配置は、現地状況にあわせ別途検討すること。
2. 各室上部及び下部に排気装置を設けることが望ましい。特に原子吸光光度計上部、ドラフト及びエーテル室には強力な排気装置が必要。
3. 分解室ドラフト内にはガス口を2個ずつ。主検査室、機器室にはガス口4～6個ずつ（実験台内に格納できる形式が望ましい。）を設ける。
4. 各室に電気用20A～50Aコンセント、分電盤による分岐回路を設けることが望ましい。（国内規定参照のこと）
5. エーテル室コンセントは防爆型とする。
6. 各室に水道設備2～10個設置。
日本の蛇口は、おおむね内径10～12mm、化学水栓は内径8mmで15～20ℓ/分。
7. 電圧、電流、周波数調整器及び分電盤、屋内配線等は国内配線規定によること。
8. 水圧、ガス圧調整器を設けることが望ましい。
9. ポンベ室には、構造上必要な措置を講ずること。
10. その他国内法規に照らし、細部の調整を計ること。

PLAN B. FLOOR PLAN OF FEED ANALYZING ROOM OF OKAZAKI NATIONAL LIVESTOCK STATION


付属 4 一 (8) 試驗研究室 PLAN(B) (岡崎種畜牧場飼料分析室)



名称	用途	構造	面積	備註
飼料分析室	飼料分析	鉄骨コンクリート	120.00	
研究室	研究	鉄骨コンクリート	80.00	
事務室	事務	鉄骨コンクリート	40.00	
倉庫	倉庫	鉄骨コンクリート	100.00	
廊下	廊下	鉄骨コンクリート	20.00	
トイレ	トイレ	鉄骨コンクリート	10.00	
洗面所	洗面所	鉄骨コンクリート	10.00	
玄関	玄関	鉄骨コンクリート	10.00	
その他	その他	鉄骨コンクリート	10.00	
合計			300.00	

設計者 岡崎種畜牧場 設計部
 監理者 岡崎種畜牧場 設計部
 縮尺 1/200
 1954.10.10

21-岡崎種畜牧場飼料分析室
 設計者 岡崎種畜牧場 設計部
 縮尺 1/200
 1954.10.10



器具设备明细表


器具设备平面图 1/50

品名	品牌	规格	数量	单位	备注	其他	合计
洗脸盆	215-107	水柱 5-(197) 5-107(标准)	4				4
洗脸盆	40-T14BA		2	2			4
化学水柜		40 台 3D 台	40	2	30		9
大便器	12-F5						1
洗脸盆	VL-630	付层类 (P1227)					1
洗脸盆	VL-410	付层类					1
洗脸盆	15-F11	B					1
洗脸盆							1
洗脸盆	20A-2277	10A	7				11
洗脸盆	P1-24	15-59-10A-2277 付层类	1				1
洗脸盆							1
洗脸盆	40-T5A						1
洗脸盆	50-C09						2

—	给水	12	4
—	排水	12	4
—	热水	12	4
—	蒸汽	12	4

设计人: 李...
 审核人: 张...
 日期: 2012年10月20日

PROPOSED PLAN LAYOUT OF TEN-MILE
PIG AND POULTRY FARM (RANGOON)
J.I.C.A. PROJECT
LIVESTOCK DEVELOPMENT AND MARKETING
CORPORATION



④ LDMC農場の全体配置図について

1. 宿舎位置の変更

道路両側に配置した宿舎群①、②のうち、①は道路からもう少し離して北側に設置する。

(↑印)

③は地図上の④の位置に変更し⑤地区は事業用地域とし、宿舎は設置しない。

2. モデルケージ鶏舎位置の変更

モデル鶏舎2棟(ケージ育成舎1、ケージ鶏舎1)が、①の位置におかれているが、宿舎位置変更後の⑤地区に設置する。

3. 鶏舎の配置変更、整理

鶏舎地区のうち、殊に育すう、育成鶏舎群は密集し、しかも配置が複雑で問題が大きい。コマーシャルブロイラーの育成と種鶏の育すう育成を分離する意味で、両地域間に防疫地帯(赤点線)を設置する。防疫地帯には植林を行う。⑥

ブロイラー鶏舎57棟は防疫地帯の右側とし、図中の→印の位置を含め、その配置を検討する。

種鶏地区は防疫地帯の左側とし、この地域に種鶏用育すう舎9棟を分散配置する。

以上の鶏舎配置については、現地における年間最多風向を十分配慮し設計すべきであろう。

4. 飼料関係施設 ⑦

飼料原料を外部から搬入する場合、同時に病原体が農場内に持込まれる危険性が極めて大きい。

ために飼料関係施設は入口に近い⑦地区に設置し既存の飼料庫を利用することが望ましい。

なお、飼料関係施設を⑦地区に配置するとしても、左側の飼料倉庫(製品)と、右側の原料倉庫FSとを入れ替えて配置すべきであろう。

5. 孵卵舎とラボの配置

停電による影響を受け易い孵卵舎⑧とラボについては、停電時には孵卵舎に設置した自家発電機による一括して電力の供給を受けることになっている。

ために、⑧をラボの位置に移し同一地域内とすることが望ましい。

(53. 8. 3 関)

付属資料 5 変電設備要請書

5th July, 1978.

Dear U Po Tin,

With reference to your letter dated 21st June, 1978 I just received a telegram from JICA, of which gist I am pleased to convey to you as follows:

1. It would soon send you through me an observation schedule in English for U Iyi Soo and you, as well as the contents of your consultation with JICA people on this project.
2. It is scheduled to send you through me designs of laboratory slaughter house and others at the end of this month.
3. It conjectures the necessary electric power calculated by you of 1 mega watt for your farm might be too much in view of the fact that Mr. Seki's farm which keeps 10,000 grown-up birds and 40,000 chicks needs the electric power of 240 KW only.

Therefore, it would like to hear from you as quickly as possible about (1) the breakdowns or details of electric power which is expected to be consumed by your farm and (2) the rough estimate of costs of the electric facilities including transformers.

Sincerely yours,

JIRO OBIKUNI,
Extra-Chancellor,
Embassy of Japan.

U Po Tin,
Deputy General Manager,
Livestock Development and Marketing
Corporation,
Incheon.

Dated: 6-7-78.

Mr. Jiro Obitsu,
Extra Chancellor,
Embassy of Japan,
Rangoon.

Dear Mr. Obitsu,

1. Thank you very much for your kindness to convey me the information from JICA regarding the observation schedule and contents of discussion, design of laboratory, slaughter house and others and electrical power consumption.
2. I tried to catch up the Electrical engineers to hold discussion with regard to your request to work out the actual and accurate, as far as possible, power consumption which would be required by the project.
3. We have been holding discussion and detail calculation had been worked out. All those detail calculations along with their work sheets are attached herewith for information and checkup (Annex. I).
4. Electrical Engineers had kindly furnished me all the necessary detail including the cost of electrical installation covering the whole project which is appended as Annex. II
5. The list of electrical facilities proposed to be supplied by Japan is attached herewith as Annex. III.
6. I hope , JICA authorities and experts concerned will come clear when they had studied the attached papers.
7. I had already managed to send Negatives of Designs regarding the civil construction and electrical installation to JICA through you on coming Monday the JULY 10, 1978. It does not cover all because some more designs are still undergoing detail touching. The rest of the designs will be sent as soon as possible, when they are finished.
8. I hope every confusion concerning the electrical power consumption will be clear when JICA had studied the attached papers along with their respective designs.
9. I had reminded my boss to expedite sending A.1,2,3 & 4 forms to Japan.

Sincerely yours,

(Pa Tin)

Deputy General Manager,

Livestock Development & Marketing Corp:

Summarised Explanation on
ELECTRIC POWER CONSUMPTION
of
J I C A P R O J E C T
at
10th. HILL FIG AND POULTRY FARM.

- (1) Total Connect Load = 1662.83 Kilo Watt (Project Only)
- (2) Including Existing Load = 1662.83 + 30 = 1692.83 KW.
- (3) Maximum Load (Estd.) = 790.70 + 30 = 820.70 KW
- (4) Calculated \bar{c} overall
 Diversity factor = 1692.83 x 50% = 846.415 KW
- (5) Minimum Consumption = 1692.83 x 25% = 423.2075 KW
 \bar{c} 25% D.F.
- (6) Operating Time/day = 12 hr/day
- (7) Daily Power Consumption = 423.2075 x 12 = 5078.49 (K.W.H.)
 in Kilo Watt hour
- (8) Cost / day (1 KWH = 0.2 K) = 5078.49 x 0.2 = 1015.698 K/day
- (9) Cost/month = 1015.698 x 30 = 30470.940 Ks.
- (10) Cost/ Annual = 1015.698 x 30 x 12 = 3,65,651.28 Ks.
- (11) Reference 1. " Farm Electrification"- by Robert H. Brown
 E.E., A.E. Indian Edition, Mc Graw-Hill Book Co.
 Inc., New York and London, Allied Pacific Private
 Ltd., Bombay.
2. " AEI - General Information on Cables and
 Conductors " - 12th. Edition , June 1965.
 Associated Electrical Industries International
 Ltd., 33 Grosvenor Place, London SW.

TOTAL CONNECT LOAD OF JICA PROJECT.

Sr. No.	Name	K W
1.	Pig Farm	181.35
2.	Poultry Farm	1039.84
3.	Technical Training Centre	136.70
4.	Feed Mill	50.94
5.	Residential	243.92
6.	Road Light	10.08
	Total Connect Load	1662.83
	Existing Load	30.00
		1692.83 Kilo Watt

K*

INDIVIDUAL CORRECT LOAD

No.	Name	No	$\frac{KW}{bdg}$	Total	Sr. No.	Name	No.	$\frac{KW}{bdg}$	Total
<u>TRAINING CENTER</u>					<u>RESIDENCIALS</u>				
1.	Main Office Bdg	1	36.88	36.88	1	Project Manager	1	5.0	5.0
2.	Lab:	3	20.0	60.0	2	As.:Gen:Man:	2	7.6	15.2
3.	Student Qtr:	2	16.8	33.6	3	Farm Manager	1	51.56	51.56
						Staff & Specialist			
4.	Fuel Store	1	0.72	0.72	4.	Deputy Farm Manager, Senior	5	3.36	16.8
						Vet., Acc:			
5.	Mach: Equip: & Store	1	5.5	5.5	5.	Assist:han: Vet. Assist:	8	3.3	26.4
				136.70	6.	Other Staff	52	2.48	128.96
									243.92
<u>FEED MILL</u>									
1.	Office	1	6.46	6.46					
2.	Feed Store	3	2.32	6.96					
3.	Product Store	3	1.20	3.6					
4.	Milling & Mixing	1	32.92	32.92					
5.	Garage	1	1.0	1.0					
				50.94					

INDIVIDUAL CONNECT LOAD

Sr. No.	Name	No	$\frac{KW}{bdy}$	Total	"	Sr. No.	Name	No.	$\frac{KW}{bdy}$	Total
<u>FIG FARM</u>					"	<u>POULTRY FARM</u>				
1.	Farm Office	1	6.46	6.46	"	1.	Farm Office	1	6.46	6.46
2.	Boar House A	1	14.9	14.9	"	2.	Incubator Hqs.	1	49.94	49.94
3.	Boar House B	1	4.9	4.9	"	3.	Brooder House	66	9.58	632.28
4.	Weaner House	3	7.27	21.81	"	4.	Grower House	17	6.28	106.76
5.	Dry Sow House	5	9.9	49.5	"	5.	Breeding "	20	10.4	208
6.	Grower House	2	4.78	9.56	"	6.	Kodol "(2)	1	0.54	0.54
7.	Finisher House	10	5.84	58.4	"	7.	" (6)	1	0.78	0.78
8.	Feed Store	1	2.32	2.32	"	8.	Feed Store	1	1.32	1.32
9.	Mach: Eqp: Sto:	1	0.5	0.5	"	9.	Mach: Eqp: St:	1	1.5	1.5
10.	Dispensery	1	1	1	"	10.	Dispensery	1	1	1
11.	P.M.	1	1	1	"	11.	P.P.P	1	30	30
12.	Slaughter	1	3	3	"	12.	Stand by P.P.	1	0.24	0.24
13.	Disinfection Room	1	0.5	0.5	"	13.	Disinfection Room	1	0.5	0.5
14.	Cold Storage	1	7.5	7.5	"					
				181.35	"					1039.34
				=====	"					=====

ANNEX. I

Electrical Estimated Load for Pig and Poultry
Development Project (10) Mile, Rangoon.

Sr. No.	Description	K.W.	Remarks
1	Pig Farm	81.20	
2.	Poultry Farm	491.02	
3.	Technical Training Centre	80.94	
4.	Feed Mill	43.04	
5.	Residential	84.42	
6.	Road Light	10.08	
		790.70	

I
PIG FACTS

Sr.No.	Name of Building	i.w. building	Building No.	Total i.w.	Remarks
1.	Farm office Building.	2.56	1	2.56	
2.	Boar House(TypeA)	4.40	1	4.40	
3.	Boar House(TypeB)	1.90	1	1.90	
4.	Weaner House	6.27	3	18.81	
5.	Dry Sow House	3.15	5	15.75	
6.	Grower House	1.78	2	3.56	
7.	Finisher House	1.84	10	18.40	
8.	Feed Store	1.32	1	1.32	
9.	Machinery & Equipment Store	0.50	1	0.50	Assumption.
10.	Dispensary	1.0	1	1.0	Assumption
11.	Post Mortem Room	1.0	1	1.0	Assumption
12.	Slaughter House	3.0	1	3.0	Assumption
13.	Dis-infection Room	0.50	1	0.50	
14.	Cold Storage	7.50	1	7.50	
				81.20	

I

1. Farm Office Building

Sr.No.	Description	No. pt. x wattage	D.F.	Total wattage	Remarks
1.	Internal Lighting	3pt x 60=180	1	180	Batten point
		12 x 40=480	1	480	F/D fitting
		2 x 60=120	1	120	36" ceiling fan.
		3 x 1000=3000	0.25	1300-	5A 3in Socket
		2 x 100 = 200			5A 2in Socket
		1 x 2000=2000		15A 3in Socket	
2.	External Lighting (Security Lighting)	8 x 60=480	1	480	Batten pt; water tight
		Grand Total		<u>2560</u>	(2.560)K.w.

I

2. Boar House (type A)

Sr. No	Description	No. pt; x wattage	D.F.	Total wattage	Remarks
1.	Internal Lighting	9 x 60=540	1	540	pendant point.
		4 x 1000=4000			5A 3in Socket
		5 x 2000=10000			15A 3in Socket
2.	Security Lighting	6 x 60=360	1	360	Batten point
		Grand Total		<u>4400</u>	(4.4.K.W.)

I

3. Boar House (type B)

Sr.No.	Description	No.pt. x wattage	D.F.	Total wattage	Remarks
1.	Internal Lighting	9 x 60=540	1	540	Pendant point
		4 x 1000=4000	0.25	1000	5A 3Pin Socket
2.	Securitylight.	6 x 60= 360	1	360	Batten point
		Grand Total		1900	(1.9 K.W)

I

4. Weaner House

Sr.No.	Description	No. pt;x wattage	D.F.	Total wattage	Remarks
1.	Internal lighting	11 x 60= 660	1	660	Pendant point
		2 x 1000=2000	0.5	1000	5A3Pin Socket
2.	Brooder light	34 x 125=4250	1	4250	Broode Lamp (125 watt)
3.	Security light	6 x 60=360	1	360	Batten point
		Grand Total		6270	(6.27 K.W.)

I

5. Dry Sow House

Sr.No.	Description	No.pt. x wattage	D.F.	Total wattage	Remarks
1.	Internal lighting	13 x 60= 780	1	780	Pendant point
		5 x 1000=5000	0.25	2250	5A 3Pin Soc:
		2 x 2000=4000			15A 3Pin Soc:
2.	Security lighting	2 x 60= 120	1	120	Batten point
		Grand Total		3150	(3.15 K.W.)

I

6. Grower House

Sr.No.	Description	No.pt. x wattage	D.F.	Total wattage	Remarks
1.	Internal Lighting	7 x 60= 420	1	420	Pendant point
		4 x 1000=4000	0.25	1000	5A 3Pin Soc:
2.	Security lighting	6 x 60=360	1	360	
		Grand Total		1780	(1.78 K.W.)

I

7. Finisher House

Sr. No.	Description	No. pt. x wattage	D.F.	Total wattage	Remarks
1.1.	Internal Lighting	8 x 60=480	1	480	Pendant point
		5 x 1000=5000	0.20	1000	5A3Pin Socket
2.	Security lighting	6 x 60=360	1	360	Batten point
		Grand Total		1840	(1.84 K.W.)

I

8. Feed Store

Sr.No.	Description	No. pt. x Wattage	D.F.	Total wattage	Remarks
1.	Internal Lighting	14 x 60= 840	1	840	Pendent point
2.	Exhaust Fan	10 x 100=1000	1	1000	(20" Exhaust Fan)
3.	Security Light	8 x 60= 480	1	480	Batten point
		Grand Total		1320	(1.32 K.W.)

GOLD STORAGE

Dimension 9' x 15' x 9'
Capacity 2000 x 3.6 lb. (Fork) (102°F)
Storage Temperature 38°F.
Product Load = sv. bt. x lb. x T.D. x $\frac{1}{24}$
= 0.68 x 2000 x 3.6 x (102-38) x $\frac{1}{24}$
= 1360 x 3.6 x 64 x $\frac{1}{24}$
= 1360 x 4.2 x 8
= 1360 x 9.6
= 13056 Btu/hr.
Space Load = 6.5 Btu/sq.ft./hr x Space Area
= 6.5(2 x 9 x 15 + 9 x 15 + 2 x 9 x 9)
= 6.5 x 702
= 4563 Btu/hr.

(Cork Insulation 4")

Total Load = 13056 + 4563
= 17619 Btu/hr.

12000 Btu/hr. = 1 ton of refrigeration = 1 HP.

Therefore H.P. = $\frac{17619 \times 24}{12000 \times 4}$ (operating 4 hr. out of 24 hrs.)

$$= \frac{17619}{2000}$$

= 8.8095 H.P.

Say 10 H.P.

II
POULTRY FARM

Sr.No.	Name of Building	K.W/Building	Building No.	Total K.W	Remarks
1.	Farm Office Building	2.56	1	2.56	
2.	Incubator House	46.94	1	46.94	
3.	Brooder House	4.58	66	302.28	
4.	Grower House	2.08	17	35.36	
5.	Breeding House	3.40	20	68.00	
6.	Model House(Layer)	0.54	1	0.54	
7.	Model House(Grower)	0.78	1	0.78	
8.	Feed Store	1.32	1	0.32	
9.	Machinery & Equipment Store	1.50	1	1.50	
10.	Dispensary	1.00	1	1.00	
11.	Poultry Processing Plant	30.00	1	30.00	
12.	Stand by Power Plant	0.24	1	0.24	
13.	Dis-infection Room	0.50	1	0.50	
			Total	<u>491.02</u> =====	

II:

3. Grower House

Sr.No.	Description	No.pt.x watt.	D.F.	Total watt.	Remarks
1.	Internal Lighting	12 x 60=0.72	1	0.72	Pendent Pt;
2.	Security Light	5 x 1000=5000	0.20	1	Soc:5A3P.
		6 x 60=0.36	1	0.36	Batten Et;
Grand Total				2.08 K.W.	=====

II

4. Breeder House

Sr. No.	Description	No.Pt.x watt	D.F.	Total watt.	Remarks
1.	Internal	34 x 60=2.04	1	2.04	Pendent Pt;
2.		8 x 1=8	1/8	1	Soc:5A3P.
2.	Security Light	6 x 60=0.36	1	0.36	Batten Et;
Grand Total				3.4 K.W.	=====

II

5. Model House (Layer House)

Sr. No.	Description	No. Pt; x watt	D.F.	Total watt:	Remarks
1.	Internal Lighting	9 x 60=0.54	1	0.54 K.W.	

II

6. Model House (Grower House)

Sr. No.	Description	No. Pt; x Watt	D.F.	Total watt	Remarks
1.	Internal Lighting	13 x 60=0.78	1	0.78 K.W.	

III. TECHNICAL TRAINING CENTRE

Sr.No.	Description	K.W./Bldg	No.of Building	Total K.W.	Remarks
1.	Main Office Building	15.18	1	15.18	
2.	Laboratory	15.00	3	45.00	
3.	Machinery and Equipment Store	4.980	1	4.980	
4.	Student Quarter	7.41	2	14.82	
5.	Fuel Store	0.96	1	0.96	
Grand Total				80.94	*****

III.

1. Main Office Building.

Sr.No.	Description	No.pt:x watt	D.F.	Total watt	Remarks
1.	Internal light	42 x 60=2.520	0.6	1.51	Pendant Pt;
2.		30 x 100=3.00	0.6	1.80	Ceiling Fan
		63 x 40=2.520	0.6	1.51	
		26 x 1000=26.00	0.25	6.50	Soc:5A3P.
		4 x 60=0.240	0.25	0.06	Mirror Lamp
3.		20 x 100=2	0.10	0.20	Soc:5A.2P.
2.	Security Light	10 x 60=0.60	1.00	0.60	
3.	Air Conditioner				
	Window type 4H.P.	3 x 1000=3.00	1.00	3.00	
Grand Total				15.18 K.W.	*****

III.

2. Machinery and Equipment Store

Sr.No.	Description	NoPt: x watt:	D.F.	Total watt:	Remarks
1.	Internal Lighting	22 x 40=880	0.5	0.440	4'-40W F/L
2.	Security Light	9 x 60=540	1.0	0.54	
3.	Air Conditioner	1/830			
	1 H.P.	4 x 1=4	4.00	4.000	
Grand Total				4.980	*****

III.

3. Student Quarter

Sr.No.	Description	No.Pt:x watt.	D.F.	Total watt	Remarks
1.	Internal Lighting				
		44 x 60=2.640	1	2.640	Pendent Lt:
		19 x 40=0.760	0.8	0.608	4'-40W F/L
		7 x 100=0.700	0.8	0.560	Ceiling Fan
		17 x 100=1.700	0.50	0.850	.Soc:5A2P.
		7 x 1000=7.000	0.25	1.75	" " 3P.
		2 x 2000=4.000	0.25	1.000	" 15A "
	Grand Total			7.410	

III.

4. Fuel Store

Sr.No.	Description	No.Pt:x watt	D.F.	Total watt	Remarks
1.	Internal Lighting	6 x 60=0.360	1	0.360	
2.	Security Lighting	5 x 60=0.300	1	0.300	
	Grand Total			0.960	

IV.
FEED MILL

Sr.No.	Description	K.W./Buidg	No of Bdg.	Total K.W.	Remarks
1.	Office Building	2.56	1	2.56	
2.	Feed Store	1.32	3	3.96	
3.	Product store	1.20	3	3.60	
4.	Milling & Mixing	32.92	1	32.92	
Grand Total				43.04	=====

IV.
1. Feed Milling & Mixing.

Sr.No.	Description	No. Pt: x watt	D.F.	Total watt	Remarks
1.	Mixer	2 x 7.5 HP x 746	4	11.19	
2.	Screw Conveyor	2 x 2.0HP x 746	1	2.98	
3.	U-Conveyor	2 x 20 HP x 746	1	2.98	
4.	Crusher	2 x 7.5 HP x 746	1	11.19	
5.	U-Conveyor	2 x 2.0HP x 746	1	2.98	
6.	General Lighting	20 x 80	1	1.60	4'-40W F/L
Grand Total				32.92	=====

IV.
2. Product Store

Sr.No.	Description	No. Lt: x watt	D.F.	Total watt.	Remarks
1.	Internal Lighting	14 x 60=0.840	1	0.840	Pendant Ft;
2.	Security Lighting	6 x 60=0.360	1	0.360	Batten Ft;
Grand Total				1.200	=====

V.

RESIDENTIAL

Sr.No.	Name of Building	K.W./Bdg.	Bdg.No.	Total	Remarks
1.	Project Manager (1300/-Scale Qr.)	5	1	5.000	
2.	Assistant General Manager. (800/---50-1000)	2.6	2	5.20	
3.	Farm Manager ,Staff Officer, & Specialist (45)-25-700)	9.36	1	9.36	(8 Rooms) (two storjes)
4.	Dy. Farm Manager, Senior Veterinarian, B.C.& Dy. Farm Manager Account- tant, Feed Mill Manager. (300-15-420)	1.11	5	5.50	
5.	Assistant Manager & Veterinarian Assist: (185-15-305)	1.05	8	8.40	
6.	Other Staff (130-10-200)	0.98	52	50.96	
Grand Total				84.42	=====

V.

1. Residential

Sr.No.	Description	No.Ft: x watt	D.F.	Total watt	Remarks
1.	130-10-200scale Qr.	8x60=0.48 2 x 1000=2.00	1 0.25	0.480 0.5 <u>0.980</u>	Pendent Pt; Soc: 5A3P
2.	185-15-305Sci:Qtr.	5 x 60=0.30 3 x 1=3	1 0.25	0.300 0.75 <u>1.05</u>	Pendent Lt; Soc: 5A3P.
3.	300-15-420Sci:Qtr.	6 x 60=360 1 x 1=1 } 1 x 2=2 }	1 0.25	0.36 0.75 <u>1.11</u>	Pendent Pt: Soc: Lt: 5A " 15A.
4.	450-25-700Sci:Qtr.	56 x 60=3.360 32 x 1 = 32 8 x 2 =16	1 0.125 0.125	3.36 4.000 2.000 <u>9.36</u>	Pendent Pt; Soc: 5A3P. " 15A."
5.	800-50-1200 "	10 x 60=0.6 5 x 1= 5 1 x 2=2	1 0.20 0.50	0.6000 1.000 1.000 <u>2.600</u>	Pendent Lt; Soc: 5A.3P. " 15A3P.

ANNEX. II.

PROVIDING ELECTRICAL INSTALLATION AND DISTRIBUTION (EXTERNAL)
IN RIG AND FOUNDRY WARE, " JICA PROJECT " AT 10 MILE.
PRIME ROAD, R A N G O O N .

Sr. No.	Particulars	Amount.
1.	<u>S U M M A R Y.</u>	
1.	High Tension Electrical Equipment and Power Cable for 6.6.k.v./0.4 K.V. Substation.	K/ 9,71,620.00
2.	High Tension Electrical Equipment And Power Cable for 33/6.6K.V. Substation.	K/ 3,43,000.00
3.	Low Tension Electrical Distribution and Control Accessories at "A" Station.	K/ 2,24,050.00
4.	Low ^{Tension} Electrical Distribution and Control Accessories at "B" Station.	K/ 3,40,270.00
5.	Low Tension Electrical Distribution and Control Accessories at "C" Station.	K/ 5,37,190.00
		K/24,14,730.00
		=====
		1,400.00
		K/24,16,130.00
		=====

(Kyats Twenty-Four Lakh Sixteen Thousand, one hundred and Thirty-
only.)

Sr. No.	Particulars	Unit	Quantity	Rate per	Amount
<u>HIGH TENSION ELECTRICAL.</u>					
<u>EQUIPMENT AND POWER CABLE FOR 6.6K.V./0.4 SUBSTATION.</u>					
1.	Power Transformer 6.6/0.4 K.V. 300 K.V.A. Indoor Type (for 30 sqm in H.T. and 65 sqm in L.T. single core).	No.	3	40,000/-ea	1,20,000/-
2.	Oil circuit breaker 3 ϕ indoor type 7.2 K.V. 600 amp rating capable of breaking capacity 250 M.V.A. Complete with bus-section comprising 3 Nos. of 7.2 K.V. 400A with power assisted mechanism making and breaking of circuit and fitted with instantaneous tripping device under fault condition in accordance with the protective relays.	No.	1	30,000/-ea	30,000/-
3.	Oil circuit breaker 3 ϕ indoor Type 7.2 K.V. 400 Amp. rating capable of breaking capacity 150 M.V.A. complete with power assisted mechanism making and breaking of circuit and fitted with instantaneous tripping device under fault condition in accordance with the protective relays.	No.	6	30,000/- ea	1,80,000/-
4.	Three phase indoor type air circuit breaker with metal link 600 Amp 500 volt rating with bus-section for three outgoing feeder of circuit breaker complete with power assisted mechanism relays.	No.	3	20,000/-ea	60,000/-
5.	7.2. K.V. 600 Amp disconnecting switch Complete with power assisted mechanism operated manually.	No.	1	7,000/-ea	7,000/-
6.	7.2 K.V. 400amp disconnecting Switch complete with power assisted mechanism manually.	No.	6	5,000/-ea	30,000/-
					C.C. 4,27,000/-

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
7.	Under Ground cable for 6.6 K.V. Grade 3 Core 30 sq.mm (packing 3 core in 300 metre coil).	Ht.	1,800	3,500/-	B.F.	4,27,000/-
8.	30 sq.mm 6.6K.V. under ground cable, cable jointing materials and accessories.	No.	4	3,000/-	ea.	12,000/-
9.	Lightning arrester 84 K.V.A. Rating 3 Nos. One Set complete with accessories.	Set.	4	15,000/-	Set	60,000/-
10.	1 x 19/083 or (1 x 50 sq.mm) polyvenyl chloride and sheathed wire 500 volt grade (packing single in 100 meter coil).	Ht.	1,000	1,000/-	mt.	10,000/-
11.	Plate copper 18"x18"x1/4" earth electrode or cast Iron plate.	Sht.	7	250/-	Sht	1,750/-
12.	3/8" Ø x 1 1/2" long brass bolt & nut.	No.	14	10/-	ea.	140/-
13.	Soldering paste or fluxite in 1 lb. tin.	Tin	3	10/-	Tin	30/-
14.	Soldering lead ready mixed	Vs.	2	100/-	Vs	200/-
15.	Emery clothes.	Sht.	12	2/-	Sht.	24/-
16.	Kerosene	Gr.	4	7/-	Gr.	28/-
17.	6.6 K.V. to 0.4 K.V. substation building with fencing and protection size in 40' x 20'.	No.	3	30,000/-	ea.	90,000/-

Total Cost of materials

6,63,672/00

18. Labour Charges for the above installation and fitting.

1,32,734/00

Amount (A)

7,96,406/00

ADD.

5% Transporting loading & unloading charges on (A)

39,820/50

2% Depreciation charges on (A)

15,928/13

3% Design, estimating & stationary charges on (A)

23,829/15

12% overhead charges on (A)

95,568/77

K. 9,71,615/75

Bay K. 9,71,620/-

(Kyats Nine Lakh Seventy One Thousand, Six Hundred and Twenty Only).

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
II. HIGH TENSION ELECTRICAL EQUIPMENT.						
AND POWER CABLE FOR 33K.V/6.6 KV SUBSTATION.						
1.	Power transformer 1000 K.V.A. 33K.V. to 6.6 KV in door type for 60 sq.mm 3 core out going terminal point complete with the above cable, entry accessories.	No.	1	1,00,000	ea	1,00,000/-
2.	Under ground cable 33 K.V. Grade 3 core 60 sq.mm butyl rubber insulated polychlorophene sheathed wire. (packing 3core in 100 metre coil)	Mt.	200	6,000	%Mt	12,000/-
3.	36 K.V. 600 amp disconnecting switch complete with power assisted mechanism operated manually.	No.	1	5,000	ea	5,000/-
4.	36 K.V. oil circuit breaker 3Ø indoor type 400 A, 750 M.V. A capable of breaking capacity complete with cubicle of power assisted mechanism making and breaking of circuit and fitted with instantaneous tripping device under fault conditions in accordance with the protective relays.	No.	1	50,000	ea.	50,000/-
5.	Lightning arrester of 42 K.V. rating 3 Nos. in one set complete with accessories.	Set	1	15,000	Set	15,000/-
6.	36 K.V. 400 amp, disconnecting switch complete with power assisted mechanism operated manually.	No.	2	5,000	ea.	10,000/-
7.	Plate copper 18"x18"x¼" Earth electrode or cast iron plate.	"	1	250	ea	250/-
8.	¾"Ø x 1½" long brass bolt & nut	"	2	10	ea	20/-
9.	Soldering paste or fluxite in 1lb tin	tin	1	10	tin	10/-
10.	Soldering lead ready mixed.	Vs	1	100	Vs	100/-
11.	Emery clothes	sht	6	2	sht	12/-
12.	Kerosene	gat	2	7	gat	14/-
13.	19/0G4 stranded copper conductor for earth continuity.	lb.	20	13	lb.	260/-
14.	33 K.V. to 6.6 K.V. substation building with fencing and protection size 40"x20"	No.	1	30,000	ea	20,000/-
Cost of materials						2,22,666/-

Sr. No.	Particulars	Unit Quantity	Rate	Per Amount
			Cost of materialsB/E	2,22,666/-
15.	Labour Charges for the above fitting and installation.			63,332/20
			Amount (A)	2,85,998/20
	<u>ADD.</u>			
16.	5% Transporting loading and unloading charges on (A)			14,299/91
17.	2% Depreciation charges on (A)			5,719/96
18.	3% Design estimating and stationary charges on (A)			8,579/95
19.	12% overhead charges on (A)			34,319/78
			Total:-	3,428,17/80

Say K. 3,43,000/-

(Kyat three lakh fourty three thousand only).

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
<u>III. LOW TENSION ELECTRICAL</u>						
<u>DISTRIBUTION AND CONTROL ACCESSORIES AT "A".</u>						
1.	Straining insulator 3"x4 1/2" for post stay.	No.	25	15/-	ea	375/-
2.	Pin Insulator 2 1/2"x3 3/4" with spindle bolt and nut.	"	150	10/-	"	1,500/-
3.	Shackle insulator 3" with bolt and nut complete with straps for medium tension.	"	200	15/-	"	3,000/-
4.	Porcelain insulator egg type 2 1/2"x3 3/4" (aerial fuse for street light and service main).	"	100	3/-	"	300/-
5.	Wire G.I. 7/16" for stay and continuity earth.	lb.	500	10/-	lb/	5,000/-
6.	Cross arm 4 pin type 3"x4"x40" hard wood complete with pole clamp, bolt and nut.	No.	50	50/-	ea	2,500/-
7.	Copper wire No. 4 S.W.G. hard drawn bare.	lb.	3,200	15/-	lb.	48,000/-
8.	Copper wire No. 8 S.W.G. hard drawn bare	"	350	15/-	"	5,250/-
9.	Bracket for street lighting	No.	39	20/-	ea	780/-
10.	1/2" P.V.C. pipe for guard with clamp, bolt & nut	"	10	30/-	"	300/-
11.	1" x 6ft. long G.I. pipe with 2 nos. pole earth.	"	10	150/-	"	1,500/-
12.	Street light fixture 4'4" OW fluorescent fitting with tube, starter, chole, 230V, A.C.	Set	39	400/-	Set	1,56,000/-
13.	Electric post 27' reinforced complete as per drawing.	No.	55	700/-	ea	38,500/-
14.	Post footing for the above post	"	55	200/-	"	11,000/-
15.	Stay rod 3/4" x 6ft. long M.S. rod with 12" long thread complete.	"	25	60/-	"	1,500/-
16.	Stay swivel 3/4" x 14"	"	25	50/-	"	1,250/-
C.O.						1,36,355/-

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
				B.F.		1,36,355/-
17.	Clamp for post stay and continuity earth made of 2"x1/2" M.S.flat.	No	60	20/-	ea	1,200/-
18.	Enamel paint in 1 gallon tin	tin	2	150/-	tin	300/-
19.	Lead ready mixed for soldering	lb.	1	100/-	lbs	100/-
20.	Soldering paste or fluxite in 1 lb tin.	tin	2	10/-	tin	20/-
21.	Emery clothes.	sht	6	2/-	sht	12/-
22.	Kerosene	gal	2	7/-	gal	14/-
23.	Paint brush 2"	No.	3	20/-	ea	60/-
24.	Hack saw blades	#	6	5/-	"	30/-
25.	Control switches for distribution triple pole with neutral 200 amp rating moulded case circuit breaker or T.P.I.C. with neutral link main switch.	"	3	1,500/-	"	4,500/-
26.	Control switches for street light supply 30 amp D.P.I.C. main switch or circuit breaker.	"	3	150/-	"	450/-
27.	2" P.V.C. pipe and cable rising rack from substation to four pole structure. (one item)					10,000/-
				Cost of materials		1,53,041/00
28.	Labour charges for above installation and fitting.					30,608/20
				Amount (A)		1,83,649/20
<u>ADD.</u>						
	5% transporting, loading and unloading charges on (A)					9,182/46
	2% depreciation charges on (A)					3,672/98
	3% design, estimating and stationary charges on (A)					5,509/48
	12% overhead charges on (A)					22,037/90
				Total K/		2,24,052/02
	Say K.			2,24,050/-		

(Kyats two lakh, twenty four thousand and fifty only).

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
IV. LOW TENSION ELECTRICAL DISTRIBUTION AND CONTROL ACCESSORIES AT " B ".						
1.	Straining insulator 3"x4½" for poststay.No.		30	15/-	ea	450/-
2.	Pin insulator 2¼"x4" with spindle bolt and nut	"	280	10/-		2,800/-
3.	Sheackle insulator 3"with bolt and nut complete withstraps for medium tension.	"	200	15/-	"	3,000/-
4.	Procelain insulator egg ty e2½"x4" (aerial fuse for street light and service main).	"	200	3/-	"	600/-
5.	Wire G.I. 7/16" for stay and continuity earth.	lb.	950	10/-	lbs	9,500/-
6.	Cross arm 4 pin type 3"x4"x40" hard wood complete with pole clamp,bolt and nut.	No.	90	50/-	ea	4,500/-
7.	Copper wire no. 4S.W.G.hard drawn bare.	lb	6,100	15/-	lb	91,500/-
8.	" " No.8 " " " "	"	700	15/-	"	10,500/-
9.	Bracket for street light fixture	No.	78	20/-	ea	1,560/-
10.	1"φ x 5ft. long G.I. pipe new with 2 Nos.3/8"φ 1½" brass bolt & nut for pole earth.	"	20	150/-	"	3,000/-
11.	¾"φP.V.C. pipe forguard with clamp, bolt and nut for above earth.	"	20	30/-	"	600/-
12.	Street light fixture 4' 40W fluorescent fitting with tube, starter, choke 230V, A.C.	"	78	400/-	"	31,200/-
13.	Electric post 27' reinforced as per drawing.	"	95	700/-	"	66,500/-
14.	Post footing for he above post.	"	95	200/-	"	19,000/-
15.	Stay rod ¾"φ x 6ft. long H.S. rod with thfeed of 12" long complete.	"	30	60/-	"	1,800/-
16.	Stay switch ¾" x 14" for rod	"	30	50/-	"	1,500/-
17.	Clamp for post stay and continuity earth made of 2"x½" H.S. flat	"	95	20/-	"	1,900/-
18.	Enamel paint in 1 gallon tin	Tin	3	150/-	Tin	450/-
19.	Solding lead for ready mixed.	Vs.	1	100/-	Vs.	100/-
						G.O. 2,50,460/-

Sr.No.	Particulars	Unit	Quantity	Rate	Per	Amount
				B.F.		2,50,460/00
20.	Soldering paste of fluxite in 1 lb. tin.	tin	2	10/-	tin	20/-
21.	Emery clothes.	sht	12	2/-	sht	24/-
22.	Kerosene	gal	4	7/-	gal	28/-
23.	Paint brush 2".	no.	6	20/-	ea	120/-
24.	Hack saw blades.	"	6	5/-	"	30/-
25.	Control switches for distribution triple pole with neutral 200 amp rating moulded case circuit breaker of T.P.I.C. with neutral link main switch."		3	1,500/-	" "	4,500/-
26.	Control switches for street light supply 30 amp D.P.I.C. main switch or circuit breaker.	"	3	150/-	"	450/-
27.	2" ϕ P.V.C. pipe and cable rising rock from substation to four pole structure. (one item)					10,000/-
				Cost of materials		2,65,632/00
28.	Labour charges for above installation and fitting.					13,281/60
				(A)		2,78,913/60
	<u>ADD.</u>					
	5% Transporting, loading and unloading charges on (A)					13,945/68
	2% depreciation charges on (A)					5,578/27
	3% design, estimating and stationary charges on (A)					8,367/41
	12% overhead charges on (A)					33,469/63
				Total K.		3,40,274/59
				Say K.		3,40,270/-

(Kyats three lakh , fourty thousand , two hundred and seventy only)

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
<u>V. LOW TENSION ELECTRICAL DISTRIBUTION AND CONTROL ACCESSORIES AT " C ".</u>						
1.	Straining insulator 3"x4½" for post stay.	No.	30	15/-	ea	450/-
2.	Pin Insulator 2"x3½" with spindle bolt and nut	"	360	10/-	"	3,600/-
3.	Shackle insulator 3" with bolt and nut complete straps for medium tension.	"	240	15/-	"	3,600/-
4.	Porcelain insulator egg type 2"x¾" (Aerial fuse for street light and service main)	"	240	3/-	"	720/-
5.	Wire G.I. 7/16" for stay and continuity earth.	lb.	1,500	10/-	lb	15,000/-
6.	Cross arm 4 pin type 3"x4"x40" hard wood complete pole clamp, bolt & nut	No.	150	50/-	ea	7,500/-
7.	Copper wire No 4 S.W.G. hard drawn bare.	lb	9,600	15/-	lb.	1,44,000/-
8.	Copper wire No. 8S.W.G. hard drawn bare."	"	1,100	15/-	"	16,500/-
9.	Bracket for street light fixture	No.	95	20/-	ea	1,900/-
10.	1"øx6ft. long G.I. pipe new with 2Nos. 3/8"x1½" brass bolt and nut for pole earth.	"	30	150/-	"	4,500/-
11.	¾" P.V.C. pipe for guard with clamp bolt & nut for above earth.	"	30	30/-	"	900/-
12.	Street light fixture 4'-40W. fluorescent fitting complete with tube, starter, choke 250V, A.C.	"	95	400/-	"	38,000/-
13.	Electric post 28' reinforced	"	120	700/-	"	84,000/-
14.	Post footing for the above post.	"	120	200/-	"	24,000/-
15.	Stay rod ¾" c 6ft. long M.S. with thread 12" long complete.	"	30	60/-	"	1,800/-
16.	Stay switch ¾" x 14" for above	"	30	50/-	"	1,500/-
17.	Clamp for post stay and continuity earth made of 2"x ¾" M.S. Flat.	"	150/-	20/-	"	3,000/-
18.	Emul paint in 1 gallon tin.	Tin	4	150/-	Tin	600/-
19.	Soldering lead ready mixed.	Vs.	2	100/-	Vs.	200/-
20.	Soldering paste or fluxite in 1 lb. tin.	tin	2	10/-	tin	20/-
21.	Hack saw blades.	No.	6	5/-	ea	30/-
C.O.						3,51,820/-

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
				B.F.		3,51,820/00
22.	E,ery clothes/	sht	6	2/-	ea	12/-
23.	Kerosene	gal	4	7/-	gal	28/-
24.	Paint brush 2"	No	6	20/-	ea	120/-
25.	Control switches for distribution triple, pole with neutral 200 amp rating moulded case circuit, breaker or T.P.I.C. with neutral link 500 volt main switch.	No	3	1,500/-	ea	4,500/-
26.	Control switches for street light supply 30 amp D.P.I.C. main switch or circuit breaker.	"	3	150/-	"	450/-
27.	2" P.V.C. Pipe and cable rising rick from substation to from substation to four pole structure.	(One item)				10,000/00
Cost of materials						3,66,930/-
28.	Labour charges for above installation and fitting.					73,386/00
						(A) 4,40,316/00
<u>ADD.</u>						
	5% transporting, loading and unloading charges on (A)					22,015/80
	2% Depreciation charges on (A)					8,806/32
	3% design, estimating and stationary charges on (A)					13,209/48
	12% overhead charges on (A)					52,837/92
Total K.						5,37,185/52

Say K. 5,37,19000

(Kyats five lakh, thirty seven thousand one hundred and ninety only).

Annex III.

ELECTRICAL FACILITIES WHICH SHOULD BE SUPPLIEDBY JAPAN" PROPOSED LIST OF ELECTRICAL FACILITIES "


Sr. No.	Particulars	Unit	Quantity	Rate C&P	Per Amount
1.	Power Transformer 6.6/0.4 KV. 330 KVA indoor Type (for 30sqmm in H.T. and 65 sqmm in L.T. single core).	No.	3	40,000	ea 1,20,000
2.	Oil circuit breaker 3 ϕ indoor type 7.2 KV. 600 amp rating capable of breaking capacity 250 M.V.A complete with bus-section comprising 3 Nos. of 7.2 KV 400 A with power assisted mechanism making and breaking of circuit and fitted with instantaneous tripping device under fault condition in accordance with the protective relays	"	1	30,000	" 30,000
3.	Oil circuit breaker 3 ϕ indoor type 7.2 K.V. 400 amp rating capable of breaking capacity 150 MVA complete with power assisted mechanism making and breaking of circuit and fitted with instantaneous tripping device under fault condition in accordance with the protective relays	"	6	30,000	" 1,80,000
4.	Three phase indoor type air circuit breaker with metal link 600 Amp 500 volt rating with bus-section for three out going feeder of circuit breaker complete with power assisted mechanism relays.	"	3	20,000	" 60,000
5.	7.2KV 600 Amp disconnecting switch complete with power assisted mechanism operated manually.	"	1	7,000	" 7,000
6.	7.2KV 400 Amp disconnecting switch complete with power assisted mechanism manually.	"	.6	5,000	" 30,000
7.	Under ground cable for 6.6.KV. Grade 3 core 30 sq. mm (Packing 3core in 300 metre coil).	Mt.	1,800	3,500	%Mt 63,000


Annex III. (Contd.)

Sr. No.	Particulars	Unit	Quantity	Rate	Per	Amount
8.	30 sq. mm. 6.6 KV. under ground cable, accessories, jointing materials and accessories	No.	4	3,000	ea	12,000
9.	Lighting arrestor 84 M.V.A. rating 3 Nos. in one set complete with accessories.	Set	4	15,000	Set	60,000
10.	1 x 19/ 0.83 or (1 x 50 Mm ²) polyvinyl chloride and sheathed wire 500 volt grade (Packing single in 100 metres coil)	Mt	1,000	1,000	%Mt	10,000
11.	Power Transformer 1000 KVA 33 KV to 6.6 KV indoor type for 60 sq. mm. 3 core out going terminal point complete with the above cable, entry accessories.	No.	1	1,00,000	Ea.	1,00,000
12.	Under ground cable 33 KV. Grade 3 core 60 Sq.mm butyl rubber insulated poly chlorophene sheathed wire (packing 3 core in 100 metre coil)	Mt	200	6,000	%Mt	12,000
13.	36KV. 600 Amp disconnecting switch complete with power assisted mechanism operated manually.	No	1	5,000	ea	5,000
14.	36 KV. oil circuit breaker 33 indoor type 400 A, 750 KV capable of breaking capacity complete with cubicle of power assisted mechanism making and breaking of circuit and fitted with instantaneous tripping device under fault condition in accordance with protective relays.	No.	1	50,000	ea.	50,000
15.	Lighting arrestor of 42 KV rating 3 Nos in one set complete with accessories	set	1	15,000	set	15,000
16.	36 KV. 400 Amp disconnector switches complete with power assisted mechanism operated manually.	No.	2	5,000	ea.	10,000
17.	Copper wire No. 4 S.W.G. hard drawn bare.	lb	189000	15	lb.	2,83,500
18.	Copper wire No.8 S.W.G. hard drawn Bare	lb	2150	15	lb.	32,250
19.	Control switches for distribution triple pole with neutral 200 Amp rating, moulded case circuit breaker or T.P.I.C. with neutral link 500 Volt main switch.	No.	9	1,500	ea.	1,35,00

Total Amount (Kyats)

10,93,250.





JICA