


3.7.4 Plan for Sewage Treatment Plants

(a) Types of sewage treatment processes

The types of sewage treatment processes are classified as follows.

Fig. 3.7.8 Sewage Treatment Processes



The following are 5 typical sewage treatment processes.

- (A) Trickling filtration process
- (B) Conventional activated sludge process
- (C) Rotary disk process
- (D) Mechanically aerated oxidation pond
- (E) Stabilization pond process

Generally speaking, the 3 factors listed below are taken into consideration when performing a comparative study.

- Efficiency
- Cost of construction
- Maintenance and operation cost.

Table 3.7.4 presents the results of the comparative study, for the present project, taking into account the 3 factors listed above. This study assumes that the unit costs of the land are the same and that the quantity and quality of the sewage are the same.

As a comparative data, Table 3.7.5 presents the costs of some sewage treatment processes adopted in India.

Table 3.7.4 Comparative Analysis of Sewage Treatment System

Method of Treatment	% of Efficiency	Index of Construction cost	Index of Operating and Maintenance cost
(A) Trickling filtration	75-85%	180	20
(B) Conventional activated sludge process	90-95%	250	25
(C) Rotary disk process	85-90%	120	15
(D) Mechanically aerated oxidation pond	90%	70	2
(E) Stabilization Pond process	75-85%	100	1

Table 3.7.5 Annual Cost of Sewage Treatment*

Sewage Treatment Process	Annual Cost (rupees/person)
Waste stabilization ponds	0.9 - 2.3
Aerated lagoons	2.8 - 4.8
Oxidation ditches	3.8 - 6.0
Conventional secondary treatment processes	3.5 - 13.2

* Central Public Health Engineering Research Institute, 1970.

The sewage treatment processes (A), (B), and (C) have high efficiency, and have been widely adopted, but as seen from the results of the master plan, the construction costs are very high, and the operation and maintenance costs exceed by far those of process (E). Thus, the present comparative study for the purpose of the present plan deals primarily with processes (D) and (E).

(b) Comparative Study on Treatment Processes

1) Mechanically aerated oxidation ponds

This method, which is used for secondary treatment of wastewater from tapioca factories, is recommended by the Thai Environmental Agency*. In this method, mechanical aeration devices are attached to the ponds which, by supplying the quantity of dissolved oxygen, maintain the ponds in the aerobic state so that pollutants are removed by aerobic bacteria. In the present planning area, planned maximum volumes of waste water to be treated are as follows.

Na Klua	10,180 m ³ /day
Pattaya	12,220 m ³ /day

If the treatment plant is divided into two units, the respective volumes to be treated in each unit would be as follows.

Na Klua	5,090 m ³ /day
Pattaya	6,110 m ³ /day

The water quality of the influent wastewater in Na Klua is BOD₅ = 198 mg/lit. and SS = 150 mg/lit.. In Pattaya, the respective figures are BOD₅ = 151 mg/lit. and SS = 150 mg/lit..

Planned water quality after treatment is BOD₅ = 30 mg/lit. and SS = 50 mg/lit. Assuming that 6 mechanical aerators of 11 kw power were installed in the aerated ponds at each treatment plant, and that two 3.7 kw aerators and two 5.5 kw aerators were installed in sedimentation ponds at the Na Klua and Pattaya plants, respectively, the following results are obtained.

	<u>Na Klua</u>	<u>Pattaya</u>
Treatment plant area	3.9 ha	4.5 ha
Construction cost (including land)	27.35 M.฿ (including in-plant pumps)	18.72 M.฿
Maintenance and supervision costs (until year 2006)	30.57 M.฿	26.68 M.฿

In using mechanically aerated oxidation ponds to treat sewage, sedimentation ponds are necessary in order for the sludge produced in the oxidation ponds through biological purification processes to be completely precipitated and removed, and in order to obtain clear treated water as a result. To remove and treat the precipitated sludge would be very difficult. One cannot very well rely on having success in removing all coliform bacteria from the mechanically aerated oxidation ponds, and thus disinfection facilities are necessary to reduce the bacteria before

*Design Guidelines for Treatment of Wastewater from Tapioca Starch Industry Environmental Quality Standard Division Aug. 1976.

the wastewater is discharged into water bodies. The aerators require maintenance which is more complex than in the case of stabilization ponds, and the costs are higher. On the other hand, they do not require as much land as stabilization ponds, and therefore, substitute for stabilization ponds in cases where it is impossible to acquire sufficient land for the latter.

2) Stabilization ponds

Stabilization ponds are relatively shallow ponds for the purposes of storing raw sewage or sewage post-precipitation treatment and providing favorable conditions for biological treatment and the bacteriological decomposition. This removal efficiency of stabilization ponds is greatly influenced by natural conditions, especially by temperatures, sunshine, and winds. Stabilization ponds have a long history of use as treatment facilities in many parts of the world. In America there are at present around 3,000 operating treatment plants which make use of these ponds. In recent years such ponds have come to be used in Israel, India, and other tropical regions. Stabilization ponds may be classified into the following three types.

- Anaerobic ponds
- Facultative ponds
- Maturation ponds

Characteristics of these three types are explained below.

(1) Anaerobic pond

The anaerobic pond has extremely high organic load and sewage is easily precipitated. This pond is intended to process sewage within a relatively short detention time. In order to keep the whole pond in the anaerobic state, it is normally required to keep the BOD₅ volumetric load above 100g BOD₅/m³.

According to the reference* in the bibliography, the BOD₅ removal efficiency and the detention time are related as follows.

(Assuming BOD volumetric load = 250 BOD₅/m³)

<u>Detention time (days)</u>	<u>BOD removal efficiency (%)</u>
1	50
2.5	60
5	70

Since anaerobic ponds have high contents of organic matter, the supply of oxygen produced by the photosynthesis of the algae is insufficient, and the quantity of dissolved oxygen in the pond approximates zero as time goes by. As a consequence, the aerobic bacteria die off and the pond becomes anaerobic.

Now, let us analyze these phenomena relating them with the occurrence of objectionable smell. It is very often the case that H₂S, which is the cause of objectionable odors, is generated when the pH of pond is low (pH ≤ 8). When the pond is in the anaerobic conditions the organic matter contained therein is digested by mainly the methane

* Sewage Treatment in Hot Climates, Duncan Mara

* Pre-Conference Short Course, International Conference on Water Pollution Control in Developing Countries Feb. 1978, Lecture Note, Environmental Division AIT.

bacteria, and as a consequence, the pond moves toward a low Ph. However, according to reference by AIT, it is said that no objectionable smell is generated if the volumetric loading of BOD₅ is below 400g BOD₅/m³ and the concentration of sulfates in the raw sewage is below 100mg/lit..

Thus, in order to maintain the anaerobic pond in appropriate conditions, the BOD₅ volumetric load should be maintained within the range of 100g BOD₅/m³ to 400g BOD₅/m³. Furthermore, if the pH value becomes excessively low, it should be compensated by adding alkaline chemicals. [CaCO₃, etc.]

The circulation of the treated water is also suggested as a method of preventing objectionable odor. Since in anaerobic ponds there is a larger production of sludge than in other types of ponds, it is necessary to clear up the sludge accumulated in the bottom of the pond every 3 to 5 years.

(2) Facultative ponds

The facultative ponds are intended to process sewage with lower organic matter load than the anaerobic ponds. The facultative ponds have generally a depth of 1 to 1.5 meters. The facultative ponds are composed of two layers, i.e., the upper layer is in the aerobic condition and the lower layer where sludge is accumulated is in the anaerobic condition.


In the aerobic layer, oxygen is supplied as a result of the photosynthesis of the algae, and thus, aerobic bacteria digest the organic matter existing therein.

As can be seen from the description above, the efficiency of the facultative ponds is widely influenced by the sunshine, the temperature and wind. In the lower anaerobic layer the same process as in anaerobic ponds takes place.

In addition, temperature, winds have an important influence on the process. Convection currents are generated in the pond as a consequence of wind and fluctuations of temperature, and this current mixes the organic matter, aerobic bacteria, algae and dissolved oxygen. In addition, the current prevents "short circuits" in the pond, improving process efficiency as a result. The facultative ponds present excellent characteristics as sewage treatment methods in tropical areas.

In tropical areas, thanks to the fairly uniform long day time from sunrise to the sunset and the high temperatures, there is an active photosynthesis of the algae all year round, which supplies an abundant quantity of dissolved oxygen to the aerobic bacteria. The month presenting the minimum average temperature should be taken as a reference in the design of facultative ponds. According to Fig. 3.7.9, since the pH value in facultative ponds is kept above 7.5 night and day, it is assumed that no objectionable smell is generated. However, since the processed water contains large quantities of algae, these must be removed in some cases.

Fig. 3.7.9 Diurnal variation of dissolved oxygen and pH in facultative pond effluent



Source: Coastal Water Pollution Survey of Chonburi Province - AIT

(3) Maturation ponds

The maturation ponds are used to treat urban sewage, and are planned together with the facultative ponds as components of a series of related sewage facilities. Like facultative ponds, the maturation ponds generally have depth of 1m to 1.5m. However, since the organic matter is removed in the facultative ponds of the preceding stage, the maturation ponds are kept completely in aerobic condition. The maturation ponds are chiefly intended to remove pathogenic bacteria contained in the sewage. The coliform organisms and viruses are almost totally removed in ponds with depth around 1.5m in aerobic condition, and in some cases no special sterilization facilities are required.


The BOD₅ removal efficiency of maturation ponds is not so much, but if the water coming from the facultative pond of the preceding stage has a BOD₅ concentration of the order of 50 to 70 mg/lit., it can be reduced to less than 25 mg/lit. by installing two maturation ponds in series, and treating sewage with a detention time of the order of 7 days in respective ponds.* Since the maturation ponds have high efficiency in the removal of coliform organisms and viruses, but have low efficiency in the removal of organic matter, the installation of this type facility is not applicable in the treatment of industrial wastewater.

3) Design of stabilization ponds

To function as a sewage treatment facilities, two or more ponds are more frequently arranged in one series, as shown in the following figure, instead of using a single pond individually.

* See page 110.

Typical Pond Layouts



F: Facultative ponds
M: Maturation ponds
A: Anaerobic ponds

If anaerobic ponds are adopted in the sewage treatment facility of this plan, the volumetric load of BOD₅ should be kept above 100g/m³ in order to keep them in the anaerobic condition. However, since the influent water of the treatment plant is planned to have a BOD₅ concentration of less than 200mg/lit., in order to maintain the anaerobic condition in the ponds with the BOD₅ volumetric load above 100mg/lit., the detention time should be less than 2 days. That naturally requires a reduced pond volume, resulting in more frequent operations to exclude sludge, inviting more risk of objectionable smells and lower BOD₅ removal efficiency.

According to references*, the optimum detention time in anaerobic ponds is 5 days, and in case detention time is longer, the ponds acquire facultative characteristics, instead of functioning anaerobically. Thus, in order to keep the volumetric load of BOD₅ at 100g BOD₅/m³/day with a detention time of 5 days, the quality of the influent water should have a BOD₅ concentration of more than 500mg/lit.

In view of the description above, the anaerobic ponds are very effective in the pre-treatment of sewage with high concentration of organic matters, and as pointed out previously, they are not appropriate for treating general wastewater from residents. Thus, in the present plan, sewage will be treated by means of combining facultative ponds and maturation ponds. The flow chart of the process is presented below.



A plan to combine anaerobic ponds and facultative ponds was adopted in the design stage of planning for the stabilization ponds at AIT. However, according to the report of AIT, since the actual quantity of influent sewage is of the order of 1/4 of the planned quantity, the ponds which are planned to work as anaerobic ones are presently working as facultative ones, and the ponds planned to function as facultative ones are presently working as maturation ones.

* See page 110.

Data referring to the BOD load, detention time, efficiency, etc., of the AIT stabilization ponds are presented below. The ponds planned to function anaerobically are 2.4m deep. Their upper layer of 1m depth is in the aerobic condition, the middle layer of 0.5m is in the anaerobic condition, and the final layer of 0.9m is the dead space, according to data from AIT.

According to the data of AIT and the results of the water quality survey, the BOD₅ removal rate becomes 87.5%, and the effluent quality of the facultative pond becomes 35mg/lit. of BOD₅. However, according to other reports*¹, the BOD₅ quality of the effluent of the facultative ponds is 50-70mg/lit.

Fig. 3.7.10 shows the relation between BOD₅ removal efficiency, temperature and detention time at the facultative ponds, presented in reference*². The causes of the differences found therein were not clear yet, but the differences in the concentrations of the various types of influent sewage are supposed to be an important factor. For the sake of safety, in the present plan it is assumed that the effluents of the facultative ponds have a BOD₅ concentration of 60mg/lit., with a further reduction to 30mg/lit. after the treatment at the maturation pond. Two maturation ponds are planned in one series, with a detention time of 7 days in each pond. However, as shown in the water quality survey of AIT, a further improved removal efficiency can also be expected. The facultative ponds and the maturation ponds are planned in accordance with reference*¹. In the anaerobic ponds there is the problem of objectionable smell, but since in the facultative ponds and in the maturation ponds the pH value is kept above 7.5, objectionable smell would not be generated.

However, during the rainy season, when the sunshine time becomes shorter, and the rain increases the quantity of influent, the photosynthesis of the algae becomes less active, causing reduction of pH value and odors may be caused by H₂S in the sewage. To prevent the objectionable smell under such conditions, a bypass piping will be installed, aiming at recycling treated water and discharging excess influent directly.

When the treated water is recycled, it will stay at the surface of the pond, because the treated water has higher temperature than the influent sewage temperature. In addition, since the treated water contains larger quantities of dissolved oxygen, it contributes to increase the pH value. This method is actually in use in a sewage treatment plant in South Africa, with excellent results. In the present plan, the quantity of recycled water is scheduled to be 1/6 of the influent sewage. In the stabilization ponds, besides the problem of objectionable smell, the treated water contains large quantities of algae, and they may cause pollution problems if discharged directly in the public water bodies.

As can be seen from the results of the water quality survey in the AIT stabilization ponds, the value of SS is higher in the effluent water compared with the influent water, and the treated water has green color. These facts are easily attributable to the algae which propagates in the ponds.

*¹ See page 110.

*² Waste Stabilization Pond W.H.O., Geneva, 1971, Gloyna, E.F.

Table 3.7.6. Results of Water Quality Surveys of AIT Stabilization Pond

	Area of the Ponds (1/2 of Depth)	Volume of the Ponds	Influent	Influent Quality	Detention Time	Superficial Load of BOD ₅	Volumetric Load of BOD ₅
Facultative Pond	423m ² x 2 ponds = 846m ²	950m ³ x 2 ponds = 1,900m ³	192m ³ /d	120mg BOD ₅ /lit.	About 10 days	272kg BOD ₅ /ha.d.	12g BOD ₅ /m ³ .d.
Assuming 0.9m of Dead Space	564m ² x 2 ponds = 1,128m ²	856m ³ x 2 ponds = 1,712m ³	192m ³ /d	120mg BOD ₅ /lit.	About 9 days	204kg BOD ₅ /ha.d.	13.5g BOD ₅ /m ³ .d.
Maturation Pond	1,595m ² x 2 ponds = 3,190m ²	2,080m ³ x 2 ponds = 4,160m ³	192m ³ /d	35mg BOD ₅ /lit.	About 22 days	21kg BOD ₅ /ha.d.	1.6g BOD ₅ /m ³ .d.

Table 3.7.7. Chemical Characteristics of AIT Raw Sewage, Facultative Pond Effluent and Maturation Pond Effluent

Characteristic	Sampling Station		
	Raw Sewage A	Facultative Pond Effluent B	Maturation Pond Effluent C
BOD ₅ , mg/l	120	35	15
S.S., mg/l	110	82	111
pH	7.3	7.5	8.4
NH ₃ -N, mg/l	5.4	3.0	0
NO ₂ -N, mg/l	0.01	0.17	0.12
NO ₃ -N, mg/l	0	0.014	0.090
Total N, mg/l	10.0	9.3	5.7
PO ₄ , mg/l P	0.48	0.39	0.32
Coliform, MPN index/100 ml	11,000,000	1,500,000	24,000
Fecal Coliform, MPN index/100 ml	46,000	9,300	1,100

Notes: AIT Wastewater Treatment Flow Diagram





Fig 3.7.10 Idealized BOD Removal Rates in Facultative Ponds




Data from I. Duarte (personal communication, 1968).

Nitrogen and phosphorus can be removed in the facultative ponds and in the maturation ponds, and the removal of algae from the discharged water is of fundamental importance in maintaining quality of the water discharged into the public water bodies. The present plan proposes the removal of algae by means of fishes and microstrainers. It is reported that the type of fish best suited for removal of algae is the guppy (Pla Hang Nok Yoong in Thailand).

The guppy is a viviparous freshwaterfish of the killifish family originally of South America, and is found worldwide as an ornamental fish. This fish has multiplied in Southeast Asian puddles and in effluents of spas in Japan, becoming a natural enemy of larvae of mosquitoes and other insects. In Thailand, it is reported that the Sanitary Authorities of the city of Bangkok have introduced the guppy into pools of wastewater, as a deliberate measure to remove mosquito larvae.*

The present plan proposes therefore the introduction of the guppy in the stabilization ponds with the aim of utilizing them in the removal of organic material. However, unfortunately, quantitative data regarding the removal of pollutant by guppies are not yet available. This, it is considered that the introduction of guppies into the stabilization ponds of the present plan are experimental, and that the subsequent collection of the required scientific data will be of significance for the future development. Since guppies have an extremely high vitality in wastewater compared with other fresh water fish, it is supposed that it is perfectly possible to raise them in the stabilization ponds. Guppy is a tropical fish, and requires water temperatures above 10°C to survive. In Pattaya, the annual minimum temperature is 25°C, so there will be no problem for their survival.

Following table is a rough estimate of the construction cost, if the flow chart is assumed.



	Na Klua sewage treatment plant	Pattaya sewage treatment plant
Area of the plants	29.8 ha	22.4 ha
Construction cost (including land)	34.66 M.฿	29.81 M.฿
Operation and maintenance costs (up to year 2006)	15.59 M.฿	11.02 M.฿

* Scientific Monthly, Vol. 23, No.10, Improvement of Ambiental Hygiene by Using Living Organisms, Hanabu Sasa.

In the treatment method utilizing stabilization ponds, the operation and maintenance is easier than other treatment methods. Operation and maintenance require the removal of grass from the ponds and in the water edges in order to prevent breeding of larvae of mosquitoes and gnats. Sludge layers which float on the surface of the anaerobic ponds when the temperature becomes higher than 22°C must also be removed.

In the facultative ponds the accumulated sludge should be removed at intervals of 10 to 15 years.

From the discussion presented above, it is concluded that the method utilizing stabilization ponds can be applied with the most moderate costs, including costs for operation and maintenance, and is also easy to operate and maintain. Thus, in the present sewerage plan the method utilizing stabilization ponds is recommended.


The following are the details of the sewage treatment with stabilization ponds.

4) Design of the treatment facilities


The planned sewage treatment facilities take 1996 as the target year, increasing the number of ponds in proportion to the quantity of sewage to be treated. Since the detention time of the sewage to be treated is relatively long, the daily average quantity of sewage should be taken into consideration in the design of the ponds.

(1) Flow chart of the sewage treatment plant

a. Na Klua Area



b. Pattaya Area



(2) Design conditions

a. Quantity of sewage to be treated

The quantity of sewage to be treated as taken into consideration in the design, is the daily average quantity in 1996, as follows.

Na Klua Treatment Station	13,360 m ³ /d	(including wastewater from Tapioca Industry and bungalows)
Pattaya Treatment Station	9,430 m ³ /d	

Generally speaking, the quantity of sewage treated in each unit of stabilization ponds is 2,500 m³/d. Thus, the Na Klua plant requires 5 units, and the Pattaya treatment plant requires 4 units.

The quantity of sewage to be treated in each unit is given as follows.

Na Klua Treatment Plant:
(13,360m³/d)/5 units = 2,680 m³/day per unit

Pattaya Treatment Plant:
(9,430m³/d)/4 units = 2,360 m³/day per unit

b. Water quality of the influent

The water quality of the influent is calculated by dividing it into three components, namely, general domestic wastewater, industrial wastewater and groundwater. Quality of the influent wastewater of the Na Klua Treatment Plant.

	Quantity	BOD ₅
General domestic wastewater	5,630 m ³ /d	200 mg/lit.
Industrial wastewater	5,000 "	300 "
Groundwater	2,730 "	5 "
Total	13,360 m ³ /d	

Influent BOD₅=

$$\frac{5,630\text{m}^3/\text{d} \times 200\text{mg}/\text{l} + 5,000\text{m}^3/\text{d} \times 300\text{mg}/\text{l} + 2,730\text{m}^3/\text{d} \times 5\text{mg}/\text{l}}{13,360 \text{ m}^3/\text{d}}$$

= 198 mg/lit.

In this case, the BOD₅ of the groundwater is assumed, for the sake of safety, to be BOD₅ = 5mg/lit., based upon the water quality study.

Quality of the influent wastewater in the Pattaya Sewage Treatment Plant:

	Quantity	BOD ₅
General domestic wastewater (Including hotel wastewater)	7,050 m ³ /d	200 mg/lit.
Groundwater	2,380 m ³ /d	5 mg/lit.
Total	9,430 m ³ /d	

Influent BOD₅=

$$\frac{7,050\text{m}^3/\text{d} \times 200\text{mg}/\text{l} + 2,380\text{m}^3/\text{d} \times 5\text{mg}/\text{l}}{9,430 \text{ m}^3/\text{d}}$$

= 151 mg/lit.

(3) Design of the ponds

a. Facultative ponds

The design of the facultative ponds is determined by the surface loading of BOD₅.

According to the reference*, the permissible surface loading of BOD₅ for purposes of design is given by the following two equations:

$$\lambda_s = 7.5 (1,054)^T$$

λ_s : Surface loading of BOD₅ kgBOD₅/ha.d

T : Minimum monthly average temperature throughout the year °F

$$\lambda_{s'} = 20T' - 120$$

T' : Minimum monthly average temperature throughout the year °C

By assuming a minimum monthly average temperature of 25°C in the Pattaya Area, the 2 equations above give the following value of the permissible surface loading of BOD₅:

$$\lambda_s = 7.5(1,054)^T = 7.5(1,054)^{\left(\frac{9}{5} \times 25 + 32\right)} = 430 \text{ kgBOD}_5/\text{ha.d}$$

$$\lambda_{s'} = 20T' - 120 = 20 \times 25 - 120 = 380 \text{ kgBOD}_5/\text{ha.d}$$

The smaller one of the two values calculated above, i.e., 380 kgBOD₅/ha.d will be taken as the permissible surface loading of BOD₅ in the design of the facultative ponds.

The removal of BOD₅ in facultative ponds is given by the following expression, according to the reference.*

$$\text{(Influent BOD}_5 \text{ quantity)} = \text{(Effluent BOD}_5 \text{ quantity)} + \text{(Quantity of BOD}_5 \text{ removed by biological oxidation)}$$

The relation above can be expressed as follows:

$$L_i Q = L_e Q + K_1 L_e V$$

L_i : Influent BOD₅ mg/l (g/m³)

L_e : Effluent BOD₅ mg/l (g/m³)

$$\frac{L_e}{L_i} = \frac{1}{1 + K_1 \left(\frac{V}{Q}\right)}$$

Q : Quantity of wastewater l/d (m³/d)

K_1 : BOD₅ removal efficiency d⁻¹

V : Pond's volume m³

$$\frac{L_e}{L_i} = \frac{1}{1 + K_1 t^*}$$

t^* : Detention time in the pond d

A : Required area of the pond m² (ha)

D : Depth of the pond m

Thus, the detention time t^* will be given as follows:

$$t^* = \frac{1}{K_1} \left(\frac{L_i}{L_e} - 1 \right).$$

And the required area of the pond will be given as follows:

$$A = \frac{Q}{DK_1} \left(\frac{L_i}{L_e} - 1 \right) = Qt^*/D.$$

* See page 110.

Here, the efficiency of removal of BOD₅ (K_T) gives the speed of biological removal of BOD₅. It is greatly influenced by temperature.

The relation between the BOD₅ removal efficiency K_T and the temperature T°C will be given as follows, as a function of its value at a given temperature (20°C in this case):

$$K_T = K_{20} \theta^{T-20}$$

Where:

K_T = BOD₅ removal efficiency at the temperature T°C d⁻¹

θ : BOD₅ removal constant
1.05-1.09 in case of stabilization ponds

K₂₀: BOD₅ removal efficiency when the temperature is T=20°C
(in South Africa K₂₀ = 0.3d⁻¹)

In the present plan the value θ=1.05 is assumed for the sake of safety, and K₂₀=0.3d⁻¹ as in South Africa.

Since in the Pattaya Area the minimum monthly average temperature during a year is 25°C, the BOD₅ removal efficiency K_T at the facultative ponds will be given as follows:

$$K_T = K_{20} \theta^{T-20} = 0.3 \times (1.05)^{25-20} = 0.383 \text{ d}^{-1}$$

The depth of facultative ponds is generally 1 to 1.5 meters. Since the area of the plan is located in a tropical area, with a minimum monthly average temperature of 25°C throughout the year, the facultative ponds of the present plan will have a depth of 1.5 meters. (The BOD₅ concentration in the sewage to be treated in the facultative ponds is assumed to be 60mg/lit., according to reference^{*}).

A safety allowance of 40cm is taken in the pond height, and the slopes will have a gradient of 1:2. The net required areas of the ponds will be calculated to correspond with the areas of the horizontal sections at a point of 1/2 the water depth.

b. Maturation ponds

A detention time of 7 days is assumed in the maturation ponds, according to reference^{*}, and in the present plan 2 ponds will be arranged in one series. The BOD₅ removal efficiency in the maturation ponds is low, but since the water treated in the facultative ponds will come with a BOD₅ concentration of 60 mg/lit., in the present plan it is assumed that the water treated in the maturation ponds will have a BOD₅ concentration below 30mg/lit.

The removal of fecal coliforms in the stabilization ponds is given by the following expression:

$$N_e = N_i / (1 + K_b t)^n$$

Where:

N_i : concentration of fecal coliform in the influent wastewater MPN/100ml

* See page 110.

N_e : Concentration of fecal coliform in the effluent water

K_b : Removal efficiency fecal coliform d^{-1}

t^* = Detention time d

(in each pond) : assumed as 7 days.

If n ponds are arranged in one series, the removal of fecal coliform will be given by the following expression:

$$N_e = \frac{N_i}{(1+K_b t^*)^1 (1+K_b t^*)^2 \dots (1+K_b t^*)^n}$$

The efficiency of removal of fecal coliform is influenced by the temperature. When it is $T^\circ C$, according to the reference, K_b is given by the following expression:

$K_b(T) = 2.6 (1.19)^{T-20}$ Since in the area of the present plan the temperature is $T^\circ C = 25^\circ C$, $K_b(T)$ is given as follows: $K_b(25) = 2.6 (1.19)^{25-20} = 6.20 d^{-1}$

A concentration of 4×10^7 MPN/100ml (most probable number per 100ml liter) of fecal coliform is assumed for the influent wastewater, and less than 3×10^3 MPN/100ml for the treated water. The maturation ponds will have the same construction as the facultative ponds.

c. Calculation of pond capacities

1. Na Klua sewage treatment plant

Facultative ponds

Quantity of sewage to be treated	2,680 m^3 /d. unit
Influent BOD ₅	198mg/l
Effluent BOD ₅	60mg/l

Required detention time

$$t^* = \frac{1}{KT} \left(\frac{L_i}{L_e} - 1 \right) = \frac{1}{K_{25}} \left(\frac{198}{60} - 1 \right) = 6.01 \text{ days}$$

Required area

$$A = \frac{Q}{DKT} \left(\frac{L_i}{L_e} - 1 \right) = \frac{2,680}{1.5 \times K_{25}} \left(\frac{198}{60} - 1 \right) = 10,729m^2 \approx 1.07 \text{ ha.}$$

Since the surface loading of BOD₅ is

$$\left(\frac{2,680m^3/d \times 198mg/l}{1.07 \text{ ha}} \right) \div 1.07 \text{ ha} = 496kg.BOD_5/ha.d > \text{permissible surface loading of BOD}_5 = 380kg.BOD_5/ha.d$$

This is higher than permissible surface loading of BOD₅.

The required area A will be given by

$$A = \left(\frac{2,680m^3/d \times 198mg/l}{380kg.BOD_5/ha.d} \right) \div 380kg.BOD_5/ha.d = 1.40 \text{ ha}$$

Thus, the ponds will be planned with an area of

$$70m \times 210m = 14,700m^2.$$

The detention time t^* will be given by

$$t^* = \frac{14,700m^2 \times 1.5m}{2,680m^3/d} = 8.2 \text{ days}$$

In this case, the BOD concentration in the effluents will be

$$L_e = \left(\frac{1}{1 + K_T t^*} \right) \times L_f$$

$$= \left(\frac{1}{1 + K_{25} \times 8.2} \right) \times 198 \text{ mg/lit.} = 48 \text{ mg/lit.}$$

Maturation pond

Detention time: 7 days x 2 ponds
Depth : 1.5 m

The ponds will be 66m x 190m = 12,540m², with a detention time of 7 days.

The concentration of coliform organisms in the treated water will have the following value:

$$N_e = \frac{N_i}{(1 + K_b(T) t^*_{Fac})(1 + K_b(T) t^*_{Mat})^2}$$

$$= \frac{4 \times 10^7}{(1 + 6.2 \times 8.2)(1 + 6.2 \times 7)^2} = 391 \text{ MPN/100ml} < 3 \times 10^3 \text{ MPN/100ml}$$

2. Pattaya sewage treatment plant

Facultative pond

Quantity of wastewater to be treated: 2,360 m³/d, unit
Influent BOD₅: 151 mg/l
Effluent BOD₅: 60 mg/l

Required detention time:

$$t^* = \frac{1}{K_{25}} \left(\frac{151}{60} - 1 \right) = 4.0 \text{ days}$$

Required area:

$$A = \frac{2,360}{1.5 \times K_{25}} \left(\frac{151}{60} - 1 \right) = 6,230 \text{ m}^2 = 0.62 \text{ ha}$$

The BOD₅ surface loading will be:

$$\frac{(2,360 \text{ m}^3/\text{d} \times 151 \text{ mg/l})}{0.62 \text{ ha}} = 575 \text{ kg BOD}_5/\text{ha.d} > 380 \text{ kg BOD}_5/\text{ha}$$

and this value exceeds the permissible surface loading of BOD₅. Thus, the required area A obtained by dividing the BOD₅ load by the permissible surface BOD₅ loading will be:

$$\frac{(2,360 \text{ m}^3/\text{d} \times 151 \text{ mg/l})}{380 \text{ kg BOD}_5/\text{ha.d}} = 0.94 \text{ ha.}$$

Then, ponds with an area of 58 x 190m = 11,020m² will be adopted in the present plan.

The detention time t* will be:

$$t^* = \frac{11,020 \text{ m}^2 \times 1.5 \text{ m}}{2,360 \text{ m}^3/\text{d}} = 7.0 \text{ days.}$$

Under the conditions calculated above, the BOD₅ concentration in effluent will be:

$$\begin{aligned}
 L_e &= \left(\frac{1}{1 + K_T t^*} \right) \times L_1 \\
 &= \left(\frac{1}{1 + K_{25} \times 7.0} \right) \times 151 \text{ mg/l} = 41 \text{ mg/l}
 \end{aligned}$$

Maturation ponds

Detention time: 7 days x 2 ponds
 Depth: 1.5 m

The maturation ponds, like the facultative ones, will be 58m x 190m = 11,020m², with a detention time of 7 days.

The concentration of fecal coliform in the wastewater to be treated will be:

$$\begin{aligned}
 N_e &= \frac{N_i}{(1 + K_b(T) t^*_{Fac})(1 + K_b(T) t^*_{Mat})^2} \\
 &= \frac{4 \times 10^7}{(1 + 6.2 \times 7)(1 + 6.2 \times 7)^2} \\
 &= 470 \text{ MPN/100ml} < 3 \times 10^3 \text{ MPN/100ml}
 \end{aligned}$$

Stabilization ponds are designed in the present plan as described above, however, it must be necessary that the execution of tests be carried out with the mini-plant at the treatment site prior to actual construction.

3. Trial calculation of BOD₅ removal

* Case 1: Using testing results in A.I.T. ponds.

Trial calculation of BOD₅ removal by facultative pond and maturation pond is made for the proposed stabilization ponds using a velocity of BOD₅ removal. This study is based on the current test results of water quality in the stabilization pond of Asian Institute of Technology (A.I.T.) Thailand.

Formula in the reference (Sewage Treatment in Hot Climates by Duncan Mara) could be applied to study a velocity of BOD₅ removal in A.I.T.'s ponds.

$$L_e = \frac{L_i}{1 + Kt}$$

where L_e : Effluent BOD₅ mg/l (g/m³)

L_i : Influent BOD₅ mg/l (g/m³)

K : BOD₅ removal efficiency (day⁻¹)

t : Detention time in the pond (day)

From Table 3.7.6 and Table 3.7.7 a velocity of BOD₅ removal can be expressed for facultative pond and maturation pond as follows.

for facultative pond (K_F) and for maturation pond (K_M)

$$K_F = \frac{L_i - L_e}{L_e t} = \frac{120 - 35}{35 \times 9} = 0.270 \text{ day}^{-1}$$

Using these results an effluent BOD₅ from the proposed stabilization ponds can be calculated.

for proposed Na Klua plant:

facultative pond

$$Le = \frac{198}{1 + 0.270 \times 8.2} = 62 \text{ mg BOD}_5/\ell$$

maturation pond (first)

$$Le = \frac{62}{1 + 0.061 \times 7} = 43 \text{ mg BOD}_5/\ell$$

maturation pond (second)

$$Le = \frac{43}{1 + 0.061 \times 7} = 30 \text{ mg BOD}_5/\ell$$

for proposed Pattaya plant:

facultative pond

$$Le = \frac{151}{1 + 0.270 \times 7} = 52 \text{ mg BOD}_5/\ell$$

maturation pond (first)

$$Le = \frac{52}{1 + 0.061 \times 7} = 36 \text{ mg BOD}_5/\ell$$

maturation pond (second)

$$Le = \frac{36}{1 + 0.061 \times 7} = 25 \text{ mg BOD}_5/\ell$$

As shown above BOD₅ at the last effluent will be not more than 30 mg/ℓ based on the current data is A.I.T. ponds. This figure could be acceptable. The result is not only economical but also technical.

* Case 2: Using same velocity of BOD₅ removal for facultative pond and maturation pond.

Velocity of BOD₅ removal in facultative pond: 0.383 day⁻¹

Velocity of BOD₅ removal in maturation pond : 0.383 day⁻¹

for proposed Na Klua plant:

maturation pond (first)

$$Le = \frac{48}{1 + 0.383 \times 7} = 13 \text{ mg BOD}_5/\ell$$

maturation pond (second)

$$Le = \frac{13}{1 + 0.383 \times 7} = 4 \text{ mg BOD}_5/\ell$$

for proposed Pattaya plant:

maturation pond (first)

$$Le = \frac{41}{1 + 0.383 \times 7} = 11 \text{ mg BOD}_5/\ell$$

maturation pond (second)

$$Le = \frac{11}{1 + 0.383 \times 7} = 3 \text{ mg BOD}_5/\ell$$

If maturation pond acts on BOD₅ removal with the same quality to facultative pond, BOD₅ of the last effluent of the proposed stabilization ponds will be less than 10 mg/ℓ.

4. Consideration to be taken on implementation.

Proposed system in this report based mainly on the references* shown at the end of the chapter.

Planning of the stabilization ponds, however, is depending on natural conditions of the site such as temperature, energy of sunshine, wind and so on. It is recommended to bear in mind some consideration prior to and during operation of plants as follows.

- An execution of tests to be carried out with the mini-scale test plant to recheck the design criteria as surface loading of 380kg/ha.day.
- Monitoring of the effluent quality at the first series of pond to be made and,
- Experience on the first installation to be taken in consideration for the second series of pond.

(4) Installation design in treatment plant

a. Na Klua treatment plant

(Quantity of sewage: 2,680 m³/day, unit)

	1981	1982	1983	1984	1985	1986	Final 1996
Daily mean sewage volume (m ³ /day)	5,850	6,540	7,250	7,800	7,970	8,150	13,360
No. of required units	3	3	3	3	3	3	5

b. Pattaya treatment plant

(Quantity of sewage: 2,360 m³/day, unit)

	1981	1982	1983	1984	1985	1986	Final 1996
Daily mean sewage volume (m ³ /day)	1,660	4,150	5,570	6,450	7,010	7,910	9,430
No. of required units	1	2	3	3	3	4	4

(5) Design of pumping facilities installed in treatment stations

a. Na Klua treatment plant

1. Lift pump (Submerged sewage pump)

Ø300 x 6.95m³/min x 15m x 37kw

	1981	1982	1983	1984	1985	1986	Final (1996)
Daily mean sewage volume (m ³ /day)	13,100	14,520	16,300	17,730	18,190	18,660	29,990
No. of required units	3	3	3	3	3	3	4

(one pump will be spare.)

2. Return pump (Submerged pump)

Ø125 x 1.55m³/min x 5.5kw x 2 pumps (one of them held in reserve)

Because the pump capacity is designed for the target year (1996) two pumps are installed even from the beginning. Amount of flow will be regulated by valves out.

b. Pattaya treatment station

Return pump (submersible pump)

Ø100 x 1.09m³/min x 3.7kw x 2 pumps (one of them is for spare)

Because the pump is designed to be installed in the target year (1996) two pumps are installed from the beginning. Amount of flow will be regulated by valves.

3.7.5 Design for Disposal of Effluent

(a) Discharge of Effluent

Possible discharge systems for effluent are the following three types, as described already in Section 3.7.1-(c), Treatment system:

1. Discharge into rivers
2. Discharge into fields and mountains for irrigation purpose.
3. Discharge into sea

In the case of alternative 1, if there is a river nearby with sufficiently large flow to accommodate the final effluent from the treatment plant, it is a very recommendable discharge system because the large purification by rivers can be expected to the final effluent, and also because this system is economical.

The flows of the Na Klua River and the Pattaya River in the project area, are almost negligible in the dry season. Therefore the purification effect of the rivers in the dry season cannot be entirely relied upon. Since the upper layer of soil in this planning area is sandy, and since the maximum

quantity of effluent at both treatment stations is about 13,000 m³/day, a considerable amount of the disposed water could be expected, in the dry season, to infiltrate into the earth before reaching the river-mouth. The environmental influence of pollution would be permissible.

Alternative 2, i.e., discharge water into the fields and mountains for irrigation and reusing it for cultivation is the superior system from the point of view of water use and also from the point of view of pollution control. But the influence to crops by nitrogen, phosphorus, etc., in the disposed water is not understood at present. It is proposed to introduce it only after further detailed investigation and examination using a model plant. As discharge sites, places close to a treatment plant would be better from the point of view of economy. Proposed irrigation sites for the Pattaya and Na Klua Treatment Stations are shown in Fig. 3.7.11.

The irrigation process would require a considerably vast land, and therefore it should be carried out jointly with other organized activities (cultivation of crops, etc.).

Alternative 3 discharge into sea, would have little influence on the seashore as already described. If the effluent has undergone secondary treatment, the influence to marine resources is smaller than primary treated water. But the cost of construction is the highest among the three proposals; if submerged discharge pipes are installed in Na Klua and Pattaya, roughly estimated construction cost reaches 58,000,000 Baht. Therefore Alternative 3 shall be recommended only if Alternatives 1 and 2 are impossible.

As a result of the above investigations, Alternative 1 was adopted as the discharge system for the planning area. The discharge facilities of Na Klua and Pattaya Treatment Plant and their influence to the sea at the river-mouths will be described below.

(b) Discharge Facilities

1) Na Klua Treatment Plant

Na Klua Treatment Plant is planned to be located along the Na Klua River, and the discharge site is the Na Klua River.


Daily maximum water amount	16,360 m ³ /day (in 1966)
Hourly maximum water amount	29,990 m ³ /day (1,250 m ³ /hour)

The discharge facilities design is based on maximum hourly water amount. Diameter of the effluent pipe is ϕ 700 and its length is about 70 m.

2) Pattaya Treatment Plant

The effluent of Pattaya Treatment Plant shall be discharged to the Pattaya River by storm water channels. In the vicinity of the treatment plant, a regulating reservoir is planned for the flood control. The area is presently used as a paddy field, and open channel should be constructed to guide the discharged water to a storm water drainage channel about 1,700 meters downstream.

Fig. 3.7.11 Proposed Irrigation Site




The planned effluent volumes are as follows.

Daily maximum water volume	14,280 m ³ /day (in 1996)
Hourly maximum water volume	26,180 m ³ /day (1,091 m ³ /hour)

The planning of the facilities shall be carried out based on the maximum hourly water volume.

Hourly maximum flow	Q = 0.303 m ³ /sec
The coefficient of roughness of the channel	n = 0.03

The cross section of the channel is planned as follows.



$$\begin{aligned}
 A &= (1.2 + 1.5) \times 0.5 \times 1/2 = 0.675 \text{ m}^2 \\
 S &= 1.2 + 0.522 \times 2 = 2.244 \text{ m} \\
 R &= \frac{A}{S} = \frac{0.675}{2.244} = 0.301 \\
 V &= \frac{0.303}{0.675} = 0.449 \text{ m} \\
 I^{1/2} &= \frac{V}{\frac{1}{n} R^{2/3}} = \frac{0.449}{\frac{1}{0.03} \times 0.301^{2/3}} = 0.02999 \\
 \therefore I &= 0.0009
 \end{aligned}$$

Accordingly a water channel of 1,670m long with 0.9% gradient will be installed.

(c) Influence to Sea Area at River-mouth

When treated water is discharged into rivers, it is considerably diluted by storm water in the rainy season. The range of influence on the sea area is calculated on the assumption that in the dry season the treated effluent from Na Klua and Pattaya Treatment Plants will be discharged unchanged (i.e., not mixed with or further purified by river water, which may be dried up in the dry season) into the sea at the river-mouths.

The computing formula is shown below:

1) Pattaya Area

Studies are carried out regarding the influence to the sea area when the effluent from the Pattaya Sewage Treatment Station is discharged to the sea.

In the pollution analyses in the sea area, the influence of pollution is calculated by using the formula for dilution and diffusion of Joseph-Sendner.

$$S = (S_0 - S_1) \left\{ 1 - \exp\left[-\frac{Q}{\pi d p} \left(\frac{1}{Y} - \frac{1}{Y_1}\right)\right] \right\} + S_1$$

where S: water quality at the point of γ (ppm)
 S_0 : wastewater quality (ppm)
 S_1 : seawater quality (ppm)
 d : mixed depth in wastewater region (m)
 p : dispersing rate (1 to 1.5 cm/sec in the ocean)
 Q : wastewater quantity (m^3/day)
 Y : distance from the original point (m)
 Y_1 : radius of range of influence (m)

Calculation will be made by using the empirical formula of Mr. Nitta for determining the area influenced by wastewater.

$$\log\left(\frac{Y_1^2 \pi}{2}\right) = 1.23 \log Q + 0.086$$

Q : wastewater quantity (m^3/day)

The disposed water volume in 1986 $Q = 12,220 m^3/day$

The disposed water volume in 1996 $Q = 14,280 m^3/day$

When we consider the above two cases, namely,

The case of $Q = 12,220 m^3/day$ (1986)

$$\log\left(\frac{Y_1^2 \pi}{2}\right) = 1.23 \log 12,220 + 0.086 \quad \log\left(\frac{Y_1^2 \pi}{2}\right) = 5.1131$$

$$\left(\frac{Y_1^2 \pi}{2}\right) = 1.297 \times 10^5$$

$$Y_1 \doteq 290 \text{ m}$$

The case of $Q = 14,280 m^3/day$ (1996)

$$\log\left(\frac{Y_1^2 \pi}{2}\right) = 1.23 \log 14,280 + 0.086$$

$$\log\left(\frac{Y_1^2 \pi}{2}\right) = 5.1963$$

$$\left(\frac{Y_1^2 \pi}{2}\right) = 1.571 \times 10^5$$

$$Y_1 \doteq 320 \text{ m}$$

In either case, the range influenced by discharged effluent is extremely small with radius $Y_1 \doteq 290m$ in the case of $Q=12,220 m^3/day$ (1986), and radius $Y_1=320m$ in the case of $Q=14,280 m^3/day$ (1996).

Calculation will be made on the dispersal conditions of effluent wastewater on the assumption that the BOD_5 value of open sea water is 2 ppm and the BOD_5 value of the effluent wastewater from the treatment plant is 30 ppm, and also on the assumption that the mixed depth is $d = 1m$ and the dispersion speed in the ocean is $p = 1.5 \text{ cm/sec}$.

$$S = (S_0 - S_1) \left\{ 1 - \exp\left[-\frac{Q}{\pi d p} \left(\frac{1}{Y} - \frac{1}{Y_1}\right)\right] \right\} + S_1$$

(1) In the case of $Q = 12,220 \text{ m}^3/\text{d}$ (1986)

$$S_0 = 30 \text{ ppm}, S_1 = 2 \text{ ppm}, Q = 12,220 \text{ m}^3/\text{d}$$

$$d = 1 \text{ m}, P = 1 \text{ cm/sec} = 864 \text{ m/d}, \gamma_1 = 290 \text{ m}$$

• $\gamma = 10 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{12,220}{\pi \times 1 \times 864} \left(\frac{1}{10} - \frac{1}{290}\right)\right\}\right] + 2$$

$$S \doteq 11.9 \text{ ppm}$$

• $\gamma = 20 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{12,220}{\pi \times 1 \times 864} \left(\frac{1}{20} - \frac{1}{290}\right)\right\}\right] + 2$$

$$S \doteq 7.3 \text{ ppm}$$

• $\gamma = 50 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{12,220}{\pi \times 1 \times 864} \left(\frac{1}{50} - \frac{1}{290}\right)\right\}\right] + 2$$

$$S \doteq 4.0 \text{ ppm}$$

• $\gamma = 100 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{12,220}{\pi \times 1 \times 864} \left(\frac{1}{100} - \frac{1}{290}\right)\right\}\right] + 2$$

$$S \doteq 2.8 \text{ ppm}$$

• $\gamma = 150 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{12,220}{\pi \times 1 \times 864} \left(\frac{1}{150} - \frac{1}{290}\right)\right\}\right] + 2$$

$$S \doteq 2.4 \text{ ppm}$$

• $\gamma = 200 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{12,220}{\pi \times 1 \times 864} \left(\frac{1}{200} - \frac{1}{290}\right)\right\}\right] + 2$$

$$S \doteq 2.2 \text{ ppm}$$

<u>Distance from Discharging Outlet</u> (m)	<u>Planned Values</u> (ppm)
10	11.9
20	7.3
50	4.0
100	2.8
150	2.4
200	2.2
290	2.0

(2) In the case of $Q = 14,280\text{m}^3/\text{d}$ (1996)

$$S_0 = 30\text{ppm}, S_1 = 2\text{ppm}, Q = 14,280\text{m}^3/\text{d},$$

$$d = 2\text{m}, P = 1\text{cm}/\text{sec} = 864\text{m}/\text{d}, \gamma_1 = 320\text{m}$$

◦ $\gamma=10\text{m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{14,280}{\pi \times 1 \times 864} \left(\frac{1}{10} - \frac{1}{320}\right)\right\} \right] + 2 \quad S \doteq 13.2\text{ppm}$$

◦ $\gamma=20\text{m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{14,280}{\pi \times 1 \times 864} \left(\frac{1}{20} - \frac{1}{320}\right)\right\} \right] + 2 \quad S \doteq 8.1\text{ppm}$$

◦ $\gamma=50\text{m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{14,280}{\pi \times 1 \times 864} \left(\frac{1}{50} - \frac{1}{320}\right)\right\} \right] + 2 \quad S \doteq 4.4\text{ppm}$$

◦ $\gamma=100$

$$S = (30-2) \left[1 - \exp\left\{-\frac{14,280}{\pi \times 1 \times 864} \left(\frac{1}{100} - \frac{1}{320}\right)\right\} \right] + 2 \quad S \doteq 3.0\text{ppm}$$

◦ $\gamma=150\text{m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{14,280}{\pi \times 1 \times 864} \left(\frac{1}{150} - \frac{1}{320}\right)\right\} \right] + 2 \quad S \doteq 2.5\text{ppm}$$

◦ $\gamma=200\text{m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{14,280}{\pi \times 1 \times 864} \left(\frac{1}{200} - \frac{1}{320}\right)\right\} \right] + 2 \quad S \doteq 2.3\text{ppm}$$

◦ $\gamma=250\text{m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{14,280}{\pi \times 1 \times 864} \left(\frac{1}{250} - \frac{1}{320}\right)\right\} \right] + 2 \quad S \doteq 2.1\text{ppm}$$

Distance from Discharging Outlet (m)	Planned Values (ppm)
10	13.2
20	8.1
50	4.4
100	3.0
150	2.5
200	2.3
250	2.1
290	2.0

Fig. 3.7.12 Diffusive Condition of Wastewater in Pattaya Sea Area (1)
(In Case of $Q=12,220 \text{ m}^3/\text{day}$ [1986])




Fig. 3.7.13 Diffusive Condition of Wastewater in Pattaya Sea Area (2)
(In Case of $Q=14,250 \text{ m}^3/\text{day}$ [1996])




Fig. 3.7.14 Diffusive Condition Drawing of Wastewater in Pattaya Sea Area
(In Case of $Q = 12,220 \text{ m}^3/\text{day}$ (1956))





Fig. 3.7.15 Diffusive Condition Drawing of Wastewater in Pattaya Sea Area
(In Case of $Q = 14,250 \text{ m}^3/\text{day}$ (1956))



2) Na Klua Area

Calculation was carried out in the same way as Pattaya system on the influence to the sea area when the treated water from Na Klua Sewage Treatment Plant is discharged to the sea.

The influence of pollution in the sea area is calculated by using the Joseph-Sendner's formula.

$$S = (S_0 - S_1) \left[1 - \exp\left\{-\frac{Q}{\pi d P} \left(\frac{1}{Y} - \frac{1}{Y_1}\right)\right\}\right] + S_1$$

Calculation will be made by using the empirical formula of Mr. Nitta for determining the area influenced by wastewater.

$$\log\left(\frac{Y_1^2}{2} \pi\right) = 1.23 \log Q + 0.086$$

$$\text{The disposed water volume in 1986} \quad Q = 10,180 \text{ m}^3/\text{day}$$

$$\text{The disposed water volume in 1996} \quad Q = 16,360 \text{ m}^3/\text{day}$$

The above two cases are studied, namely,

The case of $Q = 10,180 \text{ m}^3/\text{day}$ (1986)

$$\log\left(\frac{Y_1^2}{2} \pi\right) = 1.23 \log 10,180 + 0.086$$

$$\log\left(\frac{Y_1^2}{2} \pi\right) = 5.0155$$

$$\left(\frac{Y_1^2}{2} \pi\right) = 1.036 \times 10^5$$

$$Y_1 \doteq 260 \text{ m}$$

The case of $Q = 16,360 \text{ m}^3/\text{day}$ (1996)

$$\log\left(\frac{Y_1^2}{2} \pi\right) = 1.23 \log 16,360 + 0.086$$

$$\log\left(\frac{Y_1^2}{2} \pi\right) = 5.2690$$

$$\left(\frac{Y_1^2}{2} \pi\right) = 1.857 \times 10^5$$

$$Y_1 = 340 \text{ m}$$

In either case, the range influenced by discharged effluent is extremely small with radius $Y_1=260\text{m}$ in the case of $Q=10,180 \text{ m}^3/\text{day}$ (1986), and radius $Y_1=340\text{m}$ in the case of $Q=16,360 \text{ m}^3/\text{day}$ (1996).

Calculation will be made on the dispersal conditions of effluent wastewater on the assumption that the BOD₅ value of open sea water is 2 ppm and the BOD₅ value of the effluent wastewater from the treatment plant is 30 ppm

$$S = (S_0 - S_1) \left[1 - \exp\left\{-\frac{Q}{\pi d P} \left(\frac{1}{Y} - \frac{1}{Y_1}\right)\right\}\right] + 2$$

like in the case of Pattaya area.

(1) In the case of $Q = 10,180 \text{ m}^3/\text{d}$ (1986)

$$S_0 = 30 \text{ ppm}, S_1 = 2 \text{ ppm}, Q = 10,180 \text{ m}^3/\text{d}$$

$$d = 1 \text{ m}, P = 1 \text{ cm/sec} = 864 \text{ m/d}, Y_1 = 260 \text{ m}$$

◦ $Y=10 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{10,180}{\pi \times 1 \times 864} \left(\frac{1}{10} - \frac{1}{260}\right)\right\} \right] + 2$$

$$S \doteq 10.5 \text{ ppm}$$

◦ $Y=20 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{10,180}{\pi \times 1 \times 864} \left(\frac{1}{20} - \frac{1}{260}\right)\right\} \right] + 2$$

$$S \doteq 6.5 \text{ ppm}$$

◦ $Y=50 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{10,180}{\pi \times 1 \times 864} \left(\frac{1}{50} - \frac{1}{260}\right)\right\} \right] + 2$$

$$S \doteq 3.6 \text{ ppm}$$

◦ $Y=100 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{10,180}{\pi \times 1 \times 864} \left(\frac{1}{100} - \frac{1}{260}\right)\right\} \right] + 2$$

$$S \doteq 2.6 \text{ ppm}$$

◦ $Y=150 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{10,180}{\pi \times 1 \times 864} \left(\frac{1}{150} - \frac{1}{260}\right)\right\} \right] + 2$$

$$S \doteq 2.3 \text{ ppm}$$

◦ $Y=200 \text{ m}$ spot

$$S = (30-2) \left[1 - \exp\left\{-\frac{10,180}{\pi \times 1 \times 864} \left(\frac{1}{200} - \frac{1}{260}\right)\right\} \right] + 2$$

$$S \doteq 2.1 \text{ ppm}$$

<u>Distance from Discharging Outlet</u> (m)	<u>Planned Value</u> (ppm)
10	10.5
20	6.5
50	3.6
100	2.6
150	2.3
200	2.1
260	2.0

(2) In the case of $Q = 16,360\text{m}^3/\text{d}$ (1996)

$$S_0 = 30\text{ppm}, S_1 = 2\text{ppm}, Q = 16,360\text{m}^3/\text{d},$$

$$d = 1\text{m}, P = 1\text{cm}/\text{sec} = 864\text{m}/\text{d}, \gamma_1 = 340\text{m}$$

◦ $\gamma = 10\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{10} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 14.4\text{ppm}$$

◦ $\gamma = 20\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{20} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 8.9\text{ppm}$$

◦ $\gamma = 50\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{50} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 4.7\text{ppm}$$

◦ $\gamma = 100\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{100} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 3.2\text{ppm}$$

◦ $\gamma = 150\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{150} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 2.6\text{ppm}$$

◦ $\gamma = 200\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{200} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 2.3\text{ppm}$$

◦ $\gamma = 250\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{250} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 2.2\text{ppm}$$

◦ $\gamma = 300\text{m}$ spot

$$S = (30-2) \left[1 - \exp \left\{ - \frac{16,360}{\pi \times 1 \times 864} \left(\frac{1}{300} - \frac{1}{340} \right) \right\} \right] + 2 \quad S \doteq 2.1\text{ppm}$$

<u>Distance from Discharging Outlet (m)</u>	<u>Planned Values (ppm)</u>
10	14.4
20	8.9
50	4.7
100	3.2
150	2.6
200	2.3
250	2.2
300	2.1
340	2.0

Fig. 3.7.16 Diffusive Condition of Wastewater in Na Klua Sea Area (1)
(In Case of $Q=10,160 \text{ m}^3/\text{day}$ [1986])




Fig. 3.7.17 Diffusive Condition of Wastewater in Na Klua Sea Area (2)
(In Case of $Q=16,360 \text{ m}^3/\text{day}$ [1996])




Fig. 3.7.18 Diffusive Condition Drawing of Wastewater in Na Kha Sea Area
(In Case of $Q=10,150 \text{ m}^3/\text{day}$ [1986])





Fig. 3.7.19 Diffusive Condition Drawing of Wastewater in Na Kha Sea Area
(In Case of $Q = 16,369 \text{ m}^3/\text{day}$ [1996])



3.7.6 Sewage Treatment Plan for Ko Lan Island

(a) Basic plan

Ko Lan Island is an island covering an area of about 522 ha, approximately 8 km offshore to the west of Pattaya Beach, it consists mostly of rock formations. The project area for sewage treatment includes the fishing settlement of Ko Lan Village and tourism areas such as Ko Lan Vacation Beach, Ta Van Beach, Tien Beach and Sa Mae Beach, as shown in Fig. 3.7.20. As Ko Lan Vacation Beach is developed by a private enterprise, it is excluded from this plan, and the remaining beaches and the village are included in it.

On Ko Lan Island, mountains range from north to south in the center, and the beaches are separated, so it would be very uneconomical to carry out centralized sewage treatment by collecting all wastewater in one place. The period of use of the respective beaches except the fishing village is limited due to the adverse effects caused by the wind and waves; the period of use of Ta Van Beach and Tien Beach is from March to September, and that of Sa Mae Beach is from October to February. For the above reasons, it is determined that the treatment of sewage on Ko Lan Island will use septic tanks and sewage will be treated individually in respective beaches.

(b) Sewage Treatment Plant

1) Tourism facilities

The number of tourists to Ko Lan Island is planned as stated below in the master plan.

The number of visitors to the whole area of Ko Lan Island is estimated as follows.

	1981	1986	1996
No. of visitors/day	1,600	2,000	2,900

These visitors are distributed among four beaches. On Ko Lan Island, the serviceable beaches vary with the seasons because of the adverse effect on them from wind and waves; the rainy season is from March to September, and the dry season from October to February. Estimates of number of visitors is as follows.

From March to September

	1981	1986	1996
Ta Van Beach	900	1,120	1,630
Tien Beach	380	480	690
Ko Lan Vacation Beach	320	400	570
Total	1,600	2,000	2,900

From October to February

	1981	1986	1996
Sa Mae Beach	1,260	1,570	2,280
Ko Lan Vacation Beach	340	430	620
Total	1,600	2,000	2,900

Service facilities are planned between Sa Mae Beach and Tien Beach, and at Ta Van Beach. According to the master plan, the number of toilets in the service facilities is three per 100 visitors. The estimated number of visitors to use the toilets at the beach resorts is expected to be approximately 1/4 of the number of visitors.*


As a result, on Ta Van Beach, a septic tank for 300 persons will be installed, and on Sa Mae Beach, one for 400 persons will be installed.

2) Ko Lan Village

In 1986, the total population of Ko Lan Island is planned to be 2,820 persons. Of them, 300 persons are estimated to be residents in Ko Lan Vacation Beach; however, it is considered that 2,820 persons in terms of family members reside in Ko Lan Village. Accordingly, assuming that one family consists of six members, 470 families are to reside in the village; on this basis, it is determined that a septic tank designed for 7 persons will be installed in each house.

* Japan Architectural Center, 1976 ed.

Fig. 3.7.20 Areas on Ko Lan Island to be Served by Sewage Treatment Facilities



3.8 Estimated Work Costs

3.8.1 Construction costs

The construction costs with some detail for the respective years are shown in Tables 3.8.1 and 3.8.2.

3.8.2 Maintenance and Operation Costs

The maintenance and operation costs are shown in Table 3.8.2.

Table 3.8.1 Construction Cost for Sewerage - (1)

Unit: thousand Baht

Year	1960			1961			1962			1963			1964			1965		
	Cost without	Cost with	Total	Cost without	Cost with	Total	Cost without	Cost with	Total	Cost without	Cost with	Total	Cost without	Cost with	Total	Cost without	Cost with	Total
Sewerage Pipeline	Local	24944.2	1977.5	26921.7	1482	1876.5	3359.2	187	1184.2	473	511	64	3664	172	3776	206		
	Foreign	8452.6	8452.6	7040	2462.7	2462.7	112.4	112.4	212	212	212	746	746	746	746	746	746	746
	Total	33396.8	28224.1	33964.3	3944.9	4939.2	4501.9	299.1	1306.6	685	723	358	1390	1472	4522	1512	1492	1492
Treatment Plant	Local	17708	2387	15321	1551	1576.7	31.2	944.4	1114.2	0	0	0	0	0	0	0	0	0
	Foreign	8936.4	8936.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4
	Total	26644.4	13263.8	20385.4	10445.8	10711.1	8068.6	10388.8	10388.8	10388.8	10388.8	10388.8	10388.8	10388.8	10388.8	10388.8	10388.8	10388.8
Land and Pumping Station	Local	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376	9376
	Foreign	8936.4	8936.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4
	Total	18312.4	18312.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4	14310.4
Total (1)	Local	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6	43662.6
	Foreign	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0	17389.0
	Total	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6	61051.6
Sewerage Pipeline	Local	18347.2	277.5	18624.7	181	1880.6	36.6	1637.4	1374.4	110	1274.4	73.4	1035.4	110	1208.8	73.4	1035.4	110
	Foreign	2395.7	2395.7	2095.7	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4	1373.4
	Total	21342.9	2613.2	20720.4	3184.4	3254.0	2749.8	3010.8	2749.8	2749.8	2749.8	2749.8	2749.8	2749.8	2749.8	2749.8	2749.8	2749.8
Treatment Plant	Local	9471	826	10297	739	10026	372	1137	1137	70	244	244	443	443	443	443	443	
	Foreign	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672	2672
	Total	12143	1098	13269	1011	12748	644	1404.4	1404.4	1404.4	1404.4	1404.4	1404.4	1404.4	1404.4	1404.4	1404.4	
Land and Pumping Station	Local	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543	3543
	Foreign	8936.4	8936.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4
	Total	12479.4	12479.4	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8	8477.8
Sub Total (Final)	Local	77541.2	1601.9	79143.1	15530.4	73	2480.4	1074.3	1364.5	140	1740.5	140	412.7	412.7	412.7	412.7	412.7	
	Foreign	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7	5246.7
	Total	82787.9	11268.6	84389.8	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	15777.1	
Average Pipeline	Local	27812.1	1054.9	28867.0	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	14740.8	
	Foreign	8936.4	8936.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	4934.4	
	Total	36748.5	19413.8	33801.4	19675.2	19675.2	19675.2	19675.2	19675.2	19675.2	19675.2	19675.2	19675.2	19675.2	19675.2	19675.2		
Treatment Plant	Local	7748	675	8423	603	9028	257	257	257	57	314	314	314	314	314	314	314	
	Foreign	2149	2149	2149	2149	2149	2149	2149	2149	2149	2149	2149	2149	2149	2149	2149	2149	
	Total	9897	8894	10572	818	11227	571	571	571	571	571	571	571	571	571	571		

Construction Cost of Sewerage - (2)

Unit: thousand Baht

Month	1960			1961			1962			1963			1964			1965		
	Cost without VAT	Cost with VAT	Total	Cost without VAT	Cost with VAT	Total	Cost without VAT	Cost with VAT	Total	Cost without VAT	Cost with VAT	Total	Cost without VAT	Cost with VAT	Total	Cost without VAT	Cost with VAT	Total
Jan	5018	5018																
Feb	5018	5018																
Mar	5018	5018																
Apr	5018	5018																
May	5018	5018																
Jun	5018	5018																
Jul	5018	5018																
Aug	5018	5018																
Sep	5018	5018																
Oct	5018	5018																
Nov	5018	5018																
Dec	5018	5018																
Total	60216	60216																
Jan	60216	60216																
Feb	60216	60216																
Mar	60216	60216																
Apr	60216	60216																
May	60216	60216																
Jun	60216	60216																
Jul	60216	60216																
Aug	60216	60216																
Sep	60216	60216																
Oct	60216	60216																
Nov	60216	60216																
Dec	60216	60216																
Total	722592	722592																
Jan	722592	722592																
Feb	722592	722592																
Mar	722592	722592																
Apr	722592	722592																
May	722592	722592																
Jun	722592	722592																
Jul	722592	722592																
Aug	722592	722592																
Sep	722592	722592																
Oct	722592	722592																
Nov	722592	722592																
Dec	722592	722592																
Total	8671104	8671104																

Table 3.8.2. Operation & Maintenance

		Y/year					
		1981	1982	1983	1984	1985	1986
NA KUSA	Treatment station, electricity fee	216,692	216,692	216,692	216,692	216,692	216,692
	Relay pump No.1	47,532	47,532	47,532	47,532	47,532	47,532
	No.2	-	-	-	-	-	-
	No.3	82,716	82,716	82,716	103,224	103,224	103,224
	chlorine treatment	28,612	32,036	35,460	38,150	38,883	39,862
Personnel expense	382,800	382,800	382,800	382,800	382,800	382,800	
Maintenance costs	67,364	67,364	67,364	75,978	75,978	75,978	
Total		825,716	829,140	832,564	864,376	865,109	866,088
PATAYA	Treatment station, electricity fee	41,100	41,100	41,100	41,100	41,100	41,100
	Relay pump No.1	-	-	-	-	-	-
	No.2	-	-	-	-	-	-
	No.3	69,252	89,916	89,916	99,916	89,916	89,916
	No.4	10,194	10,194	10,194	10,194	10,194	10,194
	No.5	35,286	35,286	35,286	35,286	35,286	35,286
	No.6	78,144	147,820	217,497	217,497	217,497	217,497
chlorine treatment	8,070	20,298	27,145	31,547	34,237	38,639	
Personnel expense	382,800	382,800	382,800	382,800	382,800	382,800	
Maintenance costs	49,537	67,167	77,022	77,022	77,022	77,022	
Total		674,383	794,581	880,960	885,362	888,052	892,454
Grand total		1,500,099	1,623,721	1,713,524	1,749,738	1,753,161	1,758,542

3.9 Execution Plan

3.9.1 Construction Plan

The construction work shall be commenced in the respective years preceding the start of service so that the work will be completed by the start of service. The pump, pond, etc. shall be added so as to correspond to the water volumes of the respective years. The construction plans of facilities in relation to other construction work (road, etc.) in the respective years are shown in Table 3.9.1.

3.9.2 Correlation with Other Construction Work

Relation to the road work:

In the case of the works of sewage, since they are laid under the roads, the work will be advanced taking the years of the road construction plan into account; the roads will be constructed after the sewers are laid under the ground.

Regarding the sewers under the beach road of Pattaya, since laying of sewers in the downtown area is performed before execution of the road plan, the work of the project road will start after restoration of the pavement of the existing beach road.



Beach Road of Downtown Pattaya

Table 3.9.1 Execution Plans (1)

PATTAYA Area	1980	1981	1982	1983	1984	1985	1986	Remarks
Treatment Station	Pond (system)	Increase of system-equipments	Increase of system-equipments			Increase of system-equipments		
	Structures							
	Motor							
	Trial operation	Trial operation	Trial operation	Trial operation		Trial operation		
No.2 Relay-pumping Station	Construction of 2 tanks	Construction of 1 tank						
No.3 Relay-pumping Station	Construction of 2 tanks							
No.4 Relay-pumping Station	Construction of 2 tanks							
No.5 Relay-pumping Station	Construction of 2 tanks	Construction of 1 tank	Construction of 1 tank	Construction of 1 tank				
Laying of Sewer Pipe								

Table 3-9.2 Execution Plans (2)

Na Klua Area	1980	1981	1982	1983	1984	1985	1986	Remarks
Treatment Station	Pond (system) Structures Motor Trial operation							
	No.3 Relay-pumping Station	Construction of 2 tanks Construction of 2 tanks	Construction of 2 tanks Construction of 2 tanks	Construction of 2 tanks Construction of 1 tank				
Laying of Sewer Pipe								

Table 3.9.3 Execution Plans (3)

Ko Lan Islands	1980	1981	1982	1983	1984	1985	1986	Remarks
Ta Van Beach		Establishment of 3 purification tanks						
Samae & Tien Beach		Establishment of 4 purification tanks						
Ko Lan Village		Establishment of purification tank						


REFERENCE

- Coastal Water Pollution Survey of Chonburi Province, AIT
- Report on Environmental Survey of Pattaya
Environmental Standard Quality Division, The National Environment Board. July, 1977
- Design Guidelines for Treatment of Wastewaters from Tapioca Starch Industry
Dr. Pakit Kiravanich, Mr. Yothin Augurawasaqoon, Mr. Adisak Thongkai-mook
Environmental Quality Standard Division, Aug., 1976
- Lectures on Sewerage 1. Corporation of Sewerage Plan
Kashima Shupan-kai
- Design Criterion for Sewage Works Facilities
Japan Sewage Works Association, 1972
- Master Plan Sewerage, Drainage and Flood Protection Systems 1968
CAMP, DRESSER & McKEE
- Air-conditioning & Sanitary Facilities: Practice and Data for Practical Use of Designing by Kazumaro Yokota and Tokuo Akino
- Manual of Air Conditioning and Sanitary Engineering
- Round Number Values of Air Designing, and Architectural Facilities
Notebook
- Method of Public Sewerage Plan
Civil Engineering Dept. of Aichi Prefectural Government, 1971
- Design Criterion for Water Works Facilities
Japan Water Works Association, 1977
- Structural Standard and Instructions of Septic Tank
Japan Architectural Center, 1976
- Data of Tapioca Factory
- Alternative Waste Management Techniques for Best Practicable Waste Treatment
EPA
- Improvement of Environmental Sanitation by Use of Living Things -
by Manabu Sano
Gakujitsu Geppo (Science Monthly Report) Vol. 23, No. 10.
- Waste Stabilization Pond - by Gloyna E.F.
W.R.O., Geneva, 1971
- Sewage Treatment in Hot Climates - by Duncan Mara


- Environmental Guideline for Coastal Zone Management in Thailand
Zone of Pattaya
Environmental Impact Evaluation Division, National Environment Board
H.F. Ludwig, Dr. Eng., Nov., 1975
- Stabilization Pond Design Criteria for Tropical Asia
M.G. McCarry, M.B. Pescod, Environmental Engineering Division, AIT.
- Sewage Treatment Plant Design - WPCF Manual of Practice No. 8
- Pre-Conference Short Course
International Conference on Water Pollution Control in Developing
Countries, Feb. 1978
Environmental Engineering Division, AIT
- Pollution Control in the Tapioca Starch Industry in Thailand
Dr. Pakit Kiravanich, Mr. Yothin Unkulvasapaul
National Environment Board, 1977
- Data of the Tapioca Factories in Bang Lamung
Ministry of Industry Department of Industry Works Factory Control
Division
- Feasibility Report on Water Supply for Pattaya - Bang Lamung Aug.,
1976 Water Resources Planning Subcommittee, National Economic and
Social Development Board


CHAPTER 4

STORM WATER DRAINAGE SYSTEM




1. GENERAL
2. FIELD INVESTIGATIONS
3. PRESENT CONDITION AND PROBLEMS OF STORM WATER DRAINAGE FACILITIES
4. EFFECT OF STORM WATER DRAINAGE SYSTEM
5. BASIC PLAN AND POLICIES
6. STUDY OF THE STORM WATER DRAINAGE SYSTEM
7. COST ESTIMATION
8. EMERGENCY ACTION TO THE FLOOD AREA NEAR WAT CHAIMONKON









C O N T E N T S

CHAPTER 4 STORM WATER DRAINAGE SYSTEM


4.1	General	4-1
4.1.1	Basic Policy for the System	4-1
4.1.2	Proposed Drainage System	4-1
4.1.3	Construction Cost for the System	4-2
4.2	Field Investigations	4-3
4.2.1	Soil Investigation	4-3
4.2.2	Topographic Survey	4-5
4.2.3	Other Collected Data	4-5
4.3	Present Condition and Problems of Storm Water Drainage Facilities	4-6
4.3.1	Present Conditions	4-6
4.3.2	Problems	4-11
4.4	Effect of Storm Water Drainage System	4-12
4.5	Basic Plan and Policies	4-12
4.5.1	Proposed Drainage Area	4-12
4.5.2	Fundamental Policy	4-12
4.6	Study of the Storm Water Drainage System	4-15
4.6.1	Design Criteria and Procedure	4-15
4.6.2	Proposed Drainage Area	4-22
4.6.3	Alternative Plans for the System	4-24
4.6.4	Outline of the Drainage Facilities	4-26
4.6.5	Selection of the Optimum System	4-30
4.7	Cost Estimation	4-34
4.7.1	Construction and Land Costs	4-34
4.7.2	Maintenance and Operation	4-38
4.8	Emergency Action to the Flood Area near Wat Chaimonkon	4-39
4.8.1	Present Condition	4-39
4.8.2	Causes of Flood	4-39
4.8.3	Emergency Drainage Plan	4-39

Tables

<u>No.</u>	<u>Name</u>	<u>Page</u>
4.1.1	Phase I Construction cost for Storm Water Drainage System	4-2
4.6.1	Rainfall Intensity in Chonburi Province	4-16
4.6.2	Runoff Coefficient	4-16
4.6.3	Calculation Example of Inflow Volume	4-21
4.6.4	Total Construction Costs of Alternative Plans	4-30
4.6.5	Area of Storm Water Regulating Pond and Specification of Spillway	4-32
4.7.1	Phase I Construction and Land Costs for Storm Water Drainage System (Central Pattaya Area)	4-35
4.7.2	Phase I Construction and Land Costs for Storm Water Drainage System (Southern Na Klua Area)	4-35
4.7.3	Quantity of Work (Phase I up to 1986)	4-36
4.7.4	Unit Cost by Work	4-36
4.7.5	Maintenance and Operation Costs for Storm Water Drainage System	4-38


Figures

<u>No.</u>	<u>Name</u>	<u>Page</u>
4.2.1	Location Map of Soil Investigation and Topographic Survey	4-4
4.3.1	Present Hydrographic Map	4-7
4.5.1	Flow Chart of Feasibility Study for Storm Water Drainage System	4-14
4.6.1	Rainfall Intensity-duration Curve in Chonburi Province	4-15
4.6.2	Calculation of the Time of Concentration	4-17
4.6.3	Calculation Procedure of Ponding	4-19
4.6.4	Example of H-V Curve	4-20
4.6.5	Calculation Example of Inflow Volume	4-20
4.6.6	Calculation Example of Planned Ponding Volume and Discharge Rate	4-21
4.6.7	Proposed Drainage Area	4-22
4.6.8	Catchment Area and Mean Runoff Coefficient by Drainage Blocks	4-23
4.6.9	Alternative Plan 1	4-24
4.6.10	Alternative Plan 2	4-25
4.6.11	Drainage System in the Southern Na Klua Area	4-26
4.6.12	Outline of Drainage Facilities (Central Pattaya Area, Alternative Plan 1)	4-27
4.6.13	Outline of Drainage Facilities (Central Pattaya Area, Alternative Plan 2)	4-28
4.6.14	Outline of Drainage Facilities (Southern Na Klua Area)	4-29
4.6.15	Proposed Drainage Network	4-33
4.7.1	Flow Chart of Cost Estimation	4-34
4.7.2	Unit Cost of Land by Area	4-37
4.7.3	Organization for Maintenance and Operation of the Storm Water Drainage System	4-38
4.8.1	Flood Area near Wat Chaimonkon and Emergency Drainage Plan	4-42



LEGEND

FACILITY	PHASE I	PHASE II
OPEN CHANNEL	—	- - - - -
BOX CULVERT	■	□
SPILLWAY	■	□
PONDING AREA	●	⊘
EXISTING DRAINAGE FACILITIES	○	○



GENERAL PLAN OF STORM WATER DRAINAGE SYSTEM



LEGEND

FACILITY	PHASE I	PHASE II
CHANNEL	—	- - - - -
CULVERT	■	■
WAY	■	■
EXISTING AREA	●	◐
EXISTING DRAINAGE FACILITIES	○	○

GENERAL PLAN OF STORM WATER DRAINAGE SYSTEM

4.1 General

4.1.1 Basic Policy for the System

A proper storm water drainage system can be considered to be an indispensable part of the infrastructure from the point of view of preventing damage to private and public properties by floods and to promote an effective land use.

In the drainage system proposed in the master plan, farmland drainage, that is, drainage in rice field and swamp areas, and city drainage, that is, drainage in the development areas, were considered to be of the same level without taking the ponding effect into account. As a result, the scale of the system need to be considerably large, accounting for approximately 7% of the total construction cost of the Phase I Infrastructure Project up to 1986.

However, through the field investigation conducted at the site, it was revealed that the rice field and swamp areas in the southern part of the Pattaya Area topographically play the role of a natural storm water regulating pond, preventing a large amount of runoff toward the downstream area.

In this feasibility study, therefore, the storm water regulating effect (ponding effect) in the rice field and swamp areas was taken into consideration to ensure reduction of the peak discharge of runoff into the development area, and an economical and functional drainage system was proposed.

The proposed drainage area in this feasibility study was limited to the following areas in view of the field investigation results, such as the present condition of drainage facilities and damage by floods in the past, etc.

- Areas which require new drainage facilities under the proposed development and land use programs.
- Areas in which the existing drainage facilities need to be improved under the proposed development and land use programs.
- Areas which suffered from floods in the past.

The Central Pattaya Area and Southern Na Klua Area fall into the above-mentioned areas. (Refer to General Plan)

4.1.2 Proposed Drainage System

(a) Central Pattaya Area

Concerning the storm water drainage system in the Central Pattaya Area, the following 2 plans were studied.

1) Alternative Plan 1: Integrated Drainage Plan

This plan is to lead the storm water in the Central Pattaya Area collectively into the Pattaya River.

The storm water in each drainage block is ponded on its way to the regulating pond behind the Arterial Tourism Road (hereinafter referred to as Back Road) and in the rice field areas on the southern part of the

area and is then discharged into the sea through the spillways, box culverts and open channels.

2) Alternative Plan 2: Diversion Drainage Plan (Short-Cut Plan)

This plan is to drain the storm water in the Central Pattaya Area by diverting it with the Main Residential Road.

The storm water fallen on the south side of the road is drained in the same way as in the case of Alternative Plan 1, while the storm water fallen on the north side of the road is discharged into the sea through the open channels and box culverts (one of which is approximately 500 meters long between the Back and Beach Promenade Roads).

In this feasibility study, Alternative Plan 1 was adopted as the storm water drainage system for the Central Pattaya Area for the following reasons:

- In the Alternative Plan 2, the storm water fallen on the north side of the Main Residential Road is directly discharged into the sea without ponding, therefore the influence on the sea from this turbid water can not be neglected.
Furthermore, the direct discharge will give nuisance to the tourists and sea-bathers because the discharge point is located in the sea-bathing area.
- The maintenance of a box culvert, approximately 500 meters long between the Back Road and Beach Promenade Road (hereinafter referred to as Beach Road), requires considerable manpower and time.

(b) Southern Na Klua Area

On the other hand, in the Southern Na Klua Area a storm water drainage system consisting of newly installed drainage channels in Na Klua New Town A, box culverts and existing drainage channels from the Main Residential Road to the coast was adopted.

4.1.3 Construction Cost for the System

The Phase 1 construction costs up to 1986 for the Central Pattaya and Southern Na Klua Areas are as shown below.

Table 4.1.1 Phase 1 Construction Cost for Storm Water Drainage System

Area	Construction cost	Land cost	Total
	(1,000 Baht)	(1,000 Baht)	(1,000 Baht)
Central Pattaya	15,393	17,137	32,530
Southern Na Klua	7,547	1,306	8,853
Total	22,940	18,443	41,383

The total construction cost for this system estimated in this feasibility study, 41 million Baht, accounts for 67% of the 62 million Baht which was originally estimated in the master plan.

4.2 Field Investigations

The field investigation was carried out for about 1 month from March, 1978, for the following purposes.

- To grasp the present conditions and problems of storm water drainage facilities: (1)
- Soil investigation : (2)
- Topographic survey : (3)
- Collection of other data necessary for the storm water drainage plan : (4)

The outline of Items (2), (3) and (4) is described hereunder. Item (1) is described later in Sec.4.3.

4.2.1 Soil Investigation

The study team carried out a boring investigation with a hand auger and field permeability tests to estimate the soil characteristics of the foundations for various substructures and the runoff coefficient. The investigated points and areas are shown in Fig. 4.2.1.

(a) Soil Conditions

1) Pattaya Area

The soil of the Pattaya Area is generally composed of a tight sandy soil layer (sand, silty sand, sandy clay, etc.) down to 5 to 10 meters under the ground with N-value in the range of 10 to 50. This soil layer has a sufficient density to form a foundation for various substructures.

The permeability coefficient is considerably high and in the range of 10^{-2} to 10^{-5} m/sec. Judging from the sandy soil layer with a high permeability coefficient, the runoff coefficient of the Pattaya Area, excluding the paved and/or developed areas, is estimated to be very low.

Under the sandy soil layer, a densely tight and hard clayey layer is distributed.


2) Na Klua Area

Na Klua Area also shows similar geological features.

(b) Ground Water Table

The ground water tables of both Pattaya and Na Klua Areas were estimated by the water levels of the boring pits and existing wells. The ground water tables of both areas vary depending on whether it is the rainy season or the dry season; however, they are comparatively high throughout the year and in the range of 0.30 to 2.0 meters under the ground.

**FIG 4.2.1 LOCATION MAP OF SOIL INVESTIGATION
AND TOPOGRAPHIC SURVEY**



LEGEND

- SURVEYED AREA FOR DRAINAGE PLAN
- TOPOGRAPHIC SURVEYING POINT
- ▲ BORING POINT
- EXISTING RIVER AND OPEN CHANNEL

4.2.2 Topographic Survey

For the purpose of estimating the allowable flow capacity of the existing rivers and open channels, the study team conducted a cross-sectional survey at typical points along the existing and future main drainage routes. The survey points are shown in Fig. 4.2.1.

4.2.3 Other Collected Data

Following data have been collected to add to the above.

- Data on Rainfall Intensity.

The daily rainfall data for one year in the areas of Bang Pra and Mab Prachan reservoirs.

- The data on the construction materials and their unit costs for the drainage channels and water gates, etc.



Present Na Klua River Estuary