

APPENDIX

A - 1	Load Forecast Devided into the Regional Systems ,.....	A-1
A-1-1	Trial Calculations by Macroscopic Method	A-21
A - 2	Supply Capability from 1975 to 1984 and Supply Capability of Existing Power Plants at the End of 1974	A-26
A - 3	Estimated Generating Energy Cost by Diesel Power Plants	A-51
A - 4	Hydropower Plants to be Installed in and after 1985	A-59
A - 5	kW Balance in the Regional Systems	A-105
A - 6	Regional Power System for Electrification	A-124

APPENDIX

A-1 Load Forecast Devided into the Regional Systems

Table A-1-(1)	Load Forecast for Entire Ecuador	A-2
"	(2) Load Forecast for the Sistema Norte	A-3
"	(3) Load Forecast for the Sistema Pichincha	A-4
"	(4) Load Forecast for the Sistema Centro-Norte	A-5
"	(5) Load Forecast for the Sistema Centro-Sur	A-6
"	(6) Load Forecast for the Sistema Sur	A-7
"	(7) Load Forecast for the Sistema Esmeraldas	A-8
"	(8) Load Forecast for the Sistema Manabi	A-9
"	(9) Load Forecast for the Sistema Guayas-Los Rios	A-10
"	(10) Load Forecast for the Sistema El Oro	A-11
"	(11) Classification of Industrial Demand	A-12
"	(12) Ratio of Energy Demand by Customers	A-13
"	(13) Number of Customers and Energy Demand per Customers	A-16
A - 1 - 1	Trial Calculations by Macroscopic Method	A-21

Table A - 1 - (1)
Load Forecast for Entire Ecuador

		(Estimated)						Unit : GWh						
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980 Increase (%)	1980-1984 Increase (%)
Energy demand at customer end (GWh)		(22.9)	(23.0)	(24.1)	(21.9)	(12.4)	(13.8)	(9.6)	(10.3)	(11.0)	(11.0)	(11.0)	21.1	10.3
Industry	341.25	419.38	515.66	691.37	842.54	946.85	1,077.78	1,181.58	1,303.33	1,438.20	1,595.88			36.7
Residential	412.72	464.19	(12.5)	(13.1)	(13.3)	(13.5)	(13.6)	(12.2)	(11.9)	(11.7)	(11.5)	(11.5)	13.2	11.8
Commercial	175.20	195.12	224.09	(13.1)	(13.1)	(13.6)	(13.4)	(13.4)	(11.5)	(11.0)	(11.1)	(10.6)	13.3	12.6
Others	112.34	120.51	(7.3)	(7.5)	(7.5)	(7.2)	(7.4)	(7.4)	(6.7)	(6.6)	(6.6)	(6.6)	7.3	7.0
Subtotal	1,041.49	1,202.20	(15.4)	(15.9)	(20.4)	(16.4)	(12.6)	(13.2)	(10.6)	(10.7)	(10.7)	(10.8)	15.6	10.7
Energy requirement at sending end (GWh)	1,247.54	1,435.07	(15.0)	(15.6)	(20.3)	(16.0)	(12.2)	(13.0)	(10.4)	(10.5)	(10.5)	(10.5)	15.3	13.3
Loss factor (%)	16.5	16.2	16.0	15.9	15.6	15.4	15.2	15.0	14.8	14.6	14.4			
Load factor (%)	48	48	48	48	49	49	49	49	49	49	49	49	49	49
Max. demand at sending end (MW)	299.76	342.78	(14.4)	(15.3)	(18.0)	(15.2)	(12.6)	(12.9)	(10.5)	(10.6)	(10.5)	(10.5)	14.7	10.5
			466.07	395.10	537.10	604.95	682.91	754.63	834.44	922.11	1,018.70			13.0

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (2) Load Forecast for the Sistema Norte

	(Estimated)						Unit : GWh						
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980 Increase (%)	1980-1984 Increase (%)
Energy demand at customers end (GWh)	(13.1)	(13.4)	(2,208.9)	(-3.3)	(-1.2)	(-1.3)	(-1.4)	(-1.5)	(-1.7)	(-1.8)	(-1.8)	1.6	42.0
Industry	1.98	2.24	2.54	58.61	60.52	61.28	62.09	62.98	63.94	65.02	66.19		
Residential	8.57	9.77	11.18	12.82	14.80	17.07	19.69	22.20	24.97	28.09	31.58	14.9	12.5
Commercial	4.17	4.76	5.45	6.20	7.10	8.14	9.32	10.56	11.99	13.60	15.43	13.5	14.0
Others	4.53	4.75	(6.0)	(5.4)	(5.6)	(5.9)	(6.1)	(4.0)	(3.8)	(3.6)	(3.6)	5.7	3.8
Subtotal	19.25	21.52	(12.5)	(232.6)	(6.1)	(5.0)	(5.4)	(5.0)	(5.3)	(5.6)	(5.9)	31.0	5.5
Energy requirement at sending end (GWh)	(11.5)	(12.1)	(244.1)	(5.7)	(4.6)	(5.0)	(4.7)	(4.9)	(5.3)	(5.6)	(5.6)	30.7	5.1
Loss factor (%)	18.6	18.3	18.1	18.4	18.1	17.8	17.5	17.2	16.9	16.7	16.4		
Load factor (%)	37	37	37	59	57	56	54	53	52	51	50		
Max. demand at sending end (MW)	7.34	8.16	(11.9)	(115.5)	(3.6)	(7.5)	(8.0)	(7.0)	(7.3)	(7.5)	(7.7)	22.5	7.4
			9.13	19.68	21.38	23.00	24.84	26.58	28.51	30.65	33.01		16.2

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (3) Load Forecast for the Sistema Pichincha

		(Estimated)						Unit : Gwh				
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
		Increase (%)										
Energy demand at customers end (Gwh)	(8.9)	(14.9)	(13.9)	(13.5)	(12.9)	(13.0)	(13.1)	(13.6)	(12.8)	(13.3)	(12.8)	13.0
Industry	99.34	108.19	124.29	141.61	160.74	181.45	205.02	231.84	263.32	296.98	336.36	
Residential	140.62	(10.5)	(10.3)	(11.1)	(10.7)	(10.9)	(11.0)	(11.1)	(10.9)	(10.9)	11.0	10.9
Commercial	49.22	55.65	62.40	(12.1)	(13.4)	(13.2)	(12.9)	(13.2)	(12.0)	(13.0)	(11.6)	12.4
Others	33.11	35.57	38.08	(7.4)	(7.0)	(8.3)	(7.4)	(7.5)	(7.4)	(7.3)	(7.5)	7.4
Subtotal	322.29	354.79	396.24	(10.1)	(11.7)	(12.1)	(11.7)	(11.6)	(11.8)	(11.6)	67.78	
Energy requirement at sending end (Gwh)	(9.8)	(11.5)	(11.9)	(11.4)	(11.3)	(11.4)	(11.5)	(11.5)	(11.6)	(11.6)	11.5	11.6
Loss factor (%)	19.9	19.7	19.5	19.4	19.3	19.1	18.9	18.7	18.3	18.1	17.8	
Load factor (%)	51	51	51	51	51	51	51	51	51	51	51	
Max. demand at sending end (MW)	89.24	97.86	108.77	(11.1)	(11.9)	(11.4)	(11.7)	(11.9)	(11.8)	(11.6)	(11.4)	11.6
												11.4

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (4) Load Forecast for the Sistema Centro-Norte

	(Estimated)						Unit : (GWh)				
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
Energy demand at customers end (GWh)	(25.3)	(20.8)	(12.5)	(62.4)	(7.3)	(11.1)	(7.6)	(9.6)	(7.8)	(7.9)	22.0
Industry	31.36	39.32	47.52	53.47	86.83	93.22	103.53	111.39	122.08	131.54	141.93
Residential	24.20	28.50	(17.8)	(18.5)	(17.4)	(16.7)	(16.4)	(13.6)	(13.2)	(13.5)	13.5
Commercial	13.77	15.15	16.69	18.44	20.42	22.48	24.88	27.43	30.05	33.13	36.62
Others	8.38	(5.9)	(6.4)	(6.7)	(6.8)	(7.1)	(7.4)	(6.4)	(5.8)	(5.6)	(5.5)
Subtotal	78.23	(18.1)	(16.9)	(13.2)	(35.1)	(10.3)	(12.4)	(9.7)	(10.6)	(9.8)	(10.0)
Energy requirement at sending end (GWh)	98.73	(17.3)	(16.1)	(12.8)	(33.6)	(9.8)	(11.9)	(9.3)	(10.2)	(9.4)	(9.6)
Loss factor (%)	20.8	20.2	19.6	19.3	18.3	18.0	17.7	17.4	17.1	16.8	16.6
Load factor (%)	42	42	43	44	46	46	46	46	46	45	45
Max. demand at sending end (GWh)	26.95	(15.6)	(13.9)	(11.8)	(25.9)	(10.8)	(12.4)	(9.8)	(10.6)	(10.1)	(10.4)
	31.16	35.47	39.65	49.92	55.31	62.15	68.25	75.47	83.09	91.69	10.2
											13.0

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (5) Load Forecast for the Sistema Centro-Sur

	(Estimated)						Unit : GWh							
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	Increase (%)
Energy demand at customers end (GWh)														
Industry	11.16	12.38	13.85	10.9	(11.9)	(158.1)	(6.3)	(28.8)	(7.2)	(7.9)	(8.3)	(8.6)	30.4	8.0
Residential	19.18	21.60	24.49	(12.6)	(13.5)	(14.1)	(14.9)	(15.9)	(17.7)	(12.1)	(12.4)	(12.5)	14.8	12.3
Commercial	3.60	4.28	5.03	(17.5)	(18.8)	(19.9)	(21.2)	(23.2)	(25.2)	(14.7)	(14.6)	(14.7)	20.9	14.7
Others	3.42	3.75	4.15	(9.9)	(10.6)	(11.6)	(12.1)	(16.8)	(17.3)	(5.6)	(5.7)	(5.7)	13.0	10.0
Subtotal	37.36	41.96	47.52	(12.3)	(13.8)	(14.5)	(14.5)	(12.1)	(23.8)	(9.7)	(10.1)	(10.4)	21.0	16.5
Energy requirement at sending end (GWh)				(11.5)	(12.5)	(54.2)	(13.8)	(11.3)	(22.7)	(9.2)	(9.6)	(9.9)	(10.1)	20.1
Loss factor (%)				53.38	60.04	92.59	105.34	117.27	143.83	157.07	172.13	189.20	208.37	9.7
Load factor (%)				21.9	21.4	20.8	20.4	19.9	19.3	18.6	18.2	17.9	17.5	17.1
Max. demand at sending end (MW)				12.57	14.11	(12.3)	(13.4)	(49.9)	(14.8)	(13.2)	(23.5)	(9.0)	(9.3)	(9.8)

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (6) Load Forecast for the Sistema Sur

	(Estimated)						Unit: GWh			Increase (%)					
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984	
Energy demand at customers end (GWh)															
Industry	1.86	4.05	(118.0)	(29.8)	(13.5)	(17.7)	(56.8)	(29.4)	(10.9)	(9.4)	(10.2)	40.4	10.2	27.5	
Residential	3.63	4.21	(15.9)	(18.4)	(21.2)	(23.2)	(24.6)	(27.1)	(29.8)	(23.9)	(20.7)	21.7	25.9	23.3	
Commercial	2.36	3.17	(11.1)	(13.0)	(14.8)	(16.1)	(16.4)	(18.6)	(22.0)	(22.2)	(18.0)	15.0	19.4	16.7	
Others	3.16	3.30	(4.3)	(4.0)	(5.1)	(5.0)	(5.4)	(6.2)	(6.6)	(6.7)	(6.5)	5.0	6.5	5.6	
Subtotal	11.51	14.73	(28.0)	(17.1)	(14.3)	(16.7)	(16.6)	(23.5)	(18.4)	(19.0)	(16.3)	21.4	17.2	19.7	
Energy requirement at sending end (GWh)	14.04	17.88	(27.3)	(17.0)	(14.1)	(16.6)	(29.0)	(23.2)	(18.2)	(18.8)	(16.1)	(14.7)	21.1	16.9	19.4
Loss factor (%)	18.0	17.6	17.4	17.3	17.2	16.9	16.6	16.5	16.4	16.2	16.0				
Load factor (%)	36	37	37	38	38	38	39	40	40	41	42				
Max. demand at sending end (MW)	4.41	5.50	(24.9)	(16.6)	(12.7)	(15.2)	(27.2)	(20.5)	(16.8)	(17.4)	(14.1)	(12.9)	19.4	15.3	17.7

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (7) Load Forecast for the Sistema Esmeraldas

		Unit : GWh						Increase (%)							
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984
Energy demand at customers end (GWh)	(54.6)	(58.1)	(26.9)	(42.6)	(15.0)	(75.1)	(6.8)	(7.0)	(7.4)	(22.0)	(39.0)	(10.6)	26.9		
Industry	4.24	6.56	8.40	10.66	15.20	17.48	30.61	32.70	35.00	37.59	45.36				
Residential	4.26	5.00	5.93	7.12	8.66	10.74	13.58	17.43	21.79	26.47	31.58	23.5	22.2		
Commercial	2.13	2.52	3.02	3.66	4.49	5.59	7.09	9.02	11.30	13.72	16.22	22.2	22.0	22.5	
Others	1.45	1.71	1.95	2.23	2.52	2.85	3.20	3.55	3.91	4.30	4.73	14.1	10.2	12.5	
Subtotal	12.08	15.79	19.30	23.67	30.87	36.66	54.48	62.70	72.00	82.08	98.39	28.5	15.9	23.3	
Energy requirement at sending end (GWh)	(30.0)	(21.5)	(22.0)	(29.8)	(18.2)	(47.8)	(14.5)	(14.2)	(13.4)	(19.3)	(27.9)	15.3	22.7		
Loss factor (%)	20.9	20.4	20.0	19.6	19.2	18.8	18.3	17.9	17.5	17.0	16.6				
Load factor (%)	38	41	42	44	48	53	52	51	51	51	51				
Max. demand at sending end (MW)	4.64	5.56	6.49	7.59	9.06	10.64	14.27	16.81	19.54	22.19	26.23	20.6	16.4	18.9	

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (8) Load Forecast for the Sistema Manabi

	(Estimated)						Unit: GWh					
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980 1980-1984 Increase (%)
Energy demand at customers end (GWh)	(36.1)	(61.3)	(39.4)	(7.9)	(8.2)	(22.6)	(7.7)	(8.0)	(8.2)	(7.9)	(7.9)	19.5
Industry	7.66	10.42	16.81	23.43	25.29	27.37	33.55	36.13	38.97	42.10	45.55	
Residential	14.02	(22.4)	(23.8)	(22.2)	(22.7)	(20.8)	(18.1)	(16.6)	(14.0)	(13.0)	(12.2)	13.9
Commercial	7.07	8.18	9.70	11.34	13.42	15.70	18.07	20.68	23.34	26.06	28.92	18.5
Others	4.59	(10.0)	(10.4)	(10.2)	(8.4)	(8.5)	(8.4)	(7.4)	(7.3)	(7.1)	(7.0)	8.5
Subtotal	33.34	(22.4)	(30.6)	(25.4)	(15.5)	(15.0)	(18.2)	(12.7)	(11.5)	(10.9)	(10.5)	21.0
Energy requirement at sending end (GWh)	43.69	(21.0)	(29.1)	(23.9)	(14.2)	(13.9)	(17.1)	(11.4)	(10.7)	(10.3)	(10.2)	19.7
Loss factor (%)	23.6	22.8	21.8	20.9	20.0	19.3	18.5	17.6	17.1	16.6	16.3	
Load factor (%)	43	44	45	46	47	48	48	48	47	47	47	
Max. demand at sending end (GWh)	11.66	(17.8)	(26.2)	(20.9)	(13.2)	(13.0)	(14.7)	(11.5)	(11.2)	(10.7)	(10.4)	17.5
	13.74	17.38	20.96	23.72	26.90	30.74	34.29	38.14	42.22	46.59	51.0	14.9

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (9) Load Forecast for the Sistema Guayas-Los Ríos

	(Estimated)						Unit : GWh					
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%)
Energy demand at customers end (GWh)	(28.3)	(24.8)	(21.8)	(23.5)	(14.9)	(12.0)	(10.1)	(10.6)	(11.2)	(11.3)	20.7	10.8
Industry	178.57	229.05	285.95	348.17	430.09	494.06	553.16	609.22	674.03	749.50	833.97	16.7
Residential	191.65	214.86	(12.1)	(12.4)	(12.7)	(13.1)	(13.0)	(10.8)	(10.5)	(10.3)	(10.1)	12.7
Commercial	87.32	98.71	(13.0)	(13.1)	(12.7)	(13.0)	(12.8)	(12.5)	(9.1)	(8.9)	(8.6)	10.5
Others	51.76	55.25	(6.7)	(6.3)	(6.4)	(6.4)	(6.3)	(6.1)	(6.1)	(6.1)	(6.1)	11.3
Subtotal	509.30	597.87	(17.4)	(17.0)	(15.8)	(16.9)	(13.4)	(12.0)	(10.0)	(10.1)	(10.2)	15.4
Energy requirement at sending end (GWh)	579.48	679.39	(17.2)	(16.8)	(15.6)	(16.8)	(13.3)	(11.9)	(9.8)	(9.9)	(10.1)	10.0
Loss factor (%)	12.1	12.0	11.9	11.8	11.7	11.6	11.5	11.4	11.3	11.2	11.1	13.1
Load factor (%)	49	49	49	49	50	50	50	50	50	50	50	
Max. demand at sending end (MW)	135.97	156.26	(16.4)	(16.8)	(14.9)	(16.2)	(12.9)	(12.0)	(9.7)	(9.7)	(9.7)	12.8

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (10) Load Forecast for the Sistema El Oro

	(Estimated)						Unit: GWh				Increase (%)			
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984
Energy demand at customers end (GWh)	(42.1)	(54.5)	(30.4)	(18.8)	(9.6)	(10.7)	(9.9)	(10.0)	(10.1)	(10.2)	(26.6)	10.1	19.7	
Industry	5.04	7.16	11.05	14.41	17.13	18.77	20.78	22.85	25.14	27.69	30.51			
Residential	6.58	7.70	9.11	10.71	12.71	17.6	(17.5)	(16.9)	(18.8)	(18.0)	(17.3)	17.6	18.2	17.9
Commercial	5.07	5.75	6.56	7.44	8.46	9.55	10.87	12.04	13.43	15.07	16.99			
Others	1.44	1.74	2.06	2.39	2.72	3.09	(14.0)	(13.7)	(11.6)	(12.4)	(12.1)	(11.0)	15.6	14.0
Subtotal	18.13	(23.1)	(28.8)	(21.4)	(17.3)	(13.0)	(13.0)	(13.7)	(13.6)	(13.5)	(13.4)	19.3	15.5	17.0
Energy requirement at sending end (GWh)	22.39	(23.0)	(28.1)	(20.9)	(16.6)	(12.7)	(12.4)	(13.2)	(13.2)	(13.1)	(13.1)	16.8	13.2	16.5
Loss factor (%)	19.0	18.8	18.4	18.0	17.5	17.3	16.9	16.5	16.3	16.0	15.8			
Load factor (%)	37	37	38	38	39	40	40	41	42	42	43			
Max. demand at sending end (MW)	6.98	(8.43)	(10.56)	(12.71)	(14.56)	(14.6)	(10.6)	(11.5)	(11.5)	(11.3)	(11.3)	16.9	11.4	14.6

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (11) Classification of Industrial Demand

State	(Estimated)	Unit: GWh										Increase (%) 1974-1980 1980-1984 1974-1984 1974-1986 1980-1986 1974-1986	
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	
(1) Norte	General	1.98	2.24	2.54	2.76	3.11	3.49	3.91	4.38	4.90	5.49	6.15	12.0
	Special	-	-	55.83	57.42	57.79	58.18	58.60	59.04	59.53	60.04	61.68	1.6
	Subtotal	1.98	2.24	2.54	58.61	60.52	61.28	62.09	62.98	63.94	65.02	66.19	42.0
(2) Pichincha	General	99.34	106.19	119.23	131.38	144.78	159.55	175.82	193.76	213.52	235.30	259.30	10.2
	Special	-	-	5.06	10.23	15.96	21.90	29.20	38.08	49.30	61.68	77.06	10.1
	Subtotal	99.34	106.19	124.29	141.01	160.74	181.45	205.02	231.34	263.32	296.98	336.36	13.0
(3) Centro-Norte	General	31.38	32.71	36.20	38.67	49.76	44.85	48.17	51.74	53.57	59.88	64.09	7.4
	Special	5.61	11.32	14.60	37.07	48.37	55.36	59.65	66.51	71.86	77.84	84.09	7.4
	Subtotal	31.38	39.32	47.52	53.47	86.83	92.22	103.52	111.39	122.08	131.54	141.93	16.3
(4) Centro-Sur	General	11.16	12.38	13.85	15.49	17.34	19.41	21.72	24.30	27.19	30.43	34.05	11.8
	Special	-	-	19.55	22.38	22.80	33.06	34.42	36.17	38.19	40.45	42.04	8.0
	Subtotal	11.16	12.38	13.85	35.04	59.72	42.21	54.78	58.72	63.36	68.62	74.50	20.9
(5) Sur	General	1.86	2.08	2.33	2.60	2.91	3.26	3.65	4.08	4.57	5.11	5.72	11.9
	Special	-	1.97	2.93	3.26	4.11	7.75	10.59	11.71	12.94	14.06	15.29	11.9
	Subtotal	1.86	4.05	5.26	5.96	7.02	11.01	14.24	15.79	17.53	19.16	21.01	10.2
(6) Esmeraldas	General	4.24	4.88	5.61	6.45	7.42	8.54	9.82	11.29	12.98	14.93	17.17	15.0
	Special	-	1.68	2.79	4.21	7.78	8.94	20.79	21.41	22.02	22.66	23.69	15.0
	Subtotal	4.24	6.56	8.40	10.66	15.20	17.48	30.61	32.70	33.00	37.59	45.36	26.9
(7) Manabí	General	7.66	8.33	9.06	9.86	10.73	11.67	12.70	13.82	15.04	16.36	17.80	8.8
	Special	-	2.09	7.75	13.57	14.56	15.70	20.85	22.31	23.93	25.74	27.75	8.8
	Subtotal	7.66	10.42	16.81	23.43	25.29	27.37	33.55	36.13	38.97	42.10	45.55	19.5
(8) Guayas	General	173.57	195.34	213.71	233.31	255.78	279.31	306.12	334.91	366.38	400.82	438.50	9.4
	Special	-	33.71	72.24	114.36	174.31	214.25	247.04	274.31	307.65	348.68	395.47	9.4
	Subtotal	173.57	229.05	265.95	346.17	430.09	494.06	553.16	609.22	674.03	749.30	833.97	16.7
(9) El Oro	General	5.04	5.48	5.85	6.31	6.80	7.33	7.90	8.52	9.18	9.90	10.67	7.8
	Special	-	1.73	5.20	8.10	10.33	11.44	12.88	14.33	15.96	17.79	19.34	7.8
	Subtotal	5.04	7.16	11.05	14.41	17.13	18.77	20.75	22.85	25.14	27.69	30.51	19.7
Total	General	341.23	372.58	408.38	447.57	498.64	537.92	589.82	646.73	709.32	778.00	833.44	9.6
	Special	-	46.80	107.26	263.30	343.90	408.93	457.96	534.80	594.02	660.20	762.42	9.6
	Subtotal	341.23	419.38	515.66	691.37	842.54	946.85	1,077.73	1,181.58	1,303.34	1,488.20	1,595.86	10.3

Table A - 1 - (12) Ratio of Energy Demand by Customers (1 - 3)

		(Estimated)						(Unit : %)					
		Customers	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
1 Norte	Industry	10.3	10.4	10.5	10.6	68.7	66.3	63.7	61.6	59.4	57.2	54.9	
	Residential	44.5	45.4	46.2	45.5	16.8	18.5	20.2	21.7	23.2	24.7	26.2	
	Commercial	21.7	22.1	22.5	7.5	8.1	8.8	9.6	10.3	11.1	11.9	12.8	
	Others	23.5	22.1	20.8	6.4	6.4	6.5	6.5	6.4	6.3	6.2	6.1	
2 Pichincha	Industry	30.8	30.5	31.4	31.9	32.4	32.8	33.2	33.6	34.1	34.5	35.0	
	Residential	43.6	43.8	43.3	42.9	42.5	42.3	42.0	41.8	41.5	41.2	41.0	
	Commercial	15.3	15.7	15.7	15.9	16.2	16.3	16.5	16.7	16.8	17.0	17.0	
	Others	10.3	10.0	9.6	9.3	8.9	8.6	8.3	7.9	7.6	7.3	7.0	
3 Centro-Norte	Industry	40.1	42.6	44.0	43.7	52.5	51.1	50.5	49.6	49.2	48.2	47.3	
	Residential	30.9	30.8	31.3	32.5	28.2	29.9	30.9	32.0	32.8	33.9	35.0	
	Commercial	17.6	16.4	15.4	15.1	12.4	12.3	12.2	12.2	12.1	12.2	12.2	
	Others	11.4	10.2	9.3	8.7	6.9	6.7	6.4	6.2	5.9	5.7	5.5	
4 Centro-Sur	Industry	29.9	28.5	29.2	47.6	47.1	44.7	46.8	45.7	44.8	44.0	43.2	
	Residential	51.3	51.5	37.9	38.1	39.4	37.5	38.3	39.1	39.7	40.4		
	Commercial	9.6	10.1	10.6	8.2	8.7	9.5	9.6	10.1	10.5	10.9	11.3	
	Others	9.2	8.9	8.7	6.3	6.1	6.4	6.1	5.9	5.6	5.4	5.1	

Table A - 1 - (12) Ratio of Energy Demand by Customers (2 - 3)

		(Estimated)						(Unit: %)					
Sistema		Customers	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
5 Sur	Industry	16.1	27.5	30.4	30.2	30.5	36.9	38.7	36.2	33.7	31.7	30.3	
	Residential	31.6	28.6	28.9	30.6	32.3	31.1	31.9	35.1	38.1	40.6	42.6	
	Commercial	24.8	21.5	20.8	20.9	20.8	18.6	17.9	18.4	18.9	19.2	19.3	
	Others	27.5	22.4	19.9	18.3	16.4	13.4	11.5	10.3	9.3	8.5	7.8	
6 Esmeraldas	Industry	35.1	41.5	43.5	45.0	49.2	47.7	56.2	52.1	48.6	45.8	46.6	
	Residential	35.2	31.7	30.7	30.1	28.1	29.3	24.9	27.8	30.3	32.3	32.1	
	Commercial	17.7	16.0	15.7	15.5	14.5	15.2	13.0	14.4	15.7	16.7	16.5	
	Others	12.0	10.8	10.1	9.4	8.2	7.8	5.9	5.7	5.4	5.2	4.8	
7 Manabi	Industry	23.0	25.5	31.5	35.0	32.7	30.8	32.0	30.6	29.6	28.8	28.2	
	Residential	42.1	42.1	39.8	38.8	41.3	43.4	43.4	44.8	45.9	46.7	47.5	
	Commercial	21.2	20.0	18.2	17.0	17.4	17.7	17.2	17.5	17.7	17.9	17.9	
	Others	13.7	12.4	10.5	9.2	8.6	8.1	7.5	7.1	6.8	6.6	6.4	
8 Guayas -Los Rios	Industry	35.1	38.3	40.9	43.0	45.4	46.0	46.1	46.3	46.7	47.2		
	Residential	37.6	35.9	34.7	33.7	32.5	32.4	32.7	32.9	33.1	33.1	33.0	
	Commercial	17.1	16.5	16.0	15.6	15.0	15.0	15.0	14.9	14.8	14.6	14.4	
	Others	10.2	9.3	8.4	7.7	7.1	6.6	6.3	6.1	5.8	5.6	5.4	

Table A - 1 - (12) Ratio of Energy Demand by Customers (3 - 3)

		(Estimated)							(Unit : %)				
		Customers	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
9 El Oro	Industry	27.8	32.0	38.4	41.2	41.8	40.5	39.7	38.4	37.2	36.1	35.1	
	Residential	36.3	34.5	31.6	30.7	31.0	32.2	33.3	34.9	36.5	38.0	39.2	
	Commercial	27.9	25.7	22.8	21.3	20.6	20.6	20.4	20.2	19.9	19.6	19.5	
	Others	8.0	7.8	7.2	6.8	6.6	6.7	6.6	6.5	6.4	6.3	6.2	
Total	Industry	32.8	34.9	37.0	41.2	43.2	43.1	43.3	42.9	42.8	42.6	42.7	
	Residential	39.6	38.6	37.6	35.4	34.4	34.7	34.9	35.4	35.7	36.1	36.3	
	Commercial	16.8	16.5	16.1	15.1	14.8	14.9	14.9	15.1	15.1	15.1	15.1	
	Others	10.8	10.0	9.3	8.3	7.6	7.3	6.9	6.6	6.4	6.2	5.9	

Table A-1-(13) Number of Customers and Energy Demand per Customers (1-5)

		1974 1975 1976 1977 1978 1979 1980 1981 1982 1983 1984					Increase (%)									
							1974	1980	1980	1984	1974	1980	1984	1974	1980	1984
Sistema Norte		Number of customers (10 ³)	20.55	22.19	24.02	26.04	28.36	30.98	33.91	36.02	38.22	40.53	42.99	8.7	6.1	7.7
Residential	Requirement per customers (kWh/customer)	41.7	44.0	46.5	49.2	52.2	55.1	58.1	61.6	65.3	69.3	73.5	5.7	6.1	5.8	
Commercial	Requirement per customers (kWh/customer)	3.52	3.79	4.10	4.43	4.82	5.26	5.73	6.10	6.51	6.94	7.39	8.5	6.6	7.7	
Population (10 ³)	1,154	1,257	1,329	1,400	1,473	1,548	1,626	1,702	1,782	1,862	1,960	2,059	5.4	6.5	5.8	
Others	Requirement per capital (kWh/capital)	13.7	14.1	14.7	15.2	15.7	16.3	17.0	17.3	17.6	17.9	18.2	3.7	1.7	2.9	
Sistema Pichachá		Number of customers (10 ³)	89.43	95.36	101.54	108.97	116.69	125.15	134.49	144.79	156.30	168.07	180.31	7.0	7.6	7.3
Residential	Requirement per customers (kWh/customer)	1,572	1,630	1,669	1,748	1,807	1,868	1,931	1,993	2,050	2,115	2,186	3.4	3.2	3.4	
Commercial	Requirement per customers (kWh/customer)	3.074	3.275	3.457	3.654	3.858	4.071	4.291	4.519	4.701	4.986	5.257	5.7	5.2	5.5	
Population (10 ³)	Others	Requirement per capital (kWh/capital)	936	978	1,019	1,068	1,115	1,164	1,215	1,269	1,325	1,383	1,444	4.4	4.4	4.4
			35.4	36.4	37.4	38.6	39.7	40.9	42.1	43.2	44.3	45.6	46.9	2.9	2.7	2.9

Table A-1-(13) Number of Customers and Energy Demand per Customers (2-5)

		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	Increase (%)
Sistema Centro Norte															
Residential	Number of customers (10 ³)	37.19	41.44	46.18	51.61	58.09	65.33	73.43	80.52	87.86	96.23	105.75	12.0	9.5	11.0
	Requirement per customers (kWh/customer)	651	688	732	769	802	833	863	894	927	961	993	4.8	3.6	4.3
Commercial	Number of customers (10 ³)	11.18	11.86	12.56	13.32	14.17	14.99	15.93	16.68	17.45	18.35	19.37	6.1	5.0	5.7
	Requirement per customers (kWh/customer)	1,232	1,277	1,329	1,384	1,441	1,500	1,562	1,639	1,722	1,805	1,891	4.0	4.9	4.4
Others	Population (10 ³)	965	986	1,006	1,027	1,050	1,073	1,097	1,121	1,145	1,171	1,199	2.2	2.2	2.2
Others : Requirement per capital (kWh/capital)		9.2	9.5	9.9	10.4	10.9	11.4	12.0	12.4	12.9	13.3	13.7	4.5	3.4	4.1
Sistema Centro Sur															
Residential	Number of customers (10 ³)	20.30	22.77	25.79	29.52	34.11	39.89	47.11	50.76	54.62	59.01	63.98	15.1	8.0	12.2
	Requirement per customers (kWh/customer)	945	948	950	947	942	934	931	970	1,011	1,124	1,090	-0.2	4.0	1.4
Commercial	Number of customers (10 ³)	2.55	2.93	3.41	4.01	4.78	5.79	7.15	7.73	8.47	9.26	10.16	18.7	9.2	14.8
	Requirement per customers (kWh/customer)	1,413	1,444	1,474	1,503	1,529	1,555	1,576	1,661	1,749	1,835	1,917	1.8	5.0	3.1
Others	Population (10 ³)	503	515	527	540	553	566	579	593	607	621	636	2.4	2.4	2.4
	Requirement per capital (kWh/capital)	6.8	7.3	7.9	8.6	9.4	10.7	12.3	12.7	13.1	13.5	13.9	10.4	3.1	7.4

Table A-1-(13) Number of Customers and Energy Demand per Customers (3-5)

		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	Increase (%)
System-Sur.	Number of customers (10^3)	7.98	8.56	9.39	10.56	12.11	14.10	16.86	20.71	25.50	30.10	34.67	13.3	20.0	15.8
Residential	Requirement per customers (KWh/customer)	455	492	531	572	614	658	699	738	776	814	853	7.4	5.1	6.5
Commercial	Requirement per customers (KWh/customer)	1,252	1,322	1,395	1,470	1,552	1,627	1,696	1,761	1,824	1,908	2,007	5.2	4.3	4.8
Population (10^3)		378	387	396	406	416	426	436	446	457	468	479	2.4	2.4	2.4
Others	Requirement per capital (KWh/capital)	8.4	8.5	8.7	8.9	9.1	9.4	9.7	10.1	10.5	11.0	11.4	2.4	4.1	3.1
Sistema Esmeraldas															
Residential	Number of customers (10^3)	5.23	5.97	6.87	8.01	9.50	11.47	14.16	17.76	21.82	25.96	30.24	18.1	20.9	19.2
Commercial	Requirement per customers (KWh/customer)	814	838	863	888	912	936	959	981	998	1,020	1,044	2.8	2.1	2.5
Population (10^3)		1.16	1.36	1.61	1.91	2.30	2.79	3.44	4.23	5.16	6.06	6.89	19.9	19.0	19.5
Others	Requirement per customers (KWh/customer)	1,837	1,854	1,876	1,916	1,932	2,005	2,061	2,133	2,190	2,264	2,354	1.9	3.4	2.5
Residential	Number of customers (10^3)	204	212	221	230	240	250	261	272	283	294	305	4.2	4.0	4.1
Commercial	Requirement per customers (KWh/customer)	7.1	8.1	8.8	9.7	10.5	11.4	12.3	13.1	13.8	14.6	15.5	9.6	6.0	8.1

Table A-1-(13) Number of Customers and Energy Demand per Customers (4-5)

	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	Increase (%)	
													1974-1984		
Manabi															
Residential	Number of customers (10 ³)	17.96	20.61	24.13	28.01	32.67	37.54	42.32	47.57	52.49	57.45	62.55	15.4	10.3	13.3
	Requirement per customers (kWh/customer)	781	833	880	927	975	1,025	1,073	1,113	1,150	1,188	1,224	5.4	3.3	4.6
Commercial	Number of customers (10 ³)	5.72	6.13	6.79	7.52	8.44	9.33	10.14	11.18	12.11	12.93	13.72	10.0	7.9	9.1
	Requirement per customers (kWh/customer)	1,236	1,335	1,429	1,507	1,589	1,682	1,782	1,850	1,927	2,015	2,108	6.3	4.3	5.5
Population (10 ³)	745	759	774	789	804	819	835	851	867	884	901	1.9	1.9	1.9	
Others	Requirement per capital (kWh/capital)	6.2	6.6	7.2	7.8	8.3	8.8	9.4	9.9	10.4	10.9	11.5	7.2	5.2	6.4
Sistema Guayas-Los Ríos															
Residential	Number of customer (10 ³)	132.53	144.30	159.77	177.12	197.53	222.77	248.51	268.71	288.74	307.77	326.01	11.0	7.0	9.4
	Requirement per customers (kWh/customer)	1,446	1,489	1,519	1,540	1,556	1,561	1,580	1,620	1,666	1,724	1,793	1.5	3.2	2.2
Commercial	Number of customers (10 ³)	25.59	27.64	30.29	33.32	37.17	41.65	46.32	48.66	51.03	53.32	55.49	10.4	4.6	8.0
	Requirement per customers (kWh/customer)	3,412	3,571	3,686	3,778	3,828	3,854	3,900	4,052	4,209	4,382	4,574	2.3	4.1	3.0
Population (10 ³)	1,969	2,035	2,102	2,174	2,246	2,321	2,396	2,476	2,560	2,645	2,732	3.3	3.3	3.3	
Others	Requirement per capital (kWh/capital)	26.3	27.1	28.1	28.8	29.7	30.6	31.5	32.3	33.2	34.1	35.0	3.1	2.7	2.9

Table A-1-(13) Number of Customer and Energy Demand per Customers (5-5)

										Increase (%)															
										1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974	1980	1984	1974	1984
Sistema El Oro																									
Residential	Requirement per customers (kWh/customer)	605	631	658	687	718	748	778	812	846	880	913	4.3	4.1	4.2										
Commercial	Requirement per customers (kWh/customer)	1,116	1,157	1,201	1,247	1,303	1,353	1,407	1,469	1,544	1,638	1,744	3.9	5.5	4.6										
Others	Requirement per capital (kWh/capital)	5.6	6.4	7.3	8.1	8.9	9.7	10.4	11.3	12.1	13.0	13.8	10.9	7.3	9.4										
Total	Number of customers (10^3)	10.88	12.22	13.84	15.60	17.70	19.97	22.43	25.55	29.15	33.08	37.39	12.8	13.6	13.1										
Residential	Requirement per customers (kWh/customer)	4.54	4.97	5.46	5.96	6.49	7.06	7.58	8.20	8.70	9.20	9.74	8.9	6.5	7.9										
Commercial	Requirement per customers (kWh/customer)	260	271	282	294	306	318	331	344	358	372	387	4.1	4.0	4.1										
Others	Requirement per capital (kWh/capital)	5.6	6.4	7.3	8.1	8.9	9.7	10.4	11.3	12.1	13.0	13.8	10.9	7.3	9.4										
Residential	Requirement per customers (kWh/customer)	342.05	373.42	411.53	455.44	506.76	567.20	633.22	692.39	754.70	813.20	883.89	10.8	8.7	10.0										
Commercial	Requirement per customers (kWh/customer)	72.55	78.07	84.84	92.63	102.01	112.51	124.03	133.01	142.39	151.51	160.53	9.3	6.7	8.3										
Others	Requirement per capital (kWh/capital)	17.9	18.6	19.4	20.2	21.0	21.9	22.8	23.6	24.4	25.3	26.1	4.1	3.4	3.8										


A-1-1 Trial Calculations by Macroscopic Method

Cross Check of Load Forecast by Macro Method Since the growthrate of GNP and that of electric power demand are mutually related, the cross check of forecast for power demand are performed employing the elastic coefficient of power demand to GNP.

(1) Elastic Coefficient of Electric Power Demand to GNP


GNP and electric power demand recorded from 1965 through 1973 are as shown in Fig. A-1-1-(1)

Fig. A-1-(1) Historical Trend of GNP and Energy Demand at Customer end



The elastic coefficient by year are shown in Fig. A-1-1-(2)

Fig. A-1-(2) Elastic Coefficient between GNP and Energy Demand by Year



The transitions in elastic coefficient due to moving of periods are as indicated in Table A-1-1-(1)

Table A-1-1-(1) Elastic Coefficient between GNP and Energy Demand by Various Period

	'65	'66	'67	'68	'69	'70	'71	'72	'73
'65									
'66	0.84								
'67	1.21	1.57							
'68	1.50	1.81	2.04						
'69	1.63	1.92	2.07	2.09					
'70	1.58	1.78	1.86	1.73	1.39				
'71	2.17	2.59	3.08	3.79	8.64	-			
'72	1.58	1.71	1.75	1.66	1.53	1.56	0.53		
'73	1.05	1.07	1.01	0.89	0.73	0.62	0.35	0.25	

According to the above, in spite of the fact that GNP had fallen in 1971 (-4.2 %), the power demand had increased by 9.8%.

On the other hand, in 1972 and 1973, despite prominent increases in GNP (nominal growth rates 17.4 % and 35 % respectively) accompanying starting and expansion of petroleum production, power demand showed a stable growth (9.3 % for 1972, 8.9 % for 1973). In effect it may be said that power demand is slightly inflexible against a large variation in GNP.

This requires an examination in depth of the flow of GNP, but in case of electric power demand.

- (1) Especially, in case of the regional electrification program which is more a part of building of the infrastructure and a project for implementation from the aspect of policy rather than an economic investment, it is considered that power demand will have a slight inflexibility against large variation in GNP.
- (2) The proportion in GNP occupied by the equipment investment (1972, 364 US million dollars, 19 % of GNP, 1973, 416 US million dollars, 16 % of GNP), and the capital goods and durable consumer goods in industrial production (1972, 459 US million dollars; 1973, 714 US million dollars) are extremely low in comparison with that of developed countries almost all of the capital goods and durable consumer goods must depend on imports, and it is considered that there will be a fair amount of time-lag for power demand to be actualized after economic incentive by investment. Therefore, the downturn in the elastic coefficient seen in Table A-1-1-(1) cannot be thought to be a real trend and it is assumed that in time there will be a shift to an upward course.

(2) Outlook on Elastic Coefficient

As described above, the elastic coefficients for the years 1971 through 1973 involve peculiar factors, and it is thought it would not necessarily be suitable for elastic coefficients to be used in units of years.

The regional electrification program may be considered as a main factor governing future elastic coefficients, and the electrification program, as frequently stated, is a project to spread electric power, and especially, at the primary stage up to around 1980, it is expected that the speed of growth in electric power will be high compared with the real speed of growth of the economy. At the secondary stage from 1981 and after, the speed of growth due to regional electrification is expected to shift to a relatively declining trend compared with the primary stage.

Therefore, of the elastic coefficients which should be used for the present cross check, from 1975 until 1980, the elastic coefficient of 1.58 for 1965 to 1970 seen in the elastic coefficient table will be employed, while for 1981 to 1984, the elastic coefficient of 1.05 in the same table for 1965 to 1973 will be employed.

(3) Forecast of Economic Growth

According to the "Five-Year Comprehensive Development Plan (1973-1977)" announced in 1972, a real economic growth rate of 10% is forecast for the future economic outlook. On the other hand, according to recent performance, the real growth rate was 10.4% in 1972, 12.0% in 1973 and 13.0% (estimated) in 1973.

The constitution of the Ecuadorian economy is dependent on the trends in petroleum, and when the recent world trend of relaxation in petroleum demand is taken into consideration, it may be said there is a considerable amount of fluid factors contained in economic growth for the future. On the other hand, when consideration is given from a comprehensive standpoint to the basic tone of surplus in the overall balance of income and expenditure since production of petroleum was started and the economic policies carried out by the authorities, it is thought the growth rate of the economy hereafter can be expected to be at least 10%.

(4) Trial Calculation Results by Macro Method

The results of calculations made based on the conditions assumed above are as indicated in Table A-1-1-(2).

Year	Energy demand at customer end (MWh)
1974	1,041,488
1975	1,206,043
1976	1,396,598
1977	1,617,260
1978	1,872,787
1979	2,168,688
1980	2,511,340
1981	2,775,031
1982	3,066,409
1983	3,388,382
1984	3,744,162

(5) Comparison between Results of Forecast by Analytical Method and Macro Method

The comparison between the forecast described in Chapter 4 and the trial calculation results of (4) above is as shown in Table A-1-1-(3).

Table A-1-1-(3) Comparison of Results between Analytical Method and Macro Method

Year	Energy Demand at Customer end		Deviation $\frac{B-A}{A} \times 100 (\%)$
	Analytical Method (A)	Macro Method (B)	
1974	1,041,488	1,041,488	-
1975	1,202,203	1,206,043	0.3
1976	1,393,865	1,396,598	0.2
1977	1,677,620	1,617,260	3.6
1978	1,952,242	1,872,787	4.1
1979	2,197,336	2,168,688	1.3
1980	2,487,802	2,511,340	0.9
1981	2,751,876	2,775,031	0.8
1983	3,373,564	3,388,382	0.4
1984	3,738,602	3,744,162	0.1

Note: 1. Elastic Value between GNP and Energy Demand at Customer end

1975 - 1980 : 1.58

1981 - 1984 : 1.05

2. Annual growth rate of GNP : 10 %

As seen in Table A-1-1-(3), there is no great difference between the results of forecasts in Chapter 4 and the trial calculations by macro method.

APPENDIX

A - 2 Supply Capability from 1975 to 1984 and Supply Capability of Existing Power Plants at the End of 1974

Table A-2

(1)	Installed Capacity by Year (1975 to 1984)	A-27
(2)	Dependable Power Supply Capability in National Interconnected System	A-30
(3)	Summary of Dependable Power Supply Capability in National Interconnected System	A-33
(4)	Existing Power Plants in Sistema Norte	A-35
(5)	Existing Power Plants in Sistema Pichincha	A-36
(6)	Existing Power Plants in Sistema Centro-Norte	A-37
(7)	Existing Power Plants in Sistema Centro-Sur	A-38
(8)	Existing Power Plants in Sistema Sur	A-38
(9)	Existing Power Plants in Sistema Esmeraldas	A-39
(10)	Existing Power Plants in Sistema Manabi	A-39
(11)	Existing Power Plants in Sistema Guayas-Los Ríos	A-40
(12)	Existing Power Plants in Sistema El Oro	A-40
(13)	Summary of Dependable Supply Capability of Existing Power Plants	A-41
(14)	Dependable Supply Capability of Existing Power Plants	A-45

Table A - 2 - (1) Installed Capacity by Year (1975 to 1984) (1 - 3)

Systems		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	
(1) Norte													
Hydro	Reg.	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000	
F-O-P	4,354	4,345	4,345	4,345	4,345	(- 3,034)	1,320	1,320	1,320	1,320	1,320	1,320	
Sub-total	12,354	12,354	12,354	12,354	12,354	9,320	9,320	9,320	9,320	9,320	9,320	9,320	
Thermal	Diesel	1,409	1,409	1,409	1,409	(2,500)	3,909	3,909	3,909	3,909	3,909	3,909	
	Gas	0	0	0	0	0	0	0	0	0	0	0	
	Steam	0	0	0	0	0	0	0	0	0	0	0	
	Sub-total	1,409	1,409	1,409	1,409	3,909	3,909	3,909	3,909	3,909	3,909	3,909	
	Total	13,763	13,763	13,763	13,763	16,263	13,229	13,229	13,229	13,229	13,229	13,229	
(2) Pichicuy													
Hydro	Reg.	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400	
R-O-R	3,760	(4,500)	8,260	8,260	8,260	8,260	8,260	8,260	8,260	8,260	8,260	8,260	
Sub-total	83,160	87,660	87,660	87,660	87,660	87,660	87,660	87,660	87,660	87,660	87,660	87,660	
Thermal	Diesel	35,630	(8,720)	(- 3,720+3,355)	(- 3,720+3,355)	46,025	(+ 2,180)	43,205	43,205	43,205	43,205	43,205	43,205
	Gas	44,350	39,455	(24,100)	24,100	24,100	24,100	24,100	24,100	24,100	24,100	24,100	
	Steam	0	0	0	0	0	0	0	0	0	0	0	
	Sub-total	35,630	68,450	63,555	70,125	70,125	72,305	72,305	72,305	72,305	72,305	72,305	
	Total	118,790	158,110	151,245	157,785	159,945	159,945	159,945	159,945	159,945	159,945	159,945	
(3) Centro-Norte													
Hydro	Reg.	0	0	0	0	0	0	0	0	0	0	0	
R-O-R	15,516	15,516	15,516	15,516	(2,500)	18,116	18,116	18,116	18,116	18,116	18,116	18,116	
Sub-total	15,516	15,516	15,516	15,516	18,116	18,116	18,116	18,116	18,116	18,116	18,116	18,116	
Thermal	Diesel	9,989	(7,000)	(- 3,720+1,500)	(- 8,720+2,500)	19,989	19,989	19,989	19,989	19,989	19,989	19,989	
	Gas	15,989	15,989	26,209	26,209	19,989	19,989	19,989	19,989	19,989	19,989	19,989	
	Steam	0	0	0	0	0	0	0	0	0	0	0	
	Sub-total	24,505	31,505	41,725	38,105	38,105	38,105	38,105	38,105	38,105	38,105	38,105	
(4) Centro-Sur													
Hydro	Reg.	0	0	0	(8,000)	8,000	8,000	8,000	8,000	8,000	8,000	8,000	
F-O-R	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	
Sub-total	6,432	6,432	6,432	6,432	14,432	14,432	14,432	14,432	14,432	14,432	14,432	14,432	
Thermal	Diesel	10,820	(2,280)	(8,520)	21,620	21,620	21,620	21,620	21,620	21,620	21,620	21,620	
	Gas	10,820	13,100	21,620	21,620	21,620	21,620	21,620	21,620	21,620	21,620	21,620	
	Steam	0	0	0	0	0	0	0	0	0	0	0	
	Total	17,252	19,532	23,052	36,052	36,052	36,052	36,052	36,052	36,052	36,052	36,052	

Table A - 2 - (1) Installed Capacity by Year *(1975 to 1984) (2 - 3)

	Sistema	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(5) Sur												
Hydro												
R-O-R	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400
Sub-coal	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400
Thermal												
Diesel	2,406	(1,280)	(2,500)	6,186	6,186	*(5,000)	11,186	11,186	11,186	11,186	11,186	11,186
Sub-total	2,406	3,686	6,186	6,186	6,186	11,186	11,186	11,186	11,186	11,186	11,186	11,186
Total	4,806	6,086	8,586	8,586	8,586	13,586	13,586	13,586	13,586	13,586	13,586	13,586
(6) Esmeraldas												
Thermal												
Diesel	4,860	(5,460)	(6,000)	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320
Total	4,860	10,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320
(7) Manabi												
Thermal												
Diesel	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600
Gas	0	0	0	(10,000)	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
Total	20,600	20,600	20,600	30,600	30,600	30,600	30,600	30,600	30,600	30,600	30,600	30,600
(8) Guayas-Los Rios												
Thermal												
(Guayaquil)												
Diesel	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640
Gas	55,500	(21,500)	(21,500)	(21,500)	120,000	120,000	120,000	120,000	120,000	120,000	120,000	120,000
Steam	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000
Sub-total	126,140	147,640	169,140	190,640	190,640	190,640	190,640	190,640	190,640	190,640	190,640	190,640
Thermal (Others)												
Diesel	16,386	(6,480)	(18,160)	(+2,180+1,000)	44,706	(- 2,180)	42,526	42,526	42,526	42,526	42,526	42,526
Sub-total	16,386	23,366	41,526	44,706	44,706	42,526	42,526	42,526	42,526	42,526	42,526	42,526
Total	143,026	171,006	210,666	235,346	235,346	233,166	233,166	233,166	233,166	233,166	233,166	233,166

Table A - 2 - (1) Installed Capacity by Year (1975 to 1984) (3 - 3)

Sistema	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(9) El Oro											
Hydro	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234
R-O-R	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234	2,234
Sub-total											
Thermal											
Diesel	6,432	(5,660)	12,092	(6,000)	18,092	18,092	18,092	18,092	18,092	18,092	18,092
Sub-total	6,432	12,092	12,092	18,092	18,092	18,092	18,092	18,092	18,092	18,092	18,092
Total	8,666		14,326		20,326		20,326		20,326		20,326
Total											
Hydro											
Reg.	87,400	87,400	87,400	95,400	95,400	95,400	95,400	95,400	95,400	95,400	95,400
R-O-R	34,696	39,196	39,196	41,796	38,762	38,762	38,762	38,762	38,762	38,762	38,762
Total	122,096	126,596	126,596	137,196	134,162	134,162	134,162	134,162	134,162	134,162	134,162
Thermal											
Diesel	115,672	152,552	193,087	205,087	210,087	210,087	210,087	210,087	210,087	210,087	210,087
Gas	55,500	101,100	122,600	154,100	154,100	154,100	154,100	154,100	154,100	154,100	154,100
Steam	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000
Total	234,172	316,652	373,657	422,187	422,187	427,187	427,187	427,187	427,187	427,187	427,187
Grand-Total	356,268	443,248	505,283	559,383	556,349	561,349	561,349	561,349	561,349	561,349	561,349
INECEL											
Hydro											
Reg.	0	0	0	0	69,200	69,200	69,200	(200,000)	(200,000)	(200,000)	(200,000)
Sub-total	0	0	0	0	69,200	69,200	69,200	369,200	369,200	469,200	569,200
Thermal											
Diesel	0	0	0	30,000	30,000	30,000	30,000	30,000	30,000	30,000	30,000
Steam	0	0	0	0	73,000	(73,000)	146,000	146,000	146,000	146,000	146,000
Sub-total	0	0	0	30,000	103,000	176,000	176,000	176,000	176,000	176,000	176,000
Total				30,000	172,200	245,200	245,200	245,200	245,200	245,200	245,200

1/ Transfer to Laredoagua 2,810 | 2/ Received from Quito

" Ambaro 2,810
" Robomba 2,810 x 2 | 8,720 kW

3/ Transfer to Santa Elena
4/ Received from Quito

Additional Facilities
Guayaquil 21,500 kW
Sur (Chocna) 5,000 kW

Note: Reg : Paddle type power plant
R-O-R : Natural inflow type power plant

Table A - 2 - (2) Dependable Power Supply Capability in National Interconnected System (1 - 3)
(Unit: MW)

Sistema		Installed Capacity	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
A. Regional System													
(1) Norte		kW	-	11.20	-	-	13.62	10.93	10.93	10.93	10.93	10.93	10.93
Existing power plants		H	9,320	7.14	-	-	7.14	7.14	7.14	7.14	7.14	7.14	7.14
"		T	3,034	2.69	-	-	2.69	-	-	-	-	-	-
"		T	1,409	1.37	-	-	1.37	1.37	1.37	1.37	1.37	1.37	1.37
New power plant (Barra)		T	2,500	-	-	-	2.24	2.24	2.24	2.24	2.24	2.24	2.24
(2) Pichincha		-	116.77	-	-	-	145.76	153.53	155.64	155.64	155.64	155.64	155.64
Quito		-	112.74	-	-	-	145.76	145.76	147.87	147.87	147.87	147.87	147.87
Existing power plants		H	83,160	82.20	-	-	82.20	82.20	82.20	82.20	82.20	82.20	82.20
"		T	31,475	30.54	-	-	28.43	30.54	30.54	30.54	30.54	30.54	30.54
New power plant (Pascooba)		H	4,500	-	-	-	3.29	3.29	3.29	3.29	3.29	3.29	3.29
"		T	8,720	-	-	-	8.46	8.46	8.46	8.46	8.46	8.46	8.46
(Latacunga)		T	24,100	-	-	-	23.38	23.38	23.38	23.38	23.38	23.38	23.38
(Guayaquil)		-	-	-	-	-	-	7.77	7.77	7.77	7.77	7.77	7.77
Soc. Domingo		-	4.03	-	-	-	-	4.03	4.03	4.03	4.03	4.03	4.03
Existing power plants		T	4,155	4.03	-	-	-	1.53	1.53	1.53	1.53	1.53	1.53
New power plant (Soc. Domingo)		T	1,575	-	-	-	-	-	2.21	2.21	2.21	2.21	2.21
"		T	2,280	-	-	-	-	-	-	2.21	2.21	2.21	2.21
(3) Centro-Norte		-	20.94	-	-	-	31.48	32.40	32.40	32.40	32.40	32.40	32.40
Latacunga & 3 Other Cities		-	20.51	-	-	-	31.48	31.48	31.48	31.48	31.48	31.48	31.48
Existing power plants		H	15,416	12.13	-	-	12.13	12.13	12.13	12.13	12.13	12.13	12.13
"		T	8,633	8.38	-	-	8.38	8.38	8.38	8.38	8.38	8.38	8.38
New power plant (Latacunga)		H	1,000	-	-	-	0.97	0.97	0.97	0.97	0.97	0.97	0.97
"		T	2,500	-	-	-	2.42	2.42	2.42	2.42	2.42	2.42	2.42
(Ambato)		H	6,000	-	-	-	5.82	5.82	5.82	5.82	5.82	5.82	5.82
"		T	2,600	-	-	-	0.79	0.79	0.79	0.79	0.79	0.79	0.79
(Bogambae)		H	1,000	-	-	-	0.97	0.97	0.97	0.97	0.97	0.97	0.97
(Guaranda)		-	-	-	-	-	-	-	-	-	-	-	-
Puyo		-	-	-	-	-	-	0.92	0.92	0.92	0.92	0.92	0.92
Existing power plant		H	-	0.43	-	-	-	0.08	0.08	0.08	0.08	0.08	0.08
"		T	100	0.03	-	-	-	-	-	-	-	-	-
New power plant (Puyo)		H	356	0.35	-	-	-	0.35	0.35	0.35	0.35	0.35	0.35
(4) Centro-Sur		-	500	-	-	-	-	0.49	0.49	0.49	0.49	0.49	0.49
Existing power plants		H	-	15.41	-	-	-	-	33.98	33.98	33.98	33.98	33.98
"		T	6,432	4.91	-	-	-	-	4.91	4.91	4.91	4.91	4.91
New power plant (Quenca)		H	10,220	10.50	-	-	-	-	10.50	10.50	10.50	10.50	10.50
"		T	6,000	-	-	-	-	-	8.00	8.00	8.00	8.00	8.00
(Quenca)		H	2,280	-	-	-	-	-	2.21	2.21	2.21	2.21	2.21
"		T	8,520	-	-	-	-	-	8.26	8.26	8.26	8.26	8.26

Note : H : Hydro Power Plant
T : Thermal Power Plant

Table A - 2 - (2) Dependable Power Supply Capability in National Interconnected System (2 - 3)

(Unit : KW)

Sistema	Installed Capacity	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(5) Sur	kW	4.72	-	-	-	-	-	-	-	-	-	-
Existing power plant	H	2,400	2.39	-	-	-	-	-	-	-	-	-
"	T	2,406	2.33	-	-	-	-	-	-	-	-	-
New power plant (Loja)	H	1,280	-	-	-	-	-	-	-	-	-	-
"	"	5,000	-	-	-	-	-	-	-	-	-	-
"	(Cattamayo)	2,500	-	-	-	-	-	-	-	-	-	-
(6) Esmeraldas	-	4.71	-	-	-	-	-	-	-	-	-	-
Existing power plants	T	4,860	4.71	-	-	-	-	-	-	-	-	-
New power plant (Esmeraldas)	T	5,460	-	-	-	-	-	-	-	-	-	-
"	"	6,000	-	-	-	-	-	-	-	-	-	-
(7) Manabi	-	19.98	-	-	-	-	-	-	-	-	-	-
Existing power plants	T	20,600	19.98	-	-	-	-	-	-	-	-	-
New power plant (Manta)	T	10,000	-	-	-	-	-	-	-	-	-	-
(8) Guayas-Los Rios	-	138.74	-	-	-	-	-	-	-	-	-	-
Guayaquil & 4 Other Cities	-	133.65	-	-	-	-	-	-	-	-	-	-
Existing power plant	T	137,786	133.65	-	-	-	-	-	-	-	-	-
New power plant (Guayaquil)	T	21,500	-	-	-	-	-	-	-	-	-	-
"	"	21,500	-	-	-	-	-	-	-	-	-	-
"	"	21,500	-	-	-	-	-	-	-	-	-	-
"	"	21,500	-	-	-	-	-	-	-	-	-	-
(Balboyo)	T	12,500	-	-	-	-	-	-	-	-	-	-
(Querevedo)	T	800	-	-	-	-	-	-	-	-	-	-
"	"	5,660	-	-	-	-	-	-	-	-	-	-
"	"	1,000	-	-	-	-	-	-	-	-	-	-
Santa Elena	-	5.09	-	-	-	-	-	-	-	-	-	-
Existing power plants	T	5,240	5.09	-	-	-	-	-	-	-	-	-
New power plant (Salinas)	T	5,680	-	-	-	-	-	-	-	-	-	-
(9) El Oro	-	7.05	-	-	-	-	-	-	-	-	-	-
Existing power plants	H	2,234	0.81	-	-	-	-	-	-	-	-	-
"	T	6,432	6.24	-	-	-	-	-	-	-	-	-
New power plant (Machala)	H	5,660	-	-	-	-	-	-	-	-	-	-
"	"	6,000	-	-	-	-	-	-	-	-	-	-
Total (1) - (9) Systems	-	309.52	-	-	-	-	-	-	-	-	-	-
Hydro	-	112.35	-	-	-	-	-	-	-	-	-	-
Thermal	-	27.17	-	-	-	-	-	-	-	-	-	-

Note : H : Hydro power plant
T : Thermal power plant

Table A - 2 - (2) Dependable Power Supply Capability in National Interconnected System (3 - 3)

		(Unit : MW)									
		Installed Capacity									
Sistema		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983
B. National System Projects											
	KW	-	-	-	-	-	-	-	-	-	-
New power plants											
Quito Norte	T	30,000	-	-	29,10	167,89	237,48	437,48	537,48	637,48	737,48
Guayaquil	T	73,000	-	-	29,10	69,59	69,59	69,59	69,59	69,59	69,59
"	H	73,000	-	-	-	69,59	69,59	69,59	69,59	69,59	69,59
Pisayambo	H	69,200	-	-	69,20	69,20	69,20	69,20	69,20	69,20	69,20
Parte I - (1)	H	200,000	-	-	-	-	200,00	200,00	200,00	200,00	200,00
" (2)	H	130,000	-	-	-	-	-	100,00	100,00	100,00	100,00
" (3)	H	100,000	-	-	-	-	-	-	100,00	100,00	100,00
" (4)	H	100,000	-	-	-	-	-	-	-	100,00	100,00
G - Total (A + B)		-	-	-	219,96	580,35	692,35	726,21	973,64	1,073,64	1,173,64
Hydro		-	-	-	108,24	174,83	174,83	187,74	350,94	490,94	590,94
Thermal		-	-	-	111,72	405,52	517,50	538,47	582,70	582,70	782,70

Note : H : Hydro power plant

T : Thermal power plant

Table A - 2 - (3) Summary of Dependable Power Supply Capability in National Interconnected System (1 - 2)

Sistema		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
A. Regional System												
(1) Norte	76.50	-	-	-	97.74	76.63	76.63	76.63	76.63	76.63	76.63	76.63
Hydro	64.52	-	-	-	64.52	43.41	43.41	43.41	43.41	43.41	43.41	43.41
Thermal	11.98	-	-	-	33.22	33.22	33.22	33.22	33.22	33.22	33.22	33.22
(2) Pichincha	648.84	-	-	903.19	971.25	989.73	989.73	989.73	989.73	989.73	989.73	989.73
Quito	613.53	-	-	903.19	903.19	921.67	921.67	921.67	921.67	921.67	921.67	921.67
Hydro	346.05	-	-	375.34	375.34	375.34	375.34	375.34	375.34	375.34	375.34	375.34
Thermal	267.48	-	-	527.85	527.85	546.33	546.33	546.33	546.33	546.33	546.33	546.33
Sto. Domingo	35.31	-	-	-	68.06	68.06	68.06	68.06	68.06	68.06	68.06	68.06
Thermal	35.31	-	-	-	68.06	68.06	68.06	68.06	68.06	68.06	68.06	68.06
(3) Centro-Norte	188.82	-	-	278.31	288.00	288.00	288.00	288.00	288.00	288.00	288.00	288.00
Latacunga & Others	188.36	-	-	278.31	280.02	280.02	280.02	280.02	280.02	280.02	280.02	280.02
Hydro	111.66	-	-	115.73	117.44	117.44	117.44	117.44	117.44	117.44	117.44	117.44
Thermal	73.40	-	-	162.58	162.58	162.58	162.58	162.58	162.58	162.58	162.58	162.58
Puyo	3.76	-	-	-	7.98	7.98	7.98	7.98	7.98	7.98	7.98	7.98
Hydro	0.71	-	-	-	0.71	0.71	0.71	0.71	0.71	0.71	0.71	0.71
Thermal	3.05	-	-	-	7.27	7.27	7.27	7.27	7.27	7.27	7.27	7.27
(4) Centro-Sur	143.87	-	-	-	-	281.13	281.13	281.13	281.13	281.13	281.13	281.13
Hydro	51.95	-	-	-	-	97.42	97.42	97.42	97.42	97.42	97.42	97.42
Thermal	91.92	-	-	-	-	183.71	183.71	183.71	183.71	183.71	183.71	183.71
(5) Sur	39.96	-	-	-	-	-	-	-	114.54	114.54	114.54	114.54
Hydro	19.49	-	-	-	-	-	-	-	19.49	19.49	19.49	19.49
Thermal	20.47	-	-	-	-	-	-	-	95.05	95.05	95.05	95.05
(6) Esmeraldas	41.26	-	-	-	-	-	-	-	138.67	138.67	138.67	138.67
Thermal	41.26	-	-	-	-	-	-	-	138.67	138.67	138.67	138.67
(7) Manabi	175.08	-	-	-	-	-	-	-	260.01	260.01	260.01	260.01
Thermal	175.08	-	-	-	-	-	-	-	260.01	260.01	260.01	260.01

Table A - 2 - (3)
Summary of Dependable Power Supply Capability in National Interconnected System (2 - 2)

		(Unit : GWh)										
Sistema		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(8) Guayas-Los Rios		1,215.33	—	—	—	1,388.47	1,981.27	1,981.27	1,981.27	1,981.27	1,981.27	1,981.27
Guayaquil & Others						1,388.47	1,868.47	1,888.47	1,888.47	1,888.47	1,888.47	1,888.47
Thermal												
Santa Elena												
Thermal												
(9) El Oro		44.52	—	—	—	—	—	92.80	92.80	92.80	92.80	92.80
Hydro		71.03	—	—	—	—	—	—	—	170.13	170.13	170.13
Thermal		16.40	—	—	—	—	—	—	—	16.40	16.40	16.40
Santa Elena		54.63	—	—	—	—	—	—	—	153.73	153.73	153.73
Regional System Total		2,600.59	—	—	—	1,279.24	3,224.35	3,612.74	3,893.87	4,300.11	4,300.11	4,300.11
Hydro		610.78	—	—	—	555.59	536.90	554.00	651.12	670.21	670.21	670.21
Thermal		1,089.51	—	—	—	723.65	2,687.45	3,058.74	3,242.45	3,629.90	3,629.90	3,629.90
B. National System Projects		0	—	—	—	254.92	1,076.51	1,686.10	1,686.10	3,438.10	3,804.10	4,170.10
Hydro		0	—	—	—	—	212.00	212.00	212.00	1,964.00	2,330.00	2,696.00
Thermal		0	—	—	—	—	254.92	854.51	1,474.10	1,474.10	1,474.10	1,474.10
C - Total		—	—	—	—	—	—	1,534.16	4,300.86	5,298.84	5,579.97	7,738.21
Hydro		—	—	—	—	—	—	555.59	748.90	766.00	863.42	2,634.21
Thermal		—	—	—	—	—	—	978.57	3,551.96	4,532.84	4,716.55	5,104.00

Table A - 2 - (4) Existing Power Plants in Sistema Norte

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
La Playa	1,320	—	1956, 1960	Tulcan
El Ambi	8,000	—	1967	Ibarra
Montufar	300	—	1955	San Gabriel
El Angel	472	—	1955, 1969	Espejo
Hoja Blanca	600	—	1933, 1950	Ibarra
San Luis	822	—	1950, 1956	Otavalo
Quiroga y Imantag	440	—	1953, 1962	Cotacachi
Ontañon	400	—		Ontañon
Tulcan	—	775	1973	Tulcan
El Sagrario	—	634	1961	Ibarra
Total	12,354	1,409		
		13,763		

Table A - 2 - (5) Existing Power Plants in Sistema Pichincha

(Unit: kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(Sistema Quito)				
Los Chillos	1,760	—	1922,	Quito
La Calera	2,000	—		Machachi
Guangopolo	9,400	—	1935, 1944 1953	Quito
Cumbaya	40,000	—	1959, 1964	"
Nayon	30,000	—	1974	"
Calorina	—	11,500	1956 - 1972	"
Luluncoto	—	19,975	1971, 1973	"
	83,160	31,475		
Sub total		114,635		
(Sistema Sto. Domingo)				
Sto, Domingo	0	4,155		Sto, Domingo
	0	4,155		
Sub total		4,155		
	83,160	35,630		
Total		118,790		

Table A - 2 - (6) Existing Power Plants in Sistema Centro Norte

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(Sistema Latacunga)				
Illuchi (I), (II)	4,200	—	1951, 1954 1967	Latacunga
Latacunga	—	813	1970, 1974	"
Salcedo	—	325	1974	Salcedo
Sub total	4,200 5,338	1,138		
(Sistema Ambato)				
La Peninsula	3,000	—	1961	Ambato
Mira-Flores	1,128	—	1957	"
El Batan	—	3,000	1967	"
Sub total	4,128 7,128	3,000		
(Sistema Riobamba)				
Alao (I)	5,300	—	1954	Riobamba
San Luis	—	3,360	1973	"
Guadalupe	458	—	1911, 1928	Guadalupe
Cordovez	680	—	1925, 1952	Cordovez
Guamote	—	360		Guamote
Sub total	6,438 10,158	3,720		
(Sistema Guaranda)				
Chimbo	650	—	1965	Guaranda
Chillanes	—	775	1972	"
Sub total	650 1,425	775		
(Sistema Puyo)				
Puyo	100	—	1965	Puyo
Puyo	—	356	1972	"
Sub total	100 456	356		
Total	15,516	8,989		
	24,505			

Table A - 2 - (7) Existing Power Plants in Sistema Centro Sur

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
Saimilin	6,432		1957, 1964	Cuenca
Monay I		4,500	1970	"
Erco		3,054	1963, 1964 1966, 1967	"
Guapan		2,500	1963, 1965	"
Azogues		766	1973	Azogues
	6,432	10,820		
Total		17,252		

Table A - 2 - (8) Existing Power Plants in Sistema Sur

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
San Francisco	2,400		1957, 1961 1968	Loja
Loja		1,266	1969, 1974	"
Catamayo		1,140	1974	Catamayo
	2,400	2,406		
Total		4,806		

Table A - 2 - (9) Existing Power Plants in Sistema Esmeraldas

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(System Esmeraldas)				
Santas Bainas		4,020	1964, 1965 1968, 1971	Esmeraldas
Quininde		190	1971, 1974	Quininde
Limones		285	1971, 1974	Limones
San Lorenzo		240	1967, 1973	San Lorenzo
Muisne		125	1972	Muisne
Total	0	4,860		
		4,860		

Table A - 2 - (10) Existing Power Plants in Sistema Manabi

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
Manta				
Manta		20,600	1972, 1973	Manta
Total	0	20,600		
		20,600		

Table A - 2 - (11) Existing Power Plants in Sistema Guayas-Los Rios
 (Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(Sistema Guayaquil)				
EMELEC		33,000	1970	
"		20,000	1958, 1962	
"		10,000	1954, 1957	
"		3,050	1946, 1952	
"		42,000	1973, 1974	
"		13,500	1968	
(Sistema Duran)				
(Sistema Salinas)		4,590	1965, 1973	Duran
(Sistema Playas)		4,740	1967, 1972	Salinas
(Sistema Milagro)		500	1969	Playas
(Sistema Babahoyo)		6,640	1972, 1974	Milagro
(Sistema Babahoyo)		2,240	1974	Babahoyo
(Sistema Quevedo)		2,766	1967, 1968 1973	Quevedo
Total	0	143,026		
		143,026		

Table A - 2 - (12) Existing Power Plants in Sistema El Oro
 (Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
Machala-Diesel		6,432	1971	Machala
La Calera	1,266		1937	Zaruma
Amallilla	672		1929	Zaruma
La Cueva	296			Pinas
Total	2,234	6,432		
		8,666		

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power Plants (1 - 4) GWh
Unit : (MW)

Systema		Installed Capacity (kW)	1	2	3	4	5	6	7	8	9	10	11	12	Total	
(1) Norte																
	H	12,354	4.68	3.57	3.82	4.83	5.91	7.17	5.58	4.61	4.32	5.47	7.22	7.34	64.52	
	T	1,409	(6.29)	(5.32)	(5.14)	(6.70)	(7.94)	(9.97)	(7.50)	(6.20)	(6.01)	(7.36)	(10.02)	(9.86)	(7.37)	
			(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	(1.37)	
	Total	13,763	5.70	4.49	4.84	5.81	6.93	8.15	6.60	5.63	5.30	6.49	8.20	8.36	76.50	
(2) Pichincha																
	Quito	H	83,160	31.10	37.64	41.12	32.62	31.60	29.09	24.67	20.79	18.49	27.06	27.46	24.41	346.05
	T	31,475	22.72	20.52	22.72	21.98	22.72	21.98	22.72	22.72	21.98	22.72	21.98	22.72	22.72	267.43
			(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	(30.54)	
	Sub-total	114,635	53.82	58.16	63.84	54.60	54.32	51.07	47.39	43.51	40.47	49.78	49.44	47.13	613.53	
	Sra. Domingo	T	4,155	3.00	2.71	3.00	2.90	3.00	2.90	3.00	3.00	2.90	3.00	2.90	3.00	35.31
			(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	(4.03)	
	Total	118,790	56.82	60.87	66.84	57.50	57.32	53.97	50.39	46.51	43.37	52.78	52.34	50.13	648.86	
(3) Centro Norte																
	Latacunga	H	4,200	2.42	2.03	2.44	2.36	2.44	2.36	2.44	1.60	2.36	2.44	2.06	2.44	27.39
	T	1,138	0.82	0.74	0.82	0.80	0.82	0.80	0.82	0.82	0.80	0.82	0.80	0.82	0.82	9.68
			(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	(1.11)	
	Sub-total	5,338	3.24	2.77	3.26	3.16	3.26	3.16	3.26	3.26	3.16	3.26	3.26	3.26	3.26	37.07
	Ambato	H	4,128	2.23	1.92	2.68	2.71	2.10	2.65	3.12	2.89	1.95	2.87	1.76	1.56	28.44
	T	3,000	2.17	1.96	2.17	2.10	2.17	2.10	2.17	2.10	2.17	2.10	2.17	2.17	2.17	25.55
			(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	(2.91)	
	Sub-total	7,128	4.40	3.88	4.85	4.81	4.27	4.75	5.29	5.06	4.05	5.04	5.86	5.73	53.99	
			(5.90)	(5.77)	(6.51)	(6.60)	(5.66)	(6.52)	(7.03)	(6.79)	(6.62)	(6.76)	(5.35)	(5.00)	(5.15)	

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power Plants (2 - 4) GWh Unit: (MW)

Systema		Installed Capacity (kW)												
		1	2	3	4	5	6	7	8	9	10	11	12	Total
Riohamba	H	6,438	4.58	4.13	3.00	2.84	4.58	4.42	4.58	4.42	4.58	4.42	4.58	50.71
	T	(6.16)	(4.03)	(3.95)	(6.16)	(6.14)	(6.16)	(6.14)	(6.14)	(6.14)	(6.14)	(6.14)	(6.14)	(5.78)
	T	3,720	2.68	2.42	2.68	2.60	2.68	2.60	2.68	2.60	2.68	2.60	2.68	31.58
		(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)	(3.61)
Sub-total		10,158	7.26	6.55	5.68	5.44	7.26	7.02	7.26	7.02	7.26	7.02	7.26	82.29
Guaranda	H	650	0.45	0.40	0.45	0.43	0.45	0.43	0.45	0.37	0.36	0.45	0.45	5.12
	T	(0.60)	(0.60)	(0.60)	(0.60)	(0.60)	(0.60)	(0.60)	(0.60)	(0.50)	(0.50)	(0.60)	(0.60)	(0.58)
	T	775	0.56	0.51	0.56	0.54	0.56	0.54	0.56	0.56	0.54	0.56	0.56	6.59
		(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)	(0.75)
Sub-total		1,425	1.01	0.91	1.01	0.97	1.01	0.97	1.01	0.93	0.90	1.01	0.97	11.71
Puyo	H	100	0.06	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.71
	T	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)	(0.08)
	T	356	0.26	0.23	0.26	0.25	0.26	0.25	0.26	0.26	0.25	0.25	0.26	3.05
		(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)	(0.35)
Sub-total		456	0.32	0.28	0.32	0.31	0.32	0.31	0.32	0.32	0.31	0.32	0.31	3.76
Total		24,505	16.23	14.39	15.12	14.69	16.12	16.21	17.14	15.99	15.44	16.89	15.02	188.82
(4) Centro Sur														
	H	6,432	3.86	3.96	4.39	4.60	4.69	4.61	4.69	4.61	4.61	4.61	4.61	3.65
	T	(5.19)	(5.89)	(5.90)	(6.39)	(6.30)	(6.40)	(6.30)	(6.30)	(6.20)	(5.90)	(6.20)	(5.60)	(5.95)
	T	10,820	7.81	7.05	7.81	7.55	7.81	7.55	7.81	7.81	7.55	7.81	7.55	91.92
		(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)	(10.50)
Total		17,252	11.67	11.01	12.20	12.15	12.50	12.16	12.50	12.42	11.80	12.42	11.58	143.87
		(15.69)	(16.39)	(16.40)	(16.89)	(16.80)	(16.90)	(16.80)	(16.80)	(16.70)	(16.40)	(16.70)	(15.41)	(16.43)

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power Plants (3 - 4) Unit: GWh

Sistema		Installed Capacity (kW)	1	2	3	4	5	6	7	8	9	10	11	12	Total
(5) Sur	H	2,400	1.78 (2.39)	1.61 (2.40)	1.78 (2.39)	1.72 (2.39)	1.78 (2.39)	1.37 (1.90)	1.41 (1.40)	1.04 (1.40)	1.72 (2.39)	1.78 (2.39)	1.72 (2.39)	1.78 (2.39)	19.49
T	2,406	1.74 (2.33)	1.57 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	20.47	
Total		4,806	3.52 (4.72)	3.18 (4.73)	3.52 (4.72)	3.40 (4.72)	3.52 (4.72)	3.05 (4.23)	3.15 (4.23)	2.78 (4.23)	3.40 (4.72)	3.52 (4.72)	3.40 (4.72)	3.52 (4.72)	39.96
(6) Esmeraldas	T	4,860	3.50 (4.71)	3.16 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	41.26
(7) Manabi	T	23,160	15.72 (22.47)	15.10 (22.47)	16.72 (22.47)	16.18 (22.47)	196.86								
(8) Guayas-Los Rios															
Guyaquil	T	55,500	40.06 (53.84)	36.18 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)								
T	66,050	47.67 (64.07)	43.06 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	46.13 (64.07)	501.27
Sub-total		121,550	79.24 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	1,032.91								
Durán	T	4,590	3.31 (4.45)	2.99 (4.45)	3.31 (4.45)	3.20 (4.45)	38.96								
Santa Elena	T	4,740	3.42 (4.60)	3.09 (4.60)	3.42 (4.60)	3.31 (4.60)	40.27								
Salinas															
Santa Elena	T	500	0.36 (0.49)	0.33 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.36 (0.49)	4.25
Playas															
Milagro	T	6,640	4.79 (6.44)	4.33 (6.44)	4.79 (6.44)	4.64 (6.44)	56.42								
Bahabayo	T	2,240	1.61 (2.17)	1.46 (2.17)	1.61 (2.17)	1.56 (2.17)	18.97								
Querevedo	T	2,766	1.99 (2.68)	1.80 (2.68)	1.99 (2.68)	1.93 (2.68)	23.45								
Total		143,026	103.21 (138.74)	98.24 (138.74)	103.21 (138.74)	99.88 (138.74)	1,215.23								

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power (4 - 4)

(9) El Oro	Sistema	Installed Capacity (kW)	Unit : (MW)											
			1	2	3	4	5	6	7	8	9	10	11	Total
H	2,234	1.26 (1.69)	1.46 (2.17)	1.62 (2.17)	1.57 (2.17)	1.62 (2.17)	1.57 (2.17)	1.62 (2.17)	1.56 (2.06)	1.40 (1.94)	1.15 (1.55)	0.99 (1.37)	0.60 (0.81)	16.40 (1.87)
T	6,432	4.64 (6.24)	4.19 (6.24)	4.64 (6.24)	4.49 (6.24)	4.64 (6.24)	4.49 (6.24)	4.64 (6.24)	4.64 (6.24)	4.49 (6.24)	4.64 (6.24)	4.49 (6.24)	4.64 (6.24)	54.63 (6.24)
Total	8,666	5.90 (7.93)	5.65 (8.41)	6.26 (8.41)	6.06 (8.41)	6.26 (8.41)	6.06 (8.41)	6.26 (8.41)	6.18 (8.30)	5.89 (8.18)	5.79 (7.79)	5.48 (7.61)	5.24 (7.05)	71.03 (8.11)
Grand Total	356,268	221.42 (297.62)	209.42 (311.66)	230.36 (309.62)	217.28 (301.72)	224.23 (301.70)	217.27 (301.72)	217.62 (292.44)	211.09 (283.75)	202.87 (281.81)	219.47 (295.02)	213.69 (296.80)	215.87 (290.16)	2,600.59 (296.89)
H	122,096	52.42 (70.45)	56.77 (84.49)	61.36 (82.45)	53.74 (74.55)	55.23 (74.53)	53.73 (74.55)	48.62 (65.27)	42.09 (56.58)	39.33 (54.64)	50.47 (67.85)	50.15 (69.36)	46.87 (62.99)	610.78 (69.72)
T	178,674	128.94 (173.33)	116.47 (173.33)	128.94 (173.33)	124.78 (173.33)	128.94 (173.33)	124.78 (173.33)	128.94 (173.33)	128.94 (173.33)	124.78 (173.33)	128.94 (173.33)	124.78 (173.33)	128.94 (173.33)	1,518.17 (173.33)
T	55,500	40.06 (53.84)	36.18 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	471.64 (53.84)

Note : H : Hydro power plants

T : Thermal power plants

Figure in parenthesis indicate average output of the power plants

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (1 - 6)

Sistema	Installed Capacity (kW)	Unit: GWh													
		1	2	3	4	5	6	7	8	9	10	11	12		
(1) Norte															
La Playa	H	1,320	0.70 (0.54)	0.61 (0.94)	0.70 (1.28)	0.92 (1.12)	0.83 (1.32)	0.95 (1.32)	0.98 (1.32)	0.97 (1.30)	0.92 (1.28)	0.98 (1.32)	0.91 (1.22)	10.42 (1.19)	
El Amabi	H	3,000	2.20 (2.96)	1.44 (2.14)	1.31 (2.83)	2.04 (4.14)	3.08 (5.96)	4.29 (3.95)	2.94 (2.94)	2.19 (2.78)	2.00 (2.78)	2.78 (3.74)	4.29 (5.96)	4.43 (5.95)	32.99 (3.77)
Mosquifar	H	300	0.18 (0.24)	0.16 (0.24)	0.18 (0.24)	0.17 (0.24)	0.18 (0.24)	0.17 (0.24)	0.18 (0.24)	0.17 (0.24)	0.17 (0.24)	0.17 (0.23)	0.18 (0.23)	0.19 (0.23)	2.10 (0.24)
El Angel	H	472	0.27 (0.36)	0.27 (0.40)	0.28 (0.38)	0.29 (0.40)	0.27 (0.36)	0.27 (0.38)	0.27 (0.40)	0.30 (0.36)	0.27 (0.36)	0.27 (0.40)	0.30 (0.40)	0.30 (0.40)	3.33 (0.39)
Orotina	H	400	0.30 (0.40)	0.26 (0.39)	0.28 (0.38)	0.26 (0.36)	0.30 (0.40)	0.29 (0.40)	0.22 (0.39)	0.29 (0.39)	0.25 (0.39)	0.24 (0.39)	0.29 (0.39)	0.30 (0.40)	3.28 (0.37)
Hojas Blanca	H	600	0.34 (0.46)	0.29 (0.43)	0.34 (0.46)	0.34 (0.47)	0.41 (0.55)	0.38 (0.53)	0.26 (0.53)	0.19 (0.53)	0.19 (0.53)	0.18 (0.53)	0.26 (0.53)	0.30 (0.53)	0.30 (0.53)
San Luis	H	322	0.41 (0.55)	0.30 (0.45)	0.47 (0.63)	0.52 (0.72)	0.54 (0.73)	0.54 (0.75)	0.45 (0.50)	0.37 (0.50)	0.37 (0.50)	0.35 (0.50)	0.44 (0.50)	0.52 (0.50)	0.54 (0.52)
Quiroga	H	440	0.28 (0.38)	0.24 (0.36)	0.26 (0.35)	0.29 (0.40)	0.30 (0.40)	0.28 (0.39)	0.25 (0.39)	0.20 (0.34)	0.20 (0.34)	0.19 (0.27)	0.25 (0.27)	0.29 (0.26)	0.29 (0.26)
Yimanang	T	775	0.56 (0.75)	0.51 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.56 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.56 (0.75)	5.45 (0.62)
Tulcan	T	634	0.46 (0.62)	0.41 (0.62)	0.46 (0.62)	0.44 (0.62)	0.46 (0.62)	0.44 (0.62)	0.46 (0.62)	0.46 (0.62)	0.46 (0.62)	0.46 (0.62)	0.46 (0.62)	0.46 (0.62)	5.39 (0.62)
Total		13,763	5.70 (7.66)	4.49 (6.69)	4.84 (6.51)	5.81 (8.07)	6.93 (9.31)	8.15 (11.34)	6.60 (8.87)	6.60 (7.57)	5.30 (7.33)	6.49 (7.33)	8.20 (8.73)	8.36 (8.74)	76.50 (8.74)
(2) Pichincha (Quito)															
Los Chillos	H	1,760	0.89 (1.20)	0.81 (1.21)	0.97 (1.30)	0.93 (1.29)	0.97 (1.30)	1.00 (1.39)	1.04 (1.40)	1.04 (1.40)	1.00 (1.39)	1.04 (1.40)	0.93 (1.40)	0.89 (1.40)	11.51 (1.31)
La Calera	H	2,000	1.12 (1.51)	1.17 (1.74)	1.49 (2.00)	1.41 (1.96)	1.32 (1.77)	1.25 (1.74)	1.13 (1.52)	1.10 (1.48)	1.10 (1.78)	1.28 (1.95)	1.45 (1.95)	1.19 (1.65)	15.10 (1.72)
Gangopolo	H	9,490	5.73 (7.70)	6.32 (9.40)	6.94 (9.33)	6.00 (8.33)	5.65 (7.59)	5.27 (7.32)	4.53 (6.09)	3.76 (5.05)	3.26 (4.53)	4.73 (6.36)	5.10 (6.36)	4.50 (6.36)	61.79 (6.36)
Cumbaya	H	40,000	13.20 (17.74)	15.65 (23.29)	17.00 (22.85)	13.73 (19.07)	13.37 (17.97)	12.22 (16.97)	10.15 (13.64)	8.42 (11.32)	7.35 (10.21)	11.22 (15.08)	11.42 (15.86)	10.07 (15.53)	143.80 (16.42)

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (2 - 6)

Sistema	Capacity (kW)	Installed												Unit: GWh (MW)	
		1	2	3	4	5	6	7	8	9	10	11	12		
Nayarit	H	30,000	10,16 (13,66)	13,69 (20,37)	14,72 (19,78)	10,55 (14,65)	10,29 (13,83)	9,35 (12,99)	7,82 (10,51)	6,47 (8,70)	5,60 (7,78)	8,62 (11,59)	7,76 (12,25)	8,82 (10,43)	113,85 (13,00)
California	T	11,500	8,30 (11,16)	7,50 (11,16)	8,30 (11,16)	8,03 (11,16)	8,30 (11,16)	8,03 (11,16)	8,30 (11,16)	8,30 (11,16)	8,03 (11,16)	8,30 (11,16)	8,30 (11,16)	97,72 (11,16)	
Lulucoto	T	19,975	14,42 (19,38)	13,02 (19,38)	14,42 (19,38)	13,95 (19,38)	14,42 (19,38)	13,95 (19,38)	14,42 (19,38)	14,42 (19,38)	13,95 (19,38)	14,42 (19,38)	13,95 (19,38)	14,42 (19,38)	169,76 (19,38)
Sub-total		114,635	53,82 (72,35)	58,16 (86,55)	63,84 (85,80)	54,60 (75,84)	54,32 (73,00)	51,07 (70,95)	47,39 (63,70)	43,51 (58,49)	40,47 (56,23)	49,78 (66,92)	49,44 (68,67)	47,13 (63,35)	613,53 (70,04)
(Sto. Domingo)															
Sto. Domingo	T	4,155	3,00 (4,03)	2,71 (4,03)	3,00 (4,03)	2,90 (4,03)	3,00 (4,03)	2,90 (4,03)	3,00 (4,03)	3,00 (4,03)	3,00 (4,03)	2,90 (4,03)	3,00 (4,03)	2,90 (4,03)	35,31 (4,03)
Sub-total		4,155	3,00 (4,03)	2,71 (4,03)	3,00 (4,03)	2,90 (4,03)	3,00 (4,03)	2,90 (4,03)	3,00 (4,03)	3,00 (4,03)	2,90 (4,03)	3,00 (4,03)	2,90 (4,03)	3,00 (4,03)	35,31 (4,03)
Total		118,790	56,82 (76,38)	60,87 (90,58)	66,84 (89,83)	57,50 (79,87)	57,32 (77,03)	53,97 (74,98)	50,39 (67,73)	46,51 (62,52)	43,37 (60,26)	52,78 (70,95)	52,34 (72,70)	50,13 (72,70)	648,84 (74,07)
(3) Centro Norte (Latacunga)															
Muchi (I)	H	2,800	1,38 (1,85)	1,09 (1,62)	1,40 (1,88)	1,35 (1,88)	1,40 (1,88)	1,35 (1,88)	1,40 (1,88)	1,40 (1,88)	1,35 (1,88)	1,40 (1,88)	1,40 (1,88)	1,40 (1,88)	15,97 (1,82)
" (II)	H	1,400	1,04 (1,40)	0,94 (1,40)	1,04 (1,40)	1,01 (1,40)	1,04 (1,40)	1,01 (1,40)	1,04 (1,40)	1,01 (1,40)	1,01 (1,40)	1,01 (1,40)	1,01 (1,40)	1,01 (1,40)	11,42 (1,30)
Latacunga	T	813	0,59 (0,79)	0,53 (0,79)	0,59 (0,79)	0,57 (0,79)	0,59 (0,79)	0,57 (0,79)	0,59 (0,79)	0,59 (0,79)	0,57 (0,79)	0,59 (0,79)	0,57 (0,79)	0,59 (0,79)	6,94 (0,79)
Salcedo	T	325	0,23 (0,32)	0,21 (0,32)	0,23 (0,32)	2,74 (0,32)									
Sub-total		5,338	3,24 (4,36)	2,77 (4,13)	3,26 (4,39)	3,16 (4,39)	3,26 (4,39)	3,16 (4,39)	3,26 (4,39)	3,16 (4,39)	3,26 (4,39)	3,26 (4,39)	3,26 (4,39)	3,26 (4,39)	37,07 (4,23)

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (3 - 6)

		Unit : GWh (MW)												
		Installed Capacity (kW)												
Sistema		1	2	3	4	5	6	7	8	9	10	11	12	Total
(Ambato)														
La Peninsula	H	3,000	1.49	1.25	1.94	1.85	1.21	1.79	2.23	2.15	2.13	1.04	0.82	19.13
Miraflores	H	1,128	0.74	0.67	0.74	0.86	0.89	0.86	0.89	0.74	0.72	0.74	0.10	(2.18)
El Batan	T	3,900	2.17	1.96	2.17	2.10	2.17	2.10	2.17	2.10	2.17	2.10	2.17	25.55
Sub-total		7,128	4.40	3.88	4.85	4.81	4.27	4.75	5.29	5.06	4.05	5.04	3.86	53.99
(Riobamba)														
Alao	I	5,300	3.91	3.53	2.33	2.20	3.91	3.78	3.91	3.78	3.91	3.78	3.91	42.86
Guadalupe	H	458	0.22	0.20	0.22	0.21	0.22	0.21	0.22	0.21	0.22	0.21	0.22	(4.89)
Cordovez	H	680	0.45	0.40	0.45	0.43	0.45	0.43	0.45	0.43	0.45	0.43	0.45	5.27
San Luis	T	3,360	2.42	2.19	2.42	2.35	2.42	2.35	2.42	2.35	2.42	2.35	2.42	28.53
Guamote	T	360	0.26	0.23	0.26	0.25	0.26	0.25	0.26	0.25	0.26	0.25	0.26	3.05
Sub-total		10,158	7.26	6.55	5.68	5.44	7.26	7.02	7.26	7.26	7.02	7.26	7.26	82.29
(Quarzoza)														
Rio Chimbio	H	650	0.45	0.40	0.45	0.43	0.45	0.43	0.45	0.37	0.36	0.45	0.43	5.12
Chilcaes	T	775	0.56	0.51	0.56	0.54	0.56	0.54	0.56	0.54	0.56	0.54	0.56	(0.58)
Sub-total		1,425	1.01	0.91	1.01	0.97	1.01	0.97	1.01	0.98	0.98	1.01	0.97	11.71

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (4 - 6)

		Installed Capacity (kW)										GWh	
		Unit : (MW)											
(Puerto Prímo)		1 2 3 4 5 6 7 8 9 10 11 12 Total											
Puerto Prímo	H	100	0.06 (0.06)	0.05 (0.07)	0.06 (0.08)								
Puerto Prímo	T	336	0.26 (0.35)	0.23 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.25 (0.35)	0.25 (0.35)	0.26 (0.35)
Sub-total		456	0.32 (0.43)	0.28 (0.42)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)
Total		24,505	16.23 (21.81)	14.39 (21.43)	15.12 (20.32)	14.69 (20.33)	16.12 (21.60)	16.21 (22.44)	17.14 (22.97)	15.99 (21.50)	15.44 (21.44)	16.89 (22.70)	15.58 (20.85)
(4) Centro Sur													138.82 (21.54)
Samilia	H	6,450	3.86 (5.19)	3.96 (5.89)	4.39 (5.90)	4.60 (6.39)	4.69 (6.30)	4.61 (6.40)	4.69 (6.30)	4.61 (6.20)	4.25 (5.90)	4.61 (6.20)	4.03 (5.60)
Monay	I	4,590	3.25 (4.37)	2.93 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)
Enco	T	3,054	2.20 (2.96)	1.99 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.20 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)
Guapan	T	2,503	1.81 (2.43)	1.63 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)
Azogues	T	766	0.55 (0.74)	0.50 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.55 (0.74)
Total		17,252	11.67 (15.69)	11.01 (16.39)	12.20 (16.40)	12.15 (16.89)	12.50 (16.80)	12.16 (16.90)	12.50 (16.80)	12.42 (16.70)	11.80 (16.40)	12.42 (16.70)	11.58 (16.10)
(5) Sur													143.87 (16.43)
San Francisco	H	2,400	1.78 (2.39)	1.61 (2.49)	1.78 (2.39)	1.72 (2.39)	1.78 (2.39)	1.37 (1.90)	1.41 (1.90)	1.04 (1.40)	1.72 (2.39)	1.72 (2.39)	1.78 (2.39)
Loja	T	1,266	0.92 (1.23)	0.83 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)
Catamayo	T	1,140	0.82 (1.10)	0.74 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)
Total		4,806	3.52 (4.72)	3.18 (4.73)	3.52 (4.72)	3.40 (4.72)	3.52 (4.72)	3.05 (4.23)	3.15 (4.23)	2.78 (3.73)	3.40 (4.72)	3.52 (4.72)	3.40 (4.72)

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (5 - 6)

Unit: GWh (MW)															
Sistema	Capacity (kW)	Installed	1	2	3	4	5	6	7	8	9	10	11	12	Total
(6) Esmeraldas															
Santa Barbara I T	4,020	2.90 (3.90)	2.62 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	34.16 (3.90)	
Quinindé I T	190	0.13 (0.18)	0.12 (0.18)	0.13 (0.18)	1.55 (0.18)										
Limones T	285	0.21 (0.28)	0.19 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	2.46 (0.28)	
San Lorenzo T	240	0.17 (0.23)	0.15 (0.23)	0.17 (0.23)	2.02 (0.23)										
Muisne T	125	0.09 (0.12)	0.08 (0.12)	0.09 (0.12)	1.07 (0.12)										
Total	4,860	3.50 (4.71)	3.16 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.50 (4.71)	3.50 (4.71)	3.50 (4.71)	3.50 (4.71)	3.50 (4.71)	41.26 (4.71)	
(7) Manabí															
Monta T	20,600	14.87 (19.98)	13.43 (19.98)	14.87 (19.98)	14.39 (19.98)	175.08 (19.98)									
Total	20,600	14.87 (19.98)	13.43 (19.98)	14.87 (19.98)	14.39 (19.98)	175.08 (19.98)									
(8) Guayas-Los Ríos															
(Guayaquil) EMELEC T	3,050	2.20 (2.96)	1.99 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.20 (2.96)	25.91 (2.96)	
T	63,000	45.47 (61.11)	41.07 (61.11)	44.00 (61.11)	45.47 (61.11)	535.36 (61.11)									
T	55,500	40.06 (53.84)	36.18 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	40.06 (53.84)	471.64 (53.84)	
Sub-total	121,550	87.73 (117.91)	79.24 (117.91)	87.73 (117.91)	84.89 (117.91)	1,032.91 (117.91)									

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (6 - 6)

Sistema	Installed Capacity (kW)	Unit : GWh (MW)											
		1	2	3	4	5	6	7	8	9	10	11	12
(Durán)	T 4,590	3.31 (4.45)	2.99 (4.45)	3.31 (4.45)	3.20 (4.45)								
(Santa Elena Salinas)	T 4,740	3.42 (4.60)	3.09 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	3.20 (4.60)
(Santa Elena Playas)	T 500	0.36 (0.49)	0.33 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)
(Milagro)	T 6,640	4.79 (6.44)	4.33 (6.44)	4.79 (6.44)	4.64 (6.44)								
(Babahoyo)	T 2,240	1.61 (2.17)	1.46 (2.17)	1.61 (2.17)	1.56 (2.17)								
(Querevedo)	T 2,766	1.99 (2.68)	1.80 (2.68)	1.99 (2.68)	1.93 (2.68)								
Sub-total	21,476	15.48 (20.83)	14.00 (20.83)	15.48 (20.83)	14.99 (20.83)	15.48 (20.83)	14.99 (20.83)	15.48 (20.83)	14.99 (20.83)	15.48 (20.83)	14.99 (20.83)	15.48 (20.83)	15.48 (20.83)
Total	143,026	103.21 (138.74)	93.24 (138.74)	103.21 (138.74)	99.88 (138.74)								
(9) Sistema El Oro													
Machala I	T 6,432	4.64 (6.24)	4.19 (6.24)	4.64 (6.24)	4.49 (6.24)								
La Calera	H 1,266	0.72 (0.96)	0.83 (0.96)	0.92 (1.23)	0.89 (1.23)								
Amalilla	H 672	0.37 (0.50)	0.44 (0.65)	0.48 (0.65)	0.47 (0.65)								
La Cueva	H 296	0.17 (0.23)	0.19 (0.29)	0.23 (0.29)	0.21 (0.29)	0.22 (0.29)	0.21 (0.29)	0.22 (0.29)	0.21 (0.29)	0.22 (0.29)	0.21 (0.29)	0.22 (0.29)	0.21 (0.29)
Total	8,666	5.90 (7.93)	5.65 (8.41)	6.06 (8.41)	6.06 (8.41)	6.26 (8.41)	6.06 (8.41)	6.26 (8.41)	6.06 (8.41)	6.26 (8.41)	6.06 (8.41)	6.26 (8.41)	6.06 (8.41)

Note : H : Hydro power plants
T : Thermal power plants

Figure in parenthesis indicate average output of the power plants.

APPENDIX

A-3 Estimated Generating Energy Cost by Diesel Power Plants

Table A-3

(1)	Sistema Centro-Sur	A-52
(2)	Sistema Manabi	A-53
(3)	Sistema Esmeraldas	A-54
(4)	Sistema Santa Elena (Guayas-Los Ríos)	A-55
(5)	Sistema Babahoyo (Guayas-Los Ríos)	A-56
(6)	Sistema El Oro	A-57
(7)	Sistema Sur (Loja)	A-58

Table A-3-(1) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Centro-Sur

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	105.34	117.27	143.83	157.07	172.13	189.20	208.37	
Peak Load	MW	27.57	31.21	38.56	42.04	45.96	50.45	55.54	
1.25 x Peak	MW	34.46	39.01	48.19	52.54	57.46	63.07	69.42	
Installed Capacity	MW								
3.00 MW Units (US\$500/kW)		35.00	35.00	35.00	35.00	35.00	35.00	35.00	
5.00 MW Units (US\$460/kW)		-	19.00	20.00	20.00	20.00	20.00	20.00	
10.00 MW Units (US\$450/kW)		35.00	45.00	55.00	55.00	55.00	65.00	75.00	
Total									
Capital Recovery Factor	i = 10.5 %	0.1215							
Fixed Cost	Amortization (10 ³ US\$)	1,956	2,503	3,050	3,050	3,597	3,597	4,144	
	Fuel Cost (10 ³ US\$)	1,459	1,624	1,992	2,175	2,384	2,620	2,886	
	Lub Oil Cost (10 ³ US\$)	141.5	157.6	193.3	211.1	231.3	254.3	280.1	
Variable Cost	Number of Persons	(45)	(50)	(55)	(55)	(60)	(60)	(65)	
	Salaries (10 ³ US\$)	180	200	220	220	240	240	260	
	Repair (10 ³ US\$)	378.4	484.2	589.9	589.9	695.8	695.8	801.4	
	Maintenance (10 ³ US\$)								
	Sub-total	2,158.9	2,465.8	2,995.2	3,196.0	3,551.1	3,810.1	4,227.5	
Administrative Cost	(10 ³ US\$)	32.2	41.2	50.2	50.2	59.2	59.2	68.2	
Total Annual Cost	(10 ³ US\$)	4,147.1	5,010.0	6,095.4	6,296.2	7,207.3	7,407.1	8,433.7	
Generating Cost at sending end (mills/kWh)		39.37	42.7	42.4	40.1	41.9	39.1	40.5	

Note : Bunker C Oil : 240 g/kWh Lubricating Oil : 4g/GWh Bunker C Oil : US\$7.5/ton

Table A-3-(2) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Manabi

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	96.59	110.00	128.75	143.47	158.89	175.27	192.84	
Peak Load	MW	23.72	26.80	30.74	34.79	38.14	42.22	46.59	
1.25 x Peak	MW	29.65	33.50	38.43	43.49	47.67	52.77	58.24	
Existing Installed Capacity	MW								
3.00 MW Units (US\$430/kW)		30.00	35.00	35.00	35.00	35.00	35.00	35.00	
5.00 MW Units (US\$400/kW)		-	-	10.00	20.00	20.00	20.00	20.00	
10.00 MW Units (US\$390/kW)		-	-	-	-	-	-	30.00	
Total		30.00	35.00	45.00	55.00	55.00	55.00	65.00	
Capital Recovery factor	i = 10.5 %	0.1215							
Fixed Amortization (10 ³ US\$)		1,458	1,701	2,175	2,175	2,649	2,649	3,123	
Fuel Cost (10 ³ US\$)		1,098.8	1,251.3	1,464.7	1,632.1	1,807.5	1,993.8	2,193.7	
Lub Oil Cost (10 ³ US\$)		129.8	147.8	173.0	192.8	213.5	235.6	259.2	
Variable Cost	Number of Persons	(40)	(40)	(45)	(45)	(50)	(50)	(55)	
	Salaries (10 ³ US\$)	160	160	180	180	200	200	220	
	Repair (10 ³ US\$)	282	329	421	421	512	512	604	
	Maintenance (10 ³ US\$)								
Sub-total	(10 ³ US\$)	1,670.6	1,883.1	2,238.7	2,425.9	2,733.0	2,941.4	3,276.9	
Administrative Cost	(10 ³ US\$)	24.0	28.0	35.8	35.8	43.6	43.6	51.4	
Total Annual Cost	(10 ³ US\$)	3,152.6	3,617.1	4,449.5	4,636.7	5,425.6	5,624.0	6,451.3	
Generating Cost at sending end (mills/kWh)		32.6	32.9	34.6	32.3	34.1	32.1	33.5	

Table A-3-(3) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Esmeraldas

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	38.21	45.16	66.74	76.41	87.27	98.99	118.09	
Peak Load	MW	9.06	10.64	14.27	16.81	19.54	22.19	26.23	
1.25 x Peak	MW	11.33	13.30	17.84	21.01	24.42	27.74	32.79	
Existing Installed Capacity	MW								
3.00 MW Unit (US\$430/kW)		9.00	9.00	9.00	9.00	9.00	9.00	9.00	
5.00 MW Unit (US\$400/kW)		5.00	5.00	10.00	15.00	15.00	20.00	25.00	
Total		14.00	14.00	19.00	24.00	24.00	29.00	34.00	
Generating energy by 3.00 MW Diesel Units									
" 5.00 MW "		11.93	5.74	13.18	10.71	8.43	7.01	12.97	
" 26.28		39.42	53.56	65.70	78.84	78.84	78.84	105.12	
Capital Recovery factor	i = 10.5 %	0.1215							
Fixed Cost	Amortization (10 ³ US\$)	713.2	713.2	956.2	1,199.2	1,199.2	1,442.2	1,685.2	
Fuel Cost	(10 ³ US\$)	D=296.3 (C=299.0)	D=142.5 (C=448.4)	D=227.6 (C=597.9)	D=266.1 (C=747.4)	D=209.6 (C=896.9)	D=174.2 (C=1,035.0)	D=322.4 (C=1,195.8)	
Lub Oil Cost	(10 ³ US\$)	595.3	590.9	925.5	1,013.5	1,106.5	1,209.2	1,518.2	
Variable Cost	Number of Persons	(35)	(35)	(40)	(40)	(40)	(40)	(40)	
	Salaries	(10 ³ US\$)	140	140	160	160	160	160	160
	Repair	(10 ³ US\$)							
	Maintenance	(10 ³ US\$)	136	136	183	230	230	277	324
Sub-total		922.7	927.6	1,358.2	1,506.2	1,613.8	1,779.2	2,160.9	
Administrative Cost	(10 ³ US\$)	11.7	11.7	15.7	19.7	19.7	23.7	27.7	
Total Annual Cost	(10 ³ US\$)	1,647.6	1,632.5	2,330.1	2,725.1	2,832.7	3,245.1	3,873.8	
Generating Cost at sending end (mills/kWh)		43.1	36.6	34.9	35.7	32.5	32.8	32.8	

Note :
 Beaker C Oil : 240 gr/kWh Lubricating Oil : 4 gr/kWh Diesel Oil : US\$105.3/ton
 Diesel Oil : 236 gr/kWh Bunker C Oil : US\$47.4/ton

Table A-3-(4) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Santa Elena (Guayas-Los Ríos)

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	41.30	67.91	79.88	85.13	90.36	100.00	106.21	
Peak Load	MW	11.24	15.75	18.23	19.43	20.56	22.72	23.97	
1.25 x Peak	MW	14.05	19.69	22.79	24.28	25.69	28.40	29.96	
Installed Capacity									
3.00 MW Unit (US\$430/kW)		12.00	12.00	12.00	12.00	12.00	12.00	12.00	
5.00 MW Unit (US\$490/kW)		5.00	10.00	15.00	15.00	15.00	20.00	20.00	
Total		17.00	22.00	27.00	27.00	27.00	32.00	32.00	
Generating energy by 3.00 MW Diesel Units									
" " 5.00 MW "									
Capital Recovery factor $i = 10.5\%$		0.1215							
Fixed Amortization (10 ³ US\$)		870.	1,113	1,356	1,356	1,356	1,599	1,599	
Cost:									
Fuel Cost	(10 ³ US\$)	(D=373.2) (C=299.0)	(D=381.4) (C=597.9)	(D=352.5) (C=747.4)	(D=156.4) (C=396.9)	(D=286.3) (C=396.9)	D= 199.3 (C=1,046.4)	D= 353.7 (C=1,046.4)	
Lub Oil Cost	(10 ³ US\$)	672.2	979.3	1,099.9	1,053.3	1,183.2	1,245.7	1,400.1	
Variable Cost									
Salaries	(10 ³ US\$)	140	160	160	160	160	160	160	
Repair	(10 ³ US\$) } Maintenance	168	215	262	262	262	309	309	
Sub-total	(10 ³ US\$)	1,035.7	1,445.6	1,629.3	1,889.7	1,726.6	1,849.1	2,011.8	
Administrative Cost	(10 ³ US\$)	14.3	18.3	22.3	22.3	22.3	26.3	26.3	
Total Annual Cost	(10 ³ US\$)	1,920.0	2,576.9	3,007.6	2,968.0	3,104.9	3,474.4	3,637.1	
Generating Cost at sending end (mills/kWh)		46.5	37.9	37.6	34.9	34.4	34.7	34.2	

Note : Bunker C Oil : 240 gr/kWh Lubricating Oil : 4 gr/kWh Diesel Oil : US\$106.3/cwt
 Diesel Oil : 236 gr/kWh Bunker C Oil : US\$47.4/cwt

Table A-3-(5) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Babahoyo (Guayas-Los Rios)

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	60.46	70.09	80.94	90.40	100.69	111.76	123.85	
Peak Load	MW	15.33	17.85	20.60	23.02	25.51	28.20	30.98	
1.25 x Peak	MW	19.16	22.31	25.75	28.78	31.96	35.25	38.73	
Installed Capacity	MW								
3.00 MW Unit	(US\$430/kW)	9.00	9.00	9.00	9.00	9.00	9.30	9.00	
5.00 MW Unit	(US\$400/kW)	10.00	15.00	20.00	20.00	25.00	30.00	30.00	
Total		19.00	24.00	29.00	29.00	34.00	39.00	39.00	
Capital Recovery factor	i = 10.5 %	0.1215							
Fixed Cost	Autorization (10 ³ US\$)	956	1,199	1,442	1,442	1,685	1,928	1,928	
Fuel Cost	(10 ³ US\$)	760	881	1,017	1,137	1,266	1,406	1,558	
Lub Oil Cost	(10 ³ US\$)	81.3	94.2	108.8	121.5	135.3	150.2	166.5	
Variable Cost	Number of Persons	(40)	(40)	(40)	(40)	(45)	(45)	(45)	
	Salaries (10 ³ US\$)	160	160	160	160	180	180	180	
	Repair (10 ³ US\$) }	184.9	231.9	278.9	278.9	325.9	372.9	372.9	
Maintenance (10 ³ US\$)	Sub-total (10 ³ US\$)	1,186.2	1,367.1	1,564.7	1,697.4	1,907.2	2,109.1	2,277.4	
Administrative Cost (10 ³ US\$)	15.7	19.7	23.7	23.7	27.7	31.7	31.7	31.7	
Total Annual Cost (10 ³ US\$)	2,157.9	2,585.8	3,030.4	3,163.1	3,619.9	4,068.8	4,237.1		
Generating Cost at sending end (mills/kWh)		35.7	36.7	37.4	35.0	35.9	36.4	34.2	

Note : Bunker C Oil : 240 g/kWh Lubricating Oil : 4 g/kWh
Bunker C Oil : US\$52.4/ton

Table A-3-(6) Estimated Generating Energy Cost by Diesel Power Plants in Sistema El Oro

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	49.75	56.08	63.03	71.32	80.76	91.37	103.34	
Peak Load	MW	14.56	16.10	17.80	19.84	22.12	24.62	27.40	
1.25 x Peak	MW	18.20	20.13	22.25	24.80	27.65	30.77	34.26	
Installed Capacity	MW								
3.00 MW Unit (US\$430/kW)		12.00	12.00	12.00	12.00	12.00	12.00	12.00	
3.00 MW Unit (US\$400/kW)		10.00	10.00	10.00	10.00	15.00	20.00	25.00	
Total		22.00	22.00	22.00	22.00	27.00	32.00	37.00	
Generating energy by 3.00 MW Units		10.33	3.52	10.47	5.62	25.06	12.53	11.36	
" " 5.00 MW Units		39.42	52.56	52.56	65.70	65.70	78.84	91.98	
Capital Recovery factor	i = 10.5 %								
Fixed Cost	Amortization (10 ³ US\$)	1,113	1,113	1,113	1,356	1,356	1,599	1,842	
	(D=236.6) (D= 87.5) (D=280.1) (D=399.6) (D=374.2) (D=311.3)								
	(C=448.4) (C=597.9) (C=597.9) (C=397.9) (C=747.4) (C=396.9) (D= 282.2)								
Fuel Cost	(10 ³ US\$)	705.0	685.4	888.0	887.0	1,121.6	1,208.2	1,328.6	
Lub Oil Cost	(10 ³ US\$)	66.9	75.4	84.7	95.8	108.5	122.8	138.9	
Variable Cost	Number of Persons	(40)	(40)	(40)	(40)	(40)	(40)	(45)	
	Salaries (10 ³ US\$)	160	160	160	160	160	160	180	
	Repair (10 ³ US\$)	2.5	2.5	2.5	2.5	2.5	2.5	2.5	
	Maintenance (10 ³ US\$)								
Sub-total	(10 ³ US\$)	1,146.9	1,135.8	1,317.7	1,404.8	1,632.1	1,800.0	2,003.5	
Administrative Cost	(10 ³ US\$)	16.3	18.3	18.3	22.3	22.3	26.3	30.3	
Total Actual Cost	(10 ³ US\$)	2,278.2	2,267.1	2,449.0	2,783.1	3,030.4	3,425.3	3,875.8	
Generating Cost at sending end (mills/kWh)		45.8	40.4	38.9	39.0	37.5	37.5	37.5	

Table A-3-(7) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Sur (Loja)

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	Gwh	27.82	35.90	44.23	52.30	62.12	72.10	82.71	
Peak Load	MW	8.33	10.60	12.78	14.92	17.51	19.97	22.55	
1.25 x Peak	MW	10.42	13.25	15.97	18.65	21.89	24.97	28.19	
Installed Capacity	MW								
3.00 MW Unit (US\$480/kW)		12.00	12.00	12.00	12.00		12.00	12.00	
5.00 MW Unit (US\$440/kW)		-	15.00	5.00	10.00		15.00	20.00	
Total		12.00	17.00	17.00	22.00		27.00	32.00	
Generating energy by 3.00 MW Diesel Units									
..		-	9.62	17.95	12.88		6.40	3.87	
5.00 MW ..		-	26.28	26.28	39.42		65.70	78.84	
Capital Recovery factor	i = 10.5 %	0.1215							
Fixed Cost	Amortization (10 ³ US\$)	670	937	937	1,204	1,204	1,421	1,738	
Fuel Cost	(10 ³ US\$)	737.5	593.1	D=225.2 (C=337.9)	D=341.6 (C=506.9)	D=253.6 (C=375.9)	D=169.8 (C=244.9)	D= 102.7 (C=1,013.9)	
Lab Oil Cost	(10 ³ US\$)	37.4	48.2	59.4	70.3	83.5	96.9	111.1	
Variable Cost	Number of Persons	(30)	(35)	(35)	(40)	(40)	(40)	(40)	
	Salaries (10 ³ US\$)	120	140	140	160	160	160	160	
	Repair (10 ³ US\$)	135	187	187	239	239	291	343	
	Maintenance (10 ³ US\$) }								
	Sub-total	1,029	968.3	1,200.5	1,317.8	1,412.0	1,562.6	1,730.7	
Administrative Cost	(10 ³ US\$)	11.5	15.9	15.9	20.3	20.3	24.7	29.1	
Total Annual Cost	(10 ³ US\$)	1,711.4	1,921.2	2,153.4	2,542.1	2,636.3	3,058.3	3,497.8	
Generating Cost at sending end (mills/kWh)		61.5	\$3.5	48.7	48.6	42.4	42.4	42.3	

Note : Bunker C Oil : 240 g/kWh Lubricating Oil : 4 gr/kWh Diesel Oil : US\$112.4/ton
 Diesel Oil : 236 g/kWh Bunker C Oil : US\$54.5/ton D : Diesel Oil C : Bunker C Oil

APPENDIX

A-4 Hydro Power Plants to be Installed in and after 1985.

Table A-4

(1) Economic Comparison of Zamora, Sabanilla Projects	A-63
(2) Zamora No. 1 Project (1st stage)	A-64
(3) Zamora No. 1 Project (2nd stage)	A-66
(4) Zamora No. 2 Project	A-68
(5) Zamora No. 3 Project	A-70
(6) Sabanilla Project	A-72
(7) Economic Comparison of Guayllabamba Projects	A-80
(8) Guayllabamba No. 1 Project	A-81
(9) Guayllabamba No. 2 Project	A-83
(10) Guayllabamba No. 3 Project	A-85
(11) Economic Comparison of Chimbo, and Pangor Projects	A-92
(12) Chimbo No. 1 Project	A-93
(13) Chimbo No. 2 Project	A-95
(14) Pangor No. 1 Project	A-97
(15) Pangor No. 2 Project	A-99

Fig. A-4

- (1) Zamora, Sabanilla Project (1 - 2) A-74
- (2) Zamora, Sabanilla Project (2 - 2) A-75
- (3) Zamora No. 1 Hydro Electric Power Project A-76
- (4) Zamora No. 2, No. 3, Hydro Electric Power Projects A-77
- (5) Sabanilla Hydro Electric Power Project A-78
- (6) Guayllabamba Project (1 - 2) A-87
- (7) Guayllabamba Project (2 - 2) A-88
- (8) Guayllabamba No. 1, No. 2, Hydro Electric Power Projects A-89
- (9) Guayllabamba No. 3 Hydro Electric Power Project A-90
- (10) Chimbo, Pangor Project (1 - 2) A-101
- (11) Chimbo, Pangor Project (2 - 2) A-102
- (12) Chimbo No. 1, No. 2 Hydro Electric Power Projects A-103
- (13) Pangor No. 1, No. 2 Hydro Electric Power Projects A-104

A-4 Hydroelectric Power Project after 1985

A-4-1 Hydroelectric Power Projects under Study

INECEL has been proceeding with investigations on nine sites in order to study the technical and economic feasibilities of hydroelectric projects which should be developed in the future. The states of the major projects studied are as described below.

(1) Paute Hydroelectric Project, Second Stage, 500 MW

The Second Stage of the Project is included in the feasibility study for Paute Project as a whole, and is the expansion work to follow the First Stage of the Project.

(2) Toachi Hydroelectric Project, 350 MW

The feasibility study for the Project was completed in September 1974, and site investigations to perform the detail design of the Project are presently being carried out.

(3) Montufar Hydroelectric Project, 150 MW

A feasibility study for the Project was finished in 1974, and additional investigation work is being carried out on the damsite.

(4) Coca Hydroelectric Project, 3,200 MW

A feasibility study is scheduled to be carried out soon for this project. A loan from IDB is already definite in regard to the funds necessary for the study.

(5) Jubones Hydroelectric Project (Comprehensive Development), 380 MW

A feasibility study on the Project is presently being conducted jointly with INERHI.

(6) Chimbo-Pangor Hydroelectric Project, 419 MW

A feasibility study is scheduled to be started soon for this project. The consulting firm has already been selected.

(7) Zamora-Sabanilla Hydroelectric Project, 325 MW

A prefeasibility study on the Project has already been completed and a feasibility study is scheduled to be started soon.

(8) Guayllabamba Hydroelectric Project, 740 MW

A preliminary study is presently being conducted for the Project.

Preparation of basic data and geological surveys are mainly being carried out.

In connection with the projects listed above, studies are presently being carried out on (1) to (5) under contracts by foreign consulting firms. Therefore, the Mission examined the three sites of (6) to (8), namely, Chimbo-Pangor, Guayllabamba, and Zamora-Sabanilla which are at the preliminary study stage. The results of the examinations are described below.

A-4-2 Projects Studied by the Mission

(1) Zamora-Sabanilla Hydroelectric Project

This project would be for construction of hydroelectric power stations on the Rio Zamora located 45 km northeast to the city of Loja, which has a V-shaped valley and a swift stream of an annual average discharge of 48.8 m³/sec. The swift part of the river is from the Loja Basin (El. 2,000 m) to an elevation of 980 m and the optimum plan will be to divide this head of 1,020 m into three steps and utilize them for electric power development. It will be possible to construct three power stations of 70 MW, 65 MW and 325 MW from the upstream side, while at the farthest downstream power station an additional 325 MW can be developed.

The particulars of the project are as indicated in Tables A-4-(2) to (6).

Of these power station sites, the No. 1 site for 325 MW (First Stage) located farthest downstream will be the easiest to develop viewed from the conditions of location. The sites for both dam and power station of the No. 1 project are located along an existing road going from Loja to Zamora, and it will be possible to develop 325 MW utilizing a maximum discharge of 60 m³/sec, a tunnel of 9.6 km, a tailrace tunnel of 4 km, and head of 700 m.

The reservoir would have an effective storage capacity of 46×10^6 m³, and judging by the discharge duration, it will be possible to regulate dry season discharge of 23.5 m³/sec to an average of 29.3 m³/sec. Further, if plant factor of 50% were to be assumed, the maximum discharge would be 60 m³/sec.

The annual energy production of this power station would be 1,411.6 GWh of primary energy and 837.8 GWh of secondary energy for a total of 2,249.4 GWh. The funds required for construction would be 224 US million dollars amounting to unit cost of 689.2 US dollars per kW and 0.16 US dollars per kWh of primary energy. Taking the annual rate of the power station to be 12% of the construction cost, the energy cost will be 19.2 mills/kWh. This energy cost is low for the hydroelectric projects presently being studied in Ecuador, and this site will be the most promising when seeking a hydroelectric site in the southern part of Ecuador in the future.

In the event of development of the Rio Zamora at an early date as a supply capacity for the Sur System, it will be the most economical to utilize Sabanilla Project only and the scale in that case will be 32 MW. The construction cost would be 26.5 US million dollars which amounts to a unit cost of 0.095 US dollars per kWh.

and the energy cost will be 11.4 mills/kWh. This power station can generate the 32 MW throughout the year and in case loads were to be met combined with a diesel thermal plant, this power station would carry the base load and the diesel plant would supply the peak load.

In order to proceed with development of the Second Stage of Zamora Project having capacity of 325 MW, it will be necessary for seasonal regulation with water storage upstream. For this purpose, a dam having height of 105 m should be constructed upstream of the reservoir of Zamora No. 1 power station to provide effective storage of 280×10^6 m³, of Zamora Power Station. Also, utilizing the head provided by this dam, it will be possible to construct a power station of 65 MW immediately downstream of the dam.

Table A-4-(I) Economic Comparison of Zamora, and Sabanilla Projects

	Zamora No. 1 1st stage	Sabanilla	Zamora No. 2	Zamora No. 1 2nd stage	Total
Installed capacity (MW)	325.0	32.0	65.0	325.0	747.0
Firm energy (GWh)	1,411.6	279.9	185.0	984.9	2,861.4
Construction cost (10^6 US\$)	224.0	26.5	101.0	139.0	490.5
Construction cost per kW (US\$)	689.2	828.1	1,553.8	427.7	656.6
Construction cost per kWh (US\$)	0.159	0.095	0.546	0.141	0.171
Unit cost per kWh (US\$) 1/	0.019	0.011	0.065	0.067	0.021

1/ : Annual cost ratio 12%

Table A-4-(2) Zamora No. 1 Project (1st stage)

Location :	Zamora, Chinchipe	Monthly river inflow		
River :	Zamora	Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Type of power plant :	Dam-Waterway (Reservoir)			
Installed capacity :	325.0 MW	1	58.5	199.3
Catchment area :	1,173.0 km ²	2	42.3	158.6
Annual average river inflow :	48.8 m ³ /s	3	49.0	203.3
Total storage capacity :	65.0×10^6 m ³	4	56.2	225.8
Effective storage capacity :	46.0×10^6 m ³	5	46.2	191.8
Maximum discharge :	60.0 m ³ /s	6	56.0	224.7
Total head :	700.0 m	7	80.5	241.8
Intake level :	1,680.0 m	8	66.6	241.8
Discharge level :	980.0 m	9	46.3	185.7
Effective head :	660.0 m	10	32.6	135.4
Annual generating energy :	2,249.4 GWh	11	23.5	121.3
Firm power :	159.9 MW	12	26.8	119.9
Firm energy :	1,411.6 GWh	Total		2,249.4
Estimated construction cost :	US\$ 224.0×10^6	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Unit cost per kW :	US\$ 689.2/kW			
Unit cost per kWh :	US\$ 0.10/kWh			
Construction period :	66 months			

Zamora No. 1 Project (1st stage)

(Principal characteristics and dimensions)

Dam	Type : Rockfill Height : 150 m Crest length : 320 m Volume : $7 \times 10^6 \text{ m}^3$ Flood discharge : $1,860 \text{ m}^3/\text{s}$	High water level : 1,700 m Low water level : 1,650 m Available head : 50 m Elevation on riverbed : 1,560 m Dam crest/dam height = 2.13 Effective storage capacity : $46 \times 10^6 \text{ m}^3$ Duration capacity : 8.9 days (Effective capacity/Max. discharge)	
Intake	Type : Max. intake flow : $60 \text{ m}^3/\text{s}$		
Tunnel	Pressure tunnel Length : 9,600 m Section : 5.0 m	Surge tank Type : restricted-orifice Height : 100 m Section: 10 m	
Branch tunnel	Length : 5,100 m, Intake capacity : $20 \text{ m}^3/\text{s}$	Penstock Number of penstock : upper part 1 lower part 3 Length : 1,000 m Total length : 1,300 m Section : 4.0 m to 1.7 m	
Power house	Type : Underground Number of generator : 3 units Dimension : Height : 43 m Width : 24 m Depth : 125 m (1st, 2nd stages)	Turbine Type : Pelton Output : $114 \text{ MW} \times 3 \text{ units}$ Generator Output : $120 \text{ MVA} \times 3 \text{ units}$	Switchyard Transformer Voltage : 230 kV Capacity : $120 \text{ MVA} \times 3 \text{ units}$
Tailrace tunnel	Type : Pressure tunnel Length : 4,000 m Section : 5.0 m		

Table A-4-(3) Zamora No. 1 Project (2nd stage)

Location :	Zamora, Chinchipe	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Zamora	1		
Type of power plant :	Dam-Waterway (Reservoir)	2		
Installed capacity :	325.0 MW	3		
Catchment area :	1,173.0 km ²	4		
Annual average river inflow :	54.8 m ³ /s	5		
Total storage capacity :	65.0×10^6 m ³	6		
Effective storage capacity :	46.0×10^6 m ³	7		
Maximum discharge :	60.0 m ³ /s	8		
Total head :	700.0 m	9		
Intake level :	1,680.0 m	10		
Discharge level :	980.0 m	11		
Effective head :	660.0 m	12		
Annual generating energy :	147.1 GWh	Total		
Firm power :	113.4 MW	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Firm energy :	981.5 GWh			
Estimated construction cost :	$US\$ 139.0 \times 10^6$			
Unit cost per kW :	US\$ 427.7/kW			
Unit cost per kWh :	US\$ 0.141/kWh			
Construction period :	60 months			

Zamora No. 1 Project (2nd stage)

(Principal characteristics and dimensions)

Dam	-
Type :	-
Height :	-
Crest length :	-
Volume :	-
Flood discharge :	-

High water level : 1,700 m
 Low water level : 1,650 m
 Available head : 50 m
 Elevation on riverbed : 1,560 m
 Dam crest/dam height = 2.13
 Effective storage capacity: $46 \cdot 10^6 \text{ m}^3$
 Duration capacity 44 days
 (Effective capacity/Max. discharge)

Tunnel	Surge tank	Penstock
Pressure tunnel	Type : restricted-orifice	Number of penstock : upper part 1 lower part 3
Length : 9,600 m Section: 5.0 m	Height : 100 m Section : 10 m	Length : 1,000 m Total length : 1,300 m Section: 4.0 m to 1.7 m
Branch tunnel Length : 5,100 m, Intake capacity : 20 m^3/s		

Power house	Turbine	Switchyard
Type : Underground Number of generator : 3 units Dimension: Height : 43 m Width : 24 m Depth : 125 m (1st, 2nd stages)	Type : Pelton Output : 114 MW $\times 3$ units Generator Output : 120 MW $\times 3$ units	Transformer Voltage : 230 kV Capacity: 120 MVA $\times 3$ units

Tailrace tunnel	Type : Pressure tunnel
Length : 4,000 m	
Section: 5.0 m	

Table A-4-(4) Zamora No. 2 Project

Location :	Zamora, Chinchipe	Monthly river inflow and generating energy		
River :	Zamora	Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Type of power plant :	Dam (Run-River)	1	34.8	12.1
Installed capacity :	65.0 MW	2	30.5	14.4
Catchment area :	890.0 km ²	3	32.4	14.7
Annual average river inflow :	32.8 m ³ /s	4	34.5	13.1
Total storage capacity :	462.0×10^6 m ³	5	31.6	15.5
Effective storage capacity :	280.0×10^6 m ³	6	35.0	13.5
Maximum discharge :	100.0 m ³ /s	7	43.3	10.9
Total head :	80.0 m	8	40.4	13.8
Intake level :	1,790.0 m	9	31.5	16.8
Discharge level :	1,710.0 m	10	27.7	20.0
Effective head :	76.0 m	11	25.2	20.8
Annual generating energy :	185.0 GWh	12	25.9	19.4
Firm energy :	128. GWh	Total		185.0

Estimated construction cost : US\$ 101.0×10^6

Unit cost per kW : US\$ 1,553.8/kW

Unit cost per kWh : US\$ 0.546/kWh

Construction period : 66 months

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Zamora No. 2 Project

(Principal characteristics and dimensions)

Dam

Type : Rockfill
 Height : 105 m
 Crest length : 390 m
 Volume : $6.2 \times 10^6 \text{ m}^3$
 Flood discharge : $1,260 \text{ m}^3/\text{s}$

High water level : 1,800 m

Low water level : 1,760 m

Available head : 40 m

Elevation on riverbed : 1,710 m

Dam crest/dam height = 3.71

Effective storage capacity: $280 \times 10^6 \text{ m}^3$

Duration capacity : 32.4 days
 (Effective capacity/Max. discharge)

Intake Type :

Max. intake flow : $100 \text{ m}^3/\text{s}$

Tunnel

Pressure tunnel
 Length : 500 m
 Section : 5.7 m

Surge tank
 Type: restricted-orifice
 Height : 65 m
 Section: 10 m

Penstock
 Number of penstock : 1
 Length : 150 m
 Total length : 150 m
 Section : 5.7 m to 3.8 m

Branch tunnel

Length : — m, Intake capacity : — m^3/s

Power house

Type : Half underground
 Number of generator : 1 unit
 Dimension: Height : 32 m
 Width : 25 m
 Depth : 30 m

Turbine
 Type : Francis
 Output : 68.4 MW
 x 1 unit
 Generator
 Output : 72.2 MVA
 x 1 unit

Switchyard
 Transformer
 Voltage : 230 kV
 Capacity :
 72.2 MVA
 x 1 unit

Tailrace tunnel Type : —
 Length : — m
 Section : —

Table A-4-(5) Zamora No. 3 Project

Location :	Zamora, Chinchipe	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Zamora			
Type of power plant :	Dam-Waterway (Reservoir)			
Installed capacity :	70.0 MW			
Catchment area :	561.0 km ²	1	19.7	17.7
Annual average river inflow :	17.2 m ³ /s	2	14.9	16.1
Total storage capacity :	241.0×10^6 m ³	3	17.1	17.7
Effective storage capacity :	165.0×10^6 m ³	4	19.3	17.2
Maximum discharge :	50.0 m ³ /s	5	16.2	17.8
Total head :	190.0 m	6	19.9	17.3
Intake level :	1,990.0 m	7	29.0	18.2
Discharge level :	1,800.0 m	8	23.2	21.2
Effective head :	170.0 m	9	16.0	18.0
Annual generating energy :	215.3 GWh	10	11.9	18.5
Firm power :	23.1 MW	11	9.1	17.7
Firm energy :	204.7 GWh	12	9.9	17.9
Estimated construction cost : US\$ 146.6 x 10 ⁶		Total		215.3
Unit cost per kW : US\$ 2,094.3/kW				
Unit cost per kWh : US\$ 0.681/kWh				
Construction period :	60 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Zamora No. 3 Project

(Principal characteristics and dimensions)

Dam	Type : Rockfill Height : 140 m Crest length : 380 m Volume : $10 \times 10^6 \text{ m}^3$ Flood discharge : $670 \text{ m}^3/\text{s}$	High water level : 2,000 m Low water level : 1,960 m Available head : 40 m Elevation on riverbed : 1,880 m Dam crest/dam height = 2.71 Effective storage capacity : $165 \text{ } 10^6 \text{ m}^3$ Duration capacity 38.2 days (Effective capacity/Max. discharge)	
Intake	Type : Max. intake flow : $50 \text{ m}^3/\text{s}$		
Tunnel	Pressure tunnel Length : 5,300 m Section : 4.0 m	Surge tank Type : restricted-orifice Height : 80 m Section: 8 m	Penstock Number of penstock : 1 Length : 360 m Total length : 360 m Section : 4.0 m to 2.7 m
Branch tunnel	Length : — m, Intake capacity : — m^3/s		
Power house	Type : Underground Number of generator : 1 unit Dimension: Height : 40 m Width : 20 m Depth : 35 m	Turbine Type : Francis Output : 73.7 MW x 1 unit Generator Output : 77.8 MVA x 1 unit	Switchyard Transformer Voltage : 230 kV Capacity : 77.8 MVA x 1 unit
Tailrace tunnel	Type : Pressure tunnel Length : 100 m Section : 4.0 m		


Table A-4-(6) Sabanilla Project


Location :	Zamora, Chinchipe	Monthly river inflow and generating energy		
River :	Sabanilla	Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Type of power plant :	Water way (Run-of-River)			
Installed capacity :	32.0 MW	1	18.9	23.8
Catchment area:	137.0 km ²	2	12.7	21.5
Annual average river inflow :	14.1 m ³ /s	3	14.4	23.8
Total storage capacity :		4	16.3	23.0
Effective storage capacity :		5	13.8	23.8
Maximum discharge :	6.0 m ³ /s	6	15.1	23.0
Total head :	700.0 m	7	18.5	23.8
Intake level :	1,740.0 m	8	17.6	23.8
Discharge level :	1,040.0 m	9	14.1	23.0
Effective head :	660.0 m	10	10.4	23.8
Annual generating energy :	279.9 GWh	11	7.7	23.8
Firm power :	31.7 MW	12	9.2	23.8
Firm energy :	277.7 GWh	Total		279.9
Estimated construction cost :	US\$ 26.5 x 10 ⁶	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Unit cost per kW :	US\$ 828.1/kW			
Unit cost per kWh :	US\$ 0.095/kWh			
Construction period :	36 months			


Sabanilla Project


(Principal characteristics and dimensions)


Dam			
Type	:	High water level	:
Height	:	Low water level	:
Crest length	:	Available head	:
Volume	:	Elevation on riverbed	:
Flood discharge	:	Dam crest/dam height	—
Intake Type :		Effective storage capacity : —	
Max. intake flow : 6.0 m ³ /s		Duration capacity — (Effective capacity/Max. discharge)	
Tunnel			
Non-Pressure tunnel		Surge tank	
Length	: 5,000 m	Type	:
Section	: 3.10 m	Height	:
		Section	:
Branch tunnel			
Length	:	Intake capacity	:
Penstock			
Number of penstock		1	
Length		1,850 m	
Total length		1,850 m	
Section		1.6 m to 1.0 m	
Power house			
Type : Half underground		Turbine	
Number of generator : 1 unit		Type	: Pelton
Dimension : Height : 25 m		Output	: 33.7 MW x 1 unit
Width : 15 m		Generator	
Depth : 30 m		Output	: 35.6 MVA x 1 unit
Switchyard			
Transformer			
Voltage : 230 kV			
Capacity : 35.6 MVA			
x 1 unit			
Tailrace tunnel Type :			
Length	:		
Section	:		











(2) Guayllabamba Hydroelectric Project

This project would be for construction of power stations on the midstream part of the Rio Guayllabamba located 50 km northwest of Quito, Pichincha Province.

It will be optimum for this river to be developed in three steps utilizing the head of 880 m (EL. 1,550m to 670m) from the confluence of the Rio Guayllabamba mainstream and the tributary Rio Perlabi to the Rio Intag. In this case, it will be possible to develop No. 1 Power Plant, 420 MW, No. 2 Power Plant, 100 MW and No. 3 Power Plant, 220 MW in order from the upstream side for a total of 740 MW.

The particulars of the project are as indicated in Tables A-4-(7) to A-4-(10).

The No. 1 power station farthest upstream in the three-stepped development would have a dam of 185 m, a main tunnel of 7.4 km, providing a head of 565 m and making possible generation of 420 MW with maximum discharge of 100 m³/sec. The effective storage capacity provided by the dam would be 149×10^6 m³ making possible annual energy production of 1,883.5 GWh. Construction funds required for the project would be 338 US million dollars amounting to a unit cost of 804.8 US dollars per kW, 0.178 US dollars per kWh and energy cost of 22.0 mills/kWh.

This is a large-scale, moreover highly economical project which can be developed in the northern part of Ecuador, and being close to the load center of Quito, it is looked forward to being developed at an early date similarly to Paute Hydroelectric Project.

The No. 2 power station would use water discharged from the No. 1 power station and obtaining a head of 130 m conducting this water with a tunnel of 4.1 km it will be possible for power generation of 100 MW.

The No. 3 power station would consist of constructing a dam of 140 m immediately downstream of the junction of the mainstream and the Rio Alambi and a powerhouse immediately downstream of the dam to provide a maximum discharge of 240 m³/sec for a power station of maximum output of 220 MW. The annual energy production of this No. 3 power station would be 889.4 GWh while the construction cost would be 184 US million dollars. The unit costs would be 836.4 US dollars per kW and 0.207 US dollars per kWh and the energy cost is 24.8 mills/kWh.

There will be 740 MW of electric power which can be obtained from these three sites, the required construction cost will be 582 US million dollars, and the energy production will be 3,204.5 GWh. The overall generating cost would be 786.5 US dollars per kW and 0.182 US dollars per kWh and the energy cost will be 21.8 mills/kWh, provided that the annual rate of power station is 12 % of the construction cost.

Table A-4-(7) Economic Comparison of Guayllabamba Projects

	Guayllabamba No. 1	Guayllabamba No. 2	Guayllabamba No. 3	Total
Installed capacity (MW)	420.0	100.0	220.0	740.0
Firm energy (GWh)	1,435.0	340.9	606.2	2,382.1
Construction cost (106 US \$)	338.0	60.0	184.0	582.0
Construction cost per kW (US \$)	804.8	600.0	836.4	786.5
Construction cost per kWh (US \$)	0.179	0.139	0.207	0.182
Unit cost per kWh (US \$)	1/	0.021	0.017	0.022

1/ : Annual cost ratio 12%

Table A-4-(8) Guayllabamba No. 1 Project

Location :	Pichincha, Imbabura	Monthly river inflow and generating energy		
River :	Guayllabamba	Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Type of power plant :	Dam-Waterway (Reservoir)	1	47.9	162.1
Installed capacity :	420.0 MW	2	61.6	176.1
Catchment area :	4,295.0 km ²	3	62.6	192.9
Annual storage capacity :	49.5 m ³ /s	4	67.9	189.8
Total storage capacity :	214.0 x 10 ⁶ m ³	5	57.7	193.3
Effective storage capacity :	149.0 x 10 ⁶ m ³	6	48.2	154.7
Maximum discharge :	100.0 m ³ /s	7	40.2	134.7
Total head :	565.0 m	8	36.1	135.4
Intake level :	1,535.0 m	9	31.9	123.0
Discharge level :	970.0 m	10	41.3	124.9
Effective head :	520.0 m	11	54.6	150.6
Annual generating energy :	1,883.5 GWh	12	45.5	146.0
Firm power :	163.8 MW	Total		1,883.5
Firm energy :	1,435.0 GWh	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Estimated construction cost :	US\$ 338.0 x 10 ⁶			
Unit cost per kW :	US\$ 804.8/kW			
Unit cost per kWh :	0.179/kWh			
Construction period :	72 months			

Guayllabamba No. 1 Project

(Principal characteristics and dimensions)

Dam

Type : Rockfill
 Height : 185 m
 Crest length : 420 m
 Volume : $12 \times 10^6 \text{ m}^3$
 Flood discharge : $5,200 \text{ m}^3/\text{s}$

High water level : 1,550 m
 Low water level : 1,500 m
 Available head : 50 m
 Elevation on riverbed : 1,380 m
 $\text{Dam crest/dam height} = 420/185 = 2.27$
 Effective storage capacity : $149 \times 10^6 \text{ m}^3$
 Duration capacity 17.2 days
 (Effective capacity/Max. discharge)

Intake Type :

Max. intake flow : $100 \text{ m}^3/\text{s}$

Tunnel

Pressure tunnel

Length : 7,500 m
 Section : 5.0 m

Surge tank

Type : restricted orifice
 Height : 105 m
 Section : 10 m

Penstock

Number of penstock :
 upper part 2
 lower part 4
 Length : 800 m
 Total length : 1,720 m
 Section : 3.5 m to 1.8 m

Branch tunnel

Length : - Intake capacity : -

Power house

Type : Underground

Number of generator : 4 units
 Dimension : Height : 43 m
 Width : 24 m
 Depth : 92 m

Turbine

Type : Pelton
 Output : 111 MW
 x 4 units
 Generator
 Output : 117 MVA
 x 4 units

Switchyard

Transformer
 Voltage : 230 kV
 Capacity :
 117 kVA
 x 4 units

Tailrace tunnel Type : Pressure tunnel

Length : 190 m
 Section : 5.0 m

Table A-4-(9) Guayllabamba No. 2 Project

Location :	Pichincha, Imbabura Guayllabamba	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Guayllabamba			
Type of power plant :	Waterway (Run-of -River)			
Installed capacity :	100.0 MW	1	47.9	37.2
Catchment area :	4,295.0 km ²	2	61.6	40.7
Annual average river inflow :	49.5 m ³ /s	3	62.6	44.1
Total average capacity :	—	4	67.9	43.3
Effective storage capacity :	—	5	57.7	43.9
Maximum discharge :	100.0 m ³ /s	6	48.2	35.2
Total head :	130.0 m	7	40.2	30.7
Intake level :	970.0 m	8	36.1	31.0
Discharge level :	840.0 m	9	31.9	28.4
Effective head :	120.0 m	10	41.3	29.0
Annual generating energy :	431.6 GWh	11	54.6	34.6
Firm power :	38.9 MW	12	45.5	33.5
Firm energy :	340.9 GWh	Total		431.6
Estimated construction cost :	US\$60.0 x 10 ⁶			
Unit cost per kW :	US\$ 600.0/kW			
Unit cost per kWh :	US\$ 0.139/kWh			
Construction period :	48 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Guayllabamba No. 2 Project

(Principal characteristics and dimensions)

Dam		High water level :	—
Type	—	Low water level :	—
Height	—	Available head :	—
Crest length	—	Elevation on riverbed :	—
Volume	—	Dam crest/dam height =	—
Flood discharge :	—	Effective storage capacity :	—
Intake Type :		Duration capacity	—
Max. intake flow : 100 m ³ /s		(Effective capacity/Max. discharge)	
Tunnel			
Pressure tunnel		Surge tank	Penstock
Length : 4,200 m		Type : restricted-orifice	Number of penstock : 1
Section : 5.7 m		Height : 50 m	Length : 220 m
		Section: 11 m	Total length : 220 m
Branch tunnel			Section : 5.7 m to 3.7 m
Length : —	Intake capacity : —		
Power house			
Type : Half underground		Turbine	Switchyard
Number of generator : 1 unit		Type :	Transformer
Dimension : Height : 43 m		Output :	Voltage : 230 kV
Width : 25 m		x 1 unit	Capacity :
Depth : 50 m		Generator	111 MVA
		Output : 111 MVA	x 1 unit
Tailrace tunnel	Type : —		
Length : —			
Section : —			

Table A-4-(10) Guayllabamba No. 3 Project

Location :	Pichincha, Imbabura	Monthly river inflow and generating energy		
River :	Guayllabamba	Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Type of power plant :	Dam (Reservoir)	1	117.2	61.1
Installed capacity :	220.0 MW	2	157.0	70.6
Catchment area :	6,486.0 km ²	3	155.4	91.6
Annual average river inflow :	117.9 m ³ /s	4	166.7	99.9
Total storage capacity :	200.0×10^6 m ³	5	149.4	107.9
Effective storage capacity :	148.0×10^6 m ³	6	122.4	92.3
Maximum discharge :	240.0 m ³ /s	7	93.5	74.2
Total head :	115.0 m	8	77.5	66.9
Intake level :	785.0 m	9	76.4	56.9
Discharge level :	670.0 m	10	86.6	51.5
Effective head :	110.0 m	11	114.0	56.6
Annual generating energy :	889.4 GWh	12	103.4	59.9
Firm power :	69.2 MW	Total		889.4
Firm energy :	606.2 GWh			
Estimated construction cost :	US\$ 184.0×10^6			
Unit cost per kW :	US\$ 836.4/kW			
Unit cost per kWh :	US\$ 0.207/kWh			
Construction period :	54 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Guayllabamba No. 3 Project

(Principal characteristics and dimensions)

Dam

Type : Rockfill
 Height : 145 m
 Crest length : 270 m
 Volume : $4.8 \times 10^6 \text{ m}^3$
 Flood discharge : 2,300 m^3/s

High water level : 800 m
 Low water level : 750 m
 Available head : 50 m
 Elevation on riverbed : 670 m
 Dam crest/dam height = 1.93
 Effective storage capacity : $148 \times 10^6 \text{ m}^3$
 Duration capacity 7 days
 (Effective capacity/Max. discharge)

Tunnel

Pressure tunnel

Length : —
 Section : —

Surge tank

Type : —
 Height : —
 Section : —

Penstock

Number of penstock : 2
 Length : 320 m
 Total length : 640 m
 Section : 5.5 m to 3.9 m

Branch tunnel

Length : 3,100 m, Intake capacity : $20 \text{ m}^3/\text{s}$

Power house

Type : Underground
 Number of generator : 2 units
 Dimension : Height : 43 m
 Width : 25 m
 Depth : 68 m

Turbine
 Type : Francis
 Output : 116 MW
 x 2 units
 Generator
 Output : 122 MVA
 x 2 units

Switchyard
 Transformer
 Voltage : 230 kV
 Capacity :
 122 MVA
 x 2 units

Tailrace tunnel Type : Pressure tunnel

Length : 480 m 2
 Section : 5.5 m







Fig.A-4-(6)







(3) Chimbo-Pangor Hydroelectric Project

The Rio Chimbo has its fountain head on Mt. Chimborazo, flows south through the Western Andes, and joined by the tributary Rio Pangor, flows down through the Guayas Plain. In case of utilizing this river for hydroelectric power, there would be various development forms conceivable, but according to the results of field investigations it will be appropriate for the development form indicated in Table A-4-(11) to A-4-(15) to be adopted.

According to this development scheme, it will be possible to construct four power stations. Namely, with Chimbo No. 1 Power Plant, it would be possible for generation of 61 MW through effective water storage of $114 \times 10^6 \text{ m}^3$ by a dam of 155 m in the vicinity of San Miguel on the mainstream of the Rio Chimbo for seasonal regulation of runoff, maximum discharge of $15 \text{ m}^3/\text{sec}$, water conduction by a main tunnel of 12 km and head of 540 m.

Pangor No. 2 Power Plant would use the discharge of Chimbo No. 1 through a tunnel of 4.8 km and the water of the Rio Pangor through a tunnel of 7.1 km for daily regulation to a maximum discharge of $40 \text{ m}^3/\text{sec}$, and with a head of 328 m, generate 110 MW of power.

Chimbo No. 2 Power Plant would take the discharge of Pangor No. 2 and divert it to the Guayas Plain side by a main tunnel of 16.1 km to obtain a head of 800 m for generation of a maximum 230 MW.

Meanwhile, Pangor No. 1 Power Plant would utilize the head of 790 m upstream of Pangor No. 2 Power Plant and it would be possible for 17 MW to be generated.

It will become possible for a total of 419 MW to be generated with these four power stations and a total amount of 378.6 US million dollars would be required for this construction. Meanwhile, the annual energy production through these power stations would be 1,449.6 GWh and the unit costs would be 903.6 US dollars per kW and 0.26 US dollars per kWh. The energy cost would be 31.32 mills/kWh.

These power stations would be inferior in economy to Zamora-Sabanilla and Guayllabamba Projects, but are at a distance of only 80 km from the load center of Guayaquil, and consequently, it will be possible to develop them in the future. Regarding Pangor No. 1 Power Plant, although the scale is small at 17 MW, it should be developed as supply capacity for Riohamba.

Table A-4-(11) Economic Comparison of Chimbo, and Pangor Projects

	Chimbo No. 1	Chimbo No. 2	Pangor No. 1	Pangor No. 2	Total
Installed capacity (MW)	62.0	230.0	17.0	110.0	419.0
Firm energy (GWh)	271.3	605.6	48.2	252.9	1,178.0
Construction cost (10 ⁶ US\$)	135.0	145.0	24.8	73.8	378.6
Construction cost per kW (US\$)	2,177.4	630.4	1,458.8	670.9	903.6
Construction cost per kWh (US\$)	0.474	0.193	0.261	0.232	0.321
Unit cost per kWh (US\$)	1/	0.057	0.023	0.031	0.028
					0.039

1/ : Annual cost ratio 12%

Table A-4-(12) Chimbo No. 1 Project

Location :	Bolivar, Chimbaboro	Monthly river inflow and Generating energy		
River :	Chimbo	Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Type of power plant :	Dam-Waterway (Reservoir)	1	7.5	23.8
Installed capacity :	62.0 MW	2	12.5	21.6
Catchment area :	1,102.0 km ²	3	15.1	24.1
Annual average river inflow :	7.7 m ³ /s	4	15.0	23.5
Total storage capacity :	222.0×10^6 m ³	5	11.5	25.6
Effective storage capacity :	114.0×10^6 m ³	6	7.5	23.6
Maximum discharge :	15.0 m ³ /s	7	4.0	24.4
Total head :	540.0 m	8	2.7	24.3
Intake level :	2,340.0 m	9	2.7	23.3
Discharge level :	1,800.0 m	10	4.9	24.0
Effective head :	510.0 m	11	5.0	23.1
Annual generating energy :	285.1 GWh	12	4.8	23.8
Firm power :	31.0 MW	Total		285.1
Firm energy :	271.3 GWh			
Estimated construction cost :	US\$ 135.0×10^6			
Unit cost per kW :	US\$ 2,177.4/kW			
Unit cost per kWh :	US\$ 0.474/kWh			
Construction period :	60 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Chimbo No. 1 Project

(Principal characteristics and dimensions)

Dam

Type : Rockfill
 Height : 155 m
 Crest length : 420 m
 Volume : $9 \times 10^6 \text{ m}^3$
 Flood discharge : $1,320 \text{ m}^3/\text{s}$

High water level : 2,350 m
 Low water level : 2,320 m
 Available head : 30 m
 Elevation on riverbed : 2,210 m
 Dam crest/dam height : 2.71

Intake Type :

Max. intake flow : $15 \text{ m}^3/\text{s}$

Effective storage capacity : $114 \times 10^6 \text{ m}^3$
 Duration capacity 88 days
 (Effective capacity/Max. discharge)

Tunnel

Pressure tunnel
 Length : 12,200 m
 Section : 2.5 m

Surge tank
 Type : restricted-orifice
 Height : 70 m
 Section: 5 m

Penstock
 Number of penstock : 1
 Length : 1,450 m
 Total length : 1,450 m
 Section : 2.5 m to 1.5 m

Branch tunnel

Length : — Intake capacity : —

Power house

Type : Half underground
 Number of generator : 1 unit
 Dimension : Height : 35 m
 Width : 20 m
 Depth : 40 m

Turbine
 Type : Pelton
 Output : 65.3 MW
 x 1 unit
 Generator
 Output : 68.9 MVA
 x 1 unit

Switchyard
 Transformer
 Voltage : 138 kV
 Capacity :
 68.9 MVA.
 x 1 unit

Tailrace tunnel Type : —

Length : —
 Section : —

Table A-4-(13) Chimbo No. 2 Project

Location :	Bolivar, Chimborago Chimbo	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Chimbo			
Type of power plant :	Waterway (Pondage)			
Installed capacity :	230.0 MW	1	12.9	56.5
Catchment area	1,535.0 km ²	2	15.2	60.2
Annual average river inflow :	-	3	16.1	70.5
Total storage capacity :	-	4	16.7	71.0
Effective storage capacity :	-	5	18.6	81.7
Maximum discharge :	40.0 m ³ /s	6	16.8	71.2
Total head :	800.0 m	7	14.9	65.5
Intake level :	1,400.0 m	8	13.4	59.0
Discharge level :	600.0 m	9	13.0	55.1
Effective head :	720.0 m	10	12.7	55.9
Annual generating energy :	751.0 GWh	11	12.5	53.0
Firm power :	69.1 MW	12	11.7	51.4
Firm energy :	605.6 GWh	Total		751.0
Estimated construction cost :	US\$ 145.0 x 10 ⁶			
Unit cost per kW :	US\$ 630.4/kW			
Unit cost per kWh :	US\$ 0.193/kWh			
Construction period :	96 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Chimbo No. 2 Project

(Principal characteristics and dimensions)

Dam

Type : Concrete gravity
 Height : 60 m
 Crest length : 200 m
 Volume : $150 \times 10^3 \text{ m}^3$
 Flood discharge : $1,500 \text{ m}^3/\text{s}$

High water level : 1,400 m
 Low water level : — m
 Available head : — m
 Elevation on riverbed : 1,345 m

Intake Type :

Max. Intake flow : $40 \text{ m}^3/\text{s}$

Effective storage capacity : —
 Duration capacity : —
 (Effective capacity/Max. discharge)

Tunnel

Pressure tunnel Surge tank
 Length : 16,100 m Type : restricted-orifice
 Section : 3.7 m Height : 50 m
 Section : 6 m

Penstock
 Number of penstock :
 upper part 1
 lower part 2
 Length : 3,350 m
 Total length : 3,400 m

Branch tunnel

Length : 3,300 m, Intake capacity : $1.0 \text{ m}^3/\text{s}$

Section : 3.7 m to 1.7 m

Power house

Type : Half underground
 Number of generator : 2 units
 Dimension : Height : 43 m
 Width : 24 m
 Depth : 64 m

Turbine
 Type : Pelton
 Output : 121 MW
 x 2 units
 Generator
 Output : 128 MVA
 x 2 units

Switchyard
 Transformer
 Voltage : 230 kV
 Capacity :
 128 MVA
 x 2 units

Tailrace tunnel Type : —
 Length : —
 Section : —

Table A-4-(14) Pangor No. 1 Project

Location :	Chimborago	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Pangor			
Type of power plant :	Dam-Waterway (Pondage)			
Installed capacity :	17.0 MW	1	1.24	5.66
Catchment area :	128.7 km ²	2	1.92	7.95
Annual average river inflow :	1.8 m ³ /s	3	2.19	10.01
Total storage capacity :	0.2×10^6 m ³	4	2.38	10.55
Effective storage capacity :	0.07×10^6 m ³	5	2.83	12.97
Maximum discharge :	2.8 m ³ /s	6	2.40	10.63
Total head :	790.0 m	7	1.99	9.12
Intake level :	2,554.0 m	8	1.56	7.12
Discharge level :	1,764.0 m	9	1.42	6.29
Effective head :	750.0 m	10	1.19	5.46
Annual generating energy :	94.9 GWh	11	1.13	4.98
Firm power :	5.5 MW	12	0.89	4.09
Firm energy :	48.2 GWh	Total		94.83
Estimated construction cost :	US\$ 24.8×10^6			
Unit cost per kW :	US\$ 1,458.8/kW			
Unit cost per kWh :	US\$ 0.261/kWh			
Construction period :	36 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Pangor No. 1 Project

(Principal characteristics and dimensions)

Dam			
Type :	Concrete gravity	High water level :	2,555 m
Height :	35 m	Low water level :	2,551 m
Crest length :	100 m	Available head :	4 m
Volume :	$25 \times 10^3 \text{ m}^3$	Elevation on riverbed :	2,525 m
Flood discharge :	$130 \text{ m}^3/\text{s}$	Dam crest/dam height :	2,86
Intake Type :		Effective storage capacity : $0.07 \times 10^6 \text{ m}^3$	
Max. Intake flow : $2.8 \text{ m}^3/\text{s}$		Duration capacity 0.3 days (Effective capacity/Max. discharge)	
Tunnel			
Pressure tunnel	Surge tank	Penstock	
Length : 4,400 m	Type : restricted-orifice	Number of penstock :	1
Section : 2.0 m	Height : 20 m	Length :	3,000 m
	Section: 4 m	Total length :	3,000 m
Branch tunnel			
Length : — m, Intake capacity : —		Section : 2.0 m to 0.6 m	
Power house			
Type : Half underground	Turbine	Switchyard	
Number of generator : 1 unit	Type : Pelton	Transformer	
Dimension : Height : 22 m	Output : 17.9 MW	Voltage : 138 kV	
Width : 13 m	x 1 unit	Capacity :	
Depth : 25 m	Generator	18.9 MVA	
	Output : 18.9 MVA	x 1 unit	
Tailrace tunnel Type : —			
Length : —			
Section : —			

Table A-4-(15) Pangor No. 2 Project

Location :	Bolivar, Chimborago	Monthly river inflow and generating energy	
River :	Pangor		
Type of power plant :	Dam-Waterway (Pondage)	Month	Natural inflow (m ³ /s)
Installed capacity :	110.0 MW	1	11.5
Catchment area :	1,502.5 km ²	2	13.7
Annual average river inflow :	13.2 m ³ /s	3	14.5
Total storage capacity :	1.9×10^6 m ³	4	15.1
Effective storage capacity :	0.53×10^6 m ³	5	16.9
Maximum discharge :	40.0 m ³ /s	6	15.2
Total head :	348.0 m	7	13.9
Intake level :	1,748.0 m	8	12.5
Discharge level :	1,400.0 m	9	12.1
Effective head :	324.0 m	10	11.4
Annual generating energy :	318.6 GWh	11	11.2
Firm power :	28.9 MW	12	10.5
Firm energy :	252.9 GWh	Total	318.60
Estimated construction cost :	US\$ 73.8×10^6	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.	
Unit cost per kW :	US\$ 670.9/kW		
Unit cost per kWh :	US\$ 0.232/kWh		
Construction period :	48 months		

Pangor No. 2 Project

(Principal characteristics and dimensions)

Dam

Type : Concrete gravity
 Height : 50 m
 Crest length : 250 m
 Volume : $130 \times 10^3 \text{ m}^3$
 Flood discharge : $1,500 \text{ m}^3/\text{s}$

High water level : 1,750 m

Low water level : 1,744 m

Available head : 6 m

Elevation on riverbed : 1,705 m

Dam crest/dam height : 5.0

Effective storage capacity : $0.53 \times 10^6 \text{ m}^3$

Duration capacity : --
 (Storage capacity/Max. discharge)

Intake Type :

Max. intake flow : $40 \text{ m}^3/\text{s}$

Tunnel

Pressure tunnel Surge tank

Length : 5,200 m Type : restricted-
 Section : 3.8 m orifice
 Height : 35 m
 Section : 11 m

Penstock

Number of penstock : 1
 Length : 900 m
 Total length : 900 m
 Section : 3.8 m to 2.4 m

Branch tunnel

Length : 6,600 m; Intake capacity : $5.5 \text{ m}^3/\text{s}$

Power house

Type : Half underground

Turbine

Switchyard

Number of generator : nit

Type : Francis

Transformer

Dimension : Height : 35 m

Output : 116 MW
 x 1 unit

Voltage : 230 kV

Width : 25 m

Generator

Capacity

Depth : 40 m


Output : 122 MVA
 x 1 unit


122 MVA


x 1 unit


Tailrace tunnel Type : -

Length : -









APPENDIX

A-5 KW Balance in The Regional System

Fig. A-5-

(1)	Sistema	Norte	A-106
(2)	Sistema	Pichincha (Quito)	A-107
(3)	Sistema	Pichincha (Santo Domingo)	A-108
(4)	Sistema	Centro-Norte (Latacunga)	A-109
(5)	Sistema	Centro-Norte (Ambato)	A-110
(6)	Sistema	Centro-Norte (Riobamba)	A-111
(7)	Sistema	Centro-Norte (Guaranda)	A-112
(8)	Sistema	Centro-Norte (Puyo)	A-113
(9)	Sistema	Centro-Sur	A-114
(10)	Sistema	Sur	A-115
(11)	Sistema	Esmeraldas	A-116
(12)	Sistema	Manabi	A-117
(13)	Sistema	Guayas-Los Rios (Babahoyo)	A-118
(14)	Sistema	Guayos-Los Rios (Guayaquil, Duran)	A-119
(15)	Sistema	Guayos-Los Rios (Quevedo)	A-120
(16)	Sistema	Guayos-Los Rios (milagro)	A-121
(17)	Sistema	Guayas-Los Rios (Santa Elena)	A-122
(18)	Sistema	El Oro	A-123

Fig. A-5-(1) KW Balance in the Regional System
Sistema Norte




Fig. A-5-(2) kW Balance in the Regional System
Sistema Pichincha (Quito)




Fig. A-5-(3) KW Balance in the Regional System
Sistema Pichincha (Santo Domingo)




Fig. A-5-(4) kW Balance In the Regional System
Sistema Centro-Norte (Latacunga)




Fig. A-5-(5) kW Balance in the Regional System
Sistema Centro-Norte (Ambato)




Fig. A-5-(6) kW Balance in the Regional System
Sistema Centro-Norte (Riobamba)




Fig. A-5-(7) kW Balance in the Regional System
Sistema Centro - Norte (Guaranda)




Fig. A-5-(8) kW Balance in the Regional System
Sistema Centro – Norte (Puyo)




Fig. A-5-(9) KW Balance in the Regional System
Sistema Centro-Sur




Fig. A-5-(10) kW Balance in the Regional System
Sistema Sur




Fig. A-5-(II) kW Balance in the Regional System
Sistema Esmeraldas




Fig. A-5-(12) kW Balance in the Regional System
Sistema Manabi




Fig. A-5-(13) kW Balance in the Regional System
Sistema Guayas - Los Ríos (Babahoyo)




Fig. A-5-(14) kW Balance in the Regional System
Sistema Guayas - Los Ríos (Guayaquil, Duran)




Fig. A-5-(15) kW Balance in the Regional System
Sistema Guayas - Los Ríos (Quevedo)




Fig. A-5-(16) kW Balance in the Regional System
Sistema Guayas - Los Ríos (Milagro)




Fig. A-5-(17) kW Balance in the Regional System
Sistema Guayas-Los Ríos (Santa Elena)






Fig. A-5-(18) kW Balance in the Regional System
Sistema El Oro





APPENDIX


A-6 Regional Power Systems for Electrification


Fig. A-6- (1)	Sistema Norte	A-125
(2)	Sistema Pichincha	A-126
(3)	Sistema Centro-Norte	A-127
(4)	Sistema Centro-Sur	A-128
(5)	Sistema Sur	A-129
(6)	Sistema Esmeraldas	A-130
(7)	Sistema Manabi	A-131
(8)	Sistema Guayas-Los Ríos	A-132
(9)	Sistema El Oro	A-133












Existing		
(1)	SANTABAINAS I	4,020 kw D
(2)	QUININDE I	190 D
(3)	LIMONES	285 D
(4)	SAN LORENZO	240 D
(5)	MUISNE	125 D

Project		
(6)	SANTA BAINAS II	5,200 kw D (1975)
(7)	QUININDE III	260 D (1975)
(8)	ESMERALDAS	6,000 D (1976)

LEGEND

Existing • Project	
Power Plant	
Thermal	▲
Substation	△
138/69 kv	△
96/138 kv	△
Transmission Line	
138 kv	=====
69 "	=====
13.8 "



REPUBLIC OF ECUADOR
INECEL
RURAL ELECTRIFICATION
SISTEMA ESMERALDAS ⑥

Fig. A-6-(6)

