

第 8 章 投資計画

8.1 所要投資額	114
8.1.1 投資計画の範囲	114
8.1.2 投資額	114
8.2 収支バランス	116
8.2.1 全国連系系統に対する投資額	116
8.2.2 資金調達	116
8.2.3 販売電力収入	118
8.2.4 運転維持費および減価償却	119
8.2.5 収支バランス	123

第 8 章 投資計画

8.1 所要投資額

8.1.1 投資計画の範囲

本報告書における投資計画の範囲には第5章、長期電力開発計画を構成するプロジェクトで述べた発電プロジェクト、全国連系送変電計画および地方電化計画ならびに調査費、人材教育費、更に1985年以降の発電プロジェクトについては、1984年までに必要な資金を含めるものとした。

8.1.2 投資額

1975年から1984年までの10年間に必要な総投資額はUS\$ 882,380 × 10³であり、年平均US\$ 88,240 × 10³を投資する必要がある。このうち、発電プロジェクトに必要な投資額はUS\$ 576,380 × 10³であり、送変電設備のそれはUS\$ 175,400 × 10³である。なお、地方電化計画のために INECELはその必要資金の一部を負担するが、その額はUS\$ 73,600 × 10³、調査費・人材教育費その他US\$ 57,000 × 10³である。

内外貨別の所要投資額はTable 8-1に、年度別工事費はTable 8-2に示すとおりである。

Table 8-1 Investment Required by Year

Unit : 10³ US \$

	F. C.	L. C.	Total
(1) Generation facilities	341,150	141,950	483,100
(2) National interconnecting transmission and transforming facilities	139,230	36,170	175,400
(3) Facilities to be developed in and after 1985	38,580	54,700	93,280
(1) ~ (3) Sub total	518,960	232,820	751,780
(4) Regional electrification project	51,520	22,080	73,600
(5) Investigation cost and others	14,390	42,610	57,000
(4) ~ (5) Sub total	65,910	64,690	130,600
(1) ~ (5) Total	584,870	297,510	882,380

Note : F. C. Foreign Currency L. C. Local Currency

Table 8-2 Investment Schedule by Year

Project	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Total
1. Hydro plant											
F.C.	17,070	31,350	51,460	57,560	63,430	38,710	14,460	7,820	5,800	17,480	305,140
L.C.	13,800	20,150	23,400	24,760	20,590	11,500	340	180	8,300	10,990	133,750
Total	30,870	51,500	74,860	82,340	84,020	50,210	14,800	8,000	14,120	28,470	438,890
2. Thermal plant											
F.C.	4,760	19,450	14,660	13,750	5,110	-	-	-	9,460	7,400	74,590
L.C.	1,840	11,350	11,440	2,450	390	-	-	-	2,320	33,110	62,900
Total	6,600	30,800	26,100	16,200	5,500	-	-	-	11,780	40,510	137,490
3. Transmission line											
F.C.	7,880	33,040	32,930	43,470	16,340	5,570	-	-	-	-	139,230
L.C.	3,400	6,200	5,850	7,820	8,900	3,880	-	-	-	-	36,170
Total	11,280	39,240	38,780	51,290	25,240	9,450	-	-	-	-	175,400
National System Total (1 + 2 + 3)											
F.C.	29,710	83,840	99,050	114,780	84,380	44,280	14,460	7,820	15,260	24,880	518,960
L.C.	18,800	37,700	40,690	35,050	29,940	15,380	340	180	10,640	44,100	232,820
Total	48,510	121,540	139,740	149,830	114,320	59,660	14,800	8,000	25,900	68,980	751,780
4. Regional system											
F.C.	14,700	13,090	10,990	8,190	4,550	-	-	-	-	-	51,520
L.C.	6,300	5,610	4,710	3,510	1,990	-	-	-	-	-	22,090
Total	21,000	18,700	15,700	11,700	6,540	-	-	-	-	-	73,610
5. General investment											
F.C.	1,000	1,060	1,490	1,460	1,600	1,580	1,500	1,500	1,500	1,500	14,390
L.C.	1,000	940	1,010	1,040	1,200	1,420	1,500	1,500	1,500	1,500	12,610
Total	2,000	2,000	2,500	2,500	3,000	3,000	3,000	3,000	3,000	3,000	27,000
6. Investigation and study											
F.C.	-	-	-	-	-	-	-	-	-	-	-
L.C.	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	20,000
Total	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	20,000
7. Training and education											
F.C.	-	-	-	-	-	-	-	-	-	-	-
L.C.	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	10,000
Total	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	10,000
Total investment											
F.C.	45,410	97,990	111,530	124,430	91,230	45,860	15,960	9,320	16,760	26,380	584,970
L.C.	29,100	47,250	49,410	42,600	30,990	19,800	4,840	4,680	15,140	48,600	297,510
G.Total	74,510	145,240	160,940	167,030	122,220	65,660	20,800	14,000	31,900	74,980	882,380

8・2 収支バランス

8・2・1 全国連系系統に対する投資額

長期電力開発計画に対する収支バランスは、今回の長期計画の対象期間である1975年から1984年までの10年間に亘って検討した。

この収支バランスの検討に際し考慮されなければならない投資額としては、全国連系系統に対する発電プロジェクトおよび全国連系送変電計画の総工事費であり、その所要総額はUS\$ 751.8×10^6 である。

8・2・2 資金調達

(1) 石油利権料からの引当金

エクアドル政府は、石油輸出に伴う利権収入の47%をINECELの電力開発資金として引当てることを法律によって決めている。

この利権収入は、石油生産計画によって決定されるが、その生産計画は1975年から1979年までは 180×10^3 バレル/日、1980年以降は 140×10^3 バレル/日と計画されている。これに伴うINECELへの利権収入からの引当金は、1979年までの5年間は毎年US\$ 53.2×10^6 であり、1980年以降は毎年US\$ 41.4×10^6 である。従って、1975年から1984年までの10年間の引当金合計額は、US\$ 473×10^6 となる。

この合計額US\$ 473×10^6 のうち、地方電化計画、調査費、人材教育費などに必要な投資額は合計US\$ 130.6×10^6 であり、全国連系系統に対する投資引当額は、US\$ 342.4×10^6 である。

年度別の投資引当額はTable 8-3に示すとおりである。

(2) 償却費

1977年以降、全国連系系統に対する発電プロジェクトおよび全国連系送変電計画が順次完成するので、これに伴う設備償却費が計上され、これを全国連系系統に対する工事資金として再投資することが可能となる。

この設備償却費の合計は1984年までにUS\$ 90.6×10^6 となる。

年度別償却費はTable 8-3に示すとおりである。

(3) 外国からの借款

所要工事資金のうち、石油利権料からの引当金および設備償却費の合計額を超える金額については、外国からの借款が必要である。

この借款の合計額はTable 8-3に示すとおり、US\$ 426.3×10^6 となる。

このうち、すでに決定されている外国借款額はUS\$ 121.2×10^6 である。従って、今後、新規に期待しなければならない外国借款額は、1984年までにUS\$ 305.1×10^6 に達することとなる。

Table S-3 Investment Assigned to the National Interconnected System

	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Total
A. Petroleum concession (Revenue)	53,200	53,200	53,200	53,200	53,200	41,400	41,400	41,400	41,400	41,400	473,000
B. Regional system	21,000	18,700	15,700	11,700	6,500	-	-	-	-	-	73,600
C. General investment	2,000	2,000	2,500	2,500	3,000	3,000	3,000	3,000	3,000	3,000	27,000
D. Investigation and study	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	2,000	20,000
E. Training and education	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	1,000	10,000
Sub-total (B-E)	26,000	23,700	21,200	17,200	12,500	6,000	6,000	6,000	6,000	6,000	130,600
F. Investment assigned from the petroleum concession to the national interconnected system	27,200	29,500	32,000	36,000	40,700	35,400	35,400	35,400	35,400	35,400	342,400
G. Depreciation from the national interconnected system	-	-	1,320	4,590	7,110	10,030	16,410	16,570	17,050	17,530	90,610
H. Investment assigned to the national interconnected system (F + G)	27,200	29,500	33,320	40,590	47,810	45,430	51,810	51,970	52,450	52,930	433,010
I. Construction expenditure	48,510	121,540	139,740	149,830	114,820	59,660	14,800	8,000	25,900	68,980	751,780
Exterior borrowing (H-I)	- 21,310	- 92,040	- 106,420	- 109,240	- 67,010	- 14,230	-	-	-	- 16,050	- 426,300

(4) 外国借款に対する金利および返済条件

上記(3)で述べた外国借款の金利および返済条件は次に述べるとおりとする。

1) Paute 水力

Paute水力発電所の土木工事のうち必要な外貨分について、米州開発銀行(BID)が長期低利の借款を与えており、その条件は特別借款(Special fund)と通常借款(Ordinary fund)とに分けられるが、その条件は次のとおりである。

特別借款

金 利 : 据置期間中 1.0%

そ の 他 2.0%

返済期間 : 40年(含む据置10年)

通常借款

金 利 : 8%

返済期間 : 20年(含む据置5年)

2) 北部火力

日本政府、および日本輸出入銀行が借款を与えており、その条件は次のとおりである。

第1次借款(日本政府借款)

金 利 : 4.75%

返済期間 : 20年(含む据置7年)

第2次借款(日本輸出入銀行借款)

金 利 : 7.5%

返済期間 : 7年(含む据置2年)

3) Guayaquil火力

Guayaquil火力発電設備について契約条件の協議が進められているが、金利7.5%最終給積後10年の返済期限が適用される可能性が強いため、これを適用する。

4) 新規借款

上記3プロジェクトについては前述の借款条件を適用し、未決定分の借款期待額については、INECELが考慮している下記条件を返済条件とし、収支バランスに必要な金利および元本の返済計画を検討した。

金 利 : 年8%

返済期間 : 9年(含む据置3年)

8.2.3 販売電力収入

INECELが開発するPaute水力、Guayaquil火力発電所などで発生される電力は、全国連系送変電設備を経て各地域系統に送電され、(138/69 kV)変電所(以下2次変電所とい

う)の2次側で各地域の電力会社に卸売りされる。

INECELの販売電力収入は、この卸売り電力量をベースに現行電気料金制度を適用して算出されなければならない。しかし、現在のエクアドルにおける電気料金制度は、INECELも指摘しているように、Ⅰ)適正利益が見込まれていない、Ⅱ)資産の再評価がなされていない、Ⅲ)火力発電所の燃料費が国際価格に比較し非常に低い、などの理由から、この料金制度をここに述べる販売電力収入の算出に採用することは、このプロジェクトを純経済的に評価するには適当ではない。従って、ここでは料金制度を離れて、次の(1)で述べるように卸売り地点、すなわち、2次変電所の2次側における電力コストを売電単価として販売電力収入を算出し、収支バランスの検討を行なった。

(1) 売電単価

長期電力開発計画の資金計画に適用する売電単価は、Table 8-4に示すごとくINECELによって開発される1975年から1984年までの発送変電設備、すなわちQuitoディーゼル、Guayaquilスチーム火力、Pisayambo水力、Paute水力および全国連系送変電設備の10年間における経費30.5 mills/kWhを卸売り地点における売電単価とする。この単価は、代替設備としてのディーゼル発電所における発電コストと比較して13.0 mills/kWh安く妥当な価格といえることができる。

(2) 売電々力量

売電々力量はTable 8-5に示すとおり、全国連系系統に連系される全発電設備のうち、INECEL所有の発電設備が分担しなければならない電力量を需給バランス上から算出し、この電力量から2次変電所2次側までの送電損失2%を差し引いた残りを、販売可能電力量とした。

年度別販売可能電力量はTable 8-6に示すとおりである。

(3) 販売電力収入

上記(1)および(2)で述べた売電単価および販売電力量から求められたINECELの販売電力収入は、Table 8-6に示すとおりであり、売電収入は、北部火力が運転に入る1977年から計上され、この年の収入はUS\$ 4.1 × 10⁶ から、1984年にはUS\$ 106.3 × 10⁶に増大する。

8.2.4 運転維持費および減価償却

長期電力開発計画の対象プロジェクトの運転維持費および減価償却を算定するにあたっては、次に示すとおりINECELの算定基準によるものとした。

(1) 運転保守費

発送変電設備の運転保守のための年経費は次のとおり、

火力発電設備	建設費に対し	4.0%/年
水力	2.1%/年
送変電設備	3.3%/年

Table 8-4 Energy Cost at 138-kV Substation End

n.	Year	Energy requirement at generating end			Annual cost				Unit generating cost (mills/kWh)
		Hydro (GWh)	Thermal (GWh)	Total (GWh)	Hydro (10 ³ US\$)	Thermal (10 ³ US\$)	Transmission (10 ³ US\$)	Total (10 ³ US\$)	
1.	1977	-	138	138	-	5,303	1,951	7,254	52.6
2.	1978	212	438	650	9,009	13,696	5,931	28,636	44.1
3.	1979	212	591	803	9,009	19,710	11,783	40,502	50.4
4.	1980	212	898	1,100	9,009	23,903	20,880	53,192	47.9
5.	1981	1,964	409	2,373	51,133	17,414	25,521	94,068	39.6
6.	1982	2,330	432	2,762	52,033	17,695	25,521	95,249	34.5
7.	1983	2,696	447	3,143	52,934	17,882	25,521	96,337	30.7
8.	1984	3,062	493	3,555	53,835	18,443	25,521	97,799	27.5
9.	1985	3,062	493	3,555	53,835	18,443	25,521	97,799	27.5
10.	1986	3,062	493	3,555	53,835	18,443	25,521	97,799	27.5
11.	1987	3,062	493	3,555	53,835	18,443	25,521	97,799	27.5
.
.
.
48.	2024	3,062	493	3,555	53,835	18,443	25,521	97,799	27.5
49.	2025	3,062	493	3,555	53,835	18,443	25,521	97,799	27.5
50.	2026	3,062	493	3,555	53,835	18,443	25,521	97,799	27.5
Total		139,292	24,552	163,844	2,498,032	908,052	1,214,511	4,620,595	-

Unit average generating cost during service life : 30.5 mills/kWh.

Table 8-5. Generating Energy Share to be Borne between INECEL and Private Utilities

	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	
	Unit : GWh										
Demand at generating end	(MW)	342.78	395.10	466.07	537.10	604.95	682.91	754.63	834.44	922.11	1,018.70
	(GWh)	1,435.07	1,659.02	1,995.67	2,314.25	2,597.25	2,933.87	3,237.73	3,576.95	3,950.41	4,366.36
Hydro											
Private utilities		607.75	637.04	642.82	688.29	688.29	688.29	688.29	688.29	688.29	688.29
PISAYAMBO (76.2 MW)		-	-	-	212.00	212.00	212.00	212.00	212.00	212.00	212.00
PAUTE (200~500 MW)		-	-	-	-	-	1,752.00	2,118.00	2,484.00	2,850.00	
Sub total		607.75	637.04	642.82	900.29	900.29	2,652.29	3,018.29	3,384.29	3,750.29	
							(392.70)	(492.70)	(592.70)	(692.70)	
Thermal											
Private utilities		827.32	1,021.98	1,214.88	975.96	1,105.66	1,135.68	176.83	126.95	119.00	123.03
Nothern thermal (INECEL)		-	-	137.97	131.40	131.40		408.50	431.71	447.12	493.33
Guayaquil thermal		-	-	-	306.60	459.90	766.50	(176.00)	(176.00)	(176.00)	(176.00)
Sub total		827.32	1,021.98	1,352.85	1,413.96	1,696.96	2,033.58	585.44	558.66	566.12	616.36
							(365.93)	(341.74)	(329.41)	(326.00)	
Total		1,435.07	1,659.02	1,995.67	2,314.25	2,597.25	2,933.87	3,237.73	3,576.95	3,950.41	4,366.36
Generating energy by INECEL		-	-	137.97	650.00	803.30	1,109.90	2,372.56	2,761.71	3,143.12	3,555.33

Table 8-6 Statement of Income (Unit sales price : 30.5 mills/kWh)

Unit : x 10³ US\$

	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(A) Gross revenue	—	—	4,120	19,430	24,010	33,180	70,910	82,540	93,950	106,270
Generated energy (MWh)	—	—	137,910	650,000	803,300	1,109,900	2,372,560	2,761,710	3,143,120	3,555,330
Energy sales (MWh)	—	—	135,150	637,000	787,230	1,087,700	2,325,110	2,709,480	3,080,290	3,484,220
Unit sales price (mills/kWh)	—	—	30.5	30.5	30.5	30.5	30.5	30.5	30.5	30.5
(B) Total operation cost	90	330	4,860	15,620	21,190	30,090	36,760	38,530	39,420	40,630
1. Operation and maintenance	—	—	990	4,680	5,720	7,990	14,140	15,450	15,620	15,660
2. Fuel cost	—	—	1,950	5,460	7,250	10,850	4,960	5,240	5,430	5,990
3. Administration cost	90	330	600	890	1,110	1,220	1,250	1,270	1,320	1,450
4. Depreciation	—	—	1,320	4,590	7,110	10,030	16,410	16,570	17,050	17,530
(C) Operating income (A)-(B)	-90	-330	-740	3,810	2,820	3,090	34,150	44,010	54,530	65,640
(D) Financial expenditure (Interest)	170	170	2,830	5,720	10,210	17,970	22,910	20,390	17,320	12,890
(E) Net income (C)-(D)	-260	-500	-3,570	-1,910	-7,390	-14,880	11,240	23,620	37,210	52,760

(2) 減価償却

発電変電設備の減価償却は、耐用年数を次のように設定し、定額法によるものとした。

水力発電設備	50年
スチーム火力発電設備	25年
ディーゼル火力発電設備	20年
送変電設備	30年

(3) 燃料費 (Bunker C 重油)

北部火力 (ディーゼル)	US\$ 50.7 / ton
Guayaquil 火力 (スチーム)	US\$ 47.4 / ton

(4) 管理費

火力発電設備	建設費に対し	0.2 % / 年
水力	"	0.2 % / 年
送変電設備	"	0.2 % / 年

8・2・5 収支バランス

資金計画の収支バランスは、Table 8-6 および Table 8-7 に示すとおりである。

即ち、全国連系送変電計画が完成し Paute 水力が運転を開始する 1981 年までの Cash Balance は赤字を示す。これは 1975 年から始まる全国連系送変電計画ならびに、発電プロジェクトのための外部借款の返済によるものである。この赤字が大きいのは、借款期待額の借入れ条件が金利年 8 %、3 年据置を含む 9 年返済という電気事業のような設備産業には可成りきびしい資金条件が大きな原因であり、従って、電気事業一般に適用できるようなソフトな条件であれば、Paute 水力の建設が終了するであろう 1981 年以降は黒字になることが期待できると思料する。Table 8-7 に示すとおり、1984 年までの累積赤字額は US\$ 80.3×10^6 に達することを示している。いまこの累積赤字額を 1984 年時点において仮に零にするための売電単価を求めるとその値は 36.1 mills/kWh であり、この単価を適用した場合の Statement of Income は Table 8-8、Statement of Cash Flow は Table 8-9 に示すとおりである。この Table 8-9 に示すように Cash Balance は Paute 水力発電所が開通する 1981 年には黒字に転じ、1984 年の黒字額は US\$ 18.7×10^6 に達する。

従って、赤字巾を少なくする為には、一層長期、低利の建設資金の投入が望ましい。

Table 8-7 Statement of Cash Flow (Unit sales price : 30.5 mills/kWh)

	Unit : 10 ³ US\$									
	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(A) Cash receipt	48,250	121,040	136,170	147,920	197,430	44,793	63,050	75,990	87,060	121,740
1. Net income	-260	-500	-3,970	-1,910	-9,290	-14,880	11,240	23,820	37,210	52,760
2. Depreciation	—	—	1,320	4,590	7,110	10,030	14,410	16,570	17,050	17,530
3. INECEL's capital (Petroleum concession)	27,200	29,500	32,000	30,000	40,700	35,430	35,430	35,430	35,430	35,430
4. Exterior borrowing	21,310	92,040	106,420	109,240	63,010	14,230	—	—	—	16,050
(B) Cash disbursement	68,510	121,540	144,030	159,280	135,150	95,130	66,520	61,450	81,790	122,540
1. Construction expenditure	68,510	121,540	139,740	149,130	114,820	59,660	14,800	8,000	25,900	64,950
2. Amortization of debt (Capital)	—	—	4,290	9,450	20,330	35,470	51,720	53,450	55,890	57,590
(C) Cash balance (A) - (B)	-260	-500	-7,860	-11,360	-37,720	-50,350	-3,470	14,540	7,870	-800
(D) Accumulated total	-260	-760	-6,620	-19,830	-47,700	-98,050	-101,520	-67,360	-79,510	-80,310

Table 8-8 Statement of Income (Unit sales price : 36.1 mills/kWh)

	Unit : 10 ³ US\$									
	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(A) Gross revenue	—	—	4,840	23,000	28,420	39,870	83,940	97,700	111,200	125,780
Generated energy (GWh)	—	—	137,910	650,000	803,300	1,106,990	2,372,560	2,761,710	3,143,420	3,555,330
Energy sales (MWh)	—	—	135,150	637,000	787,230	1,061,700	2,325,110	2,706,480	3,083,760	3,434,220
Unit sales price (mills/kWh)	—	—	36.1	36.1	36.1	36.1	36.1	36.8	36.1	36.1
(B) Total operation cost	90	330	4,860	15,620	21,190	30,090	36,760	38,530	39,420	40,430
1. Operation and maintenance	—	—	990	4,880	5,720	7,990	14,140	15,450	15,620	15,660
2. Fuel cost	—	—	1,650	5,400	7,250	10,850	4,960	5,240	5,430	5,990
3. Administration cost	90	330	600	890	1,110	1,120	1,250	1,270	1,320	1,450
4. Depreciation	—	—	1,320	4,590	7,110	10,030	14,410	16,570	17,050	17,330
(C) Operating income (A) - (B)	-90	-330	20	7,380	7,230	9,180	47,180	59,170	71,780	85,350
(D) Financial expenditure (Interest)	170	170	2,830	5,720	10,210	17,970	22,910	20,390	17,320	12,880
(E) Net income (C) - (D)	-260	-500	-2,810	1,660	-2,980	-8,790	24,270	38,780	54,460	72,470

Table 8-9 Statement of Cash Flow (Unit sales price : 36.1 mills/kWh)

	Unit : 10 ³ US\$									
	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(A) Cash receipt	48,250	121,040	136,930	151,490	111,840	50,870	78,080	90,750	106,910	141,250
1. Net income	-260	-500	-3,310	1,660	-2,980	-8,790	24,270	38,780	54,460	72,470
2. Depreciation	—	—	1,320	4,590	7,110	10,030	14,410	16,570	17,050	17,530
3. INECEL's capital (Petroleum concession)	27,200	29,500	32,000	36,000	45,700	35,430	35,430	35,430	35,430	35,430
4. Exterior borrowing	21,310	92,040	106,420	109,240	63,010	14,230	—	—	—	16,050
(B) Cash disbursement	68,510	121,540	144,030	159,280	135,150	95,130	66,520	61,450	81,790	122,540
1. Construction expenditure	68,510	121,540	139,740	149,130	114,820	59,660	14,800	8,000	25,900	64,950
2. Amortization of debt (Capital)	—	—	4,290	9,450	20,330	35,470	51,720	53,450	55,890	57,590
(C) Cash balance (A) - (B)	-260	-500	-7,100	-7,790	-23,310	-44,260	9,560	29,300	25,120	18,710
(D) Accumulated total	-260	-760	-7,860	-15,650	-39,060	-83,320	-73,660	-44,360	-19,240	-530

APPENDIX

A - 1	Load Forecast Divided into the Regional Systems	A-1
A-1-1	Trial Calculations by Macroscopic Method	A-21
A - 2	Supply Capability from 1975 to 1984 and Supply Capability of Existing Power Plants at the End of 1974	A-26
A - 3	Estimated Generating Energy Cost by Diesel Power Plants	A-51
A - 4	Hydropower Plants to be Installed in and after 1985	A-59
A - 5	kW Balance in the Regional Systems	A-105
A - 6	Regional Power System for Electrification	A-124

APPENDIX

A-1 Load Forecast Devided into the Regional Systems

Table A-1-	(1)	Load Forecast for Entire Ecuador	A-2
"	(2)	Load Forecast for the Sistema Norte	A-3
"	(3)	Load Forecast for the Sistema Pichincha	A-4
"	(4)	Load Forecast for the Sistema Centro-Norte	A-5
"	(5)	Load Forecast for the Sistema Centro-Sur	A-6
"	(6)	Load Forecast for the Sistema Sur	A-7
"	(7)	Load Forecast for the Sistema Esmeraldas	A-8
"	(8)	Load Forecast for the Sistema Manabi	A-9
"	(9)	Load Forecast for the Sistema Guayas-Los Rios	A-10
"	(10)	Load Forecast for the Sistema El Oro	A-11
"	(11)	Classification of Industrial Demand	A-12
"	(12)	Ratio of Energy Demand by Customers	A-13
"	(13)	Number of Customers and Energy Demand per Customers	A-16
A - 1 - 1		Trial Calculations by Macroscopic Method	A-21

Table A - 1 - (1) Load Forecast for Entire Ecuador

	Unit: GWh													
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984
Energy demand at customer end (GWh)	341.23	(22.9)	(23.0)	(34.1)	(21.9)	(12.4)	(13.8)	(9.6)	(10.3)	(10.2)	(11.0)	21.1	10.3	16.7
Industry	419.38	419.38	515.06	691.37	942.54	946.85	1,077.78	1,181.58	1,303.33	1,438.20	1,595.86			
Residential	412.72	(12.5)	(13.1)	(13.1)	(13.3)	(13.5)	(13.6)	(12.2)	(11.9)	(11.7)	(11.5)	13.2	11.8	12.6
Commercial	175.20	(13.1)	(13.1)	(13.3)	(13.6)	(13.4)	(13.4)	(11.5)	(11.0)	(11.1)	(10.6)	15.3	11.1	12.4
Others	112.34	(7.3)	(7.3)	(7.5)	(7.2)	(7.4)	(7.4)	(6.7)	(6.6)	(6.6)	(6.6)	7.3	6.6	7.0
Subtotal	1,041.49	(15.4)	(15.9)	(20.4)	(16.4)	(12.6)	(13.2)	(10.6)	(10.7)	(10.7)	(10.8)	15.6	10.7	13.6
Energy requirement at sending end (GWh)	1,247.04	(15.0)	(15.6)	(20.3)	(16.0)	(12.2)	(13.0)	(10.4)	(10.5)	(10.4)	(10.5)	15.3	10.5	13.3
Loss factor (%)	16.5	16.2	16.0	15.9	15.6	15.4	15.2	15.0	14.8	14.6	14.4			
Load factor (%)	48	48	48	49	49	49	49	49	49	49	49			
Max. demand at sending end (GWh)	299.76	(14.4)	(15.3)	(18.0)	(15.2)	(12.6)	(12.9)	(10.5)	(10.6)	(10.5)	(10.5)	14.7	10.5	13.0
	342.78	342.78	395.10	466.67	537.10	604.95	682.91	754.63	834.44	922.11	1,018.70			

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (2) Load Forecast for the Sistema Norte

	Unit: GWh														
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%)			
												1974-1980	1980-1984	1974-1984	
Energy demand at															
cueterone end (GWh)															
Industry	1.98	(13.1)	(13.4)	(2,208.9)	(3.3)	(1.2)	(1.3)	(1.4)	(1.5)	(1.7)	(1.8)	77.6	1.6	42.0	
		2.24	2.54	58.61	60.52	61.28	62.09	62.98	63.94	65.02	66.19				
Residential	8.57	(13.9)	(14.5)	(14.7)	(15.4)	(15.3)	(15.3)	(12.8)	(12.4)	(12.5)	(12.4)	14.9	12.5	13.9	
		9.77	11.18	12.82	14.80	17.07	19.69	22.20	24.97	28.09	31.58				
Commercial	4.17	(14.2)	(14.4)	(13.8)	(14.5)	(14.7)	(14.4)	(13.4)	(13.5)	(13.5)	(13.5)	14.3	13.5	14.0	
		4.76	5.45	6.20	7.10	8.14	9.32	10.56	11.99	13.60	15.43				
Others	4.53	(5.0)	(6.0)	(5.4)	(5.6)	(5.9)	(6.1)	(4.0)	(3.8)	(3.6)	(3.6)	5.7	3.8	4.9	
		4.75	5.04	5.31	5.61	5.94	6.30	6.56	6.81	7.05	7.31				
Subtotal	19.25	(11.8)	(12.5)	(242.6)	(6.1)	(5.0)	(5.4)	(5.0)	(5.5)	(5.6)	(5.9)	31.0	5.5	20.1	
		21.52	24.21	82.94	88.03	92.42	97.40	102.30	107.71	113.76	120.51				
Energy requirement at															
sending end (GWh)	28.65	(11.5)	(12.1)	(244.1)	(5.7)	(4.6)	(5.0)	(4.7)	(4.9)	(5.3)	(5.6)	30.7	5.1	19.8	
		26.36	29.56	101.68	107.51	112.48	118.13	123.67	129.77	136.63	144.31				
Loss factor (%)	18.6	18.3	18.1	18.4	18.1	17.8	17.5	17.2	16.9	16.7	16.4				
Load factor (%)	37	37	37	37	37	36	34	33	32	31	30				
Max. demand at sending	7.34	(11.2)	(11.9)	(115.5)	(8.6)	(7.5)	(8.0)	(7.0)	(7.3)	(7.5)	(7.7)	22.5	7.4	16.2	
end (MW)		8.16	9.13	19.68	21.36	23.00	24.84	26.58	28.51	30.65	33.01				

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (3) Load Forecast for the Sistema Pichincha

	Unit: Gwh													
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984
Energy demand at customers end (GWh)	99.34	(8.9)	(14.9)	(13.9)	(13.5)	(12.9)	(13.0)	(13.1)	(13.6)	(12.8)	(13.3)	12.8	13.2	13.0
Industry	108.19	(10.5)	(14.9)	(13.9)	(13.5)	(12.9)	(13.0)	(13.1)	(13.6)	(12.8)	(13.3)	(13.3)	12.8	13.2
Residential	140.62	(10.5)	(10.3)	(11.1)	(10.7)	(10.9)	(11.0)	(11.1)	(11.1)	(10.9)	(10.9)	(10.9)	10.8	11.0
Commercial	49.22	(13.1)	(12.1)	(13.4)	(13.2)	(12.9)	(13.2)	(13.1)	(12.0)	(13.0)	(11.6)	(11.6)	13.0	12.4
Others	33.11	(7.4)	(7.0)	(8.3)	(7.4)	(7.5)	(7.4)	(7.3)	(7.3)	(7.3)	(7.5)	(7.5)	7.5	7.3
Subtotal	322.29	(10.1)	(11.7)	(12.1)	(11.7)	(11.6)	(11.7)	(11.8)	(11.8)	(11.6)	(11.6)	(11.6)	11.5	11.7
Energy requirement at sending end (GWh)	402.51	(9.8)	(11.5)	(11.9)	(11.4)	(11.3)	(11.4)	(11.5)	(11.3)	(11.2)	(11.0)	(11.0)	11.2	11.3
Loss factor (%)	19.9	19.7	19.5	19.4	19.3	19.1	18.9	18.7	18.3	18.1	17.8	17.8	17.8	17.8
Load factor (%)	51	51	51	51	51	51	51	51	51	51	51	51	51	51
Max. demand at sending end (MW)	89.24	(9.7)	(11.1)	(11.9)	(11.4)	(11.7)	(11.9)	(11.8)	(11.6)	(11.5)	(11.4)	(11.4)	11.3	11.6
		97.86	108.77	121.71	135.80	151.41	169.33	189.27	211.31	235.71	262.68	262.68	262.68	262.68

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (4) Load Forecast for the Sistema Centro-Norte

	Unit : (GWh)													
	(Estimated) 1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%) 1974-1980 1980-1984 1974-1984		
Energy demand at customers end (GWh)	31.38	(25.3) 39.32	(20.8) 47.52	(12.5) 53.47	(62.4) 86.83	(7.3) 93.22	(11.1) 103.53	(7.6) 111.39	(9.6) 122.98	(7.8) 131.54	(7.9) 141.93	22.0	8.2	16.3
Residential	24.20	(17.8) 28.50	(18.5) 33.78	(17.5) 39.70	(17.4) 46.62	(16.7) 54.40	(16.4) 63.34	(13.6) 71.98	(13.2) 81.46	(13.5) 92.45	(13.6) 104.99	17.4	13.5	15.8
Commercial	13.77	(10.0) 15.15	(10.2) 16.09	(10.4) 18.44	(10.8) 20.42	(10.1) 22.48	(10.7) 24.88	(9.9) 27.43	(9.9) 30.06	(10.2) 33.13	(10.5) 36.62	10.4	10.1	10.3
Others	8.88	(5.9) 9.41	(6.4) 10.01	(6.7) 10.68	(6.8) 11.40	(7.1) 12.21	(7.4) 13.11	(6.4) 13.94	(5.8) 14.76	(5.6) 15.58	(5.5) 16.44	6.7	5.8	6.4
Subtotal	78.23	(18.1) 92.38	(16.9) 108.00	(13.2) 122.29	(35.1) 165.27	(10.3) 182.31	(12.4) 204.86	(9.7) 224.65	(10.6) 248.35	(9.8) 272.70	(10.0) 299.98	17.4	10.0	14.4
Energy requirement at sending end (GWh)	98.73	(17.3) 115.77	(16.1) 134.36	(12.8) 151.50	(35.6) 202.34	(9.8) 222.26	(11.9) 248.77	(9.3) 271.89	(10.2) 299.68	(9.4) 327.96	(9.6) 359.61	16.7	9.6	13.8
Loss factor (%)	20.8	20.2	19.6	19.3	18.3	18.0	17.7	17.4	17.1	16.8	16.6			
Load factor (%)	42	42	43	44	46	46	46	46	46	45	45			
Max. demand at sending end (MGW)	26.95	(15.6) 31.16	(13.9) 35.47	(11.8) 39.65	(25.9) 49.92	(10.8) 55.31	(12.4) 62.15	(9.8) 68.25	(10.6) 75.47	(10.1) 83.09	(10.4) 91.69	14.9	10.2	13.0

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (5) Load Forecast for the Sistema Centro-Sur

	Unit : GWh												
	(Estimated) 1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1984 Increase (%)	
Energy demand at customers end (GWh)													
Industry	11.10	(10.9) 12.38	(11.9) 13.85	(153.1) 35.04	(13.3) 39.72	(6.3) 42.21	(29.8) 54.78	(7.2) 58.72	(7.9) 63.36	(8.3) 68.62	(8.6) 74.50	30.4	8.0
Residential	19.18	(12.6) 21.60	(13.5) 24.49	(14.1) 27.96	(14.9) 32.13	(15.9) 31.25	(17.7) 43.84	(12.3) 49.22	(12.1) 55.20	(12.4) 62.03	(12.5) 69.77	14.8	12.3
Commercial	3.60	(17.5) 4.23	(18.8) 5.03	(19.9) 6.03	(21.2) 7.31	(23.2) 9.00	(25.2) 11.27	(14.7) 12.92	(14.6) 14.81	(14.7) 16.99	(14.7) 19.48	20.9	14.7
Others	3.42	(9.9) 3.75	(10.6) 4.15	(11.6) 4.63	(12.1) 5.19	(16.8) 6.06	(17.3) 7.11	(5.6) 7.51	(5.7) 7.93	(5.7) 8.38	(5.7) 8.87	13.0	5.7
Subtotal	37.36	(12.3) 41.96	(13.3) 47.52	(55.0) 73.66	(14.5) 84.35	(12.1) 94.52	(23.8) 117.00	(9.7) 128.37	(10.1) 141.30	(10.4) 156.02	(10.6) 172.62	21.0	10.2
Energy requirement at sending end (GWh)	47.87	(11.3) 53.38	(12.3) 60.04	(54.2) 92.59	(13.8) 105.34	(11.3) 117.27	(22.7) 143.83	(9.2) 157.07	(9.6) 172.13	(9.9) 189.20	(10.1) 204.37	20.1	9.7
Loss factor (%)	21.9	21.4	20.8	20.4	19.9	19.3	18.6	18.2	17.9	17.5	17.1		
Load factor (%)	43	43	43	44	44	43	43	43	43	43	43		
Max. demand at sending end (MW)	12.57	(12.3) 14.11	(13.4) 16.01	(49.9) 24.01	(14.8) 27.57	(13.2) 31.21	(23.5) 38.56	(9.0) 42.04	(9.3) 45.96	(9.8) 50.45	(10.1) 55.54	20.5	9.6

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (6) Load Forecast for the Sistema Sur

	Unit: GWh															
	(Estimated) 1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984		
Energy demand at customers end (GWh)																
Industry	1.86 (118.0) 4.05	(29.8) (13.5) 5.26	(17.7) (17.7) 7.02	(56.8) (11.01) 15.79	(29.4) (29.4) 15.79	(10.9) (10.9) 17.51	(9.4) (9.4) 19.16	40.4 (10.2) 21.01	10.2	27.5						
Residential	3.63 (15.9) 4.21	(18.4) (21.2) 6.04	(23.2) (23.2) 7.44	(24.6) (24.6) 9.27	(27.1) (27.1) 11.78	(29.8) (29.8) 15.29	(20.7) (20.7) 24.50	21.7 (20.7) 29.57	25.9	23.3						
Commercial	2.86 (11.1) 3.17	(13.0) (14.8) 4.12	(16.1) (16.1) 4.78	(16.4) (16.4) 5.56	(18.6) (18.6) 6.60	(22.0) (22.0) 9.83	(18.0) (18.0) 11.60	15.0 (15.0) 13.40	19.4	16.7						
Others	3.16 (4.3) 3.30	(4.0) (5.1) 3.60	(5.0) (5.0) 3.78	(5.4) (5.4) 3.99	(6.2) (6.2) 4.23	(6.6) (6.6) 4.51	(6.5) (6.5) 5.13	5.0 (6.3) 5.45	6.5	5.6						
Subtotal	11.51 (28.0) 14.73	(17.1) (14.3) 19.72	(16.7) (16.7) 23.02	(29.6) (29.6) 29.83	(23.5) (23.5) 36.85	(19.0) (19.0) 51.93	(16.3) (16.3) 60.39	17.2 (15.0) 69.43	17.2	19.7						
Energy requirement at sending end (GWh)	14.04 (27.3) 17.88	(17.0) (14.1) 23.86	(16.6) (16.6) 27.82	(29.0) (29.0) 35.90	(23.2) (23.2) 44.23	(18.2) (18.2) 62.12	(16.1) (16.1) 72.10	21.1 (14.7) 82.71	16.9	19.4						
Loss factor (%)	18.0	17.6	17.4	17.3	17.2	16.9	16.6	16.5	16.4	16.2	16.0					
Load factor (%)	36	37	37	38	38	39	40	40	41	41	42					
Max. demand at sending end (MW)	4.41 (24.9) 5.50	(16.6) (12.7) 7.23	(15.2) (15.2) 8.33	(27.2) (27.2) 10.60	(20.5) (20.5) 12.78	(17.4) (17.4) 14.92	(14.1) (14.1) 19.97	19.4 (12.9) 22.55	15.3	17.7						

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (7) Load Forecast for the Sistema Esmeraldas

	Unit: GWh													
	(Estimated) 1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%) 1974-1980 1980-1984 1974-1984		
Energy demand at customers end (GWh)	4.24	(54.6) 6.56	(28.1) 8.40	(26.9) 10.66	(42.6) 15.20	(15.0) 17.48	(75.1) 30.61	(6.8) 32.70	(7.0) 35.00	(7.4) 37.59	(22.0) 45.86	39.0	10.6	26.9
Residential	4.26	(17.6) 5.00	(18.5) 5.93	(20.0) 7.12	(21.7) 8.66	(24.0) 10.74	(26.4) 13.58	(28.3) 17.43	(25.0) 21.79	(21.5) 26.47	(19.3) 31.58	21.3	23.5	22.2
Commercial	2.13	(18.4) 2.52	(19.8) 3.02	(21.1) 3.66	(22.7) 4.49	(24.5) 5.59	(26.8) 7.09	(27.3) 9.02	(25.3) 11.30	(21.4) 13.72	(18.2) 16.22	22.2	23.0	22.5
Others	1.45	(17.5) 1.71	(14.2) 1.95	(14.2) 2.23	(13.0) 2.52	(13.2) 2.85	(12.4) 3.20	(11.0) 3.55	(10.0) 3.91	(10.0) 4.30	(9.9) 4.73	14.1	10.2	12.5
Subtotal	12.08	(30.7) 15.79	(22.2) 19.30	(22.6) 23.67	(30.4) 30.87	(18.8) 36.06	(48.6) 54.48	(15.1) 62.70	(14.8) 72.00	(14.0) 82.08	(19.9) 98.39	28.5	15.9	23.3
Energy requirement at sending end (GWh)	15.28	(30.0) 19.86	(21.5) 24.13	(22.0) 29.44	(29.8) 38.21	(18.2) 45.16	(47.8) 66.74	(14.5) 76.41	(14.2) 87.27	(13.4) 98.99	(19.3) 118.09	27.9	15.3	22.7
Loss factor (%)	20.9	20.4	20.0	19.6	19.2	18.8	18.3	17.9	17.5	17.0	16.6			
Load factor (%)	38	41	42	44	48	48	53	52	51	51	51			
Max. demand at sending end (MW)	4.64	(19.9) 5.56	(16.8) 0.49	(16.9) 7.39	(19.5) 9.06	(17.4) 10.64	(34.2) 14.27	(17.8) 16.81	(16.2) 19.54	(13.6) 22.19	(18.2) 26.23	20.6	16.4	18.9

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (8) Load Forecast for the Sistema Manabí

	Unit : GWh													
	(Estimated) 1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984
Energy demand at customers end (GWh)														
Industry	7.66	(30.1) 10.42	(61.3) 16.81	(39.4) 23.43	(7.9) 25.29	(8.2) 27.37	(22.6) 33.55	(7.7) 36.13	(7.9) 38.97	(8.0) 42.10	(8.2) 45.55	27.9	7.9	19.5
Residential	14.02	(22.4) 17.17	(23.8) 21.25	(22.2) 25.95	(22.7) 31.84	(20.8) 38.45	(18.1) 45.42	(16.6) 52.94	(14.0) 60.37	(13.0) 68.22	(12.2) 76.57	21.6	13.9	18.5
Commercial	7.07	(15.8) 8.18	(18.6) 9.70	(16.9) 11.34	(18.3) 13.42	(17.0) 15.70	(15.1) 18.07	(14.5) 20.68	(12.8) 23.34	(11.6) 26.05	(11.0) 28.92	16.9	12.5	15.1
Others	4.59	(10.0) 5.04	(10.4) 5.57	(10.2) 6.14	(8.4) 6.65	(8.5) 7.22	(8.4) 7.82	(7.4) 8.40	(7.3) 9.01	(7.1) 9.66	(7.0) 10.33	9.3	7.2	8.5
Subtotal	33.34	(22.4) 40.31	(30.6) 53.33	(25.4) 66.86	(15.5) 77.20	(15.0) 88.74	(18.2) 104.96	(12.7) 118.15	(11.5) 131.69	(10.9) 146.03	(10.5) 161.37	21.0	11.4	17.1
Energy requirement at sending end (GWh)	43.09	(21.0) 52.87	(29.1) 68.26	(23.9) 84.58	(14.2) 96.59	(13.9) 109.99	(17.1) 128.75	(11.4) 143.47	(10.7) 158.89	(10.3) 175.27	(10.2) 192.84	19.7	10.6	16.0
Loss factor (%)	23.6	22.8	21.8	20.9	20.0	19.3	18.5	17.6	17.1	16.6	16.3			
Load factor (%)	43	44	45	46	46	47	48	48	48	47	47			
Max. demand at sending end (MW)	11.66	(17.8) 13.74	(26.2) 17.33	(20.9) 20.96	(13.2) 23.72	(13.0) 26.80	(14.7) 30.74	(11.5) 34.29	(11.2) 38.14	(10.7) 42.22	(10.4) 46.59	17.5	11.0	14.9

Note : Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (9) Load Forecast for the Sistema Guayas-Los Rios

Unit: GWh

	Increase (%)													
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1984	1980-1984	1974-1984
Energy demand at customers end (GWh)	178.57	(28.3)	(24.8)	(21.8)	(23.5)	(14.9)	(12.0)	(10.1)	(10.6)	(11.2)	(11.3)	20.7	10.8	16.7
Industry		259.05	285.95	348.17	430.09	494.06	553.16	609.22	674.03	749.50	833.97			
Residencial	191.65	(12.1)	(12.9)	(12.4)	(12.7)	(13.1)	(13.0)	(10.8)	(10.5)	(10.3)	(10.1)	12.7	10.5	11.8
Commercial	87.32	(13.0)	(13.1)	(12.7)	(13.0)	(12.8)	(12.5)	(9.1)	(8.9)	(8.8)	(8.6)	12.9	8.9	11.3
Others	51.76	(6.7)	(6.7)	(6.3)	(6.4)	(6.4)	(6.3)	(6.1)	(6.1)	(6.1)	(6.1)	6.5	6.1	6.3
Subtotal	509.30	(17.4)	(17.0)	(15.8)	(16.9)	(13.4)	(12.0)	(10.9)	(10.1)	(10.3)	(10.2)	15.4	10.1	13.3
Energy requirement at sending end (GWh)	579.48	(17.2)	(16.8)	(15.6)	(16.8)	(13.3)	(11.9)	(9.8)	(9.9)	(10.1)	(10.1)	15.3	10.0	13.1
		679.39	793.69	917.70	1,071.90	1,213.97	1,358.07	1,491.68	1,640.09	1,806.23	1,988.38			
Loss factor (%)	12.1	12.0	11.9	11.8	11.7	11.6	11.5	11.4	11.3	11.2	11.1			
Load factor (%)	49	49	49	49	50	50	50	50	50	50	50			
Max. demand at sending end (MW)	135.97	(16.4)	(16.8)	(14.9)	(16.2)	(12.9)	(12.0)	(9.7)	(9.7)	(9.9)	(9.7)	14.9	9.7	12.8
		158.26	184.92	212.53	246.96	278.88	312.42	342.63	375.88	413.21	453.01			

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (10) Load Forecast for the Sistema El Oro

	Unit: GWh														
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	1974-1980	1980-1984	1974-1984	
Energy demand at customers end (GWh)															
Industry	5.04	(42.1) 7.16	(54.5) 11.05	(30.4) 14.41	(18.8) 17.13	(9.6) 18.77	(10.7) 20.78	(9.9) 22.85	(10.0) 25.14	(10.1) 27.69	(10.2) 30.51	26.6	10.1	19.7	
Residential	6.58	(17.0) 7.70	(18.2) 9.11	(17.6) 10.71	(18.6) 12.71	(17.5) 14.94	(16.9) 17.46	(18.8) 20.75	(18.9) 24.67	(18.0) 29.11	(17.3) 34.13	17.6	18.2	17.9	
Commercial	5.07	(13.5) 5.75	(14.0) 6.56	(13.4) 7.44	(13.7) 8.46	(12.9) 9.55	(11.7) 10.67	(12.9) 12.04	(11.5) 13.43	(12.2) 15.07	(12.7) 10.99	13.2	12.3	12.9	
Others	1.44	(20.2) 1.74	(18.8) 2.06	(15.8) 2.39	(14.0) 2.72	(13.7) 3.09	(11.6) 3.45	(12.4) 3.88	(12.1) 4.35	(11.0) 4.82	(11.0) 5.35	15.0	11.0	14.0	
Subtotal	18.13	(23.1) 22.35	(28.8) 28.78	(21.4) 34.95	(17.3) 41.01	(13.0) 46.35	(13.0) 52.36	(13.7) 59.52	(13.6) 67.59	(13.5) 76.69	(13.4) 86.98	19.3	13.5	17.0	
Energy requirement at sending end (GWh)	22.39	(23.0) 27.55	(28.1) 35.28	(20.9) 42.66	(16.6) 49.75	(12.7) 56.08	(12.4) 63.03	(13.2) 71.32	(13.2) 80.76	(13.1) 91.37	(13.1) 103.34	18.8	13.2	16.5	
Loss factor (%)	19.0	18.8	18.4	18.0	17.5	17.3	16.9	16.5	16.3	16.0	15.8				
Load factor (%)	37	37	38	38	39	40	40	41	42	42	43				
Max. demand at sending end (MW)	6.98	(20.7) 8.43	(25.3) 10.56	(20.3) 12.71	(14.6) 14.56	(10.6) 16.10	(10.5) 17.80	(11.5) 19.94	(11.5) 22.12	(11.3) 24.62	(11.3) 27.40	16.9	11.4	14.6	

Note: Figures in parenthesis indicate growth rate of the demand.

Table A - 1 - (11) Classification of Industrial Demand

Sistema	(Estimated)										1972-1982 1980-1984 1972-1984	Increase (%)	
	1976	1975	1976	1977	1978	1979	1980	1981	1982	1983			1984
(1) Norte	1.98	2.28	2.54	2.78	3.11	3.49	3.91	4.38	4.90	5.49	6.15	12.0	12.0
General	-	-	-	55.83	57.41	57.79	58.18	58.60	59.04	59.53	60.04		
Special	-	-	-	-	-	-	-	-	-	-	-		
Subtotal	1.98	2.28	2.54	58.61	60.52	61.28	62.09	62.98	63.94	65.02	66.19	77.6	42.0
(2) Pichincha	94.34	108.19	119.23	131.38	144.78	159.55	175.82	193.76	213.52	235.30	259.50	10.0	10.1
General	-	-	5.06	10.23	15.96	21.90	29.20	38.08	49.80	61.04	77.04		
Special	94.34	108.19	124.29	141.61	160.74	181.45	205.02	231.84	260.32	296.98	336.36	12.5	13.0
Subtotal	94.34	108.19	119.23	131.38	144.78	159.55	175.82	193.76	213.52	235.30	259.50	10.0	10.1
(3) Centro-Norte	31.38	33.71	36.20	38.87	41.76	44.85	48.17	51.74	55.57	59.68	64.09	7.4	7.4
General	-	-	-	-	-	-	-	-	-	-	-		
Special	31.38	33.71	36.20	38.87	41.76	44.85	48.17	51.74	55.57	59.68	64.09	7.4	7.4
Subtotal	31.38	33.71	36.20	38.87	41.76	44.85	48.17	51.74	55.57	59.68	64.09	7.4	7.4
(4) Centro-Sur	11.16	12.38	13.85	15.49	17.34	19.41	21.72	24.30	27.19	30.43	34.05	11.7	11.8
General	-	-	-	-	-	-	-	-	-	-	-		
Special	11.16	12.38	13.85	15.49	17.34	19.41	21.72	24.30	27.19	30.43	34.05	11.7	11.8
Subtotal	11.16	12.38	13.85	15.49	17.34	19.41	21.72	24.30	27.19	30.43	34.05	11.7	11.8
(5) Sur	1.86	2.08	2.33	2.60	2.91	3.26	3.65	4.08	4.57	5.11	5.72	11.9	11.9
General	-	-	-	-	-	-	-	-	-	-	-		
Special	1.86	2.08	2.33	2.60	2.91	3.26	3.65	4.08	4.57	5.11	5.72	11.9	11.9
Subtotal	1.86	2.08	2.33	2.60	2.91	3.26	3.65	4.08	4.57	5.11	5.72	11.9	11.9
(6) Emmeraldas	4.24	4.88	5.61	6.45	7.42	8.54	9.82	11.29	12.98	14.93	17.17	15.0	15.0
General	-	-	-	-	-	-	-	-	-	-	-		
Special	4.24	4.88	5.61	6.45	7.42	8.54	9.82	11.29	12.98	14.93	17.17	15.0	15.0
Subtotal	4.24	4.88	5.61	6.45	7.42	8.54	9.82	11.29	12.98	14.93	17.17	15.0	15.0
(7) Manabá	7.00	8.33	9.06	9.86	10.73	11.67	12.70	13.82	15.04	16.36	17.80	8.6	8.6
General	-	-	-	-	-	-	-	-	-	-	-		
Special	7.00	8.33	9.06	9.86	10.73	11.67	12.70	13.82	15.04	16.36	17.80	8.6	8.6
Subtotal	7.00	8.33	9.06	9.86	10.73	11.67	12.70	13.82	15.04	16.36	17.80	8.6	8.6
(8) Guayas - Non Lico	178.57	195.34	213.71	233.81	255.78	279.81	306.12	334.91	366.38	400.82	438.50	9.4	9.4
General	-	-	-	-	-	-	-	-	-	-	-		
Special	178.57	195.34	213.71	233.81	255.78	279.81	306.12	334.91	366.38	400.82	438.50	9.4	9.4
Subtotal	178.57	195.34	213.71	233.81	255.78	279.81	306.12	334.91	366.38	400.82	438.50	9.4	9.4
(9) El Oro	5.04	5.43	5.83	6.31	6.80	7.33	7.90	8.52	9.18	9.90	10.67	7.8	7.8
General	-	-	-	-	-	-	-	-	-	-	-		
Special	5.04	5.43	5.83	6.31	6.80	7.33	7.90	8.52	9.18	9.90	10.67	7.8	7.8
Subtotal	5.04	5.43	5.83	6.31	6.80	7.33	7.90	8.52	9.18	9.90	10.67	7.8	7.8
Total	341.23	372.58	406.38	447.57	498.44	557.92	626.78	708.32	804.78	918.00	1053.44	9.6	9.7
General	-	-	-	-	-	-	-	-	-	-	-		
Special	341.23	372.58	406.38	447.57	498.44	557.92	626.78	708.32	804.78	918.00	1053.44	9.6	9.7
Subtotal	341.23	372.58	406.38	447.57	498.44	557.92	626.78	708.32	804.78	918.00	1053.44	9.6	9.7

Unit: GWh

Table A - 1 - (12) Ratio of Energy Demand by Customers (1 - 3)

Sistema	Customers	(Estimated)											(Unit : %)
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	
1 Norte	Industry	10.3	10.4	10.5	70.6	68.7	66.3	65.7	61.6	59.4	57.2	54.9	
	Residential	44.5	45.4	46.2	15.5	16.8	18.5	20.2	21.7	23.2	24.7	26.2	
	Commercial	21.7	22.1	22.5	7.5	8.1	8.8	9.6	10.3	11.1	11.9	12.8	
	Others	23.5	22.1	20.8	6.4	6.4	6.4	6.5	6.4	6.3	6.2	6.1	
2 Pichincha	Industry	30.8	30.5	31.4	31.9	32.4	32.8	33.2	33.6	34.1	34.5	35.0	
	Residential	49.6	49.8	49.3	42.9	42.5	42.3	42.0	41.8	41.5	41.2	41.0	
	Commercial	15.3	15.7	15.7	15.9	16.2	16.3	16.5	16.7	16.8	17.0	17.0	
	Others	10.3	10.0	9.6	9.3	8.9	8.6	8.3	7.9	7.6	7.3	7.0	
3 Centro-Norte	Industry	40.1	42.6	44.0	43.7	52.5	51.1	50.5	49.6	49.2	48.2	47.3	
	Residential	30.9	30.8	31.3	32.5	28.2	29.9	30.9	32.0	32.8	33.9	35.0	
	Commercial	17.6	16.4	15.4	15.1	12.4	12.3	12.2	12.2	12.1	12.2	12.2	
	Others	11.4	10.2	9.3	8.7	6.9	6.7	6.4	6.2	5.9	5.7	5.5	
4 Centro-Sur	Industry	29.9	28.5	29.2	47.6	47.1	44.7	46.8	45.7	44.8	44.0	43.2	
	Residential	51.3	51.5	51.5	37.9	38.1	39.4	37.5	38.3	39.1	39.7	40.4	
	Commercial	9.6	10.1	10.6	8.2	8.7	9.5	9.6	10.1	10.5	10.9	11.3	
	Others	9.2	8.9	8.7	6.3	6.1	6.4	6.1	5.9	5.6	5.4	5.1	

Table A - 1 - (12) Ratio of Energy Demand by Customers. (2 - 3)

Sistema	Customers	(Estimated)													(Unit : %)
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984			
5 Sur	Industry	16.1	27.5	30.4	30.2	30.5	36.9	38.7	36.2	33.7	31.7	30.3			
	Residential	31.6	28.6	28.9	30.6	32.3	31.1	31.9	35.1	38.1	40.6	42.6			
	Commercial	24.8	21.5	20.8	20.9	20.8	18.6	17.9	18.4	18.9	19.2	19.3			
	Others	27.5	22.4	19.9	18.3	16.4	13.4	11.5	10.3	9.3	8.5	7.8			
6 Esmeraldas	Industry	35.1	41.5	43.5	45.0	49.2	47.7	56.2	52.1	48.6	45.8	46.6			
	Residential	35.2	31.7	30.7	30.1	28.1	29.3	24.9	27.8	30.3	32.3	32.1			
	Commercial	17.7	16.0	15.7	15.5	14.5	15.2	13.0	14.4	15.7	16.7	16.5			
	Others	12.0	10.8	10.1	9.4	8.2	7.8	5.9	5.7	5.4	5.2	4.8			
7 Manabí	Industry	23.0	25.5	31.5	35.0	32.7	30.8	32.0	30.6	29.6	28.8	28.2			
	Residential	42.1	42.1	39.8	38.8	41.3	43.4	43.4	44.8	45.9	46.7	47.5			
	Commercial	21.2	20.0	18.2	17.0	17.4	17.7	17.2	17.5	17.7	17.9	17.9			
	Others	13.7	12.4	10.5	9.2	8.6	8.1	7.5	7.1	6.8	6.6	6.4			
8 Guayas -Los Rios	Industry	35.1	38.3	40.9	43.0	45.4	46.0	46.0	46.1	46.3	46.7	47.2			
	Residential	37.6	35.9	34.7	33.7	32.5	32.4	32.7	32.9	33.1	33.1	33.0			
	Commercial	17.1	16.5	16.0	15.6	15.0	15.0	15.0	14.9	14.8	14.6	14.4			
	Others	10.2	9.3	8.4	7.7	7.1	6.6	6.3	6.1	5.8	5.6	5.4			

Table A - 1 - (12) Ratio of Energy Demand by Customers (3 - 3)

Sistema	Customers	(Estimated)													(Unit : %)
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984			
9 El Oro	Industry	27.8	32.0	38.4	41.2	41.8	40.5	39.7	38.4	37.2	36.1	35.1			
	Residential	36.3	34.5	31.6	30.7	31.0	32.2	33.3	34.9	36.5	38.0	39.2			
	Commercial	27.9	25.7	22.8	21.3	20.6	20.6	20.4	20.2	19.9	19.6	19.5			
	Others	8.0	7.8	7.2	6.8	6.6	6.7	6.6	6.5	6.4	6.3	6.2			
Total	Industry	32.8	34.9	37.0	41.2	43.2	43.1	43.3	42.9	42.8	42.6	42.7			
	Residential	39.6	38.6	37.6	35.4	34.4	34.7	34.9	35.4	35.7	36.1	36.3			
	Commercial	16.8	16.5	16.1	15.1	14.8	14.9	14.9	15.1	15.1	15.1	15.1			
	Others	10.9	10.0	9.3	8.3	7.6	7.3	6.9	6.6	6.4	6.2	5.9			

Table A-1-(13) Number of Customers and Energy Demand per Customers (1-5)

	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%)		
												1974-1980	1980-1984	1974-1984
Sistema Norte														
Number of customers (10 ³)	20.55	22.19	24.02	26.04	28.36	30.98	33.91	36.02	38.22	40.53	42.99	8.7	6.1	7.7
Requirement per customers (kWh/customer)	4.17	4.40	4.65	4.92	5.22	5.51	5.81	6.10	6.51	6.93	7.35	5.7	6.1	5.8
Number of customers (10 ³)	3.52	3.79	4.10	4.43	4.82	5.26	5.73	6.10	6.51	6.94	7.39	8.5	6.6	7.7
Requirement per customers (kWh/customer)	1.184	1.257	1.329	1.400	1.473	1.548	1.626	1.732	1.842	1.900	2.089	5.4	6.5	5.8
Population (10 ³)	330	336	343	350	357	364	371	378	386	394	401	2.0	2.0	2.0
Requirement per capital (kWh/capita)	13.7	14.1	14.7	15.2	15.7	16.3	17.0	17.3	17.6	17.9	18.2	3.7	1.7	2.9
Sistema Pichincha														
Number of customers (10 ³)	89.43	95.36	101.54	108.97	116.09	125.15	134.49	144.79	156.30	168.07	180.31	7.0	7.6	7.3
Requirement per customers (kWh/customer)	1.572	1.630	1.689	1.748	1.807	1.868	1.931	1.993	2.050	2.115	2.186	3.3	3.2	3.4
Number of customers (10 ³)	16.01	16.99	18.05	19.36	20.76	22.22	23.85	25.61	27.57	29.37	31.09	6.9	6.9	6.9
Requirement per customers (kWh/customer)	3.074	3.275	3.457	3.654	3.858	4.071	4.291	4.519	4.701	4.986	5.257	5.7	5.2	5.5
Population (10 ³)	936	978	1,019	1,068	1,115	1,164	1,215	1,269	1,325	1,383	1,444	4.4	4.4	4.4
Requirement per capital (kWh/capita)	35.4	36.4	37.4	38.6	39.7	40.9	42.1	43.2	44.3	45.6	46.9	2.9	2.7	2.9

Table A-1-(13) Number of Customers and Energy Demand per Customers (2-5)

	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%)		
												1974-1980	1980-1984	1974-1984
Sistema Centro Norte														
Number of customers (10 ³)	37.19	41.44	40.18	51.61	58.09	65.33	73.43	80.52	87.86	96.23	105.75	12.0	9.5	11.0
Requirement per customers (kWh/customer)	651	688	732	769	802	833	863	894	927	961	993	4.8	3.6	4.3
Number of customers (10 ³)	11.18	11.86	12.56	13.32	14.17	14.99	15.93	16.68	17.45	18.35	19.37	6.1	5.0	5.7
Requirement per customers (kWh/customer)	1,232	1,277	1,329	1,384	1,441	1,500	1,562	1,639	1,722	1,805	1,891	4.0	4.9	4.4
Population (10 ³)	965	986	1,006	1,027	1,050	1,073	1,097	1,121	1,145	1,171	1,199	2.2	2.2	2.2
Requirement per capital (kWh/capital)	9.2	9.5	9.9	10.4	10.9	11.4	12.0	12.4	12.9	13.3	13.7	4.5	3.4	4.1
Sistema Centro Sur														
Number of customers (10 ³)	20.30	22.77	25.79	29.52	34.11	39.89	47.11	50.76	54.62	59.01	63.98	15.1	8.0	12.2
Requirement per customers (kWh/customer)	945	948	950	947	942	934	931	970	1,011	1,124	1,090	-0.2	4.0	1.4
Number of customers (10 ³)	2.55	2.93	3.41	4.01	4.78	5.79	7.15	7.78	8.47	9.26	10.16	18.7	9.2	14.8
Requirement per customers (kWh/customer)	1,413	1,444	1,474	1,503	1,529	1,555	1,576	1,661	1,749	1,835	1,917	1.8	5.0	3.1
Population (10 ³)	503	515	527	540	553	566	579	593	607	621	636	2.4	2.4	2.4
Requirement per capital (kWh/capital)	6.8	7.3	7.9	8.6	9.4	10.7	12.3	12.7	13.1	13.5	13.9	10.4	3.1	7.4

Table A-1-(13) Number of Customers and Energy Demand per Customers (4-5)

	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%)		
												1974-1980	1980-1984	1974-1984
Manabí														
Number of customers (10 ³)	17.96	20.61	24.13	28.01	32.67	37.54	42.32	47.57	52.49	57.45	62.55	15.4	10.3	13.3
Residential														
Requirement per customers (kWh/customer)	781	833	880	927	975	1,025	1,073	1,113	1,150	1,188	1,224	5.4	3.3	4.6
Commercial														
Number of customers (10 ³)	5.72	6.13	6.79	7.52	8.44	9.33	10.14	11.18	12.11	12.93	13.72	10.0	7.9	9.1
Requirement per customers (kWh/customer)	1,236	1,335	1,429	1,507	1,589	1,682	1,782	1,850	1,927	2,015	2,108	6.3	4.3	5.5
Others														
Population (10 ⁵)	745	759	774	789	804	819	835	851	867	884	901	1.9	1.9	1.9
Requirement per capital (kWh/capital)	6.2	6.6	7.2	7.8	8.3	8.8	9.4	9.9	10.4	10.9	11.5	7.2	5.2	6.4
Sistema Guayas-Los Rios														
Number of customer (10 ³)	132.53	144.30	159.77	177.12	197.53	222.77	248.51	268.71	288.74	307.77	326.01	11.0	7.0	9.4
Residential														
Requirement per customers (kWh/customer)	1,446	1,489	1,519	1,540	1,556	1,561	1,580	1,620	1,660	1,724	1,793	1.5	3.2	2.2
Commercial														
Number of customers (10 ³)	25.59	27.64	30.29	33.32	37.17	41.65	46.32	48.66	51.03	53.32	55.49	10.4	4.6	8.0
Requirement per customers (kWh/customer)	3,412	3,571	3,686	3,778	3,828	3,854	3,900	4,052	4,209	4,382	4,574	2.3	4.1	3.0
Others														
Population (10 ⁵)	1,969	2,035	2,102	2,174	2,246	2,321	2,396	2,476	2,560	2,645	2,732	3.3	3.3	3.3
Requirement per capital (kWh/capital)	26.3	27.1	28.1	28.8	29.7	30.6	31.5	32.3	33.2	34.1	35.0	3.1	2.7	2.9

Table A-1-(13) Number of Customer and Energy Demand per Customers (S-5)


	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	Increase (%)		
												1974-1980	1980-1984	1974-1984
Sistema El Oro														
Number of customers (10 ³)	10.88	12.22	13.84	15.60	17.70	19.97	22.43	25.55	29.15	33.08	37.39	12.8	13.6	13.1
Requirement per customers (kWh/customer)	605	631	658	687	718	748	778	812	846	880	913	4.3	4.1	4.2
Number of customers (10 ³)	4.54	4.97	5.46	5.96	6.49	7.06	7.58	8.20	8.70	9.20	9.74	8.9	6.5	7.9
Requirement per customers (kWh/customer)	1.116	1.157	1.201	1.247	1.303	1.353	1.407	1.469	1.544	1.638	1.744	3.9	5.5	4.6
Commercial														
Population (10 ³)	260	271	282	294	306	318	331	344	358	372	387	4.1	4.0	4.1
Requirement per capital (kWh/capital)	5.6	6.4	7.3	8.1	8.9	9.7	10.4	11.3	12.1	13.0	13.8	10.9	7.3	9.4
Total														
Number of customers (10 ³)	342.05	373.42	411.53	455.44	506.76	567.20	633.22	692.39	754.70	818.20	883.89	10.8	8.7	10.0
Requirement per customers (kWh/customer)	1.207	1.243	1.275	1.303	1.327	1.346	1.370	1.406	1.444	1.487	1.535	2.1	2.9	2.4
Commercial														
Number of customers (10 ³)	72.55	78.07	84.84	92.63	102.01	112.51	124.03	133.01	142.39	151.51	160.53	9.3	6.7	8.3
Requirement per customers (kWh/customer)	2.415	2.538	2.641	2.740	2.827	2.906	2.990	3.109	3.224	3.368	3.515	3.6	4.1	3.8
Others														
Population (10 ³)	6,289	6,479	6,670	6,878	7,087	7,301	7,521	7,750	7,988	8,232	8,484	3.0	3.1	3.0
Requirement per capital (kWh/capital)	17.9	18.6	19.4	20.2	21.0	21.9	22.8	23.6	24.4	25.3	26.1	4.1	3.4	3.8

マクロ手法による需要想定の試算

GNP の倍加速度と電力需要の倍加速度は、相互に関連し合うので、電力需要の対GNP 弾性値を用いて電力需要を試算する。


(1) GNP および電力需要の実績ならびに電力需要の対GNP 弾性値 1965 年から 1973 年までのGNP および電力需要の実績は Fig A-1-1-(1)のとおりである。

Fig. A-1-(1) Historical Trend of GNP and Energy Demand at Customer end



また、年度別弾性値は Fig. A-1-1-(1)

Fig. A-1-(2) Elastic Coefficient between GNP and Energy Demand by Year



次に弾性値の期間移動による推移は Table A-1-1-(1)に示すとおりである。

Table A-1-1-(1) Elastic Coefficient between GNP and Energy Demand by Various Period

	→ from									
	'65	'66	'67	'68	'69	'70	'71	'72	'73	
'65										
'66	0.84									
'67	1.21	1.57								
'68	1.50	1.81	2.04							
'69	1.63	1.92	2.07	2.09						
'70	1.58	1.78	1.86	1.73	1.39					
'71	2.17	2.59	3.08	3.79	8.64	-				
'72	1.58	1.71	1.75	1.66	1.53	1.56	0.53			
'73	1.05	1.07	1.01	0.89	0.73	0.62	0.35	0.25		

これによると、1971年にはGNPは落込んでいるにも拘らず(-4.2%)、電力需要は9.8%の増加となっている。

一方、1972年、1973年には石油生産の開始、増産に伴ってGNPは著増(それぞれ名目伸率17.4%、35%)したにも拘らず、電力需要は安定的に増加している(1972年9.3%、1973年8.9%)。即ち、GNPの大幅な変動に対しては電力需要はやゝ硬直的であると云える。

このことはGNPのフローについて掘り下げた検討を要するが、電力需要面からみた場合

- ① 特に地方電化計画のように経済投資というよりは、むしろインフラ整備の一環であり、政策的側面からの実施課題であるので、これによる電力需要はGNPの大幅変動に対してはやゝ硬直性をもつと考えられる。
- ② GNPのなかで占める総資本形成(1972年US\$364×10⁶、GNP比19%、1973年US\$416×10⁶、GNP比16%)にくらべて工業生産(1972年US\$459×10⁶、1973年US\$714×10⁶)のなかで占める資本財・耐久消費財の割合(1971年5.9%)が極めて低く、資本財・耐久消費財の殆どは輸入に依存せざるを得ない経済構造のため投資による経済刺激から電力需要の顕在化までにはかなりのタイムラグが考えられる。したがってTable A-1-1-(IX)にみられる弾性値の低下傾向はすう勢的なものとは考えられず、いずれ上昇過程に移ることが予想される。

(2) 弾性値の見通し

以上により、1971年～1973年の各年度の弾性値は特異な要素を含むもので、試算に用いるべき弾性値として単年度を用いるのは、必ずしも適当ではないと考えられる。

今後の弾性値を左右する主な要因に地方電化計画が考えられるが、地方電化計画はしばしば触れたように電力の普及事業であり、特に1980年頃までの第1次段階では経済の実質的成長速度に比し電力需要の成長速度は大きいことが予想される。1980年以降の第2次段階では総需要自体が増大した後でもあるので、地方電化による需要の成長速度は第1次段階にくらべ相対的に低下傾向に推移することが予想される。

よって今回の試算に用いるべき弾性値のうち、1975年から1980年までは、弾性値表にみられる1965～1970年の弾性値1.58を用い、1981年から1984年までは、同表の1965年から1973年の弾性値1.05を用いることとする。

(3) 経済成長の見通し

1972年に発表された「総合開発5ヶ年計画(1973~1977)」によれば、今後の経済見通しとして実質10%の経済成長率を想定している。一方、最近の実績によると、実質成長率は1972年10.4%、1973年12.0%、1974年13.0%(推定)となっている。

エクアドルの経済は、石油の動向に左右される体質をもっているため、最近における世界的な石油需給面の緩和傾向を考慮すると、今後の経済成長はかなり流動的な要素を含んでいる。一方また、石油生産開始以来の総合収支における黒字基調、および政策当局による諸施策をも総合勘案すれば、今後の経済成長率は少なくとも10%は、期待し得るものと考えられる。

(4) 試算結果

以上の想定条件により算定された結果は、Table A-1-1-(2)に示すとおりである。

Table A-1-1-(2) Load Forecast (by macro-method)

Year	Energy demand at customer end (MWh)
1974	1,041,488
1975	1,206,043
1976	1,396,598
1977	1,617,260
1978	1,872,787
1979	2,168,688
1980	2,511,340
1981	2,775,031
1982	3,066,409
1983	3,388,382
1984	3,744,162

(6) 今回想定結果と試算結果との比較

第4章の想定結果と、前項(4)の試算結果を比較すれば、Table A-1-1-(3)に示す通りである。

Table A-1-1-(3) Comparison of Results between Analytical Method and Macro Method

Year	Energy Demand at Customer end		Deviation $\frac{B-A}{A} \times 100 (\%)$
	Analytical Method (A)	Macro Method (B)	
1974	1,041,488	1,041,488	-
1975	1,202,203	1,206,043	0.3
1976	1,393,865	1,396,598	0.2
1977	1,677,620	1,617,260	3.6
1978	1,952,242	1,872,787	4.1
1979	2,197,336	2,168,688	1.3
1980	2,487,802	2,511,340	0.9
1981	2,751,876	2,775,031	0.8
1983	3,373,564	3,388,382	0.4
1984	3,738,602	3,744,162	0.1

Note: 1. Elastic Value between GNP and Energy Demand at Customer end
1975 - 1980 ; 1.58
1981 - 1984 ; 1.05

2. Annual growth rate of GNP ; 10 %

Table A-1-1-(3)にみられるように、第4章の想定と、マクロ手法による試算、いずれの手法によっても、想定値に大差はみられない。

APPENDIX

A - 2 Supply Capability from 1975 to 1984 and Supply Capability of Existing Power Plants at the End of 1974

Table A-2

(1)	Installed Capacity by Year (1975 to 1984)	A-27
(2)	Dependable Power Supply Capability in National Interconnected System	A-30
(3)	Summary of Dependable Power Supply Capability in National Interconnected System	A-33
(4)	Existing Power Plants in Sistema Norte	A-35
(5)	Existing Power Plants in Sistema Pichincha	A-36
(6)	Existing Power Plants in Sistema Centro-Norte	A-37
(7)	Existing Power Plants in Sistema Centro-Sur	A-38
(8)	Existing Power Plants in Sistema Sur	A-38
(9)	Existing Power Plants in Sistema Esmeraldas	A-39
(10)	Existing Power Plants in Sistema Manabi	A-39
(11)	Existing Power Plants in Sistema Guayas-Los Rios	A-40
(12)	Existing Power Plants in Sistema El Oro	A-40
(13)	Summary of Dependable Supply Capability of Existing Power Plants	A-41
(14)	Dependable Supply Capability of Existing Power Plants	A-45

Table A - 2 - (1) Installed Capacity by Year (1975 to 1984) (1 - 3)

Subarea	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(1) Norte											
Hydro											
Reg.	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000	8,000
P-O-P	4,345	4,345	4,345	4,345	(- 3,034)	1,320	1,320	1,320	1,320	1,320	1,320
Sub-total	12,354	12,354	12,354	12,354	9,320	9,320	9,320	9,320	9,320	9,320	9,320
Thermal											
Diesel	1,409	1,409	1,409	(2,500)	3,909	3,909	3,909	3,909	3,909	3,909	3,909
Gas	0	0	0	0	0	0	0	0	0	0	0
Steam	0	0	0	0	0	0	0	0	0	0	0
Sub-total	1,409	1,409	1,409	3,909	3,909	3,909	3,909	3,909	3,909	3,909	3,909
Total	13,763	13,763	13,763	16,263	13,229	13,229	13,229	13,229	13,229	13,229	13,229
(2) Pichincha											
Hydro											
Reg.	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400	79,400
P-O-P	3,760	8,260	8,260	8,260	8,260	8,260	8,260	8,260	8,260	8,260	8,260
Sub-total	83,160	87,660	87,660	87,660	87,660	87,660	87,660	87,660	87,660	87,660	87,660
Thermal											
Diesel	35,630	(18,720)	(18,720+3,833)(-2,180+6,720)	46,025	46,025	(+2,180)	46,205	46,205	46,205	46,205	46,205
Gas	0	24,100	24,100	24,100	24,100	24,100	24,100	24,100	24,100	24,100	24,100
Steam	0	0	0	0	0	0	0	0	0	0	0
Sub-total	35,630	68,450	63,385	70,125	70,125	72,305	72,305	72,305	72,305	72,305	72,305
Total	118,790	156,110	151,245	157,785	157,785	159,965	159,965	159,965	159,965	159,965	159,965
(3) Centro-Norte											
Hydro											
Reg.	0	0	0	0	0	0	0	0	0	0	0
P-O-P	15,516	15,516	15,516	(2,600)	18,116	18,116	18,116	18,116	18,116	18,116	18,116
Sub-total	15,516	15,516	15,516	18,116	18,116	18,116	18,116	18,116	18,116	18,116	18,116
Thermal											
Diesel	8,989	(7,000)	(8,720+1,500) (- 8,720+2,500)	19,989	19,989	19,989	19,989	19,989	19,989	19,989	19,989
Sub-total	8,989	15,989	20,209	19,989	19,989	19,989	19,989	19,989	19,989	19,989	19,989
Total	24,505	31,505	41,725	38,105	38,105	38,105	38,105	38,105	38,105	38,105	38,105
(4) Centro-Sur											
Hydro											
Reg.	0	0	0	(8,000)	8,000	8,000	8,000	8,000	8,000	8,000	8,000
P-O-P	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432	6,432
Sub-total	6,432	6,432	6,432	14,432	14,432	14,432	14,432	14,432	14,432	14,432	14,432
Thermal											
Diesel	10,820	(2,260)	(6,520)	21,620	21,620	21,620	21,620	21,620	21,620	21,620	21,620
Sub-total	10,820	15,100	21,620	21,620	21,620	21,620	21,620	21,620	21,620	21,620	21,620
Total	17,252	19,532	28,052	36,052	36,052	36,052	36,052	36,052	36,052	36,052	36,052

Table A - 2 - (1) Installed Capacity by Year (1975 to 1984) (2-3)

Sistema	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(Unit: kW)											
(5) Sac											
Hydro											
R-O-F	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400
Sub-total	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400	2,400
Thermal											
Diesel	2,400	(1,280)	(2,500)	6,186	6,186	(5,000)	11,186	11,186	11,186	11,186	11,186
Sub-total	2,400	3,686	6,186	6,186	6,186	11,186	11,186	11,186	11,186	11,186	11,186
Total	4,800	6,086	8,586	8,586	8,586	13,586	13,586	13,586	13,586	13,586	13,586
(6) Esmeraldas											
Thermal											
Diesel	4,860	(5,460)	(6,000)	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320
Total	4,860	10,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320	16,320
(7) Manabí											
Thermal											
Diesel	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600	20,600
Gas	0	0	0	(10,000)	10,000	10,000	10,000	10,000	10,000	10,000	10,000
Total	20,600	20,600	20,600	30,600	30,600	30,600	30,600	30,600	30,600	30,600	30,600
(8) Quayas-Los Rios											
Thermal											
(Quayaquil)											
Diesel	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640	7,640
Gas	55,500	(21,500)	(21,500)	(21,500)	120,000	120,000	120,000	120,000	120,000	120,000	120,000
Steam	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000	63,000
Sub-total	126,140	147,640	169,140	190,640	190,640	190,640	190,640	190,640	190,640	190,640	190,640
Thermal (Others)											
Diesel	16,886	(6,480)	(18,160)	44,706	44,706	(- 2,180)	42,526	42,526	42,526	42,526	42,526
Sub-total	16,886	23,366	41,526	44,706	44,706	42,526	42,526	42,526	42,526	42,526	42,526
Total	143,026	171,006	210,666	235,346	235,346	233,166	233,166	233,166	233,166	233,166	233,166

Table A - 2 - (2) Dependable Power Supply Capability in National Interconnected System (1 - 3)

System	Installed Capacity (kW)	(Unit: MW)											
		1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	
A. Regional System													
(1) Norte													
Existing power plants	H 9,320	7.14	-	-	13.62	10.93	10.93	10.93	10.93	10.93	10.93	10.93	10.93
"	T 3,084	2.69	-	-	7.14	7.14	7.14	7.14	7.14	7.14	7.14	7.14	7.14
"	T 1,409	1.37	-	-	2.69	1.37	1.37	1.37	1.37	1.37	1.37	1.37	1.37
"	T 2,500	-	-	-	2.24	2.24	2.24	2.24	2.24	2.24	2.24	2.24	2.24
New power plant (Boarra)	-	-	-	-	-	153.53	155.64	155.64	155.64	155.64	155.64	155.64	155.64
(2) Pichincha	-	-	-	-	145.76	145.76	147.87	147.87	147.87	147.87	147.87	147.87	147.87
Quito	-	-	-	-	112.74	82.20	82.20	82.20	82.20	82.20	82.20	82.20	82.20
Existing power plants	H 83,160	82.20	-	-	82.20	82.20	82.20	82.20	82.20	82.20	82.20	82.20	82.20
"	T 31,475	30.54	-	-	28.43	28.43	30.54	30.54	30.54	30.54	30.54	30.54	30.54
New power plant (Paschoa)	H 4,500	-	-	-	3.29	3.29	3.29	3.29	3.29	3.29	3.29	3.29	3.29
" (Lutuncoro)	T 8,720	-	-	-	8.46	8.46	8.46	8.46	8.46	8.46	8.46	8.46	8.46
" (Guangopolo)	T 24,100	-	-	-	23.38	23.38	23.38	23.38	23.38	23.38	23.38	23.38	23.38
Sto. Domingo	-	-	-	-	-	7.77	7.77	7.77	7.77	7.77	7.77	7.77	7.77
Existing power plants	T 4,155	4.03	-	-	4.03	4.03	4.03	4.03	4.03	4.03	4.03	4.03	4.03
New power plant (Sto. Domingo)	T 1,575	-	-	-	1.53	1.53	1.53	1.53	1.53	1.53	1.53	1.53	1.53
"	T 2,280	-	-	-	2.21	2.21	2.21	2.21	2.21	2.21	2.21	2.21	2.21
(3) Centro-Norte	-	-	-	-	-	-	-	-	-	-	-	-	-
Latacunga & 3 Other Cities	-	-	-	-	20.94	32.40	32.40	32.40	32.40	32.40	32.40	32.40	32.40
Existing power plants	H 15,416	20.51	-	-	31.48	31.48	31.48	31.48	31.48	31.48	31.48	31.48	31.48
"	T 8,633	12.13	-	-	12.13	12.13	12.13	12.13	12.13	12.13	12.13	12.13	12.13
New power plant (Latacunga)	T 1,000	-	-	-	8.38	8.38	8.38	8.38	8.38	8.38	8.38	8.38	8.38
" (")	T 2,500	-	-	-	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97
" (")	T 6,000	-	-	-	2.42	2.42	2.42	2.42	2.42	2.42	2.42	2.42	2.42
" (")	T 2,600	-	-	-	5.82	5.82	5.82	5.82	5.82	5.82	5.82	5.82	5.82
" (")	T 1,000	-	-	-	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79	0.79
Puyo	-	-	-	-	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97	0.97
Existing power plant	H 100	0.43	-	-	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92	0.92
"	T 356	0.35	-	-	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08
New power plant (Puyo)	-	-	-	-	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49
(4) Centro-Sur	-	-	-	-	-	-	-	-	-	-	-	-	-
Existing power plants	H 6,432	4.91	-	-	-	-	-	-	-	-	-	-	-
"	T 10,320	10.50	-	-	-	-	-	-	-	-	-	-	-
New power plant (Cuenca)	H 8,000	-	-	-	-	-	-	-	-	-	-	-	-
" (")	T 2,280	-	-	-	-	-	-	-	-	-	-	-	-
" (")	T 8,520	-	-	-	-	-	-	-	-	-	-	-	-

Note: H: Hydro power plant
T: Thermal power plant

Table A - 2 - (2) Dependable Power Supply Capability in National Interconnected System (2 - 3)
(Unit: kW)

Sistema	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(5) Sur											
Existing power plant	4.72	-	-	-	-	-	-	13.24	13.24	13.24	13.24
"	2,400	-	-	-	-	-	-	2.39	2.39	2.39	2.39
New power plant (Loja)	2.33	-	-	-	-	-	-	2.33	2.33	2.33	2.33
" (")	1,280	-	-	-	-	-	-	1.24	1.24	1.24	1.24
" (Catamayo)	-	-	-	-	-	-	-	4.85	4.85	4.85	4.85
"	2,500	-	-	-	-	-	-	2.43	2.43	2.43	2.43
(6) Esmeraldas											
Existing power plants	4.71	-	-	-	-	-	-	15.83	15.83	15.83	15.83
"	4,860	-	-	-	-	-	-	4.71	4.71	4.71	4.71
New power plant (Esmeraldas)	4.71	-	-	-	-	-	-	5.30	5.30	5.30	5.30
" (")	-	-	-	-	-	-	-	5.82	5.82	5.82	5.82
(7) Manabi											
Existing power plants	19.98	-	-	-	-	29.68	29.68	29.68	29.68	29.68	29.68
"	20,000	-	-	-	-	19.98	19.98	19.98	19.98	19.98	19.98
New power plant (Manta)	19.98	-	-	-	-	9.70	9.70	9.70	9.70	9.70	9.70
(8) Guayas-Los Rios											
Existing power plants	138.74	-	-	-	215.60	226.20	226.20	226.20	226.20	226.20	226.20
"	133.65	-	-	-	215.60	215.60	215.60	215.60	215.60	215.60	215.60
New power plant (Quayequil)	133.65	-	-	-	133.65	133.65	133.65	133.65	133.65	133.65	133.65
" (")	21,500	-	-	-	20.86	20.86	20.86	20.86	20.86	20.86	20.86
" (")	21,500	-	-	-	20.86	20.86	20.86	20.86	20.86	20.86	20.86
" (Babahoyo)	21,500	-	-	-	20.86	20.86	20.86	20.86	20.86	20.86	20.86
" (Quevedo)	12,500	-	-	-	12.13	12.13	12.13	12.13	12.13	12.13	12.13
"	800	-	-	-	0.78	0.78	0.78	0.78	0.78	0.78	0.78
"	5,660	-	-	-	5.49	5.49	5.49	5.49	5.49	5.49	5.49
" (Vince)	1,000	-	-	-	0.97	0.97	0.97	0.97	0.97	0.97	0.97
Santa Elena											
Existing power plants	5.09	-	-	-	-	10.60	10.60	10.60	10.60	10.60	10.60
"	5,240	-	-	-	-	5.09	5.09	5.09	5.09	5.09	5.09
New power plant (Salinas)	5.09	-	-	-	-	5.51	5.51	5.51	5.51	5.51	5.51
(9) El Oro											
Existing power plants	7.05	-	-	-	-	-	-	18.36	18.36	18.36	18.36
"	2,234	-	-	-	-	-	-	0.81	0.81	0.81	0.81
New power plant (Machala)	6.24	-	-	-	-	-	-	6.24	6.24	6.24	6.24
"	5,660	-	-	-	-	-	-	5.49	5.49	5.49	5.49
"	6,000	-	-	-	-	-	-	5.82	5.82	5.82	5.82
Total (1) - (9) Systems	339.32	-	-	190.86	412.46	454.85	488.73	536.16	536.16	536.16	536.16
Hydro	112.35	-	-	108.24	105.63	105.63	118.54	121.74	121.74	121.74	121.74
Thermal	227.17	-	-	82.62	306.83	349.22	370.19	414.42	414.42	414.42	414.42

Note: H: Hydro power plant
T: Thermal power plant

Table A - 2 - (2) Dependable Power Supply Capability in National Interconnected System (3-3)

Sistema	(Unit: MW)											
	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	
B. National System Projects												
New power plants												
T				29.10	167.89	237.48	237.48	437.48	537.48	637.48	737.48	
T				29.10	29.10	29.10	29.10	29.10	29.10	29.10	29.10	
T					69.59	69.59	69.59	69.59	69.59	69.59	69.59	
H					69.20	69.20	69.20	69.20	69.20	69.20	69.20	
H						200.00	200.00	200.00	200.00	200.00	200.00	
H						100.00	100.00	100.00	100.00	100.00	100.00	
H						100.00	100.00	100.00	100.00	100.00	100.00	
G - Total (A+B)				219.96	580.35	692.33	726.21	973.64	1,073.64	1,173.64	1,273.64	
Hydro				108.24	174.83	174.83	187.74	390.94	490.94	490.94	490.94	
Thermal				111.72	405.52	517.50	538.47	582.70	582.70	682.70	782.70	

Note: H: Hydro power plant
T: Thermal power plant

Table A - 2 - (3) Summary of Dependable Power Supply Capability in National Interconnected System (1 - 2)

Sistema	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(Unif: GWh)											
A. Regional System											
(1) Norte	76.50	-	-	97.74	76.63	76.63	76.63	76.63	76.63	76.63	76.63
Hydro	64.52	-	-	64.52	43.41	43.41	43.41	43.41	43.41	43.41	43.41
Thermal	11.98	-	-	33.22	33.22	33.22	33.22	33.22	33.22	33.22	33.22
(2) Pichincha	648.84	-	-	903.19	971.25	989.73	989.73	989.73	989.73	989.73	989.73
Quito	613.53	-	-	903.19	903.19	921.67	921.67	921.67	921.67	921.67	921.67
Hydro	346.05	-	-	375.34	375.34	375.34	375.34	375.34	375.34	375.34	375.34
Thermal	267.48	-	-	527.85	527.85	546.33	546.33	546.33	546.33	546.33	546.33
Sto. Domingo	35.31	-	-	-	68.06	68.06	68.06	68.06	68.06	68.06	68.06
Thermal	35.31	-	-	-	68.06	68.06	68.06	68.06	68.06	68.06	68.06
(3) Centro-Norte	188.82	-	-	278.31	288.00	288.00	288.00	288.00	288.00	288.00	288.00
Latacunga & Others	185.06	-	-	278.31	280.02	280.02	280.02	280.02	280.02	280.02	280.02
Hydro	111.66	-	-	115.73	117.44	117.44	117.44	117.44	117.44	117.44	117.44
Thermal	73.40	-	-	162.58	162.58	162.58	162.58	162.58	162.58	162.58	162.58
Puyo	3.76	-	-	-	7.98	7.98	7.98	7.98	7.98	7.98	7.98
Hydro	0.71	-	-	-	0.71	0.71	0.71	0.71	0.71	0.71	0.71
Thermal	3.05	-	-	-	7.27	7.27	7.27	7.27	7.27	7.27	7.27
(4) Centro-Sur	143.87	-	-	-	-	-	281.13	281.13	281.13	281.13	281.13
Hydro	51.95	-	-	-	-	-	97.42	97.42	97.42	97.42	97.42
Thermal	91.92	-	-	-	-	-	183.71	183.71	183.71	183.71	183.71
(5) Sur	39.96	-	-	-	-	-	-	114.54	114.54	114.54	114.54
Hydro	19.49	-	-	-	-	-	-	19.49	19.49	19.49	19.49
Thermal	20.47	-	-	-	-	-	-	95.05	95.05	95.05	95.05
(6) Esmeraldas	41.26	-	-	-	-	-	-	138.67	138.67	138.67	138.67
Thermal	41.26	-	-	-	-	-	-	138.67	138.67	138.67	138.67
(7) Manabí	175.08	-	-	-	-	260.01	260.01	260.01	260.01	260.01	260.01
Thermal	175.08	-	-	-	-	260.01	260.01	260.01	260.01	260.01	260.01

Table A - 2 - (3) Summary of Dependable Power Supply Capability in National Interconnected System (2 - 2)
(Unit: GWh)

Sistema	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
(B) Guayas-Los Rios	1,215.33	-	-	-	1,888.47	1,981.27	1,981.27	1,981.27	1,981.27	1,981.27	1,981.27
Quaysquil & Others Thermal	1,170.71	-	-	-	1,888.47	1,888.47	1,888.47	1,888.47	1,888.47	1,888.47	1,888.47
Santa-Elena Thermal	44.52	-	-	-	-	92.80	92.80	92.80	92.80	92.80	92.80
(C) El Oro	71.03	-	-	-	-	-	-	170.13	170.13	170.13	170.13
Hydro Thermal	16.40	-	-	-	-	-	-	16.40	16.40	16.40	16.40
Thermal	54.63	-	-	-	-	-	-	153.73	153.73	153.73	153.73
Regional System Total	2,000.59	-	-	1,279.24	3,224.35	3,612.74	3,893.87	4,300.11	4,300.11	4,300.11	4,300.11
Hydro Thermal	610.78	-	-	555.59	536.90	554.00	651.42	670.21	670.21	670.21	670.21
Thermal	1,989.81	-	-	723.65	2,687.45	3,058.74	3,242.45	3,629.90	3,629.90	3,629.90	3,629.90
B. National System Projects	0	-	-	254.92	1,076.51	1,686.10	1,686.10	3,438.10	3,804.10	4,170.10	4,536.10
Hydro Thermal	0	-	-	212.00	212.00	212.00	212.00	1,964.00	2,330.00	2,696.00	3,062.00
Thermal	0	-	-	254.92	864.51	1,474.10	1,474.10	1,474.10	1,474.10	1,474.10	1,474.10
C - Total	-	-	-	1,534.16	4,300.86	5,298.84	5,579.97	7,738.21	7,738.21	8,470.21	8,836.21
Hydro Thermal	-	-	-	555.59	748.90	766.00	863.42	2,634.21	3,000.21	3,366.21	3,732.21
Thermal	-	-	-	978.57	3,551.96	4,532.84	4,716.55	5,104.00	5,104.00	5,104.00	5,104.10

Table A - 2 - (4) Existing Power Plants in Sistema Norte

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
La Playa	1,320	—	1956, 1960	Tulcan
El Ambi	8,000	—	1967	Ibarra
Montufar	300	—	1955	San Gabriel
El Angel	472	—	1955, 1969	Espejo
Hoja Blanca	600	—	1933, 1950	Ibarra
San Luis	822	—	1950, 1956	Otavalo
Quiroga y Imantag	440	—	1953, 1962	Cotacachi
Ontaño	400	—		Ontaño
Tulcan	—	775	1973	Tulcan
El Sagrario	—	634	1961	Ibarra
Total	12,354	1,409		
	13,763			

Table A - 2 - (5) Existing Power Plants in Sistema Pichincha
(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(Sistema Quito)				
Lós Chillos	1,760	—	1922,	Quito
La Calera	2,000	—		Machachi
Guangopolo	9,400	—	1935, 1944 1953	Quito
Cumbaya	40,000	—	1959, 1964	"
Nayón	30,000	—	1974	"
Calorina	—	11,500	1956 - 1972	"
Luluncoto	—	19,975	1971, 1973	"
Sub total	83,160	31,475		
		114,635		
(Sistema Sto, Domingo)				
Sto, Domingo	0	4,155		Sto, Domingo
Sub total	0	4,155		
		4,155		
Total	83,160	35,630		
		118,790		

Table A - 2 - (6) Existing Power Plants in Sistema Centro Norte

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(Sistema Latacunga)				
Iluchi (I), (II)	4,200	—	1951, 1954 1967	Latacunga
Latacunga	—	813	1970, 1974	"
Salcedo	—	325	1974	Salcedo
Sub total	4,200	1,138		
		5,338		
(Sistema Ambató)				
La Península	3,000	—	1961	Ambato
Mira-Flores	1,128	—	1957	"
El Batán	—	3,000	1967	"
Sub total	4,128	3,000		
		7,128		
(Sistema Riobamba)				
Alao (I)	5,300	—	1954	Riobamba
San Luis	—	3,360	1973	"
Guadalupe	458	—	1911, 1928	Guadalupe
Córdovez	680	—	1925, 1952	Córdovez
Guamóte	—	360		Guamóte
Sub total	6,438	3,720		
		10,158		
(Sistema Guaranda)				
Chimbo	650	—	1965	Guaranda
Chillanes	—	775	1972	"
Sub total	650	775		
		1,425		
(Sistema Puyo)				
Puyo	100	—	1965	Puyo
Puyo	—	356	1972	"
Sub total	100	356		
		456		
Total	15,516	8,989		
		24,505		

Table A - 2 - (7) Existing Power Plants in Sistema Centro Sur

(Unit : kW)				
Power Plants	Hydro	Thermal	Year of Operation	Location
Salmiin	6,432		1957, 1964	Cuenca
Monay I		4,500	1970	"
Brco		3,054	1963, 1964 1966, 1967	"
Guapan		2,500	1963, 1965	"
Azogues		766	1973	Azogues
Total	6,432	10,820		
	17,252			

Table A - 2 - (8) Existing Power Plants in Sistema Sur

(Unit : kW)				
Power Plants	Hydro	Thermal	Year of Operation	Location
San Francisco	2,400		1957, 1961 1968	Loja
Loja		1,266	1969, 1974	"
Catamayo		1,140	1974	Catamayo
Total	2,400	2,406		
	4,806			

Table A - 2 - (9) Existing Power Plants in Sistema Esmeraldas

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(System Esmeraldas)				
Santas Bañas		4,020	1964, 1965 1968, 1971	Esmeraldas
Quininde		190	1971, 1974	Quininde
Limones		285	1971, 1974	Limones
San Lorenzo		240	1967, 1973	San Lorenzo
Mulsne		125	1972	Mulsne
Total	0	4,860		
		4,860		

Table A - 2 - (10) Existing Power Plants in Sistema Manabi

(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
Manta		20,600	1972, 1973	Manta
Total	0	20,600		
		20,600		

Table A - 2 - (11) Existing Power Plants in Sistema Guayas-Los Rios
(Unit : kW)

Power Plants	Hydro	Thermal	Year of Operation	Location
(Sistema Guayaquil)				
EMBLEC		33,000	1970	
"		20,000	1958, 1962	
"		10,000	1954, 1957	
"		3,050	1946, 1952	
"		42,000	1973, 1974	
"		13,500	1968	
(Sistema Duran)		4,590	1965, 1973	Duran
(Sistema Salinas)		4,740	1967, 1972	Salinas
(Sistema Playas)		500	1969	Playas
(Sistema Milagro)		6,640	1972, 1974	Milagro
(Sistema Babahoyo)		2,240	1974	Babahoyo
(Sistema Quevedo)		2,766	1967, 1968 1973	Quevedo
Total	0	143,026		
		143,026		

Table A - 2 - (12) Existing Power Plants in Sistema El Oro

Power Plants	Hydro	Thermal	Year of Operation	Location
Machala-Diesel		6,432	1971	Machala
La Calera	1,266		1937	Zaruma
Amalilla	672		1929	Zaruma
La Cueva	296			Pinas
Total	2,234	6,432		
		8,666		

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power Plants (1 - 4) GWh
Unit: (MW)

Sistema	Installed Capacity (KW)	1	2	3	4	5	6	7	8	9	10	11	12	Total
(1) Norte														
H	12,354	4.68 (6.29)	3.57 (5.32)	3.82 (5.14)	4.83 (6.70)	5.91 (7.94)	7.17 (9.97)	5.58 (7.50)	4.61 (6.20)	4.32 (6.01)	5.47 (7.36)	7.22 (10.02)	7.34 (9.86)	64.52 (7.37)
T	1,409	1.02 (1.37)	0.92 (1.37)	1.02 (1.37)	0.98 (1.37)	1.02 (1.37)	0.98 (1.37)	1.02 (1.37)	1.02 (1.37)	0.98 (1.37)	1.02 (1.37)	0.98 (1.37)	1.02 (1.37)	11.98 (1.37)
Total	13,763	5.70 (7.76)	4.49 (6.69)	4.84 (6.51)	5.81 (8.07)	6.93 (9.31)	8.15 (11.34)	6.60 (8.87)	5.63 (7.75)	5.30 (7.38)	6.49 (8.73)	8.20 (11.39)	8.36 (11.23)	76.50 (8.74)
(2) Pichincha														
H	83,160	31.10 (41.81)	37.04 (56.01)	41.12 (55.26)	32.62 (45.30)	31.60 (42.86)	29.09 (40.41)	24.67 (33.16)	20.79 (27.95)	18.49 (25.69)	27.06 (36.38)	27.46 (38.13)	24.41 (32.81)	346.05 (39.50)
T	31,475	22.72 (30.54)	20.52 (30.54)	22.72 (30.54)	21.98 (30.54)	22.72 (30.54)	21.98 (30.54)	22.72 (30.54)	22.72 (30.54)	21.98 (30.54)	22.72 (30.54)	21.98 (30.54)	22.72 (30.54)	267.48 (30.54)
Sub-total	114,635	53.82 (72.35)	58.16 (86.55)	63.84 (85.90)	54.60 (75.84)	54.32 (73.40)	51.07 (70.95)	47.39 (63.70)	43.51 (58.49)	40.47 (56.23)	49.78 (66.92)	49.44 (68.67)	47.13 (63.35)	613.53 (70.04)
Sto. Domingo	4,155	3.00 (4.03)	2.71 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	35.31 (4.03)
Total	118,790	56.82 (76.38)	60.87 (90.58)	66.84 (89.83)	57.50 (79.87)	57.32 (77.43)	53.97 (74.96)	50.39 (67.73)	46.51 (62.52)	43.37 (60.26)	52.78 (70.95)	52.34 (72.70)	50.13 (67.38)	648.84 (74.07)
(3) Centro-Norte														
H	4,200	2.42 (3.25)	2.03 (3.02)	2.44 (3.28)	2.36 (3.28)	2.44 (3.28)	2.36 (3.28)	2.44 (3.28)	1.60 (2.15)	2.36 (3.28)	2.44 (3.28)	2.06 (2.86)	2.44 (3.28)	27.39 (3.12)
T	1,138	0.82 (1.11)	0.74 (1.11)	0.82 (1.11)	0.80 (1.11)	0.82 (1.11)	0.80 (1.11)	0.82 (1.11)	0.82 (1.11)	0.80 (1.11)	0.82 (1.11)	0.80 (1.11)	0.82 (1.11)	9.68 (1.11)
Sub-total	5,338	3.24 (4.36)	2.77 (4.13)	3.26 (4.39)	3.16 (4.39)	3.26 (4.39)	3.16 (4.39)	3.26 (4.39)	2.42 (3.26)	3.16 (4.39)	3.26 (4.39)	2.86 (3.97)	3.26 (4.39)	37.07 (4.23)
Ambato	4,128	2.23 (2.99)	1.92 (2.86)	2.68 (3.60)	2.71 (3.69)	2.10 (2.75)	2.65 (3.61)	3.12 (4.12)	2.89 (3.88)	1.95 (2.71)	2.87 (3.85)	1.76 (2.44)	1.56 (2.09)	28.44 (3.24)
T	3,000	2.17 (2.91)	1.96 (2.91)	2.17 (2.91)	2.10 (2.91)	2.17 (2.91)	2.10 (2.91)	2.17 (2.91)	2.17 (2.91)	2.10 (2.91)	2.17 (2.91)	2.10 (2.91)	2.17 (2.91)	25.55 (2.91)
Sub-total	7,128	4.40 (5.90)	3.88 (5.77)	4.85 (6.51)	4.81 (6.60)	4.27 (5.66)	4.75 (6.52)	5.29 (7.03)	5.06 (6.79)	4.05 (5.62)	5.04 (6.76)	3.86 (5.35)	3.73 (5.00)	53.99 (6.15)

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power Plants (2 - 4)

Unit: (MW) GWh

State	Installed Capacity (MW)	Unit: (MW) GWh													
		1	2	3	4	5	6	7	8	9	10	11	12	Total	
Rioabamba	H 6,438	4.58 (6.16)	4.13 (6.15)	3.00 (4.03)	2.84 (3.95)	4.58 (6.16)	4.42 (6.14)	4.58 (6.16)	4.58 (6.16)	4.42 (6.14)	4.58 (6.16)	4.42 (6.14)	4.58 (6.16)	4.58 (6.16)	50.71 (5.78)
	T 3,720	2.68 (3.61)	2.42 (3.61)	2.68 (3.61)	2.60 (3.61)	2.68 (3.61)	2.60 (3.61)	2.68 (3.61)	2.68 (3.61)	2.60 (3.61)	2.68 (3.61)	2.60 (3.61)	2.68 (3.61)	2.68 (3.61)	31.58 (3.61)
	Sub-total	10,158 (9.77)	6.55 (9.76)	5.68 (7.64)	5.44 (7.56)	7.26 (9.77)	7.02 (9.75)	7.26 (9.77)	7.26 (9.77)	7.02 (9.75)	7.26 (9.77)	7.02 (9.75)	7.26 (9.77)	7.26 (9.77)	82.29 (9.39)
Guaranda	H 650	0.45 (0.60)	0.40 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.37 (0.50)	0.45 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.45 (0.60)	5.12 (0.58)
	T 775	0.56 (0.75)	0.51 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.56 (0.75)	6.59 (0.75)
	Sub-total	1,425 (1.35)	0.91 (1.35)	1.01 (1.35)	0.97 (1.35)	1.01 (1.35)	0.97 (1.35)	1.01 (1.35)	0.93 (1.25)	1.01 (1.35)	1.01 (1.35)	0.97 (1.35)	1.01 (1.35)	1.01 (1.35)	11.71 (1.33)
Puyo	H 100	0.06 (0.08)	0.05 (0.08)	0.06 (0.08)	0.71 (0.08)										
	T 356	0.26 (0.35)	0.23 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.26 (0.35)	3.05 (0.35)
	Sub-total	456 (0.43)	0.28 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.32 (0.43)	3.76 (0.43)
	Total	24,505 (21.81)	14.39 (21.43)	15.12 (20.32)	14.69 (20.33)	16.12 (21.60)	16.21 (22.44)	17.14 (22.97)	15.99 (21.50)	15.44 (21.44)	16.89 (22.70)	15.02 (20.85)	15.58 (20.94)	15.58 (20.94)	188.82 (21.53)
(*) Centro-Sur	H 6,432	3.86 (5.19)	3.96 (5.89)	4.39 (5.90)	4.60 (6.39)	4.69 (6.30)	4.61 (6.40)	4.69 (6.30)	4.61 (6.20)	4.61 (6.20)	4.61 (6.20)	4.61 (6.20)	4.61 (6.20)	4.61 (6.20)	51.95 (5.93)
	T 10,820	7.81 (10.50)	7.05 (10.50)	7.81 (10.50)	7.55 (10.50)	7.81 (10.50)	7.55 (10.50)	7.81 (10.50)	7.81 (10.50)	7.55 (10.50)	7.81 (10.50)	7.55 (10.50)	7.81 (10.50)	7.81 (10.50)	91.92 (10.50)
	Total	17,252 (15.69)	11.01 (16.39)	12.20 (16.40)	12.15 (16.89)	12.50 (16.80)	12.16 (16.90)	12.50 (16.80)	12.42 (16.70)	11.80 (16.40)	12.42 (16.70)	11.58 (16.10)	11.46 (15.41)	11.46 (15.41)	143.87 (16.43)

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power Plants (3 - 4) Unit: MW

System	Installed Capacity (KW)	1	2	3	4	5	6	7	8	9	10	11	12	Total
(5) Sur														
H	2,400	1.78 (2.39)	1.61 (2.40)	1.78 (2.39)	1.72 (2.39)	1.78 (2.39)	1.37 (1.90)	1.41 (1.90)	1.04 (1.40)	1.72 (2.39)	1.78 (2.39)	1.72 (2.39)	1.78 (2.39)	19.49 (2.22)
T	2,406	1.74 (2.33)	1.57 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	1.68 (2.33)	1.74 (2.33)	20.47 (2.33)
Total	4,806	3.52 (4.72)	3.18 (4.73)	3.52 (4.72)	3.40 (4.72)	3.52 (4.72)	3.05 (4.23)	3.15 (4.23)	2.78 (3.73)	3.40 (4.72)	3.52 (4.72)	3.40 (4.72)	3.52 (4.72)	39.96 (4.55)
(6) Esmeraldas														
T	4,860	3.50 (4.71)	3.16 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	41.26 (4.71)
(7) Manabi														
T	23,160	16.72 (22.47)	15.10 (22.47)	16.72 (22.47)	16.18 (22.47)	16.72 (22.47)	16.18 (22.47)	16.72 (22.47)	16.72 (22.47)	16.18 (22.47)	16.72 (22.47)	16.18 (22.47)	16.72 (22.47)	196.86 (22.47)
(8) Guayae-Los Rios														
Guayaquil	55,500	40.06 (53.84)	36.18 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	471.64 (53.84)
T	66,050	47.67 (64.07)	43.06 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	46.13 (64.07)	47.67 (64.07)	561.27 (64.07)
Sub-total	121,550	87.73 (117.91)	79.24 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	1,032.91 (117.91)
Duran	4,590	3.31 (4.45)	2.99 (4.45)	3.31 (4.45)	3.20 (4.45)	3.31 (4.45)	3.20 (4.45)	3.31 (4.45)	3.31 (4.45)	3.20 (4.45)	3.31 (4.45)	3.20 (4.45)	3.31 (4.45)	38.96 (4.45)
Santa Elena Salinas	4,740	3.42 (4.60)	3.09 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	40.27 (4.60)
Santa Elena Playas	500	0.36 (0.49)	0.33 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	4.25 (0.49)
Milagro	6,640	4.79 (6.44)	4.33 (6.44)	4.79 (6.44)	4.64 (6.44)	4.79 (6.44)	4.64 (6.44)	4.79 (6.44)	4.79 (6.44)	4.64 (6.44)	4.79 (6.44)	4.64 (6.44)	4.79 (6.44)	56.42 (6.44)
Babahoyo	2,240	1.61 (2.17)	1.46 (2.17)	1.61 (2.17)	1.56 (2.17)	1.61 (2.17)	1.56 (2.17)	1.61 (2.17)	1.61 (2.17)	1.56 (2.17)	1.61 (2.17)	1.56 (2.17)	1.61 (2.17)	18.97 (2.17)
Quevedo	2,766	1.99 (2.68)	1.80 (2.68)	1.99 (2.68)	1.93 (2.68)	1.99 (2.68)	1.93 (2.68)	1.99 (2.68)	1.99 (2.68)	1.93 (2.68)	1.99 (2.68)	1.93 (2.68)	1.99 (2.68)	23.45 (2.68)
Total	143,026	103.21 (138.74)	93.24 (138.74)	103.21 (138.74)	99.88 (138.74)	103.21 (138.74)	99.88 (138.74)	103.21 (138.74)	103.21 (138.74)	99.88 (138.74)	103.21 (138.74)	99.88 (138.74)	103.21 (138.74)	1,215.23 (138.74)

Table A-2-(13) Summary of Dependable Supply Capability of Existing Power (4 - 4)

Unit: GWh

System	Installed Capacity (MW)												Total	
	1	2	3	4	5	6	7	8	9	10	11	12		
(9) El Oro														
H	2,234	1.26 (1.09)	1.46 (2.17)	1.62 (2.17)	1.57 (2.17)	1.62 (2.17)	1.62 (2.17)	1.54 (2.06)	1.40 (1.94)	1.15 (1.55)	0.99 (1.37)	0.60 (0.81)	0.60 (1.87)	16.40 (1.87)
T	6,432	4.04 (6.24)	4.19 (6.24)	4.04 (6.24)	4.49 (6.24)	4.04 (6.24)	4.04 (6.24)	4.04 (6.24)	4.49 (6.24)	4.04 (6.24)	4.49 (6.24)	4.04 (6.24)	4.04 (6.24)	54.63 (6.24)
Total	8,666	5.90 (7.93)	5.65 (8.41)	5.66 (8.41)	6.06 (8.41)	5.66 (8.41)	5.66 (8.41)	5.58 (8.30)	5.89 (8.18)	5.79 (7.79)	5.48 (7.61)	5.24 (7.05)	5.24 (8.11)	71.03 (8.11)
Grand Total	356,268	221.42 (297.62)	209.42 (311.66)	230.36 (309.62)	217.28 (301.72)	224.23 (301.70)	217.62 (292.44)	211.09 (283.75)	202.87 (281.81)	219.47 (295.02)	213.69 (296.80)	215.87 (290.16)	215.87 (296.89)	2,600.59 (296.89)
H	122,096	52.42 (70.45)	56.77 (84.49)	61.36 (82.45)	53.74 (74.55)	55.23 (74.53)	53.73 (74.55)	42.09 (56.58)	39.33 (54.04)	50.47 (67.85)	50.15 (69.36)	46.87 (62.99)	46.87 (69.72)	610.78 (69.72)
T	178,674	128.94 (173.33)	116.47 (173.33)	128.94 (173.33)	124.78 (173.33)	128.94 (173.33)	128.94 (173.33)	128.94 (173.33)	124.78 (173.33)	128.94 (173.33)	124.78 (173.33)	128.94 (173.33)	128.94 (173.33)	1,518.17 (173.33)
T	55,500	40.06 (53.84)	36.18 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	40.06 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	40.06 (53.84)	471.64 (53.84)

Note: H: Hydro power plants

T: Thermal power plants

Figure in parenthesis indicate average output of the power plants

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (I - 6)

Unit: (MW)

Sistema	Installed Capacity (kw)	Unit: (MW)												Total
		1	2	3	4	5	6	7	8	9	10	11	12	
(1) Norte														
La Playa	H 1,320	0.70 (0.94)	0.61 (0.91)	0.70 (0.94)	0.92 (1.28)	0.83 (1.12)	0.95 (1.32)	0.98 (1.32)	0.97 (1.30)	0.92 (1.28)	0.98 (1.32)	0.95 (1.32)	0.91 (1.22)	10.42 (1.19)
Er Anabl	H 8,000	2.20 (2.96)	1.44 (2.14)	1.31 (1.76)	2.04 (2.83)	3.08 (4.14)	4.29 (5.96)	2.94 (3.96)	2.19 (2.94)	2.00 (2.78)	2.78 (3.74)	4.29 (5.96)	4.43 (5.95)	32.99 (3.77)
Montufar	H 300	0.18 (0.24)	0.16 (0.24)	0.18 (0.24)	0.17 (0.24)	0.18 (0.24)	0.17 (0.24)	0.18 (0.24)	0.17 (0.24)	0.17 (0.24)	0.17 (0.24)	0.18 (0.25)	0.19 (0.26)	2.10 (0.24)
El Angel	H 472	0.27 (0.36)	0.27 (0.40)	0.28 (0.38)	0.29 (0.40)	0.27 (0.36)	0.27 (0.38)	0.30 (0.40)	0.27 (0.36)	0.27 (0.36)	0.27 (0.36)	0.29 (0.40)	0.30 (0.40)	3.38 (0.39)
Ocañon	H 400	0.30 (0.40)	0.26 (0.39)	0.28 (0.38)	0.26 (0.36)	0.30 (0.40)	0.29 (0.40)	0.22 (0.30)	0.25 (0.34)	0.24 (0.33)	0.29 (0.39)	0.29 (0.40)	0.30 (0.40)	3.28 (0.37)
Hoja Blanca	H 600	0.34 (0.46)	0.29 (0.43)	0.34 (0.46)	0.34 (0.47)	0.41 (0.55)	0.38 (0.53)	0.26 (0.35)	0.19 (0.26)	0.18 (0.25)	0.26 (0.35)	0.41 (0.57)	0.37 (0.50)	3.77 (0.43)
San Luis	H 822	0.41 (0.55)	0.30 (0.45)	0.47 (0.63)	0.52 (0.72)	0.54 (0.73)	0.54 (0.75)	0.45 (0.60)	0.37 (0.50)	0.35 (0.49)	0.44 (0.59)	0.52 (0.72)	0.54 (0.73)	5.45 (0.62)
Quiroga	H 440	0.28 (0.38)	0.24 (0.36)	0.26 (0.35)	0.29 (0.40)	0.30 (0.40)	0.28 (0.39)	0.25 (0.34)	0.20 (0.27)	0.19 (0.26)	0.25 (0.34)	0.29 (0.40)	0.30 (0.40)	3.13 (0.36)
Tuicán	T 775	0.56 (0.75)	0.51 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	6.59 (0.75)
El Sagrario	T 634	0.46 (0.62)	0.41 (0.62)	0.46 (0.62)	0.44 (0.62)	0.46 (0.62)	0.44 (0.62)	0.46 (0.62)	0.46 (0.62)	0.44 (0.62)	0.46 (0.62)	0.44 (0.62)	0.46 (0.62)	5.39 (0.62)
Total	13,763	5.70 (7.66)	4.49 (6.09)	4.84 (6.51)	5.81 (8.07)	6.93 (9.31)	8.15 (11.34)	6.60 (8.87)	5.63 (7.57)	5.30 (7.38)	6.49 (8.73)	8.20 (11.39)	8.36 (11.23)	76.50 (8.74)
(2) Pichincha														
Los Chillos (Quito)	H 1,760	0.89 (1.20)	0.81 (1.21)	0.97 (1.30)	0.93 (1.29)	0.97 (1.30)	1.00 (1.39)	1.04 (1.40)	1.04 (1.40)	1.00 (1.39)	1.04 (1.40)	0.93 (1.29)	0.89 (1.20)	11.51 (1.31)
La Calera	H 2,000	1.12 (1.51)	1.17 (1.74)	1.49 (2.00)	1.41 (1.96)	1.33 (1.77)	1.25 (1.74)	1.13 (1.52)	1.10 (1.48)	1.28 (1.78)	1.45 (1.95)	1.19 (1.65)	1.19 (1.60)	15.10 (1.72)
Guangopolo	H 9,400	5.73 (7.70)	6.32 (9.40)	6.94 (9.33)	6.00 (8.33)	5.65 (7.59)	5.27 (7.32)	4.53 (6.09)	3.76 (5.05)	3.26 (4.53)	4.72 (6.36)	5.10 (7.08)	4.50 (6.05)	61.79 (7.05)
Gumbaya	H 40,000	13.20 (17.74)	15.65 (23.29)	17.00 (22.85)	13.73 (19.07)	13.37 (17.97)	12.22 (16.97)	10.15 (13.64)	8.42 (11.32)	7.35 (10.21)	11.22 (15.08)	11.42 (15.86)	10.07 (15.53)	143.80 (16.42)

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (2 - 6)

Unit: GWh
(MW)

Sistema	Installed Capacity (KW)	GWh												Total
		1	2	3	4	5	6	7	8	9	10	11	12	
Nayoa	H 30,000	10.16 (13.66)	13.69 (20.37)	14.72 (19.78)	10.55 (14.65)	10.29 (13.83)	9.35 (12.99)	7.82 (10.51)	6.47 (8.70)	5.60 (7.78)	8.62 (11.59)	8.82 (12.25)	7.76 (10.43)	113.85 (13.00)
Calorina	T 11,500	8.30 (11.16)	7.50 (11.16)	8.30 (11.16)	8.03 (11.16)	8.30 (11.16)	8.03 (11.16)	8.30 (11.16)	8.30 (11.16)	8.03 (11.16)	8.30 (11.16)	8.03 (11.16)	8.30 (11.16)	97.72 (11.16)
Zulucoro	T 19,975	14.42 (19.38)	13.02 (19.38)	14.42 (19.38)	13.95 (19.38)	13.95 (19.38)	13.95 (19.38)	14.42 (19.38)	14.42 (19.38)	13.95 (19.38)	14.42 (19.38)	13.95 (19.38)	14.42 (19.38)	169.76 (19.38)
Sub-total	114,635	53.82 (72.35)	58.16 (86.55)	63.84 (85.80)	54.60 (75.84)	54.32 (73.00)	51.07 (70.95)	47.39 (63.70)	43.51 (58.49)	40.47 (56.23)	49.78 (66.92)	49.44 (68.67)	47.13 (63.35)	613.53 (70.04)
(Sto. Domingo)														
Sto. Domingo	T 4,155	3.00 (4.03)	2.71 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	35.31 (4.03)
Sub-total	4,155	3.00 (4.03)	2.71 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	2.90 (4.03)	3.00 (4.03)	35.31 (4.03)
Total	118,790	56.82 (76.38)	60.87 (90.58)	66.84 (89.83)	57.50 (79.87)	57.32 (77.03)	53.97 (74.98)	50.39 (67.73)	46.51 (62.52)	43.37 (60.26)	52.78 (70.95)	52.34 (72.70)	50.13 (67.38)	648.84 (74.07)
(3) Centro Norte (Latacunga)														
Iluehi (I)	H 2,800	1.38 (1.85)	1.09 (1.62)	1.40 (1.88)	1.35 (1.88)	1.40 (1.88)	1.35 (1.88)	1.40 (1.88)	1.40 (1.88)	1.35 (1.88)	1.40 (1.88)	1.05 (1.46)	1.40 (1.88)	15.97 (1.82)
" (II)	H 1,400	1.04 (1.40)	0.94 (1.40)	1.04 (1.40)	1.01 (1.40)	1.04 (1.40)	1.01 (1.40)	1.04 (1.40)	0.20 (0.27)	1.01 (1.40)	1.04 (1.40)	1.01 (1.40)	1.04 (1.40)	11.42 (1.30)
Latacunga	T 813	0.59 (0.79)	0.53 (0.79)	0.59 (0.79)	0.57 (0.79)	0.59 (0.79)	0.57 (0.79)	0.59 (0.79)	0.59 (0.79)	0.57 (0.79)	0.59 (0.79)	0.57 (0.79)	0.59 (0.79)	6.94 (0.79)
Salcido	T 325	0.23 (0.32)	0.21 (0.32)	0.23 (0.32)	2.74 (0.32)									
Sub-total	5,338	3.24 (4.36)	2.77 (4.13)	3.26 (4.39)	3.16 (4.39)	3.26 (4.39)	3.16 (4.39)	3.26 (4.39)	2.42 (3.26)	3.16 (4.39)	3.26 (4.39)	2.86 (3.97)	3.26 (4.39)	37.07 (4.23)

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (3 - 6)

Sistema	Installed Capacity (kW)	Unit: (MW)													
		1	2	3	4	5	6	7	8	9	10	11	12	Total	
(Ambato)															
La Peninsula	H 3,000	1.49 (2.00)	1.25 (1.86)	1.94 (2.61)	1.85 (2.57)	1.21 (1.63)	1.79 (2.49)	2.23 (3.00)	2.15 (2.89)	1.23 (1.71)	2.13 (2.86)	1.04 (1.44)	0.82 (1.10)	19.13 (2.18)	
Miraflores	H 1,128	0.74 (0.99)	0.67 (1.00)	0.74 (0.99)	0.86 (1.12)	0.89 (1.12)	0.86 (1.12)	0.89 (1.12)	0.74 (0.99)	0.72 (1.00)	0.74 (0.99)	0.72 (1.00)	0.74 (0.99)	9.31 (1.06)	
El Estan	T 3,000	2.17 (2.91)	1.96 (2.91)	2.17 (2.91)	2.19 (2.91)	2.17 (2.91)	2.10 (2.91)	2.17 (2.91)	2.17 (2.91)	2.10 (2.91)	2.17 (2.91)	2.10 (2.91)	2.17 (2.91)	25.55 (2.91)	
Sub-total	7,128	4.40 (5.90)	3.88 (5.77)	4.85 (6.51)	4.61 (6.60)	4.27 (5.66)	4.75 (6.52)	5.29 (7.08)	5.06 (6.79)	4.05 (5.62)	5.04 (6.76)	3.86 (5.35)	3.73 (5.00)	53.99 (6.16)	
(Riobamba)															
Alto I	H 5,300	3.91 (5.26)	3.53 (5.25)	2.33 (3.13)	2.20 (3.06)	3.91 (5.26)	3.78 (5.25)	3.91 (5.26)	3.91 (5.26)	3.78 (5.25)	3.91 (5.26)	3.78 (5.25)	3.91 (5.26)	42.86 (4.89)	
Cañadupe	H 458	0.22 (0.30)	0.20 (0.30)	0.22 (0.30)	0.21 (0.29)	0.22 (0.30)	0.21 (0.29)	0.22 (0.30)	0.22 (0.30)	0.21 (0.29)	0.22 (0.30)	0.21 (0.29)	0.22 (0.30)	2.58 (0.29)	
Cordovez	H 680	0.45 (0.60)	0.40 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	5.27 (0.60)	
San Luis	T 3,360	2.42 (3.26)	2.19 (3.26)	2.42 (3.26)	2.35 (3.26)	2.42 (3.26)	2.35 (3.26)	2.42 (3.26)	2.42 (3.26)	2.35 (3.26)	2.42 (3.26)	2.35 (3.26)	2.42 (3.26)	28.53 (3.26)	
Guamote	T 360	0.26 (0.35)	0.23 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	3.05 (0.35)	
Sub-total	10,158	7.26 (9.77)	6.55 (9.76)	7.64 (9.76)	7.44 (9.56)	7.26 (9.77)	7.02 (9.75)	7.26 (9.77)	7.26 (9.77)	7.02 (9.75)	7.26 (9.77)	7.02 (9.75)	7.26 (9.77)	82.29 (9.39)	
(Guaranda)															
Rio Chumbo	H 650	0.45 (0.60)	0.40 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	0.37 (0.50)	0.36 (0.50)	0.45 (0.60)	0.43 (0.60)	0.45 (0.60)	5.12 (0.58)	
Chillanes	T 775	0.56 (0.75)	0.51 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	0.54 (0.75)	0.56 (0.75)	6.59 (0.75)	
Sub-total	1,425	1.01 (1.35)	0.91 (1.35)	1.01 (1.35)	0.97 (1.35)	1.01 (1.35)	0.97 (1.35)	1.01 (1.35)	0.93 (1.25)	0.90 (1.25)	1.01 (1.35)	0.97 (1.35)	1.01 (1.35)	11.71 (1.35)	

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (4 - 6)

Unit: GWh

Sistema	Installed Capacity (KW)	Month												Total			
		1	2	3	4	5	6	7	8	9	10	11	12				
(Puyo)																	
Puyo	H 100	0.06 (0.08)	0.05 (0.07)	0.06 (0.08)	0.71 (0.08)												
Puyo	T 356	0.26 (0.35)	0.23 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.25 (0.35)	0.26 (0.35)	0.26 (0.35)	3.05 (0.35)
Sub-total	456	0.32 (0.43)	0.28 (0.42)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.31 (0.43)	0.32 (0.43)	0.32 (0.43)	3.76 (0.43)
Total	24,505	16.23 (21.81)	14.39 (21.43)	15.12 (20.32)	14.69 (20.33)	16.12 (21.60)	16.21 (22.44)	17.14 (22.97)	15.99 (21.50)	15.44 (21.44)	16.89 (22.70)	15.02 (20.85)	15.02 (20.85)	15.02 (20.85)	15.56 (20.94)	15.56 (20.94)	188.82 (21.54)
(4) Centro Sur																	
Saumlín	H 6,430	3.86 (5.19)	3.96 (5.89)	4.39 (5.90)	4.60 (6.39)	4.69 (6.30)	4.61 (6.40)	4.69 (6.30)	4.61 (6.20)	4.25 (5.90)	4.61 (6.20)	4.05 (5.60)	4.05 (5.60)	4.05 (5.60)	4.05 (5.60)	4.05 (5.60)	51.95 (5.95)
Monay I	T 4,500	3.25 (4.37)	2.93 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.14 (4.37)	3.25 (4.37)	3.25 (4.37)	38.24 (4.37)
Erco	T 3,054	2.20 (2.96)	1.99 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.20 (2.96)	25.91 (2.96)
Guspan	T 2,500	1.81 (2.43)	1.63 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.75 (2.43)	1.81 (2.43)	1.81 (2.43)	21.30 (2.43)
Azoques	T 766	0.55 (0.74)	0.50 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.53 (0.74)	0.55 (0.74)	0.55 (0.74)	6.47 (0.74)
Total	17,252	11.67 (15.69)	11.01 (16.39)	12.20 (16.40)	12.15 (16.89)	12.50 (16.80)	12.16 (16.90)	12.50 (16.80)	12.42 (16.70)	11.80 (16.40)	12.42 (16.70)	11.58 (16.10)	11.58 (16.10)	11.58 (16.10)	11.46 (15.41)	11.46 (15.41)	143.87 (16.43)
(5) Sur																	
San Francisco	H 2,400	1.78 (2.39)	1.61 (2.40)	1.78 (2.39)	1.72 (2.39)	1.78 (2.39)	1.37 (1.90)	1.41 (1.90)	1.04 (1.40)	1.72 (2.39)	1.78 (2.39)	1.72 (2.39)	1.72 (2.39)	1.72 (2.39)	1.78 (2.39)	1.78 (2.39)	19.49 (2.22)
Loja	T 1,266	0.92 (1.23)	0.83 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.92 (1.23)	10.83 (1.23)
Catamayo	T 1,140	0.82 (1.10)	0.74 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.79 (1.10)	0.82 (1.10)	0.82 (1.10)	9.64 (1.10)
Total	4,806	3.52 (4.72)	3.18 (4.73)	3.52 (4.72)	3.40 (4.72)	3.52 (4.72)	3.05 (4.23)	3.15 (4.23)	2.78 (3.73)	3.40 (4.72)	3.52 (4.72)	3.40 (4.72)	3.40 (4.72)	3.40 (4.72)	3.52 (4.72)	3.52 (4.72)	39.96 (4.55)

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (5 - 6)

Unit: GWh
(MW)

System	Installed Capacity (kW)	1	2	3	4	5	6	7	8	9	10	11	12	Total
(6) Esmeraldas														
Santa Rufina I T	4,020	2.90 (3.90)	2.62 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	2.81 (3.90)	2.90 (3.90)	34.16 (3.90)
Quinde I T	190	0.13 (0.18)	0.12 (0.18)	0.13 (0.18)	1.55 (0.18)									
Limones T	285	0.21 (0.28)	0.19 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	0.20 (0.28)	0.21 (0.28)	2.46 (0.28)
San Lorenzo T	240	0.17 (0.23)	0.15 (0.23)	0.17 (0.23)	2.02 (0.23)									
Muisne T	125	0.09 (0.12)	0.08 (0.12)	0.09 (0.12)	1.07 (0.12)									
Total	4,860	3.50 (4.71)	3.16 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	3.40 (4.71)	3.50 (4.71)	41.26 (4.71)
(7) Manabí														
Mouta T	20,600	14.87 (19.98)	13.43 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	175.08 (19.98)
Total	20,600	14.87 (19.98)	13.43 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	14.39 (19.98)	14.87 (19.98)	175.08 (19.98)
(8) Guayas-Los Ríos														
(Guayaquil) EMELEC T	3,050	2.20 (2.96)	1.99 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	2.13 (2.96)	2.20 (2.96)	25.91 (2.96)
" T	63,000	45.47 (61.11)	41.07 (61.11)	45.47 (61.11)	44.00 (61.11)	45.47 (61.11)	44.00 (61.11)	45.47 (61.11)	45.47 (61.11)	44.00 (61.11)	45.47 (61.11)	44.00 (61.11)	45.47 (61.11)	535.36 (61.11)
" T	55,500	40.06 (53.84)	36.18 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	38.76 (53.84)	40.06 (53.84)	471.64 (53.84)
Sub-total	121,550	87.73 (117.91)	79.24 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	84.89 (117.91)	87.73 (117.91)	1,032.91 (117.91)

Table A-2-(14) Dependable Supply Capability of Existing Power Plants (6 - 6)

Unit : GWh
(MW)

Sistema	Installed Capacity (MW)	Unit : GWh (MW)													
		1	2	3	4	5	6	7	8	9	10	11	12	Total	
(Durán)	T 4,500	3.31 (4.45)	2.99 (4.45)	3.31 (4.45)	3.20 (4.45)	3.31 (4.45)	38.96 (4.45)								
(Santa Elena Salinas)	T 4,740	3.42 (4.60)	3.09 (4.60)	3.42 (4.60)	3.31 (4.60)	3.42 (4.60)	40.27 (4.60)								
(Santa Elena Playas)	T 500	0.36 (0.49)	0.33 (0.49)	0.36 (0.49)	0.35 (0.49)	0.36 (0.49)	4.25 (0.49)								
(Milagro)	T 6,040	4.79 (6.44)	4.33 (6.44)	4.79 (6.44)	4.64 (6.44)	4.79 (6.44)	56.42 (6.44)								
(Baboyo)	T 2,240	1.61 (2.17)	1.46 (2.17)	1.61 (2.17)	1.56 (2.17)	1.61 (2.17)	18.97 (2.17)								
(Quevedo)	T 2,766	1.99 (2.68)	1.80 (2.68)	1.99 (2.68)	1.93 (2.68)	1.99 (2.68)	23.45 (2.68)								
Sub-total	21,476	15.48 (20.83)	14.00 (20.83)	15.48 (20.83)	14.99 (20.83)	15.48 (20.83)	182.32 (20.83)								
Total	143,026	103.21 (138.74)	93.24 (138.74)	103.21 (138.74)	99.88 (138.74)	103.21 (138.74)	1,215.23 (138.74)								
(9) Sistema El Oro															
Machala	I T 6,432	4.64 (6.24)	4.19 (6.24)	4.64 (6.24)	4.49 (6.24)	4.64 (6.24)	54.63 (6.24)								
La Calera	H 1,266	0.72 (0.96)	0.83 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.89 (1.23)	0.92 (1.23)	0.87 (1.17)	0.92 (1.23)	0.87 (1.17)	0.92 (1.23)	0.87 (1.17)	0.92 (1.23)	9.30 (1.06)
Amalilla	H 672	0.37 (0.50)	0.44 (0.65)	0.48 (0.65)	0.47 (0.65)	0.48 (0.65)	0.47 (0.65)	0.48 (0.65)	0.46 (0.61)	0.48 (0.65)	0.46 (0.61)	0.48 (0.65)	0.46 (0.61)	0.48 (0.65)	4.89 (0.56)
La Cueva	H 296	0.17 (0.23)	0.19 (0.29)	0.23 (0.29)	0.21 (0.29)	0.22 (0.29)	0.21 (0.29)	0.22 (0.29)	0.21 (0.28)	0.22 (0.29)	0.21 (0.28)	0.22 (0.29)	0.21 (0.28)	0.22 (0.29)	2.21 (0.25)
Total	8,666	5.90 (7.93)	5.65 (8.41)	6.06 (8.41)	6.06 (8.41)	6.26 (8.41)	6.06 (8.41)	6.26 (8.41)	6.18 (8.30)	6.26 (8.41)	6.18 (8.30)	6.26 (8.41)	6.18 (8.30)	6.26 (8.41)	71.03 (8.11)

Note : H : Hydro power plants
T : Thermal power plants

Figure in parenthesis indicate average output of the power plants.

APPENDIX

A-3 Estimated Generating Energy Cost by Diesel Power Plants

Table A-3

(1)	Sistema Centro-Sur	A-52
(2)	Sistema Manabi	A-53
(3)	Sistema Esmeraldas	A-54
(4)	Sistema Santa Elena (Guayas-Los Rios)	A-55
(5)	Sistema Babahoyo (Guayas-Los Rios)	A-56
(6)	Sistema El Oro	A-57
(7)	Sistema Sur (Loja)	A-58

Table A-3-(1) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Centro-Sur

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	105.24	117.27	143.83	157.07	172.13	189.20	208.37	
Peak Load	MW	27.57	31.21	38.56	42.04	45.96	50.45	55.54	
1.25 x Peak	MW	34.46	39.01	48.19	52.54	57.46	63.07	69.42	
Installed Capacity	MW								
3.00 MW Units (US\$500/kW)		35.00	35.00	35.00	35.00	35.00	35.00	35.00	
5.00 MW Units (US\$460/kW)		-	10.00	20.00	20.00	30.00	30.00	40.00	
10.00 MW Units (US\$450/kW)		35.00	45.00	55.00	55.00	65.00	65.00	75.00	
Total									
Capital Recovery Factor	$i = 10.5\%$	0.1215							
Fixed Cost	Amortization (10 ³ US\$)	1.956	2.503	3.050	3.050	3.050	3.597	4.144	
	Fuel Cost (10 ³ US\$)	1.459	1.624	1.992	2.175	2.384	2.620	2.886	
	Lub Oil Cost (10 ³ US\$)	141.5	157.6	193.3	211.1	231.3	254.3	280.1	
Variable Cost	Number of Persons	(45)	(50)	(55)	(55)	(60)	(60)	(65)	
	Salaries (10 ³ US\$)	180	200	220	220	240	240	260	
	Repair (10 ³ US\$)	378.4	484.2	589.9	589.9	695.8	695.8	801.4	
	Maintenance (10 ³ US\$)								
Sub-total		2,158.9	2,465.8	2,995.2	3,196.0	3,551.1	3,810.1	4,227.5	
Administrative Cost	(10 ³ US\$)	32.2	41.2	50.2	50.2	59.2	59.2	68.2	
Total Annual Cost	(10 ³ US\$)	4,147.1	5,010.0	6,095.4	6,296.2	7,207.3	7,407.1	8,433.7	
Generating Cost at sending end (mills/kWh)		39.37	42.7	42.4	40.1	41.9	39.1	40.5	

Note: Bunker C Oil: 240 gr/kWh Lubricating Oil: 4gr/GWh Bunker C Oil: US\$57.5/ton

Table A-3-(2) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Manabi

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	96.59	110.00	128.75	143.47	158.89	173.27	192.84	
Peak Load	MW	23.72	26.80	30.74	34.79	38.14	42.22	46.59	
1.25 x Peak	MW	29.65	33.50	38.43	43.49	47.67	52.77	58.24	
Existing Installed Capacity	MW	-	-	-	-	-	-	-	
3.00 MW Units (US\$430/KW)		30.00	35.00	35.00	35.00	35.00	35.00	35.00	
5.00 MW Units (US\$400/KW)		-	-	10.00	20.00	20.00	20.00	30.00	
10.00 MW Units (US\$390/KW)		30.00	35.00	45.00	55.00	55.00	55.00	65.00	
Total		30.00	35.00	45.00	55.00	55.00	55.00	65.00	
Capital Recovery factor	i = 10.5 %	0.1215							
Fixed Cost	Amortization (10 ³ US\$)	1.458	1.701	2.175	2.175	2.649	2.649	3.123	
	Fuel Cost (10 ³ US\$)	1.098.8	1.251.3	1.464.7	1.632.1	1.807.5	1.998.8	2,198.7	
	Lub Oil Cost (10 ³ US\$)	129.8	147.8	173.0	192.8	213.5	235.6	259.2	
	Number of Persons	(40)	(40)	(45)	(45)	(50)	(50)	(55)	
	Salaries (10 ³ US\$)	160	160	180	180	200	200	220	
	Repair (10 ³ US\$)	282	329	421	421	512	512	604	
	Maintenance (10 ³ US\$)								
	Sub-total (10 ³ US\$)	1,670.6	1,888.1	2,238.7	2,425.9	2,733.0	2,941.4	3,276.9	
	Administrative Cost (10 ³ US\$)	24.0	28.0	35.8	35.8	43.6	43.6	51.4	
Total Annual Cost (10 ³ US\$)		3,152.6	3,617.1	4,449.5	4,636.7	5,425.6	5,634.0	6,451.3	
Generating Cost at sending end (mills/kWh)		32.6	32.9	34.6	32.3	34.1	32.1	33.5	

Table A-3-(3) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Esmeraldas

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh		38.21	45.16	66.74	76.41	87.27	98.99	118.09
Peak Load	MW		9.06	10.64	14.27	16.81	19.54	22.19	26.23
1.25 x Peak	MW		11.33	13.30	17.84	21.01	24.42	27.74	32.79
Existing Installed Capacity	MW								
3.00 MW Unit (US\$430/KW)		9.00	9.00	9.00	9.00	9.00	9.00	9.00	9.00
5.00 MW Unit (US\$400/KW)		5.00	5.00	5.00	10.00	15.00	15.00	20.00	25.00
Total		14.00	14.00	14.00	19.00	24.00	24.00	29.00	34.00
Generating energy by 3.00 MW Diesel Units		11.98	5.74	13.18	13.18	10.71	8.43	7.01	12.97
"	5.00 MW "	26.28	39.42	53.56	53.56	65.70	78.84	91.98	105.12
Capital Recovery factor	i = 10.5%								0.1215
Fixed Cost	Amortization (10 ³ US\$)		713.2	713.2	956.2	1,199.2	1,199.2	1,442.2	1,685.2
	Fuel Cost (10 ³ US\$)		D=296.3 C=299.0	D=142.5 C=448.4	D=327.6 C=597.9	D=266.1 C=747.4	D=209.6 C=896.9	D=174.2 C=1,035.0	D=322.4 C=1,195.8
	Lab Oil Cost (10 ³ US\$)		595.3	590.9	925.5	1,013.5	1,106.5	1,209.2	1,518.2
	Number of Persons		51.4	60.7	89.7	102.7	117.3	133.0	158.7
	Salaries (10 ³ US\$)		(35)	(35)	(40)	(40)	(40)	(40)	(40)
	Repair (10 ³ US\$)		140	140	160	160	160	160	160
	Maintenance (10 ³ US\$)		136	136	183	230	230	277	324
	Sub-total		922.7	927.6	1,358.2	1,506.2	1,613.8	1,779.2	2,160.9
Administrative Cost (10 ³ US\$)			11.7	11.7	15.7	19.7	19.7	23.7	27.7
Total Annual Cost (10 ³ US\$)			1,647.6	1,652.5	2,330.1	2,725.1	2,852.7	3,245.1	3,873.8
Generating Cost at sending end (mills/kWh)			43.1	36.6	34.9	35.7	32.5	32.8	32.8

Note : Bunker C Oil : 240 gr/kWh Lubricating Oil : 4 gr/kWh Diesel Oil : US\$105.3/ton
 Diesel Oil : 236 gr/kWh Bunker C Oil : US\$47.4/ton

Table A-3-(4) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Santa Elena (Guayas-Los Rios)

Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh	41.30	67.91	79.88	85.13	90.36	100.00	106.21
Peak Load	MW	11.24	15.75	18.23	19.43	20.56	22.72	23.97
1.25 x Peak	MW	14.05	19.69	22.79	24.28	25.69	28.40	29.96
Installed Capacity								
3.00 MW Unit (US\$430/kW)		12.00	12.00	12.00	12.00	12.00	12.00	12.00
5.00 MW Unit (US\$400/kW)		5.00	10.00	15.00	15.00	15.00	20.00	20.00
Total		17.00	22.00	27.00	27.00	27.00	32.00	32.00
Generating energy by 3.00 MW Diesel Units		15.02	15.35	14.18	6.29	11.52	8.02	14.23
"	5.00 MW "	26.28	52.56	65.70	78.84	78.84	91.98	91.98
Capital Recovery factor	$i = 10.5\%$		0.1215					
Fixed Cost	Amortization (10 ³ US\$)	870	1,113	1,356	1,356	1,356	1,599	1,599
	Fuel Cost (10 ³ US\$)	D=373.2 C=299.0	D=381.4 C=597.9	D=352.5 C=747.4	D=156.4 C=896.9	D=286.3 C=896.9	D=199.3 C=1,046.4	D=353.7 C=1,046.4
	Lub Oil Cost (10 ³ US\$)	55.5	91.3	107.4	114.4	121.4	134.4	142.7
	Number of Persons	(35)	(40)	(40)	(40)	(40)	(40)	(40)
	Salaries (10 ³ US\$)	140	160	160	160	160	160	160
	Repair (10 ³ US\$)	168	215	262	262	262	309	309
	Maintenance (10 ³ US\$)							
	Sub-total (10 ³ US\$)	1,035.7	1,445.6	1,629.3	1,589.7	1,726.6	1,849.1	2,011.8
	Administrative Cost (10 ³ US\$)	14.3	18.3	22.3	22.3	22.3	26.3	26.3
	Total Annual Cost (10 ³ US\$)	1,920.0	2,576.9	3,007.6	2,968.0	3,104.9	3,474.4	3,637.1
	Generating Cost at sending end (mills/kWh)	46.5	37.9	37.6	34.9	34.4	34.7	34.2

Note : Bunker C Oil : 240 gr/kWh Lubricating Oil : 4 gr/kWh Diesel Oil : US\$105-3/ton
 Diesel Oil : 236 gr/kWh Bunker C Oil : US\$47.4/ton

Table A-3-(5) Estimated Generating Energy Cost by Diesel Power Plants in Sistema Babahoyo (Guayas-Los Rios)

	Year	1977	1978	1979	1980	1981	1982	1983	1984
Total Production	GWh		60.46	70.09	80.94	90.40	100.69	111.76	123.85
Peak Load	MW		15.33	17.85	20.60	23.02	25.51	28.20	30.98
1.25-x Peak	MW		19.16	22.31	25.75	28.78	31.96	35.25	38.73
Installed Capacity	MW		9.00	9.00	9.00	9.00	9.00	9.00	9.00
3.00 MW Unit (US\$430/KW)			10.00	15.00	20.00	20.00	25.00	30.00	30.00
5.00 MW Unit (US\$400/KW)			19.00	24.00	29.00	29.00	34.00	39.00	39.00
Total									
Capital Recovery factor									0.1215
Fixed Cost	Amortization (10 ³ US\$)		956	1,199	1,442	1,442	1,665	1,928	1,928
	Fuel Cost (10 ³ US\$)		760	881	1,017	1,137	1,266	1,406	1,558
	Lub-Oil Cost (10 ³ US\$)		81.3	94.2	108.8	121.5	135.3	150.2	166.5
Variable Cost	Number of Persons		(40)	(40)	(40)	(40)	(45)	(45)	(45)
	Salaries (10 ³ US\$)		160	160	160	160	180	180	180
	Repair (10 ³ US\$)		184.9	231.9	278.9	278.9	325.9	372.9	372.9
	Maintenance (10 ³ US\$)								
	Sub-total (10 ³ US\$)		1,186.2	1,367.1	1,564.7	1,697.4	1,907.2	2,109.1	2,277.4
Administrative Cost	(10 ³ US\$)		15.7	19.7	23.7	23.7	27.7	31.7	31.7
Total Annual Cost	(10 ³ US\$)		2,157.9	2,585.8	3,030.4	3,163.1	3,619.9	4,068.8	4,237.1
Generating Cost at seeding end (mills/kWh)			35.7	36.7	37.4	35.0	35.9	36.4	34.2

Note : Bunker C Oil : 240 gr/kWh Lubricating Oil : 4 gr/kWh
Bunker C Oil : US\$52.4/ton

APPENDIX

A-4 Hydro Power Plants to be Installed in and after 1985.

Table A-4

(1) Economic Comparison of Zamora, Sabanilla Projects	A-63
(2) Zamora No. 1 Project (1st stage)	A-64
(3) Zamora No. 1 Project (2nd stage)	A-66
(4) Zamora No. 2 Project	A-68
(5) Zamora No. 3 Project	A-70
(6) Sabanilla Project	A-72
(7) Economic Comparison of Guayllabamba Projects	A-80
(8) Guayllabamba No. 1 Project	A-81
(9) Guayllabamba No. 2 Project	A-83
(10) Guayllabamba No. 3 Project	A-85
(11) Economic Comparison of Chimbo, and Pangor Projects	A-92
(12) Chimbo No. 1 Project	A-93
(13) Chimbo No. 2 Project	A-95
(14) Pangor No. 1 Project	A-97
(15) Pangor No. 2 Project	A-99

Fig. A-4

(1)	Zamora, Sabanilla Project (1 - 2)	A-74
(2)	Zamora, Sabanilla Project (2 - 2)	A-75
(3)	Zamora No. 1 Hydro Electric Power Project	A-76
(4)	Zamora No. 2, No. 3, Hydro Electric Power Projects	A-77
(5)	Sabanilla Hydro Electric Power Project	A-78
(6)	Guayllabamba Project (1 - 2)	A-87
(7)	Guayllabamba Project (2 - 2)	A-88
(8)	Guayllabamba No. 1, No. 2, Hydro Electric Power Projects	A-89
(9)	Guayllabamba No. 3 Hydro Electric Power Project	A-90
(10)	Chimbo, Pangor Project (1 - 2)	A-101
(11)	Chimbo, Pangor Project (2 - 2)	A-102
(12)	Chimbo No. 1, No. 2 Hydro Electric Power Projects	A-103
(13)	Pangor No. 1, No. 2 Hydro Electric Power Projects	A-104

A-4 1985年以降の水力発電プロジェクト

A-4-1 調査中の水力プロジェクト

INECELは、将来開発すべき水力プロジェクトの技術的、経済的可能性を調べるため、9つの地点について調査を進めている。その主なプロジェクトの調査状況は次のとおりである。

(1) Paute水力Ⅱ期；500 MW

Ⅱ期工事は、Paute水力全体について調査されたフィジビリティ調査の中に含まれており、PauteⅠ期後の増設工事である。

(2) Toachi水力；350 MW

本プロジェクトは、フィジビリティ調査を1974年9月に終了し、現在実施設計にはいるための調査工事を実施中である。

(3) Montufar水力；150 MW

本プロジェクトは、1974年にフィジビリティ調査を終了し、1975年より、ダムサイトの追加調査工事を実施中である。

(4) Coca水力；3,200 MW

本プロジェクトは、近くフィジビリティ調査が実施される予定である。この調査のために必要な費用は、すでにBIDからの融資が決定している。

(5) Jubones水力（総合開発）；380 MW

本プロジェクトは、現在 INERHI と共同でフィジビリティ調査を実施している。

(6) Chimbo-Pangor水力；419 MW

本プロジェクトは、近くフィジビリティ調査が実施される予定である。すでにコンサルタントも決定している。

(7) Zamora-Sabanilla水力；325 MW

本プロジェクトの予備調査は、すでに終了しているが、近くフィジビリティ調査が実施される予定である。

(8) Guayllabamba水力；740 MW

本プロジェクトは、現在予備調査実施中。主に基礎資料の作成、および地質調査が行なわれている。

以上のうち、(1)から(5)までは現在外国コンサルタント会社と契約し、調査を実施している。従って、本調査閉としては、(1)から(8)のプロジェクトのうち、予備調査段階にある(6)から(8)、すなわち、Chimbo-Pangor、Guayllabamba、Zamora、Sabanillaの3地点について検討した。

その結果を以下に述べる。

A-4-2 調査団が検討したプロジェクト

(1) Zamora-Sabanilla 水力開発計画

本プロジェクトは、Loja市の北東約45 kmに位置し、急流のV字形溪谷で、年平均48.8 m³/sの流量をもつRio Zamoraに水力発電所を建設しようとするものである。この急流部は、Loja盆地(標高2,000 m)から標高980 m迄の区間であり、この間の落差1,020 mを3段階に分けて発電に利用するのが最適の計画であらう。これは、上流から70 MW, 65 MWおよび325 MWの3つの発電所を建設することが可能であり、最下流の発電所には更に325 MWを追加開発することができる。計画の諸元については、Table A-4-(2)~(6)に示すとおりである。

このうち、立地条件からみて最も開発容易な発電所地点は、最下流のNo 1, 325 MW (I期)で、ダム、発電サイトともLoja市からZamoraに通じる既設の道路沿いに位置している。

No 1発電所は、最大使用水量60 m³/sを9.6 kmのトンネルと4.0 kmの放水路により導水し、700 mの落差を得て325 MWの発電ができる。ダム築造による貯水池は、有効46 × 10⁶ m³で、流況からみると渴水量23.5 m³/sを平均29.3 m³/sまで調整することができる。更に、50%負荷に相当するものとする最大使用水量は60 m³/sとなる。この発電所の年間発生電力量は、一次電力量1,411.6 GWh, 二次電力量837.8 GWh, 合計2,249.4 GWhである。また、この工事に必要とする資金は、US\$ 224 × 10⁶で、kW当り単価はUS\$ 689.2 (206.8千円)一次電力量のkWh当りは、US\$ 0.16 (48円)である。これは、年間経費率を12%とすれば、発電原価は、19.2 mills/kWh (5.76円/kWh)となる。

この発電原価は、エクアドル内で現在調査されている水力プロジェクトの中では安価なものであり、将来エクアドル南部で水力地点を求める時は、最も有力な地点とならう。また、Rio Zamoraを早期に開発し、Sur系統への供給力とする場合には、Sabanilla 32 MWを単独開発するのが最も経済的であらう。この場合の工事費は、US\$ 26.5 × 10⁶であり、kWh当り単価は、US\$ 0.095, 発電原価は11.4 mills/kWh (3.42円/kWh)となる。この発電所は、年間を通じてフルに32 MWの電力を発生できるのでディーゼル火力と組み合わせて負荷に対応する場合、この発電所がベース負荷、ディーゼル火力はピーク負荷を分担することになる。

Zamora No 1 II期は、Zamora No 1の貯水池の上流に高さ105 mのダムを築造し、有効貯水量280 × 10⁶ m³を季節調整することにより325 MWの発電が可能となる。

また、このダムがもつ落差を利用して65 MWの発電所をダム直下流に建設することも可能となる。

Table A-4-(I) Economic Comparison of Zamora, and Sabanilla Projects

	Zamora No.1 1st stage	Sabanilla	Zamora No. 2	Zamora No.1 2nd stage	Total
Installed capacity (MW)	325.0	32.0	65.0	325.0	747.0
Firm energy (GWh)	1,411.6	279.9	185.0	984.9	2,861.4
Construction cost (10 ⁶ US\$)	224.0	26.5	101.0	139.0	490.5
Construction cost per kW (US\$)	689.2	828.1	1,553.8	427.7	656.6
Construction cost per kWh (US\$)	0.159	0.095	0.546	0.141	0.171
Unit cost per kWh (US\$) 1/	0.019	0.011	0.065	0.067	0.021

1/ : Annual cost ratio 12%

Table A-4-(2) Zamora No. 1 Project (1st stage)

Location :	Zamora, Chinchipe	Monthly river inflow		
		Month	Natural Inflow (m ³ /s)	Generating energy (GWh)
River :	Zamora			
Type of power plant :	Dam-Waterway (Reservoir)			
Installed capacity :	325.0 MW			
Catchment area :	1,173.0 km ²	1	58.5	199.3
Annual average river inflow :	48.8 m ³ /s	2	42.3	158.6
Total storage capacity :	65.0 x 10 ⁶ m ³	3	49.0	203.3
Effective storage capacity :	46.0 x 10 ⁶ m ³	4	56.2	225.8
Maximum discharge :	60.0 m ³ /s	5	46.2	191.8
Total head :	700.0 m	6	56.0	224.7
Intake level :	1,680.0 m	7	80.5	241.8
Discharge level :	980.0 m	8	66.6	241.8
Effective head :	660.0 m	9	46.3	185.7
Annual generating energy :	2,249.4 GWh	10	32.6	135.4
Firm power :	159.9 MW	11	23.5	121.3
Firm energy :	1,411.6 GWh	12	26.8	119.9
		Total		2,249.4
Estimated construction cost :	US\$ 224.0 x 10 ⁶	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Unit cost per kW :	US\$ 689.2/kW			
Unit cost per kWh :	US\$ 0.10/kWh			
Construction period :	66 months			

Zamora No. 1 Project (1st stage)

(Principal characteristics and dimensions)

Dam	
Type	: Rockfill
Height	: 150 m
Crest length	: 320 m
Volume	: $7 \times 10^6 \text{ m}^3$
Flood discharge	: $1,860 \text{ m}^3/\text{s}$

High water level : 1,700 m

Low water level : 1,650 m

Available head : 50 m

Elevation on riverbed : 1,560 m

Dam crest/dam height = 2.13

Effective storage capacity : $46 \times 10^6 \text{ m}^3$

Duration capacity : 8.9 days

(Effective capacity/Max. discharge)

Intake Type :
Max. intake flow : $60 \text{ m}^3/\text{s}$

Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : 9,600 m	Type : restricted-orifice	Number of penstock : upper part 1 lower part 3
Section : 5.0 m	Height : 100 m	Length : 1,000 m
	Section : 10 m	Total length : 1,300 m
Branch tunnel		Section : 4.0 m to 1.7 m
Length : 5,100 m, Intake capacity : $20 \text{ m}^3/\text{s}$		

Power house		Switchyard
Type : Underground	Turbine	Transformer
Number of generator : 3 units	Type : Pelton	Voltage : 230 kV
Dimension : Height : 43 m	Output : 114 MW x 3 units	Capacity : 120 MVA x 3 units
Width : 24 m	Generator	
Depth : 125 m (1st, 2nd stages)	Output : 120 MVA x 3 units	

Tailrace tunnel Type : Pressure tunnel
Length : 4,000 m
Section : 5.0 m

Table A-4-(3) Zamora No. 1 Project (2nd stage)

		Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Location :	Zamora, Chinchipe			
River :	Zamora			
Type of power plant :	Dam-Waterway (Reservoir)			
Installed capacity :	325.0 MW			
Catchment area :	1,173.0 km ²	1		
Annual average river inflow :	54.8 m ³ /s	2		
Total storage capacity :	65.0 x 10 ⁶ m ³	3		
Effective storage capacity :	46.0 x 10 ⁶ m ³	4		
Maximum discharge :	60.0 m ³ /s	5		
Total head :	700.0 m	6		
Intake level :	1,680.0 m	7		
Discharge level :	980.0 m	8		
Effective head :	660.0 m	9		
		10		
		11		
		12		
Annual generating energy :	147.1 GWh	Total		
Firm power :	113.4 MW			
Firm energy :	981.5 GWh			
Estimated construction cost :	US\$ 139.0 x 10 ⁶			
Unit cost per kW :	US\$ 427.7/kW			
Unit cost per kWh :	US\$ 0.141/kWh			
Construction period :	60 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Zamora No. 1 Project (2nd stage)

(Principal characteristics and dimensions)

Dam	
Type :	-
Height :	-
Crest length :	-
Volume :	-
Flood discharge :	-

High water level : 1,700 m
 Low water level : 1,650 m
 Available head : 50 m
 Elevation on riverbed : 1,560 m
 Dam crest/dam height = 2.13

Intake Type :
Max. intake flow : 60 m ³ /s

Effective storage capacity: 46 10⁶m³
 Duration capacity 44 days
 (Effective capacity/Max. discharge)

Tunnel	Surge tank	Penstock
Pressure tunnel	Type : restricted-orifice	Number of penstock : upper part 1 lower part 3
Length : 9,600 m	Height : 100 m	Length : 1,000 m
Section: 5.0 m	Section : 10 m	Total length : 1,300 m
Branch tunnel		Section: 4.0 m to 1.7 m
Length : 5,100 m, Intake capacity : 20 m ³ /s		

Power house		Switchyard
Type : Underground	Turbine	Transformer
Number of generator : 3 units	Type : Pelton	Voltage : 230 kV
Dimension: Height : 43 m	Output : 114 MW	Capacity: 120 MVA
Width : 24 m	x 3 units	x 3 units
Depth : 125 m	Generator	
(1st, 2nd stages)	Output : 120 MW	
	x 3 units	

Tailrace tunnel Type : Pressure tunnel
Length : 4,000 m
Section: 5.0 m

Table A-4-(4) Zamora No. 2 Project

		Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Location :	Zamora, Chinchipe			
River :	Zamora			
Type of power plant :	Dam (Run-River)			
Installed capacity :	65.0 MW			
Catchment area :	890.0 km ²	1	34.8	12.1
Annual average river inflow :	32.8 m ³ /s	2	30.5	14.4
Total storage capacity :	462.0 x 10 ⁶ m ³	3	32.4	14.7
Effective storage capacity :	280.0 x 10 ⁶ m ³	4	34.5	13.1
Maximum discharge :	100.0 m ³ /s	5	31.6	15.5
Total head :	80.0 m	6	35.0	13.5
Intake level :	1,790.0 m	7	43.3	10.9
Discharge level :	1,710.0 m	8	40.4	13.8
Effective head :	76.0 m	9	31.5	16.8
Annual generating energy :	185.0 GWh	10	27.7	20.0
Firm energy :	128.0 GWh	11	25.2	20.8
		12	25.9	19.4
		Total		185.0

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Estimated construction cost : US\$ 101.0 x 10⁶

Unit cost per kW : US\$ 1,553.8/kW

Unit cost per kWh : US\$ 0.546/kWh

Construction period : 66 months

Zamora No. 2 Project

(Principal characteristics and dimensions)

Dam	
Type	: Rockfill
Height	: 105 m
Crest length	: 390 m
Volume	: $6.2 \times 10^6 \text{ m}^3$
Flood discharge	: $1,260 \text{ m}^3/\text{s}$

High water level : 1,800 m
 Low water level : 1,760 m
 Available head : 40 m
 Elevation on riverbed : 1,710 m
 Dam crest/dam height = 3.71

Intake Type :
Max. intake flow : $100 \text{ m}^3/\text{s}$

Effective storage capacity: $280 \times 10^6 \text{ m}^3$
 Duration capacity : 32.4 days
 (Effective capacity/Max. discharge)

Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : 500 m	Type : restricted-orifice	Number of penstock : 1
Section : 5.7 m	Height : 65 m	Length : 150 m
	Section: 10 m	Total length : 150 m
		Section : 5.7 m to 3.8 m
Branch tunnel		
Length : - m, Intake capacity : - m^3/s		

Power house		Switchyard
Type : Half underground	Turbine	Transformer
Number of generator : 1 unit	Type : Francis	Voltage : 230 kV
Dimension: Height : 32 m	Output : 68.4 MW	Capacity :
Width : 25 m	x 1 unit	72.2 MVA
Depth : 30 m	Generator	x 1 unit
	Output : 72.2 MVA	
	x 1 unit	

Tailrace tunnel	Type : -
Length : - m	
Section: -	

Table A-4-(5) Zamora No. 3 Project

		Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Location :	Zamora, Chinchipe			
River :	Zamora			
Type of power plant :	Dam-Waterway (Reservoir)			
Installed capacity :	70.0 MW			
Catchment area :	561.0 km ²	1	19.7	17.7
Annual average river inflow :	17.2 m ³ /s	2	14.9	16.1
Total storage capacity :	241.0 x 10 ⁶ m ³	3	17.1	17.7
Effective storage capacity :	165.0 x 10 ⁶ m ³	4	19.3	17.2
Maximum discharge :	50.0 m ³ /s	5	16.2	17.8
Total head :	190.0 m	6	19.9	17.3
Intake level :	1,990.0 m	7	29.0	18.2
Discharge level :	1,800.0 m	8	23.2	21.2
Effective head :	170.0 m	9	16.0	18.0
Annual generating energy :	215.3 GWh	10	11.9	18.5
Firm power :	23.1 MW	11	9.1	17.7
Firm energy :	204.7 GWh	12	9.9	17.9
Estimated construction cost :	US\$ 146.6 x 10 ⁶	Total		215.3
Unit cost per kW :	US\$ 2,094.3/kW			
Unit cost per kWh :	US\$ 0.681/kWh			
Construction period :	60 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Zamora No. 3 Project

(Principal characteristics and dimensions)

<p>Dam</p> <p>Type : Rockfill</p> <p>Height : 140 m</p> <p>Crest length : 380 m</p> <p>Volume : $10 \times 10^6 \text{ m}^3$</p> <p>Flood discharge : $670 \text{ m}^3/\text{s}$</p>	<p>High water level : 2,000 m</p> <p>Low water level : 1,960 m</p> <p>Available head : 40 m</p> <p>Elevation on riverbed : 1,880 m</p> <p>Dam crest/dam height = 2.71</p> <p>Effective storage capacity : $165 \times 10^6 \text{ m}^3$</p> <p>Duration capacity 38.2 days (Effective capacity/Max. discharge)</p>			
<p>Intake Type :</p> <p>Max. Intake flow : $50 \text{ m}^3/\text{s}$</p>				
<p>Tunnel</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 33%; border: none;"> <p>Pressure tunnel</p> <p>Length : 5,300 m</p> <p>Section : 4.0 m</p> </td> <td style="width: 33%; border: none;"> <p>Surge tank</p> <p>Type : restricted-orifice</p> <p>Height : 80 m</p> <p>Section : 8 m</p> </td> <td style="width: 33%; border: none;"> <p>Penstock</p> <p>Number of penstock : 1</p> <p>Length : 360 m</p> <p>Total length : 360 m</p> <p>Section : 4.0 m to 2.7 m</p> </td> </tr> </table> <p>Branch tunnel</p> <p>Length : - m, Intake capacity : - m^3/s</p>		<p>Pressure tunnel</p> <p>Length : 5,300 m</p> <p>Section : 4.0 m</p>	<p>Surge tank</p> <p>Type : restricted-orifice</p> <p>Height : 80 m</p> <p>Section : 8 m</p>	<p>Penstock</p> <p>Number of penstock : 1</p> <p>Length : 360 m</p> <p>Total length : 360 m</p> <p>Section : 4.0 m to 2.7 m</p>
<p>Pressure tunnel</p> <p>Length : 5,300 m</p> <p>Section : 4.0 m</p>	<p>Surge tank</p> <p>Type : restricted-orifice</p> <p>Height : 80 m</p> <p>Section : 8 m</p>	<p>Penstock</p> <p>Number of penstock : 1</p> <p>Length : 360 m</p> <p>Total length : 360 m</p> <p>Section : 4.0 m to 2.7 m</p>		
<table style="width: 100%; border: none;"> <tr> <td style="width: 40%; border: none;"> <p>Power house</p> <p>Type : Underground</p> <p>Number of generator : 1 unit</p> <p>Dimension: Height : 40 m Width : 20 m Depth : 35 m</p> </td> <td style="width: 20%; border: none;"> <p>Turbine</p> <p>Type : Francis</p> <p>Output : 73.7 MW x 1 unit</p> <p>Generator</p> <p>Output : 77.8 MVA x 1 unit</p> </td> <td style="width: 40%; border: none;"> <p>Switchyard</p> <p>Transformer</p> <p>Voltage : 230 kV</p> <p>Capacity : 77.8 MVA x 1 unit</p> </td> </tr> </table>		<p>Power house</p> <p>Type : Underground</p> <p>Number of generator : 1 unit</p> <p>Dimension: Height : 40 m Width : 20 m Depth : 35 m</p>	<p>Turbine</p> <p>Type : Francis</p> <p>Output : 73.7 MW x 1 unit</p> <p>Generator</p> <p>Output : 77.8 MVA x 1 unit</p>	<p>Switchyard</p> <p>Transformer</p> <p>Voltage : 230 kV</p> <p>Capacity : 77.8 MVA x 1 unit</p>
<p>Power house</p> <p>Type : Underground</p> <p>Number of generator : 1 unit</p> <p>Dimension: Height : 40 m Width : 20 m Depth : 35 m</p>	<p>Turbine</p> <p>Type : Francis</p> <p>Output : 73.7 MW x 1 unit</p> <p>Generator</p> <p>Output : 77.8 MVA x 1 unit</p>	<p>Switchyard</p> <p>Transformer</p> <p>Voltage : 230 kV</p> <p>Capacity : 77.8 MVA x 1 unit</p>		
<p>Tailrace tunnel Type : Pressure tunnel</p> <p>Length : 100 m</p> <p>Section : 4.0 m</p>				

Table A-4-(6) Sabanilla Project

Location :	Zamora,Chinchipe	Monthly river inflow and generating energy		
		Month	Natural Inflow (m ³ /s)	Generating energy (GWh)
River :	Sabanilla			
Type of power plant :	Water way (Run-of-River)			
Installed capacity :	32.0 MW			
Catchment area::	137.0 km ²	1	18.9	23.8
Annual average river inflow :	14.1 m ³ /s	2	12.7	21.5
Total storage capacity :	-	3	14.4	23.8
Effective storage capacity :	-	4	16.3	23.0
Maximum discharge :	6.0 m ³ /s	5	13.8	23.8
Total head :	700.0 m	6	15.1	23.0
Intake level :	1,740.0 m	7	18.5	23.8
Discharge level :	1,040.0 m	8	17.6	23.8
Effective head :	660.0 m	9	14.1	23.0
Annual generating energy :	279.9 GWh	10	10.4	23.8
Firm power :	31.7 MW	11	7.7	23.8
Firm energy :	277.7 GWh	12	9.2	23.8
Estimated construction cost :	US\$ 26.5 x 10 ⁶	Total		279.9
Unit cost per kW :	US\$ 828.1/kW			
Unit cost per kWh :	US\$ 0.095/kWh			
Construction period :	36 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Sabanilla Project

(Principal characteristics and dimensions)

Dam	
Type :	—
Height :	—
Crest length :	—
Volume :	—
Flood discharge :	—

High water level :	—
Low water level :	—
Available head :	—
Elevation on riverbed :	—
Dam crest/dam height :	—

Intake
Type :
Max. intake flow : 6.0 m ³ /s

Effective storage capacity :	—
Duration capacity :	—
(Effective capacity/Max. discharge)	

Tunnel		
Non-Pressure tunnel	Surge tank	Penstock
Length : 5,000 m	Type : —	Number of penstock : 1
Section : 3.10 m	Height : —	Length : 1,850 m
	Section : —	Total length : 1,850 m
		Section : 1.6 m to 1.0 m
Branch tunnel		
Length : —	Intake capacity : —	

Power house		
Type : Half underground	Turbine	Switchyard
Number of generator : 1 unit	Type : Pelton	Transformer
Dimension : Height : 25 m	Output : 33.7 MW	Voltage : 230 kV
Width : 15 m	x 1 unit	Capacity :
Depth : 30 m	Generator	35.6 MVA
	Output : 35.6 MVA	x 1 unit
	x 1 unit	

Fallrace tunnel
Type : —
Length : —
Section : —













FIG. A-4-(1)








REPUBLIC OF ECUADOR
INECEL

HYDRO - ELECTRIC
POWER PROJECT
ZAMORA NO.2, NO.3

FIG. A-4-(4)



REPUBLIC OF ECUADOR
 INECEL
 HYDRO -- ELECTRIC
 POWER PROJECT
 SABANILLA

Fig. A-4-(5)

(2) Guayllabamba 水力開発計画

この Project は Pichincha 県 Quito 市の北西 50 km に位置する Rio Guayllabamba の中流部に発電所を建設しようとするものである。

この地点は、Rio Guayllabamba 本流と、支流の Rio Perlabi の合流点から Rio Intag までの間の落差 880 m (EL 1,550 ~ 670 m) を 3 段に開発するのが最適であろう。この場合、上流から No. 1. 420 MW, No. 2. 100 MW, および No. 3. 220 MW の合計 740 MW の開発が可能である。計画の諸元は Table A-4-(7) から A-4-(10) に示すとおりである。

3 段に開発する最上流の No. 1. 発電所は、185 m のダムを築造し、最大使用水量 100 m³/s を 7.4 km のトンネルにより導水し、落差 565 m を得て 420 MW の発電が可能となる。ダムによる有効貯水量は 149 × 10⁶ m³ であり、年間 1,883.5 GWh の発電が可能である。また、この工事に必要とする工事費は US\$ 338 × 10⁶ であり、kW 当り単価は US\$ 804.8, kWh 当り単価は、US\$ 0.178 (53.4 円) であり、発電原価は 22.0 mills/kWh (経費率 12 %) である。

この Project は、エクアドル北部で開発可能な大規模でしかも経済性の高いものであり、また、需要地である Quito 市に近く、Paute 水力と同様早期に開発が待たれる Project である。

No. 2. 発電所は、No. 1. 発電所の放流水を水路 4.1 km で導き、落差 130 m を得て 100 MW の発電が可能である。

No. 3. 発電所は、本流と Rio Alambi の合流点の直下流に 140 m のダムと、その直下に発電所を建設し、最大使用水量 240 m³/s により 220 MW の発電を行なうものである。この No. 3 発電所の年間可能発生電力量は、889.4 GWh であり、工事費は US\$ 184 × 10⁶ である。発電単価は kW 当り US\$ 836.4, kWh 当り US\$ 0.207 であり、水力としては安価である (発電原価は 24.8 mills/kWh である)。

以上述べた 3 地点で 740 MW の電力を得ることができ、そのために必要とする総工事費は US\$ 582 × 10⁶ であり、発生電力量は 3,204.5 GWh/Year である。発電総合単価は、kW 当り US\$ 786.5, kWh 当り US\$ 0.182 である (発電原価は経費率を 12 % とすると 21.8 mills/kWh である)。

Table A-4-(7) Economic Comparison of Guayllabamba Projects

	Guayllabamba No. 1	Guayllabamba No. 2	Guayllabamba No. 3	Total
Installed capacity (MW)	420.0	100.0	220.0	740.0
Firm energy (GWh)	1,435.0	340.9	606.2	2,382.1
Construction cost (10 ⁶ US\$)	338.0	60.0	184.0	582.0
Construction cost per kW (US\$)	804.8	600.0	836.4	786.5
Construction cost per kWh (US\$)	0.179	0.139	0.207	0.182
Unit cost per kWh (US\$)	✓ 0.021	0.017	0.025	0.022

✓ : Annual cost ratio 12%

Table A-4-(8) Guayllabamba No. 1 Project

		Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
Location :	Pichincha, Imbabura			
River :	Guayllabamba			
Type of power plant :	Dam-Waterway (Réservoir)			
Installed capacity :	420.0 MW			
Catchment area :	4,295.0 km ²	1	47.9	162.1
Annual storage capacity :	49.5 m ³ /s	2	61.6	176.1
Total storage capacity :	214.0 x 10 ⁶ m ³	3	62.6	192.9
Effective storage capacity :	149.0 x 10 ⁶ m ³	4	67.9	189.8
Maximum discharge :	100.0 m ³ /s	5	57.7	193.3
Total head :	565.0 m	6	48.2	154.7
Intake level :	1,535.0 m	7	40.2	134.7
Discharge level :	970.0 m	8	36.1	135.4
Effective head :	520.0 m	9	31.9	123.0
Annual generating energy :	1,883.5 GWh	10	41.3	124.9
Firm power :	163.8 MW	11	54.6	150.6
Firm energy :	1,435.0 GWh	12	45.5	146.0
Estimated construction cost :	US\$ 338.0 x 10 ⁶	Total		1,883.5
Unit cost per kW :	US\$ 804.8/kW	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Unit cost per kWh :	0.179/kWh			
Construction period :	72 months			

Guayllabamba No. 1 Project

(Principal characteristics and dimensions)

Dam	
Type	: Rockfill
Height	: 185 m
Crest length	: 420 m
Volume	: $12 \times 10^6 \text{ m}^3$
Flood discharge	: $5,200 \text{ m}^3/\text{s}$

High water level : 1,550 m
 Low water level : 1,500 m
 Available head : 50 m
 Elevation on riverbed : 1,380 m
 Dam crest/dam height = $420/185 = 2.27$
 Effective storage capacity : $149 \times 10^6 \text{ m}^3$
 Duration capacity 17.2 days
 (Effective capacity/Max. discharge)

Intake Type	:
Max. intake flow	: $100 \text{ m}^3/\text{s}$

Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : 7,500 m	Type : restricted-orifice	Number of penstock :
Section : 5.0 m	Height : 105 m	upper part 2
	Section: 10 m	lower part 4
		Length : 800 m
Branch tunnel		Total length : 1,720 m
Length : -	Intake capacity : -	Section : 3.5 m to 1.8 m

Power house		
Type : Underground	Turbine	Switchyard
Number of generator : 4 units	Type : Pelton	Transformer
Dimension : Height : 43 m	Output : 111 MW	Voltage : 230 kV
Width : 24 m	x 4 units	Capacity :
Depth : 92 m	Generator	117 kVA
	Output : 117 MVA	x 4 units
	x 4 units	

Tailrace tunnel Type	: Pressure tunnel
Length	: 190 m
Section	: 5.0 m

Table A-4-(9) Guayllabamba No. 2 Project

Location :	Pichincha, Imbabura	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Guayllabamba			
Type of power plant :	Waterway (Run-of - River)			
Installed capacity :	100. 0 MW			
Catchment area :	4, 295. 0 km ²	1	47. 9	37. 2
Annual average river inflow :	49. 5 m ³ /s	2	61. 6	40. 7
Total average capacity :	—	3	62. 6	44. 1
Effective storage capacity :	—	4	67. 9	43. 3
Maximum discharge :	100. 0 m ³ /s	5	57. 7	43. 9
Total head :	130. 0 m	6	48. 2	35. 2
Intake level :	970. 0 m	7	40. 2	30. 7
Discharge level :	840. 0 m	8	36. 1	31. 0
Effective head :	120. 0 m	9	31. 9	28. 4
Annual generating energy :	431. 6 GWh	10	41. 3	29. 0
Firm power :	38. 9 MW	11	54. 6	34. 6
Firm energy :	340. 9 GWh	12	45. 5	33. 5
Estimated construction cost : US\$ 60. 0 x 10 ⁶		Total		431. 6
Unit cost per kW :	US\$ 600. 0/kW			
Unit cost per kWh :	US\$ 0, 139/kWh			
Construction period :	48 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Guayllabamba No. 2 Project

(Principal characteristics and dimensions)

Dam	
Type :	-
Height :	-
Crest length :	-
Volume :	-
Flood discharge :	-

High water level :	-
Low water level :	-
Available head :	-
Elevation on riverbed :	-
Dam crest/dam height =	-

Intake Type :	
Max. intake flow :	100 m ³ /s

Effective storage capacity :	-
Duration capacity	-
(Effective capacity/Max. discharge)	

Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : 4,200 m	Type : restricted-orifice	Number of penstock : 1
Section : 5.7 m	Height : 50 m	Length : 220 m
	Section: 11 m	Total length : 220 m
		Section : 5.7 m to 3.7 m
Branch tunnel		
Length : -	Intake capacity : -	

Power house		Switchyard
Type : Half underground	Turbine	Transformer
Number of generator : 1 unit	Type :	Voltage : 230 kV
Dimension : Height : 43 m	Output :	Capacity :
Width : 25 m	x 1 unit	111 MVA
Depth : 50 m	Generator	x 1 unit
	Output : 111 MVA	
	x 1 unit	

Tailrace tunnel Type :	-
Length :	-
Section :	-

Table A-4-(10) Guayllabamba No. 3 Project

Location :	Pichincha, Imbabura	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Guayllabamba			
Type of power plant :	Dam (Reservoir)			
Installed capacity :	220.0 MW			
Catchment area :	6,486.0 km ²	1	117.2	61.1
Annual average river inflow :	117.9 m ³ /s	2	157.0	70.6
Total storage capacity :	200.0 x 10 ⁶ m ³	3	155.4	91.6
Effective storage capacity :	148.0 x 10 ⁶ m ³	4	166.7	99.9
Maximum discharge :	240.0 m ³ /s	5	149.4	107.9
Total head :	115.0 m	6	122.4	92.3
Intake level :	785.0 m	7	93.5	74.2
Discharge level :	670.0 m	8	77.5	66.9
Effective head :	110.0 m	9	76.4	56.9
Annual generating energy :	889.4 GWh	10	86.6	51.5
Firm power :	69.2 MW	11	114.0	56.6
Firm energy :	606.2 GWh	12	103.4	59.9
Estimated construction cost : US\$ 184.0 x 10 ⁶		Total		889.4
Unit cost per kW : US\$ 836.4/kW				
Unit cost per kWh : US\$ 0.207/kWh				
Construction period :	54 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Guayllabamba No. 3 Project

(Principal characteristics and dimensions)

Dam	
Type	: Rockfill
Height	: 145 m
Crest length	: 270 m
Volume	: $4.8 \times 10^6 \text{ m}^3$
Flood discharge	: $2,300 \text{ m}^3/\text{s}$

High water level : 800 m
 Low water level : 750 m
 Available head : 50 m
 Elevation on riverbed : 670 m
 Dam crest/dam height = 1.93


Intake Type :
Max. Intake flow : $240 \text{ m}^3/\text{s}$


Effective storage capacity : $148 \times 10^6 \text{ m}^3$
 Duration capacity : 7 days
 (Effective capacity/Max. discharge)






Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : -	Type : -	Number of penstock : 2
Section : -	Height : -	Length : 320 m
	Section : -	Total length : 640 m
Branch tunnel		Section : 5.5 m to 3.9 m
Length : 3,100 m, Intake capacity : $20 \text{ m}^3/\text{s}$		

Power house		Switchyard
Type : Underground	Turbine	Transformer
Number of generator : 2 units	Type : Francis	Voltage : 230 kV
Dimension : Height : 43 m	Output : 116 MW	Capacity :
Width : 25 m	x 2 units	122 MVA
Depth : 68 m	Generator	x 2 units
	Output : 122 MVA	
	x 2 units	

Tailrace tunnel Type : Pressure tunnel
Length : 480 m, 2
Section : 5.5 m











REPUBLIC OF ECUADOR
 INECEL
 HYDRO - ELECTRIC
 POWER PROJECT
 GUAYLLABAMBA NO. 1, NO. 2

Fig A-4-(B)



REPUBLIC OF ECUADOR
INECEL

HYDRO - ELECTRIC
POWER PROJECT

GUAYLLABAMBA NO: 3

FIG. A-4-(9)

(3) Chimbo-Pangor 水力開発計画

Rio Chimbo は Mt. Chimborazo を源流とし、西アンデス山中を南流し、支流の Rio Pangor を合わせて Guayas 平野に流下する川である。この川を水力に利用する場合、種々の開発方式が考えられるが、現地調査の結果、Table A-4-01 から A-4-05 に示す開発方式が妥当であると判断した。この開発案によると、4つの発電所を建設することができる。すなわち、Chimbo No 1 は Rio Chimbo 本流の San Miguel 付近に 155 m のダムを築造し、有効貯水量 114×10^6 を得て流量を季節調整し、最大使用水量 $15 \text{ m}^3/\text{s}$ を 12 km の主トンネルで導水し落差 540 m を得て 61 MW の発電が可能である。Pangor No 2 は Chimbo No 1 の放流水を 4.8 km のトンネル、Rio Pangor の水を 7.1 km のトンネルで導水し、日調整をして最大使用水量を $40 \text{ m}^3/\text{s}$ とし、落差 328 m を利用して 110 MW の発電が可能である。

また、Chimbo No 2 は Pangor No 2 の放流水を導入し、16.1 km の主トンネルで Guayas 平野側に分水、落差 800 m を得て 230 MW の発電をしようとするものである。

一方、Pangor No 1 は、Pangor No 2 の上流にある落差 790 m を利用して 17 MW の発電をしようとするものである。

これらの4つの発電所によって合計 419 MW の発電が可能となるが、これに要する総工事費は US\$ 378.6×10^6 である。また年間可能発生電力量は合計 1,449.6 GWh で、発電単価は US\$ $903.6/\text{kW}$ 、US\$ $0.26/\text{kWh}$ である（発電原価は、経費率を 12% とすると 31.32 mills/kWh である）。

これらの計画は、経済性において Zamora, Guayllabamba よりも劣るが、需要地である Guayaquil に 80 km の近距離にあり、将来、開発が可能となろう。また、Pangor No 1 は 17 MW と規模は小さいが、Riobamba 向けの電力として開発すべきであろう。

Table A-4-(11) Economic Comparison of Chimbo, and Pangor Projects

	Chimbo No.1	Chimbo No.2	Pangor No.1	Pangor No.2	Total
Installed capacity (MW)	62.0	230.0	17.0	110.0	419.0
Firm energy (GWh)	271.3	605.6	48.2	252.9	1,178.0
Construction cost (10 ⁶ US\$)	135.0	145.0	24.8	73.8	378.6
Construction cost per kW (US\$)	2,177.4	630.4	1,458.8	670.9	903.6
Construction cost per kWh (US\$)	0.474	0.193	0.261	0.232	0.321
Unit cost per kWh (US\$)	1/	0.057	0.031	0.028	0.039

1/ : Annual cost ratio 12%

Table A-4-(12) Chimbo No. 1 Project

Location :	Bolívar, Chimbórago	Monthly river inflow and Generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Chimbo			
Type of power plant :	Dam-Waterway (Reservoir)			
Installed capacity :	62.0 MW			
Catchment area :	1,102.0 km ²	1	7.5	23.8
Annual average river inflow :	7.7 m ³ /s	2	12.5	21.6
Total storage capacity :	222.0 x 10 ⁶ m ³	3	15.1	24.1
Effective storage capacity :	114.0 x 10 ⁶ m ³	4	15.0	23.5
Maximum discharge :	15.0 m ³ /s	5	11.5	25.6
Total head :	540.0 m	6	7.5	23.6
Intake level :	2,340.0 m	7	4.0	24.4
Discharge level :	1,800.0 m	8	2.7	24.3
Effective head :	510.0 m	9	2.7	23.3
Annual generating energy :	285.1 GWh	10	4.9	24.0
Firm power :	31.0 MW	11	5.0	23.1
Firm energy :	271.3 GWh	12	4.8	23.8
Estimated construction cost :	US\$ 135.0 x 10 ⁶	Total		285.1
Unit cost per kW :	US\$ 2,177.4/kW	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Unit cost per kWh :	US\$ 0.474/kWh			
Construction period :	60 months			

Chimbo No. 1 Project

(Principal characteristics and dimensions)

Dam	
Type	: Rockfill
Height	: 155 m
Crest length	: 420 m
Volume	: $9 \times 10^6 \text{ m}^3$
Flood discharge	: $1,320 \text{ m}^3/\text{s}$

High water level : 2,350 m
 Low water level : 2,320 m
 Available head : 30 m
 Elevation on riverbed : 2,210 m
 Dam crest/dam height : 2.71

Intake Type :	
Max. intake flow :	$15 \text{ m}^3/\text{s}$

Effective storage capacity : $114 \times 10^6 \text{ m}^3$
 Duration capacity : 88 days
 (Effective capacity/Max. discharge)

Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : 12,200 m	Type : restricted-orifice	Number of penstock : 1
Section : 2.5 m	Height : 70 m	Length : 1,450 m
	Section : 5 m	Total length : 1,450 m
		Section : 2.5 m to 1.5 m
Branch tunnel		
Length : -	Intake capacity : -	

Power house		
Type : Half underground	Turbine	Switchyard
Number of generator : 1 unit	Type : Pelton	Transformer
Dimension : Height : 35 m	Output : 65.3 MW	Voltage : 138 kV
Width : 20 m	x 1 unit	Capacity :
Depth : 40 m	Generator	68.9 MVA
	Output : 68.9 MVA	x 1 unit
	x 1 unit	

Tailrace tunnel Type :	-
Length :	-
Section :	-

Table A-4-(13) Chimbo No. 2 Project

Location :	Bollivar, Chimborago	Monthly river inflow and generating energy		
		Month	Natural Inflow (m ³ /s)	Generating energy (GWh)
River :	Chimbo			
Type of power plant :	Waterway (Pondage)			
Installed capacity :	230.0 MW			
Catchment area	1,535.0 km ²	1	12.9	56.5
Annual average river inflow :	-	2	15.2	60.2
Total storage capacity :	-	3	16.1	70.5
Effective storage capacity :	-	4	16.7	71.0
Maximum discharge :	40.0 m ³ /s	5	18.6	81.7
Total head :	800.0 m	6	16.8	71.2
Intake level :	1,400.0 m	7	14.9	65.5
Discharge level :	600.0 m	8	13.4	59.0
Effective head :	720.0 m	9	13.0	55.1
Annual generating energy :	751.0 GWh	10	12.7	55.9
Firm power :	69.1 MW	11	12.5	53.0
Firm energy :	605.6 GWh	12	11.7	51.4
Estimated construction cost :	US\$ 145.0 x 10 ⁶	Total		751.0
Unit cost per kW :	US\$ 630.4/kW	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Unit cost per kWh :	US\$ 0.193/kWh			
Construction period :	96 months			

Chimbo No. 2 Project

(Principal characteristics and dimensions)

<p>Dam</p> <p>Type : Concrete gravity</p> <p>Height : 60 m</p> <p>Crest length : 200 m</p> <p>Volume : $150 \times 10^3 \text{ m}^3$</p> <p>Flood discharge : $1,500 \text{ m}^3/\text{s}$</p>		<p>High water level : 1,400 m</p> <p>Low water level : - m</p> <p>Available head : - m</p> <p>Elevation on riverbed : 1,345 m</p> <p>Dam crest/dam height : 3.33</p>																					
<p>Intake Type :</p> <p>Max. intake flow : $40 \text{ m}^3/\text{s}$</p>		<p>Effective storage capacity : -</p> <p>Duration capacity : -</p> <p>(Effective capacity/Max. discharge)</p>																					
<p>Tunnel</p> <table border="0"> <tr> <td>Pressure tunnel</td> <td>Surge tank</td> <td>Penstock</td> </tr> <tr> <td>Length : 16,100 m</td> <td>Type : restricted-orifice</td> <td>Number of penstock :</td> </tr> <tr> <td>Section : 3.7 m</td> <td>Height : 50 m</td> <td> upper part 1</td> </tr> <tr> <td></td> <td>Section: 6 m</td> <td> lower part 2</td> </tr> <tr> <td></td> <td></td> <td>Length : 3,350 m</td> </tr> <tr> <td>Branch tunnel</td> <td></td> <td>Total length : 3,400 m</td> </tr> <tr> <td>Length : 3,300 m, Intake capacity : $1.0 \text{ m}^3/\text{s}$</td> <td></td> <td>Section : 3.7 m to 1.7 m</td> </tr> </table>			Pressure tunnel	Surge tank	Penstock	Length : 16,100 m	Type : restricted-orifice	Number of penstock :	Section : 3.7 m	Height : 50 m	upper part 1		Section: 6 m	lower part 2			Length : 3,350 m	Branch tunnel		Total length : 3,400 m	Length : 3,300 m, Intake capacity : $1.0 \text{ m}^3/\text{s}$		Section : 3.7 m to 1.7 m
Pressure tunnel	Surge tank	Penstock																					
Length : 16,100 m	Type : restricted-orifice	Number of penstock :																					
Section : 3.7 m	Height : 50 m	upper part 1																					
	Section: 6 m	lower part 2																					
		Length : 3,350 m																					
Branch tunnel		Total length : 3,400 m																					
Length : 3,300 m, Intake capacity : $1.0 \text{ m}^3/\text{s}$		Section : 3.7 m to 1.7 m																					
<p>Power house</p> <p>Type : Half underground</p> <p>Number of generator : 2 units</p> <p>Dimension : Height : 43 m</p> <p> Width : 24 m</p> <p> Depth : 64 m</p>		<p>Turbine</p> <p>Type : Pelton</p> <p>Output : 121MW</p> <p> x 2 units</p> <p>Generator</p> <p>Output : 128 MVA</p> <p> x 2 units</p>																					
		<p>Switchyard</p> <p>Transformer</p> <p>Voltage : 230 kV</p> <p>Capacity :</p> <p> 128 MVA</p> <p> x 2 units</p>																					
<p>Tallrace tunnel Type : -</p> <p>Length : -</p> <p>Section : -</p>																							

Table A-4-(14) Pangor No. 1 Project

Location :	Chimborago	Monthly river inflow and generating energy		
		Month	Natural inflow (m ³ /s)	Generating energy (GWh)
River :	Pangor			
Type of power plant :	Dam-Waterway (Pondage)			
Installed capacity :	17.0 MW			
Catchment area :	128.7 km ²	1	1.24	5.66
Annual average river inflow :	1.8 m ³ /s	2	1.92	7.95
Total storage capacity :	0.2 x 10 ⁶ m ³	3	2.19	10.01
Effective storage capacity :	0.07 x 10 ⁶ m ³	4	2.38	10.55
Maximum discharge :	2.8 m ³ /s	5	2.83	12.97
Total head :	790.0 m	6	2.40	10.63
Intake level :	2,554.0 m	7	1.99	9.12
Discharge level :	1,764.0 m	8	1.56	7.12
Effective head :	750.0 m	9	1.42	6.29
Annual generating energy :	94.9 GWh	10	1.19	5.46
Firm power :	5.5 MW	11	1.13	4.98
Firm energy :	48.2 GWh	12	0.89	4.09
Estimated construction cost :	US\$ 24.8 x 10 ⁶	Total		94.83
Unit cost per kW :	US\$ 1,458.8/kW	Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.		
Unit cost per kWh :	US\$ 0.261/kWh			
Construction period :	36 months			

Pangor No. 1 Project

(Principal characteristics and dimensions)

Dam	
Type :	Concrete gravity
Height :	35 m
Crest length :	100 m
Volume :	$25 \times 10^3 \text{ m}^3$
Flood discharge :	$130 \text{ m}^3/\text{s}$

High water level : 2,555 m
 Low water level : 2,551 m
 Available head : 4 m
 Elevation of riverbed : 2,525 m
 Dam crest/dam height : 2,86

Intake Type :
Max. intake flow : $2.8 \text{ m}^3/\text{s}$

Effective storage capacity : $0.07 \times 10^6 \text{ m}^3$
 Duration capacity 0.3 days
 (Effective capacity/Max. discharge)

Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : 4,400 m	Type : restricted-orifice	Number of penstock : 1
Section: 2.0 m	Height : 20 m	Length : 3,000 m
	Section: 4 m	Total length : 3,000 m
		Section : 2.0 m to 0.6 m
Branch tunnel		
Length : - m, Intake capacity : -		

Power house		Switchyard
Type : Half underground	Turbine	Transformer
Number of generator : 1 unit	Type : Pelton	Voltage : 138 kV
Dimension : Height : 22 m	Output : 17.9 MW	Capacity :
Width : 13 m	x 1 unit	18.9 MVA
Depth : 25 m	Generator	x 1 unit
	Output : 18.9 MVA	
	x 1 unit	

Tailrace tunnel Type : -
Length : -
Section: -

Table A-4-(15) Pangor No. 2 Project

		Monthly river inflow and generating energy		
		Month	Natural Inflow (m ³ /s)	Generating energy (GWh)
Location :	Bollivar, Chimborago			
River :	Pangor			
Type of power plant :	Dam-Waterway (Pondage)			
Installed capacity :	110.0 MW			
Catchment area :	1,502.5 km ²	1	11.5	23.66
Annual average river inflow :	13.2 m ³ /s	2	13.7	25.31
Total storage capacity :	1.9 x 10 ⁶ m ³	3	14.5	29.74
Effective storage capacity :	0.53 x 10 ⁶ m ³	4	15.1	29.94
Maximum discharge :	40.0 m ³ /s	5	16.9	34.63
Total head :	348.0 m	6	15.2	30.07
Intake level :	1,748.0 m	7	13.9	28.49
Discharge level :	1,400.0 m	8	12.5	25.71
Effective head :	324.0 m	9	12.1	23.99
Annual generating energy :	318.6 GWh	10	11.4	23.40
Firm power :	28.9 MW	11	11.2	22.21
Firm energy :	252.9 GWh	12	10.5	21.48
Estimated construction cost :	US\$ 73.8 x 10 ⁶	Total		318.60
Unit cost per kW :	US\$ 670.9/kW			
Unit cost per kWh :	US\$ 0.232/kWh			
Construction period :	48 months			

Note: Monthly energy was calculated in consideration of regulating effect by water reservoir.

Pangor No. 2 Project

(Principal characteristics and dimensions)

Dam	
Type : Concrete gravity	
Height : 50 m	
Crest length : 250 m	
Volume : $130 \times 10^3 \text{ m}^3$	
Flood discharge : $1,500 \text{ m}^3/\text{s}$	


High water level : 1,750 m
 Low water level : 1,744 m
 Available head : 6 m
 Elevation on riverbed : 1,705 m
 Dam crest/dam height : 5.0
 Effective storage capacity : $0.53 \times 10^6 \text{ m}^3$
 Duration capacity : --
 (Storage capacity/Max. discharge)

Intake Type :
Max. Intake flow : $40 \text{ m}^3/\text{s}$

Tunnel		
Pressure tunnel	Surge tank	Penstock
Length : 5,200 m	Type : restricted-orifice	Number of penstock : 1
Section : 3.8 m	Height : 35 m	Length : 900 m
	Section : 11 m	Total length : 900 m
		Section : 3.8 m to 2.4 m
Branch tunnel		
Length : 6,600 m, Intake capacity : $5.5 \text{ m}^3/\text{s}$		


Power house		Switchyard
Type : Half underground	Turbine	Transformer
Number of generator : nit	Type : Francis	Voltage : 230 kV
Dimension : Height : 35 m	Output : 116 MW	Capacity : 122 MVA
Width : 25 m	x 1 unit	x 1 unit
Depth : 40 m	Generator	
	Output : 122 MVA	
	x 1 unit	

Tailrace tunnel Type : --
Length : --
Section : --





REPUBLIC OF ECUADOR
 I N E C E L
 CHIMBO, PANGOR
 PROJECT (1-2)

FIG. A-4-(10)



REPUBLIC OF ECUADOR
 I N E C E L
 CHIMBO, PANGOR
 PROJECT

FIG. A-4-(11)







REPUBLIC OF ECUADOR
 INECEL

HYDRO - ELECTRIC
 POWER PROJECT

CHIMBO NO.1, NO.2

Fig A-4-(12)



REPUBLIC OF ECUADOR	
INECEL	
HYDRO - ELECTRIC	
POWER PROJECT	
CHIMBO NO;2	
PANGOR NO;1, NO;2	

Fig A-4-(13)

APPENDIX

A-5 KW Balance in The Regional System

Fig. A-5-

(1)	Sistema	Norte	A-106
(2)	Sistema	Pichincha (Quito)	A-107
(3)	Sistema	Pichincha (Santó Domingo)	A-108
(4)	Sistema	Centro-Norte (Latacunga)	A-109
(5)	Sistema	Centro-Norte (Ambato)	A-110
(6)	Sistema	Centro-Norte (Riobamba)	A-111
(7)	Sistema	Centro-Norte (Guaranda)	A-112
(8)	Sistema	Centro-Norte (Puyo)	A-113
(9)	Sistema	Centro-Sur	A-114
(10)	Sistema	Sur	A-115
(11)	Sistema	Esmeraldas	A-116
(12)	Sistema	Manabi	A-117
(13)	Sistema	Guayas-Los Rios (Bahahoyo)	A-118
(14)	Sistema	Guayos-Los Rios (Guayaquil, Duran)	A-119
(15)	Sistema	Guayos-Los Rios (Quevedo)	A-120
(16)	Sistema	Guayos-Los Rios (milagro)	A-121
(17)	Sistema	Guayas-Los Rios (Santa Elena)	A-122
(18)	Sistema	El Oro	A-123

Fig. A-5-(1) kW Balance in the Regional System
Sistema Norte




Fig. A-5-(2) kW Balance In the Regional System
Sistema Pichincha (Quito)




Fig. A-5-(3) kW Balance in the Regional System
Sistema Pichincha (Santo Domingo)





Fig. A-5-(4) kW Balance in the Regional System
Sistema Centro-Norte (Latacunga)



Transfer From
Sis, Pichincha (Quito)
2.11 MW

Fig. A-5-(5) kW Balance in the Regional System
Sistema Centro-Norte (Ambato)




Fig. A-5-(6) kW Balance in the Regional System
Sistema Centro-Norte (Riobamba)




Fig. A-5-(7) kW Balance in the Regional System
Sistema Centro-Norte (Guaranda)




Fig. A-5-(8) kW Balance in the Regional System
Sistema Centro-Norte (Puyo)




Fig. A-5-(9) kW Balance In the Regional System
Sistema Centro-Sur




Fig. A-5-(10) kW Balance in the Regional System
Sistema Sur




Fig. A-5-(II) kW Balance in the Regional System
Sistema Esmeraldas




Fig. A-5-(12) kW Balance in the Regional System
Sistema Manabí




Fig. A-5-(13) kW Balance in the Regional System
Sistema Guayas - Los Rios (Babahoyo)




Fig. A-5-(14) kW Balance in the Regional System
Sistema Guayas - Los Rios (Guayaquil, Duran)




Fig. A-5- (15) kW Balance in the Regional System
Sistema Guayas - Los Rios (Quevedo)




Fig. A-5--(16) kW Balance in the Regional System
Sistema Guayas - Los Rios (Milagro)




Fig. A-5-(17) kW Balance in the Regional System
Sistema Guayas-Los Rios (Santa Elena)





Fig. A-5-(18) kW Balance in the Regional System
Sistema El Oro




APPENDIX

A-6 Regional Power Systems for Electrification

Fig. A-6- (1)	Sistema Norte	A-125
(2)	Sistema Pichincha	A-126
(3)	Sistema Centro-Norte	A-127
(4)	Sistema Centro-Sur	A-128
(5)	Sistema Sur	A-129
(6)	Sistema Esmeraldas	A-130
(7)	Sistema Manabí	A-131
(8)	Sistema Guayas-Los Ríos	A-132
(9)	Sistema El Oro	A-133

Existing	
(1) LA PLAYA	1.320 kWh
(2) EL AMBI	8.000 H
(3) MONTUFAR	300 H
(4) EL AVGEL	472 H
(5) ONTANON	400 H
(6) HOJA BLANCA	600 H
(7) SAN LUIS	822 H
(8) QUIROGA Y	
IMANTAG	440 H
(9) TURCAN	775 D
(10) EL SAGRARIO	634 D
Project	
(11) IBARRA	D 2.500 kw (1976)




REPUBLIC OF ECUADOR
INECEL


RURAL ELECTRIFICATION
SISTEMA - NORTE ①

Fig. A - 6 - (1)

SISTEMA Sto. DOMINGO



Existing	
(1) LOS CHILLOS	1.760 kw H
(2) LA CALERA	2.000 H
(3) GUANGOPOLO	9.400 H
(4) CUMBAYA	40.000 H
(5) NAYON	30.000 H
(6) CALORINA	11.500 D
(7) LULUNCOTO	19.975 D
(8) Sto. DOMINGO	4.155 D
Project	
(9) PASOCHOA	4.500 kw H (1975)
(10) QUITO GAS	24.100 G ()
(11) LULUNCOTO	8.720 D ()
(12) QUITO DIESEL	30.000 D (1977)
(13) Sto. DOMINGO	1.575 D (1976)
(14)	2.280 D (1976)




LEGEND

	Existing	Project
Power Plant		
Hydro	⬆	⊙
Thermal	⬆	⬆
Substation		
230/138 kv, 138/69-46 kv	△	△
69/138, 46/22-13.8 kv	△	△
Transmission Line		
230 kv	====	====
138 kv	=====	=====
69 kv	-----	-----
46 kv	-----	-----
22 kv	-----	-----
13.8 kv	-----	-----
6.3 kv	-----	-----

REPUBLIC OF ECUADOR
 INECEL
 RURAL ELECTRIFICATION
 SISTEMA PICHINCHA ②

Fig. A-6-(2)



Existing	kW	H	D
(1) ILLUCHI I	2,800	H	
(2) I	1,400	H	
(3) LATACUNGA	813	D	
(4) SALCEDO	325	D	
(5) LA PENINSULA	3,000	H	
(6) MIRA FLORES	1,128	H	
(7) EL BATAN	3,000	D	
(8) ALAO I	5,300	H	
(9) GUADALUPE	456	H	
(10) CORDOVEZ	680	H	
(11) SAN LUIS	3,360	D	
(12) GUAMOTE	360	D	
(13) RIO CHIMBO	650	H	
(14) CHILLANES	775	D	
(15) PUYO	100	H	
(16) /	356	D	


Project	kW	H	D
(17) LATACUNGA	1,000	D	(1975)
(18) /	2,500	D	(1976)
(19) AMBATO	6,000	D	(1975)
(20) RIO VERDE		H	
(21) ALAO II	2,600	H	(1977)
(22) GUARANDA	1,000	D	(1975)
(23) PUYO	500	D	(1975)

REPUBLIC OF ECUADOR
INECEL
 RURAL ELECTRIFICATION
 SISTEMA CENTRO NORTE (3)

Fig. A-6-(3)

Existing		
(1) SAN FRANCISCO	2 400	kw H
(2) LOJA	1 266	0
(3) CATAMAYO I	1 140	0
Project		
(4) CATAMAYO II	1 280	kw 0 (1975)
(5)	2 500	0 (1977)

	Existing	Project
Power Plant		
Hydro		
Thermal		
Substation		
138/69 kv		
69/13.8 kv		
less Than 13.8 kv		
Transmission Line		
138 kv		
69 "		
22 "		
13.8 "		




REPUBLIC OF ECUADOR
 I N E C E L
 RURAL ELECTRIFICATION
 SISTEMA SUR ⑤

Fig. A-6-(5)


Existing			
(1) SANTABAINAS I	4.020 ^{kw}	D	
(2) QUININDE I	190	D	
(3) LIMONES	285	D	
(4) SAN LORENZO	240	D	
(5) MUISNE	125	D	
Project			
(6) SANTA BAINAS II	5.200 ^{kw}	D (1975)	
(7) QUININDE II	260	D (1975)	
(8) ESMERALDAS	6.000	D (1976)	

LEGEND		
	Existing	Project
Power Plant		
Thermal	▲	⬆
Substation		
138/69 kv		△
96/138 kv		△
Transmission Line		
138 kv	====	====
69 kv	====	----
13.8 kv	----



REPUBLIC OF ECUADOR
 INECEL
 RURAL ELECTRIFICATION
 SISTEMA ESMERALDAS ⑥

Fig. A-6-(8)




Existing	
(1) MANTA	20.600 ^{kw} D
(2) PORTOVIEJO	800 D
(3) BAHIA	1.020 D
(4) JIPIJAPA	590 D
(5) PAJAN	150 D
Project	
(6) MANTA	10.000 ^{kva} G (1976)

LEGEND		
	Existing	Project
Power Plant		
Thermal	▲	⬆
Substation		
138/69kv		△
69/13.8-34.5/13.8	▲	△
Transmission Line		
138 kv	=====	-----
69 "	-----	-----
34.5 "	-----	-----
13.8 "	-----

REPUBLIC OF ECUADOR
 INECEL
 RURAL ELECTRIFICATION
 SISTEMA MANABI ⑦

Fig.A-6-(7)

Existing		Project	
(1) EMELEC	3,050 D	(10) EMELEC	21,500 G (1975)
(2) "	63,000 V	(11) "	21,500 G (1976)
(3) "	55,500 G	(12) "	73,000 G (1977)
(4) DURAN	4,590 D	(13) SALINAS	5,680 D (1975)
(5) SALINAS	4,740 D	(14) BABAHOYO	12,500 D (1976)
(6) PLAYAS	500 D	(15) QUEVEDO	800 D (1975)
(7) MILAGRO	6,640 D	(16) "	5,660 D (1976)
(8) BABAHOYO	2,240 D	(17) VINCE	1,000 D (1976)
(9) QUEVEDO	2,766 D		




REPUBLIC OF ECUADOR
 INECEL
 RURAL ELECTRIFICATION
 SISTEMA GUAYAS-LOS RIOS

Fig.A-6-(8)

Existing			
(1) MACHARA I	6.432	kw	D
(2) LA CALERA	1.266	H	
(3) AMALILLA	672	H	
(4) LA CUEVA	296	H	
Project			
(5) MACHARA II	5.660	D	(1975)
(6)	6.000	D	(1977)

	Existing	Project
Power Plant		
Hydro		
Thermal		
Substation		
138/69 kv		
69/13.8		
Less Than 13.8 kv		
Transmission Line		
138 kv		
69 "		
13.8 "		
6.3 "		



REPUBLIC OF ECUADOR
 INECEL
 RURAL ELECTRIFICATION
 SISTEMA EL. ORO ⑨

Fig. A-6-(9)

