

第 9 章 結論及び提言

第9章 結論及び提言

9-1 結論

パラオに於ける既設電力系統，将来の開発予定地域及び新発電所の建設状況等の現地調査，先方政府との協議結果等を検討して基本設計調査報告書として取りまとめたが，結論として次のことが挙げられる。

- (1) 現状の発電設備は設備が老朽化している為，故障が多く安定供給が困難と判断される。
- (2) 長期的な視点より見て，新設発電所より供給した方が発電コストの低減が可能で政府の財政負担の大巾な軽減が可能となる。
- (3) 新発電所の建設は，英国よりの政府借款によりIPSECO社が実施しており，発電所の運転開始予定時期は1985年6月である。そのため，新発電所からコロールの需要地まで電気を送電する送電線をなるべく早く建設する必要がある。
- (4) 現地調査の結果，本送電線の建設は技術的に問題なく実施できる。
- (5) 安定的な電力の供給により産業，経済活動の活発化，住民の福祉，民生の安定が図られる。

上記を総合的に勘案すると，本計画の実施は意義深いものであり日本国政府が無償資金協力を行うことは充分妥当なものと判断される。

9-2 提言

本プロジェクトで建設される送配変電設備は，パラオの将来の発展の基礎をなすものであり，長期的にその機能を維持する為に，下記の2点についての検討が必要と考えられる。

- (1) 建設時に実施される日本側の技術研修と，その後のIPSECO社の技術サービスを通して保守運転技術を習得することにより，計画的な保修計画を実施して信頼性の高い電力の供給ができる体制を整備する。
- (2) 電力供給体系については，現在の逆ざやの解消を図ることが必要と感じられるものであり，発電コスト相当の電力料金収入を得られる程度までの料金改訂が望ましいと考えられる。また，その際に消費者の形態別に料金体系を設定すること，及び政府使

用電力については、帰属する財源が同一であるとしても事例別会計管理が望ましいと考えられることから、これも料金徴収対象とすること等を検討する必要があると思料される。

但し、料金改訂に際しては、それが企業誘致等産業・経済の開発との関係から阻害要因とならないよう留意する必要がある。

資料編

資 料

章	資料番号	
1	1 - 1	主要面談者
	1 - 2	調査団員構成
	1 - 3	調査日程
	1 - 4	打合せ議事録(写)
3	3 - 1 - (1)~(4)	気象統計
	3 - 2 - (1)~(2)	地質資料
4	4 - 1	アイメリーク発電所主回路接続図
	4 - 2	アイメリーク発電所一般平面図
5	5 - 1 - (1)~(2)	電化計画実地調査結果
6	6 - 1	塩分付着量測定結果
	6 - 2	装柱図
	6 - 3	昇圧変電所 単線結線図
	6 - 4	降圧変電所 単線結線図
	6 - 5	昇圧変電所 一般平面図
	6 - 6	降圧変電所 一般平面図
	6 - 7	暫定運転システム
	6 - 8	暫定運転単線結線図
8	8 - 1	新発電所発電コスト内訳
	8 - 2	新発電所借入金明細

調査団員構成メンバー

氏 名	分 担	所 属
黒木 利知	総 括	通商産業省 資源エネルギー庁 公益事業部 技術課
佐々木直義	計画監理	国際協力事業団 無償資金協力部 基本設計課
市川 武司	送変電計画	(株)EDPCインターナショナル
堀 隆雄	配電計画	(株)EDPCインターナショナル
小島 弘司	変電設計	(株)EDPCインターナショナル
満田 稔彦	土木・地質	(株)EDPCインターナショナル
石井 成夫	経済財務分析	(株)EDPCインターナショナル

調 査 日 程

日順	月日	曜日	調 査 項 目
1	1月9日	水	東京発グアム着 総領事館 表敬訪問 事前調査報告書、インセプションレポートにより調査内容を説明
2	1月10日	木	グアム発コロール着、副大統領、国家資源大臣にインセプションレポートにより、調査目的の説明、質問状の提示、調査日程等につき打合せ
3	1月11日	金	前日に引続き質問状を中心に、国家資源大臣と協議 既設マラカル発電所調査
4	1月12日	土	マラカル発電所の運転記録整理
5	1月13日	日	アイライ州の既設電気設備調査
6	1月14日	月	国家開発計画について調査 送電線Aルート踏査及び新設アイメリーク発電所調査
7	1月15日	火	送電線Bルート調査
8	1月16日	水	現地調査結果に基づき国家資源大臣と協議
9	1月17日	木	負荷想定、送電系統の構成につき協議
10	1月18日	金	質問事項に関する回答及び議事録につき協議
11	1月19日	土	送電線ルート及び関連電化地域調査
12	1月20日	日	議事録準備
13	1月21日	月	議事録調印 (黒木、佐々木) コロール発グアム着 総領事館に調査概要報告 (市川他)新設アイメリーク発電所調査
14	1月22日	火	(黒木、佐々木)グアム発 東京着 (市川他)モガミ村 ネッケン、オイスカ他の電化地域調査 建設関連状況、経済情勢一般につき調査
15	1月23日	水	ガスパン、メドーム、イメルスベッチ村の電化地域及び建設 関連資料調査
16	1月24日	木	調査結果につき打合
17	1月25日	金	送電線ルート調査 建設工事につき打合せ
18	1月26日	土	資料整理
19	1月27日	日	マラカル発電所運転状況調査

日順	月日	曜日	調 査 項 目
20	1月28日	月	国家資源大臣と質問状につき打合せ コロール発グアム着
21	1月29日	火	グアム発 東京着

**REPUBLIC OF PALAU**

OFFICE OF THE PRESIDENT

P.O. Box 100

Koror, Palau 96940

MINISTRY OF NATIONAL RESOURCES


MINUTES OF DISCUSSIONS

In response to a request made by the Government of the Republic of Palau, the Government of Japan through Japan International Cooperation Agency (JICA), dispatched from January 10 to 29, 1985 to the Republic of Palau a Basic Design Study Team, headed by Mr. Toshichika Kuroki to gather pertinent information necessary for the design of the Babelthaup Electrical Power Transmission Line Phase I Project. The Team while in Palau, conducted field surveys to ascertain field conditions of the proposed electrical transmission line corridor, discussed with cognizant officials and reviewed existing reports and statistical data to develop design criteria applicable to the project, made projection of future electrical power demand for the proposed electrification area within the design period and cost estimate for the project.

As a result of the study, both parties have agreed to recommend to their respective Governments to further consider the attached statements of understanding toward the realization of the project.




Toshichika Kuroki
Team Leader, JICA's
Basic Design Study Team



Koichi L. Wong
Minister of National Resources
Republic of Palau

Date Jan. 21, 1985 Date JANUARY 21, 1985





REPUBLIC OF PALAU

OFFICE OF THE PRESIDENT
P.O. Box 100
Koror, Palau 96940

Phone: 403
Cable: Gov't Palau

MINISTRY OF NATIONAL RESOURCES

STATEMENTS OF UNDERSTANDING

1. The design period for Babelthaup Electrical Power Transmission Line Phase I Project covers ten years from 1985 to 1995.
2. Based on a study conducted by JICA's Basic Design Study Team which took into consideration the estimated population growth, potential commercial and industrial developments and social advancement in the Republic of Palau during the design period, it is concluded that the electrical power demand in the country will reach no less than 9,000 KW by 1995. See Annex I.
3. From preliminary indications, Route B seem most preferable for part of the main electrical power transmission line. See Annex II.
4. The scope of the Babelthaup Electrical Power Transmission Line Phase I Project includes the following: An appropriately sized transformer substation (13.8 KV step-up to 34.5 KV) to be located at the Aimeliik power station; electrical power transmission lines originating at the step-up substation and extended through the Nekken Forestry station where one of the feeder terminates and the other continues through (possibly Route B) where the voltage drops through an appropriately sized transformer substation (34.5 KV step-down to 13.8 KV) and integrated with the existing Koror-Airai power system; provision of appropriate electrical power transmission lines (probably at a lower voltage than the proposed 34.5 KV main power transmission line) to the community of Mechebechubl in Ngatpang State and the communities of Mongami, Ngchemiangel, Medorm, Nekken, OISCA Training Center and Elechui, all of Aimeliik State; and, provision of certain electrical equipment and materials to be installed by the Republic of Palau.

5. Typical design criteria applicable to the project are shown in Annex III, IV and V.
6. The Government of the Republic of Palau shall be responsible for upgrading the existing Koror-Airai 13.8 KV electrical power transmission system to be compatible with the 34.5 KV Aimeliik-Airai power transmission line when the demand for electrical power approaches 9,000 KW which is estimated to take place by 1995.
7. The JICA Basic Design Team will convey to the Government of Japan that the Government of Palau will cooperate to the fullest by providing services and/or undertakings outlined in Annex VI to ensure that the project will be implemented in the most economical and expeditious manner.

Annex I

ELECTRIC POWER REQUIREMENTS IN THE PROJECT AREA BY 1995

A. Use excluding residential in Koror	2580 KW
B. Residential use in Koror	2920 KW
C. New electrification area	130 KW
D. Additional requirements except for residential use	3370 KW
Total	<u>9,000 KW</u>

(Note)

1. Present electric power use 4,000 KW
2. Assumption of residential use by 1995:
 - (a) Population projection (present) 12,180
 (by 1995) 12,725
 (increase) 545
 - (b) Average residents per house in Palau:

(population)	12,180
(number of houses)	2,265
(average residents per house)	5.4
 - (c) Increase of houses in Palau: 110 (545/5.4)
 - (d) Increase of houses in the project area: 75 (2/3 of 110)

(Koror)	40
(other area)	35
 - (e) Average electric power usage:

(Koror)	2 KW per house
(other area)	1 KW per house
3. Item B and C above include the increase of houses - 40 houses in Koror and 35 houses in the electrification area.
4. Item D includes the present power requirements not receiving power from the Government system and the estimated demands in future, such as the increase of demands except for residential use and and the requirements from Grace Hotel, Airport terminal, MIC, Van Camp, Palau Pacific Resort, New National Hospital, new sewage lift stations and so on.


Annex II

COMPARISON TABLE OF TRANSMISSION ROUTES

Items		Route		
		A	B	C
(1)	Length (KM)	20	20	11
(2)	Construction cost (%)	130	100	not less than 500
(3)	Maintenance and repair	easy	easy	difficult
(4)	Construction work	easy	easy	difficult
(5)	Relation with electrification	2	1	3
(6)	Transmission loss	3	2	1
(7)	Total judgement	2	1	3

Note: Numerical order in items (5), (6) and (7) indicate order of priority.


POWER SYSTEM DIAGRAM




STEPUP SUBSTATION LOCATION


ANNEX III-2

UNIT : FEET & INCH




 : The area shall be cleared and leveled by the Government of Palau.

STEPDOWN SUBSTATION LOCATION




UNIT: meter

 : The area shall be cleared and leveled by the Government of Palau.

TO AIR PORT

34.5 KV TRANSMISSION LINE

(2 Ccts)



NOTE: These types are applied to the transmission line from Imelsubech to Nekkeng.

34.5 KV TRANSMISSION LINE


OR

13.8 KV DISTRIBUTION LINE

(1 Cct)

SUSPENSION POLE

SECTION POLE




34.5 KV TRANSMISSION LINE

AND

13.8 KV DISTRIBUTION LINE

(2 Ccts)




NOTE 1: It is possible to be mounted the transformer on the pole, if necessary.

NOTE 2: These types are applied to the "B" Route:

TYPICAL CROSS SECTION
ROAD ROUTE "B"

UNIT : millimeter



PROJECT DESIGN CRITERIA

1. The drawing point between the power station and the project lies on the terminal board of the cubicle for the out-going feeder in the power station.
2. The main cable between CB for the out-going feeder and transformers for 13.8KV/34.5 KV and the control cables for AC 110V and DC 110V are design along the existing cable duct in the power station.
3. The control panel for switchboard is designed along with the main unit of control panel in the power station.
4. The CB's for transmission lines are designed to be automatically reclosed in case of a fault in the transmission line.
5. DC electric source is supplied by DC 30V in the power station. Since only DC 110V is adopted in the Japanese standard, DC 110V battery and changer are to be specifically designed to meet the need.
6. The earth wire in the switch yard is designed with meshed components and is connected to the earth of the power station, and the earth resistivity is designed within one ohm.
7. The Japanese standard is adopted for the entire design and procurement of machines based on S.I. Unit in their measurement.
8. The tranformer substations are to be designed to provide for catchment of spilled transformer oil, and proper fencing to protect people and animals from high voltages.
9. The control panel for the switch yard is to be compatible with that in the power station in size and color.
10. Additional space for tansformer to be used in conjunction with future additional generation capacity (beyond 16 megawatt) is not considered at this time; however, a bus arrangement is to be properly designed.
11. Wind velocity is 40 m/s as a 10-minute average, corresponding to a maximum wind velocity of 52 m/s.
12. Seismic intensity. Horizontal is 0.4G and vertical is 0.25G.
13. Temperature: 35 degrees C maximum ambient temperature.
28 degrees C average ambient temperature.
20 degrees C minimum ambient temperature.

14. Lightning: 37 days/year
15. Earth of neutral wire: Required at each pole.
16. ACSR inner creased conductor is recommended by JICA's Basic Design Study Team but Government of Palau recommends either bare copper conductor and/or all aluminum conductor (AAC) of proper sizes.
17. Clearance and height of the transmission and distribution line are to be based on REA rules and regulations in general.
18. Poles are to be located no less than 1.5 meters from the edge of the existing road in Route B, but should be at least 20 feet from the center line of the road at other areas in general.
19. Voltage drop in the transmission and distribution lines shall not be more than 10 percent.
20. Electric poles are to be prestressed concrete with galvanized steel rungs in general.
21. Cross arms and other hardwares are to be heavy galvanized steel.
22. Voltage fluctuation of service wire drops shall be within plus or minus 10 percent. Conforming to standard design.

UNDERTAKINGS OF THE GOVERNMENT OF PALAU

Annex VI

1. To secure the necessary real estates and right of ways for the project.
2. To clear and level the sites for the transformer substation.
3. To clear and improve the road along Route B ready for power transmission line construction.
4. Designate a place where a 24-hour watch can be maintained so that the alarm for transmission line fault can be received.
5. Exempt tax and provide for immediate custom clearance for commodities necessary for project implementation.
6. Accord Japanese nationals whose services may be required in connection with the supplying of products and services under the verified contract such facilities as may be necessary for their entry into the Republic of Palau and stay therein for the performance of the required work under the project.
7. To maintain and use properly and effectively the facilities constructed and equipment purchased under the Grant Aid.
8. To bear all the expenses other than those to be borne by the Grant Aid, that is to receive, transport, store and install only those equipment and materials necessary for the hook-up of individual facility and/or home, as distinguished from those responsibilities to be assumed by the Contractor of this project.
9. To coordinate with the inhabitants living in the project areas to ensure expediency of the project implementation.
10. To maintain the present pier at Aimeliik in good repair so that the Contractor can utilize same for the implementation of the project.

Appendix 3-1-(1) Monthly Temperature, Precipitation, Humidity (2-1)

KOROR (1983)

MONTH	TEMPERATURE (°C)						MONTHLY AVERAGE (°C)	PRECIPITATION		MEAN RELATIVE HUMIDITY	
	AVERAGE		EXTREME		TOTAL (mm)	DAYS		09:00 am (%)	15:00 pm (%)		
	Max.	Min.	Max.	Min.							
JANUARY	30.3	23.6	31.1	22.2	87	19	75	72			
FEBRUARY	30.9	23.7	31.7	22.2	16	12	73	66			
MARCH	31.1	24.1	31.7	22.8	43	10	72	66			
APRIL	31.7	24.1	32.2	22.8	79	12	72	67			
MAY	31.8	24.8	32.8	22.8	146	20	75	71			
JUNE	31.2	24.2	32.8	22.2	469	27	81	77			
JULY	30.3	24.2	32.8	22.2	538	26	82	81			
AUGUST	31.1	24.5	32.8	22.8	456	25	80	77			
SEPTEMBER	30.6	24.6	32.8	22.8	298	19	82	78			
OCTOBER	31.2	24.3	32.8	22.8	361	24	80	78			
NOVEMBER	31.3	24.7	32.8	23.3	290	27	79	79			
DECEMBER	31.1	24.4	32.2	22.8	266	26	80	78			
TOTAL											
AVERAGE	31.1	24.3	32.3	22.7	254	21	78	74			

SOURCE: NATIONAL WEATHER SERVICE OFFICE, PALAU

Appendix 3-1-(2) Monthly Temperature, Precipitation, Humidity (2-2)

KOROR (1984)

MONTH	TEMPERATURE (°C)				MONTHLY AVERAGE (°C)	PRECIPITATION		MEAN RELATIVE HUMIDITY	
	AVERAGE		EXTREME			TOTAL (mm)	DAYS	09:00 am (%)	15:00 pm (%)
	Max.	Min.	Max.	Min.					
JANUARY	30.8	23.7	32.2	22.8	27.3	472	28	81	79
FEBRUARY	30.6	23.7	31.7	22.8	27.2	275	25	82	77
MARCH	31.2	24.1	32.2	22.2	27.6	345	25	79	76
APRIL	31.3	24.6	32.2	22.8	27.9	184	24	78	73
MAY	31.8	24.5	32.0	22.8	28.2	276	27	78	75
JUNE	30.9	23.8	31.7	22.8	27.3	419	25	81	79
JULY	31.4	23.6	32.8	22.2	27.5	326	22	78	75
AUGUST	30.5	23.9	32.2	21.1	27.2	444	22	78	77
SEPTEMBER	31.1	24.1	32.8	22.2	27.6	264	21	76	75
OCTOBER	30.1	24.2	32.2	22.8	27.2	405	26	82	78
NOVEMBER					No Data				
DECEMBER					No Data				
TOTAL	-	-	-	-	-	-	-	-	-
AVERAGE	31.0	24.0	32.3	22.5	27.5	341	24.5	79	76

SOURCE: NATIONAL WEATHER SERVICE OFFICE, PALAU

Appendix 3-1-(3)
Yearly and Monthly Average Temperature

KOROR
1978-1984

MONTH	AVERAGE TEMPERATURE (°F)						
	1978	1979	1980	1981	1982	1983	1984
JANUARY	81.3	81.4	80.8	81.1	81.7	80.5	81.1
FEBRUARY	80.1	81.3	80.2	80.4	81.7	81.2	80.9
MARCH	82.0	81.3	81.4	81.2	81.1	81.7	81.7
APRIL	81.9	81.3	81.8	82.0	81.7	82.2	82.3
MAY	82.6	81.4	82.5	82.6	81.8	83.0	82.7
JUNE	81.8	81.0	81.8	80.9	81.5	81.9	81.2
JULY	82.3	81.1	81.1	81.2	81.1	81.1	81.5
AUGUST	80.8	81.6	80.9	81.7	81.1	82.0	81.0
SEPTEMBER	80.9	82.1	81.6	81.6	82.4	82.0	81.7
OCTOBER	81.4	82.0	82.3	81.2	81.8	82.0	80.9
NOVEMBER	81.7	82.2	83.0	82.5	82.3	82.4	—
DECEMBER	81.8	81.5	82.3	82.1	81.7	82.0	—
TOTAL							
AVERAGE	81.6	81.6	81.7	81.5	81.7	81.8	—

Yearly and Monthly Precipitation

KOROR
1978-1984

MONTH	PRECIPITATION (INCH)						
	1978	1979	1980	1981	1982	1983	1984
JANUARY	10.34	6.98	8.72	11.32	5.79	3.44	18.57
FEBRUARY	22.46	6.47	16.01	15.00	6.81	.64	10.81
MARCH	6.02	7.96	5.53	4.49	9.90	1.71	13.58
APRIL	8.98	27.69	18.80	3.00	9.45	3.12	7.23
MAY	12.52	11.26	10.02	9.66	19.12	5.73	10.85
JUNE	16.04	22.84	19.50	29.17	22.41	18.48	16.49
JULY	9.13	17.79	12.40	21.14	19.40	21.20	12.82
AUGUST	20.36	11.69	15.26	6.89	10.94	17.96	17.47
SEPTEMBER	10.85	12.29	13.60	16.70	4.04	11.73	10.39
OCTOBER	20.06	11.97	17.11	14.30	8.82	14.23	15.94
NOVEMBER	17.66	11.57	12.17	11.37	9.92	11.40	—
DECEMBER	10.33	11.57	19.95	9.81	13.71	10.48	—
TOTAL	164.75	160.08	169.07	132.83	137.31	120.12	
AVERAGE	13.73	13.34	14.09	12.74	11.44	10.01	—

SOURCE: NATIONAL WEATHER SERVICE OFFICE, PALAU

Appendix 3-1-(4)
Max. and Min. Precipitation

(Unit : mm)

Items Month	Monthly Precipitation		Monthly Precipitation		Daily Precipitation	
	Max.	Year	Min.	Year	Max.	Year
January	714	1974	54	1973	352	1974
February	570	1978	31	1973	214	1980
March	558	1972	62	1955	157	1953
April	703	1979	42	1948	431	1979
May	697	1954	206	1974	209	1958
June	580	1979	150	1976	148	1972
July	884	1962	105	1964	209	1962
August	626	1952	210	1975	208	1962
September	528	1962	171	1967	215	1949
October	571	1974	172	1951	157	1957
November	560	1958	119	1957	131	1967
December	536	1975	161	1969	164	1974

———— Shows Max. (Min) Value for Past 10 Years.

Max. Wind Speed

Items Month	Max. for Past 10 Years		
	Speed m/s	Direction	Year
January	19.1	NW	1975
February	13.3	SE	1968
March	32.4	S	1967
April	26.7	SW	1976
May	15.5	SW	1976
June	17.8	SW	1967
July	15.1	W	1969
August	15.1	SW	1978
September	15.1	N	1969
October	16.0	SW	1968
November	26.2	SE	1964
December	22.2	N	1972

———— Shows Max. (Min) Value for Past 10 Years.

Source : National Wether Service Office, Palau

MAP UNITS

SOILS ON BOTTOM LANDS

- 1 Dachel-Messei-Ngersuuf: Very deep, very poorly drained, and somewhat poorly drained, level and nearly level soils; on valley and coastal bottom lands
- 2 Ngerungor Variant-Ngerungor: Very deep, very poorly drained, level and nearly level soils; on bottom lands and in depressional areas
- 3 Itacheromei: Very deep, very poorly drained, level soils; in the intertidal zone adjacent to the shoreline

SOILS ON MARINE TERRACES

- 4 Tebecheding-Ngaspang: Very deep, somewhat poorly drained and moderately well drained, nearly level to steep soils; on dissected terraces

SOILS ON VOLCANIC UPLANDS

- 5 Airmalik-Palau: Very deep, well drained, nearly level to very steep; on hills
- 6 Babelthuaup-Airmalik-Ngardmau: Very deep, well drained, nearly level to very steep soils; on hills and ridges
- 7 Ngerdok-Babelthuaup: Very deep, well drained, nearly level to very steep soils; on ridgetops and side slopes
- 8 Oliei-Nekken-Rock outcrop: Shallow and moderately deep, well drained, strongly sloping to very steep soils, and Rock outcrop; on hills and ridge-tops

SOILS ON LIMESTONE

- 9 Rock outcrop-Peliliu: Rock outcrop, and shallow, well drained, very steep soils; on uplands

- 10 Peliliu-Rock outcrop: Shallow, well drained, nearly level to moderately steep soils, and Rock outcrop; on low-lying coral islands


SOILS THAT FORMED IN CORAL SAND

- 11 Ngedebus: Very deep, somewhat excessively drained, nearly level to gently sloping soils; on raised beach deposits

Compiled 1981

U.S. DEPARTMENT OF AGRICULTURE
SOIL CONSERVATION SERVICE
FOREST SERVICE
U.S. DEPARTMENT OF INTERIOR
OFFICE OF THE HIGH COMMISSIONER
TRUST TERRITORY OF THE PACIFIC ISLANDS
UNIVERSITY OF HAWAII AT MANOA
COLLEGE OF TROPICAL AGRICULTURE AND HUMAN RESOURCES


GENERAL SOIL MAP
ISLANDS OF PALAU
FEDERATED STATES OF MICRONESIA



Each area outlined on this map consists of more than one kind of soil. The map is thus meant for general planning rather than a basis for decisions on the use of specific tracts.

Appendix 3-2-(2) Grading Analysis and Physical, Chemical Properties

SOIL NAME AND MAP SYMBOL	SAMPLING DEPTH (cm)	CLASSIFICATION	FRAG- MENTS > 76mm (%)	PERCENTAGE PASSING SIEVE NUMBER							FERMEABILITY (cm/hr)	pH	LIQUID LIMIT (%)
				# 4 (5)		# 10 (1.5)		# 40 (0.5)		# 200 (0.075)			
				(%)	(%)	(%)	(%)	(%)	(%)	(%)			
⑤ Aimeilik	0 - 10	Silt loam	0	85-100	85-100	75-100	60-90	5	5	3.6-5.0	80-90		
	10 - 86	Silt loam, Silty clay clay	0	95-100	90-100	85-100	75-90	5	5	4.5-5.5	75-85		
	86 - 150	Silt loam, Silty clay loam	0	100	100	90-100	80-95	5	5	4.5-5.5	75-85		
⑤ Babelthuap	0 - 10	Very gravelly loam	0-15	80-90	20-50	20-50	15-40	15	15	3.6-5.5	35-60		
	10 - 64	Silty clay loam, Silty clay	0	95-100	75-90	70-90	65-85	5	5	3.6-5.5	65-85		
	64 - 150	Silty loam, Silty clay loam	0	95-100	75-90	70-85	65-85	5	5	4.5-5.5	80-95		
⑧ Nakken	0 - 20	Very gravelly silt loam	10-20	30-55	25-50	25-45	20-35	5	5	5.6-6.5	25-35		
	20 - 46	Very gravelly clay loam	10-20	30-55	25-50	25-45	20-45	1.5	1.5	5.1-6.0	35-45		
	46 - 56	Very gravelly silt loam	10-20	40-60	35-55	30-50	25-40	1.5	1.5	5.1-6.0	25-35		
	56 - 150	Unweathered bedrock	—	—	—	—	—	—	—	—	—		
⑤ Ngatpang	0 - 15	Silty clay loam	0	80-100	75-100	70-100	65-95	1.5	1.5	4.5-5.5	80-90		
	15 - 28	Gravelly silty clay	0	45-80	35-75	30-75	25-70	1.5	1.5	3.6-5.0	75-85		
		Gravelly clay loam											
① Dechel 408	28 - 114	Very gravelly clay loam	0	95-100	90-100	80-100	70-95	0.5	0.5	3.6-5.0	75-85		
	114 - 150	Clay, silty clay	0	100	100	90-100	75-95	0.2	0.2	3.6-5.0	80-100		
		Clay, silty clay											
		Mucky silt loam	0	100	100	90-100	70-100	5	5	5.1-7.3	75-100		
③ L lachetomei	10 - 102	Silty clay loam	0	100	100	90-100	85-100	0.5	0.5	5.1-7.3	65-75		
	102 - 109	Very gravelly silty clay loam	10-15	35-60	30-55	30-55	25-55	1.5	1.5	5.1-7.3	65-75		
	109 - 168	Silty clay loam, Silty loam	0	100	100	90-100	85-100	0.2	0.2	5.1-7.3	65-75		
④ Tabecheding	0 - 150	Peat	—	—	—	—	—	15	15	5.6-6.0	—		
	0 - 18	Silty clay loam	0	100	100	95-100	90-95	1.5	1.5	3.6-5.0	50-60		
	18 - 51	Clay, Silty clay	0	80-100	75-100	70-100	60-95	0.2	0.2	3.6-4.4	80-100		
	51 - 158	Clay, Silty clay	0	80-100	75-100	70-100	60-95	< 0.2	< 0.2	3.6-4.4	90-115		



1	EXISTING ROAD	0.4 M	SEE
2	EXISTING ROAD	0.4 M	SEE
3	EXISTING ROAD	0.4 M	SEE
4	EXISTING ROAD	0.4 M	SEE
5	EXISTING ROAD	0.4 M	SEE
6	EXISTING ROAD	0.4 M	SEE
7	EXISTING ROAD	0.4 M	SEE
8	EXISTING ROAD	0.4 M	SEE
9	EXISTING ROAD	0.4 M	SEE
10	EXISTING ROAD	0.4 M	SEE
11	EXISTING ROAD	0.4 M	SEE
12	EXISTING ROAD	0.4 M	SEE
13	EXISTING ROAD	0.4 M	SEE
14	EXISTING ROAD	0.4 M	SEE
15	EXISTING ROAD	0.4 M	SEE
16	EXISTING ROAD	0.4 M	SEE
17	EXISTING ROAD	0.4 M	SEE
18	EXISTING ROAD	0.4 M	SEE
19	EXISTING ROAD	0.4 M	SEE
20	EXISTING ROAD	0.4 M	SEE
21	EXISTING ROAD	0.4 M	SEE
22	EXISTING ROAD	0.4 M	SEE
23	EXISTING ROAD	0.4 M	SEE
24	EXISTING ROAD	0.4 M	SEE
25	EXISTING ROAD	0.4 M	SEE
26	EXISTING ROAD	0.4 M	SEE
27	EXISTING ROAD	0.4 M	SEE
28	EXISTING ROAD	0.4 M	SEE
29	EXISTING ROAD	0.4 M	SEE
30	EXISTING ROAD	0.4 M	SEE
31	EXISTING ROAD	0.4 M	SEE
32	EXISTING ROAD	0.4 M	SEE
33	EXISTING ROAD	0.4 M	SEE
34	EXISTING ROAD	0.4 M	SEE
35	EXISTING ROAD	0.4 M	SEE
36	EXISTING ROAD	0.4 M	SEE
37	EXISTING ROAD	0.4 M	SEE
38	EXISTING ROAD	0.4 M	SEE
39	EXISTING ROAD	0.4 M	SEE
40	EXISTING ROAD	0.4 M	SEE
41	EXISTING ROAD	0.4 M	SEE
42	EXISTING ROAD	0.4 M	SEE
43	EXISTING ROAD	0.4 M	SEE
44	EXISTING ROAD	0.4 M	SEE
45	EXISTING ROAD	0.4 M	SEE
46	EXISTING ROAD	0.4 M	SEE
47	EXISTING ROAD	0.4 M	SEE
48	EXISTING ROAD	0.4 M	SEE
49	EXISTING ROAD	0.4 M	SEE
50	EXISTING ROAD	0.4 M	SEE
51	EXISTING ROAD	0.4 M	SEE
52	EXISTING ROAD	0.4 M	SEE
53	EXISTING ROAD	0.4 M	SEE
54	EXISTING ROAD	0.4 M	SEE
55	EXISTING ROAD	0.4 M	SEE
56	EXISTING ROAD	0.4 M	SEE
57	EXISTING ROAD	0.4 M	SEE
58	EXISTING ROAD	0.4 M	SEE
59	EXISTING ROAD	0.4 M	SEE
60	EXISTING ROAD	0.4 M	SEE
61	EXISTING ROAD	0.4 M	SEE
62	EXISTING ROAD	0.4 M	SEE
63	EXISTING ROAD	0.4 M	SEE
64	EXISTING ROAD	0.4 M	SEE
65	EXISTING ROAD	0.4 M	SEE
66	EXISTING ROAD	0.4 M	SEE
67	EXISTING ROAD	0.4 M	SEE
68	EXISTING ROAD	0.4 M	SEE
69	EXISTING ROAD	0.4 M	SEE
70	EXISTING ROAD	0.4 M	SEE
71	EXISTING ROAD	0.4 M	SEE
72	EXISTING ROAD	0.4 M	SEE
73	EXISTING ROAD	0.4 M	SEE
74	EXISTING ROAD	0.4 M	SEE
75	EXISTING ROAD	0.4 M	SEE
76	EXISTING ROAD	0.4 M	SEE
77	EXISTING ROAD	0.4 M	SEE
78	EXISTING ROAD	0.4 M	SEE
79	EXISTING ROAD	0.4 M	SEE
80	EXISTING ROAD	0.4 M	SEE
81	EXISTING ROAD	0.4 M	SEE
82	EXISTING ROAD	0.4 M	SEE
83	EXISTING ROAD	0.4 M	SEE
84	EXISTING ROAD	0.4 M	SEE
85	EXISTING ROAD	0.4 M	SEE
86	EXISTING ROAD	0.4 M	SEE
87	EXISTING ROAD	0.4 M	SEE
88	EXISTING ROAD	0.4 M	SEE
89	EXISTING ROAD	0.4 M	SEE
90	EXISTING ROAD	0.4 M	SEE
91	EXISTING ROAD	0.4 M	SEE
92	EXISTING ROAD	0.4 M	SEE
93	EXISTING ROAD	0.4 M	SEE
94	EXISTING ROAD	0.4 M	SEE
95	EXISTING ROAD	0.4 M	SEE
96	EXISTING ROAD	0.4 M	SEE
97	EXISTING ROAD	0.4 M	SEE
98	EXISTING ROAD	0.4 M	SEE
99	EXISTING ROAD	0.4 M	SEE
100	EXISTING ROAD	0.4 M	SEE

JCR APPROVAL

EXPORT LINES AMENDED TO RUN PARALLEL TO BOUNDARY WALL

CLIENT	PALAU POWER STATION
PRIME CONTRACTOR	SITE PLAN
MAIN CONTRACTOR	MICHAEL J. CROFTON & ASSOCIATES

THE REPUBLIC OF PALAU

PRIME CONTRACTOR
P.E.E.C.O. INTERNATIONAL POWER SYSTEMS LTD.
103-105 JERMYN STREET
LONDON SW1Y 6EE


MAIN CONTRACTOR
MEL APE LTD CROSSLEY ENGINES
P.O. BOX POTTERY LANE
OPENSHAW
MANCHESTER

SCALE 1:250

DRG. NO. 5500 - C100-12

Appendix 4-2

Appendix 5-1-(1) ELECTRIFICATION AREA MAP



Appendix 5-1-(2) Detail of Electrification Plan (1)

No	State	Area	Houses						Others		Total kVA	Remarks	
			Existing		Future		Total	Items	kVA				
			No.	kVA	No.	kVA			No.	kVA			Exsit.
①	Airai	Zone 1	—	—	10	13	10	13			13		
②	'	2	—	—	5	6	5	6			6		
③	'	3	—	—	10	13	10	13			13		
④	'	4	—	—	10	13	10	13			13		
⑤	'	5	1	1	2	3	3	4			4		
⑥	'	6	2	3	—	—	2	3			3	Seven (7) houses already receive the power of Airai State.	
⑦	Aimelilik	NEKKENG	3	4	—	—	3	4	Forestry Stn. OISCA	12.5 12.5	12.5 12.5	29	
⑧	'	Imelsubech	11	14	—	—	11	14	IPSECO	13	—	13	27
⑨	'	Medorm	13	16	—	—	13	16	Communi.Center	4	—	4	20
⑩	'	Imul	24	30	—	—	24	30					30
⑪	'	Ngeikeai	8	10	—	—	8	10	Government Office Elementary School Kindergarten Billiards Repair Shop Ice Plant	6 4 4 1 4 24	6 4 4 1 4 24	43	220V, 3φ

Appendix 5-1-(2) Detail of Electrification Plan (2)


No.	State	Area	Houses					Others			Total	Remarks		
			Existing		Future		Total	Items	kVA					
			No.	kVA	No.	kVA			No.	kVA			Exsit.	Future
⑫	Aimeilik	Elechui	5	6	—	—	5	6	Communi. Center	4	—	4	10	Because rood condition is very bad , Construction of distribution line is very difficult.
⑬	Ngatpang	Housing area	—	—	30	38	30	38					38	
⑭	"	Ngatpang	11	14			11	14	Government Office Communi. Center Meeting Place Elementary School Pier Ice Plant Dock House Public Works	6 6 3 4 0.5 24 0.5 —	— — — — — — — 6	6 6 3 4 0.5 24 0.5 6		220V, 3ø
Total			78	98	67	86	145	184				50	323	

Appendix 6 - 1 Measurement of Salt Contamination


Test No.	Kind of Insulator	Dia. x Height (mm)	Insulation Mark	Insulation Color	Exposed Term	Surface of Measurement	Salt Contamination
1-1	Pin Type	135φ x 110	1973 ME	Gray	1/17 ~ 1/19 (3 days)	All	Less Than 0.01%
1-2	"	"	"	"	1/20 ~ 1/25 (6 days)	"	"
2	"	"	"	"	1/17 ~ 1/25 (9 days)	"	"
3	"	"	"	"	"	"	"
4	"	"	1970 ME	Brown	More Than 10 Years	"	"
5	High - Voltage Pin Type	168φ x 145	CHANCE' 1968	"	1/17 ~ 1/25 (9 days)	"	"
6	Dead End Type	155φ x 128	LOCKE 1951EU	"	More Than 10 Years	Under	"
7	"	"	"	"	"	Under + Upper	"
8-1	Suspension	254 x 140	(Nishigai) 1950-10	Gray	1/17 ~ 1/19 (3 days)	"	"
8-2	"	"	"	"	1/20 ~ 1/25 (6 days)	"	"
9	"	"	"	"	1/17 ~ 1/25 (9 days)	"	"
10	"	"	"	Brown	"	"	"
11	"	"	"	"	"	"	"

* Salt Contamination : Measured it by washing surface of the insulator with 150 ml - water.

Appendix 6 - 2 - (1) Example of Support Structure Arrangement




Suspension Pole 34.5 kV 2cct




Section Pole 34.5 kV 1cct
13.8 kV 1cct

Suspension Pole 34.5 kV 1cct
13.8 kV 1cct


Appendix 6 - 2 - (2) Example of Support Structure Arrangement





Section Pole 34.5kV 1cct




Suspension Pole 34.5kV 1cct




Suspension Pole 13.8kV 1cct



Section Pole 13.8kV 1cct





Appendix 6 - 3

REPUBLIC OF PALAU

**STEP-UP SUBSTATION
SINGLE LINE DIAGRAM**

EPDC International Ltd
TOKYO JAPAN


S.R.I.	SUBMITTED:
T.R.I.	RECOMMENDED:
C.A.I.	APPROVED:

LOCATION	DATE	DESCRIPTION	BY

REVISION

JICA
CONSTRUCTION
SCOPE

IPSECO




To Distribution Line (13.8kV)

From Transmission Line (34.5kV)

Appendix 6 - 4

REPUBLIC OF PALAU	
STEP-DOWN SUBSTATION SINGLE LINE DIAGRAM	
EPDC International Ltd. TOKYO JAPAN	
D.R.:	SUBMITTED:
T.R.:	RECOMMENDED:
C.K.:	APPROVED:



LOCATION	DATE	DESCRIPTION	BY
REVISION			



Appendix 6-5
 REPUBLIC OF PALAU
 LAYOUT
 FOR STEP-UP SUBSTATION

SCALE	EPOC International Ltd. TOKYO JAPAN
1/100	D.R.: SUBMITTED; T.R.: RECOMMENDED; C.A.: APPROVED;
SHEET NO. OF	

LOCATION	DATE	DESCRIPTION	BY
REVISION			




A-A SECTION

Appendix 6 - 6

REPUBLIC OF PALAU	
LAYOUT FOR STEP-DOWN SUBSTATION	
SCALE	EPOC International Ltd. TOKYO JAPAN
1/100	G.R.: SUBMITTED:
	F.R.: RECOMMENDED:
	C.R.: APPROVED:

LOCATION	DATE	DESCRIPTION	BY
REVISION			



REPUBLIC OF PALAU
**POWER SYSTEM DIAGRAM OF
 TEMPORARY TRANSMISSION
 SCHEME**

Appendix 6 - 7


LOCATION	DATE	DESCRIPTION	BY

EPOC International L.L.C. TOKYO JAPAN
 SUBMITTED:
 RECOMMENDED:
 APPROVED:

SHEET NO. 1 OF

2

3



Appendix 6 - 8

REPUBLIC OF PALAU	
SINGLE LINE DIAGRAM OF TEMPORARY TRANSMISSION SCHEME	
EPOC International Ltd. TOKYO JAPAN	
D.R.:	SUBMITTED:
T.R.:	RECOMMENDED:
C.A.:	APPROVED:

LOCATION	DATE	DESCRIPTION	BY

新発電所発電コスト（内訳）

・ 年間発生電力量

以下の算定により機械・設備の耐用年数（15年）の間における，年間平均発生電力量を48,287,700KWH/年とする。

（i）1985年1月の発電実績より平均負荷率を70%とする。

（根拠）休日；平均 2,274KWH

平日；平均 3,101KWH

ピーク；4,110

$$\text{平均負荷率} = \frac{2,274 \times 2 + 3,101 \times 5}{4,110 \times 7} = 70\%$$

（ii）現在の最大電力需要量：4,000KW，10年後の同量：9,000KW平均負荷率70%における10年間の平均発電量は4,550KWH/h。

（根拠）

$$1985\text{年} : 4,000\text{KW} \times 70\% = 2,800\text{KWH/h}$$

$$1995\text{年} : 9,000\text{KW} \times 70\% = 6,300\text{KWH/h}$$

（iii）設備・機械の耐用年数を15年とし，10年後から15年後の間の電力需要増加を年率5.6%とした場合の同期間の平均発電量は7,437KWH/h。

（増加率 5.6%の根拠）

今後10年間の年間平均増加量：350KWH/h（=（6,300 - 2,800）KWH/h ÷ 10年）に基づき，10年後～15年後の増加率を5.6%/年とする。

$$350\text{KWH/h} \div 6,300\text{KWH/h} \text{（10年後の平均発電量）} = 5.6\%$$

（10年後～15年後の平均発電量）

$$\{ (6,300 + 350) + (6,650 \times 1.056^1) + (6,650 \times 1.056^2) + (6,650 \times 1.056^3) + (6,650 \times 1.056^4) \} \div 5\text{年} = 7,437\text{WH/h}$$

（iv）以上から発電コスト算定に当たっての平均年間発生電力量は，48,287.7MWH/年とする。

$$\text{平均発電量} : (4,550\text{KWH/h} \times 10\text{年} + 7,437\text{KWH/h} \times 5\text{年}) \div 15\text{年} = 5512.3\text{KWH/h}$$

$$\text{平均年間発生電力量} : 5,512.3\text{KWH} \times 24 \times 365 = 48,287,748\text{KWH/年}$$

$$\Rightarrow 48,287,700\text{KWH/年}$$

・建設費

建設費総額から燃料油タンク建設費6百万ドルを差し引く。

$$28,965.8 \text{千ドル} - 6,000 \text{千ドル} = 22,965.8 \text{千ドル}$$

・年間経費

資本費：2,363.5千ドル

パラオ政府には減価償却の概念がないが、借入金のうち発電所建設費充当資金に対応する借入金の元本の返済は、事業収入に依るものではなく、米国の援助資金を原資とするパラオ政府財政の直接的負担となることから、これと同借入金支払利息を資本費とし、対応期間は機械・設備耐用年数の15年とする。

(借入金明細は資料8-2参照)

借入金合計：32,478.7千ドル

支払利息計：17,666.4千ドル

元本・利息合計：50,145.1千ドル

$$\text{発電所建設費対応分} : 50,145.1 \text{千ドル} \times \frac{22,965.8 \text{千ドル}}{32,478.7 \text{千ドル}} = 35,452.6 \text{千ドル}$$

$$\text{年間資本費} : 35,452.6 \text{千ドル} \div 15 \text{年} = 2,363.5 \text{千ドル}$$

直接費：1,115.1千ドル

(修繕費) 建設費の2%とする。

$$22,965.8 \text{千ドル} \times 0.02 = 459.3 \text{千ドル}$$

(諸費) 建設費の0.4%とする。

$$22,965.8 \text{千ドル} \times 0.004 = 91.9 \text{千ドル}$$

(人件費) 国家資源省公共事業庁所属職員の年間平均給与は、パラオ政府説明から7千ドル前後であることから、1984年度の人件費(推定)342.6千ドルに人員増加15人=105千ドルを見込むこととする。

$$342.6 \text{千ドル} + 105 \text{千ドル} = 447.6 \text{千ドル}$$

(潤滑油費) 消費率 1.6g/KWH, 比重0.91, 単価1.37ドル/ℓ (=5.18ドル/gal)

とする。

$$1.6 \times 1/1,000 \times 1/0.91 \times 48,287.7 \text{千KWH} \times 1.37 = 116.3 \text{千ドル}$$

燃料費：2,241.6千ドル

消費率 210g/KWH, 比重0.95, 単価21セント/ℓ (=79セント/gal) とする

$$210 \times 1/1,000 \times 1/0.95 \times 48,287.7 \text{ kWh} \times 0.21 = 2,241.6 \text{ 千ドル}$$

・年間総経費：5,720.2千ドル

・資本費を除く総経費：3,356.7千ドル

発電コスト：

資本費を含む場合：0.118ドル/KWH⇒12セント/KWH

資本費を除く場合：0.0695ドル/KWH⇒7セント/KWH

Appendix 8-2-(1) Details of the Loans From British Banks

(Unit: US\$ 1,000.-)

Consolidated Basis of Three Loans							
Repayment schedules of each loan are as per attached next page. Appendix 8-2-(2)							
⊗ "Equivalent to Construction Cost" indicates that a pro-rata portion of the power plant construction cost against total repayment amount.							
Date	Borrowing	Repayment of Principal (A)	Balance of Borrowing	Interest Payment (Calculated at 12.5% p.a.)		Repayment Amount in Each Fiscal Year (A)+(B)=(C)	Equivalent to Construction Cost (C) x 70.7% (⊗)
				Term	Int. Amount (B)		
1983. 6. 8	32,478.7		32,478.7				
				1983.6.8 - 8.31 (85 d/s)	862.7	862.7	609.9
9. 1			32,478.7				
				1983.9.1-84.2.29 (182 d/s)	1,847.2	3,714.7	2,626.3
1984. 3. 1			32,478.7				
				1984.3.1 - 8.31 (184 d/s)	1,867.5	9,994.6	7,066.2
9. 1			32,478.7				
				1984.9.1-85.2.28 (181 d/s)	1,837.1	8,730.7	6,172.6
1985. 3. 1		2,282.0	30,196.7				
				1985.3.1 - 8.31 (184 d/s)	1,736.2	5,477.4	3,872.5
9. 1		4,139.2	26,057.5				
				1985.9.1-86.2.28 (181 d/s)	1,473.9	5,048.6	3,569.4
1986. 3. 1		4,139.2	21,918.3				
				1986.3.1 - 8.31 (184 d/s)	1,260.3	4,624.9	3,269.8
9. 1		1,857.3	20,061.0				
				1986.9.1-87.2.28 (181 d/s)	1,134.7	3,962.1	2,801.2
1987. 3. 1		1,857.3	18,203.7				
				1987.3.1 - 8.31 (184 d/s)	1,046.7	1,833.4	1,296.2
9. 1		1,857.3	16,346.4				
				1987.9.1-88.2.29 (182 d/s)	929.7	17,666.4	35,452.6
1988. 3. 1		1,857.3	14,489.1				
				1988.3.1 - 8.31 (184 d/s)	833.1	50,145.1	
9. 1		1,857.3	12,631.8				
				1988.9.1-89.2.28 (181 d/s)	714.5		
1989. 3. 1		1,857.3	10,774.5				
				1989.3.1 - 8.31 (184 d/s)	619.5		
9. 1		1,857.3	8,917.2				
				1989.9.1-90.2.28 (181 d/s)	504.4		
1990. 3. 1		1,857.3	7,059.9				
				1990.3.1 - 8.31 (184 d/s)	405.9		
9. 1		1,857.3	5,202.6				
				1990.9.1-91.2.28 (181 d/s)	294.3		
1991. 3. 1		1,734.2	3,468.4				
				1991.3.1 - 8.31 (184 d/s)	199.4		
9. 1		1,734.2	1,734.2				
				1991.9.1-92.3.1 (183 d/s)	99.2		
1992. 3. 1		1,734.2	0				
	32,478.7	32,478.7					

Appendix 8 - 2 - (2)

(Unit : US\$ 1,000.-)

Date	Repayment	Balance	Interest (11.25% fixed)
Amount : US\$ 24,278,700 Lender : International Westminster Bank PLC Guaranteed by ECGD			
1983.6.8		24,278.7	
1985.9.1	1,734.2	22,544.5	
1986.3.1	1,734.2	20,810.3	
1986.9.1	1,734.2	19,076.1	
1987.3.1	1,734.2	17,341.9	
1987.9.1	1,734.2	15,607.7	
1988.3.1	1,734.2	13,873.5	
1988.9.1	1,734.2	12,139.3	
1989.3.1	1,734.2	10,405.1	
1989.9.1	1,734.2	8,670.9	
1990.3.1	1,734.2	6,936.7	
1990.9.1	1,734.2	5,202.5	
1991.3.1	1,734.2	3,468.3	
1991.9.1	1,734.2	1,734.2	
1992.3.1	1,734.2	0	
Amount : US\$ 1,354,200 out of US\$ 8,200,000 Lender : County Bank			
1983.6.8		1,354.2	
1985.9.1	123.1	1,231.1	
1986.3.1	123.1	1,108.0	

(Unit : US\$ 1,000.-)

Date	Repayment	Balance	Interest (11.25% fixed)
1986.9.1	123.1	984.9	
1987.3.1	123.1	861.8	
1987.9.1	123.1	738.7	
1988.3.1	123.1	615.6	
1988.9.1	123.1	492.5	
1989.3.1	123.1	369.4	
1989.9.1	123.1	246.3	
1990.3.1	123.1	123.1	
1990.9.1	123.1	0	
Amount : US\$ 6,845,800 out of US\$ 8,200,000 Lender : County Bank			
1983.6.8		6,845.8	
1985.3.1	2,282.0	4,563.8	
1985.9.1	2,281.9	2,281.9	
1986.3.1	2,281.9	0	

JICA