

### 2.3.5 Road tanker transportation

This is temporary vehicle transportation considered for lateral drainage-1 (elimination of standing water)

Amount to be transported : 1.0 m<sup>3</sup>/min  
No. of road tankers : 8 unit/day (5,000 Imp. gallon tanker)  
Distance : 10 km to West Bay  
Operation hours : 12 hours/day

- Cycle time of vehicle

Loading time : 20 min  
Transportation : 60 min (return)  
Unloading : 20 min

---

One cycle : 100 min

- Required number of road tankers

Capacity of transportation per unit tanker  
 $22.5 \text{ m}^3/100 \text{ min} = 0.225 \text{ m}^3/\text{min}/\text{unit}$

Required number

$1.0 \text{ m}^3/\text{min} \times 24/12/0.225 \text{ m}^3/\text{min} = 8$   
8 units of 5,000 Imp. Gallon tankers





Fig. 2.3.1  
GRAVITY FLOW PIPE LINE

- LEGEND
- ☒ MANHOLE
  - ▬ GRAVITY FLOW PIPE 400
  - ▬ PRESSURE PIPE 1250
  - - - SURFACE WATER SEWERAGE







Fig. 2.3.2  
OPEN CHANNEL WITH  
RECREATION POND

OPEN CHANNEL - SECTION



RECREATION POND - SECTION






Fig. 2.3.3 Section of Open Channel and Recreation Pond

Sheet Method



Concrete Slab Method



Rubber Asphalt Method




Fig. 2.3.4 Water Shut-off Methods

## 2.4 Disposal Points

Unless the quantity is very limited, there is a problem that high salinity groundwater abstracted from Rayyan may diminish biological treatment capacity at sewage treatment works if disposed there.

Therefore disposal points are either sea or desert.

### 2.4.1 West Bay


Water shall be discharged into sea directly by way of outfall (Fig. 2.4.1) or through a mangrove lagoon DRP-4006 for water quality improvement.

### 2.4.2 Musherib Stormwater Trunk Line


Transfer line shall be connected to the upstream end of the Wadi Musherib stormwater trunk line in progress at Wadi Musherib, discharging the water into Doha Bay.

### 2.4.3 Desert

Disposal at desert area was examined but considering the recirculation of discharged water, distance to the possible area is far greater than those for the other two alternatives. Should closer locations be used, shutoff of infiltration by sheet covering is required for a huge area and not economical.



PLAN



SECTION

Fig. 2.4.1 Outfall Structure

## 2.5 Cost Estimation of the Alternatives

Regarding all the alternative in Section 2, rough cost estimation was made for comparison purpose according to the cost data obtained in Doha and information in Japan. Prior to cost estimation, quantities of the works for each alternative were also calculated.

Especially cost for mangrove lagoon project is just indicative cost for civil construction.

### 2.5.1 Unit rates

Sources of unit rates are referred to in the relevant section of Wadi Musherib drainage plan. In addition for pump station equipment and special pipe for transfer line, prices currently prevailing in Japan were used.

The applied unit rates for cost estimation are listed in Table 2.5.1.



Table 2.5.1 Unit Rates for Cost Estimation

Item	Specification	Unit	Rate (QR)	Remarks	
Excavation	Including dewatering	m <sup>3</sup>	180		
Disposal of surplus soil		"	30		
Backfilling		"	30		
Gravel filling	Dia. 13-20, 25-45 and 50-75 mm with compaction	"	45		
Structural concrete	Sulphate resistant cement, GRADE 25	"	300		
Lean concrete	Sulphate resistant cement, GRADE 15	"	260		
Reinforcing bar		ton	3,000		
Shuttering		m <sup>2</sup>	20		
Perforated pipe	ESVC pipe	ø300	m	150	Material and installation
		ø450	"	200	
		ø600	"	500	
Closed pipe	Concrete pipe	ø600	m	200	
Manhole	Precast concrete manhole, ø900 (inner diameter)	H=4-5 m	no.	6,000	Material and installation
		5 -6 m	"	7,000	
		> 6 m	"	8,500	
Reinstatement of road	Asphalt pavement	m <sup>2</sup>	75		
Embankment	H=1.7 m	"	25		
Fence	Galvanized wire mesh fence, H=2.0 m	m	400		
Gate	W=6.0 m, H=2.0 m	no.	5,250		
Pump house	Reinforced concrete frame with block wall	m <sup>2</sup>	3,500		
Discharge pipe	Ductile iron pipe with bends and fittings	ø250	m	326	Material and installation
		ø350	"	489	
Earthwork	Excavation, disposal of surplus soil, backfilling and dewatering	m <sup>3</sup>	180		
Pavement cutting and resurfacing		m <sup>2</sup>	250	For discharge pipe line	
Intermediate water chamber		no.	41,000		
Branch		"	2,670		
Temporary outfall		"	12,000		

## 2.5.2 Bill of Quantities

Quantities of the major works for groundwater collection system and transfer system are as follows;

### (1) Collection system

Table 2.5.2 Quantities of the Works for Collection System at Old Rayyan


Item		Spec.	Unit	Elimination of standing water	Comb arrangement	Perimeter arrangement
Pipe Length	ø600	Perforated pipe	m	-	-	327
	ø450	"	"	1,030	2,500	1,646
	ø300	"	"	-	3,580	3,868
Manhole			no.	10	59	59
Excavation			m <sup>3</sup>	8,700	57,800	54,800
Gravel filling			"	3,800	26,100	24,900
Sand filling			"	-	-	-
Concrete			"	600	1,700	1,600

(2) Transfer system

Table 2.5.3 Quantities of the Works for Transfer System at Old Rayyan

Item		Spec.	Unit	①	②	③	④
Pipe Length	ø250	Ductile iron pipe	m	6,700	6,700	-	-
	ø350	Ductile iron pipe	"	6,400	6,400	-	-
	ø250	Poly vinyl chloride pipe	"	-	-	2,400	2,400
	ø400	ESVC pipe	"	-	-	-	3,400
Open channel		W=5.5 D=1.5	m	-	-	3,300	-
Manhole			no.	0	0	4	25
Excavation			m <sup>3</sup>	37,000	37,000	171,400	9,700
Sand filling			"	0	0	1,100	4,000

The numbers of transfer systems mentioned in Table 2.5.3 refer to the following four routes;



### 2.5.3 Construction Cost

From unit rates and quantities of the works, construction cost for alternatives were derived as follows;

In these construction costs, land requisition cost and engineering fee are not included.

#### (1) Collection system

Table 2.5.4 Construction Cost of Collection System for Old Rayyan

(Unit: x 10<sup>3</sup> QR)

Alternative		Elimination of standing water	Comb arrangement	Perimeter arrangement	Remarks
Item					
Pipe work	Earth work	1,990	11,630	11,030	Excavation, disposal of surplus soil, backfilling and dewatering
	Installation	700	2,880	2,760	Pipe material delivered at site, concrete cradle, gravel and concrete bed
Manhole		150	870	870	Material, installation and earth work
Road reinstatement		150	380	1,200	
Pump station		1,000	-	-	Equipment, building and pump pit
Total		3,900	15,770	15,860	


## (2) Transfer system

Table 2.5.5 Construction Cost of Transfer System at Old Rayyan

		Unit Qatar Rials (x10 <sup>3</sup> )				
Item		①	②	③	④	Remarks
Pipe Work	Earth work	6,660	6,660	610	1,820	Excavation, disposal of surplus soil, backfilling and dewatering
	Installation	6,310	6,310	590	1,220	Pipe delivered at site Concrete cradle, gravel and bed concrete, thrust boring
Manhole		-	-	20	110	Material installation and earth work
Open channel		-	-	5,440	-	Earth work, slope protection, water shutoff sheet, walkway, plantation, culvert, etc.
Recreation pond		-	-	8,270	-	Park facilities in addition to the items of open channel
Pump station		3,130	3,130	2,120	2,120	Equipment, building and pump pit
Outfall		-	20	-	-	Earth work, concrete work
Mangrove lagoon		13,900	-	-	-	
Total		30,000	16,120	17,050	5,270	

Construction cost for the whole drainage system (combination of the collection system and transfer system) is shown in Table 2.5.6.

Table 2.5.6 Summary of Cost Estimation for Old Rayyan



## 2.6 Comparison of Alternatives

Regarding collection system and transfer-disposal system, features of each alternative are examined here. However alternative plan for elimination of standing water is different in purpose from the others and has been removed from the comparison.

### 2.6.1 Collection system

Table 2.6.1 Comparison Table for Collection System at Old Rayyan

	Perimeter arrangement	Comb arrangement	Utilizing existing wells
Effect of diminishing groundwater level	High	High	Rather low due to random locations
Collection method	Cutting flow from outside of the area	Collecting ground-water inside the area	Collecting ground-water inside the area
Land use	Allocated under roads and almost no obstruction	Allocated inside the area and somewhat restricting	Small pipes restricting
Length of the lateral drainage	Relatively short	Relatively long	Rather short
Cost	Relatively small	Relatively high	Relatively high

As summarized above, perimeter arrangement is recommendable for collecting system at Old Rayyan.

## 2.6.2 Transfer and disposal system

Alternatives proposed here have basically different functions other than transfer and disposal of drained groundwater and they therefore cannot be evaluated by one scale. In order to determine the final plan the following parameters shall be considered.

- a. Cost
- b. Urgency
- c. Re-use
- d. Pollution control
- e. Accordance with other projects

### a. Cost

Route-4 (gravity flow pipe method via Jaida petrol station) is considerably cheaper than others.

### b. Urgency

Considering the serious situation at Rayyan, at least the standing water shall be eliminated by the immediate implementation of phase-1. And discharge to No. 14 sewerage pumping station during phase-2 construction is inevitable.

When adopting Route-3 and 4 connecting to Wadi Musherib stormwater trunk line, implementation schedule thereof is important. Completion date for upstream end at Musherib Dam is not clear and there may be some discrepancy in timing of connection.

### c. Re-use

Route-1 (West Bay mangrove lagoon) shall be evaluated by the re-use parameter. As irrigation water for mangrove and date plantation, groundwater from Rayyan is more efficient than sea water.

Route-3 (open channel and recreational pond) aims to contribute a scenic landscape and recreational area for the citizens.

### d. Pollution control

It is estimated that quality of groundwater from Old Rayyan shall not require treatment before discharging into sea. Nevertheless Route-1 and 3 have water treatment functions. Route-1 contains the mangrove lagoon where mangrove trees improve COD and other ions by biochemical actions. On the other hand, Route-3 contains an open channel section where water flows on boulders and oxidization of water with air improves the water quality.

### e. Accordance with other projects

Doha Municipality has a plan to develop a garden near the Musherib Dam area and the Amir's Office has a plan for mangrove lagoon in the West Bay Development project. Therefore all alternatives shall have accordance with other projects by authorities concerned.



### 2.6.3 JICA's recommendation

When considering the construction cost and period, total pipe line system via Jaida Petrol Station is the most effective, but from the point of landscaping, open channel and recreation pond system is highly evaluated. However the plan composed of discharging the abstracted groundwater to the mangrove afforestation lagoon near the seashore offers the best re-use opportunity for the abstracted water in accelerating the growth of mangrove and diversification of mangrove species, and the development of such a large green afforestation park will definitely enhance the beauty of Doha City.

In conclusion the JICA study team recommend the lateral drainage in perimeter arrangement and discharge at West Bay coupled with mangrove afforestation.

### 3. Preliminary Design

According to the comparison of alternatives in 2.6, preliminary design is performed hereinafter.

#### 3.1 Lateral Drainage Facilities

##### 3.1.1 Outline of Drainage Facilities

Quantities of the lateral drainage facilities are as follows;

- Perforated pipe	:	ø300 - 3,910 m
		ø450 - 1,664 m
		ø600 - 330 m
		<hr/>
		Total 5,904 m
- Connection pipe to discharge pump station	:	ø600 - 25 m
- Manhole	:	59 nos.

General plan of the lateral drainage system is shown on DWG. No. DRP-3001 and detailed plans on DWG. Nos. DRP-3020 and 3021. The transversal and longitudinal sections are on DWG. Nos. DRP-3002 thru 3004.

##### 3.1.2 Outline of Drainage Plan

The lateral drainage facilities are designed to be located so as to cover and surround the project area. They shall be connected to the discharge pump station to be located in the center of the project area at the lowest part.

In addition to the perimeter drainage pipe, lateral drainage pipe is also provided in the central part of the network so that the distance between the drainage pipes located in parallel is at most 500 m. This enables the drainage by the lateral drain and the resultant drop of groundwater level to be more effective.

Since the lateral drainage pipe located in the central part of the network can collect less groundwater than the surrounding pipe once the groundwater level is lowered, it shall be used for the transfer line to the discharge pump station from the surrounding pipeline.

In the project area for Old Rayyan, the land is under suburban utilization such as large scale farming and housing so that few public roads run within this area. Therefore, a part of the lateral drainage pipeline shall be placed within private land.

### (1) Determination of Route

The lateral drainage pipe shall be placed

- to surround and cover the area where the groundwater level is less than 1.5 m below the ground level,
- in principle along the secondary roads so that no land acquisition is required and the hindrance to traffic by the construction can be minimized,
- under the carriage way where it cannot be placed along the road because it is too narrow,
- where the elevation of the road is higher than that of the vicinity, at the bottom of the embankment in order to reduce the cost of earth work, and
- to avoid houses and structures in cases when it cannot be placed along the road.

### (2) Depth of Lateral Drainage Pipe

The groundwater level in the lateral drainage network is about QND + 5.5 m and the invert level of pipe is set so that the depth of 3.5 to 4.0 m from the groundwater level can be kept.

Therefore, the invert level of the most upstream point is set as QND + 2.0 m. The hydraulic gradient is determined as 1/1000 and thereby the intake pit at the discharge pump station is not so deep.

As a result, the invert level is set ranging from QND + 2.0 m to QND + 0.3 m with an earth cover of 4 to 7 meters.

### (3) Design of Pipe

Since most of the abstracted groundwater, discharge of which is taken as 3,000,000 m<sup>3</sup>/year or 0.095 m<sup>3</sup>/sec, is considered to come from outside the project area, pipes on the perimeter of the drainage system are designed to drain the whole abstracted groundwater and the groundwater discharge amount in the pipe is calculated per linear meter.

The diameter of pipes is calculated for the discharge at the point concerned of the network. The discharge at each point is shown in Fig. 3.1.1.

Calculation of the diameter shall be done in the same manner as the drainage plan for Wadi Musherib.




Fig. 3.1.1 Volume of Abstracted Groundwater at Each Point

Carrying capacities for different diameters of pipe are listed below;

Table 3.1.1 Carrying Capacity of Pipe

Diameter (mm)	Hydraulic gradient	Velocity (m/sec)	Discharge Capacity of Pipe (m <sup>3</sup> /sec)
ø300	0.001	0.682	0.0241
ø450	0.001	0.911	0.0725
ø600	0.001	1.112	0.1573

(4) Typical Section of Lateral Drainage

A typical section of the lateral drainage shall be as shown below.




Fig. 3.1.2 Typical Section of Lateral Drainage

Since ground condition in this area is as a whole better than in the project area at Wadi Musherib, excavation can be done without supporting structures. However, in order to avoid the collapse of the excavated surface, excavation shall be done with the slope of 1:0.2 up to the top level of pipe and then vertically. This enables the earth pressure on the pipe to be reduced.

After pipe laying and prior to backfilling, geotextile sheets shall be applied and three kinds of gravel shall be filled around the perforated pipe as described in the relevant section of Wadi Musherib drainage plan.

#### (5) Pipe Foundation

The buried pipes are subject to moment and shear forces by the action of backfill materials and/or surcharge load on the ground. When the bearing surface is unevenly finished (bumpy) in the construction, pipes may be damaged by these forces. Therefore to resist the external forces by the combination of pipe and foundation, concrete foundation as attached below was considered.




Fig. 3.1.3 Pipe Foundation

#### (6) Materials for Pipe

For pipe materials, as described in the relevant section of Wadi Musherib drainage plan, extra strength vitrified clay (ESVC) pipe shall be employed.

#### (7) Manhole

(Refer DRP-3005)

Manholes shall be located in general about 100 meter apart, as mentioned in the relevant section of Wadi Musherib drainage plan.

## 3.2 Discharge Pump Station and Discharge Pipe Line

### 3.2.1 Design Policy

#### (1) Design conditions

Basic design conditions are set as follows;

a. Design discharge quantity

3,000,000 m<sup>3</sup> per year  
5.7 m<sup>3</sup> per min

b. Design water intake level of pump pit

According to the result of the lateral drainage network for groundwater collection, water intake levels are,

High water to start	QND + 1.500 m
Low water to stop	QND + 0.800 m

c. Ground floor level of pump station

Considering the future land reclamation around the pump station, ground floor level shall be QND + 7,000 m.

d. Operation

There shall be no full time operator but patrol once a day. Therefore pumps shall be activated or shut-off automatically according to the water level. Simple control system shall be considered as much as possible.

e. Electric power

Power source shall be from the public electric network system and received in 6,000V and 50Hz.

f. Settling basin

Conveyed water is groundwater without debris or suspended solids therefore settling basin is not provided.

g. Discharge point

Transferred water shall be discharged at Natural Reserve Area in the Regional Park for New District project which is proceeding by the Amir's Office.

#### h. Discharge pipe line

Route of the pipe line and longitudinal section are shown on the Drawing DRP-4001.

Highest point : Near cement factory in Haul Road, elevation QND + 20,960 m where an intermediate chamber is provided to have free water surface enabling the gravity flow after this point.

Number of curves : 5 points in pressurized part out of 7 points in total

#### (2) Location of the pump station

Location of the pump station was selected at a point adjacent to a new pumping station for sewerage line planned by MPW and has the following advantages.

- Almost lowest point in the project area and suitable for collecting water.
- Adjacent to the existing and newly proposed pump station and convenient for daily patrol.
- Proposed site has been already incorporated in the governmental use area.

#### (3) Method of operation and monitoring

- Pumps are operated by automatic on-off according to the water level in the intake pit.
- Pump operation is controlled automatically for two (2) number units.
- One of three pumps is stand-by unit and automatically turned-on upon trouble in any one of the two running pumps.
- As monitoring equipment, flowmeter, integrating meter and EC meter with recording function are provided.

#### (4) Emergency power supply

Provision of diesel generator for emergency was examined but excluded for the following reasons.

- Reliability of public electric power supply system in Doha is very high.
- Purpose of the pump station is pumping of groundwater and even an occurrence of one or two days black out may not cause serious problem.
- Cost for emergency generator and housing it is considerably high.

#### (5) Route of the discharge pipe line

Two routes, A and B, for the pipe line from Old Rayyan to the West Bay are considered as shown in Fig. 3.2.1. On either route, pipes are installed in the foot path of the road.






Fig. 3.2.1 Route of Discharge Pipe Line

For the Selection of Route A, following matters were considered.

- Length of the pipe line is shortest from pump station to the out fall.
- Curves at crossing of main roads are 7 in number but there is no sudden vertical change, and they are manageable from the hydraulic point of view.
- There is no difficulty in land acquisition
- In Route A, in comparison with Route B residential areas and commercial zones are much less and there is sufficient area secured for intermediate water chamber.

(6) Pipe material

Under such corrosive conditions, pipe materials generally considered are ductile iron pipe, aluminum coated steel pipe, fiber reinforced plastic pipe, poly vinyl chloride pipe, asbestos pipe etc. Anticorrosion measures for ductile iron pipe such as internal cement mortar lining and external PVC tape wrapping and for steel pipe such as aluminum smelt coating are considered.

After examination on safety, durability and workability, ductile iron pipe was selected for the following reasons;

- Widely adopted for underground pipes in Qatar and good results are obtained.
- Regarding PVC pipe and asbestos pipe, strength to withstand high pressure and durability is not sufficient.
- Aluminum coated pipe is preferable regarding anticorrosive effect which is referred to in Fig. 3.2.2, and low cost but in durability and difficulty of site erection is inferior to ductile iron pipe.

It is recommended to adopt push-on-joint as joint for the ductile pipes.




Fig. 3.2.2 Aluminized Steel Pipe

The microstructure of the coated layer of aluminium coated steel pipe is shown above. The microstructure consists of  $\text{Al}_2\text{O}_3$ , aluminium, alloy ( $\text{Fe}_2\text{Al}_5$ ) and Fe substrate layers. The thickness of each layer is few angstrom units of  $\text{Al}_2\text{O}_3$ , 30 to 50 micron for the aluminium and 120 micron in average for the alloy layer, respectively. (According to JIS, the thickness of coated layer for anti-corrosion used should be more than 70 micron). The thickness of the coating may seem very thin but the galvanic corrosion protection mechanisms between each layer provides substantial prevention of corrosion in sea water.

(7) Depth of the pipe

Standard depth of pipe installation shall be 120 cm at places under road, foot path and road shoulder and at crossing parts with other pipes a minimum of 30 cm shall be secured, considering the following;

- Safety against horizontal earth pressure and live loads from above.
- Enabling the provision of control and air valves in the earth covering above pipe.
- In this pipe line there is no branch along the way with no possibility for provision of such in the future. Therefore this pipe line shall be installed as deep as possible in order to avoid interference with other piping and cabling.
- Standard depths of underground facilities are as follows

Potable water	90 mm
Sewerage	120 mm
Electric cable	40 mm
Telephone cable	40 mm

(8) Water hammer protection

There are some countermeasures for water hammering in the pipe line which are curbing intensive velocity change and curbing the pressure rise and fall. For this pipe line the fly wheel method was considered being one of the simple and reliable measures and was confirmed to be satisfactory in the computation.

- Result of the computation

without fly wheel

maximum negative pressure

- 7.436 kg/cm<sup>2</sup>

at the point of 5,229.9 m from the pump station with the elevation of QND + 20.71 m and out of allowance

with fly wheel of 40 kg/m<sup>2</sup>

maximum negative pressure

- 0.530 kg/cm<sup>2</sup>

at the point of 5,047.5 m from the pump station with the elevation of QND + 20.21 m and within allowance

(MAX./MIN. PRESSURE LINE)




Fig. 3.2.3 Result of Water Hammer Computation

### 3.2.2 Outline of the facilities

#### (1) Pump facilities

Flow diagram, electrical oneline diagram and arrangement of the pump system are as shown in Drawings DRP-4002 and 4003.

Total head : 122.0 m  
Actual head : 21.4 m  
Head loss : 98.19 m  
Flow rate : 2.85 m<sup>3</sup>/min  
Number of Pumps : 3 units (one stand by)  
Type of Pump :  
Material : Casing forged cast iron rotor, impellar, rod and sleeve SUS 316  
Motor : 110 KW x 415 V x 50Hz

#### (2) Discharge pipe line (pump station, water chamber, pressure pipe part)

Length : 6,700 m  
Pressure : 12 kg/cm<sup>2</sup>  
Pipe material : Ductile iron pipe  
BS 4772 K-9  
with external protection, 2 x 1.1 mm PVC tape wrapping  
and internal lining cement mortar 5 mm

#### (3) Intermediate water chamber

Water level : QND + 22.20 m  
Ground level : QND + 20.96 m  
Water chamber : Reinforced concrete chamber  
2.5 m x 2.5 m x 3.3 m height  
Capacity : 30 m<sup>3</sup>

#### (4) Discharge pipe line (Water chamber-West Bay, gravity flow part)

Length : 7.7 m  
Pressure : 3 kg/cm<sup>2</sup>  
Pipe material : Ductile iron pipe  
same as above specification

### 3.3 Groundwater Distribution in Mangrove Lagoon at West Bay

Uniform distribution of groundwater is required for the lagoon. For this reason a water distribution channel was considered along the north bank.




Fig. 3.3.1 Water Distribution Channel

### 3.4 Specification of Construction Work and Material

The standard specifications for civil, electrical and mechanical works published by Ministry of Public Works are deemed to be adopted in this project. Special notes to be specified in addition to these, are as follows.

#### (1) Investigation before excavation

Following investigation shall be done before excavation

- subsurface conditions
- neighboring buildings and structures
- necessity of shoring
- groundwater level
- groundwater quality

#### (2) Dewatering

All the excavation shall be executed in dry conditions with necessary dewatering. During all excavation work, attention shall be paid to excavation wall, that is, soil or rock condition, groundwater level and seepage aspect. Especially when encountering the situation where big flow seems to be connected with a particular source, the reason shall be clarified and adequate action shall be taken as required. "Washing out" or "piping" phenomena shall be carefully checked. Rate of dewatering at initial stage shall be moderate and determined considering the surrounding situation.

Disposal of the water shall be by the discharge pump station and sand settling basin shall be provided.

#### (3) Monitoring points

On both sides of the trench excavation, monitoring points for ground deformation by drawdown shall be selected, measured and recorded before and after the work. These points shall be strong enough for long term observation during drainage operation.

#### (4) Concrete work

Concrete used in this project shall be dense concrete. Covering to reinforcing steel in concrete shall be more than 70 mm and external surface in the ground shall be coated with an anti salt-attack paint.

#### (5) Perforated pipe

Pipe to be used in this drainage scheme shall be half perforated Extra Strength Vitrified Clay pipe conforming to BS 65.

Internal diameters to be used are;

- 300 mm
- 450 mm
- 600 mm




Fig. 3.4.1 Detail of Perforated Pipe

(6) Gravel

In backfilling work of lateral drainage trench, the following three kinds of gravel shall be used.

Nominal dia.	50 - 75 mm
Nominal dia.	25 - 40 mm
Nominal dia.	13 - 20 mm

(7) Geotextile

Geotextile material shall be synthetic fiber (polypropylene) and the type suitable for sand piping protection.

(8) Ductile iron pipe

Pipe for discharge pipe line shall be ductile iron pipe conforming to BS4772 designation K-9.

Diameter	Wall thickness	Unit length
250 mm	6.8 mm	5 - 6 m
350 mm	7.7 mm	6 m

External protection

PVC tape, thickness 1.1 mm spiral two (2) layer wrapping

Internal protection

Cement mortar coating 5 mm

Joint

T type push-on-joint




Fig. 3.4.2 Push-on Joint



### 3.5 Cost Estimation

The drainage system for Old Rayyan district is composed of the following;

- a. Lateral drainage facilities
- b. Discharge pump station and discharge pipe
- c. Mangrove lagoon

#### 3.5.1 Unit Rates

Source of unit rates applied in the cost estimation are referred to in the relevant section of Wadi Musherib drainage plan.

#### 3.5.2 Bill of Quantities

##### (1) Lateral Drainage Facilities

Lateral drainage facilities are composed of ESVC perforated pipe (diameter 300, 450 and 600 mm), a short length (25 m) of concrete closed pipe (diameter 600 mm) and manholes (diameter 900 mm).

Bill of quantities for lateral drainage facilities are shown in Table 3.5.1.

Table 3.5.1 Bill of Quantities for Lateral Drainage Facilities

Item	Unit	ø300			ø450			ø600			Sub- Total	MANHOLE			Sub- total	Total
		3-5 m	5-7 m	3-5 m	5-7 m	3-5 m	5-7 m	3-5 m	5-7 m	4-5 m		5-6 m	> 6 m			
Excavation	m <sup>3</sup>	6,626	27,678	7,884	7,218	1,656	1,598	52,660	472	829	844	2,145	54,805 m <sup>3</sup>			
Disposal of surplus soil	"	5,080	10,934	6,220	3,130	1,306	693	27,363	74	109	88	271	27,634 "			
Backfilling	"	1,546	16,744	1,664	4,088	350	905	25,297	398	720	756	1,874	27,171 "			
Gravel filling	"	4,748	10,221	5,475	2,755	1,111	589	24,899	4	5	3	12	24,911 "			
Structural concrete	"	137	296	394	198	83	44	1,152	-	-	-	-	1,152 m <sup>3</sup>			
Lean concrete	"	69	148	111	56	23	12	419	4	5	3	12	431 "			
Shuttering	m <sup>2</sup>	491	1,056	876	441	184	98	3,146	-	-	-	-	3,146 m <sup>2</sup>			
Reinstatement of road	"	2,621	7,765	2,792	1,846	587	409	16,020	192	194	252	738	16,758 "			
ESVC perforated pipe	ø300 m	1,227	2,641	-	-	-	-	3,868	-	-	-	-	3,868 m			
	ø450	-	-	1,095	551	-	-	1,646	-	-	-	-	1,646 "			
	ø600	-	-	-	-	205	122	327	-	-	-	-	327 "			
Concrete pipe	ø600	-	-	-	-	25	-2	25	-	-	-	-	25			
Precast concrete manhole	no	-	-	-	-	-	-	-	20	24	15	59	59 nos			

Note: Figures below pipe diameters and manholes indicate excavation depths.

(2) Discharge Pump Station and Discharge Pipe line

Discharge pump station and discharge pipe line consist of the following;

A. Discharge pump station

- i) Civil work
  - a. Pump pit
  - b. Surrounding works
    - Embankment
    - Access road
    - Fence & gate
    - Site surfacing
  
- ii) Building work
  - Pump house (foundations for building and equipments, structure, and building facilities)
  
- iii) Equipments
  - a. Main pump units
  - b. Valves
  - c. Drainage pump
  - d. Pipe
  - e. Panel
  - f. Instrument
  - g. Overhead crane

B. Discharge pipe line

Discharge pipe line is composed of discharge pipe of ductile cast iron with diameter 250 mm for pressurized line and 350 mm for gravity flow line, intermediate water chamber and temporary outfall.

Bill of quantities for discharge pump station and discharge pipe line are shown in Table 3.5.2.

Table 3.5.2 Bill of Quantities for Discharge Pump Station and Discharge Pipe Line

Item	Unit	Discharge Pump Station				Dis-charge Pipe Line	Total
		Civil Work		Building work	Equip-ments		
		Pump pit	Surround- ing work				
Excavation	m <sup>3</sup>	1,140					1,140
Disposal of surplus soil	"	767					767
Backfilling	"	373					373
Structural concrete	"	208					208
Lean concrete		11					11
Reinforcing bar	ton	20.8					20.8
Shuttering	m <sup>2</sup>	842					842
Embankment	m <sup>3</sup>		1,415				1,415
Access road	m <sup>2</sup>		100				100
Fence	m		96				96
Gate	no.		1				1
Site surfacing	m <sup>3</sup>		62				62
Pump house	m <sup>2</sup>			160			160
Main pump	set				3		3
Valves	"				3		3
Drainage pump	"				1		1
Pipe	"				1		1
Panel	"				1		1
Instrument	"				1		1
Overhead crane	"				1		1
Discharge pipe	∅250	m				6,700	6,700
	∅350	m				7,700	7,700
Earthwork	m <sup>3</sup>					37,000	37,000
Resurfacing	m <sup>2</sup>					1,200	1,200
Intermediate water chamber	set					1	1
Branch	set					1	1
Temporary outfall	"					1	1

(3) Mangrove Lagoon

Construction of mangrove lagoon is composed of the following;

- a. Embankment
- b. Surface protection
- c. Road pavement
- d. Reinforced concrete distribution channel

Embankment to the level of QND + 0 for the mangrove plantation is not included in the cost.

Table 3.5.3 Bill of Quantities for Mangrove Lagoon

Item	Unit	Quantity
Embankment	m <sup>3</sup>	150,000
Surface protection	m <sup>3</sup>	30,000
Road	m <sup>2</sup>	25,000
Water distribution channel	m	1,600

3.5.3 Construction Cost

Construction cost of the drainage system for Old Rayyan is obtained using the unit rates in Table 2.5.1 and bill of quantities in Table 3.5.1, 3.5.2 and 3.5.3.

Summary of the construction costs is shown in Table 3.5.4.

Table 3.5.4 Construction Cost for Old Rayyan

Item	Unit	Rate (QR)	Lateral Drainage Pipe		Discharge Pump Station & Discharge Pipe Line		Mangrove Lagoon	
			Quantity	Amount ( x 10 <sup>3</sup> QR)	Quantity	Amount ( x 10 <sup>3</sup> QR)	Quantity	Amount ( x 10 <sup>3</sup> QR)
Excavation	m <sup>3</sup>	180	54,805	9,865	1,140	205		
Disposal of surplus soil	"	30	27,634	829	767	23		
Backfilling	"	30	27,171	815	373	11		
Gravel filling	"	45	24,911	1,121	-	-		
Structural concrete	"	300	1,152	346	208	62		
Lean concrete	"	260	431	112	11	3		
Reinforcing bar	ton	3,000	-	-	20.8	62		
Shuttering	m <sup>2</sup>	20	3,146	63	842	17		
Perforated pipe	ø300	m	150	3,868	580			
	ø450	"	200	1,646	329			
	ø600	"	500	327	164			
Concrete pipe	ø600	"	500	25	13			
Precast concrete manhole	H=4-5m	no.	6,000	20	120			
	5-6	"	7,000	24	168			
	> 6	"	8,500	15	128			
Embankment	m <sup>3</sup>	25			1,415	35	150,000	3,750
Road	m <sup>2</sup>	75	16,020	1,202	100	8	25,000	1,875
Fence	m	400			96	38		
Gate	no.	5,250			1	5		
Site surfacing	m <sup>3</sup>	45			62	3		
Pump house	m <sup>2</sup>	3,500			160	560		
Main pump	set	317,000			3	951		
Valves	"	18,000			3	54		
Drainage pump	"	5,000			1	5		
Pipe	"	81,000			1	81		
Panel	"	641,000			1	641		
Instrument	"	270,000			1	270		
Overhead crane	"	108,000			1	108		
Discharge pipe	ø250	m	326		6,700	2,184		
	ø350	"	489		7,700	3,765		
Earthwork	m <sup>3</sup>	180			37,000	6,660		
Cutting & resurfacing	m <sup>2</sup>	250			1,200	300		
Intermediate water chamber	set	41,000			1	41		
Branch	"	8,000			1	8		
Temporary outfall	"	12,000			1	12		
Surface protection	m <sup>2</sup>	260					30,000	7,800
Distribution channel	m	300					1,600	480
Subtotal				15,860		16,100		13,900
Total					45,860	( x 10 <sup>3</sup> QR)		

#### 4. Implementation Program

##### 4.1 Implementation program

This project consists of the following three major facilities;

- Lateral drainage facility
- Discharge pump station and discharge pipe line
- Mangrove afforestation

The overall term for implementation is three (3) years considering site investigation, detailed design, tendering, equipment procurement, civil works and mechanical and electrical erection works, after which maintenance of young mangrove trees will be started.

Overall program is as shown in Table 4.1.1. Major points to be noted in the Implementation Program are the following. Because of the difficulty in disposal of highly saline groundwater during construction stage of lateral drainage facility, permanent discharge pump station and discharge pipe line to West Bay shall be constructed at first. Under the present progress of New District "Regional Park" project, it is unavoidable to directly discharge abstracted groundwater at West Bay temporarily until dredging and mangrove lagoon have been completed. It is considered that (2.5) years will be required for dredging, and that within a total of (3) years related road works in the park will be completed. At the same time the appropriate government body executing the mangrove afforestation should begin test plantation and production seedlings, such that within (4) years actual afforestation may commence.

Table 4.1.1 IMPLEMENTATION PROGRAM FOR OLD BAYVYN

No.	Description	1st year			2nd year			3rd year			4th year			5th year		
		1	6	12	1	6	12	1	6	12	1	6	12	1	6	12
1.	Lateral Drainage															
	(1) Topographic Survey & Underground Facility Survey															
	(2) Detail Design & Tender Documents															
	(3) Tender															
	(4) Civil Works															
2.	Pump Station & Discharge Pipe															
	(1) Topographic survey & Underground Facility Survey															
	(2) Detail Design & Tender Documents															
	(3) Tender															
	(4) Land Acquisition															
	(5) Pump Station															
	a) Civil & Building Works															
	b) Equipments															
	(6) Discharge Pipe															
3.	Mangrove Afforestation															
	(1) Culture Test of Seedings															
	(2) Culture of Seedings															
	(3) Mangrove Lagoon Construction															
	(4) Afforestation & Maintenance															



#### 4.2 Expenditure in Each Fiscal Year

Total cost of the Project is summarized in the table below.

Lateral drainage	17.5	MNQRS
Discharge pump station and pipeline	18.9	MNQRS
Civil work for Mangrove afforestation	15.3	MNQRS
<b>Total</b>	<b>51.7</b>	<b>MNQRS</b>

Above figures consist of;

- Topographic survey and investigation of underground facilities
- Detail design, Tender, and Construction management
- Land acquisition for pump station
- Civil construction and associated temporary facilities
- Equipment procurement and electrical and mechanical erection works

On the other hand the following items are not considered;

- Governmental administrative cost
- Compensation to residents for inconvenience during construction (if any)
- Land acquisition for mangrove afforestation
- Cost for mangrove afforestation itself

Cost breakdown by each fiscal year are tabled in Table 4.2.1 below.

Table 4.2.1 Expenditure for Each Fiscal Year

(Unit: x10<sup>3</sup>QR)

Item	Year				Total
	1st	2nd	3rd	4th	
1. Engineering Services	1,600	3,000	-	-	4,600
2. Land Acquisition	1,200	-	-	-	1,200
3. Civil & Building Works	-	12,000	29,800	2,000	43,800
4. Equipments	-	2,100	-	-	2,100
<b>Total</b>	<b>2,800</b>	<b>17,100</b>	<b>29,800</b>	<b>2,000</b>	<b>51,700</b>

Notes:

- 1) Cost of engineering services were derived from 10 percent of construction cost.
- 2) Land acquisition for Discharge Pump Station was considered only and unit rate per square meter is 1,000 QR.
- 3) Breakdowns of each item in the table are shown on Table 4.2.2 and allocation to each year is shown on Table 4.2.3.

Table 4.2.2 Cost Breakdown

(Unit: x 10<sup>3</sup> QR)

Item	Construction Cost	Engineering Fee	Land Acquisition
1. Lateral Drainage		1,000	—
(1) Pipe Work	15,000		
(2) Manhole	900		
Sub Total	15,900	1,600	0
2. Discharge Pump Station & Discharge Pipe line		1,600	
(1) Discharge Pump Station			1,200
- Civil & Building Work	1,000		
- Equipments	2,100		
(2) Discharge Pipe			
- Pipe material	4,200		
- Civil Work & Pipe Installation	8,800		
Sub Total	16,100	1,600	1,200
3. Mangrove Lagoon Construction	13,900	1,400	—
Total	45,900	4,600	0
Grand Total		51,700	



5. Drawings




## DRAWING LIST

(1/2)

DWG. NO.	TITLE
DRP-1001	DRAINAGE IMPROVEMENT PLAN
DRP-3001	OLD RAYYAN LATERAL DRAINAGE-GENERAL PLAN
DRP-3002	OLD RAYYAN LATERAL DRAINAGE TRANSVERSAL AND LONGITUDINAL SECTIONS (1/3)
DRP-3003	OLD RAYYAN LATERAL DRAINAGE TRANSVERSAL AND LONGITUDINAL SECTIONS (2/3)
DRP-3004	OLD RAYYAN LATERAL DRAINAGE TRANSVERSAL AND LONGITUDINAL SECTIONS (3/3)
DRP-3005	OLD RAYYAN MANHOLE AND TYPICAL SECTION OF LATERAL DRAIN
DRP-3020	OLD RAYYAN LATERAL DRAINAGE - DETAILED PLAN (1/2)
DRP-3021	OLD RAYYAN LATERAL DRAINAGE - DETAILED PLAN (2/2)
DRP-4001	DISCHARGE PIPE LINE GENERAL PLAN AND LONGITUDINAL SECTION
DRP-4002	DISCHARGE PUMP STATION (1/2)
DRP-4003	DISCHARGE PUMP STATION (2/2)
DRP-4004	DISCHARGE PIPE LINE DETAILS (1/2)
DRP-4005	DISCHARGE PIPE LINE DETAILS (2/2)
DRP-4006	MANGROVE AFFORESTATION PLAN
DRP-4020	DISCHARGE PIPE LINE DETAILED PLAN (1/9)
DRP-4021	DISCHARGE PIPE LINE DETAILED PLAN (2/9)
DRP-4022	DISCHARGE PIPE LINE DETAILED PLAN (3/9)


---

DWG. NO.	TITLE
DRP-4023	DISCHARGE PIPE LINE DETAILED PLAN (4/9)
DRP-4024	DISCHARGE PIPE LINE DETAILED PLAN (5/9)
DRP-4025	DISCHARGE PIPE LINE DETAILED PLAN (6/9)
DRP-4026	DISCHARGE PIPE LINE DETAILED PLAN (7/9)
DRP-4027	DISCHARGE PIPE LINE DETAILED PLAN (8/9)
DRP-4028	DISCHARGE PIPE LINE DETAILED PLAN (9/9)
DRP-4029	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (1/10)
DRP-4030	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (2/10)
DRP-4031	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (3/10)
DRP-4032	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (4/10)
DRP-4033	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (5/10)
DRP-4034	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (6/10)
DRP-4035	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (7/10)
DRP-4036	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (8/10)
DRP-4037	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (9/10)
DRP-4038	DISCHARGE PIPE LINE TRANSVERSAL AND LONGITUDINAL SECTIONS (10/10)



STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1 : 20000
DRAINAGE IMPROVEMENT PLAN		DRP I 1001
JAPAN INTERNATIONAL COOPERATION AGENCY DRAWN _____ CHECKED _____ APPROVED _____ <i>M. Oseki</i>		





**LEGEND**  
 — PERFORATED PIPE  
 ○ MANHOLE  
 - - - PRESSURIZED PIPE





STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:5000
OLD RAYYAN LATERAL DRAINAGE GENERAL PLAN		DRP 1 3001
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>

METRES ABOVE QATAR NATIONAL DATUM

OFFSET

GROUND LEVEL

CHAINAGE







METRES ABOVE QATAR NATIONAL DATUM


OFFSET

GROUND LEVEL

CHAINAGE



TRANSVERSAL SECTION (SCALE VER. 1:200, HOR. 1:1000)




METRES ABOVE QATAR NATIONAL DATUM

GROUND LEVEL

INVERT LEVEL

CHAINAGE





LONGITUDINAL SECTION A - B - J - K (SCALE VER. 1:200, HOR. 1:2000)

METRES ABOVE QATAR NATIONAL DATUM

GROUND LEVEL










INVERT LEVEL

CHAINAGE




LONGITUDINAL SECTION C - D (SCALE VER. 1:200, HOR. 1:2000)



STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:200
		1:1000
		1:2000
OLD RAYYAN LATERAL DRAINAGE - TRANSVERSAL AND LONGITUDINAL SECTIONS (1/3)		DRP 1 3002
JICA JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED



TRANSVERSAL SECTION (SCALE VER. 1:200, HOR. 1:1000)



LONGITUDINAL SECTION D-E-H-J (SCALE VER. 1:200, HOR. 1:2000)



LONGITUDINAL SECTION F-I (SCALE VER. 1:200, HOR. 1:2000)





STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:200 1:1000 1:2000
OLD RAYYAN LATERAL DRAINAGE - TRANSVERSAL AND LONGITUDINAL SECTIONS (2/3)		DRP I 3003
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED

METRES ABOVE QATAR NATIONAL DATUM

OFFSET

GROUND LEVEL

CHAINAGE








METRES ABOVE QATAR NATIONAL DATUM

OFFSET

GROUND LEVEL

CHAINAGE




TRANSVERSAL SECTION (SCALE VER. 1:200, HOR. 1:1000)

METRES ABOVE QATAR NATIONAL DATUM


GROUND LEVEL

INVERT LEVEL

CHAINAGE



LONGITUDINAL SECTION D → C → H (SCALE VER. 1:200, HOR. 1:2000)




LONGITUDINAL SECTION A → G (SCALE VER. 1:200, HOR. 1:2000)

METRES ABOVE QATAR NATIONAL DATUM

GROUND LEVEL

INVERT LEVEL

CHAINAGE




LONGITUDINAL SECTION F → G → H (SCALE VER. 1:200, HOR. 1:2000)


STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:200 1:1000 1:2000
OLD RAYYAN LATERAL DRAINAGE - TRANSVERSAL AND LONGITUDINAL SECTIONS (3/3)		DRP 1 3004
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED

## MANHOLE LIST

MANHOLE NO.	LOCATION	DEPTH (D) (m)	TYPE	MANHOLE HEIGHT (H) (m)	MANHOLE NO.	LOCATION	DEPTH (D) (m)	TYPE	MANHOLE HEIGHT (H) (m)	MANHOLE NO.	LOCATION	DEPTH (D) (m)	TYPE	MANHOLE HEIGHT (H) (m)
1	AK+ 000 AG+ 000	4.800	A	5.100	26	DH+ 000 DJ+ 000	6.800	B	7.100	51	DH+ 650	3.950	A	4.250
2	AK+ 103	4.403	A	4.710	27	DJ+ 103	4.503	A	4.810	52	AG+ 100	5.900	B	6.200
3	AK+ 203	4.403	A	4.710	28	DJ+ 203	5.603	B	5.910	53	AG+ 200	4.500	A	4.800
4	AK+ 303	5.203	B	5.510	29	DJ+ 303	5.303	B	5.610	54	AG+ 306	4.406	A	4.710
5	AK+ 403	5.403	B	5.710	30	DJ+ 411	5.011	B	5.320	55	DJ+1241 DH+ 742 FH+ 844	5.677	B	5.980
6	AK+ 503	4.503	A	4.810	31	DJ+ 513	4.813	A	5.120	56	DJ+1364	4.500	A	4.800
7	AK+ 603	4.303	A	4.610	32	DJ+ 613	4.813	A	5.120	57	DJ+1464	4.800	A	5.100
8	AK+ 703	4.203	A	4.510	33	DJ+ 688 FE+ 395	4.998	A	5.300	58	AK+1210	5.110	B	5.410
9	AK+ 801	5.301	B	5.610	34	DJ+ 796	4.496	A	4.800	59	AK+1338 DJ+1571	4.975	A	5.280
10	AX+ 856	4.656	A	4.960	35	DJ+ 894	4.594	A	4.900					
11	AK+ 954	5.754	B	6.060	36	DJ+ 994	4.594	A	4.900					
12	AX+1055	5.345	B	5.650	37	DJ+1094	5.094	B	5.400					
13	AK+1125 CB+ 606	5.325	B	5.630	38	DJ+1194	4.694	A	5.000					
14	CB+ 534	5.534	B	5.840	39	FE+ 000 FH+ 000	7.500	B	7.800					
15	CB+ 471	6.471	B	6.780	40	FE+ 095	5.795	B	6.100					
16	CB+ 366	4.266	A	4.570	41	FE+ 195	5.295	B	5.600					
17	CB+ 266	3.766	A	4.070	42	FE+ 295	5.495	B	5.800					
18	CB+ 169	3.869	A	4.170	43	FH+ 100	5.600	B	5.900					
19	CB+ 073	5.473	B	5.780	44	FH+ 200	5.900	B	6.200					
20	CB+ 000 DH+ 489	5.689	B	5.990	45	FH+ 303	7.803	B	8.110					
21	DH+ 464	5.864	B	6.170	46	FH+ 424	7.624	B	7.930					
22	DH+ 419	5.919	B	6.220	47	FH+ 548 AG+ 418	5.748	B	6.080					
23	DH+ 324	6.324	B	6.630	48	FH+ 650	4.350	A	4.650					
24	DH+ 234	6.934	B	7.240	49	FH+ 744	4.344	A	4.650					
25	DH+ 118	7.218	B	7.520	50	DH+ 569	4.169	A	4.470					




$D < 5.0 M$




$D \geq 5.0 M$

TYPICAL SECTION OF MANHOLE (S=1:50)



PERFORATED PIPE  $\phi 600$  &  $\phi 450$




PERFORATED PIPE  $\phi 300$

TYPICAL SECTION OF LATERAL DRAIN (S=1:50)

### NOTES

1. FOR GENERAL PLAN OF LATERAL DRAINAGE, SEE DWG. NO. DRP-3001.
2. FOR TRANSVERSAL AND LONGITUDINAL SECTIONS, ON WHICH THE LOCATIONS OF MANHOLES ARE INDICATED, SEE DWG. NOS. DRP-3002 THRU 3004.
3. GEOTEXTILE SHALL BE PROVIDED ON THE EXCAVATED SURFACE FROM THE TRENCH BOTTOM TO THE GROUND WATER LEVEL AT THE SITE.
4. GRAVEL (13~20mm) SHALL BE PROVIDED ABOVE THE GROUND WATER LEVEL AND THE THICKNESS SHALL NOT BE LESS THAN 10 METER.

STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:50
OLD RAYYAN MANHOLE AND TYPICAL SECTION OF LATERAL DRAIN		DRP 1 3005
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>




**LEGEND**

- PERFORATED PIPE #600
- PERFORATED PIPE #450
- PERFORATED PIPE #300
- MANHOLE
- AG+200 --- CHAINAGE (AS INTERMEDIATE) (MH-53) --- MANHOLE NUMBER
- 2000 --- INVERT LEVEL (METERS ABOVE QATAR NATIONAL DATUM)
- 2000 --- INVERT LEVEL (METERS ABOVE QATAR NATIONAL DATUM)
- CB+000 --- CHAINAGE (AS ORIGIN)
- CH+489 --- CHAINAGE (AS INTERMEDIATE) (MH-20) --- MANHOLE NUMBER
- 100 --- DISTANCE BETWEEN MANHOLES

STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:2000
OLD RAYYAN LATERAL DRAINAGE DETAILED PLAN (1/2)		DRP 1 3020
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED


MATCH LINE TO DWG. NO. DRP-3003




- PERFORATED PIPE 1600
- PERFORATED PIPE 1450
- PERFORATED PIPE 1300
- MANHOLE
- CHAINAGE (AS INTERMEDIATE) - MANHOLE NUMBER
- INVERT LEVEL (METERS ABOVE QATAR NATIONAL DATUM)
- CHAINAGE (AS ORIGIN) - CHAINAGE (AS INTERMEDIATE) - MANHOLE NUMBER
- DISTANCE BETWEEN MANHOLES

STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:2000
OLD RAYYAN LATERAL DRAINAGE DETAILED PLAN (2/2)		DRP I 3021
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED

# RAYYAN DISCHARGE PIPE LINE




PLAN (SCALE 1:20,000)




LONGITUDINAL SECTION (SCALE VER. 1:200, HOR. 1:20,000)

<b>STATE OF QATAR</b>		<b>SCALE</b>
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:200 1:20,000
DISCHARGE PIPE LINE GENERAL PLAN AND LONGITUDINAL SECTION		<b>DRP I 4001</b>
<small>JAPAN INTERNATIONAL COOPERATION AGENCY</small>		
<small>DRAWN</small>	<small>CHECKED</small>	<small>APPROVED</small>
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>







PUMP ARRANGEMENT S=1:100




SECTION A - A S=1:100



LAYOUT OF PUMP STATION S=1:300



FLOW DIAGRAM




ELECTRICAL ONE LINE DIAGRAM

STATE OF QATAR	SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY	1:100 1:300
DISCHARGE PUMP STATION (1/2)	DRP 1 4002
 JAPAN INTERNATIONAL COOPERATION AGENCY	
DRAWN	CHECKED
 APPROVED	




INTERMEDIATE WATER CHAMBER 1:50

SECTION




PLAN




TEMPORARY OUTFALL 1:50

SECTION




PLAN




TYPICAL SECTION 1:20

SHOULDER OF ROAD




UNDER ROAD



UNIT: MM


D	W
250	850
350	950

LEGEND




STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:20 1:50
DISCHARGE PIPE LINE DETAILS (1/2)		DRP 1 4004
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED


BRANCH 1:20




AIR VALVE BOX 1:20




DRAINAGE 1:20




SLUICE VALVE BOX 1:20





LEGEND




STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:20
DISCHARGE PIPE LINE DETAILS (2/2)		DRP 1 4005
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED



STATE OF QATAR	SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY	1: 100 1: 5 000
MANGROVE AFFORESTATION PLAN	DRP I 4 006
 JAPAN INTERNATIONAL COOPERATION AGENCY	
DRAWN	CHECKED
APPROVED 	



STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:2000
DISCHARGE PIPE LINE		DRP
DETAILED PLAN (1/9)		4020
JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED



STATE OF QATAR		SCALE
THE STUDY ON DRAINAGE IMPROVEMENT PLAN, DOHA CITY		1:2000
DISCHARGE PIPE LINE DETAILED PLAN (2/9)		DRP 4021
 JAPAN INTERNATIONAL COOPERATION AGENCY		
DRAWN	CHECKED	APPROVED
		<i>M. Arora</i>