

Fig. AP.4-6 Work Completion, Normal Condition




Fig. AP.4-7 Work Completion, Seismic Condition

4. 3 Stress Analysis of Artvin Dam

4.3 Stress Analysis of Artvin Dam

4.3.1 General

Stress analysis has been performed for the Artvin arch dam by Trial load method. In the analysis, normal and earthquake conditions are considered.

4.3.2 Basic Concept and Equations

In this method, basic assumption is that an arch dam is composed of arch elements and cantilever elements (as shown in the Fig. AP.4-8) and that acting loads are to be born by both arch and cantilever elements where deflections taken place at a grid point formed by the elements are equal due to the continuity of the body.

In the analysis, "radial adjustment computation" where only the radial deflection is to be adjusted equal was performed.

Following is a basic equations to be realized in the computation.

 $cr(\Delta f)m,n = ar(\Delta f)m,n$ crPm,n + arPm,n = Pm,n

,where

 Δ : Delfection

P: Load acting to the grid point denoted by (m,n)

Sufices are; cr: Cantilever

ar: Arch

m,n: Grid point of cantilever m and arch n

Fig. AP.4-9 is to be referred.

4.3.3 Calculation Condition

1) Design condition

	Dam Crest Elevation	505.00 m
n da serie Este da serie Este da serie	High Water Level	500.00 m
	Sediment Level	413.00 m
• * •	Foundation Elevation	345.00 m
	Water Level in Earthquake	500.00 m
	Downstream Water Level	395.00 m

2) Physical properties

1.1114

Symbol	Physical property	Unit-	Value
Ec	Elastic modulus of concrete	t/m ²	2,000x10 ³
ER	Elastic modulus (Left bank) of bed rock (Right bank)	t/m^2 t/m^2	450x10 250x10
Gc	Shear elastic modulus of concrete	t/m ²	830x10 ³
c	Poisson's ratio of concrete	-	0.2
R	Poisson's ratio of bed rock	_	0.2
ĸ _R	Ratio of deflection in radial direction due to actual shear distribution against due to assumed uniform shear distribution		1.25
Ks	Ratio of delfeciton in tangential direction due to actual shear distribution against due to assumed uniform shear distribution		1.00
WC	Unit weight of concrete	t/m ³	2.35
Ww	Unit weight of water	t/m ³	1.0
Ws	Unit weight of sediment	t/m ³	1.1
С	Thermal expansion coeff. of concrete	1/°C	1×10 ⁻⁵

S. 199

3) Load condition

Considered loads are dead weight, hydrostatic pressure, sediment pressure, uplift, temperature loads and seismic forces.

(1) In calculating hydrostatic pressure and uplift, water level of upstream was taken to be 505.00 equal to the dam crest so as to keep the design in safety side, which should take place in case of land sliding at Havuzlu or other upstream location.

Sesiment pressure was calculated by;

Ps = CsWshs

where Cs = 0.4

(3) Temperature loads were computed in accordance with the following temperature variation.

El. (m)	Temp. lowering (°C)
505.00	-6.0
488.50	-5.0
455.00	-4.0
425.00	-3.0
395.00	-2.5
365.00	-2.0
345.00	-2.0
• • • • • • • • • • • • • • • • • • •	

(4) Uplift was assumed to be simple gradient between upstream and downstream pressure which corresponds to each water level.

(5) Hydrodynamic pressure was calculatead with the Westerguard's equation.

$$Pd = \frac{7}{8} WwK.H.h$$

Seismic coefficient (K) was taken to be 0.3.

4.3.4 Result

The calculation has been performed by a computer. The result is summarized in the following table and figures.

Case	EL.(m)	Maximum Stress	s (kg/cm ²)
		Vertical (cantilever)	Horizontal (Arch)
Normal	488,50	10.2	46.8
Condition	455.00	24.1	58.3 (cr)
	425.00	35.0.1 magnitud	65.6 (cr)
	395.00	40.7	62.3 (cr)
	365.00	43.9	53.0 (cr)
	345.00	44.0	42.5 (cr)
	<u> </u>		
Seismic	488.50	14.3	86.7
Condition	455.00	1. Marshar 31:4	93.2 (cr)
	425.00	54.0	86.8 (cr)
	395.00	60.4	87.3 (cr)
Į	365.00	60.6	71.2 (cr)
1	345.00	57.8	55.1 (cr)
· · · · · · · · · · · · · · · · · · ·			


From the result, all the stresses are within an usual allowable stress, i.e.

Normal condition $\vec{0}$ aN = 70 kg/cm³ Seismic condition $\vec{0}$ aS = 100 kg/cm³

and the state of the

A 4-59

In further stage, however, more detail analyses such as FEM or model tests should be performed taking the foundamental properties of material to be actually used.



and the second second







Fig. AP.4–9 Numbering of Grids





A 4--61




Fig. AP.4-11 Distribution of Horizontal Stresses (Normal Condition)

A 4--63




Fig. AP.4-12 Distribution of Vertical Stresses (Normal Condition)

A 4--65




Fig. AP.4-13 Load Share by Arch or Cantilever Element (Seismic Condition)

in the top arch.

A 4–67






Fig. AP.4-14 Distribution of Horizontal Stresses (Seismic Condition)






River Profile and Cross Sections

A 4-73


4

4




A 4--74

14




495				÷					<u>.</u>						· · _										
NOKTA NO. POINT NO.	· .	2		3		4		5	4	6	ə	P.Ì	01	7		K,	i ș	(0 11	12	13 1-	4 15	i e i	17 18	5 19 20
ARA MESAFE DISTANCE BETWEEN POINT	15,81		8		17.24		9.90		14.64			8	13.02		8.5		6.74	9.26	8	88		88	88		404
BAŞLANGIÇTAN MESAFE &	}	13.81		34.27		51.5		9 9		8	84.90	26 56 26	1	IOB. 95		123.91	30.65		143.91	147.91	10.15	16.601	5 B	167.91	92 11 12
KOT ELEVATION		551.48 ·		542.16		533.62		96.920		e N	316 75	8		\$08 80°		910.26	508.41		501.40	20113	22	201.02	≦ <u>×</u> :	2002	0.700
	1	1							Ч÷.		<i>.</i>							ō	3					S.	3





A 4--76

/0




Á 4-77







480			1	and the second		
NOKTA NO. POINT_NO.	. 2	3 P.1	105 K.5	4 56 78	9 10 11 12 13 1	4 15 16
ARA MESAFE DISTANCE BETWEEN POINT	11.14	6.80 7.14	10.97 11.86	8.57 4.27 5.00 5.00	8 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9 9	8 8 8 75
BASLANGICTAN MESAFE	1.14	17.94	35.05	47. 91 56.48 60.75 65.75	5 6 8 8 8 8 8 5 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6	105.25
KOT ELEVATION	516.94	509.58	497.20	490.64 489.98 490.08 489.55	489.01 489.01 489.01 489.01	
			• • • • •	s co	·····	5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5

A 4–79



A 4---80









1/100

t


L





٠ĺ	ARA MESAFE DISTANCE BETWEEN POINT	4		0 	8	8			10.64	8	88	3 8	8	8	88		23.36			35.90		2	2		1 8	14 50	
	BASLANGICTAN MESAFE DISTANCE TO THE START	8	8		2	24.52	33.60	43.60		57.24		67.24	72.24	r,	82 24 85,24 87,24			110.60		- · .	146.50			167.60	80.60		
L	KOT ELEVATION	516.70	510.73		\$	19.155	18.684	469.60		479.50	479.26	4 79.06	679.62	129.62	480.064			481.66			496.35			201.06	109.92	}	
ţ		T			•				ŝ	2	-+		-	·	ŝ.	2		·	•					••••	4		-



Note: Water elevation was taken on 30, 9, 1985









A 4–87

.




· · · ·			ан А.								
	1	· · · · · · · · · · · · · · · · ·	505 7						<u>,,,,,,,,,,,,,,</u> ,		7
		. ·	500				., <u>.</u>				/
								-	· ·		
. *			495 -						/	,	
	· .		490 -				- ···				
•								. /			· .
· ·			485				. : : ···			***	· ····· .
			480								
		$\sim 10^{10}$					/	/-			
		\	475								
	KESIT 1985 YII ÇORUH NEHİR E		470								
	CROSS S YEAR IS CORUH I	ECTION 1 15	465				· · · · · · · · · · · · · · · · · · ·	<u> </u>		· ·_ ·	
	1/100	- 	460			/ .			· •	<u></u> .	·
				ÇORUH ÇORUH	NEHRİ RIVER						
	ior	kotu 30,9,1985 ihinde verilmistir ter elevation was en on 30,9,1985	455		<u> </u>					· · ·	<u>.</u>
	·	NOKTA NO.	450	23 4 5	6 7 89				.		
	· · ·	POINT NO. ARA MESAFE DISTANCE BETW		++-++	886	8		3			
		BAŞLANGIÇTAN DISTANCE TO TH		8 9 - 9 9 4 4 9 4 8 9 7 9 7 9 7 9 7 9 7 9 7 9 7 9 7 9 7 9 7	21.42 26.42 23.42 23.42 23.42 23.42 23.42 23.42 23.42		6	02.06			
		KOT ELEVATION	459.4	455.48 455.48	456 16 456 16 456 16		469.28	487.46			
n de la dela Anti-	e de la composición de la composición de la composición de la composición de la composición de la composición d La composición de la c		1	28	Ster		• · · · · · · · · · · · · · · · · · · ·				


.





A-4-90



Λ 4--91







A-4-94

390						an Se	т. 1. – 25			÷÷	/	: : :		÷.,		in Se g		•		۰.
NOKTA NO. POINT NO.	1 1	2		Ρ	122	K 22		3	5 6	78	9 ji		14					13		-is
ARA MESAFE DISTANCE BETWEEN POINT	8 5		3520		8.8	ſ	20.56	Ę	844	88 88	4.46	9.51	· • .	• • • • •	53.20		:		12 12	
BASLANGICTAN MESAFE DISTANCE TO THE START	3	8			\$ \$	60.25			85.0 89.6	93.BL	01.81		115,80					169.00	:	184.75
KOT ELEVATION	3,1	4.38.66 9.96			402,66-	402.20			391,53 331,28	391, 23	391,40		397.51					429.3(446.01
			14 E		· · ·			ក្តីភ្ល	}-} -	+-+-	202	2	- 4					+ .`		

CORUH NEHRI

-

17100 1

KESIT 22 1985 Yili Çoruh Nehri Nehir Enkesiti CROSS SECTION : 22 YEAR 1985 CORUH RIVER RIVER CROSS SECTION

425 420

415

410

405

400

395


-


ľ

450

445

440-435 430 ÷






KESIT : 24 1985 YILI CORUH NEHRİ NEHİR ENKESITİ
CROSS SECTION : 24 YEAR 1985 CORUM RIVER RIVER CROSS SECTION




- Not Su kotu 30.9.1985 tarihinde verilmistir Note: Water elevation was taken on 30.9.1985

	380	}	. '			• •	·	-						- j	1 e					анан 1911 - Мариянан 1911 - Мариянан			
•	NOKTA NO. POINT NO.	1	- 2		5	P	124	¥24				4	5 6	7.1	8 9	10	12		16	1	15		14
	ARA MESAFE DISTANCE BETWEEN POINT	13.60	·	17,10	17.30	÷ .	8		•	32.03		802	4 0	4 3 8 8 8	4	8	4	20.73	Γ	18.30		18,60]:
	BAŞLANGIÇTAN MESAFE DISTANCE TO THE START	000	3.60				- 00'B4	62.00			1.1			90	о, с	0	. ത		141.70	·	160.00		178.60
	KOT ELEVATION	429.75	417,40	405.04-	5000	i	- 293.71	393.63-				0.1	0.49	5	84 9 2 7 2	10	86.2	n ginnen Stan	398.49	_•_•_•	410.90		424.62
								- -				22	-		++		10,0	2	-4				


A 4–97



A 4--98





A 4--99


















A--5 TRANSMISSION LINE PLAN

		Page
5.1	Transmission Line Plan from Hopa to Ankara	A5-2
5.2	Condition of Study	A5-2
5.3	Result of Study	A5-4
5.4	Construction Schedule and Cost Estimation	A55

200

Page

List of Table

Table AP.5-1	Estimated Construction Cost
Table AP.5-2	Fund Requirement in Each Year
Table AP.5-3	Estimated Construction Cost (for Yusufeli Project)
Table AP.5-4	Fund Requirement in Each Year (for Yusufeli Project)
Table AP.5-5	Estimated Construction Cost (for Artvin Project)
Table AP.5-6	Fund Requirement in Each Year (for Artvin Project)

A-5 TRANSMISSION LINE PLAN

Almost all power systems in Turkey are mutually interconnected to form a nation-wide grid. The feature of these interconnected systems is that the load centers are located in Ankara and in the western areas such as Istanbul, Izumir, etc., while a large part of the power supply capacity is located in the eastern region. The power consuming areas and the power generating areas are interconnected by long 380 kV transmission lines, which form the key transmission system connecting the east and west of Turkey.

As the distance between the power consuming areas and the power generating areas amount to about 1,000 km, it is expected that the power systems will face various technical problems as the electric demand increases in the future.

In planning power transmission for this Project which is situated in the northeastern region of Turkey, it would be required to conduct power system analysis studies, including the possibility of introducing a higher system voltage.

However, the power system analysis study related to this Project was excluded from the scope of the present study after consultation with the Government of Turkey held in February, 1986, because it was difficult at this stage to collect the data and information required for power system analysis. For this reason, a detailed power system analysis was not conducted relating to the present study.

However, a very general power transmission study was conducted based on the concept that the power output of this Project is transmitted to Ankara from Hopa Substation via Samsun thus assumed.

This transmission study was conducted with the objective of economic evaluations of this Project.

5.1 Transmission Line Plan from Hopa to Ankara

In Chapter 9-3 of this Main Report, it is assumed that the output of the Coruh Hydroelectric Power Development Project will be transmitted from Hopa to the load center of Ankara by means of the transmission facility which would be completed by the time of completion of the said project by TEK.

However, studies are performed here for a transmission line which is assumed to be constructed from Hopa to Ankara mainly form the point of view of power system stability, because the power system expansion program of TEK is not precisely known at this stage.

5.2 Condition of Study

(1) Transmission Line Voltage

The transmission line characteristics have been studied here for two cases: (1) All of the related power system is interconnected by 750 kV transmission line. (2) The section from Ankara to Samsun is interconnected by a 750 kV line, and the section from Samsun to Hopa is interconnected by a 380 kV line.

The power system models used in this study are illustrated below.

[CASE 1]

----- AC 750 kV ------ACSR 954 MCM x 4 b., 1 cct.

<	AC 750 kV		AC 380 kV>	•
ACSR	954 MCM x	4 b. ACSR	954 MCM x 2 b.	
「大臣」です。	l'ect.		1 cct.	
tan di sa k	n shata sh	Sector of the sector se		

Transmission Line Impedance:

-	Case 1.	Ankara Hopa; 2.38 + j37	.8/750 kV
	Case 2.	Ankara Samsun; 1.24 + j19 Interconnection transformer;	and the second second second second second second second second second second second second second second second
		Samsun Hopa;	8.89 + j70.3/380 kV
e 19	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	Total;	10.13 + 197.5

The transmission line impedance of the following values were assumed.

750 kV: 0.003076 + j0.049 (%/km/1 cct., 1,000 MVA base) 380 kV: 0.02403 + j0.19 (%/km/1 cct., 1,000 MVA base)

The impedance of the interconnection transformer was assumed as 15% for its capacity, and the capacity was selected at 2,000 MVA.

(2) Generator Capacities

Coruh Project side;	1,000 MW hydroelectric power	
Ankara side;	infinite bus	•
		۰.,

(3) Load Conditions

It was assumed that the whole power is to be transmitted to Ankara, and the intermediate loads were neglected.

5.3 Result of Study

(1) Selection of Transmission Voltage

In the two study cases selected in Section 2. (1), the phase angle differences between the power plant bus and Ankara were as described below.

[Case 1] $P = 1.0 = (1 \times 1/0.378) \sin \theta$ $\theta = 22.2$ degrees

[Case 2] $P = 1.0 = (1 \times 1/0.975) \sin \theta$ $\theta = 90$ degrees

Thus the phase angle difference in Case 2 indicates that the condition is at the transmission capacity limit, and it is necessary to interconnect the whole distance with a 750 kV transmission line.

(2) Transmission Capacity Limit

The characteristics of the transmission line was studied for the case that power other than from Yusufeli and Artvin were superimposed on the transmission line, to find out the status when the line power flow is increased over the output of the two Projects.

As the planned transmission line has only one circuit, the assumed fault condition has to be an one-line-to-ground fault. Although more detailed data are required for rigorous studies, the results of roughly study based only on the available data indicated that the transmission capacity limit is approximately 1,500 MW.

5.4 Construction Schedule and Cost Estimation

and the second second second second second second second second second second second second second second second

(1) Construction Schedule

A period of 42 months was assumed to be required for construction of a transmission line (750 kV, single circuit) from Hopa to Ankara which is 780 km long.

(2) Cost Estimation

* The construction cost of the transmission line was calculated based on the unit construction cost, which was proposed by EIE through TEK.

* Concerning electrical equipments, the switch gear sets and the outgoing lines for the Hopa Substation outgoing circuit and the Ankara Substation incoming circuits were counted in the construction cost.

- * The state tax is calculated as 10% of the material and equipment costs.
- * The project controlling cost is calculated as 15% of each transmission and electrical equipment construction cost including the installation cost.
- * The construction costs to be paid by the domestic currency and the foreign currency are presented in Table AP.5-1 and Table AP.5-2 respectively.

The transmission capacity limit of this transmission line is assumed as 1,500 MW as discussed in the preceding section. The cost of the transmission line was allocated to Yusufeli Project (540 MW), Artvin Project (320 MW) and other projects which use this transmission capacity in proportion to the amount of power.

The construction costs to be paid by the domestic currency and the foreign currency are presented in Table AP.5-3 through Table AP.5-6.

Table AP.5-1Estimated Construction Cost
(for 1,500 MW Capacity)

(10)6	Т	.L)

		<u></u>	·
Description	D.C.	F.C.	Total
Financial Cost			
(I) with Tax			
Transmission Line	18,876	41,184	60,060
Electrical Equipment	154	1,120	1,274
Project Controlling	6,439	2,761	9,200
Sub Total	25,469	45,065	70,534
Interest during Construction Period	6,380	13,835	20,215
Grand Total	31,849	58,900	90,749
		en en en en en en en en en en en en en e	
(II) without Tax			
Transmission Line	14,757	41,184	55,941
Electrical Equipment	140	1,120	1,260
Project Controlling	6,439	2,761	9,200
		an an an an an an an an an an an an an a	
Grand Total	21,336	45,065	66,401
		in an an an an an an an an an an an an an	

A 5-6

Table AP.5-2 Fund Requirement in Each Year (for 1,500 MW Capacity)

(106 T.L.) 1,120 45,065 1,120 13, 835 58,900 41,184 45,065 2,761 41,184 2,761 ပ် မျ Total 6,380 18,876 6,439 21,336 6,439 31,849 140 25,469 14,757 ບ ດ 4,281 4,281 I. ł 1 ប៉ ផ្អ 5th Year (9th) 2,420 2.,420 ł 1 1 1 1 1 I с. О 4,013 5,648 9,661 4,118 1,008 522 4,118 ,008 5,648 Е.С. 4th Year (8th) 7,259 2,055 9,740 6,314 7,685 140 154 1,217 5,902 1,217 с. С. 9,460 8,649 9,460 3,296 8,649 112 699 12,756 112 669 ь. С 3rd Year (7th) 9,688 5,902 0 1,630 7,532 1,630 1,291 6,767 Q 8,397 С О 1,132 1,132 I,834 23,146 20,180 21,312 20,180 21,312 С Рч 2nd Year (6th) 2,953 2,641 5,594 8,142 4,971 7,612 530 2,641 D.C. 8,645 9:056 8,645 408 408 11t 8,237 8,237 ь. С. lst Year (2th) 1,859 951 824 1,775 Ö 951 - 621 84 ŧ р.С Electrical Equipment Electrical Equipment Project Controlling Construction Period Project Controlling Transmission Line Transmission Line Interest during Grand Total Grand Total (II) without Tax Description Sub Total Financial Cost (I) with Tax

A 5-7

Table AP.5-3

Estimated Construction Cost (for Yusufeli Project)

(10⁶ T.L.)

Description	D.C.	F.C.	Total
Financial Cost			
(I) with Tax			· ·
Transmission Line	6,796	14,826	21,622
Electrical Equipment	55	403	458
Project Controlling	2,318	995	3,313
Sub Total	9,169	16,224	25,393
Interest during Construction Period	2,297	4,981	7,278
Grand Total	11,466	21,205	32,671
(II) without Tax			
Transmission Line	5,313	14,826	20,139
Electrical Equipment	50	403	453
Project Controlling	2,318	995	3,313
Grand Total	7,681	16,224	23,905
conomic Cost			
	3,603	14,826	18,429
Transmission Line	3,003	403	441
Electrical Equipment		403 995	2,826
Project Controlling	1,831	566	2,020
Grand Total	5,472	16,224	21,696

A 5---8

					· · ·		•	· · · · · · · · · · · · · · · · · · ·	· · ·		E)	(106 T.L.)	
Description	lst (5	t Year (5th)	2nd Year (6th)	d Year (6th)	3rd (7	l Year (7th)	4th (8	n Year (8th)	5th (9	n Year (9th)	To	Total	
	D.C.	F.C.	D.C.	F.C.	D.C.	F.C.	D.C.	F.C.	D.C.	F.C.	D.C.	F.C.	
Financial Cost							-						
(I) with Tax	نون در در											• • •	
												•	
Transmission Line Electrical Equipment	 	сч 	1,790	7,265	2,436	3,114 40	2,273 55	1,482 363	11	11	•	14,826 403	
Froject Controlling	18. 1942	14/	-icv	403	190	7.07	4.30	100	1	I	21012	ח ת ת	
Sub Total	639	3,112	2,741	7,673	3,023	3,406	2,766	2,033	H And	1	691,6	16,224	
Interest during	30 7 7	871	101	* YYY	ት ት ት ት ት ት ት ት ት ት ት ት ት ት ት ት ት ት ት	1 187	074	1 445	871	1 541	797 6	4 68 7 7 7	
			द २ न	2		24 C	2		•	4 	1		
Grand Total	699	3,260	2,932	8,333	3,488	4,593	3,506	3,478	871	1,541	11,466	21,205	
(II) without Tax												, <u> </u>	
Transmission Line	0	2,965	1,063	7,265	2,125	3,114	2,125	1,482	I	I	5,313	14,826	
Electrical Equipment Project Controlling	ent	147	- 951	408	587	40 252	438	188 188	1 1	()	2,318	604 995	والمتعادية والمتعادية والمتعادية والمتعادية والمتعادية والمتعادية والمتعادية والمتعادية والمتعادية والمتعادية و
Grand Total	342	3,112	2,014	7,673	2,712	3,406	2,613	2,033	I	1	7,681	16,224	
Economic Cost											- 		
Transmission Line	0	2,965	721	7,265	1,441	3,114	1,441	1,482	. 1	I	3,603	14,826	
Electrical Equipment Project Controlling	ent - 270 ag 270	147	751	408	0 464	40 252	38 346	188	i disc i disc i discont	1 1	38 1,831	403 995	
Grand Total	270	3,112	1,472	7,673	1,905	3,406	1,825	2,033	1	I 	5,472	16,224	

Table AP.5–5Estimated Construction Cost(for Artvin Project)

(10⁶ T.L.)

Description	D.C.	F.C.	Total
Financial Cost			
(I) with Tax			
Transmission Line	3,964	8,649	12,613
Electrical Equipment	32	236	268
Project Controlling	1,353	581	1,934
Sub Total	5,349	9,466	14,815
Interest during Construction Period	1,340	2,905	4,245
Grand Total	6,689	12,371	19,060
(II) without Tax			
Transmission Line	3,098	8,649	11,747
Electrical Equipment	29	236	265
Project Controlling	1,353	581	1,934
Grand Total	4,480	9,466	13,946
Economic Cost			
Transmission Line	2,100	8,649	10,749
Electrical Equipment	22	236	258
Project Controlling	1,068	581	1,649
Grand Total	3,190	9,466	12,656

A 5-10

(106 T.L.)

Table AP.5-6 Fund Requirement in Each Year (for Artvin Project)

8,649 236 581 8,649 99466 8,649 236 9,466 236 581 997,66 2,905 581 12,371 C F4 Total 1,340 3,190 2,100 1,068 3,964 5,349 6,689 3,098 29 4,480 22 1,353 1,353 32 ບໍ_່ດ 899 899 1.1 111 t t ţ 1 τ ł ч с щ 5th Year (9th) 508 508 Ł L I I i i t ł 1 1 l I 0 0 865 212 110 865 212 110 1,187 2,030 865 212 110 843 1,187 1,187 с я 4th Year (8th) 840 22 202 1,064 1,326 32 256 2,046 1,239 29 256 1,524 1,614 432 с П 1,816 24 147 1,816 24 147 1,816 24 147 2,679 1,987 692 1,987 1,987 U H 3rd Year (7th) 840 1,581 0 270 0 342 1,763 271 2,034 1,239 342 1,110 1,421 р. С 4,476 4,476 4,238 4,476 4,238 4,238 385 4,861 238 238 238 1 C F 2nd Year (6th) 1,710 620 1,175 420 438 858 1,044 1,599 555 555 111 I ł 2.0 1,816 1,816 1,730 1,816 1,730 1,902 1,730 1 8 86 86 - 86 1 С Гч lst Year (5th) 200 173 373. 391 200 158 158 200 0 0 18 1 1 ۱ с П Electrical Equipment Electrical Equipment Electrical Equipment Construction Period Project Controlling Project Controlling Project Controlling Transmission Line Transmission Line Transmission Line Interest during Grand Total Grand Total Grand Total (II) without Tax Description Sub Total Financial Cost Economic Cost (I) with Tax

A 5-11

A-6 DATA PROVIDED BY EIE

A--6 Data Provided by EIE

		Page
6.1	Meteorology and Hydrology	A6-1
6.2	Geology	A63
6.3	Development Planning	A6-5
6.4	Project Design	A6-7
6.5	Construction Planning and Cost Estimation	A68
6.6	Electric Power Situation	A6-9
6.7	Transmission Line	A6-11
6.8	Economic Evaluation	A612
6.9	Master Plan Report for Coruh River Basin Prepared by EIE (1982)	A6-13

A-6 Data Provided by EIE

Item Notes No. 2302, 2304, 2305, 2314, (1) Daily discharge data of stations 2315, 2316, 2318, 2320, 2321, 2322, 2323, 23325 Meydancik, Savsat, Ardanuc, (2) Daily Precipitation data of stations Sarigol, Senkaya, Tortum, Kirik, Yusufeli, Sarimese, Aydintepe, Bayburt, Ispir, Olur, Narmon, Oltu, Pazaryolu, Camlikaya, Kilickaya No. 2305, 2321, 2322, 2323 (3) Rating curves of stations No. 23 - 13, 23 - 4 (4) Daily discharge data of DSI's stations (5) Monthly evaporation data of stations Bayburt, Ispir (6) Design flood flows of existing and planned dams in Turkey including characteristics of river basin (7) Suspended sedimentation data of stations in turkey Total sediment volume (dead volume) (8) of existing dams in Turkey (9) Precipitation and vapor pressure data during selected historical storms 1982 Water Year Discharge "published (10)by EIE in 1985 (11) Location map of dams and hydropower plants which are existing, under construction or planned in turkey Location map of stream gaging (12)stations, sediment stations and snow course stations (13) Location map of meteorological stations and stream gaging stations within the basin (14) Wind velocity and wind direction measured at various height above Samsun City

6.1 Meteorology and Hydrology

A 6-1

	Item	Notes
(15)	Daily temperature of Bayburt station	
(15)	Daily temperature of dayburt station	
(16)	Backing data concerning flood	
	discharge calculation due to snowmelt as was carried out by EIE	
(17)	Specific sediment per square kilo- meter evaluated at stations in Turkey	
(18)	Annual peak discharges observed at	
	stream gaging stations in Coruh river	
(19)	Enveloping curves of monthly maximum	
//	vapor pressures	
(20)	Hydrology report titled "UNESCO-	
(20)	Uluslararasi Hidroloji Programi (UHP)	
	Turkiye"	
(21)	"Report on Engineering Hydrology for	
	Kargi and Guraogut Dama on Sakarya	
	River" Volume I, II, III	
(22)	Staff gage reading of Coruh river	
	water level 200 m downstream of Inanli damsite	a state factor of the state
	THAULT NAMOICE	
(23)		
	during selected historical storms at Bayburt and Artvin	and the second second second second
(07)		
(24)	Maximum l2-hour persisting vapor pressures for each month in every	
	year	
(25)	Daily precipitation data during	
. = > }	selected historical storms at	
	stations around the basin	
26)	Catchment area of alternative Inanli	Upstream damsite : $15,400 \text{ km}^2$
	damsite	Downstream damsite: 15,540 km ²
		a second second second second second
		n Alexandre Stevenski se se se se se se se se se se se se se
		and the strategy of the second second second second second second second second second second second second sec
		<mark>) - Energy </mark>
	A 6–2	

-

6.2 Geology

	Item	Notes
(1)	Geological map of Yusufeli reservoir	1 : 25000
(2)	Geological map of Yusufeli damsite	1 : 1000
(3)	Geological profile of Yusufeli damsite	1 : 1000
(4)	Coordination of drillholes and adits	
(5)	Logs of drillholes and adits	
(6)	Groundwater measurement record	
(7)	Geological map of Inanli reservoir	1 : 25000
(8)	Location map of investigation works at Inanli damsite (Plan)	1 : 1000
(9)	Ditto (Profile)	and a state of the state of the state of the state of the state of the state of the state of the state of the s State of the state of
(10)	Geological map of Inanli tunnel	1 : 1000
(11)	Geological profile of Inanli tunnel	1 : 5000
(12)	List of drillholes and adits at Inanli damsite	
(13)	Logs of drillholes	
(14)	Data of permeability test at Inanli damsite	
(15)	Location map of drillholes at Havuzlu landslide	
(16)	Geological plan at Inanli damsite (existing site)	
(17)	Logs of adits at Inanli damsite (existing site)	
(18)	Data of seismic prospecting at Havuzlu landslide	
(19)	Data of seismic prospecting along adíts at Yusufeli damsite	
(20)	Some geological data along Inanli tunnel near Esenkaya village	

A 6-3

un oraș en 1990 Alexandre alexandre alexandre alexandre Alexandre alexandre alexandre alexandre alexandre alexandre alexandre alexandre alexandre alexandre alexandre a

	Item	Notes
(21)	Results of soil tests at Tortum landslide, Vecaket landslide, Havuzlu landslide and Demirkent landslide	
(22)	Geological log of adit LA-2 (50 m from TD 76 m to TD 126.75 m)	
(23)	Geological logs of drillholes RSI-16 and ST-1	
(24)	Photographs for the shear tests	
(25)	Geological map of Inanli downstream damsite	1/2,000
(26)	Surface geological investigations based on the new topographic map at	
(27)	Yusufeli dam site Various investigations at Inanli	
	downstream dam site	
	A 6–4	

 (1) Topographical maps scale: 1/5,000 covering reservoir area of Yusufeli and Inanli projects (2) Characteristics of Coruh River basin (3) Water resource development plan of Coruh River basin (4) Salient features of existing reservoir type power stations in Turkey (5) Major Items of investment cost for hydropower project (6) Reservoir elevation-compensation cost curve of Yusufeli reservoir (7) Reservoir elevation-compensation cost curve of Inanli reservoir (8) Survey and investigation cost and administration cost of existing projects in Turkey (9) Salient features of Katakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operstion and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlati ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation Values Report 		Item	nationality.	Notes	
 (3) Water resource development plan of Coruh River basin (4) Salient features of existing reservoir type power stations in Turkey (5) Major Items of investment cost for hydropower project (6) Reservoir elevation-compensation cost curve of Yusufeli reservoir (7) Reservoir elevation-compensation cost curve of Inanli reservoir (8) Survey and investigation cost and administration cost of existing projects in Turkey (9) Salient features of Karakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(1)	covering reservoir area of Yusufeli	66 sheets		
 Coruh River basin (4) Salient features of existing reservoir type power stations in Turkey (5) Major Items of investment cost for hydropower project (6) Reservoir elevation-compensation cost curve of Yusufeli reservoir (7) Reservoir elevation-compensation cost curve of Inanli reservoir (8) Survey and investigation cost and administration cost of existing projects in Turkey (9) Salient features of Karakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(2)	Characteristics of Coruh River basin			
 reservoir type power stations in Turkey (5) Major Items of investment cost for hydropower project (6) Reservoir elevation-compensation cost curve of Yusufeli reservoir (7) Reservoir elevation-compensation cost curve of Inanli reservoir (8) Survey and investigation cost and administration cost of existing projects in Turkey (9) Salient features of Karakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(3)				
 hydropower project (6) Reservoir elevation-compensation cost curve of Yusufeli reservoir (7) Reservoir elevation-compensation cost curve of Inanli reservoir (8) Survey and investigation cost and administration cost of existing projects in Turkey (9) Salient features of Karakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(4)	reservoir type power stations in			
 curve of Yusufeli reservoir (7) Reservoir elevation-compensation cost curve of Inanli reservoir (8) Survey and investigation cost and administration cost of existing projects in Turkey (9) Salient features of Karakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(5)		-		
 curve of Inanli reservoir (8) Survey and investigation cost and administration cost of existing projects in Turkey (9) Salient features of Karakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(6)				
 administration cost of existing projects in Turkey (9) Salient features of Karakale, Artvin, Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(7)			-	
 Borcka and Muratli projects (including storage capacity curve) (10) Reservoir water level-storage capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(8)	administration cost of existing			
 capacity curve and water level-area curve of Yusufeli and Inanli projects (scale: 1/5,000) (11) Definition of firm power, firm energy and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(9)	Borcka and Muratli projects			
 and secondary energy (12) Operation and maintenance cost of major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(10)	capacity curve and water level-area curve of Yusufeli and Inanli projects			
 major hydropower plants (13) Artvin, Borcka, Muratli barajlari ve Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation 	(11)				
Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of Feasibility Study 1984) (14) Yusufeli Damsite Expropriation	(12)			·	
	(13)	Hes Yapilabilirlik Ara Raporu (Artvin, Borcka, Muratli dam and powerstation Interim Report of			
	(14)				

	Item		Notes
(15)	Inanli Damsite Expropria Report	ation Values	
(16)	Topographical maps scale covering Yusufeli dam s	e: 1/1,000 ite	
(17)	Area and population (as	of 1980)	
(18)	General conditions of An province	rtvin	
(19)	River cross section and	rating curves	
		· · · ·	
		:	
		1	
		۰. •	
		· · · ·	
			••••••••••••••••••••••••••••••••••••••
		A 6-6	

6.4 Project Design

	Item	Notes
(1)	A probabilistic assessment of the seismic hazard in Turkey	
(2)	Report on the Turkish eashquake of October 30, 1983	
(3)	Regional rearrangement of earthquake catalogues of Turkey	
н 		
		and the second state of the second second second second second second second second second second second second
* .		
· · · ·		
•		
	А 6-7	L

	Item		Notes
(1)	Location of project area possibilities	a and access	
(2)	Ekonomik Etud Tablolari prices of construction v roads)	1984 (Unit works of	
(3)	Unit construction costs civil works established		
(4)	Material cost		
(5)	Labor cost		
(6)	Unit construction cost, schedule and quantities project		
(7)	Inland transportation		
			•
	· · · · · · · · · · · · · · · · · · ·		
		· · · ·	
		A 6-8	

6.5 Construction Planning and Cost Estimation

6.6 Electric Power Situation

	Item	Notes
(1)	Targets and performance of long-range plane (growth rate)	
(2)	Economic activity	
(3)	Population actual and estimated	
(4)	Installed generating capacity	a da anti-arresta da anti-arresta da anti-arresta da anti- arresta da anti-arresta da anti-arresta da anti-arresta da anti-arresta da anti-arresta da anti-arresta da anti- arresta da anti-arresta da anti-arresta da anti-arresta da anti-arresta da anti-arresta da anti-arresta da anti-
(5)	Energy generated per capita	
(6)	Monthly maximum demand	
(7)	Basic data for demand forecast	
(8)	Electricity demand forecast by TEK	
(9)	Energy balance	
(10)	Breakdown of energy generated in a selected month	
(11)	Gross energy generated	
(12)	Electrification ratio	
(13)	Major hydraulic power stations under construction	
(14)	Power development plan in Turkey	
(15)	Total of hydraulic power station projects in Turkey	
(16)	Construction schedule of power stations in Turkey	
(17)	Production schedule of available energy generated	an an an an an an an an an an an an an a
(18)	Transmission and distribution lines	
(19)	Loss and drop of voltage	
(20)	Power demand forecast method in Turkey	

	Item	Notes
(21)	Expanded development plan of power system in project area and the project plan of transmission line and substation	
(22)	Current situation and future plan of power dispatching system	
(23)	Typical daily demand curve in 1984 or 1983	
(24)	Daily load curve of selected date of typical month	
(25)	Planning data of telecommunication system for the project	
(26)	System of electricity tariff	
(27)	Receiving point of electric power for construction and capacity of existing substation	
(28)	Major plants in operation shown in Tables-22 to 25.	
(29)	Plants's name and figures are checked by EIE.	
(30)	Long term electric power development scheme 1982	
(31)	Construction schedule of power stations in Turkey (average and continuous capacity)	
(32)	Turkiye Elektrik Istatistikleri Ozeti (1984 Yili Sonu)	
(33)	Turkiye Elektrik Enerjisi Talep Tahmin Calismalari (1984 - 2000)	gentine in the second second second second second second second second second second second second second second
		n an an gha ta ak pitata Barta. An an an an an an an an
		n en franziska se state en franzenska se se se se se se se se se se se se se

6.7 Transmission Line

6.7	Transmission Line		
	Item		Notes
(1)	Construction cost of 154 transmission line in 1984	kV	
(2)	Unit prices for transmiss in 1985	ion lines	
		х. х.	
			and the second second second second second second second second second second second second second second second
		· · · · · · · · ·	
	· ·		
	• •		
	an an Araba an Araba an Araba Araba an Araba an Araba an Araba Araba an Araba an Araba		and and the second second second second second second second second second second second second second second s Second second br>Second second
11 1	n an an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna an Anna		
		· · ·	
		<u>.</u>	
		· • •	
•			
		: - 	
·.			
·•	an an an an Arland an Arland an Arland. Anns an Arland an Arland an Arland an Arland an Arland an Arland an Arland an Arland an Arland an Arland an Arl		
		A 6-11	

6.8 Economic Evaluation

	Item	Notes
(1)	TEK's annual reports 1984, 1983, and 1982	
(2)	TEK's annual production cost in 1984	
(3)	Basic criteria of economic analysis	
(4)	Loan condition	
(5)	Unit price of imported energy in 1984, Bulgaria and U.S.S.R.	
(6)	Commence year of Yusufeli and Inanli project	
(7)	Electric Tariff	
(8)	Distribution ratio of electricity to local demand	
(9)	Alternative thermal	
(10)	Operation Activities Report	May 1985, August 1983, December 1984
(11)	Construction and operational cost of lignite thermal power plant	For reference only
(12)	Annual report of TKI	For reference only
		· · ·

Item			Notes				
(1) Master Plan Vo	olume I					<u></u>	
	olume 2						
	olume 3						
	olume l						
	olume 2	}					
(6) Geology							
(7) Drawings		{					
							÷
	·						
					-		
a de la companya de la companya de la companya de la companya de la companya de la companya de la companya de La companya de la companya de la companya de la companya de la companya de la companya de la companya de la comp							
		ļ					
	•						
		ļ					
					-		•
				·			
			· · ·	•		_ ^ ^ *	. •
	A 6-13	↓	 -	. ·			

6.9 Master Plan Report for Coruh River Basin Prepared by EIE (1982)