3.1.2 Water Resources Development Plan and its Present Status

(1) Hydroelectric Power Development Plan

A Master Plan for hydroelectric power development plan for the Coruh River was prepared by EIE in 1982. According to the Master Plan, the development plan for the basin would consist of construction of 11 dams and power plants with installed capacity of 2,003 MW and annual energy production of 7,468 GWh. The breakdown of the plan is as follows:

Dam	and Power Plant	Installed capacity (MW)	Annual energy production (GWh)
1.	Lalelí	85.00	180.79
2.	Kilicci	27.10	74.90
3.	Ispir	58.48	276.47
4.	Gullbag	64.40	291.55
5.	Akus	115.50	355.63
6.	Karakale	201.60	801.51
7.	Yusufeli	417.00	1,445.05
8.	Artvin (Inanli)	192.60	746.13
9.	Deriner (Artvin)	511.00	1,993.56
10.	Borcka	230.00	870.93
11.	Muratli	100.00	431.06
	Total	2,002.68	7,467.58

With regard to the Yusufeli and Artvin projects mentioned above, a Feasibility Study was made by JICA from 1985 to 1986 as a part of technical cooperation provided by the Japanese Government.

As for the Deriner, Bortcka, and Muratli projects, it is scheduled for feasibility studies to be completed by EIE by the end of 1986. Feasibility studies have been started by EIE in 1986 on the remaining 6 projects also.

With respect to tributaries of the Coruh River, according to development plans of the reconnaissance level, 26 power plants would be constructed having a total installed capacity of 866.0 MW and total annual energy production of 2,414 GWh. The approximate breakdown of these are as follows:

	Number of power _plants	Total installed capacity (MW)	Total annual energy production (GWh)
North Creeks Development Plan	7	144.6	381.0
Altiparmak Development Plan	4	223.0	509.6
Berta Development Plan	7	257.5	770.9
Oltu Development Plan	4	159.6	538,1
Lower Coruh Tributary Development Plan	4	81.5	214.4
Total	26	866.0	2,414.0

Other than the abovementioned plans, there is the Tortum No.l Hydroelectric Power Plant with an installed capacity 26 MW which has been constructed on the Tortum River, a right-bank tributary of the Coruh River, and this is presently in operation. The power from this plant is connected to Hopa Substation by a transmission line.

(2) Irrigation Plan

Although an investigation of reconnaissance level has been conducted, there is an irrigation development plan for the Bayburt Plain in the upstream area of the Coruh river, according to which it is planned to irrigate a total area of 27,084 ha.

3.2 General Condition in Projects Area

3.2.1 Landform and Natural Conditions

(1) Landform

The project area generally consists of steep mountainland. The principal mountains in the project area are Mt. Tatos (3,937 m), Mt. Kop (2,953 m), and Mt. Cam (3,850 m), with all mountains having heights of 2,000 to 3,000 m or over forming divides of rivers. Accordingly, there is extremely little flat area, and when confined to the reservoir areas of Yusufeli and Artvin and their surroundings, no flat area can be seen.

The Coruh is a river having a total length of approximately 410 km and it originates at the northeastern end of Turkey. However, its mouth is located inside Soviet territory where the river empties into the Black Sea. The major tributaries of the Coruh are the Barhal River, Oltu River, and Tortum River, all located in the Yusufeli Reservoir. The catchment area at the Yusufeli dam site is $15,250 \text{ km}^2$ and the average annual inflow is $3,777 \times 10^6 \text{ m}^3$.

- (2) Natural Conditions
 - (a) Geology

The basement rocks at the dam site and reservoir area of the Project consist of the Berta Formation, the Pugey Formation and the Yusufeli Formation of the Mesozoic Era and Ikizdere granites of the Tertiary Period. The Pugey Formation partially consists of calcareous rocks, but these are not pure limestone and have interbeds of solutionresistant or insoluble rocks. Furthermore, the distribution area of this Pugey Formation is surrounded by insoluble formations so that watertightness of the reservoir is assured. The relationship of deposits of the various formations are the Berta Formation contacting the Pugey Formation by a thrust fault, and the Pugey Formation contacintng the Yusufeli Formation by inclined unconfor-

3--6

mity. As for the Ikizdere granites, they are large-scale rock bodies intruded into the various formations. Further, since this project area, seen from a geotectonic history point of view, is an area that was subjected to Hercinium orogeny of the Paleozoic Era and Alpine orogeny of the Mesozoic to Cenozoic Eras, there are comparatively numerous large and small faults.

(b) Seismicity

)

The eastern part of the Anatolian Peninsula is divided by two transform faults constituting the plate boundaries of the North Anatolian Fault and the East Anatolian Fault. The project area is located approximately 170 km north of the point where the two faults intersect each other and so is not in an area along a so-called active fault. However, it is at distances of 200 to 100 km from the cities of Erzincan and Erzurum which have experienced large-scale earthquakes in the past, and therefore, this is an area where care must be excercised.

(c) Meteorology

The Coruh River Basin can generally be divided into continental climate and Black Sea climate. Continental climate is predominent in the project area. The annual precipitation is 440 mm and about 50 percent of the annual rainfall comes in the wet season of March to June. There is also snowfall in January and February.

According to the records of Yusufeli Meteorological Observation Station, the maximum, minimum, and mean temperatures are 43.8°C, -14.3°C, and 14.2°C, respectively.

3.2.2 Natural Environment

(1) Scenery

Places that are especially considered to be scenic spots cannot be seen in the project area. However, there is a continuation of cliffs showing rare formations reminiscent of a natural museum of geology in the area along the Tortum River from the upstream end of the reservoir to Lake Tortum.

(2) Vegetation

No rare species of plant has been reported so far to exist in the project area.

The topography of the project area is of rugged mountains with little vegetation. Trees exist mainly scattered at hamlets along streams, and infrequently, there are short trees at mountainland. Especially, at the dam site sheer cliff rise at both banks with bare rock exposed and hardly any vegetation. There is also little vegetation in the area to be submerged by creation of the reservoir.

Vegetation is seen from the vicinity of Artvin downstream of the project area, from where to the Black Sea coast vegetation is comparatively abundant.

(3) Animal Life

So far, rare species of either land or aquatic animals have not been reported to exist in the project area.

With regard to fishes, there has been no report of the existence of migratory fish. The extent of fishes inhabiting the streams of the project area is that some carps and daces are found and there is no fishing industry.

(4) Water Quality

Water quality investigations of the Coruh River are being carried out at the Karsikoy (No. 2315) and Bayburt (No. 2304) gauging stations. Observations have been made once monthly (1971-1976). According to the results, pH values of 6.3 to 8.8 are indicated. According to the results of analyses the water quality is of C_2S_1 class.

Visual observations made at the times of the field reconnaissances carried out in June-July 1985 and February 1986 showed a substantial amount of turbidity of the river water in the vicinity of Borcka located in the downstream area of the Coruh River. However, when confined to the project site, impairment of water quality was not seen, except for turbidity of the river water during heavy rainfall.

Changes in water quality which can occur with creation of a large-scale reservoir are eutrophication, low water temperatures, and long-term turbidity.

A problem related to water quality that could conceivable occur as a result of implementation of the Project is long-term turbidity of reservoir water. However, there has been no case of water quality having been changed posing a problem that have been reported so far at existing reservoirs in Turkey.

Although the possibility of long-term turbidity of water caused by the Project is a topic for further study, it may be judged that this will not be a decisive matter to adversely affect implementation of the Project.

3–9

3.2.3 Social Environment

The project area is located in Artvin Province.

Artvin province covers an area from the Black Sea coast to the midstream part of the Coruh River and consists of seven counties, the areas and populations of which (as of 1980) are as follows:

		<u>Area (km²)</u>	Population	
Ar	tvin Province	7,436	228,997	
	Artvin County	1,052	29,964	
	Ardanuc County	.969	21,945	
	Arhavi County	314	17,772	
	Borcka County	1,168	43,601	
	Hopa County	289	29,426	
	Savsat County	1,317	45,179	
	Yusufeli County	2,327	41,110	

The capital of Artvin Province is the city of Artvin located approximately 47 km southeast of Hopa on the Black Sea coast, and faces the mainstream, Coruh River.

The population of Artvin City (as of 1980) was 14,307. The city has governmental offices, banks, hospitals, schools, hotels, communication facilities, commercial shops, etc., and therefore, has the various facilities indispensable for commercial activity and daily livelihood.

The project area is located in Yusufeli County of Artvin Province. The following paragraphs mainly describe the features of the project area.

(1) Population

The Project consists of the Yusufeli Project and the Artvin Project. When the Yusufeli Project is implemented, the town of Yusufeli and villages in the vicinity will be affected by Yusufeli Reservoir. These communities are Yusufeli, Yeniyuva, Irmakyani, Uysallar, Kabandibi, Demircubuk, Vacekent, Hazuket, Tasbasi, part of Takkale, Celtiktuzu, Cevreli, Ballidut, Medan, Kirazli, Ginler, part of Arpacik, Gorgulu, Boylar, and Yarbasi. The populations of these communities were 6,806, 7,164 and 7,473 according to the population census of 1970, 1975 and 1980, respectively.

When the Artvin Project is implemented, the villages of Inanli, Sebzeciler, and Bez will be affected by Artvin Reservoir.

The populations of these villages were 442, 419 and 363 according to the population census of 1970, 1975 and 1980, respectively.

The population growth in the Yusufeli district is extremely small, while in the Inanli district, the population is decreasing. The reasons are that it is difficult to find employment in the surrounding area, while land suitable for agriculture is insufficient, and there is practically no demand for seasonal laborers in the surroundings so that the younger generation have migrated to the cities.

(2) Culture and Public Facilities

The town of Yusufeli which is the center of the Yusufeli project area has an elementary school, junior high school, high school, and a vocational school. Larger villages in the area have elementary schools.

Elementary schools do not exist at the villages in the Artvin project area. An elementary school, a junior high school and a vocational school exist at Demirkent where a governmental office is located.

Besides these schools, there are mosques at Yusufeli Town and the various villages.

(3) Health and Sanitation

There is no problem of infectious disease affecting the health and sanitation of the people in the Yusufeli and Artvin project areas.

Health care administration of Yusufeli County is handled by the province with health center personnel making the rounds of the surrounding villages.

(4) Transportation and Communications

A two-lane national highway asphalt-paved over its entire length passes through the project area from Trabzon on the Black Sea coast, running through Hopa, Artvin, the Artvin site, and the Yusufeli site to Erzurum. The distance between Trabzon and Yusufeli is 335 km, while that between Erzurum and Yusufeli is 120 km.

There is daily regular bus service between Artvin City and Yusufeli Town. Jeepable roads connect to larger villages. Yusufeli Town has postal service where telephone and other communication services are handled.

(5) State of Economic Activity

(a) Agriculture

The greater part of the economy in the project area is supported by agriculture. Agricultural land has been developed at flat areas along the banks of streams and on mountain slopes, and water of the Coruh River and tributaries is utilized. The agricultural products are fruits, vegetables, rice, etc. Olive and grains such as barley are grown where water suply is inadequate.

Animal husbandry is practised at villages, but not very extensively.

(b) Mining and Manufacturing

Large-scale factories do not exist in the project area. Yusufeli Town has a flour mill, macaroni plant, lumber mill, automobile repair shop, etc., which are all of small scale. Mineral resources have not been discovered in the project area.

(c) Commerce and Tourism

Most of the items shipped consist of agricultural products which are mainly collected at Erzurum City and Artvin City.

There are no important historical sites for tourism in the project area.

There are relics of ancient castle walls and bridges at Sarigal close to the project area.

(d) Fishing and Boat Navigation

Fresh water fishing and boat navigation do not exist on the Coruh River in the project area.

(6) Submersion and Relocation

The objects of compensation such as houses and cultivated land to be submerged as a result of implementation of the Project and compensation costs were investigated in detail by EIE in 1984.

The population, cultivated land, and major items to be submerged by the reservoir of the Yusufeli Project are shown below.

(Figures correspond to high water level of 700 m)

Population: Approximately 7,000 persons

Cultivated land:

	(Decare)
Sb (vegetable field - tomato, pepper, beans)	320,60
ST ₁ (wheat, barley, corn)	1,338.70
Mbk (orchard - cherry, apricot, pomegranate)	2,679.70
Bg (orchard - grape)	31.60
CL (paddy - rice)	1,297.00
Ma (pasture - grazing)	1,178.00
Cay (pasture - hay)	22.90

Principal buildings:

House	1,613 units	
School	12	
Mosque	10	$F_{\rm eff} = 1$

The population, cultivated land, and major items to be submerged by the reservoir of the Artvin Project are as shown below.

(Figures correspond to the original site)

Population: Approximately 360 persons

Cultivated land:

	(Decare)
Sb (vegetable field - tomato, pepper, beans)	14.80
ST ₁ (wheat, barley, corn)	12.80
Mbk (orchard - cherry, apricot, pomegranate)	50.50
Zy (olive)	196.90

Principal buildings:

House		65 units		
School		0		
Mosque		1		

With regard to submersion and relocation accompanying implementation of the Project, since the population is relatively

large, study of the plan concerning submersion and relocation will be extremely important subject for further study.

As mentioned under (4), Transportation and Communications, there is a national highway connecting Artvin and Erzurum. This national highway plays an extremely important role in transportation of freight. Due to implementation of the Project, it will be necessary to relocate the national highway to be submerged before starting water impoundment of the reservoir.

Especially, regarding the project site and the part of the national highway in the surroundings, it will be necessary to relocate the road before starting on the main work. Since transportation of passengers and freight can not be interrupted, the outcome of the national highway relocation work will govern the start of work in the Project.

(7) Water Utilization Rights

The water utilization rights of the Coruh River belong to the Turkish Government, and not to the local muncipality or private enterprises.

All dams and power plants are constructed by DSI. After completion, these dams and power plants are transferred from DSI to TEK.

CHAPTER 4 PRESENT STATE OF ELECTRIC ENTERPRISE

CHAPTER 4. PRESENT STATE OF ELECTRIC ENTERPRISE

CONTENTS

()

	• •	Page
4.1	Present Status of Electric Power	4 – 1
4.2	Electric Power Enterprises	4 – 4
4.3	Present Status of Power Supply Facilities	4 - 5
4.4	Present Status of Power Demand and Supply	4 10

List of Figures

ì

Fig. 4–1	Installed Capacity and Energy Generated
Fig. 4–2	Percentage of Hydraulic Power Plants in Total Installed Capacity
Fig. 4-3	Percentage of Hydraulic Energy in Gross Energy Generated
Fig. 4–4	Typical Daily Demand Curve

List of Tables

Table 4-1	Installed Generating Capacity
Table 4–2	Major Power Plants in Operation
Table 4-3	Major Transmission Line in Operation
Table 4-4	Transmission and Distribution Lines
Table 4–5	Gross Energy Generated
Table 4-6	Monthly Maximum Demand
Table 4–7	TEK's Energy Balance
Table 4-8	Meeting of the Peak
Table 4-9	Distribution of Electrical Energy Generated

4.1 Present Status of Electric Power

The national economy of the Republic of Turkey, which had been in a state of recession after the first oil crisis, started to recover gradually since 1980, owing to international assistance and the determined efforts for economic reconstruction by the Republic of Turkey itself.

A great deal of emphasis is placed on the development of electric power, which is regarded as one of the important pillar for the economic reconstruction. In particular, the power generation capacity is being steadily expanded, with hydroelectric power development playing the central role.

The past trend of the total installed generation capacity and the total amount of electricity generation are illustrated in Fig. 4-1.




Fig. 4–1 Installed Capacity and Energy Generated

The installed capacity as of 1984 was 8,459 MW, which consisted of 54% thermal power and 46% hydro power.

The annual generation was 30,614 GWh, of which the hydroelectric power accounts for 46%.

The annual power generation per capita is 630 kWh. Although this figure is low as compared to per capita consumption of 5,000 to 7,000 kWh in the highly industrialized countries, the growth of power generation in Turkey is large. The annual growth rate was over 10% before the first oil crisis. Thereafter, the growth rate declined to a relatively low level of 4 to 5% due to deteriorated economic conditions, but in 1984, it recorded a high growth rate of 11.9% over the previous year, reflecting the recovery of economic activities.

This rapid growth of electric demand had caused shortage in the supply capacity, and the Republic of Turkey started import of electricity from Bulgaria in 1975, and from U.S.S.R. in 1979. This import of electricity still continues today.

The amount of electricity import has increased year by year, amounting to 2,653 GWh in 1984, which accounts for approximately 8% of the total electricity consumption in this country.

Also, there is strong latent demand for electric power, and it can be estimated that the future growth rate will even exceed 10%. The electric power development projects are being aggressively implemented to meet this future demand.

According to the power development plan, large hydroelectric and thermal power plants will be completed and connected to the Turkish national power grid in succession in the period around 1987 to 1990, including Elbistan Thermal Power Plant (4,200 MW) and hydroelectric power plants such as Karakaya (1,800 MW), Altinkaya (700 MW) and Ataturk (2,400 MW).

More emphasis is placed on hydroelectric power projects from the point of view of effective utilization of water resources, which is a genuine indigenous primary energy source of Turkey. Thus it is planned to bring the ratio of hydro power to thermal power between 50:50 and 55:45 by the year 2000.

In the long-range plan, nuclear power is also expected to play an important role. It is planned to commission the first nuclear power plant (1,000 MW) in 1992, and a total of 9 nuclear power plants (10,000 MW) will start operation in succession before 2005.

Power consumption in 1984 by categories was 65% in mining and manufacturing industries, 33% in agriculture, commerce and household uses, and 2% in transportation. These ratio have not changed substantially in the past 10 years.

The power system in the Republic of Turkey is interconnected throughout the country, and independent power systems accounts for only 4% of the total capacity.

The major transmission system consists of 380 kV lines (4,464 km), 154 kV lines (15,679 km) and 66 kV lines (2,182 km). The 66 kV lines and 34.5 kV lines are used for local transmission systems. The transmission/distribution network of voltages of 34.5 kV and less have a total length of 110,000 km and are being expanded year by year. Yet a substantial number of villages without electric service exists in local agricultural regions.

The rate of electrification of households is around 70% at present.

As of April 1, 1985, the electric rate in the Republic of Turkey is determined by the following two different rate systems, and a consumer can select one of them at his option.

a) 2-Stage Rate System

- i) kW rate: Annual rate of 18,600 TL or monthly rate of 1,500 TL per kW of electric demand.
- ii) kWh rate: 29.2 TL per kWh.

iii) Time band rates

Peak hours: 40.5 TL/kWh.

- Daytime: 29.2 TL/kWh.
- Nighttime: 19.4 TL/kWh.

(This rate is applied to a consumer having contract capacity exceeding 700 kW.)

b) Uniform Rate System: 32.8 TL/kWh

4--3

4.2 Electric Power Enterprises

Electric power administration in the Republic of Turkey is under the jurisdiction of the Ministry of Energy and Natural Resources.

The greater part of the electric enterprise are made up of state-owned systems, and these are operated by the Turkish Electricity Authority (TEK). In addition, there are the General Directorate of Electrical Power Resources Survey and Development Administration (EIE) and the General Directorate of State Hydraulic Works (DSI) which are government agencies.

(a) Electric Power Development Planning and Investigation: (EIE)

- (b) Construction of dams and hydroelectric power plants: (DSI)
- (c) Operation of hydroelectric power plant, construction and operation of thermal power plant, transmission and distribution: (TEK)

Most of the electric enterprises are state owned, and powerplants and power system operated by TEK, although there are some privately owned enterprises.

EIE is an organization entrusted with the tasks of conducting surveys and formulating plans for electric power development. EIE carries out investigations of power development sites, and determines their scales, and implementation schedule taking into consideration predicted future power demand and supply.

DSI is an organization established in 1953 with 25 regional offices throughout the country, and is in charge of construction and operation of dams for flood control, irrigation and drainage, and supply of domestic and industrial water, and in addition construction of hydroelectric power plants. With regard to hydroelectric power projects, there are cases where DSI implements them independently and cases where EIE participates in the survey stage.

TEK is an electric power enterprise which undertakes construction, maintenance and operation of thermal power plants, nuclear power plants and transmission lines, and maintenance and operation of hydroelectric power stations constructed by DSI. Of the entire power

generating capacity in the Republic of Turkey, 85% is operated by TEK. The remaining 15% consists of municipally-owned power plants and plants operated by private enterprises.

There are three patterns for power distribution - one is territory directly supplied by TEK, two is distribution undertaken by municipal organizations supplied with power by TEK, and three is areas supplied by Electricity and Gas Services. Since the service areas of these three patterns of distribution overlap at places, study is underway to remedy this situation from the standpoint of rationalization.

4.3 Present Status of Power Supply Facilities

The past trend of the power generation capacity in Turkey, and the ratio of hydroelectric power in the total installed capacity are presented in Table 4-1 and Fig. 4-2 respectively for each year. The ratio of hydroelectric power is 46% of the total capacity (3,875 MW) as of 1984. The hydroelectric power plants, including Hasan Ugurlu (500 MW) and Oymapinar (540 MW) which were commissioned after 1980, play very important roles in power system.

The present policy of the Government of Turkey, which places priority on domestic energy source utilization with the objective of improving international balance of trade, is not expected to change in the future, and the development of hydroelectric power and lignite-fired thermal power plant will be promoted.

The major power plants in operation are listed in Table 4-2.

As discussed before, the transmission line voltages in Turkey is 380 kV and 154 kV. The 220 kV transmission voltage is also used for interconnection with the power system of U.S.S.R.

The major transmission lines are listed in Table 4-3.

Keban-Golbasi Line and Golbasi-Umraniya Line extend over a distance of 900 km, being the trunk line that spans central Turkey. This line interconnects the large power sources in the East and the load centers in the West.

The past trends in the expansion of total lengths of transmission lines and distribution lines are given in Table 4-4. Table 4-1 Installed Generating Capacity

Unit: MW

2,235 2,578 2,711 3,192 3,732 4,187 4,364 4,727 4,869 5,119 1,490 1,644 1,959 1,967 1,967 1,272 1,324 1,371 1,371 1,381 1,418 Total Hydraulic 725 872 892 985 1,449 1,780 1,873 1,873 1,873 1,873 2,131 412 445 470 497 497 505 616 723 724 Total $\begin{array}{c}1,510\\1,706\\1,819\\2,207\\2,283\end{array}$ Thermal 2,407 2,491 2,854 2,988 2,988 985 ,028 ,257 ,244 860 879 901 921 921 748 814 833 842 898 958 979 1,042 1,068 1,068 704 739 786 792 828 828 871 880 868 868 863 Total Operated by Others Hydraulic 145 145 145 145 143 203 203 203 258 259 259 259 259 259 81 97 122 126 126 Thermal 699 720 809 809 623 6642 666 684 683 726 725 721 721 605 611 631 639 640 1,4871,7641,8782,3502,8341,079 1,099 1,104 3,229 3,385 3,685 3,685 4,051 662 773 568 585 585 589 589 Total Operated by TEK Thermal Hydraulic 582 669 782 1,191 1,521 1,614 1,614 1,622 1,872 3331 348 358 352 353 360 471 557 577 582 905 1,095 1,568 1,568 302 302 522 522 522 1,708 1,771 2,071 2,179 2,179 237 237 237 237 237 237 1965 1966 1967 1968 1969 Year 1970 1971 1972 1973 1973 1975 1976 1977 1978 1978 1960 1961 1962 1962 1963

5,119 5,537 6,638 6,935 8,459

2,131 2,356 3,082 3,239 3,875

2,988 3,181 3,556 3,556 4,584

1,068 1,095 1,095 999 1,272

259 259 259 259 259 259 259 231

809 836 836 758

4,051 4,442 5,543 5,936 7,187

1,872 2,097 2,823 2,998 3,644

2,179 2,345 2,938 3,543

1981 1981 1982 1983

1984

1,041

Table 4-2 Major Power Plants in Operation

Energy Generated (GWh, 460 180 5,820 40 100 110 65 Firm Hydraulic Power Plants Average 6,000 80 190 562 400 - 135 250 400 1,217 569 41 2220 2220 314 42 42 65 65 350 3350 3350 3350 3357 307 30 85 Capacity (MW) 26.18 8.25 20.12 Installed 278.4 128 ,330 73.3 14.4 10.8 15.2 60 15.4 70 56 26.4 53 76 160 500 540 138 23 48 (A+B) ო | Hasan Ugurlu Name Suat Ugurlu 00 Oymapinar 1 Demirkopru Aslantas I Kesikkopru Keban I -Dogankent Gokcekaya Cag-Cag] Kadincik Kadincik Hirfanli Ikizdere Kovada 2 Kovada 1 Sariyar Hazar l Seyhan Tortum Cildir Almus Kemer Goksu Kepez Generated (GWh) 300 830 1,800 2,970 4,200 350 3,780 2,700 3,900 90 540 360 360 340 340 77 75 75 70 75 70 255 300 5540 770 75 70 255 80 255 120 600 28 Energy Ц Thermal Power Flants Capacity (MW) Installed 630 50 129 35.1 180 30 120 15 50 80 16.8 129 630 680 680 15 30 20 18 29 17 19 44 5 Eskischir - Seker **Tuncbilek B 1,2** Aliaga - Cevrim Petkim - Aliaga Soma B 1,2,3 Yatagan 1,2,3 Dalaman - SEKA Turhal - Seker Elbistan A 1,2 Silifke - SEKA Seyitomer 1,3 [zmit - SEKA [uncbilek A Name Seydisehir Jeotermal Caralagzi Ambarali Bornova **LSDEMIR** Irdemir Karabuk Ankara Soma A Engil IPRAS Hopa Izmir AKSA

Name	Nominal Voltage (kV)	Length (Km)	Conductor (MCM)
Keban-Golbasi	380	550	2 x 954
Golbasi-Umraniya	380	355	954
Golbasi-Gokcekaya	380	167	954
Gokcekaya-Umraniaya	380	216	954
Osmaniya-Seydisehir	380	418	2 x 954
Balikesir-Bursa	380	120	2 x 954
Yatagan-Ismir II	380	150	2 x 954
Elbistan-Kayseri	380	138	2 x 954
Oymapinar-Kepez	380	100	2 x 954
Bursa-Adapazari II	380	154	2 x 954
Gokcekaya-Seyitomer - Ismir 11	380	435	954
Нора - S.S.C.B.	220	31	954

Table 4--3 Major Transmission Line in Operation

Year	Transmission Lines			Distribu-		
	380 kV & 220 kV	154 kV	66 kV	Total	tion Lines	Total
1962	-	2,166	1,024	3,190	2,432	5,622
1967		4,129	1,870	5,999	6,071	12,070
1972	355	6,010	2,436	8,801	44,861	53,662
1977	2,684	10,748	2,481	15,913	70,583	86,496
1978	2,856	12,527	2,490	17,873	77,214	95,087
1979	2,890	13,677	2,494	19,061	83,714	102,775
1980	2,897	14,351	2,498	19,746	96,393	116,139
1981	2,915	15,143	2,498	20,556	99,104	119,660
1982	3,469	15,602	2,490	21,561	102,589	124,150
1983	3,638	15,662	2,315	21,615	110,961	132,576
1984	4,480	15,679	2,182	22,341	116,241	138,582

Table 4–4 Transmission and Distribution Lines

)

4.4 Present Status of Power Demand and Supply

The total electricity generation in Turkey was 30,614 GWh as of 1984, which was about 2.3 times the amount in a decade before. The average annual growth rate is 8.6%. The past trend in the electricity generation is given in Table 4-5.

The trend in the ratio of hydroelectric power in the total energy generation is illustrated in Fig. 4-3. The ratio of hydroelectric power grew steadily since 1973, and recorded 46% as of 1984.

The past trends in the maximum load of each month are given in Table 4-6. The annual maximum load was normally observed in December. Since 1978, however, the yearly maximum sometimes occurred in months other than December, the peak month being November in 1978 and 1980, and September in 1983. The reason for this may be that the supply shortage became serious from 1978, and the load in December was suppressed due to load restrictions enforced.

The annual average growth rate of the peak demand in the past ten years is 8.1%, being at a similar level as the energy growth.

A typical daily load curve is presented in Fig. 4-4. The yearly trends of the power demand and supply in TEK's power system is presented in Table 4-7. The ratio of different energy sources in the supply power in meeting the peak load, and the status of power shortage are given in Table 4-8. The ratio is different energy sources in annual generations from 1981 to 1984 are given in Table 4-9.

The analysis of the power demand and supply balance in 1984 in the TEK power system indicates that the proportion of the imported electricity was 9.9% - Bulgaria accounting for 7.4% and U.S.S.R. 2.5%. The purchase of electricity by TEK from other companies account for 1.1% of the total. The rate of transmission loss of 5.9% is a universal level.

Regarding the proportion of source of power for the peak load, the weight of hydroelectric power was 53.6% in 1984, and contribution of the dam type hydroelectric power plants were remarkable. The imported power also accounts for 5% of the peak supply.




Fig. 4-2 Percentage of Hydraulic Power Plants in Total Installed Capacity




Fig. 4–3 Percentage of Hydraulic Energy in Gross Energy Generated




Fig. 4-4 Typical Daily Demand Curve

Table 4--5 Gross Energy Generated

6,936 7,838 8,623 9,781 11,242 2,815 3,011 3,560 3,983 4,451 5,551 6,217 $\begin{array}{c} 12,425\\ 13,477\\ 15,623\\ 18,283\\ 18,283\\ 20,565\end{array}$ 21,726 22,522 23,275 24,673 26,552 27,347 30,614 Total Gub Unit: Hydraulid 2,603 3,356 5,904 8,375 8,593 9,365 10,304 11,348 12,616 14,167 11,249 11,249 13,967 1,001 1,265 1,124 2,104 1,648 2,179 2,338 2,338 2,382 3,175 3,445 3,445 3,033 2,610 3,204 Total Thermal 1,814 1,746 2,436 9,822 9,719 9,719 9,908 11,972 1,879 2,803 2,774 3,213 3,835 3,761 4,393 5,590 7,171 8,038 12,361 12,215 11,927 12,057 12,385 15,998 15,998 $\begin{matrix} 1,394\\ 1,764\\ 1,829\\ 2,034\\ 1,977\end{matrix}$ 3,754 3,588 3,588 3,588 3,588 3,588 3,588 3,588 3,588 3,588 l,144 1,040 1,471 1,916 2,248 2,350 1,979 2,118 2,167 2,288 2,778 2,778 3,328 3,328 Total Furnished by Others Hydraulid 250 268 315 I,300 I,170 I,315 I,491 I,491 I,202 I,202 I,707 364 412 567 595 640 696 675 913 913 568 752 1,260 1,175 1,160 Thermal 894 772 1,156 1,599 1,536 1,518 1,654 2,168 1,030 1,352 1,332 1,467 1,382 1,276 1,552 1,552 1,552 1,251 1,205 2,454 2,454 2,545 2,594 2,129 2,129 2,221 2,221 10,258 11,189 12,845 15,454 17,237 17,968 18,934 19,415 20,588 23,243 23,689 26,686 2,589 2,687 3,124 3,517 4,240 5,020 5,590 6,273 7,802 9,124 Total 1,671 1,971 2,089 Furnished by TEK Hydraulid 2,535 2,749 2,358 1,912 2,291 2,035 2,604 4,644 7,200 7,433 8,061 9,134 10,033 11,125 11,125 12,987 10,147 12,260 751 997 809 1,740 1,236 1,682 1,682 1,771 1,771 Thermal 920 974 1,280 849 1,451 1,442 1,746 2,453 2,485 2,841 3,915 5,890 6,833 9,907 9,800 9,382 9,463 9,463 10,256 113,542 14,426 8,223 8,585 8,201 8,201 9,804 9,804 1968 1969 1970 1971 1971 Year 1960 1961 1962 1963 1964 1965 1966 1967 1973 1974 1975 1975 1977 1978 1979 1980 1981 1982 1982 1983 1984

Unit: MW

Table 4-6 Monthly Maximum Demand

pr.MayJun.Jul.Aug.Sep.Oct.Nov.Dec.77677176381486390892889389779779779639871,0181,0271,0589889779779639871,1251,1781,2851,2871081,1021,0911,0981,1121,1781,2851,5021,5032641,4671,4671,2561,2561,2561,5271,9041,9575041,4661,4671,2581,1221,9141,9241,9741,9575831,6961,6451,6681,6681,5021,5211,9041,9511,9745831,6961,4671,5281,5211,5211,9241,9332,7823212,0372,0342,0342,3422,4842,7332,7823212,2682,0592,0342,3422,4842,5032,7332,7823212,2682,0482,0362,3422,4842,5032,7823,5643,5643212,2682,0482,0592,1863,4853,4963,5493,5643,5913212,2682,0542,1863,4853,4842,5502,7933,5643,56432403,2483,4853,4853,4853,5493,5643,5643,56432412,5693,4853,5483,
May Jun. Jul. Aug. Sep. Oct. 771 763 737 763 814 863 1 977 977 977 963 987 1,018 1 1 977 977 977 963 987 1,054 1,145 1 1,102 1,091 1,098 1,112 1,178 1,264 1,145 1 1,256 1,266 1,263 1,521 1,521 1,642 1 1,466 1,467 1,467 1,468 1,914 1,926 1 1,466 1,467 1,468 1,521 1,642 1 1,422 1,466 1,467 1,468 1,521 1,926 2 2,550 2 2,550 2 2,550 2 2,550 2 2,550 2 2 2,569 3 3,567 3,526 3,250 3,526 3,526 3,526 3,526 3,526 3,547
May Jun. Jul. Jul. Jul. Sep. 771 763 737 763 814 1 977 977 973 840 843 944 1 977 977 963 787 1,054 1 178 1 1,102 1,091 1,093 1,112 1,178 1 178 1 1,256 1,256 1,256 1,258 1,357 1 178 1 1,696 1,645 1,668 1,687 1,747 1
May Jun. Jul. Jul. Jul. Aug. 771 763 737 763 737 763 977 977 977 963 1,112 1 1,102 1,091 1,098 1,112 1 1,256 1,256 1,260 1,258 1 1,696 1,467 1,478 1,502 1 1,696 1,645 1,648 1,502 1 1,696 1,645 1,648 1,502 1 1,696 1,645 1,648 1,502 1 1,696 1,645 1,668 1,502 1 2,037 2,034 2,034 2,078 2 349 3 2,709 2,712 2,759 2,342 3,485 3 3,485 3
May Jun. Jul. Jul. Jul. Aug 771 763 737 76 895 873 840 84 977 977 977 963 11 1,102 1,091 1,098 1,11 1,250 1,256 1,467 1,478 1,53 1,696 1,645 1,668 1,63 1,63 1,696 1,645 1,668 1,53 3,34 2,037 2,059 2,034 2,34 3,34 2,709 2,712 2,759 2,85 3,48 3,43 3,226 3,186 3,186 3,18 3,43 3,43 3,433 3,448 3,436 3,43 3,43 3,549 3,549 3,549 3,43 3,43 3,549 3,549 3,549 3,451 4,51 4,564 4,542 4,542 4,51 5,029 5,16
May Jun. Jun. Jun. 771 763 7 895 873 8 977 977 977 977 977 977 1,102 1,091 1,0 1,250 1,256 1,2 1,696 1,645 1,6 1,696 1,645 1,6 1,696 1,645 1,6 2,037 2,059 2,1 2,709 2,712 2,7 3,443 3,448 3,448 3,549 3,549 3,6 3,549 3,549 3,6 3,549 3,549 3,6 3,549 3,549 3,6 3,549 3,549 3,6 4,564 4,542 4,4 5,000 4,954 5,0
May 771 895 1,102 1,250 1,250 1,256 1,266
Mag Way 0,00,135,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0,0
· vu sss4u 44400 9000000
APr. APr. 2721 44,1988 44,1989 44,19600 44,19600 44,19600 44,196000000000000000000000000000000000000
Mar. 806 916 1,014 1,122 1,272
Feb. 791 791 909 1,147 1,292 1,292 1,503 1,713 1,713 1,713 1,713 1,713 2,864 2,891 2,284 3,305 3,305 3,305 3,305 3,305 4,697 4,697 4,831
Jan. 790 903 1,170 1,296 1,296 1,758 1,758 1,758 1,758 2,352 2,352 2,352 3,594 3,586 3,594 3,586 3,594 4,080 4,615
Year 1966 1966 1966 1969 1970 1972 1974 1975 1976 1978 1978 1978 1978 1978 1978 1978 1978

.

Table 4-7 TEK's Energy Balance

`)

1,577 (5.9) 1,632 25,054 2,948 28,002 26,425 26,686 1984 1,556 (6.6) 1,463 2,484 22,226 24,710 23,154 23,689 1983 1,410 (6.1) 22,516 23,243 1,895 23,926 1,212 22,031 1982 1,160 (5.6) 1,099 1,752 21,241 19,489 20,081 20,588 1981 1,200 (6.1) 1,074 19,415 1,484 18,341 19,824 18,624 1980 1,033 (5,4) 17,817 1,117 1,172 17,956 19,934 18,989 61979 923 (5,2) 1,060 17,820 912 16,908 17,968 16,897 1978 841 (4.9) 16,245 16,213 985 17,054 17,230 809 1977 Energy Supplied to the Network (GWh) Energy Purchased (GWh) Gross Generation (GWh) Power Plant Internal Consumption (GWh) Net Generation (GWh) Network Loss (GWh) (%) Energy Sold (GWh) Year

	1982		198	33	1984			
	(MW)	(%)	(MW)	(%)	(MW)	(%)		
Power Plants with dam	2,291.0	50.8	1,886.0	39.8	2,694.0	49.4		
Rivers	208.5	4.6	238.0	5.0	232.0	4.2		
Fuel-Oil	771.4	17.1	723.4	15.3	799.1	14.6		
Stone-coal	117.2	2.6	64.8	1.4	92.1	1.7		
Lignite	698.4	15.5	1,271.4	26.8	1,361.6	25.0		
Diesel-Oil	176.1	3.9	189.1	4.0	3.0	0.1		
Supplied from Bulgaria from U.S.S.R.	200.0 50.0	4.4 1.1	250.0 108.0	5.3 2.3	205.0 70.0	3.7		
TOTAL	4,512.6	100.0	4,730.7	100.0	5,456.8	100.0		
Total Peak without interruption	5,001.5		5,333.1		5,456.8			
Interruption and Rstriction imposed	488.9	(9.8)	602.4	(11.3)	0			
Date	December 1982, Wec at 18.35	Inesday	September 1983, Wec at 20.50	lnesday	December 15th. 1984, Wednesday at 17.30 p.m.			

Table 4-8 Meeting of the Peak

Year	1981		1982		1983		1984	
	GWh	×	GWh	x	GWh	%	GWh	%
Thermal Power Plants	12,057	48.9	12,385	46.6	<u>16,004</u>	58.5	17,187	56.1
Coal Lignite Oil Others Gas. Tur. Diesel Geothermal	892 5,244 5,196 725	3.6 21.3 21.1 2.9	913 6.011 4,823 638	3.4 22.6 18.2 2.4	787 7,790 6,348 1,079	2.9 28.5 23.2 3.9	705 9,413 6,711 358	2.3 30.7 21.9 1.2
Hydraulic Power Plants	12,616	51.1	14,167	53.4	11,343	41.5	13,427	43.9
Total	24,673	100.0	26,552	100.0	27,347	100.0	30,614	100.0

Table 4-9 Distribution of Electrical Energy Generated

CHAPTER 5 ELECTRIC POWER DEMAND AND SUPPLY FORECAST

)

CONTENTS

.

		•	Page
5.1	Electri	c Power Demand Forecast	5 – 1
	5.1.1	Power Demand Forecast Conducted by TEK	5 – 1
	5.1.2	Electric Power Demand Forecast	
		by Macroscopic Method	5 – 5
	5.1,3	Comparison of Results of Forecasts	5 – 12
5.2	Power	Supply Program	5 – 12
	5.2.1	Electric Power Development Plan	5 – 12
•	5.2.2	Demand and Supply Balance	5 - 20

List of Figures

Fig. 5-1 Correlation between per Capita GNP and Growth Rate

Fig. 5-2 Correlation between per Capita GNP and per Capita Energy

- Fig. 5–3 Comparison of Demand Forecasts: Energy
- Fig. 5-4 Ratio of Hydraulic Power Plants in Total Installed Capacity (Forecast)
- Fig. 5–5 Utilization of the Hydroelectric Potential of Turkey
- Fig. 5–6 Demand Forecast: Power

 \bigcirc

)

Fig. 5–7 Demand Forecast: Energy

List of Tables

Table 5-1Results of Demand Forecast by TEKTable 5-2Average Growth Rate of Energy Generation

Table 5-3Energy Generation per Capita

Table 5-4 Basic Data for Demand Forecast

Table 5-5 Results of Demand Forecast by Macro-Method

Table 5-6 Comparison of Demand Forecasts

Table 5-7 Construction Schedule of Power Plant in Turkey

Table 5-8 Schedule of Energy Generation

 Table 5-9
 Major Hydraulic Power Plants under Construction

Table 5-10 Power Demand and Supply Balance

Table 5–11 Estimated Energy Balance

CHAPTER 5. ELECTRIC POWER DEMAND AND SUPPLY FORECAST

5.1 Electric Power Demand Forecast

This chapter is devoted to the outline of demand forecast performed by TEK, the long term demand forecast by the macroscopic method prepared by the JICA team, and a comparison of the results of these forecasts.

The Yusufeli Project is scheduled to commence operation around the year 2000, and as the long term demand forecast was prepared up to the year 2008, the trend of power demand in the period around the commissioning of this project can be studied.

5.1.1 Power Demand Forecast Conducted by TEK

TEK's method of electric power demand forecast is as described below.

The period of demand forecast is divided into two periods. For the first period, forecast by category of demand, in which the consumers (factories, shops, general residence, etc.) are surveyed concerning their production plans, trend of consumption, behavior of consumption, etc., and the survey results are converted to electric demands, and such demands are added to the predicted total demand. For the second period, the macroscopic method is used. The past records of total power generation (from 1970 to 1982) and the forecast values for the first period are taken as the basis, and the prediction is made by means of the correlation between the power demand and the macroscopic indices such as population growth rate and GNP per capita growth rate.

The following calculation conditions have been used.

- (1) Period of forecast: 22 years (from 1984 to 2005)
- (2) Reference year: 1983
- (3) Population growth rate: 2.1%
- (4) Growth rate of GNP per capita: 5.55% p.a.
- (5) Forecast of maximum demand:

The load factor is assumed as 64% based on past record. The maximum demand in each year is calculated by the following equation.

 $P_{max} = E_g / (L_f \times 365 \times 24) \quad (MW)$ where: P_{max} ; maximum demand (MW) E_g ; total annual generation (MWh) L_f ; load factor (=0.64)

The result of demand forecast conducted by TEK is presented in Table 5-1. The average growth rates of annual generation for each five years are given in Table 5-2.

In the demand forecast method of TEK, the first period is defined only for the very near future (3 to 5 years), and this method can be regarded as a combination of microscopic and macroscopic methods when it is applied to a long range forecast.

As indicated in Table 5-2, the demand growth rate dropped sharply in the period from 1978 to 1983 due to the economic recession caused by the oil crisis. Later, the annual growth rate revived to more than 10% reflecting the recovery in economic activities.

The forecast projects that the total annual generation in the year 2003 will be approximately 206,000 GWh, and the per capita electricity consumption will amount to 2,895 kWh.

The trend of per capita electricity consumption for the period of forecasting is presented in Table 5-3.

Year	Gross Energy Generated (GWh)	Maximum Demand (MW)
1984	33,175	5,790
1985	36,850	6,570
1986	41,000	7,300
1987	45,800	8,170
1988	51,200	9,130
1989	57,050	10,180
1990	63,300	11,290
1991	70,000	12,480
1992	77,200	13,770
1993	84,950	15,150
1994	93,300	16,640
1995	102,450	18,270
1996	112,550	20,100
1997	123,600	22,045
1998	135,800	24,220
1999	148,800	26,540
2000	162,600	29,000
2001	177,130	31,000
2002	189,822	33,100
2003	205,958	35,400
2004	223,232	37,900
2005	239,938	40,500

Table 5-1 Results of Demand Forecast by TEK

)

· · · · · · · · · · · · · · · · · · ·	
Period (Year)	Growth Rate (%)
1963 - 1968	11.7
1968 - 1973	12.4
1973 - 1978	12.5
1978 - 1983	5.8
<u> 1963 - 1983</u>	10.6
1983 - 1988	11.3
1988 - 1993	10.7
1993 - 1998	9.8
1998 - 2003	8.7
<u> 1983 - 2003</u>	<u>10.1</u>

Table 5-2 Average Growth Rate of Energy Generation

Table 5-3 Energy Generation per Capita

Planned Period	Energy Generation (GWh)	Population	kWh	Growth Rate (%)
End of 1988	51,200	52,370	978	9.2
End of 1993	84,950	58,000	1,465	8.4
End of 1998	135,800	64,240	2,114	7.6
End of 2003	205,958	71,150	2,895	6.5

5.1.2 Electric Power Demand Forecast by Macroscopic Method

Several methodology of electric power demand forecasting are in practical use, including; (1) the method utilizing past trend, (2) the cross section method, (3) the forecasting by demand category method, and (4) the method utilizing correlations with economic indices such as GNP. The methods from (1) to (3) can be regarded as empirical methodology. All methods except the forecasting by demand category method are macroscopic in nature.

In this study, the demand forecast has been conducted based on a method utilizing the correlation between the electric power demand and GNP.

(1) Demand Forecast Based on GNP

It has been statistically proven that strong correlations exist between the energy or electric power demand and economic indices.

In particular, if the relation between the per capita GNP and the per capita electricity consumption is studied, a strong correlation can be found which is expressed by an approximation equation. Thus the power demand forecasting is very often performed by utilizing this correlation.

The following indices and basic conditions were used in the demand forecast of this study.

(a) Criteria and Statistical Indices

"New Method of Long Range or Very Long Range Demand Forecast of Energy Including Electricity Viewed from Worldwide Standpoint: Edited by EPDC"

(b) Period of Forecast; 25 years (from 1984 to 2008)

Although Yusufeli and Artvin Projects are to commence operation in 1997 according to the Master Plan, the actual year of commissioning is estimated to be around 2000 according to the studies made this time. One of the objectives of the power demand forecast is to determine the time of commissioning a project, and a sufficient time band in the demand forecast is required in determining the start of operation. For this reason, the forecast was made for 25 years from 1984, or up to the year 2008.

(c) Calculation condition

i) Reference year; 1983

ii) Per capita GNP (1968 value); US\$540

The gross national products in the reference year (1983) divided by the population of that year was converted to the value of the reference year for the economic indices.

GNP in 1983; US $$25,653 \times 10^6$ Population in 1983; 47,279 x 10^3

Based on these statistics, the GNP per capita was calculated as US\$540.

iii)

Growth rate of GNP per capita; 4.0%

The growth rate of GNP per capita had been 4.2% for the 15 years before the oil crisis (1962 to 1977). (See Table 5-4.)

Even including the low growth rates that were caused by the oil crisis, the average growth rate for the 22 years including the period after the oil crisis (from 1962 to 1984) remains at 3.0%.

The general status of economy of Turkey is recovering from the recession that have continued from 1977. This tendency is indicated by the GNP growth rate of 3.7% in 1984.

Thus it was assumed that the oil crisis and the economic recession that followed is a temporary phenomenon, and the long term growth rate was assumed as 4.0%.

iv) Per capita electricity consumption; 630 kWh (in 1983)

The value 630 kWh was obtained by dividing the total electricity consumption of 29,658 GWh in the reference year (1983) with the population of 47,279 x 10^3 .

v) Population; 47,279,000 (in 1983)

The total population of 47,279,000 in the reference year of 1983 was taken from "The Turkish Economy, '84".

vi) Population growth rate; 2.1%


The population growth rate in Turkey was at a level of 2.5% in the period before 1977. Thereafter the growth rate tended to decrease, being 2.1% in the 7 years from 1977 to 1984. (See Table 5-4.) The growth rate of 2.1% recorded in the recent period was taken as the basis of this study.

The correlation between the per capita GNP and its growth rate was obtained from the data in Fig. 5-1, and the correlation between the per capita GNP and per capita electricity consumption is based on the data in Fig. 5-2.

(2) Result of Forecast

The forecast values of total annual generation calculated based on data of Table 5-4, Fig. 5-1 and Fig. 5-2 are presented in Table 5-5.

The forecast of the maximum demand was obtained by equation (5) in 5.1.1, based on the total generation obtained above and on the 64% load factor projected by TEK.



Growth Rate (%)






Table 5-4 Basic Data for Demand Forecast

	GNP ((Constant Price	e in 1968)	Energy Generated	inerated	Population		Per	Capita	
		4 1	Growth		Growth		9	NР	Energy (Generated
	(pillion)) =	Rate	GWh	Rate	(Lhousand)	15 \$ US	Growth Rate	kWh	Growth Rate
			(%)		(%)			(%)		(%)
1962	76.8	8,496	6.2		18.2	28,933	290		120	
1963	84.2	9,314	9,6	3, 983	11.9	29,655	310	6.9	130	8.3
1964	87.6	9,690	4.0	4,451	11.7	30, 394	320	3.2	150	15.4
1965	90.4	10,000	3.2	4,953	11.3	31, 391	320	0	160	6.7
1966	101.2	11, 194	11.9	5, 551	12.1	31,934	350	9.4	170	6.3
1967	105.5	11, 670	4 3	6,217	12.0	32, 750	360	2.9	061	-1.8
										0
Average			6.6		11.8	(2.5)		4.4		9 8
1968	112.5	12.444	6.6	6,936	11.6	33,585	370	2.8	21.0	10.5
1969	118.6	13, 119	5.4	7, 938	13.0	34,442	380	2.7	230	9,5
1970	125.4	13,872	5.7	8,623	10.0	35, 605	390	2 6	240	4.3
1971	138.2	15,288	10.2	9,781	13.4	36, 215	420	2.2	270	12.5
1972	148.5	16,420	74	11, 242	14.9	37, 132	440	4.7	300	111
									-	
Averoge			1 2		12.6	(2.2)		4.1		9.6
0/0		11,312	10.4	12,425	0.0	38,072	450		022	
4/6-	200	18, 384		13.47		33,056		0.0	200	
1975	191	090	6.0	15,623	6.01	40, 548	200	2.4	590	4
9/6	0 1 0 1	21,039		10, 203		40,910		0.0	00 0 1 1 0 0	
	203.4	002,22	0.0	50,05	0.2	41.(00			1420	α'n
Average			6.5		12.8	(2.4)		4.2		10.3
1978	2.09.2	23 142	6 2	21 726	56	42.640	540	C	510	4
6261	208.3	23.042	- 0.4	22.522	2.2	43 530	530		520	0.2
1 980	206.1	22, 799	-	23, 275	3.3	44, 737	510	- 3.9	520	0
1981	214.7	23,750	4.2	24,673	6.0	45,366	520	2.0	540	3.8
1982	224.5	24,834	4.6	26,552	7.6	46, 312	540	3.8	570	5.6
Average			2.0		2	(2.1)		0		3.1
F 9 P 1		75 653	L.	27347	0 E	47 279	540	С	580	
1984	245.5	27.157	6.3	30,614	6.11	48,265	560	3.7	630	8.6
Average		· · ·	4.6		7.3	(2 . 1)		1.8		5.1
										 .

A STATE

			pita GNP	Per Cap	pita kWh		Gro		Maximum
		Growth	US\$		Growth	Population	Energy G	enerated	Demand
1.	Year	Rate	(1968	kWh	Rate	(10^3)	GWh	Growth	. · .
	<u></u>	(%)	Price)		(%)			Rate(%)	(MW)
Ľ	1983	4.0	540	630	3.9	47,279	29,568		4,731
	1984	4.05	562	670		48,270	32,300		5,800
	1985	4.05	585	720		49,280	35,500		6,300
	1986	4,05	609	770	1	50,310	38,800		6,900
	1987	4.2	635	830	1 -	51,370	42,690		7,600
	1988	4.2	662	890		52,450	46,700		8,300
ŀ	1.1							. (
A	verage	4•1:			7.2	(2.1)		9.6	
	1989	4.2	690	960		53,550	51,400		9,200
	1990	4.2	719	1,010		54,670	55,200	ļ	9,800
	1991	4.3	740	1,040		55,800	58,000		10,300
	1992	4.3	782	1,130		57,000	64,700		11,500
	1993	4.3	816	1,215		58,200	70,700		12,600
	·. ·								
A	verage	4.25			6.4	(2.1)		8.6	
	1994	4.3	851	1,295		59,400	76,900		13,700
	1995	4.3	888	1,380	-	60,650	83,700	•	14,900
	1996	4.3	926	1,470		61,920	91,000		16,200
r	1997	4.35	966	1,540	(63,220	97,400		17,400
	1998	4.35	1,008	1,630		64,550	105,200		18,800
A	verage	4.3			6.1	(2.1)		8.3	
	1999	4.3	1,051	1.730		65,910	114,000		20,300
	2000	4.3	1,096	1,840		67,290	123,800		22,100
	2001	4.3	1,143	1,940	ł	68,700	133,300	\$ {	23,800
	2002	4.3	1,192	2,050	1	70,140	143,800	1 1	25,700
	2003	4.3	1,243	2,170	А	71,610	155,400		27,700
A	verage	4.3			5.9	(2.1)		8.1	
	2004	4.2	1,295	2,290		73,110	167,400		29,900
	2005	4.2	1,349	2,420	1	74,650	180,700]	32,200
	2005	4.2	1,406	2,550		76,220	194,400	· ·	34,700
	2008	4.1	1,400	2,710	1	77,820	210,900		37,600
	2007	4.1	1,404	2,850	1	79,450	226,400	\	40,400
	2000		1,024	2,050		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	440,400		
A	verage	4.15			5.6	(2.1)		7.8	

Table 5-5 Results of Demand Forecast by Macro-Method

ı.

1/ Including imported energy of 2,221 GWh

5.1.3 Comparison of Results of Forecasts

The power demand forecast obtained by the macroscopic method and that prepared by TEK are compared and given in Table 5-6 and Fig. 5-3.

The values of annual total generation obtained by the macroscopic method are lower than TEK's forecast, the difference being 22.5% in 1988.

In terms of annual growth rate of demand, however, the difference between the two forecasts is small. The average annual growth rate for a period of 22 years up to 2005 is 9.9% according to TEK's forecast, and 8.6% according to the macroscopic method.

This difference is based on the growth rate of per capita GNP adopted in the forecast. This value is 5.55% in TEK's forecast, and 4.0% in the macroscopic forecast conducted in this study.

5.2 Power Supply Program

This chapter pertains to the electric power development plan for economic development and economic operation of power facilities which are required to secure stable power supply meeting the demand projected in the above forecast, and the analysis of electric power demand and supply balance.

5.2.1 Electric Power Development Plan

It is estimated at present that the hydroelectric power potential that can be economically developed in Turkey amounts to 30,800 MW, which will provide firm energy of 72,500 GWh annually and annual generation of 102,500 GWh. As of 1984, only about 13% of this hydroelectric potantial has been developed.

The electric power development plan formulated for the period from 1985 to 2003 is given in Table 5-7 and Table 5-8. This plan is based on the plans formulated by DSI and TEK, and the original plans were modified to some extent so that it is compatible to the power demand forecast obtained by the macroscopic method. According to this plan, the total installed capacity in the year 2000 will become 3.9 times the present value, amounting to 33,038 MW.

The firm generation will also be 3.9 times, and will be 132,923 GWh annually.

In the development program, a number of lignite-fired thermal power plants, typically represented by Elbistan Thermal Power Plant, will be developed in succession until the end of the 1990's. The first nuclear power plant will be completed in mid-1990's, and the thereafter the weight of development programs will be shifted toward the nuclear power.

Large hydroelectric projects, typically represented by Altinkaya and Karakaya will be completed around 1990. Thereafter large hydroelectric projects, such as Ataturk, Kayraktepe and Boyabat will be implemented in the period from early 1990's to the late 1990's.

The details of this electric power development plan is presented in Table.AP.1-1 in Appendix 1.

In 2000, the hydroelectric power will account for approximately 55% of the total installed capacity. The trend of this proportion is presented in Fig. 5-4.

As indicated in Fig. 5-5, the degree of utilization of the hydroelectric potential of Turkey will advance year by year. By year 2000, 61.5% of the hydroelectric resources available will be utilized, and the hydroelectric power will substantially contribute to the power supply of Turkey as valuable indigenous energy resource. The hydroelectric power plants now under construction are listed in Table 5-9.




Fig. 5-3 Comparison of Demand Forecasts: Energy





Fig. 5-4 Ratio of Hydraulic Power Plants in Total Installed Capacity (Forecast)





	By T	ЕК	By Macro	-method	Differ	ence
Period (Year)	GWh :	Growth	GWh :	Growth	(c)	%
(Ical)	(a)	Rate (%)	(b)	Rate (%)	(a)-(b)	(c)/(a)
End of 1983	$\frac{1}{30,000}$	6.1	$\frac{2}{29,568}$	5.8	432	1.4
End of 1988	51,200	11.3	46,700	9.6	4,500	8.8
End of 1993	84,950	10.7	70,700	8.6	14,250	16.8
End of 1998	135,800	9.8	105,200	8.3	30,600	22.5
End of 2003	205,958	8.7	155,400	8.1	50,558	24.5
End of 2005	239,938	7.9	180,700	7.8	59,238	24.7
1983 - 2005		9.9		8.6		

Table 5--6 Comparison of Demand Forecasts

 $\underline{1}/$ Estimated by JICA Team

2/ Actural record

Table 5-7 Construction Schedule of Power Plant in Tuekey

(Unit: MW)	apacity	Tota	(1) + (4)	5,778	6_118 6_118	7,138	7,965	8,520	8,934	9,677	9,946	10,624	11,770	12,761	13,546	14,632	16,114	17,323	18,68F	20,132	21,695	23,208	24,864			
)	Continuous Capacity	Hydraulic	(#)	1,194	1,194	1,204	1,731	2,136	2,200	2,223	2,292	2,470	3,016	3,407	3,592	3,678	3,840	4,149	4,607	5,158	5,421	5,934	6,490		l	
	Capacity	Tota	(1) + (3)	6,205	6.545	7,571	8,444	9,139	9,625	10,403	10,713	•	12,766	•	•	•	•	•	•	•	•	ົ	27,703		1	
	Average C	Hydraulic	(3)	1,621	1.621	1,637	2,210	2,755	2,891	2,949	3,059	3,388	4,012	4,511	4,785	4,926	5,178	5,703	6,395	7,191	7,628	8,433	9,329		I	
		Tot.	+(7) + (7)	8,459		9,839	-	d.	-	14,506	15,033	16,555	18,130	19,840	21,371	23,161	25,221	27,068	29,968	33,038	35,397	38,392	42,254		ş	
	ity	ulic	(7) TOTAT	3,875	3.875	3,905	4,855	6,006	6,396	7,052	7,379	8,401	9,376	10,486	11,417	12,207	12,947	13,894	15,894	18,064	19,123	21,118	23,880		Ī	
	Installed Capac	Hydra	JUET A MON		1 1 1 1 1 1 1 1	30	950	1,151	390	656	327	1,022	975	1,110	166	062	740	647	2,000	2,170	1,059	1,995	2,762		20,005	
	Ins	Thermal		4,584	4.924	5,934	6,234	6,384	6,734	7,454	•	1	8,754	•	9,954	10,954	12,274	13,174	14,074	14,974	16,274	17,274	18,374		1	
		10	New Flant	<u>8</u>	340	1,010	300	150	350	720	200	500	600	600	009	I,000	1,320	006	006	006	1,300	1,000	1,100		13,790	
		Year		Existing	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998	6661	2000	2001	2002	2003		Total (Addit-	TODAL/
												5	17			- - -			•		·					

					(Unit : GWh)
	[By Hyd	raulic	Tot	and the second
Year	By Thermal: (1)	Firm: (2)	Average: (3)	Firm : (1)+(2)	Average : (1)+(3)
Existing	23,420	10,460	14,200	33,880	37,620
1985	25,370	10,460	14,200	35,830	39,570
1986	31,250	10,544	14,342	41,792	45,592
1987	33,050	15,161	19,358	48,211	52,408
1988	33,950	18,714	24,132	52,664	58,082
1989	36,050	19,272	25,326	55,322	61,376
1990	40,370	19,473	25.,837	59,843	66,207
1991	41,570	20,076	26,799	61,646	68,369
1992	44,720	21,635	29,683	66,355	74,403
1993	48,620	26,423	35,146	75,043	83,766
1994	52,220	29,848	39,514	82,068	91,734
1995	56,120	31,462	41,919	87,582	98,039
1996	62,120	32,217	43,151	94,337	105,271
1997	70,340	33,639	45,359	103,979	115,699
1998	76,190	36,346	49,955	112,536	126,145
1999	82,040	40,358	56,021	122,398	138,061
2000	87,740	45,183	62,997	132,923	150,737
2001	95,690	47,488	66,824	143,178	162,514
2002	101,690	51,980	73,872	153,670	175,562
2003	108,290	56,849	81,726	165,139	190,016
Total (Additional)	84,870	46,389	67,526	131,259	152,396

Table 5-8 Schedule of Energy Generation

	Installed	Energy Gene	rated (GWh)	Year of
Project	Capacity (MW)	Average	Firm	Commissioning
Adiguze1	61	280	150	1986
Kilickaya	120	332	277	1986
Karakaya	1,800	7,354	6,800	1989
Catalan	156	491	271	1990
Karacaoren	32	142	84	1986
Gezende	150	528	130	1988
Altinkaya	700	1,632	1,236	1988
Menzelet	120	334	192	1987
Ataturk	2,400	8,900	7,400	1991
Kralkizi	90	140	111	1991

Table 5--9 Major Hydraulic Power Plants under Construction

· .

.

an de la companya de Reference de la companya de la compa Reference de la companya de la compa

5–19

5.2.2 Demand and Supply Balance

The balance of demand and supply was evaluated for both kW and kWh based on the demand obtained by the forecast described above.

In evaluating the kW balance, it was checked if sufficient supply capacity is secured for the peak load in the dry season, and in the summer and winter peak periods.

In this evaluation, it is required to assume the daily load curves for the years around the time of commissioning of Yusufeli Project. These daily load curves were formulated based on the typical load curves in the past and present, and on the total maximum demand obtained by the forecast, and it was checked if the sufficient supply capacity can be secured. In assuming the load curve, the load characteristics in the past had to be analyzed.

The following factors were taken into consideration in the analysis.

- * Monthly electricity demands in the past, maximum demand of each month, annual electricity demand, and annual load factor.
- * Typical daily load curves in each month in the past, and the daily load factor.

* Wet season and dry season in Turkey

The kWh balance was checked in terms of the annual total kWh demand and the kWh demand in the most dry month.

In checking the adequacy of the supply capability, it was studied whether the supply capability of both hydro and thermal plants are sufficient for the maximum demand obtained by the forecast in each year.

In estimating the supply capability of the thermal power plants, the reduction of output of old thermal power plants, the rate of decommissioning, the rate of faults and repair shutdowns were taken into consideration.

In estimating the hydroelectric power supply, the fault and repair shutdown rates were considered as in the case of thermal plants. At

the same time, the firm power in the most dry year was estimated to calculate the supply capability to be secured by hydro power.

The conditions assumed in calculating the supply capability are presented below.

* Thermal Power

Output reduction and decommissioning rate:

It was assumed that the present plant capacity is reduced at the rate of 5% per year.

Fault and repair shutdown rate: 7.3%/year

* Hydro Power

Fault shutdown rate: 0.5%Repair shutdown rate: $2\% \times 1/12$ months

The results of the studies discussed above are summarized in Table 5-10 and Table 5-11 in the form of kW and kWh balances up to the year 2003. The demand and supply balance trends are presented as charts in Fig. 5-6 and Fig. 5-7.


As indicated by these tables and charts, sufficient supply capability satisfying the demand can be secured in terms of both firm output and firm generation. However, the present status is such that electric power amounting to 8% of the total consumption is being imported as of 1984. This is due to the low availability of the generating facilities in Turkey which, in combination with problems in the power system and load dispatching operations, creates supply shortage.

Considering this situation, it is concluded that prompt implementation of the established power development projects is indispensable, and it is expected that the stable balance in power demand and supply will gradually be secured after 1989.

It is estimated that Yusufeli and Artvin Power Plants will commence services around the year 2000. The additional supply capability of 540 MW and 320 MW provided by these Project at that time means that an about 7.8% supply margin will be created for the total demand.

An about 7.4% margin will also be created in terms of the firm electricity supply.

Thus it can be concluded that the proposed timing of completion of this Project is appropriate in securing proper balance of electric power demand and supply.



Peak Demand and Capacity of Supply Power (MW)




Table 5-10 Power Demand and Supply Balance

(4)/(2) ÷.8 7.6 8.4 11.2 7.4 7.5 8.1 9-1 3.0 6.2 3.7 2.0 6°.1 2.6 1.6 1.5 3.3 2.9 ۍ و Allowance (3) - (2) = (4)539 594 706 868 702 434 268 275 410 278 281 660 610 1,388 2,068 2,490 317 1,977 3,577 (Meg Dependable Capacity (MW) (3) 16,165 20,670 22,230 24,733 29,438 32,045 35,432 8,529 9,446 10,413 11,972 12,279 13,493 14,765 17,413 116,81 27,392 7,784 10,897 Available Power Supplied Continuous (MW) 7,965 17,323 21,695 23,208 6,118 7,138 8,520 8,934 9,946 11,770 14,632 16,114 20,132 24,864 9,677 10,624 13,592 12,761 18,681 Average (MW) 6,545 8,444 9,139 9,625 10,403 10,713 11,542 12,766 13,865 14,739 15,880 17,452 20,469 22,165 27.,703 7,571 18,877 23,902 25,707 Installed Capacity (MW) 42,254 8,799 9,839 13,130 14,506 15,033 18,130 19,840 27,068 29,968 33,038 38,392 11,089 12,390 16,555 35,397 21,371 23,161 25,221 Capacity (MW) (1)x 1.15 =(2) 23,345 7,245 7,935 8,740 9,545 10,580 11,270 11,845 13,225 14,490 15,755 17,135 18,630 20,010 21,620 25,415 27,370 29,555 31,855 Reserve Peak Demand (MW) (1) 11,500 6,900 7,600 8,300 9,200 9,800 16,200 20,300 6,300 10,300 12,600 13,700 14,900 17,400 18,800 22,100 23,800 25,700 27,700 1985 1986 1987 1988 1989 1990 1992 1993 1994 1995 1996 1997 1998 1999 2000 2002 2003 Year 1661 2001 4

	Energy Demand	Auntlahle 8-	ergy Supplied		Allow	20.00	
Year	Estimated :(1)	Firm : (2)	Average :(3)	Fir		Aver	age
	(GWh)	(GWh)	(GWh)	GWh:(4) (2)-(1)	% (4)/(1)	GWh:(5)	% (5)/(1)
1984	32,300	33,880	37,620	1,580	4.9	5,320	16.5
1985	35,500	35,830	39,570	330	0.9	4,070	11.5
1986	38,800	41,794	45,592	2,994	7.7	6,792	17.5
1987	42,600	48,211	52,408	5,611	13.2	9,808	23.0
1988	46,700	52,664	58,082	5,964	12.8	11,382	24.4
1989	51,400	55,322	61,376	3,922	7.6	9,976	19.4
1990	55,200	59,843	66,207	4,643	8.4	11,007	19.9
1991	58,000	61,646	68,369	3,646	. 6.3	10,369	17.9
1992	64,700	66,355	74,403	1,655	2.6	9,703	15.0
1993	70,700	75,043	83,766	4,343	6.1	13,066	18.5
1994	76,900	82 ,068	91,734	5,168	6.7	14,834	19.3
1995	83,700	87,582	98,039	3,882	4.6	14,339	17.1
1996	91,000	94,337.	105,271	3,337	3.7	14,271	15.7
1997	97,400	103,979	115,699	6,579	6,8	18,299	18.8
1998	105,200	112,536	126,145	7,336	7.0	20,945	19,9
1999	114,000	122,398	138,061	8,398	7.4	24,061	21.1
2000	123,800	132,923	150,737	9,123	7.4	26,937	21.8
2001	133,300	143,178	162,514	9,878	7.4	29,214	21.9
2002	143,800	153,670	175,562	9,870	6.9	31,762	22.1
2003	155,400	165,139	190,016	9,739	6.3	34,616	22.3

Table 5-11 Estimated Energy Balance

CHAPTER 6 METEOROLOGY AND HYDROLOGY

CHAPTER 6. METEOROLOGY AND HYDROLOGY

CONTENTS

		Page
6.1	General	6 - 1
6.2	River Runoff	6 - 1
6.3	Evaporation	6 - 14
6.4	Sedimentation	6 37
6.5	Probable Flood	6 - 41
6.6	Probable Maximum Flood	6 - 46

List of Figures

)

Fig. 6-1 Isohyetal Map Fig. 6-2 **Existing Stream Gaging Stations** Fig. 6-3 Seasonal Variation of Precipitation and Runoff Fig. 6-4 **Spectral Analysis** Fig. 6-5 Correlation Analysis between Nos. 2316 and 2305 G.S. Fig. 6-6 Correlation Analysis between Nos. 2321 and 2305 G.S. Fig. 6–7 Correlation Analysis between Nos. 2322 and 2305 G.S. Fig. 6-8 Correlation Analysis between Nos. 2322 and 2315 G.S. Fig. 6–9 Correlation Analysis between Nos. 2315 and 2305 G.S. Correlation Analysis between Nos. 2323 and 2302 G.S. Fig. 6-10 Fig. 6-11 **Existing Class A Pan Evaporation Data** Fig. 6–12 **Relation between Monthly Average Temperatures** and Monthly Evaporation of Bayburt Station Sediment Rating Curve at No. 2315 Station Fig. 6–13 Fig. 6–14 Sediment Rating Curve at No. 2316 Station Fig. 6–15 Flood Frequency at No. 2305 Station Fig. 6–16 Flood Frequency at No. 2323 Station Fig. 6-17 Flood Frequency at No. 2321 Station Fig. 6-18 **Enveloping Curves of Maximum Persisting** 12 hour Vapor Pressure Fig. 6-19 Depth-Duration Curves of Max. Precipitation Fig. 6-20 12hr – 1 cm Unit Hydrograph for Coruh River 12hr – 1 cm Unit Hydrograph for 01tu, Tortum Fig. 6--21 and Altiparmak Creek Fig. 6-22 PMP Hydrograph Fig. 6-23 PMP Hydrograph of Yusufeli Damsite Fig. 6–24 Probable Maximum Floods in Turkey Fig. 6–25 Location Map of Existing and Planned Dams Depths of Precipitable Water in a Column of Air Fig. 6–26

List of Tables

Table 6–1	Monthly Precipitation at Meteorological Station
Table 6-2	Observed Monthly Average Temperatures at Yusufeli Station
Table 6–3	Observed Monthly Average Temperatures at Bayburt Station
Table 6-4	Correlation Analysis of Stream Gaging Station
Table 6-5	Natural Flow Calculation at Damsites
Table 6–6	Natural Flow at Karakale Damsite
Table 6–7	Natural Flow at Yusufeli Damsite
Table 6–8	Natural Flow at Artvin (U) Damsite
Table 6-9	Natural Flow at Artvin (L) Damsite
Table 6-10	Natural Flow at Deriner Damsite
Table 6–11	Natural Flow at Borcka Damsite
Table 6–12	Natural Flow at Muratli Damsite
Table 6-13	Observed Monthly Class A Pan Evaporations of Bayburt Meteorological Station
Table 6-14	Actual Monthly Evaporations from Yusufeli Reservoir
Table 6-15	Existing Suspended Sediment Data
Table 6–16	Characteristics of Sediment Data
Table 6-17	List of Measured Flood Peaks
Table 6-18	Flood Peak Discharges at No. 2305 Station
Table 6-19	Flood Peak Discharges at No. 2323 Station
Table 6-20	Flood Peak Discharges at No. 2321 Station
Table 6-21	Probable Floods at Damsites
Table 6–22	Storm Maximization of Historical Storms
Table 6-23	Time Distribution of PMP
Table 6–24	Maximum Snowmelt Runoff at Yusufeli Damsite
Table 6–25	Probable Maximum Flood of Planned Dams in Turkey

CHAPTER 6. METEOROLOGY AND HYDROLOGY

6.1 General


The Coruh river basin is situated in the northeastern part of Turkey near the boundary between Turkey and the Soviet Union. Average elevation of the basin is approximately 2,000 m. The Coruh river is the longest river in the northeastern part with the length of about 410 km. The Coruh river flows from the Dilek Daglari mountains to the Black Sea. The most downstream 20 km part of the River belongs to the territory of the Soviet Union. The drainage area of the River is 19,750 km² in Turkey. Its mean annual runoff is 5.96 billion cubic meter, or 189 m³/sec at the border.

General climatological characteristics of the Coruh river basin could be classified into Continental and Black Sea climate. Continental climate is predominant over the catchment basin of the Yusufeli dam site with mean annual rainfall of 440 mm. While over the Yusufeli basin rainy season extends from March to June when fifty percent of annual precipitation concentrates, rainy season in the most downstream part of the Coruh river extends from autumn to winter with annual precipitation over 1,000 mm. Maximum, minimum and mean annual temperatures at Yusufeli station are 43.8°C, -14.3°C and 14.2°C respectively.

Locations of meteorological stations and stream gaging stations are given in Fig. 6-1. Isohyetal lines of annual rainfall over the basin are also given in Fig. 6-1. Mean monthly precipitations at stations are shown in Table 6-1. Monthly mean temperatures at Yusefeli and Bayburt stations are shown in Tables 6-2 and 6-3.

6.2 River Runoff

The Yusufeli damsite is located just downstream of Oltu-Tortum and Altiparmak tributaries so as to regulate the river flow including the major tributaries. There are a number of stream gaging stations established in the Coruh river basin as shown in Fig. 6-1, some of which are not in operation. Existing runoff data on the Coruh river including major tributaries are given in Fig. 6-2.



Δ	DMI	PRECIPITATION STATIONS
Δ	DMI	PRECIPITATION AND BALANCE
Δ	DMI	PRECIPITATION AND SYPHON-
4	DMI	PRECIPITATION AND EVAPORA
A	DMI	PRECIPITATION AND TEMPERAT
بھر	0MI	PRECIPITATION, EVAPORATION
്ക്	DMI	PRECIPITATION, EVAPORATION, TERMOHYGROGRAPH STATIONS
<u>_</u>	DMI	PRECIPITATION AND TERMOGR
	DSI	PRECIPITATION STATIONS
*	0SI	PRECIPITATION AND BALANCE.
	DSI	PRECIPITATION AND SYPHON-F
ر≜	ÐSI	PRECIPITATION AND EVAPORAT
٨	0\$I	PRECIPITATION AND TEMPERAT
×	05!	PRECIPITATION, EVAPORATION 4
≽≰	DSI	PRECIPITATION, EVAPORATION, 7 TERMOGRAPH STATIONS
≵≜∡	DSI	PRECIPITATION, EVAPORATION, TERMOHYGROGRAPH STATIONS
.هم	DSI	PRECIPITATION AND TERMOGR4
۲	DSI	PRECIPITATION STATIONS OUT
D	EIE	SNOW GAGING STATIONS
80 آکر	ĜATEPE	:


OSI SNOW GAGING STATIONS \diamond DMI SNOW GAGING STATIONS EIE HYDROMETRIC STATIONS IN OPE HYDROMETRIC STATIONS OUT OF HYDROMETRIC STATIONS IN OPE 051 68 DSI HYDROMETRIC STATIONS OUT OF BOUNDARY OF CORUH RIVER DRAIN!

O

o

BOUNDARY OF SUB DRAINAGE BOUNDARY BETWEEN TURKEY-USSR PLANNED DAMSITE · O SETTLEMENT CENTERS 424 /47 ANNUAL MEAN PRECIPITATION AND ANNUAL MEAN ISOHYETAL CONTOUR

Fig. 6-1 Isohyetal Map



Δ	DMI	PRECIPITATION STATIONS
۵	DMI	PRECIPITATION AND BALANCE-PLUVIOGRAPH STATIONS
Δ	DMI	PRECIPITATION AND SYPHON-PLUVIOGRAPH STATIONS
رک	DMI	PRECIPITATION AND EVAPORATION STATIONS
<u>م</u>	DMI.	PRECIPITATION AND TEMPERATURE STATIONS
بكر	DMI	PRECIPITATION, EVAPORATION AND TEMPERATURE STATIONS
≱	DMI	PRECIPITATION, EVAPORATION, TEMPERATURE AND TERMOHYGROGRAPH STATIONS
<u>م.</u>	DMI	PRECIPITATION AND TERMOGRAPH STATIONS
•	DSI	PRECIPITATION STATIONS
*	DSI	PRECIPITATION AND BALANCE-PLUVIOGRAPH STATIONS
`▲	ÐSI	PRECIPITATION AND SYPHON-PLUVIOGRAPH STATIONS
م	OSI	PRECIPITATION AND EVAPORATION STATIONS
<u> </u>	DSI	PRECIPITATION AND TEMPERATURE STATIONS
×≜∢	DSI	PRECIPITATION, EVAPORATION AND TEMPERATURE STATIONS
يلجز	DSI	PRECIPITATION, EVAPORATION, TEMPERATURE AND TERMOGRAPH STATIONS
ړگې	DSI	PRECIPITATION, EVAPORATION, TEMPERATURE AND TERMOHYGROGRAPH STATIONS
▲_	DSI	PRECIPITATION AND TERMOGRAPH STATIONS
۲	dsi	PRECIPITATION STATIONS OUT OF OPERATION
Þ	εie	SNOW GAGING STATIONS

	\diamond	OSI SNOW GAGING STATIONS
	O	DMI SNOW GAGING STATIONS
601/2	8	EIE HYDROMETRIC STATIONS IN OPERATION
o 802KUS A,T	•	EIE HYDROMETRIC STATIONS OUT OF OPERATION
	0	DSI HYDROMETRIC STATIONS IN OPERATION
	٠	DSI HYDROMETRIC STATIONS OUT OF OPERATION
		BOUNDARY OF CORUH RIVER DRAINAGE AREA

412/18 0 \$ELIM

----- BOUNDARY OF SUB DRAINAGE

BOUNDARY BETWEEN TURKEY-USSR

🐨 – PLANNED DAMSITE

• • SETTLEMENT CENTERS

424/47 ANNUAL MEAN PRECIPITATION AND GAGING PERIOD ANNUAL MEAN ISOHYETAL CONTOUR

Fig. 6-1 Isohyetal Map

	Station	i	÷		Observation	on Period	(Years)		•
	1	RIVEL			- - - - -				
So.	Name		61	1940	1950 1	1960	1970	1980	1990
2302	Tev Könrüsü	Tortum		1941		1966 15 11	1968 II		·
1									
NOKC.	Bouhurt 1			19.42				1984	
5000	- indeed	Au un							
				1942				1984	
2305	Peterek	Coruh							
2314	Catakköprű	Tortum				1963 1967	7		
2315	Karşıköy	Çoruh			-	1965		1984	
2316	Ispir Köprü	Coruh			-	1965		1984	
2320	Laleri	Çoruh					970	1984	
2321	Dutdere	Altiparmak					1972	1984	
2322	Altınsu	Çoruh					1972	1984	
2323	Ishan• Köprü	Oltu				1963 1965 HT		1984	
2325	Asağı Kumlu	oltu					1974	1984	et.

Fig. 6-2 Existing Stream Gaging Stations

·

.

6–5

Table 6--1 Monthly Precipitation at Meteorological Station

	428.8	41.8	31.3	39 • I	15.9	16.8	10.1	41.7	59 °8	72.0	45 . 3	25.3	29.7	13	Sarimese	
		r • •	r • •			2 • •		•••	1.10	0 • 0 • 0	1.11) • •	√ • •	2	ocuraya	
		1						•			1	4 1				
	396.4	23.5	29.4	28.1	18.9	24.6	38.7	53.2	64.4	46.6	29 .1	20.5	19.4	25	olur	
	383.1	17.6	23.8	29.3	19.6	23.2	41.7	54.4	65.2	41.6	26.1	21.8	18.8	25	Oltu	
	410.2	18.1	27 • 0	30.4	17.3	29.9	33.2	64.2	70.0	49.1	30.0	21.0	20.0	25	Narman	
	455.9	24.9	33.4	38.1	20.2	24.0	34.8	62.8	67.3	55.3	38.6	29.0	27.5	30	Tortum	·
	305.1	23.+5	26.2	20.0	17.6	15.0	24.7	43.3	42.1	32.7	25 • 6	16.3	18.1	23	Yusufeli	· -
	413.7	34.5	31.2	28.5	23.9	27.5	21.1	59.4	60.9	42.3	37 .8	22.8	23.8	18	Kilickaya	
	511.4	52.6	40.8	39 .5	28.1	22.1	25.3	54.9	65.6	59.8	48 . 3	35.7	38.7	19	Camlikaya	
•	442.4	39.2	36.0	31.4	22.6	15.4	23.8	46.8	60.4	59.4	38.8	38 • 9	29.7	30	Ispir	
	430.8	41.7	38 • 8	33 . 8	20.9	10.3	15.3	47.3	54.2	62.4	41.5	31.9	32.7	18	Pazaryolu	
	514.9	43.0	45.5	40.3	19.5	19.0	23.9	60.2	75.1	64.6	48.0	35.6	40.2	14	Kirík	
	432.3	26.3	44.0	38 5	20.8	13.7	21.4	53.4	67.1	57.0	38.6	27 • 2	24.3	54	Bayburt	
	415.6	39.8	36.3	40.4	19.0.	10.9	9.1	6 •0 7	61.5	60.2	41.8	25.2	30.5	15	Aydintepe	
	Total	Dec.	Nov.	Oct.	Sept.	Aug.	July	June	May	Apr.	Mar.	Feb.	Jan.	Years	Station	
	(unit: mm)	,n)-														41

Note; The observation periods in this table cover the duration from the beginning of the observation period until the end of 1983. There are some breaks in observation periods of several stations.

											(uni	t: °C
Year	I	11	III	IV	V	VI	VII	VIII	IX	X	XI	XII
1965	2.2	2.8	9.4	12.6	19.5	22.7	25.2	26.3	22,3	12.2	7.5	4.3
66	6.5	8.4	10.6	15.9	18.7	23.0	27.7	27.5	21.5	17.7	12.0	6.3
67	1.6	0.6	7.5	13.1	17.5	20.6	22.6	24.0	20.5	16.1	8.4	2.0
68	-1.3	1.3	. 7.3	16.1	20.2	21.4	25.8	24.9	21.4	16.4	10.8	3.1
69	1.9	3.0	9.6	12.8	20.1	24.9	24.5	27.2	21.4	14.1	7.8	5.7
1970	4.4	6.8	10.5	17.8	19.0	23.0	26.5	24.3	21.5	14.4	10.6	3.0
71	2.4	4.4	9.5	14.6	19.7	20.9	26.9	24.0	25.0	14.6	8.7	1.3
72	4.1	1.0	7.7	16.4	18.2	22.4	27.0	27.8	22.2	17.9	7.3	1.5
73	-0.1	5.8	7.9	13.8	18.7	20.2	25.4	24.7	21.9	16.7	5.4	1.9
74	-1.2	3.3	10.3	11.1	20.0	24.4	25.0	25.3	20.1	19.4	10.0	4.3
75	1.9	1.7	7.8	17.8	19.2	24.6	26.8	26.0	21.4	14.5	9.2	0.1
76	-1.2	-2.1	6.8	14.2	18.4	21.2	24.6	25.6	21.4	15.7	9.0	4.6
77	1.0	6.2	8.6	14.7	18.3	20.6	24.9	25.8	21.2	12.4	8.3	2.1
78	0.8	5.0	10.2	12.0	18.4	18.0	24.9	24.0	21.4	16.4	6.0	2.1
79	1.0	6.2	10.2	14.6	20.2	22.3	23.9	27.8	22.8	15.4	10.1	2.8
1980	0.8	2.1	9.2	13.5	19.0	23.7	27.2	24.8	20.2	14.1	9.7	5.5
81	4.4	6.4	9.9	12.5	16.5	23.1	27.3	26.0	23.1	17.0	7.7	6.6
82		-	. –		.	· _	- -	-	22.1	15.5	7.0	1.5
83	-1.7	3.2	7.8	16.0	19.8	22.3	26.4	24.3	21.6	15.0	9.2	3.5
84	4.2	4.4	10.1	14.0	17.8	22.7	25.3	22.8	23.9	15.8	9.6	1.2

Table 6-2 Observed Monthly Average Temperatures at Yusufeli Station

,

Table 6--3 Observed Monthly Average Temperatures at Bayburt Station

								•				(unit:	t: °C)
Ř	Month Year	н	IJ	III	ΪV	Δ	ΓΛ	IIV	VIII	IX	x	ТХ	11X
	1977	-9.3	-0-1	1.2	7.7	11.4	14.5	17.4	18.7	15.4	4.9	3.2	-6 - -
	1978	-6.5	-2.0	1.3	5.2	10.8	13.3	20.2	17.3	16.0	10.1	9.0	9.0
	1979	-3.7	6 0-	2.1	7.8	12.2	14.7	16.6	21.2	16.5	8 8	4.8	-5.4
	1980	-10.0	۳ . ۳	-1.3	6.3	12.0	16.4	21.8	18.3	14.0	8.5	4.0	-2.8
	1981	-2.6	-0	2.5	5.2	8.9	14.9	19.7	17 • 9	16.3	10.7	1.3	2.0
	1982	-6.8	-8.4	1.8	9*6	11.5	14.8	17.2	17.4	14.2	8.2	-0.2	-4.1
	1983	-10.9	-7.2	0.2	7 • 4	11.9	14.8	19.0	17.5	13.7	8•6	4.1	-1.0
	1984	-1.3	-2.0	3•1	6.3	10.5	14.8	19.0	15.6	16.5	8.6	3.1	-8.7
]													

The average values of runoff serve an important role for hydropower planning, especially significant are those variations of streamflow such as seasonal variations in runoff and yearly variations in total runoff. Seasonal variations in runoff at No. 2305 gaging station and in precipitation at Bayburt from 1942 to 1983 are shown in Fig. 6-3.

)

Variations in annual total runoff are principal in reservoir design. Accordingly, stochastic methods are used to detect the regularity of fluctuations of hydrological data in random time series.

The distribution of periodic components in the hydrologic data series x(t) of precipitation or stream flow can be obtained by Fourier transformation as follows.

$$X(f) = \int_{-\infty}^{\infty} x(t) e^{-i2\pi f t} dt$$

$$Sx(f) = \lim_{T \to \infty} \left[\frac{1}{T} | X(f) |^2 \right]$$

The Sx(f) represents the average energy values per unit time of periodic components f and is called power spectrum.

When $X_T(t)$, the record length T of which is finite, is applied to the above equations, the estimated power spectrum is;

$$S(f) = \frac{1}{T} | X(f) |^2$$

The S(f) is usually unstable spectrum which fluctuates heavily in zigzags and is called raw power spectrum.

The smoothed power spectrum is obtained by using the lag Weighed function W(t), which is called lag window. In this study, Hanning window is applied, which is generally used for this purpose.

Hydrologic properties over the drainage basin of Yusufeli dam site were investigated by using spectral analysis for the annual runoff at No. 2305 station (1942 - 1984) and the annual precipitation at Bayburt station (1931 - 1983). Fig. 6-4 indicates that hydrological records in the catchment basin of Yusufeli dam site such as precipitation and stream flow have the superior ingredient of approximately 5 years cycle.





Fig. 6-3 Seasonal Variation of Precipitation and Runoff



The correlation analyses were performed to extend monthly flow at the stream gaging stations and to estimate natural monthly flow at dam sites. The results of correlation analyses are shown in Table 6-4 and Figs. $6-5 \sim 6-10$. Natural flow calculations at damsites are explicated in Table 6-5 and their results are listed in Tables $6-6 \sim 6-12$.

6.3 Evaporation

The observation of monthly evaporation is being undertaken at nearby stations where the standard Weather Bureau Class A pans are used. The evaporation stations are listed in Fig. 6-11.


In reservoir design, it is necessary to estimate the monthly distribution of annual evaporation and the increased loss over the reservoir resulting from the construction of the dam, i.e., reservoir evaporation less evapotranspiration after the construction. In general the volume of water required to balance the continuity equation for a basin represents evapotranspiration.


Considering the vegetation in the reservoir, evapotranspiration in the reservoir before the construction was neglected.


Correlation analysis was made to derive a reliable relation between monthly pan evaporation and monthly average temperature at Bayburt station.


The used data are shown in Table 6-3 and 6-13. The regression curve and equation derived from the analysis are indicated in Fig. 6-12.


Yusufeli meteorological station, where air temperatures are being observed, is located near the Yusufeli dam site. Actual monthly distribution of annual evaporation from the reservoir was estimated by using monthly average temperatures at Yusufeli and the regression equation. The pan coefficient of 0.70 was used in the estimation. The monthly evaporations from 1965 to 1984 are shown in Table 6-14. Monthly average temperatures at Yusufeli station are shown in Table 6-2.




















Fig. 6-6 (1) Correlation Analysis between Nos. 2321 and 2305 G.S.




Fig. 6-6 (2) Correlation Analysis between Nos. 2321 and 2305 G.S.






Fig. 6-7 Correlation Analysis between Nos. 2322 and 2305 G.S.










Fig. 6-8 (2) Correlation Analysis between Nos. 2322 and 2315 G.S.










Fig. 6-10 Correlation Analysis between Nos. 2323 and 2302 G.S.

Station Name	Observation 1 1960 1970	Period 1980 1990	Remarks
Bayburt	15	977 1984	Within the basin
Ispir	15	977 1984	ditto
Gümüşhane	1972		Around the basin
Erzincan	1962	1984	ditto





Log Y = 0.83074 + 1.13068 Log X




Table 6-4 Correlation Analysis of Stream Gaging Station

Station	Years	Independent Variable (X)	Regression Equation	Common Observation Period	Correlation Coefficient
Ispir Koprusu (2316)	1942-1964	2305	AugFeb.: logY=0.21658+0.74067 logX MarMay: logY=-0.33494+1.05292 logX JunJuly: logY=-0.80677+1.19157 logX	19651984	0.866 0.988 0.981
	1965-1984	Obse	Observation Period		
Dutdere (2321)	1942-1971	2305	OctMay: logY=-0.54102+0.90431 logX JunSept.: logY≈-0.34967+0.91898 logX	1972-1984	0.955
	1972-1984	Obse	Observation Period		
	1942-1964	2305	logY=0.57244+0.92012 logX	1972-1984	0.988
Altinsu (2322)	1965-1971	2315	<pre>AprSept.: logY=-0.24436+1.06124 logX OctMar.: logT=0.31064+0.79238 logX</pre>	1972-1984	0.995 0.886
	1972-1984	Obse	Observation Period		
Ishan Kop	1942-1964	2302	logY=0.70359+0.88125 logX	1963-1967	0.983
(2323)	1965-1984	Obse	Observation Period		
Karsikoy	1942-1964	2305	logY=0.94709+0.79786 logX	1965-1984	0.946
(2315)	1965-1984	Obse	Observation Period		
				-	

6–26

•				· · · · · · · · · · · · · · · · · · ·	· .
Dam	Qi	Qj	Ai	Aj	Adam-Ai Aj-Ai
Karakale	Q2316	Q2305	A2316	A2305	0.763
Yusufeli	Q2305		A2305		0.149
Artvin(U)	+Q2321	Q2322	+A2321	A2322	0.190
Artvin(L)	+Q2323		+A2323		0.229
Deriner	01311	02215	A2322	Δ2315	0.047
Borcka	Q2322	Q2315	ALJZZ	RESTS .	0.428
Muratli	-	Q2315		A2315	1.005

 Table 6–5
 Natural Flow Calculation at Damsites

Natural Flow at damsites is calculated as follows:

 $Qdam = Qi + (Qj - Qi) \times \frac{Adam - Ai}{Aj - Ai}$

Where,

Qdam; natural flow at a damsite Qi,Qj; natural flow at a gaging station Adam; catchment area of a damsite Ai,Aj; catchment area of a gaging station

6---27

Damsite
Karakale
Flow at
Natural
Table 6–6

•

		• 1 1	MAR.	4.9 R.	MAY	- NUL	- 101-	AUG.	5E P.	CC 1 -	NOV.	CEC.	TOTAL
27	ŵ	101.70	174-29	£56-82	925.57	363-52	17271	89.87	11-11	42.84	96.61	94.06	3116-5
43	ļ	59.30	80-09	277.03	55"215	241.42	123.66	76.19	56.18	63.0E	67.54	66. 86	1602.6
4 4 4 1	58°10	62-23 97.30	157.81	268.75 760.86	992.08 201 10	448.64	5444	86.16	65.23 63 66	59.47	66-86 66-86	48.25	2564.57
	ł	11		10.000	271-10		017	21.26	4 4 • 90		20.07	52.55	
47		52.84	168.79	24 P = 20	197.18	06-271	67.36		25.50		81.82		1195.65
4.8		46.95	- 45-24	266.00	. 420 70	341-78	701-78				4 5 78	40.09	1539.67
64	,	34.07	65.01	160-55	393-03	198.69	62.78	47-04	40+56	44.01	39.48	37,13	1161.27
05	34	35.47	88-73	32.026	42.0-20	204.41	101 90	53.98		68.74	56.46	48.69	1487.19
51	45	40-96	68-46	256+81	327-62	257.49	102.65	50"65	55.47	108.47	81.39	60.16	1467-59
25	ŝ	•1€•19	82.13	351.56	363266	Z62.86	146.51	65.92	41.74	63-23	40-44	37.74	1588.96
μ μ	:	36.51	48-42	229-37	408.70	278.08	125.41	68.40	62.57	53.10	52.41	42.01	1440-48
54	29-24	41.35	91.56	346.95	568.52	38°88°	196.03	66-18	22 55	53.44	41.65	77 . 44	1974.03
55		36.51	59-20	135.53	01-2552	124.54	42.57	29-85	· 26+44	29•55	29-59	33,28	824.79
95	DE .	45.40	60.93	22-252	321-62	21*592	116.65	52.58	41.75	38-25	34-54	01 IE	1301.64
21		36-52	121-27	262-32	358.56	309.48	121-03	54.74	43.05	43.40	44.35	42+62	1505.
	37.30	37 48	15-18	268-75	405.63	16-612	104 20	56.67	. 48* 25	46-52	44.61	45.83	1459-13
55		34.24	97-56	277.03	496-41	354.49	144.75	75.59	14°-00	77-85	70.20	55-17	1786.05
29	16-85	162.30	259.51	6:0:31	151.95	412:35	201.36	89-82	. 52.23	20.94	44.21	41-22	-2815-
		30.20	62.10	262.32	314.73	191.59	49.18	26.76	25+35	29-32	36.78	57.93	1114.
	83*25	46.61	590-84	356.16	. 29*595	276.28	10.52	46.69	46.52	16-25	48-34	05"67	1744.21
5 28		54.65	83.09	508.42	827.II	729.72	371.64	135。45	62-74	61.11	54.13	51.37	2992.35
64	48.34	46.00	- £2 * LII	3 19. 20	578.70	E4-26E	114-02	58.19	51=02	20-10	54-00	28,86	2201
65	• . •	45.83	150.77	420.68	555.71	357-78	138.12	50.59	49.67	14.98	67.96	65,99	2044103
99	55*D8 5	16.35	- 143.75	951-13	81-126	328-81	139+36		02 * 25	50.36	49.21	53,80	52°561
61		41+11	80.16	305.11	555,23	308.02	250-52	96 - 54	77-04	-58.11	62+52	81.95	2013-03
39	26-69	65-48	166.54	831•30	15-262	369,65	182-90	109.25	11-201	116.41	121-94	91-40	2954-31
0		54 - E4	191.29	425.25	6/8°91	300-27	121.99	88-41	65.05	81-41	60.54	08.75	-1527
21	•	24.92	139.19		314-32	87*241	H4 64	59.64	4 6 - 53	50-81	5-46	18. 44	1493-10
		- to - to	140.49	218.15	925-24	26-115	142-32	42.10	11.04	> 1 • 0 +	24 64	80*69	TE /0 -0/
2		24.14	87.35	230.64	402.66 	34 3. 0 7	149.41	10-86	61.55	10.65	64.49	45.10	1828.10
	5 - 5 - 41	45.60	62.64	191.40	12-196	285+84	128.14	49.39	31.61	53.40	63+57	14.10	1362.72
		00-D+	0/ - DC T		27-504	21++62		10 J	r	10.1	20 - T - T		
		32-25	161101	5 11 - 2 /	406-50	284.34	102-25	4 3• IC	41-14	26•26	43.U3	26-95	
2:	0 × 4 × 0	1 1 1 1	55 • 50 T	10 - N - A 0 - N - A	00-056	4 K C • F A				5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5 5			2160-44
-			11100	2 C 3 C U U		340.11		10.00	48.00		0.00	10-10	
0 L - r						24 240	13.2.1	0 76	1 1	20-22		404 C C C C	
		34 42	21-071	26 2.7	20 7 3 2 A	20.5 22	10.00	10.00	20.00	52 02	50 TT	10.05	71.0701
	- v	- 4 - 4 - 7 - 7 - 7 - 7 - 7 - 7 - 7 - 7 - 7 - 7	99-90	200,20	08-044	26.7.62		64.44	20112	C 7 - 1 - 2	59.77	101	1730.81
		E9.7E	66.19	*d *55	515.99	10.01	122.29	56.84	43. 28	47.53	42.64	34.83	1722.84
1 M		30.28	81°	166.06	285.13	197.25	72.61	29.71	10-52	52.04	135.10	90.05	1194.63
										4			
AV	1E-94 V	50.94	111.69	343.20	490.83	315-04	137.45	65-81	51.74	59.16	59.86	54.45	1789.50
MA	4 98.31	162.30	259.57	E56.82	99.8-08	729.72	371.64	135.45	102-11	116.41	135-10	94.06	3116.50
		•	• • •										

	- C	
	1	
		Damsite
		t Yusufeli
		v at
	•	Flow
	•	Natural
		6-1
	•	Table 6-7

44	JAK.	FEF.	HAP.	SPR.	Y2H	-NUC	.JUL.	AUC.	SE P.	. tu:	.VON	DEC.	TOTAL
2.5	128.84	211.19	337.59	1379.38	1546-08	864-02	400-14	212-63	171.86	189-14	209-01	201.49	12-6129
4.3	159,68	135.81	172.85	515-30	870.94	529.42	2.86.83	176.42	132.74	142.40	154.42	149-67	3426.48
77	OFTEEL	136.26	310,80	551.24	1854.33	01.010	205 48	206.49	160.32	146.85	160.48	121-68	5204.70
¢ 2	11.21	97.27	128-62	387.07	827.58	712.17	291-27	145.32	1.10, 53	118-30	117.55	113-33	3160.22
0 F \$	20.00	1 2 4 0 1 1 2 4 0 1	160.45	412-03	04 0 40 77 0 40	896.43	25.125	290.90	101.81	21-122	10-11	142 17	12-4504
- 27	174.35		175.85	17.27	11.272	P455.79	765.48	158-91	157.30	137-75	124-02	10.67	3648-92
0	102.48	10.10	146.96	317.75	909.33	496.95	168.52	121.57	108,82	116.71	105-54	99.15	
50	93.56	E0.E6	194.45	627.52	45-44	531.48	270.16	140.20	101.87	171.64	142.56	125.77	3448.08
15	117.95	105.75	170.47	512.14	756.42	644.80	269.02	152.84	155.02	263.53	197.23	154-36	3512.52
- 25	140.50	150.65	188.00	123-50	86.216	674.46	52-532	179.25	EE * 5EI	21.911	114.29	111.19	38 23 + 54
513	102.56	102 36	129 . 72	4.50-48	924.44	663.91	323.14	183.00	156.12	132-94	133.21	114.05	3475.93
4	51 - 11	115-34	212.62	632-76		966.51	548-05	226.04	163.86	147-26	130-52	122 77	4571.19
52	103.14	.E6-15	142-70	301.86	Į	337.88	114-76	75.04	12-29	81.73	82.84	13-26	20:53 14
0 F A A	80°68	55 FTT		4 20 4 0 2 4	17. 17. U	644°22	54 56N	140.00	00 ~ 1 T	117 20 20	102-201	67°16	2071°1205
10	50-62 11-11-11-		CE CH L	6 1 0 2 7	1	18 657	740 010	127.021	121.52	26.161	DL 71	95 311	2166.61
ים יי יי			200,000			759.96	10 662	191.40			175.40	141.50	38.71 .07
- 20	746-47	11-11-	57 / 72	1095,51	ſ	E27.00	447.55	225.99	4 2 2	120.74	106.93	102-26	5388.64
61	77.82	77.52	130.98	447.03	578.01	387.54	112.76	62.37	57.91	69.74	85.15	122-56	2209.39
29	60.52	54.72	345.11	621-02	870.60	560.09	246.47	112.12	104.34	101.30	104.79	105.65	3367.12
ት ት ት	112.57	112.85	162.59	- 32-36	1618-98	1458.70	781-12	353,58	155.74	169.91	149.90	11-051	6128.81
54	11/.05	107.55	35.525	15.551	I206.05	89.968	281.65	139.03	122-65	123+38	120-01	131+10	4209.78
65	108-51	:58.76	291.32	761.53	34-356	713.07	315.45	143.52	110.61	172-80	151.73	139.04	3991.79
÷.	159.10	151.44	245-67	667-36.	1080.53	51 7. EQ	268-20	127.92	29 EZ I	111-20	62 601	14-011	10-2015
5 C	72-26	22-13	48-261	515.45	~r	20-20-020	224 200	C3.86.7	114.64	341.41	143-54	120021	4171-13
6 6							79 7PC	C	114672	10 001	- 00 + C 0 - 1		1780 35
	27 71	102-171	110-120	07-720	81.31A.	327.56	196.53	179.83	10-11-1	10.121	57-101	10-30	2087.76
- +			238.01	4.61-0.8		712.84	264.65	217.41	102.50	119.72	114, 70	147.74	3630-47
	10.001	00 00	198.87	757.5		171.22	12.775	153.91	155.74	158.38	151-15	113.68	2804.09
1	109-26	124.23	159.63	4 18 04	820-35	673-08	201.76	114.83	94 25	125-99	135 83	115-27	3191.44
124	22-05	85.80	242.46	387.16	727.57	454.25	153.06		164.51	12-86	00-16	50.99	2907.16
75	93.56	81,78	196.48	664.11	736.72	557+50	209 66	95.17	95. 55	127.10	105. 25	85.78	3073,26
- 24	99.66	96.30	227.23	1:2.51	1236.65	840.64	402-76	166.72	132.70		139.87	125.12	13-9954
77	14*56	109,77	206-91	513.39	11-166	634.24	282.10	148.72	114.70	139.74	124.21	106.58	3470.94
78	102.27	137.63	270.80	657.32	1221.44		360.39	154.02	106.19	121.36	119.34	122.46	4129.39
52	120.72	137.36	208-06	18.4	26~628	770.58	399.65	144.91	51-19	154-34	256.29	191.12	5809.08
08	142.13	128,30	97-0	1023-24	1086-76	509.97	55 I N N	10-271	16-26	Ņ		17-171	90-170+
81	110-52	C	163.18		186.78	27.024	214.02	121.42	110-16	12.55	104-14	101-20	3214.18
n V a ca			****			210-02	11 11 11 11 11 11 11 11 11 11 11 11 11	21-21 T	10 70		01 000		7576 133
ά α			141+02		01+100						<u>ا</u>		
٨V	115.76	116.12	216.88	636-11	965.76	685.60	313.81	158.74	127-74	140.97	139-12	126.64	3777.25
	02 200		31 1.77	55 X121	60	1450 70	781 12	353.50	216-17	043_53	256.29	07 102	00 2274
a R	50C+ 45	114100					144040						

Ank. Max. May. Juk. Juk. <thjuk.< th=""> Juk. Juk. <thj< th=""><th>APR. ANY JUN. JUL. AUG. SEP. UC. 1410.5 185.37 904.35 215.10 13.57 13.57 13.45 1410.5 8195.25 835.80 704.35 215.10 13.57 13.45 144.62 525.26 8195.25 835.80 704.35 215.10 13.57 134.46 525.26 819.22 511.27 535.25 144.62 225.45 525.26 819.22 511.62 105.45 111.46 113.45 521.56 913.22 116.20 155.45 111.52 122.51 133.52 531.56 913.22.53 377.40 155.45 134.75 134.75 532.58 138.75 555.45 555.45 146.41 115.50 137.55 531.71 837.45 146.41 115.40 157.45 134.75 532.59 157.45 147.41 115.40 157.45 147.75 531.71 847.76 157.45 147.41<</th></thj<></thjuk.<>	APR. ANY JUN. JUL. AUG. SEP. UC. 1410.5 185.37 904.35 215.10 13.57 13.57 13.45 1410.5 8195.25 835.80 704.35 215.10 13.57 13.45 144.62 525.26 8195.25 835.80 704.35 215.10 13.57 134.46 525.26 819.22 511.27 535.25 144.62 225.45 525.26 819.22 511.62 105.45 111.46 113.45 521.56 913.22 116.20 155.45 111.52 122.51 133.52 531.56 913.22.53 377.40 155.45 134.75 134.75 532.58 138.75 555.45 555.45 146.41 115.50 137.55 531.71 837.45 146.41 115.40 157.45 134.75 532.59 157.45 147.41 115.40 157.45 147.75 531.71 847.76 157.45 147.41<
HAR. APR. NAY JUL. JUL. AUL. ADG. 344.11 1410.26 185.25 185.39 604.35 215.10 175.13 1710.25 185.25 185.39 604.35 215.10 175.13 174.11 1410.26 195.25 555.80 259.40 172.12 175.14 575.55 446.01 368.37 404.35 215.01 175.15 575.55 446.01 368.37 400.21 216.02 180.05 547.48 895.27 116.02 146.59 146.51 181.04 323.56 913.25 493.47 155.56 446.01 181.04 323.56 913.25 493.47 156.47 156.47 181.04 323.56 446.01 325.57 118.70 176.20 181.04 323.55 118.75 157.57 157.57 158.47 181.04 565.46 173.56 177.58 156.43 157.55 181.11 775.75<	FEE MAR. AP. JUN. JUN. JUN. JUL. AUG. 215-35 354-11 1410.26 185.37 868.37 704.37 215.16 215-35 374.11 1410.26 185.37 868.37 704.37 215.16 215-35 374.11 1410.26 352.26 879.27 711.67 219.70 131-25 352.26 879.27 810.47 204.37 204.37 216.45 92.01 130.25 341.76 395.26 199.77 211.62 199.77 92.01 346.75 357.26 876.75 399.27 211.62 199.77 92.01 346.75 357.26 990.47 357.25 190.41 171.26 92.01 191.62 347.75 397.24 377.24 319.71 357.25 192.015 194.42 305.41 194.42 314.41 327.24 194.21 102.775 130.55 397.26 199.76 397.26 197.44 35
MAR. APR. APR. APV. JUN. 344.11 1410.36 1363.37 863.39 374.11 1410.36 1365.73 555.25 895.37 316.57 553.57 895.57 895.57 316.57 553.57 895.57 895.57 316.57 553.57 895.57 895.57 316.57 553.57 895.57 895.57 316.57 525.56 913.25 895.57 316.57 521.52 913.25 495.74 317.58 531.57 913.25 495.74 317.58 531.57 913.25 495.74 310.53 487.76 913.25 495.74 310.53 487.76 913.25 547.48 190.43 531.71 824.89 696.64 190.43 531.71 824.89 696.64 190.43 531.45 7147.49 7147.49 215.43 474.75 171.26 733.59 147.45 171.26 133.55 1474.30 147.45 1101.57 1474.30 164.31 147.45 121.10 147.45 1474.30 147.45 1476.71 1476.71 1474.30	FEB. MAR. AP.R. MAY JUN. 215.35 344.11 1410.36 1853.37 868.39 137.83 175.73 555.26 879.52 555.80 137.83 175.73 555.26 879.52 555.80 141.83 175.73 555.56 879.52 555.80 97.76 152.94 515.73 555.46 714.75 97.76 152.94 515.73 555.56 875.52 855.80 97.76 152.94 514.43 314.75 856.37 868.37 97.76 152.94 514.43 314.75 856.47 868.37 97.77 151.74 323.56 517.48 591.46 866.47 105.37 135.53 675.31 675.48 866.47 866.47 105.37 135.54 135.55 144.32 339.16 676.48 105.30 144.32 305.41 874.48 876.48 876.48 105.31 177.18 864.49
MAR. APR. APR. APV. JUN. 344.11 1410.36 1363.37 863.39 374.11 1410.36 1365.73 555.25 895.37 316.57 553.57 895.57 895.57 316.57 553.57 895.57 895.57 316.57 553.57 895.57 895.57 316.57 553.57 895.57 895.57 316.57 525.56 913.25 895.57 316.57 521.52 913.25 495.74 317.58 531.57 913.25 495.74 317.58 531.57 913.25 495.74 310.53 487.76 913.25 495.74 310.53 487.76 913.25 547.48 190.43 531.71 824.89 696.64 190.43 531.71 824.89 696.64 190.43 531.45 7147.49 7147.49 215.43 474.75 171.26 733.59 147.45 171.26 133.55 1474.30 147.45 1101.57 1474.30 164.31 147.45 121.10 147.45 1474.30 147.45 1476.71 1476.71 1474.30	FEB. MAR. AP.R. MAY JUN. 215.35 344.11 1410.36 1853.37 868.39 137.83 175.73 555.26 879.52 555.80 137.83 175.73 555.26 879.52 555.80 141.83 175.73 555.56 879.52 555.80 97.76 152.94 515.73 555.46 714.75 97.76 152.94 515.73 555.56 875.52 855.80 97.76 152.94 514.43 314.75 856.37 868.37 97.76 152.94 514.43 314.75 856.47 868.37 97.77 151.74 323.56 517.48 591.46 866.47 105.37 135.53 675.31 675.48 866.47 866.47 105.37 135.54 135.55 144.32 339.16 676.48 105.30 144.32 305.41 874.48 876.48 876.48 105.31 177.18 864.49
MAR. APR. MAV. 344.11 1410.36 156.33 344.11 1410.36 156.35 354.17 1410.36 156.35 354.17 1410.36 156.35 354.17 1410.36 156.35 354.17 1410.36 156.35 355.55 525.26 875.52 356.13 525.56 974.35 151.04 321.54 950.10 171.96 511.80 765.92 171.96 511.82 950.10 171.96 511.82 950.10 171.96 511.82 755.36 190.42 475.73 1191.25 190.42 475.73 1217.83 190.42 475.73 131.25 190.42 475.73 131.25 190.42 475.73 1217.83 190.42 475.73 1217.83 190.42 674.89 164.35 190.42 475.73 1217.83 190.42 674.89 1011.55 190.42 771.28 857.29 190.42 741.74 1300.96 191.55 177.28 857.25 194.43 177.28 854.47 <	FEE. MAR. AR. AR. AR. MAY Z15.35 344.11 1410.36 1563.37 215.35 344.11 1410.36 1563.37 215.35 344.11 1410.36 1563.37 137.67 315.73 315.75 875.52 137.63 315.73 525.26 879.52 99.08 130.05 394.36 835.22 97.08 130.05 394.36 910.45 97.01 365.27 475.63 910.45 97.01 365.24 191.66 925.24 97.05 117.98 67.65 927.48 91.66 171.98 67.67 991.65 91.65 190.45 177.78 991.65 105.47 157.71 874.95 1777.81 105.47 157.75 1978.79 1978.79 105.46 57.75 1777.81 874.95 105.46 175.75 1777.81 874.95 105.46 57.55
MAR. APR. APR. 344.11 1410.36 344.11 1410.36 354.13 525.26 316.67 524.46 316.67 524.36 316.67 524.46 316.67 524.46 316.67 524.46 316.67 524.46 316.67 524.46 315.66 519.00 354.41 519.00 354.43 513.00 355.73 513.00 355.66 513.00 171.96 513.36 171.96 513.36 171.96 513.36 171.96 513.36 171.96 513.36 171.96 513.36 171.96 513.35 171.96 513.35 151.04 523.35 355.44 632.35 154.45 523.35 155.06 523.35 155.04 523.25 312.55 170.27 155.04 770.41 155.04 770.42 155.04 520.44 215.55 774.75 155.04 770.41 215.55 771.72 164.33 710.41	FEE MAR. ADR. ADR. 215.35 544.11 140.36 131.83 175.45 524.36 92.09 130.05 94.35 92.09 130.05 94.36 92.01 130.05 294.36 92.03 171.95 524.56 135.07 348.22 524.56 135.07 348.22 524.56 135.07 348.22 524.56 135.07 348.22 524.56 135.07 348.22 524.56 135.07 348.22 524.56 135.07 348.22 524.56 105.75 171.96 510.67 105.75 190.54 575.16 105.75 190.54 575.36 105.75 190.54 575.25 105.76 135.65 532.35 105.77 166.35 532.35 105.74 155.36 575.25 105.74 155.35 451.16 105.74 155.35 451.17 105.42 312.55 451.17 105.42 312.55 451.17 155.36 152.55 451.17 155.36 152.55 451.17 <td< td=""></td<>
	FEE. 215.35 137.35 137.35 137.35 135.37 135.37 135.37 135.37 115.31 115.37 125.36 101.74 101.74 101.74 101.74 101.74 101.74 115.36 101.74 101.74 101.74 115.36 115.36 115.37 115.37 115.36 115.36 115.37 115.36

6–30

	õ	•	
	Э		
	Artvin		
ć	at		
•	Flow		
	Natural		
	Table 6–9		

					•						•	
		•								IN	unit: 10 ⁶	ົສ
•N₫C	• FEE •	MAR.	APR.	- AXM	JUK	Jut.	AUG.	SEP.	-u21	NCV.	DEC	TOTAL
1.5.19		350.20	14:5-28	1877-64	872.47	405-34	217.41	175-76	194-20	-515-53	208-44	6374-17
12421		322.00	20-122	19 192	44750	E24253	210-84	130-06	140-14	164-08	174-47	11-2552
112.55	ند جري	95-1E1	401-16	842.48	717.15	256.60	147.79	1.12.37	120.72	119-59	115.43	3216.47
104.89	.	165-27	4 85-34	952*25	06*563	402-28	258.68	162-66	230-55	171.05	144.56	4082*95
139.54	4 137.15	353.46	\$21.59	451.81	370.47	156.01	116.91	107.53	123+54	195.25	135,34	2859.00
126.00		128.57	1 1	26.356	857.19	519-14	160.54	25*651	139.82	125.64	111.72	3699,00
103-87		152.98	3 2 9 • 0 2	916.91	502.35	171-14	123.49	110.28	118-26	106.90	100.47	2828.19
		200-12	051-06 657 16	09+166	535 IO	275 CU	1-2-22	103+00	1/4=/U	141-46	12 1 - 1 - 1 - 1	79 97 97 56
				- 476-76-	212.70		174.01	1000	170.72		111-54	TO PARE
102 83	 	131 29	454.54	933.99	699 1B	27-21	184.89	156,99	135.43	135.49	115.31	2522,35
14.65	ſ	218.74	656.39	1201.41		548-01	227-33	165-09	148-51	132.13	123.86	4633.75
103.76		145-83	305. 6B	552.04	340.35	116.97	76.61	72.73	32.6C	83.60	11*26	2119.07
86.42		54.9.55	451.84	687.62		303.60	146. 73	115.41	115-21	103-04	91.24	30.14.96
85.16		263.22	54.4.73	833.38		303-46	141.55	119.16	121.35	126-27	118.12	3464.92
53°501		25-541	506-97	79- 32	643.60	264.68	132.62	125.24	123-03	116.69	117.53	5233_19
117.84			550-13	1015-40	776-22	33.2-69	194.42	153-09	191.36	178.49	143.75	39-6665
20-612	2.222		1-140-06	15-15-1	11 548	458.25	22.9.51	145.10	123-80	109-29-201		2000.0000
17-37			24-594	555.71	401.58	116.97	54-27	59.83	71-66	87-69	127.54	50* 2677
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		CT-000	041-1-1- 040 70	1 × × 0 × 0		104407	200 - 10 11 10	101-12	1001001	104.00	13 251	0440.035 A366 07
*****			7 - 2 + 6 5		140200	61-161	02 000	136-62	C 7 1 7 1	00-761	14-221	44 3027
		288-92	291952	1026.79	733.41	21-426	143.51		71-21	150.55	142.26	4117-24
161-14			651-93	1121-21	633.04	214-53	129-85	125-70	111.52	105.36	110.79	3865-56
9.8.54	4. 90.25	• :	535.62	1238-48	651-29	572.21	245-20	180-10	149.60	147.51	199.51	4268.63
156.13		313.06	1785.51	1822.40	580.84	445.51	248-15	215.11	211.22	219-81	174.06	6727.56
140-40	1		841-49	1365.21	557.78	232.94	152-54	145-46	193-07	137-26	133.46	4335-16
120-3			52*245	042+71.	352.65	190.00	133 95	2.2	152-01	127-72	124,80	5084 •08
			70000	10-10-101	11.001	27 0 17		102-75	122.20		144.00	21 25.95
44-401	4. 131-00.		441.76	858,550 858,50	00-664			CT-12	12451	191691	104121	14.4656
52-25			36735	958-14	467.42	156-17	108.82	12.071	101-25	የ	102.20	2991.06
96.33	3 84.63	. `	723.79	762.90	572.54	213-46	97.04	101.57	131.90	108.79	89.01	2190.05
102.71			176-28	1277-43	862.55	412.97	169-10	135.18	ko-	143-54	128.32	1.
102.35		211.07	527.03	1010-14	647.80	288.03	151.48	117-56	144.25	128.53	109.35	3549.68
104-70	142.6	279-96	720.67	51-5521	743.21	372.14	160.33	109.47		123.45	126.76	4263713
126.30		ZI (- 8/	24U-39	91 1.08	143-01	404 II	149-52	53+ 50	20+663	200.00	120.40	CZ*2004
144 94		306-87	1041+32	1116-01 207 27	516.86	15 122	131 48	101-94	135-07	131.50	131.53	72°EI14
	200 20 20		76 22	04 5701) io	u in		20 20 1	n Jw	26. 201	2	25.00 62
- 5L		155-51	361.41	631-46	480.00	184.83	82.20	01 - 10 9 - 10	119.02		167.81	2670.10
118-51	1 11.5.65	223-53	655+01	1025-27	699.11	220.37	161.60	130.14	144.06	142.21	129.77	3873.23
214-0	02 322-28	469.18	1785.51	1897.81	1489.04	759.19	356.95	219.11	268-41	260.60	208.44	6727,56
78-71	57-92 1	128-97	209. E B	451-81	3E U78	50 214						
						10.0011	12.40	12.50	00+1	83.60	- TO-52	2119-07

6--31

Table 6-10 Natural Flow at Deriner Damsite

.

}	1	1	ŕ	}			1		}).	1		ľ		1	ľ		}.]	, . 1	Ì		1.)	•	1]			1]			
TOTAL	7970-69	4448.56	3804.11	52° E095	3419,30	4228-50	3267 - 57	4101417.39		4016.90	5285.63	2407.62	20362525 4140-95	4026.57	4863.11	1297.98	3129.08	1542.12	5283.57	53 52 . 09	4840 06 5460 24	< 27 E GI	4919-57	4015.96	4938 . 46	5241.04	3833.24	4360-76	5812-57	4500.00	5343 84	50.56.05	4800-21	26-1295	4849 00	10 11 100	12 01.72
DEC.	719.66	202.47	148.60 138.70	12-191	163-48	124-60	115.82	144 81	117.63	130.26	137-42	104.35	132.05	141.49	168.74	127.94	176.73	157-69	207.96	177-81	115.66 336 75	184-14	164.98	181-51	221.97	12-241	126.99	122.85	160.6L	137-42	250-73	177.70	15*521	24.17	163.97	35 256	
NOV.	246-20	204.44	202.47 142.26	91-661	245.10	57 5 77	122.79	64 771	175-63	160.72	146.83	93 28	122201	137.93	212 04	136-90		165-73	169.82	235.64	25 IOI	195.71	171.42	10-261	173.22	196. (4	127-47	140.89	14-281	111 02	308.64	129.10	194.68	309.55	176.20	370 55	
ccr.	247.44	191.62	181.21 147.08	267.70	148.35	┣-,	136.14	18-102	133.82	162.72	163.73	32.56	124,3F	143.53	233.96	156.44	92.48	185-53	215.08	225.67	174-82		249.44	258-22	ا منم	147-12	128-62	183.60	265.35	191.01	176.40	173.41	175.85	147.56	177.91	0	76767
SEP.	216.03	177.48	157.75	174.24	119.55	16.7.4B	127 17	101.33	147.08	190.13	5.	59 83	201 1 N T	148.60	173.99	150.21	80.48	190-63	156.69	106.98	16-521	742.01	152.88	15-581	10.1E1	212-20	220-84	122.04	162-18	10-021	11.8.42	132.80	172.13	135.81	155.86	, a o a c	
AUG.	767.70	. 229.11	257-39	279-65	137.67	21-611	145-06	170,01	199-76	206.89	243*85	94,08	161-22	153.66	227.41	267-10	84.76	394.50	179.22	145.31	56-051 56-051	175.74	139.44	175.11	266.75	190.66 156.47	125-75	116.42	194.42	774 65	198.71	159.85	195.71	163.09	192-04	304 60	
JUL.	492.69	366.72	675.17	445.56	213.02	308.13	200.00	104 - 5 - 10 A	426-70	371-36	553-38	141-24	354-74	32.515	422-12	566.78	160.72	578.28	90-14E	41.1-82	54-52E	697-96	220.11	226-12	327+00	400+14 406-23	188.28	252.75	512-70	2444 13	503.42	245.38	463.03	232-23	367.47	070 OD	
100	959-79	666.38	115121	12-588	417-53	921.50	960.09	705.00	118-52	755.92	10.919	369 04	631 57 631 57	00-B-51	938.53	1073. 83	542-19	1784.26	1027-51	935.29	187-18 807-46	1368.79	587.89	\$2.5	909.27	953.500 953.88	565 66	720-27	58-510T		1015-36	588-69	1225.83	628-46) v	AC ADT 1	
МАҮ	2163.42	1052.80	2316-43	5-r	532-22	ς, ι κι (28-656	77-5758		1031.73	22.1251	62C+12	1008.51	EBSEDI	1230.37	1792.27	914.34	1953.84	91-6141	1335-57	1575-50	13-5672	1668-65	814.95	1375.24	1232.64	12:2.89	1026.47	1651-56	27	1287.69	1404-50	1056.35	1351-15	36.	2700 61	
APR.	17.3	725.46	705-82		657-59	5	71 - 745			635.56	865.48	127 23	650.51	5	725,46	12.5	6 3 U. 5 I	1012521	954 0	1129-15	924,36 744,86	2414013	1020-40	18-195	688.05	10.53 L L C	46.72	1115-20	1017 63	20000	759.54	01-3221	568.88	573.96	8 66.03		
MAR.	2	235.91	435.86 161.22	215.46		00	193.32	204.68	26-242	149.61	66	1 64 46	07 E40	22 * 252	282.03	55*689	181.41	243.89	86.7.16	377.31	248.46	362.56	264.51	52*112	318,82	264.26		318.96	319,31	12.72	B0 * 1 TE	r_{2}		182, 74 243, 10	293.45	40 684	51 c
FEC.	301-04	180.71	116.59	120.47	161-97	D8-241	T np*10	127.17	186.67	114.00	146.07	114,00	115-55	116.85	107.22	461.16	51.64	167-24	10.241	142.51	198.21	219.13	135.77	177.28	171.28	206.54	112.13	115.32	132.04		510 512	5. T		122.32	157.27	7C L77	- U
JAN.	260.51	215.46	132-57	62.221	158.20	154.67	C4*611	135-20	167.59	108.00	132.05	112 44	82. 89	116.33	141.24	531422	00.456	162.22	SB_B71	159-03	104-36	231.162	134.08	160.12	160.66	140-18	124 04	125.59	135-37	CE LER	188.31	11.6.17	149.08	152 /4 1 CB 80	148.25	291 55	0
٨٨	42	41	4 4 4 4	\$0	47		**	្ ភូសា	25	ŝ	+ 1 5 1		0 -	58	59	09		33	54	65	90	58	6.5	01.		2 2 2	14	. 15	91.	a a	54	ЪВ	81	2 8 8 8	AV	4	1

	е Е	TOTAL	E385.61 4875.27	7042.95	5022.21	3814.42	4618-36	4491.94	4167-04	4406.14	2728.53	4003-04	4412-37	7777_05	3469.75	5130.15 8028 49	5736.99	5952.85	59.64 .56	\$901.56	5382.14	5446 27	5619-04	4124.34	4752.45	6520°12	6140.56	5888.70	5340.15	5039.30	CT=1774	5279.83	9907.56	2728+53
	unit: 10 ⁶	DEC	315.13 232.56	173.91	188.01	190-21	147.63	211.69	139-65	153.67	124.80	155.65	166.08	151-11	204-66	179.19 182 88	256.37	215.09	440,85	223+65	197.79	220°10	187.56	150.99	145-71	173.57 166.85	248.12	312-84	217-84	165.70	17-707	196.99	440-85	119.49
	In	-NON	322-70 234-69	232.56	225.64	278.35	169+16	200.05 277.05	148.54	187.19	212.35	130.36 161.31	162.15	161-02	136.46	174.18	204-29	294.98	115-58 232-25	225.83	206-45	231.24	234.85	139.28	172.13	233.41	234-13	361.98	272.41	181.99	524-13	210-56	361.98	112.25
•		001-	281.44 220.83	209-53	302.44	173-63	189.32 160.1E	238.35	157.64	189.38 140.44	112.35	141.3E 158.20	168.32	187.51	111.45	172.75	266.25	281.00	134-50 206-45	241-50	314.46	326.92 218.28	190.00	133.57	228-56	348-83	175.71	227.84	199.14	176.12	195.28	21'0- 73	357.65	111.45
:		*d35	248-14	227.51	201-95	142-24	154.55	138.49 205-53	172.24	215.22	108-45	152.81	173.91	201-C8	97.83	168.32	162.78	112.99	160.28 256.05	282+68	168.53	203-94 145.04	220.14	251.71	130.43	167.71	157-28	137.85	185.28	142.28	124-28	177.86	282.68	97.83
ca Damsite		AUG	302-44 261-23	291.46	315-13	161-87	207-92 170-01	191.86 208.18	229-64	237.33	113.25	187.74	179.46	75-405	102.71	175.30	1E-102	160-38	165 81 335 2E		154.06	193-02 290-05	196.00	147.85	127.85	213-95	244.95	212-42	201-43	1.	116-28	215.76	435.75	102-71
w at Borch		JUL.	92-762 26-762	723.42	442.85	243.94	345.26 229.90	347.75	465-19	411.61	165.80	359-46	352-72	404-44	187-19	370.05	379.89	60-645	363+07 716+06	675.11	240-47	246.81	447-28	206.57	274.85	534.42 382.28	521.42	530. 65	400.42	350-14	234.54	420-27	1027-65	165-80
Natural Flow at Borcka Damsite		NOL	1008.68 714.53	1204.29	12.26	459.67	970.55 606.42	622-36	167.62	604.89	61-604	783.00 880.80	E07-07	66-184	588.12	800.52	1015.87	986.77	833, 91 654, 88	1431.27	627,13	433.17 559.96	1016.99	610.99	746.56	1098.71	1079.70	1050.42	1280.70		6 2 C • Z R	877.74	1 81 4. 27	409-19
6-11		MAY	2177.97	2323.85	115.5111	578.94	1107-14	1107-14	1046.56	1080-05	674.31	1057-04	1082-13	12/5.80	863-54	1214.60	1455.23	1397.34	1565 74	2879-37	1736.79	924 51 1441 94	1166.41	1292.13	1035.28	1232.42	1627.42	1345.41	1454-10	1387.85	935-84	1322.37	2875.37	578.94
Table		. A qA	2034.23	1	1			10.00	1	· 1		5	۱.	- 1		1	- 1 .	5		1.	- 1		1.	1		\$ `	1.	- 1		<u>۱</u>	1	942.16	2552-44	420-94
•		MA P	521.01 268.51	11	1.			1	1	- F		1	1	1		1.	1.			1.			1 - :			1	1	- 1	1.1	6.84	20	342.01	732.29	175.02
		۶EB.	337.17 208.55	218.14 138 49	13.521	188.56	127-44	132.11	215.46	135.60	135.60	164-68	al alt	128.02	114.44	166.60	166.65	167.51	242-92	271.88	159.06	214.37	177.42	125+26	141.55	141-85	240.30	280.13	199-56	154.59	~]	187.08.	511.45	114.44
· · · ·		JAN-	246-57	205.20	145.20	184.43	1 42 - 54	163-56	*I*56I	128.90	133.65	115.33	02.851	160-44	108-15	156.51	174.18	189.82	225-83	268-70	156.85	192-00	171-28	132.43	149.59	162-42	5		5 2	100		174.90	327.73	100-58
		λ۸	т. Т. Т.	44	27	47	49 49	51	25	ŝ	r in No	56	8.0	60		79	44	é5	66 67	66	-63	22	21		ŝ	22	78	79		82	63	AV	MA	ИЧ

Table 6-12 Natural Flow at Muratli Damsite

TOTAL	01-1505	5541-70	4778-70	2677.41	4428.19	5228-03	4179-84	5184.63	5395.35	5013.88	6334.79	3225.24	4581.06	2123.35	5933 28	11.82EB	3999.78	5163.49	50 43 *T	6826-52	5917-15	6753-15	10952-12	6105-Ur	6237-67	6215.57	5934.24	4582-81	594) - (54	5484-10	6964.15	6738 .07	6291 • 96 61 79 - 40	5687.07	4864.14	5954.42	10952.12	3225-24
DEC.TC	370-10	279-03	200-40	228-92	231.41	182-47	171-15	214.41	173-50	189.69	198-80	156-22	120-01	- 77* 70	237.91	186.75	247:74	218.89	474577	272.30	159.76	599-86	284-35	248+18 276 33	163.19	240.14	260-24	187.89	101-02	208.99	356-70	407-94	273.30	229.09	315.50	247.69	. 599.86	150-01
NDV-	378-25	281-40	2/9.05	275.16	329.79	207.47	180.16	222.25	183.78	227.99	210.65	141.62	162.71	01 22 2	500-062	198.14	169.81	213.19	224.5U	385.84	136.65	296.41	287-37	200-24	259.23	293.40	319.52	51-151	20-022	319.52	330.57	444.11	413-57 390-86	241.18	42.3.01	264.37	444.11	136.65
001+	333.20	265.91	253.23	356.24	212.56	230.46	197.18	285.51	194.75	230.48	231.12	141.62	175-51	14.4.1	316.65	222-61	140.57	ZI 1 • 8 1	26*867	365.74	151.17	260.24	30.5 4 7	413-91	269.26	5.0	190.51	19-141	476-27	397.89	202.97	30.6+46	203 97	220-05	238-12	261.15	476.27	140.57
SEP.	296.38	248.66	273.38	244.68	176.50	236.38	185.76	172+16 252-23	710.47	264.11	15-242	137-03	186.71 - 42	193.01	20-747	227-36	124.45	206-50	20401	137.66	88-E31	265-38	318-52	192.52	166-79	232.10	149.71	299.43	143.08	258.23	179.86	167-80	169.81 216.03	152.73	150.72	211.28	318-52	124-45
AUG.	356.24	310.89	344.20	370-10	199.12	251.41	208+42	233 28	774-76	284.35	- 92° - 82E	142-58	228.61	36-962	204-87	356-24	130-24	214.47	55 554 57 554	183.88	05.681	375.79	393 87	1/0.84	326.55	204-98	188.90	181.87	147.05	2E 242	278-32	234.11	211-00	205.58	142.68	252 . 54	499,99	130-24
- 10f	607.17	465-05	799.40	560.46	291.71	402.86	276.06	101-00 101-00 101-00	53525	474.25	612:05	203.62	448.14	- 67 1 05	530.44	686.25	227.99	425.65	1100,00	492.34	405.53	783.73	744.54	212.50	395.88	463.20	473.25	235-12		434.07	572.73	574.74	546.60 546.60	3784 80	252+39	471.72	1106.06	203.62
- NUL	1087.21	790.51	1280.46 898.00	1013.04	525.39	1049.22	679.15	645-61 831 23	844.64	882.54	1145.62	471.66	860.33	27*666	1066 14	02.9911	660.15	878.11	1 202 19	1069.09	108.32	930.43	1532-29	689-28 287-30	1040-95	1066.07	1077.13	659.14	1 39 - 10	837.99	187.65	1108.28	1365-52	720.67	701.34	947.37	1868.18	471-66
MAY		1	.2346.15 1118.59	51-1511	650.61	1184.83	1122.76	L L E 4 - 83	124.84	1158-04	1503.44	745.25	12.276	1105-24	1250-51	1875-50	941.83	522.53	275272	1497.13	1692.05	1754-35	3013-34	184 (+80	1543-35	1265-02	1372.53	1357.46	1 7 9 4 0 5	1251-15	1700-09	1448.90	1562.44	68-36-1	1021.85	1400-76	3013-34	650-61
APR.	79.48		5	ļ		Į.	- {		L		-		50°51	- [041+V3 841-40					1268.13	[16.57	8	.	614.93	1	, ,,,,,, ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	52.63		710-38	1245.95	777.70	1021-26	2681.77	454.87
MAR	590.07	318.54	245.50 228.61	294.63	575.31	229-85	270.40	547 - 44 78 - 50	37 7.23	214-15	372.85	251.10	256.86	D8 7+4	372,85	808.67	260.79	660.15	528+30	690.29	25-115	305-45	657-13	445.12	560-67	402.94	411.96	446.12	26 1.90		465.21	421-00	547.61 454.16	319.52	448-13	£16.83	808-67	214.15
F E B .	E1.495	252.62	172.16	11/16	225.54	Z08.11	159.31	104. 75	255-29	168.80	01-607	168.80		110*20	159.55	- 280-24	144-05	206-82	220-00	206.99	311.48	154.74	39-255	194 493	271.29	211.00	399.50	155.74	174.54	199,95		372.77	245.17	- 203- 97	186.85	232.50	580.24	144.09
JAN.	347.85		192,63	180.16	224+66	220-47	176-50	201-05	236-49	161-01	85*161	166.77		71 + 177	203 62	383-83	136-67	152-56	- 223+83 - 275-83	217-13	12-182	140.67	F	141.91	240.14	193.92	204.98	145.69	100-02	165.79		316.51	261.24	265-28	165.79	215-51	3R3•83	127-72
٨٨	42	64	5 4 5 10	- 94	47.	B	5	25	25	(C	54	55.	<u> </u>		0 0 0 0	100	61	29	50	59	99	67	08	50	22	12	EL			17	84	79	08 18	- 78	83	AV	MA	1

•

• • • • • •			F	Table 6–13	÷	Observed Monthly Class A Pan Evaporations of Bayburt Meteorological Station	nthly Cla orologica	ss A Pan I Station	Evaporat	ions of				
												, m	(unit: mm)	
Month Year	н	Ц	III	IV	Δ	ΓΛ	ΛIΙ	IIIV	IX	X	IX	XII	Total	
1977	1	I 	: ; l	 	 	133.0	178.4	192.2	137.2	43.5	Q	D	l	
1978	9	D	A	A	127 •2	158.5	158.5 206.1	183.0	156.8	77.1	Q	Q	908.7	
1979	A	Q	Q	Q	121.4	140.3	176.0	201.2	158.6	66.2	Δ.	â	863.7	
1980	A	Q	G	Q	121.2	178.2	230.2	185.1	144.4	75.3	Ē	Q	934.4	
1981	P	A	A	A	98.0	136.6	197.6	182.6	135.0	78.0	Â	A	827.8	
1982	<u>А</u>	D	Q	A	105.1	152.4	159.6	168.2	116.7	73.1	Q	Q	775.1	
1983	A	Q	А'	Ð	0•66	148.1	190.9	176.2	131.6	68.2	Q	A	814.0	
1984	A	D	A	A	92.2	138.0	198.1	148.1	152.8	196.9	: A	Q	926.1	

D; unmeasurable due to frost
 -; no data available

6--35

Table 6-14	Actual Monthly	Evaporations	from	Yusufeli Reservoir
				1.

						. •					•		(unit: _m
Years	Į	11	111	IV	v	٧I	VII	VIII	IX	X	xı	XII	Annual Tota
1965	11.5	15.2	59.7	83.2	136.3	161.8	182.1	191.2	158.6	80.2	46.3	24.6	1,150.8
66	39.3	52.6	68.4	108.2	130.	164.2	202.7	201.	152.2	122.2	78.7	38.	1,357.4
67	8.1	2.7	46.3	86.9	120.6	145.	161.	172.3	144.2	109.8	52.5	10.4	1,059.8
68	D	6.4	44.9	109.8	141.8	151.4	187.	179.7	151.4	112.	69.9	17.	1,171.2
69	9.8	16.5	61.2	84.7	141.1	17917	175.4	198.5	151.4	94.4	48.3	34.	1,195.9
1970	25.3	41.4	67.7	122.9	132.4	164.2	192.8	174.8	152.2	96.7	68.4	16.5	1,255.3
71	12.7	25.3	60.4	98.3	137.9	147.4	196.1	177.3	180.5	98.3	54.7	6.4	1,190.4
72	D	4.8	47.7	112.1	126.1	159.4	196.9	203.5	157.8	123.7	44.9	7.5	1,184.2
73	b	34.6	49.1	92.3	130.	141.8	183.8	178.1	165.4	114.4	31.9	9.8	1,121.
74	D	18.3	66.2	72.1	140.2	175.6	180.5	182.9	141.1	135.5	64.1	24.6	1,201.1
75	9.8	8.6	48.4	122.9	133.9	177.2	195.2	188.7	151.4	135.3	58.3	0.3	1,230.1
76	D	D	41.4	95.2	127.6	149.8	177.2	185.4	151.4	106.7	56.8	26.6	1,118.3
77	4.8	37.3	54.0	99.	126.8	145.	179.7	187.	149.8	81.7	51.9	11.	1,128.1
78	3.7	29.3	65.5	78.7	127.6	124.5	179.7	172.3	151.4	112.	36.0	11.	1,091.7
79	4.8	27.3	65.5	98.3	141.8	158.6	177.9	203.5	162.6	104.4	64.8	15.2	1,228.3
1980	3.7	11.0	58.3	90.	132.4	169.9	198.5	178.9	141.8	94.4	61.9	32.6	1,173.3
81	25.3	38.6	63.4	82.5	112.8	165.1	199.4	188.7	165.1	116.7	47.7	40.	1,245.2
82	-	~	-	-	-	-	· –	-	157.0	105-1	42.8	10.7	-
83	Ð	17,7	48.4	109.0	138.7	158.6	192.0	174.8	153.0	101.3	58,3	19.5	1,171.3
84	24.0	25.3	64.8	93.7	122.9	161.8	182.9	162.6	171.5	107.4	61.2	5.8	1,183.9
Ave.	9.6	21.7	56.9	96.8	131.6	157.9	186.4	184.3	155.5	107.6	55.0	18.1	1,181.4

6--36

Suspended sediment samplings are being carried out by EIE at 85 stations. Suspended sediment samples collected usually at an interval of one month are used to develop the sediment rating curve for each station.

In the Coruh river basin suspended sediment samples are collected at the following stations in Table 6-15.

Station Name	No.	Period	Number of Samples
Karsikoy	2315	June 1967 - Oct. 1984	182
Ispir Koprusu	2316	Sept. 1969 - Oct. 1984	167
Laleli	2320	July 1971 - Nov. 1983	88
Asagi Kumlu	2325	June 1977 - Oct. 1984	84


Table 6-15 Existing Suspended Sediment Data


The data series measured at No. 2315 and No. 2316 stations have the considerable variability of sediment load and river discharge as are shown in Table 6-16.


ſ	Station No.	Suspend	ed Sedime	nt (PPM)	River D	ischarge	(m ³ /sec)
ļ	Station No.	Max,	Min.	Ave.	Max.	Min.	Ave.
	2315	6,170	12	469	868	37.6	146.3
ĺ	2316	3,000	13	167	327	7.5	24.6

Table 6-16 Characteristics of Sediment Data

Two sediment rating curves relating suspended sediment discharge and river water discharge at Nos. 2315 and 2316 stations were constructed to estimate daily sediment load. The curves are given in Fig. 6-13 and 6-14. The regression equations were derived as follows.







)

Fig. 6-14 Sediment Rating Curve at No. 2316 Station

No. 2315: $\log S = -0.40123 + 1.92772 \log Q$ No. 2316: $\log S = -0.21199 + 1.98650 \log Q$

where,

S; suspended sediment discharge in tons per day

Q; river water discharge in cubic meters per second

The sediment rating curves should be generally used with caution. However, as they were used to estimate mean annual sediment yield, the erros in estimating the sediment rating curves were considered to tend to compensate. The mean annual sediment yields in tons per square kilometer at Nos. 2315 and 2316 stations were respectively estimated by using the sediment rating curves and daily discharge data recorded at Nos. 2315 and 2316 stream gaging stations from October 1964 to September 1983. Calculation results are shown below.

Station No.	Catchment Area (km ²)	Calculation Period (years)	Mean Annual Sediment Yield (tons/km ²)
2315	19,654	19	360
2316	5,505	19	138

The sediment volume in the reservoir depends on the specific density of the deposited material. The specific density varies with the kind of sediment and the age of the deposits. The kinds of suspended sediment and their contents are found below by the gradation analysis made by EIE.

Sand	Silt	Clay
33%	37%	30%

The dry specific density W_t at time t were found by Lane and Koelzer to be defined by $W_t = W_1 + K \log t$, where W_1 is the initial specific density and K is a consolidation coefficient. The average density of the total sediment accumulation at time t can be found by integrating from year 1 to year t.

The average specific density after 50 years of the deposits in the Yusufeli reservoir was estimated to be 1.195 ton/m^3 .

The average annual sediment yields at Nos. 2315 and 2316 stations were estimated by adding 12% of the suspended sediment load as the bed load transport to the suspended sediment load.

> No. 2315: 337 m³/km² No. 2316: 129 m³/km²

Fleming utilized data from over 250 catchment basins in the world to derive mean annual suspended load Qs in tons as a function of mean annual discharge Q in cubic feet per second for various vegetal covers: Qs = aQ^n , where a and n are coefficients for various vegetal cover types. The Qs was calculated for No. 2315 station in order to check the mean annual suspended sediment yield of 360 ton/km² estimated. The Qs was found 280 ton/km² taking into consideration the vegetal cover over the Corub river basin. The value of 360 ton/km² is considered to be reasonably satisfactory in view of an order of estimation.

6.5 Probable Flood

The observation of flood peak discharges is being made by EIE at some stream gaging stations located on the Coruh river and its tributaries. The list of the stations together with the measured flood peaks is given in Table 6-17.

The three gaging stations, Nos. 2305, 2323 and 2321, were selected to find probable flood for various return periods at Yusefeli and Artvin damsites.

In the flood frequency analysis, the Gumbel distribution and the log-Pearson Type III distribution were applied. Flood peaks recorded at the three stations are listed in Tables 6-18 6-20. Maximum historical flood peaks are 798 m^3 /sec, 469 m^3 /sec and 89 m^3 /sec for Nos. 2305, 2323 and 2321 stations respectively.

Probable floods for various return periods at the damsites were estimated by summing up the three probable floods at the above stations

Station			Catchment	Observation	Historical Max, Flood	
No.	Name	River	Area (km ²)	Period	Discharge (m ³ /s)	Date
2302	Tev Koprusu	Tortum	1,744	1941 - 68	227	-
2304	Bayburt	Coruh	1,734	1942 - 84	216	Apr.ll
2305	Peterek	Coruh	7,272	1942 - 84	798	May 4
2306	Aralik	Aralik	70	1945 - 56	33	-
2307	Deviskel	Deviskel	193	1945 - 59	21	-
2308	Borcka	Coruh	19,443	1956 - 65	1,169	May 26
2310	Kan	Coruh	4,405	1954 - 63	509	May 7
2311	Dikkale	Tortum	1,457	1965 - 67	74	Jul.5
2314	Catakkopru	Tortum	1,965	1964 - 67	85	May 22
2315	Karsikoy	Coruh	19,654	1965 - 84	2,431	Apr.18
2316	Ispir Kopru	Coruh	5,505	1965 - 84	449	Apr.18
2319	Uluboga	Tortum	1,824	1970 - 74	70	May 11
2320	Laleli	Coruh	4,760	1971 - 84	328	Apr.12
2321	Dutdere	Barhal	586	1972 - 84	89	May 23
2322	Altinsu	Coruh	18,326	1972 - 84	1,018	May 20
2323	Ishan Kopru	Oltu	6,854	1965 - 84	469	May 20

Table 6-17 List of Measured Flood Peaks

			<u>`</u>		
	Date		Discharge (m ³ /sec)	Date	Discharge (m ³ /sec)
16	Apr.	1942	754	22 May 1964	480
7	May	1943	239	28 Apr. 1965	350
4	May	1944	798	1 May 1966	337
10	May	1945	194	13 May 1967	332
13	June	1946	219	18 Apr. 1968	679
5	Apr.	1947	139	14 May 1969	395
30	May	1948	246	15 Apr. 1970	276
13	May	1949	219	9 May 1971	310
8	May	1950	226	1 May 1972	256
3	Мау	1951	166	12 May 1973	238
7	Apr.	1952	239	12 May 1974	310
20	May	1953	226	13 Apr. 1975	241
6	May	1954	317	21 May 1976	369
24	May	1955	144	15 May 1977	402
26	Apr.	1956	206	10 Apr. 1978	412
17	June	1957	232	6 June 1979	247
16	May	1958	213	11 Apr. 1980	580
20	May	1959	401	4 June 1981	267
11	May	1960	578	23 Apr. 1982	390
16	Мау	1961	191	1 June 1983	205
10	Apr.	1962	261	27 May 1984	281
2	June	1963	489	······································	

Table 6-18 Flood Peak Discharges at No. 2305 Station

Date	Discharge (m ³ /sec)	Date	Discharge (m ³ /sec)
18 May 1965	154		
2 May 1966	191		
13 May 1967	249		
18 Apr. 1968	422		
30 Apr. 1969	378		
15 Apr. 1970	146		
17 May 1971	165		
1 May 1972	174		
12 May 1973	205		
13 May 1974	231		
15 May 1975	99.8		
21 May 1976	227		
14 May 1977	220		
18 May 1978	295		
14 June 1979	230		
11 Apr. 1980	263		
5 June 1981	196		······································
19 May 1982	224		
18 May 1983	97.8		
20 May 1984	469		
			an an de sei de ser provinsiones. An anti-anti-anti-anti-anti-anti-anti-anti-

Table 6-19 Flood Peak Discharges at No. 2323 Station

Table 6–20	Flood Peak Discharges at No.	2321 Station
•		

	Table 6–20	Flood Peak Dis	charges at No. 2321 Sta	ition
•	· · ·		· · · · · · · · · · · · · · · · · · ·	
Date	2 	Discharge (m ³ /sec)	Date	Discharge (m ³ /sec)
1 June	1972	70.1		
23 May	1973	89.0		
3 Sept.	1974	80.6		
13 Apr.	1975	69.8		· · · ·
29 June	1976	86.0		
15 May	1977	62.0		
18 June	1978	64.4		
27 June	1979	80.1		
10 Apr.	1980	66.1		· · · · · · · · · · · · · · · · · · ·
23 June	1981	77.9		
12 May	1982	60.3		
6 June	1983	54.8		
17 June	1984	52.6		· · · · · · · · · · · · · · · · · · ·
	· · · · · · · · · · · · · · · · · · ·			·
·····				· · · · · · · · · · · · · · · · · · ·
· · · · · · · · · · · · · · · · · · ·		1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 -		
				<u></u>