



Fig. 5-21 Main Flow Diagram



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
MAIN FLOW DIAGRAM	
SCALE	DRAWING NO.
NON	P - 5


NO	REVISION	DATE	REVISED	CHECKED
			5 -	165

Fig. 5-22 Outline of Coal Handling



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Outline of Coal Handling	
SCALE NON	DRAWING NO. P-6

Fig. 5-23 Coal Handling System Flow Chart




Symbol


UL	Unloader
S/R	Stacker/Reclaimer
S	Stacker
R	Reclaimer
BC	Belt conveyor
BF	Belt feeder
VF	Vibrating feeder
SC	Screen
CR	Crusher
T	Tripper
TH	Truck-Hopper

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
Coal Handling System Flow Chart	
SCALE	DRAWING NO.
NON	P - 7

Fig. 5-24 Diagram of Coal Handling System



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Diagram of Coal Handling System	
SCALE NON	DRAWING NO. P-8




NO	REVISION	DATE	REVISED	CHECKED

Fig. 5-25 HO and LO Flow Diagram

THE ARAB REPUBLIC OF EGYPT	
SIHAI COAL-FIRED THERMAL POWER PROJECT	
TITLE HEAVY OIL AND LIGHT OIL FLOW DIAGRAM	
SCALE	DRAWING NO.
NON	P-9

Fig. 5-26 Flow Diagram of Ash Handling System



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
FLOW DIAGRAM OF ASH HANDLING SYSTEM	
SCALE	DRAWING No.
NON	P - 10

NO	REVISION	DATE	REVISED	CHECKED




Fig. 5-27 One Line Diagram for P/S and T/L

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	One Line Diagram for Power Station and Transmission Line
SCALE	DRAWING NO.
NON	P - 11




Fig. 5-28 Main One Line Diagram

NO	REVISION	DATE	REVISED	CHECKED

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE MAIN ONE LINE DIAGRAM	
SCALE NON	DRAWING NO. P-12







Fig. 5-29 Plant Interlock Diagram

Symbol	Explanation
→	Electrical line
→	Hydraulic line
→	Mechanical line
→	Pneumatic line
□	Motion
□	Hand operation
→	"OR" logic
→	"AND" logic
→	"NOT" logic
→	"Wipe out" logic
⊖	Time delay relay
△	2 out of 3 detection


Basic Plant Interlock	
Trouble	Trip
Electrical trouble	E → T → B
Turbine trouble	T → E → B
Boiler trouble	B → T → E
Plant Emergency trip "PB"	B → T → E
E; Electric Section	
T; Turbin Section	
B; Boiler Section	

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE PLANT INTERLOCK DIAGRAM	
SCALE NON	DRAWING NO. P-13

Fig. 5-30 Machinery Arrangement Plan of Ayun Musa P/S Outdoor Switch Yard



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
MACHINERY ARRANGEMENT PLAN OF AYUN MUSA P/S OUTDOOR SWITCH YARD	
SCALE	DRAWING NO.
	P - 14



Symbol	Main Equipment Specification	No.
U L	1,300 T/H Unloader	2
S R	3,200/1,200 T/H Stacker/Reclaimer	1
S	3,200 T/H Stacker	1
R	1,200 T/H Reclaimer	2
T H	25 T Truck Hopper	4
M G	Magnet Separator	5
C S	Conveyor Scale	6
S M	Sampling Equipment	2
B H	300 T x 2 Mix Bin	1
V F	100 - 500 T/H Feeder	4
S C	500 T/H Screen	2
C R	75 T/H Crusher	2
T	500 T/H Toripper	2

Fig. 5-31 Coal Handling System Plot Plan

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE COAL HANDLING SYSTEM PLOT PLAN	
SCALE	DRAWING NO.
	P - 15

5-2-3 Civil Works

1) Civil Works

a. Land Reclamation

a) Grounds for determination of EL+4.000 of ground level

- i. The elevation in Egypt is established on the basis of the Mean Sea Level at Alexandria Port.
- ii. EL±0 is +1.145 Datum Level at Ayun Musa, and the lower water level is C.D.L+0.400 and the high water level is C.D.L+1.900. (Refer to attached chart "Relationship between Tidal Levels.")
- iii. The significant wave height for this project is +1.500 m.
- iv. The ground level of the site for this project will be high water level + significant wave height + Free board. Thus,

In C.D.L expression:


$$1.900 \text{ m} + 1.500 \text{ m} + 1.745 \text{ m} = +5.145 \text{ m}$$

In EL expression:

$$0.755 \text{ m} + 1.500 \text{ m} + 1.745 \text{ m} = +4.000 \text{ m}$$

The ground level of Abu-Sultan power plant in Ismailiya is EL+4.000.

Fig. 5-32 Relationship between Tidal Levels



b) Compacted fill material

Material to be used for compacted fill shall be selected granular material conforming to the requirements for soil group GW, GP, GM, GC or SW from classification of soil.

Table 5-15 Unified Soil Classification Including Identification and Description

Major division	Group symbol	Typical name	Field identification procedures ^b	Laboratory classification criteria ^a
Clean gravels (little or no fines)	GW	Well graded gravels, gravel-sand mixtures, little or no fines	Wide range in grain sizes and substantial amounts of all intermediate particle sizes	$D_{15}/D_{50} > 4$ $1 < D_{30}/D_{10} < 3$ D_{10}, D_{30}, D_{50} = sizes corresponding to 10, 30, and 60% on grain-size curve Not meeting all gradation requirements for GW
	GP	Poorly graded gravels or gravel-sand mixtures, little or no fines	Predominantly one size, or a range of sizes with some intermediate sizes missing	
Gravels with fines (appreciable amount of fines)	GM	Silty gravels, gravel-sand-silt mixtures	Nonplastic fines or fines with low plasticity (see 31L soils)	Atterberg limits below A line or $PI < 4$ Atterberg limits above A line with $PI > 7$ Soils above A line with $4 < PI < 7$ are border-line cases, require use of dual symbols
	GC	Clayey gravels, gravel-sand-clay mixtures	Plastic fines (see CL soils)	
Sands (little or no fines)	SW	2. Sands (more than half of coarse fraction smaller than No. 4 sieve) ^c		$D_{15}/D_{50} > 5$ $1 < D_{30}/D_{10} < 3$
		Well graded sands, gravelly sands, little or no fines	Wide range in grain sizes and substantial amounts of all intermediate particle sizes	

G : Gravel M : Silt
 W : Well-graded C : Clay
 P : Poorly graded S : Sand

c) Earth work

- i. Prior to commence fill work, top soil shall be free from trash, vegetation or other debris.
- ii. Fill shall be compacted in layers not exceeding 0.200 m in thickness from original surface to specified ground level.
- iii. Slope of fill shall be 1:1.8.

d) Drainage system


- i. Drainage system shall be furnished street drain which locate inside of fence in the plant and street drain shall be connected catchment pond.
- ii. Catchment pond shall be capacity of 10 m³.
- iii. Catchment pond shall be able to set submerged pump.

b. Circulating Water System

a) Intake canal

- i. Circulating water shall be clean and low-temperature during the whole of year.
- ii. Intake canal is not influenced by water from outlet of discharge.
- iii. Typical section of intake canal is studied on the basis of the design conditions.

Fig. 5-33 Intake Canal



Required Discharge (1,200 MW)	61.4 m ³ /s
Velocity of low water level	
at tidal condition	0.30 m/s
Coefficient of roughness	0.05
Head loss (L.W.L at tidal condition)	0.040 m
Length of intake canal	L = 1,472 m

iv. Consideration on the intake canal water velocity to be taken into account are the following items:

- i) Intake canal velocity should be fairly low for effective sedimentation of fine particles like small sand.

$$L = \frac{H}{U} \times V$$

where,

L: Required length of intake canal

H: Sedimentation depth, (5.500 m - 0.745 m) at L.W.L tidal condition

U: Sedimentation speed in case of 0.080 mm particles, 0.006 m/s

V: Velocity in the intake canal 0.30 m/s at L.W.L tidal condition

$$L = \frac{(5.500 - 0.745)}{0.006} \times 0.30 = 238.000 \text{ m} \quad 1,472 \text{ m}$$

- ii) If the flow velocity increases, the loss head would increase in proportion to the square of the velocity, which could cause an increase of the condenser circulating water pump power consumption.

The loss head at 0.30 m/s of flow velocity is calculated as follows.

Loss due to inflow	He = 0.001 m
Loss due to gradual	
of flow condition	Hgc = 0.001 m
Loss due to friction	Hf = 0.038 m
<u>Loss due to bends</u>	<u>Hbc = 0.000 m</u>
Total	H = 0.040 m

This loss head of 0.040 m is negligibly small as compared with the loss head between the pumping structure and the condenser.

b) Circulating water pipeline

P.C. pipe, culvert box and steel pipe studied construction cost and construction period.

As a result, P.C. pipe of construction cost and construction period is superior to culvert box and steel pipe.


Item	Design Discharge	Construction Cost	Reference of Construction Period
Culvert Box	30.7 m ³ /s	6.1 x 10 ⁶ LE	3
Steel Pipe	30.7 m ³ /s	5.6 x 10 ⁶ LE	2
P.C. Pipe	30.7 m ³ /s	4.0 x 10 ⁶ LE	1

(Construction cost includes material.)

i. P.C. pipe shall be subjected to following loads.

Normal operating pressure, transient pressure, earth pressure, wheel load, buoyance force

ii. Dimension of P.C. pipe is studied by the design conditions.



Typical Section


Velocity in the P.C. pipe $V = 2.4$ m/s

- iii. Manholes shall be provided three (3) locations on the circulating pipeline, and air valves shall be located in conjunction with the manholes.

c) Intake pumping structure


- i. Intake pumping structure in this project shall be provided circulating water for the first stage 600 MW plant only, and shall be a reinforced concrete box like structure.
- ii. The structure shall be sized to accommodate four screenwells for 4.400 m wide travelling screen on the inlet side, and shall be provided with four sets of gate for the screenwells and four sets of gate for the pump wells.
- iii. Level of bottom slab of the structure shall be EL-5.500, and level of top slab shall be EL+4.000.
- iv. The structure shall include bar screen to prevent large floating or submerged objects from entering inlet.

- v. Velocity water through bar screen shall not exceed 0.47 m/s at low water level tidal conditions.
- vi. The structure shall be furnished to prevent entrance of sand from outdoor.
- vii. Building shall be made on the structure and plan crane.
- viii. Extension for the structure shall be partly made in advance for 1,200 MW.



Longitudinal Section

- ix. Head loss will be 0.072 m at L.W.L tidal conditions as coefficient of roughness 0.016.
- d) Discharge channel and discharge canal
- i. Discharge channel and discharge canal shall handle the discharge from the circulating water system for the second stage 1,200 MW only.
 - ii. The elevation of discharge shall be such that maximum vacuum at any point in the circulating water system shall not exceed 8.0 m under any conditions.
 - iii. Discharge weir shall be provided to dissipate energy in the water.




Intake Pumping Structure

iv. Outlet

Water from condenser shall not be given to influence circulating water at point of intake canal.

v. Determination of outlet



Typical Section


Item		First Stage 600MW	Second Stage 1,200MW
L.W.L. tidal conditions	Sea Level in Outlet	EL-0.745	EL-0.745
	Discharge	30.7m ³ /s	61.4m ³ /s
	Velocity	0.78m/s	1.11m/s
H.W.L. tidal conditions	Sea Level in Outlet	EL+0.755	EL+0.755
	Discharge	30.7m ³ /s	61.4m ³ /s
	Velocity	0.46m/s	0.83m/s
Coefficient of roughness		0.05	0.05

c. Fuel Oil Storage Tank Foundation & Oil Dyke

- a) These storage tanks shall be provided for the first stage 600 MW only.

	Fuel Oil Storage	Light Oil Storage
Diameter (m)	50.360 x 3 pcs	15.500 x 1 pc
Height (m)	18.260	10.660
Capacity (T)	34,000 x 3 pcs	1,800 x 1 pc

- b) The minimum spacing (shell to shell) between any two adjacent tanks shall be more than height of the tank.
- c) The capacity of the dyked area shall impound 110% of the total capacity of required fuel oil.
- d) The minimum distance from fuel oil tank shell to an exterior dyke wall shall be 15.000 m, but not smaller than 1/2 times the height of tank.
- e) The minimum distance from light oil tank shell to an exterior dyke wall shall be 1/3 times the tank height.
- f) Exterior dyke wall shall be liquid tight reinforced concrete.
- g) Tank foundation shall be displacement of gravel and sand.
- h) The bearing capacity of displacement shall confirm $K_{30} \geq 20 \text{ kg/cm}^2$ by using plate bearing test.



DETAIL OF TANK FOUNDATION

d. Coal Storage Yard & Coal Handling

- a) Foundations for belt conveyor of coal handling shall be decided to determine sliding and overturning as spread foundation.
- b) Foundations of stacker and reclaimer shall be spread foundation.
- c) Retaining wall shall be provided to prevent coal from falling in the coal storage yard.
- d) Tie-bar of stacker and reclaimer shall be placed to keep the gauge of rail every 9.000 m in the coal storage yard.

e. Ash Disposal Facilities

a) Ash pond facilities are fomulated as follows:

1st Stage with 600 MW : 3,200,000 m³ for 10 years

2nd Stage (Long-range plan)

600 MW : 2,560,000 m³ for 8 years

600 MW : 12,800,000 m³ for 40 years

b) Determination of unit weight of ash

Unit weight of ash (W) is 0.8 t/m³ and specific gravity of ash (ρ) is 2.2 t/m³.

Solid of volume percentage of ash

$$= \frac{\text{Unit weight of ash (W)}}{\text{Specific gravity of ash } (\rho)} \times 100$$

$$= (0.8/2.2) \times 100 = 36\%$$

Unit weight of ash above H.W.L. + 0.755 meters will be generally 1.2 t/m³ of dry density (rd) at optimum moisture content of 20% to 30%.

Unit weight of ash to be planned is,

$$= \frac{2.875 \times 1.2 + 2.255 \times 0.8}{5.130} = 1.0 \text{ t/m}^3$$

Fig. 5-34 Typical Section of Revetment for Ash Pond




Fig. 5-35(1) Area for Ash Pond

ASH DISPOSAL FACILITIES OF 1ST STAGE
FOR 10-YEAR OPERATION OF 600 MW POWER PLANT

An ash pond with a disposal capacity of 3,200,000 m³ required for 10-year operation will be built in the sea-side of the power station. The revetment of the ash pond in the sea will be built on a level of about EL-1.500 m for an economical purpose. Ash will be disposed up to a level of EL+3.650 m and thereafter the suitable soil will be filled up with a thickness of 0.350 m for leveling at EL+4.000 m.





TABLE FOR REQUIRED CAPACITY

E L (m)	1st STAGE (600MW×10) EL-1.5m~EL+4.0m	
	A (m ²)	V (m ³)
- 5		
- 4		
- 3		
- 2		
- 1	95,000	24,000
± 0	715,000	429,000
+ 1	745,000	1,159,000
+ 2	810,000	1,936,000
+ 3	902,000	2,884,000
+ 4	953,000	3,550,000
+ 5		
+ 6		
REQUIRED CAPACITY		3,200,000




1ST STAGE (600MW-10 YR.)

REQUIRED CAPACITY V=3,200,000 m³

ACTUAL CAPACITY V=3,550,000 m³

HEIGHT OF REVETMENT EL-1.5 m~EL+4.0 m



ASH DISPOSAL FACILITIES OF AND AFTER 2ND STAGE
FOR 8-YEAR OPERATION OF 600 MW POWER PLANT
(Long-range Plan)

Another ash pond with a disposal capacity of 2,560,000 m³ required for 8-year operation after 1st stage will be built adjacent to and in the direction of south of the previous ash pond. The revetment of the ash pond in the sea and filling method are the same with those planned in the 1st stage.

Fig. 5-35(2) Area for Ash Pond

PLAN






TABLE FOR REQUIRED CAPACITY

EL (m)	2nd STAGE (a)(600MW×8) EL-1.5 m~EL+4.0 m	
	A (m ²)	V (m ³)
- 5		
- 4		
- 3		
- 2		
- 1	120,000	30,000
± 0	372,000	276,000
+ 1	441,000	683,000
+ 2	543,000	1,175,000
+ 3	675,000	1,817,000
+ 4	675,000	2,778,000
+ 5		
+ 6		
REQUIRED CAPACITY		2,560,000



2ND STAGE (600MW-8 YR.)

REQUIRED CAPACITY V=2,560,000 m³
ACTUAL CAPACITY V=2,778,000 m³
HEIGHT OF REVETMENT EL-1.5 m~EL+4.0 m



TYPICAL SECTION FOR REVETMENT

ASH DISPOSAL FACILITIES OF AND AFTER 2ND STAGE FOR 40-YEAR OPERATION OF 600 MW POWER PLANT (Long-range Plan)

Further expansion of the ash pond to accommodate ash of 12,800,000 m³ for 40-year operation of 600 MW power plant will be planned. The required capacity of the pond is so large that two types of the pond, Type-A and Type-B are considered.

Type-A

Where a level after ash disposal is set at EL+4.000 m, the bottom level of the revetment in the sea will be EL-5.000 m.

(Fig. 5-35(3) Area for Ash Pond





TABLE FOR REQUIRED CAPACITY

EL (m)	2nd STAGE (b) TYPE-A) EL-5.5m~EL+4.0m	
	A (m ³)	V (m ³)
- 5	117,000	29,000
- 4	449,000	312,000
- 3	673,000	873,000
- 2	848,000	1,633,000
- 1	1,141,000	2,584,000
± 0	1,668,000	3,988,000
+ 1	1,970,000	5,543,000
+ 2	2,292,000	7,937,000
+ 3	2,832,000	10,498,000
+ 4	2,832,000	13,330,000
+ 5		
+ 6		
REQUIRED CAPACITY		12,800,000



2ND STAGE : (600MW-40YR) TYPE-A
 REQUIRED CAPACITY V=12,800,000 m³
 ACTUAL CAPACITY V=13,330,000 m³
 HEIGHT OF REVETMENT EL-5.5m~EL+4.0m




Fig. 5-35(4) Area for Ash Pond

Type-B

At first, the size of the revetment and filling level will be set at EL-1.500 m in the sea bottom and at EL+4.000 m as same as the first stage. After that additional revetment with a height of 2.000 m will be built on the filled-up disposal area.






TABLE FOR REQUIRED CAPACITY

EL (m)	(600MW×40) (TYPE-B) EL-1.5m~EL+6.0m	
	A (m ²)	V (m ³)
- 5		
- 4		
- 3		
- 2		
- 1	234,000	59,000
± 0	761,000	556,000
+ 1	1,063,000	1,204,000
+ 2	1,385,000	2,691,000
+ 3	1,925,000	4,346,000
+ 4	1,925,000	6,271,000
+ 5	3,553,000	9,824,000
+ 6	3,553,000	13,377,000
REQUIRED CAPACITY		12,800,000



2ND STAGE (600MW-40YR.) TYPE-B

REQUIRED CAPACITY V=12,800,000 m³
 ACTUAL CAPACITY V=13,377,000 m³
 HEIGHT OF REVETMENT EL-1.5m~EL+6.0m



5-2-4 Harbor Facilities

1) Design Conditions for Preliminary Design

a. Design Datum Level

For the design datum level, the elevation level (E.L.) is adopted.

In the topographic map of Egypt, the mean sea level at Alexandria is used as the base level. It was made clear during the field survey, that the mean sea level of the Gulf of Suez was 6 cm higher than that of Alexandria Port. (Based on the survey by the Survey Authority of Egypt).

b. Chart Datum Level

It was confirmed during the field survey that the bench mark at the Suez Canal Authority situated by the Canal in Suez City was EL-1.145 m. This datum level is considered to agree with the chart datum level (C.D.L.).

c. Relation between Design Datum Level and Chart Datum Level

- EL 0.00 m = C.D.L. +1.145 m

- Mean high water springs (H.W.L.)

= C.D.L +1.9 m

- Mean low water springs (L.W.L)

= C.D.L +0.4 m

The relation between the elevation and the chart datum level is shown in the section of civil facilities.

d. Field Conditions

a) Wind velocity Maximum 35 m/sec

(Presumed from data obtained at site survey)

b) Wave height

Maximum wave height $H_{max} = 2.5$ m

(Data from Meteorological Authority)

Significant wave height $H_{1/3} = 1.3$ m - 1.5 m

Period -

Wave direction South

c) Currents Maximum 1.5 knot

d) Tide

Tidal levels referred to Datum of Sounding

Place	Lat. N	Long. E	Heights in meters above datum			
			MHWS (HWL)	MHWN	MLWN	MLWS (LWL)
Suez	29°56'	32°33'	1.9	1.6	0.7	0.4

e) Littoral drift

Of littoral draft nearer to the shore nothing is known.

According to information from Suez Port Authority, bathymetric survey have revealed that only very little basin siltation has taken place since the last dredging of port Ibrahim in 1966, when the commercial basin was dredged to 9 m below MLW and Arsenal Basin to 7 m below MLW.

Also, studies of sedimentation patterns in Gulf of Suez reveal that little movement of sedimentation appear, but they are not a conspicuous phenomenon. As the waves and tidal currents in Gulf of Suez are small, a littoral drift phenomenon would not be large.

e. Design Conditions of Berths and Causeway

- a) Wave height in design $H_{1/3} = 1.5$ m
(significant wave height)
- b) Wind velocity in design $U_{max} = 35$ m/sec
(Maximum wind velocity)
- c) Seismic coefficient $K = 0.05$
- d) Current velocity $V_{max} = 1.5$ knot
- e) Berthing velocity of ship
- i. Coaler 0.15 m/sec
 - ii. Oil tanker 0.15 m/sec
 - iii. Small craft 0.2 m/sec
- f) Surcharge
- i. Coaler berth 3 t/m²
 - ii. Oil tanker berth 1 t/m²
 - iii. Small craft berth 1 t/m²

*Temporary surcharge

$$= \frac{1}{2} \times (\text{Surcharge in ordinary condition})$$

- g) Unloader crane
- i. Weight 1,100 t 2 unit
 - ii. Rail gauge 20 m
- h) Height of wharf crown

Crown height of berths was determined considering sea conditions (wave height) and utility for users.

HWL + Wave height + Free board

$$1.9 + 1.5 + 0.745 = +4.145 \text{ m (CDL)}$$

$$4.145 - 1.145 = +3 \text{ m (EL)}$$

- i) The lay of the sea bed

The sea topographical map and the sounding map, etc. will be shown in the following page.

j) Soil characteristics

As no data of soil investigation in the proposed site of harbor construction, the data of 3 boring logs drilled by EEA at the points of turbine/generator, coal storage center and cooling water intake pit in the power plant area and the data of bore holes of Suez Channel around were studied and arranged to use into the proposed port.

The location and the result of soil investigation above mentioned are attached following or additional document as reference data.

. N-value in foundation of pile's tops

N = 24.6 (supplementary values)

. N-value balanced from sea bed to pile's tops

N = 19.8 (supplementary values)

. Angle of internal friction of sand

$\phi = 35^\circ$

k) Kind of materials used

The cement used shall be under water cement (Type V).

f. Design will be made based on the Technical Standard for Construction of Harbor Facilities of Japan.


2) Preliminary Design of Harbor Facilities

a. Layout of the Harbor Facility shows next page.

b. Mooring Facility

a) Wharf of unloading for coal


Typical section is decided as follow.



(N. B.) . Structural type shall be more studied, if it is possible to be find more economical one after soil investigation.


. Kind of cement used shall be unader water cement (Type V).

Fig. 5-36 Layout of Harbour Facility




b) Wharf of unloading for oil

Typical section of the wharf of unloading for oil is decided as follow.




c) Wharf of small craft

Typical section of the wharf of small craft



c. Jetty (Road)

Typical section of Jetty (Road) is decided as follow.



- i. Filling by dredged suitable material shall be filled up EL+1.000 in order to make cheaper construction cost.
 - ii. Filling and dredged materials shall be made balance of earth volume.
 - iii. Slope of filling by dredged material will be assumed 1:50 in consideration of stability.
 - iv. Width of causeway shall be 20.000 m in consideration of belt conveyor, road and pipe line.
- d. Schematic Examination of Section of Major Harbour Facility
- a) Wharf of unloading for coal
 - i. Impacted force by the ship and fender
Impacted force by the ship shall be calculated with an appropriate formula.

Table 5-16 Result of Computation

Item	Wharf of Coal	Wharf of Oil
Deadweight tonnage (D/W)	60,000	5,000
Drainage tonnage (T)	78,000	6,600
Added weight (T)	29,000	3,300
Virtual Weight of ship (T)	110,000	9,900
Berthing Velocity of ship (m/s)	0.15	0.15
Effective Berthing energy of ship (t.m)	62.6	5.7
Rubber Fender to be used	CH-1,300	V-400H x 2,000
Absorbing energy of rubber fender (t.m)	74.4	7.2
Reaction force of rubber fender (t)	149	66

* Wharf for Coal

Effective berthing energy of ship < Absorbing energy of rubber fender
62.5 T < 74.4 T ----- Satisfy

* Wharf for Oil

Effective berthing energy of ship < Absorbing energy of rubber fender
5.7 T < 7.2 T ----- Satisfy

ii. Determination of batter piles

i). Design conditions

Table 5-17 External Force of Design

Unit: ton

Load conditions	Normal conditions		Impacted force by ship		earthquake (extreme)	
	W = 3.0 t/m ² V	H	W = 3.0 t/m ² V	H	W = 1.5 t/m ² V	H
Load						
Surcharge on the slab	375.0	-	(-) 375.0	-	187.5	9.38
Dead load of slab	262.5	-	262.5	-	262.5	13.13
Dead load of piles	V1 = 11.7 V2 = 23.4	- -	V1 = 11.7 V2 = 23.4	-	V1 = 11.7 V2 = 23.4	0.29
Impacted force by ship	-	-	-	* 50.0	-	-
Total	672.6	-	(297.6) 672.6	50.0	485.1	22.8

* Impacted force by ship can be calculated as 1/3 X reaction of rubber fender.

ii) Pushing and pulling forces from batter piles

Batter piles can be calculated by impacted force by ship.

Pulling capacity of ship 70/3

= 2.33 t < Impacted force by ship = 50 t

Unit : ton

Case	Item	Axial force of batter pile	
		P1	P2
1	Normal condition	69.62	69.62
2	Berthing velocity (without surcharge)	127.40	-65.80
3	Berthing velocity	166.20	-26.98
4	Earthquake	94.24	6.16
Design for axial force		166.20	-65.80

iii) Determination of stress for axial force

. Allowable stresses of steel piles

Compressive stress of axial direction

(The material is STK 41-JIS.)

in $0 < \frac{L}{r} < 93$

$$\sigma_{sa} = 1,400 - 8.4 (L/r - 20)$$

where,

L: Effective buckling length of the pile (cm)

r: Radius of gyration of area for the cross sectional area of pile (cm)

$$\sigma_{sa} = 1,400 - 8.4 (1,660/31.3 - 20)$$

$$= 1,123 \text{ kg/cm}^2$$

. Stresses of batter piles

$$\sigma_s = P/A$$

where,

A: Gross of section area 444.3 cm²

P: Pushing force 166.2 t

$$\begin{aligned}\sigma_s &= \frac{166.2 \times 10^3}{444.3} = 374 \text{ kg/cm}^2 < \sigma_{sa} \\ &= 1.123 \text{ kg/cm}^2 \text{ Satisfy}\end{aligned}$$

iv) Study for embedded length of batter piles

Ultimate bearing capacity can be designed to drive the sand layer.

* Pushing force (P1 = 166.2 t)

$$R_u = 40.N. A_p + (\bar{N}_s/5 \times L_{sU})$$

where,

R_u : Ultimate bearing capacity of the pile (t)

A_p : Area of head top of the pile (0.635 m²)

L_{sU}: Whole skin area of pile (2.88 m x L m)

\bar{N}_s : Mean N value for the total embeded length of the piles

N : N value at head top of the pile

$$N = \frac{N_1 + N_2}{2}$$

$$\bar{N}_s = \frac{(15 + 15 + 15 + 15 + 30 + 28.5)}{6}$$

$$= 19.8$$

$$N_1 = 28.5$$

$$N_2 = \frac{(15 + 15 + 15 + 30 + 28.5)}{5} = 20.7$$

$$N = \frac{28.5 + 20.7}{2} = 24.6$$

$$R_u = 40 \times 24.6 \times 0.635 +$$

$$(19.8/5 \times 17.6 \times 2.88) = 825.54 \text{ t}$$

$$\text{Safety factor } F = \frac{R_u}{P_1} = \frac{825.54}{166.2} = 4.97 > 2.5 \quad (\text{Satisfied})$$

* Extracting force ($P_2 = -65.8 \text{ t}$)

$$R_u' = 19.8/5 \times 17.6 \times 2.88 = 200.7 \text{ t}$$

$$\text{Safety factor } F = \frac{200.7}{65.6} = 3.05 > 3.0 \quad (\text{Satisfied})$$

R_u' : Resistance for extracting force
of pile

iii. Determination of vertical pile (for one rigid
frame 5 piles)

i) Design conditions

Unit: ton

	Normal Condition $W = 3 \text{ t/m}^2$		Earthquake $W = 1.5 \text{ t/m}^2$		During Operation Storm	
	V	H	V	H	V	V
Surcharge on the slab	375	-	187.5	9.38	-	-
Dead load of slab	262.5	-	262.5	13.13		
Wheel load	-	-	-	-	242.1*	264.1*
Total	637.5	-	450	22.50	242.1	264.1

* for one support point

Unit load per travel wheel are as shown in the following
figure case (1)

ii) Characteristic length of pile

$$= \sqrt[4]{\frac{E_s}{4EI}}$$

$$K_r = 0.15 N = 0.15 \times 15 = 2.25 \text{ kg/cm}^3$$

$$E_s = K_r B = 2.25 \times 90 = 202.5 \text{ kg/cm}^2$$

$$EI = 2.1 \times 10^6 \times 43.4 \times 10^4$$

$$= 91.14 \times 10^{10}$$

$$= \sqrt[4]{\frac{202.5}{4 \times 91.14 \times 10^{10}}} = 0.00273 \text{ cm}^{-1}$$

$$= 0.273 \text{ m}^{-1}$$

$$= 3.66 \text{ m}$$

$h = 18.50$ m (Pile length from sea bottom)

$$\beta h = 0.273 \times 18.5 = 5.05$$

iii) Bending moment

$$\phi_0(\beta h) = \frac{1 + \beta h}{2\beta h} = 0.60$$

$$M_0 = 4.5 \times 18.5 \times 0.6 = 49.95 \text{ t.m}$$

iv) Stress

	$= \frac{P}{A} + \frac{H}{Z}$	sa
Normal conditions	$\frac{637,500/5}{444.3} = 287.0$	1.072
Earthquake	$\frac{90 \times 10^3}{444.3} + \frac{49.95 \times 10^3}{9,640} = 720.6$	1.608
During operation	$\frac{242,100}{444.3} = 545$	1,072
Storm	$\frac{264,100}{444.3} = 594$	1,608

Slenderness

$$\frac{L}{r} = \frac{1,850}{31.3} = 59$$

$$\sigma_{sa} = 1,400 - 8.4 (59 - 20) = 1.072 \text{ kg/cm}^2$$

$$\text{Extreme } \sigma_{sa} = 1.072 \times 1.5 = 1.608$$

v) Study for pushing force (Storm)

$$R_u = 40 N A_p + \frac{\bar{N}}{S} \cdot L_s U$$

$$= 40 \times 24.6 \times 0.625 + \left(\frac{19.8}{5}\right) \times 17.6 \times 2.88$$

$$= 825.54 \text{ t}$$

$$\text{Safety factor } F = \frac{R_u}{P}$$

$$= \frac{825.54}{264.1} = 3.1 > 2.5 \quad \text{Satisfy}$$

b) Wharf of unloading for oil

i. Result of safety factor and bearing capacity of rubble base


Section \ Item	Normal condition		Earthquake	
	Sliding	Overturning	Sliding	Overturning
EL-2.00	1.73	3.04	1.40	2.44
EL-4.50	1.89	2.46	1.44	1.89
EL-6.50	1.76	1.46	1.32	1.13
EL-8.50	2.05	2.88	1.52	1.85
Compressive in forward of wall	Upper rubble mound	t/m ² 37.51	t/m ² 49.60	
do.	Lower	29.33	34.67	
Allowable bearing capacity		52.60	47.080	

ii. Result of examination for sliding in base

Normal condition $F = 1.06 > 1.00$ Earthquake $F = 1.353 > 1.00$

c). Design condition to be calculated (for reference)

Fig. 5-38 GEOLOGICAL SECTION FOR
BOREHOLES ALONG AYUN MUSA



() : SUPPLEMENTARY VALUES

d) Corrosion control

Mortal lining with fiberglass reinforced plastic cover shall be placed above -0.6 m CDL (splash and tidal zone) and tar-epo coating shall be painted below -0.6 m CDL till one m depth from under ground and aluminum anode as Cathodic protection shall be set for getting the effect of corrosion control below Mean Sea Level. Anode plates shall be set each pile below M.S.L. Protective current densities will be taken below typical values or more.

In sea water 0.1 A/m²

In rubble work 0.05 A/m²

In soil (below sea water) 0.02 A/m²

e. Fender

Coaler berth Rubber fender C-1300 type
(25 - 30 m pitch)

Oil tanker berth Rubber fender V-400H type
(10 - 20 m pitch)

Small craft berth Rubber fender V-150H type
(5 - 10 m pitch)

f. Post

Tractive forces on post

	Bollard	Bitt
Coaler berth	150 t x 2 nos	70 t (25 - 30 m pitch)
Oil tanker berth	50 t x 2 nos	25 t (20 - 25 m pitch)
Small craft berth	25 t x 2 nos	15 t (10 - 15 m pitch)

g. Channel

a) Length of channel

The length of a channel at a harbour entrance and the area of a continuous moving basin shall be kept 5 time of ship length or more by considering the stopping distance of the ship.

Generally, two or three tug boats will be used for 60,000 DWT-class ship, the length of the channel was determined as 1,300 m into considering above situations.

b) Width of channel

The width of channel shall be applied follows in accordance with the length of objective ship, the width of objective ship, remarkable large traffic volume, meteorological and sea conditions.

1. The length or more of objective ship, in case of a channel crossed by sailing ships.
2. Half length or more of objective ship, in case of a channel not crossed by sailing ships.

Width of channel was determined as 200 m in considering length of channel and use of tug boat.

Water depth of channel was determined as same as the depth of coaler berth.

h. Basins

This basins used for ship maneuvering (mooring, releasing, turning), not for anchorage or mooring with two anchors.

The area of a basin for turning of the bow of ship shall exceed an area of circle with the radius of 1.5 times the overall length of the ship. For the turning of the bow of ship by using an anchor or using tug boats, the area should exceed an area of circle with the radius of the overall length of the ship.

The area of basin was determined calculation above mentioned adding freeboard. Water depth was taken as the same as each berth.

a) Basin for coaler

$$\text{Area } 500 \text{ m} \times 550 \text{ m} = 275,000 \text{ m}^2$$

$$\text{Water depth EL-16 m (C.D.L -14.855 m)}$$

b) Basin for oil tanker

$$\text{Area } 350 \times 380 = 133,000 \text{ m}^2$$

$$\text{Water depth EL-8.5 m (C.D.L -7.355 m)}$$

c) Basin for small craft

$$\text{Area } 140 \times 150 = 21,000 \text{ m}^2$$

$$\text{Water depth EL-5.0 m (C.D.L -3.855 m)}$$

i. Dredging

Side slopes of channel and basins

The grade of side slopes was calculated as 1:3 in considering permanent stability after dredging.

At the proposed area, break waters are not necessary because of small waves and currents.

Dredging soil volume, 3,900,000 m³ will be dredged by cutter suction pump dredger.

j. Rough Quantities of Major Materials

Major Material	Quantities
Concrete	20,000 m ³
Stone (20 - 500 kg)	100,000 m ³
Stone (0 - 20 kg)	20,000 m ³
Sand	150,000 m ³
Steel pipe pile	5,500 t
	(900 ϕ , t - 16, L = 34 m)
Steel bar (Round)	100 t
Steel bar (Deformed)	900 t
Fender	20 nos
Bit, etc.	23 nos
Marking sign, etc.	15 nos

k. Aggregates used

Aggregates will be transported from following the place of production..

a) Ataqqa

Rubble and Armor stone	20 - 1,000 kg (each size)
Stone for rubble backing	0 - 50 kg
Crushed stone	5 - 10 kg
Crushed stone coarse aggregate	20 m/m, 40 m/m, 50 m/m
Sand & fine aggregate	

Transportation to the site

Water way by stone (sand) berge	dist. 10 km
On road by truck	dist. 50 km

b) Kabret

Sand and fine aggregate

By truck

dist. 35 km

c) Fanara

Gravel and coarse aggregate

By truck


dist. 50 km

1. Cement

Halkis Cement Company at Ataga in Suez shall supply cement which apply International Standard.

Fig. 5-40 Quarry Sites

S. = 1:250,000



m. Water Supply for Construction Work

After commencement of order, contractors shall construct a RO Desalination plant as temporary. Before operation of this plant, water for construction will be transported from Port Tewfic or private jetty owned by Suez Petroleum Company by water barge or tank rolly.

n. Labor Supply

Most of laborers can be got in Suez City where population is about 0.4 million.

A lot of skilled laborers from the project of New Aswan High Dam completed already are living in Suez. Contractors can employ them without arrangement for their accommodations.

Laborers as commuters from Suez will be able to attend their working places about half hour's commute using bus and transportation boat.

Divers and some specialists of works will be employed from foreign countries.

o. Machinery & Equipment for Construction Works

Some kind of machineries and equipments in Egypt are available to use as rental or subcontractor.

But, generally, rental cost is rather expensive in comparison with normal depreciation.

Available machineries & equipments to arrange in Egypt are shown below list.

List of Machineries & Equipments

Dump truck	6 t, 12 t, 25 t, 40 t
Truck	6 t, 25 t
Trailer	25 t, 45 t
Transportation boat	20 - 30 persons
Bus, micro bus	
Floating crane	200 t, 500 t
Tug boat	1,500 HP
Motor scraper	24 m ³ , 16 m ³
Bulldozer	11 t
Truck crane	15 - 20 t

Machineries & equipments not mentioned above shall be imported by contractors, otherwise rented from special organs (for example, Suez Canal Authority).

Dredger	Cutter suction	5,000 HP - 8,000 HP	1 fleet
	Grub type	2 - 8 m ³ bucket	1 - 2 fleet
Bucket-crane pontoon		2 - 4 m ³	2 - 3 fleet
Piling pontoon		Hummer 6 - 9 t	1 fleet
Piling pontoon		Hummer 2 - 4 t	1 fleet
Flat barge		100 - 300 t	some fleet
Crane barge		30 - 60 t	a few fleet




Fig. 5-41 Sounding Map




Fig. 5-44 North Ayun Musa (Boring Location)

Fig. 5-45 GEOLOGICAL SECTION FOR BOREHOLES ALONG SUEZ CHANNEL





Fig. 5-46 Civil Works



PLAN



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
CIVIL WORKS	
SCALE	DRAWING NO.
1/4,000	C-01





Fig. 5-47 Sectional View of Land Reclamation


THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
SECTIONAL VIEW OF LAND RECLAMATION	
SCALE	DRAWING NO.
1/2,000	C-02

Fig. 5-48 Intake and Discharge Channel for Circulating Water System




COL(m)	EL (m)
+7.0	+6.0
+6.0	+5.0
+5.145	+4.0
+5.0	+3.0
+4.0	+2.0
+3.0	+1.0
+2.0	+0.755
+1.145	+1.0
+1.0	+0.745
+0.0	-1.0


TABLE OF TIDAL




SECTION 1-1




SECTION 3-3



SECTION 2-2



SECTION 6-6




SECTION 4-4




SECTION 5-5


THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE INTAKE AND DISCHARGE CHANNEL FOR CIRCULATING WATER SYSTEM	
SCALE	DRAWING NO.
1/5,000	C-03
1/2,000	



PLAN



SECTION B-B




SECTION C-C


CDL(m)	EL (m)
+70	+60
+60	+50
+50	+40
+40	+30
+30	+20
+20	+10
+10	0
0	-10
-10	-20
-20	-30
-30	-40
-40	-50
-50	-60
-60	-70

HWL γ +1.200 HWL γ 0.755
 LWL γ +0.900 LWL γ -0.745

TABLE OF TIDAL




SECTION A-A




CIRCULATING WATER PIPE LINE

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE INTAKE PUMPING STRUCTURE FOR CIRCULATING WATER SYSTEM	
SCALE 1/600 1/200	DRAWING NO. C-04


Fig. 5-50 Box Culvert, Channel and Weir for Circulating Water System




NO.	REVISION	DATE	REVISED BY	CHK'D BY




PLAN




SECTION ①-①




DETAIL OF EXTERIOR DYKE



DETAIL OF INTERMEDIATE DYKE



DETAIL OF TANK FOUNDATION




THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Fuel Oil Storage Tank Foundation & Oil Dyke	
SCALE 1/2,000 1/100	DRAWING NO. C-06


NOV. 15TH '83

NO.	REVISION	DATE	BY	CHECKED


5 - 227




PLAN



①-① SECTION
(RECLAIMER)
(STACKER-RECLAIMER)



②-② SECTION
(STACKER)



① DETAIL

() --- STACKER



Fig. 5-52 Coal Storage Yard

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Coal Storage Yard	
SCALE 1/4,000 1/400	DRAWING NO. C-07







Fig. 5-53 Ash Disposal Facility




CDL (m)	EL (m)
+7.0	+6.0
+6.0	+5.0
+5.0	+4.0
+4.0	+3.0
+3.0	+2.0
+2.0	+1.0
+1.0	+0.0
0.0	-1.0
-1.0	-2.0
	-3.0
	-4.0
	-5.0
	-6.0
	-7.0

HWL \pm 1.900 HWL \pm 0.755
 LWL \pm 0.400 LWL \pm -0.745
 +5.145 GL


TABLE OF TIDAL



SECTION C-C



PLAN FOR ASH POND



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Ash Disposal Facility	
SCALE 1/20,000 1/400	DRAWING NO. C-08




Fig. 5-54 Road and Landscaping






Fig. 5-55 Typical Section of Dredging and Land Grading




THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Typical Section of Dredging and Land Grading	
SCALE	DRAWING NO. C-10

NOV. 15th '83

Fig. 5-56 Plan of Harbour and Causeway



PLAN




THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
PLAN OF HARBOUR AND CAUSEWAY	
SCALE	DRAWING NO.
1/10,000	C-11

NO.	REVISION	DATE	REVISED	CHECKED

5 - 232

Fig. 5-57 Front View of Berths




THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Front View of Berths	
SCALE 1/500	DRAWING NO. C-12


NO.	REVISION	DATE	BY	CHECKED	DATE

5 - 233


Fig. 5-58 Detail of Wharf




PLAN




SECTION ④-④
(REVELMENT)




SECTION ③-③
(SMALL CRAFT BERTH)



SECTION ①-①
(COALER BERTH)



SECTION ②-②
(OIL TANKER BERTH)



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE Detail of Wharf	
SCALE 1/2,000 1/400	DRAWING NO. C-13

Fig. 5-59 Detail of Causeway








Fig. 5-59 SECTION OF CAUSE WAY



① DETAIL



② DETAIL



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
DETAIL OF CAUSEWAY	
SCALE	DRAWING NO.
1/2,000	C-14
1/400	
1/40	

