

5-2-5 Architectural Facilities

1) Design Conditions for Main Facilities

a. Soil Conditions and Type of Foundation

Boring test with 3 bore holes was carried out at the site in July 1983. (See attached Borehole Logs Data)

The selection of types of foundations for the buildings and equipment should be made on the basis of the boring data.

Severe conditions against settlement and inclining are required of the foundations of the important heavy structures such as the powerhouse, turbine-generator pedestal, boiler, stack and other major equipment.

Therefore, the foundations of the important structures have to be supported by piles driven to the solid bearing stratum with larger than 50 of N-values and thickness of 5 m or more at the depths of GL-20 to - 30 m or deeper.

For detailed study, the results of many more additional boring tests should be used.

As the piles for the above-mentioned soil conditions, the steel pipe piles or the high strength prestressed concrete piles that can penetrate the relatively hard intermediate layers would be suitable, and the latter concrete piles would be superior from the view point of corrosion resistance and cost.

The locally produced concrete piles would not be able to penetrate the intermediate layers and the special method of drilling the hole with the earth drill would have to be resorted to, if these local piles are to be used.

b. Main Materials

a) Concrete

Under water cement will be used for all the building foundations and the super structures on the wharf for protection of salt damage. Portland cement will be used for the super structures of the other buildings.

Compressive strength at 28 days  $F_c =$  over 210 kg/cm<sup>2</sup>

b) Reinforcing bars

Round bars  $F_y =$  over 2,400 kg/cm<sup>2</sup>

Deformed bars  $F_y =$  over 3,000 kg/cm<sup>2</sup>

c) Structural steel

Rust proofing measures will be taken to the reinforced concrete buildings due to seawater splash.

Rolled steel shape  $F_y =$  over 2,400 kg/cm<sup>2</sup>

2) Preliminary Design of Architectural Facilities

a. Powerhouse

a) Plan and Elevation

i. Based on the equipment layout planned by the power plant design department, column span is planned to best suit the equipment and piping layout and to realize good structural design. The height of story is determined in consideration of the height of equipment, piping space, space for maintenance, etc.

ii. The following rooms are planned in accordance with the plant manning program.

i) Shift room, locker room and toilet for operators on the 2nd floor

- ii) Shift room, locker room and toilet for instrument maintenance crew, on the 1st floor
- iii) Shift room, locker room and toilet for boiler and turbine maintenance crew on the ground floor
- iv) Air conditioning equipment room for air-conditioning of the above rooms, central control room and relay room, on the 1st floor

b) Structural design

i. Loads and load combinations

The following loads are considered in the structural design.

- i) Dead load
- ii) Live load
- iii) Wind load
- iv) Seismic load
- v) Crane load
- vi) Active soil pressure

Combinations of loads are in accordance with the standard employed.

Static analysis is made in principle for the stress analysis of structures.

Design of sections of structural members is made in accordance with the standard employed.

ii. Dead load

Dead load is computed, in principle, on the basis of the actual conditions. Aside from the main equipment load and main piping load, the following specific gravity values are used for main materials.

i) Concrete	2.4 t/m <sup>3</sup>
ii) Structural steel	7.86 t/m <sup>3</sup>
iii) Soil	2.00 t/m <sup>3</sup>
iv) Sand	1.60 t/m <sup>3</sup>

### iii. Live load

Live load includes the load of miscellaneous equipment and miscellaneous piping, and the following values are used for structural frame design with the load at the time of hauling-in of equipment, load of dismantled equipment parts at overhaul and human load.

i) Roof	100 kg/m <sup>2</sup>
ii) Office and shift room	300 kg/m <sup>2</sup>
iii) Turbine room and operating floor	1,500 kg/m <sup>2</sup>
iv) 1st floor and 2nd floor	500 kg/m <sup>2</sup>
v) Control room	800 kg/m <sup>2</sup>
vi) Steel grating floor	500 kg/m <sup>2</sup>
vii) Ground floor	1,000 kg/m <sup>2</sup>
viii) Stair and corridor	500 kg/m <sup>2</sup>

### iv. Wind load

The maximum design wind speed of 35 m/sec is adopted, based on the meteorological statistics.

The vertical distribution of wind load and the net pressure coefficient depending upon shape are in accordance with the standard employed.

### v. Seismic load

The total lateral force is to be obtained by the total weight above ground level multiplied by 0.05.

The distribution of lateral force at individual levels will be in accordance with the standard employed.

vi. Crane load

A 60 ton travelling crane will be installed in the powerhouse, for overhaul and maintenance of equipment.

The maximum wheel pressure of the crane is obtained by the maximum reaction caused by the dead weight of crane and the approaching distance of the hook. The crane load is treated as a moving load of the maximum wheel pressure, and the impact factor in the vertical, lateral and longitudinal directions is considered based on the standard employed.

vii. As the result of the preliminary design on the basis of the foregoing design load conditions, the quantities of main materials are as follows.

Steel frame	5,700 tons
Concrete	13,000 m <sup>3</sup>
Reinforcing bars	1,300 tons
Pile	700 pcs

## c) Design of appurtenant facilities

## i. Ventilating system

Ventilating facilities satisfying the following conditions will be installed for the turbine-generator room, battery room, coal mill room, belt conveyor room, toilet, kitchen and shower room, with the heat generated by the equipment taken into consideration.

	<u>Frequency of Air Change</u>
Turbine-generator room	More than 10 times/hour
Battery room	More than 13 times/hour
Coal mill room	More than 10 times/hour
Belt conveyor room	More than 5 times/hour
Toilet, kitchen and shower room	More than 10 times/hour

As a result of the preliminary design on the basis of the above design conditions, the turbine-generator room will have the forced ventilating system consisting of the roof ventilating fans of 670,000 m<sup>3</sup>/hour capacity and the air supply fans with special inlet air filter for dust and sound proofing.

ii. Air conditioning system

The central control room, relay room, communication equipment room and shift room will be air-conditioned at 21°C and 50% relative humidity.

As a result of the preliminary design, the air conditioning unit of 230,000 kcal/hr of cooling capacity and 29,700 m<sup>3</sup>/hr of air volume will be installed.

iii. Others

Sewage treatment facilities will be installed to treat the sewage and rain water drainage for re-use for irrigation of plants in the power plant grounds.




Fig. 5-60 Powerhouse (Ground Floor)

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
POWERHOUSE (GROUND FLOOR)	
SCALE	DRAWING NO.
1/600	A - 1







Fig. 5-61 Powerhouse (Operating Floor)

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
POWERHOUSE (OPERATING FLOOR)	
SCALE	DRAWING NO.
1/600	A - 2

Fig. 5-62 Sectional View of Powerhouse



THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
SECTIONAL VIEW OF POWERHOUSE	
SCALE	DRAWING NO.
1/400	A - 3 - 1




Fig. 5-63 Sectional View of Duct system

THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
SECTIONAL VIEW OF DUCT SYSTEM	
SCALE	DRAWING NO.
1/400	A - 3 - 2



b. Service Building

a) Plan and elevation

Based on the manning program planned by the power plant design department, the following facilities, room and systems are planned to be arranged in the service building.

- i. Superintendent room, engineer rooms, conference rooms, locker rooms, shower rooms, toilets, etc.
- ii. Chemical laboratory and chemist office
- iii. Simulator room and class rooms for training
- iv. Dining room and canteen for guests and engineers
- v. Medical office for first aid
- vi. Mechanical and electrical rooms for airconditioners
- vii. Height of stories is planned in consideration of ceiling height and airconditioner duct space

b) Structural design

i. Loads and load combinations

The following loads are considered in the structural design.

- i) Dead load
- ii) Live load
- iii) Seismic load

Combinations of loads are in accordance with the standard employed.

Static analysis is made in principle for the other analysis of structures. Design of sections of structural members is made in accordance with the standard employed.

ii. Dead load

Live load is computed, in principle, on the basis of the actual conditions. The specific gravity is in accordance with that of the powerhouse.

iii. Live load

The following live loads are used for structural design.

i) Roof	100 kg/m <sup>2</sup>
ii) Office	300 kg/m <sup>2</sup>
iii) Stairway, corridor and toilet	300 kg/m <sup>2</sup>
iv) Simulator room	800 kg/m <sup>2</sup>

iv. Seismic load

The total lateral force is to be obtained by the total weight above ground level multiplied by 0.05.

The distribution of lateral force at individual levels will be in accordance with the standard employed.

v. As the result of preliminary design based on the above load conditions, the quantity of concrete and materials are as follows.

Concrete	2,100 m <sup>3</sup>
Reinforcing bars	210 tons

## c) Equipment design

## i. Ventilating facilities

Ventilating facilities should be equipped with locker room, airconditioner room, dining kitchen, store room, toilet and shower room in accordance with the following conditions.

<u>Rooms</u>	<u>No. of Ventilation</u>
Locker room	More than 10 times/h
Airconditioner room	More than 18 times/h
Dining kitchen	More than 10 times/h
Storage house	More than 8 times/h
Toilet	More than 10 times/h
Shower room	More than 10 times/h

Each room will be equipped with the ventilating fans in accordance with the above conditions.


## ii. Airconditioning facilities

Except the ventilated rooms and houses, airconditioning facilities should be equipped to maintain room temperature and humidity at 25°C and 50% respectively. As the result of preliminary design, airconditioning capacity will be 300,000 kcal/h with air flow of 25,360 m<sup>3</sup>/h.


## iii. Others

Waste water will be treated by waste water treatment plant so that the waste water can be reusable for watering the plants planted within the power plant compound.

NO.	REVISION	DATE	REVISED	DESIGN




FIRST FLOOR




GROUND FLOOR


Fig. 5-64 Service Building



SECTION A-A



SECTION B-B




THE ARAB REPUBLIC OF EGYPT	
SINAI COAL-FIRED THERMAL POWER PROJECT	
TITLE	
SERVICE BUILDING	
SCALE	DRAWING NO.
	A - 4





Table 5-18 Borehole Logs





AYUN MUSA COAL-FIRED POWER STATION  
BOREHOLE LOCATION

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuın Musa Coal Power BORE NO. : B-4		SHEET NO. : 2	
Station			
GROUND LEVEL : 1.67		WATER LEVEL :	
		DATE OF W.L. :	

DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA							
					NO.	TYPE	SPT. IN VALUE	RECOVERY	q <sub>u</sub> kg/cm <sup>2</sup>	D <sub>60</sub> mm	D <sub>10</sub> mm	W/C %	L.L. %	P.L. %	
11	[Hatched Pattern]	Yellow hard silty clay with limestone fragments		3.75	7	98									
12															
13	[Dotted Pattern]	Yellow dense clayey silty fine sand		3.0	8										
14															
15					9										
16	[Hatched Pattern]	Yellow hard silty clay traces of fine sand		3.0	10		24						31	41.92	1.1
17															
18							U.S. 4						25.8		
19	[Hatched Pattern]	Yellow stiff silty clay with traces of fine sand			12		21								
20		Yellowish hard clay with traces of limestone and iron oxides													

X COORDINATE :		Y COORDINATE :	
ENGINEER :	CHECKED BY :	DRAWN BY :	DATE :
M. Hanna A. Wadie	H. Şubuk	A. Wadie	July 7th, 1983

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuun Musa Coal Power BORE NO.:		B-4		SHEET NO.:		3	
GROUND LEVEL:		1.67		WATER LEVEL:		DATE OF W.L.:	

DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA				
					NO.	TYPE	SPT. IN VALUE	ZINC COV. %	q <sub>u</sub> kg/cm <sup>2</sup>	D <sub>60</sub> mm	D <sub>10</sub> mm	W/C %
21		Yellowish medium gray silty fine sand	1.0									
22			2.75	13	35		0.08			6.21		
23												
24		White calcareous v. stiff silty clay	1.5	14	27					17.35		
25		Light gray very stiff calc. silty clay	1.5	U.S	5			0.18	20.1			
26												
27		Yellow silty clay with trace of sand and with iron oxides at 29.0 m.	3.0		78						23	15.3
28												
29					16	62				21.8		
30					17	100			0.6	0.002		

X COORDINATE :		Y COORDINATE :	
ENGINEER :	CHECKED BY :	DRAWN BY :	DATE :
M. Hanna A. Wadie	H. Sheta	A. Wadie	July 7th. 1983

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuun Musa Coal Power BORE NO. : B-4 SHEET NO. : 4  
Station

GROUND LEVEL : 1.67 WATER LEVEL : DATE OF W.L. :

DEPTH m	SECTION	DESCRIPTION	CASING - N	THICKNESS OF LAYER	SAMPLING DATA				LABORATORY DATA					
					NO.	TYPE	SPT. IN VALUE	%RECOVER- RY	q <sub>u</sub> kg/ cm <sup>2</sup>	D <sub>60</sub> mm	D <sub>10</sub> mm	W/C %	L.L. %	P.L. %
31	[Hatched Area]	Yellow very dense medium to fine sand with pockets of silty clay		4	18		100							
32														
33					19		100		0.23					
34	[Hatched Area]	Yellowish brown laminated hard silty clay with traces of fine sand with gypsum crystals at 37.5 m and sand at 39 m.		8.5	20		36					21.9		
35														
36					21		41							
37							>100							
38														
39														
40														

X COORDINATE :		Y COORDINATE :	
ENGINEER :	CHECKED BY :	DRAWN BY :	DATE :
M. Hanna A. Wadie	H. Sheta	A. Wadie	July 7th. 1983

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuun Musa Coal Power Station		BORE NO. : B-4				SHEET NO. : 5								
GROUND LEVEL : 1.67		WATER LEVEL :				DATE OF W.L. :								
DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA				LABORATORY DATA					
					NO.	TYPE	SPT. IN VALUE	RECOVERY %	q <sub>u</sub> kg/cm <sup>2</sup>	D <sub>60</sub> mm	D <sub>10</sub> mm	W/C %	L.L. %	P.L. %
41														
42														
43		Gray very dense sand with traces of gypsum crystals		2.0										
44														
45		Dark gray hard silty clay with interlayers of clay stone and traces of gypsum crystals.												
46				5.0										
47														
48														
49		Gray silty sand with gypsum crystals		1.0										
50		END OF BORING												
X COORDINATE :					Y COORDINATE :									
ENGINEER : M. Hanna A. Wadie			CHECKED BY : <i>H. Saleh</i>			DRAWN BY : A. Wadie			DATE : July 7th. 1983					



## ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS &amp; MATERIALS TESTING

PROJECT : Ayuun Musa Coal Power Station		BORE NO. : B-5		SHEET NO. : 1/5									
GROUND LEVEL : 2.4 m		WATER LEVEL :		DATE OF W.L. :									
DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA					
					NO.	TYPE	SPT. IN VALUE	RECOVER- RY	$q_u$ kg/cm <sup>2</sup>	$D_{60}$ mm	$D_{10}$ mm	W/C %	L.L. %
		Creamy calcareous fine to med. sandy silt with shells.		0.5									
1		Creamy loose calcareous fine sand		1.0			9						
2		Gray loose fine to medium sand		1.0			7						
3		Yellow compact fine sand with shells		3.0			22						
4		. with dolomite limestone fragments at 5. m depth.					22		0.30	0.14			
5							52						
6		Light gray medium dense sand sand with cemented lumps.		1.0			11						
7		Gray very stiff sandy clay		0.5			29						
		Light gray clayey sand.		0.75									
8		Light yellow very dense fine sand with a pocket of light brown clay, some coarse to fine gravel.		0.40			63	0.4					
9							15			39.14			
10		Light gray very stiff silty clay with traces of fine sand and gypsum crystals in a longitudinal pattern.		1.6			23						
X COORDINATE :			Y COORDINATE :										
ENGINEER : R. F. El-Raheb		CHECKED BY : H. Shik		DRAWN BY : R.R.			DATE : 27/6/1983						

## ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS &amp; MATERIALS TESTING

PROJECT : Ayun Musa Coal Power Station		BORE NO. : B-5		SHEET NO. : 2/5									
GROUND LEVEL : .....		WATER LEVEL : .....		DATE OF W.L. : .....									
DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA					
					NO.	TYPE	SPT. IN VALUE	%RECOVERY	q <sub>u</sub> kg/cm <sup>2</sup>	D <sub>60</sub> mm	D <sub>10</sub> mm	W/C %	L.L. %
		Preliminary field description											
11		Light yellow coarse sand with gravel.		0.5								24,	
12		Light gray very stiff silty clay		0.75			15						
12		Yellow gray very stiff calc. clayey silt.				US <sub>1</sub>					32.5	63.2	28
13		Becomes med. and with gravel at 13.0 m.					8						
14		& med. to soft at 15.0 m		4.5			16						
15		A layer of fine gravel.					14						
16												23.1	
17		Creamy calc. hard silty clay with horizontal and vertical fissures filled with sand and pockets of sand.		2.75			52						
18							63						
19		with thin seams of sand at 18.0 m											
20		Yellow hard laminated calc. silty clay with fine sand in between laminae.		1.5			74					19.9	
X COORDINATE :			Y COORDINATE :										
ENGINEER : R. F. El-Raheb		CHECKED BY : M. S. K.		DRAWN BY : R. R.		DATE : 27/6/1983							

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING












PROJECT : Ayuın Musa Coal Power Station BORE NO. : B-5 SHEET NO. : 3/5

GROUND LEVEL : WATER LEVEL : DATE OF W.L. :

DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA				LABORATORY DATA							
					NO.	TYPE	SPT IN VALUE	RECOVER RY	q <sub>u</sub> kg/cm <sup>2</sup>	σ <sub>bc0</sub> mm	D <sub>10</sub> mm	w/c %	L.L. %	P.L. %		
		Preliminary field description														
21		Dark yellow very dense fine sand, traces of silt.		2.25			50/5"									
22		A layer of fine gravel.		0.5												
		Light brown very dense fine sand		0.25			90									
		Brown sandy clay		0.25												
23		Light brown very fine sand.		0.75												
24		Yellow calc. hard laminated clayey silt with very fine sand in between laminae and with gypsum crystals at 29.0 m.		6.0			43						44	20		
25							34							21		
26									26						26.45	
27																
28									33						26	
29		White calc. clay stone.		1.0			100/2"									
30																
X COORDINATE :			Y COORDINATE :													
ENGINEER : R. F. El-Raheb			CHECKED BY : M. Suka			DRAWS BY : R.R.			DATE : 27/6/1983							

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Aydin Musa Coal Power Station		BORE NO. : B-5		SHEET NO. : 4/5								
GROUND LEVEL : .....		WATER LEVEL : .....		DATE OF W.L. : .....								
DEPTH m	SECTION	DESCRIPTION Preliminary field description	CASING - Y THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA					
				NO.	TYPE	SPT. IN VALUE	ZINC COVE- RY	q <sub>u</sub> kg/cm <sup>2</sup>	U <sub>60</sub> mm	D <sub>10</sub> W/C mm	L.L. %	P.L. %
31		Cemented med. sand.	0.75									
		Gray hard silty clay.	0.5			53						
32		Gray cemented sand.	0.75									
33		Gray hard clayey silt with gypsum crystals from 35.0 m to 39.0 m.	8.0			100/2"						
34							86			3731		
35												
36							54			3037		
37											34	71.6307
38												
39												
40						50/ "			25			
X COORDINATE :			Y COORDINATE :									
ENGINEER : R. F. El-Raheb		CHECKED BY : H. S. A.		DRAWN BY : R. R.			DATE : 27/6/1983					

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Aydin Musa Coal Power Station		BORE NO. : B-5		SHEET NO. : 5/5										
GROUND LEVEL : .....		WATER LEVEL : .....		DATE OF W.L. : .....										
DEPTH m	SECTION	DESCRIPTION Preliminary field description	CASING- M	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA						
					NO.	TYPE	SPT. IN VALUE	RECOVER- RY	q <sub>u</sub> kg/cm <sup>2</sup>	D <sub>10</sub> mm	D <sub>60</sub> mm	W/C %	L.L. %	P.L. %
41	Hatched	Light gray clayey med. sand		2m			100/1"					26.6		
42		Light gray clay stone		1m										
43	Hatched	Light gray hard silty fissured laminated clay with gypsum crystals in fissures and fine sand in laminae.		5m			50/2"							
44							52							
45	Hatched	END OF BORING												
46														
47	Hatched													
48														
49	Hatched													
50														
X COORDINATE :			Y COORDINATE :											
ENGINEER : R. F. El-Raheb		CHECKED BY : <i>H. S. K.</i>		DRAWN BY : R. R.		DATE : 27/6/1983								

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuun Musa Coal Power BORE NO. : B-6		SHEET NO. : 1											
GROUND LEVEL : 2.57		WATER LEVEL : DATE OF W.L. :											
DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA				LABORATORY DATA				
					NO.	TYPE	SPT. IN VALUE	RECOVER- RY	q <sub>u</sub> kg/cm <sup>2</sup>	D <sub>60</sub> mm	D <sub>10</sub> mm	W.C. %	L.L. %
1		Yellow calcareous fine silty loose sand some gravel and shells with gypsum crystals at 2.0 m.	7.0		2		8						
2					3		29						
3					4		10						
4					5		15						
5					6		16						
6					7		12						
7					Yellow dense coarse sand with gravel and shells			8		34			
8		9		36									
9		Gravelly at 9.50 m depth	4.75										
10													10
X COORDINATE :			Y COORDINATE :										
ENGINEER : M. Hanna A. Wadie		CHECKED BY : <i>H. S. K.</i>		DRAWN BY : A. Wadie		DATE : 16 July 1983							

ARDAMAN - ACE

CONSULTING ENGINEERS. IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuun Musa Coal Power Station BORE NO.: B-6 SHEET NO.: 2

GROUND LEVEL: 2.57 WATER LEVEL: DATE OF W.L.:

DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA						
					NO.	TYPE	SPT. IN VALUE	PRECOVE- RY	$f_u$ kg/cm <sup>2</sup>	$D_{60}$ mm	$D_{10}$ mm	W/C %	L.L. %	P.L. %
11		Yellowish brown very stiff sandy clay with gypsum crystals and coarse gravel			11		30							
12		Yellow fine dense sand with traces of clay and gravel		3.0	12		47							
13														
14														
15		Light gray stiff clayey silt		2.25										
16														
17		Yellowish gray hard silty clay with traces of fine sand		2.0										
18														
19		Yellow very dense silty fine sand with pockets of clay												
20														

X COORDINATE : Y COORDINATE :

ENGINEER : M. Hanna A. Wadie	CHECKED BY : <i>H. S. K.</i>	DRAWN BY : A. Wadie	DATE :
------------------------------------	---------------------------------	------------------------	--------

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuin Nusa Coal Power BORE NO.: B-6 SHEET NO.: 3  
Station

GROUND LEVEL: WATER LEVEL: DATE OF W.L.:

DEPTH m	SECTION	DESCRIPTION	CASING - %	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA						
					NO.	TYPE	SPT IN VALUE	ZRECOVER RY	qu kg/cm <sup>2</sup>	D <sub>60</sub> mm	D <sub>10</sub> mm	U/C Z	L.L. Z	P.L. Z
21	[Diagonal Hatching]	Yellowish gray hard silty clay with traces of fine sand.		3.0	17		45						47	18
22					18		100							
23	[Dotted Pattern]	Yellow v. dense fine sand some clay.		2.5	19		100							
24					20		42					22.4		
25	[Diagonal Hatching]	Yellowish brown silty clay with traces of sand and gypsum crystals.		8.5	21		46						20.7	
26					22		36				27	56	25	
27					23		100					22.7		
28														
29														
30														


X COORDINATE : Y COORDINATE :

ENGINEER : M. Hanna A. Wadie	CHECKED BY : <i>M. Sidiq</i>	DRAWN BY : A. Wadie	DATE :
------------------------------------	---------------------------------	------------------------	--------



ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Avuin Nusa Coal Power BORE NO. : .....		B-6 .....		SHEET NO. : .....		4 .....								
GROUND LEVEL : .....		WATER LEVEL : .....		DATE OF W.L. : .....										
DEPTH m	SECTION	DESCRIPTION	CASING - N	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA						
					NO.	TYPE	SPT. IN VALUE	WRECCOVE- RY	qu kg/ cm <sup>2</sup>	D <sub>60</sub> %	D <sub>10</sub> %	W/C %	L.L. %	P.L. %
31														
32														
33						24		48						
34		Gray hard silty clay with gypsum.			25		100							
35	Becomes yellowish brown at 35 m.		4.5	26		100								
36														
37					27		100							
38	Yellowish gray hard silty clay.				28		50				26			
39											39			
40														
X COORDINATE :			Y COORDINATE :											
ENGINEER : M. Hanna A. Wadie		CHECKED BY : <i>H. S. H.</i>		DRAWN BY : A. Wadie		DATE :								

ARDAMAN - ACE

CONSULTING ENGINEERS IN SOIL MECHANICS, FOUNDATIONS & MATERIALS TESTING

PROJECT : Ayuin Musa Coal Power Station		BORE NO. : B-6		SHEET NO. : 5										
GROUND LEVEL : .....		WATER LEVEL : .....		DATE OF W.L. : .....										
DEPTH m	SECTION	DESCRIPTION	CASING - M	THICKNESS OF LAYER	SAMPLING DATA			LABORATORY DATA						
					NO.	TYPE	SPT IN VALUE	PRECOVE- IN	$q_u$ kg/cm <sup>2</sup>	$D_{60}$ mm	$D_{10}/W.C$ %	L.L %	P.L %	
41		With gypsum crystals from 43 m to 48 m.												
42					30	70					36			
43					11							41		
44						31	100							
45														
46					32	100								
47														
48					33	53								
49		Yellowish brown silty fine sand.		1.5	34	100								
50		END OF BORING												
X COORDINATE :			Y COORDINATE :											
ENGINEER : M. Hanna A. Wadie		CHECKED BY : <i>A. Wadie</i>		DRAWN BY : A. Wadie		DATE :								

## 5-3 PRELIMINARY DESIGN FOR TRANSMISSION LINE AND SUBSTATION FACILITIES

## 5-3-1 Transmission Line

1) Overhead Transmission Line between Ayun Musa PS and New Suez  
SS

## a. Outline of Transmission Line

Voltage : 220 kV  
 No. of circuit : 4 circuits (two circuits one tower  
 two routes)  
 Conductor : AAAC 620 mm<sup>2</sup> x 2  
 Length : 40 km

## b. Conductor

Maximum allowable temperature rise of conductor is 80°C with the ambient temperature 42°C. The transmission capacity of one circuit is 300 MW in normal condition and 600 MW in emergency case.

AAAC (All Aluminium Alloy Conductor) is the standard of EEA in the sea side area as a salt resistant conductor. There are other kinds of salt resistant conductors; High Strengthened Aluminium Conductor (HAL) and Thermo Resistance Aluminium Alloy with aluminum coated steel. is

The comparison of construction costs of the above-mentioned three (3) kinds of conductors is shown as follows.

## a) Conductor size

## i. Conditions of calculation

Max. allowable temp. rise of conductor:	80°C
Max. ambient temp.:	42°C
Min. wind velocity:	0.6 m/sec.
Solar radiation:	0.1 W/cm <sup>2</sup>

## ii. Conductor size

AAAC	:	620 mm <sup>2</sup> x 2 (1,602 A)
HAL	:	560 mm <sup>2</sup> x 2 (1,606 A)
TAC/Al.-S	:	410 mm <sup>2</sup> x 2 (1,619 A)

## b) Comparison of Construction Costs

The average span of transmission line is assumed at 350m. The size of steel tower and the type of insulator are changed by the conductor type as follows.

<u>Conductor/Size</u>	<u>Steel Tower Weight (t/10km)</u>	<u>Insulator Size x pc.</u>
AAAC 620 mm <sup>2</sup> x 2	435	Smog 320 mm x 20
HAL 560 mm <sup>2</sup> x 2	462	Smog 250 mm x 23
TAC/Al-S 410 mm <sup>2</sup> x 2	385	Smog 250 mm x 23

The comparison of construction costs per 10 km is shown in Table 5-19. The construction cost of transmission line using AAC is more expensive than that of TAC/Al-S about 35%.

## c) Recommendation

To economize the transmission line construction cost, it is desirable to check on the standard of the salt resistant conductor again by REA.

Table 5-19 Comparison of Construction Cost by Conductor Type (per 10 km)

ITEM	Unit: 10 <sup>6</sup> ₹		
	HAL <sub>2</sub> 560mm <sup>2</sup> x2	AAAC 620mm <sup>2</sup> x2	TACSR/AW 410mm <sup>2</sup> x2
<b>Tower</b>			
Material	117,533	110,664	97,940
Erection	107,544	101,260	89,620
<u>Subtotal</u>	<u>225,077</u>	<u>211,924</u>	<u>187,564</u>
<b>Insulator</b>			
Material	43,240	101,462	43,240
Erection	1,372	1,372	1,372
<u>Subtotal</u>	<u>44,612</u>	<u>102,834</u>	<u>44,612</u>
<b>Conductor</b>			
Material	123,975	185,179	135,563
Erection	4,667	4,667	4,667
<u>Subtotal</u>	<u>128,642</u>	<u>189,846</u>	<u>140,230</u>
<b>Groundwire</b>			
Material	3,037	3,037	3,037
Erection	291	291	291
<u>Subtotal</u>	<u>3,328</u>	<u>3,328</u>	<u>3,328</u>
<u>Construction</u>	<u>67,559</u>	<u>85,435</u>	<u>63,199</u>
<u>T O T A L</u>	<u>469,218</u>	<u>593,367</u>	<u>438,943</u>

Note: HAL..... High strength AL.

AAAC.... All Al. Alloy Conductor

Tacsr/AW..Thermo resistance AL. with Almo Weld wire

c. Overhead Grounding Wire

One grounding wire for each tower

Wire: 130 mm<sup>2</sup> compound wire with optical fiber

d. Insulator

Design Condition

Standard voltage for design: 245 kV

Lightning surge voltage : 1,050 kV

Min. clearance distance : 180 cm

Min. leakage distance : 990 cm

No. of insulators for a string : 20 pc 320 mm Smog  
type

Reason:

Pollution condition of smog insulator : 0.224 mg/cm<sup>2</sup>

Flush over voltage of insulator per pc: V

$$V = k \times 28 / (w/0.1)^{\frac{1}{5}} \times (1.5(K^{\frac{1}{3}} + 2) + 5/8 \times K) \times A$$

(From transmission line standard in Japan JEAC 6001)

where;

K = 0.1 mg/cm<sup>2</sup> .. factor of unsoluble dust  
coherence

w = 0.32 mg/cm<sup>2</sup> .. equivalent salt coherence  
density

A = 1.50 .. correction factor of 320 mm  
smog insulator

Then;

$$V = 16.3 \text{ kV/pc}$$

Therefore;

$$16.3 \text{ kV} \times 20 = 326.0 \text{ kV} > 245 \text{ kV}$$

Minimum clearance distance, 180 cm, is enough for lightning surge voltage, 1,050 kV. The amount of switching surge voltage is  $(220 \text{ kV} \times 2.8 =) 616 \text{ kV}$ . So, its needed minimum clearance distance is enough with 130 cm. Thus, minimum clearance distance of 180 cm is acceptable for design of the steel tower.

2) Transmission Line for Canal Crossing

The interconnecting line from Ayun Musa PS to Unified system must cross the Suez Canal. Existing Suez Canal is one line passage with a width of 288 m, and there is a future expansion plan of another passage with a width of 260 m or more. Canal crossing transmission line should be considered with the future expansion plan for its design. Four alternative plans for the canal crossing were finally studied as follows.

a. Overhead Transmission Line Plan

Two steel towers will be constructed for canal crossing. One is erected at the east side bank about 50 m distance from the canal, and another at the west side of the future extension canal. The span of canal crossing will become 800 m. The height of tower will be 161 m to keep the height of lowest conductor from sea level as 80 m.

b. Cable through Ahmed Hamdi Tunnel

There is an allocated space in the Ahmed Hamdi Tunnel which has a width of 2.1 m at lower part and a height of 2.8 m, and is designed for common use of power cable and water pipe to Sinai peninsula. Twelve (12) cables are necessary to transmit 1,200 MW. The allocated space for

power cable is not sufficient for the cables. To install cables, it is necessary to replace the existing two water pipes (outer diameter: 60 cm) and additional allocation of space in air ducts. To construct the drawing out ducts of cables at both end of the tunnel, it is necessary to take care of existing facilities, control cables and radio, duct of water pipes. Refer to APPENDIX-C.

c. Cable System using New Duct

A pit will be dug 40 m depth each at both side of the canal, and a tunnel for cables, diameter of 3.6 m and length of 850 m, will be constructed.

Twelve 220 kV, 2,000 mm<sup>2</sup> cables will be installed in the tunnel for four interconnecting lines.

d. Submarine Cable System

Twenty four cables, 220 kV 1,400 mm<sup>2</sup> will be laid at the bottom of the canal. To keep cooling efficiency for the cables, a cable will be laid at an interval of 2 m. So, the width of cable passage will become 50 m. The construction period of the submarine cables may be farster than that of the extension of canal. Therefore, additional excavation along the future canal site will be necessary. The additional quantity of excavation is estimated more than 400,000 m<sup>3</sup>.

e. Conclusion

Comparison of construction costs and operation characters of each crossing method is shown in Table 5-20. The most cheapest and easiest in operation is the overhead transmission line method. But the Canal Authority rejects the method because of the safty of navigation of the



canal. In other crossing methods by cables, the method which uses Ahmed Hamdi Tunnel is the cheapest one, and also easy for operation. It is recommendable to adopt the method which uses Ahmed Hamdi Tunnel for cables.

3) Branch Transmission Line from the Existing Transmission Line

The existing transmission line is 220 kV Sakr SS - Suez SS 400 mm<sup>2</sup> single conductor line two circuits. From the line, New Suez SS will be branched with AAAC 620 mm<sup>2</sup> single conductor lines.

Table 5-20 (1) Comparison of Construction Cost for T/L

ITEMS	CASE 1 Overhead line	CASE 2 New Duct	CASE 3 Submarine	CASE 4 Ahmed Hamdi Tunnel
Conductor or Cable	620 sq. mm x1/ Phase AAC	2000 sq. mm x1/ Phase OF Cable	1400 sq. mm x2/ Phase OF Cable	2000 sq. mm x1/ Phase OF Cable
No. of circuits	4	4	4	4
Length (m)	850	1000	1000	2000
Construction Cost (M.L.Y)				
Steel Tower	318	1824	-	-
Tunnel	-	-	-	-
Excavation	-	-	5000	400
Civil Work	-	1200	310	100
Oil Box	-	-	480	-
Duct Both End	-	240	230	200
Cable or Conductor	90	503	1480	1008
Cable Head	-	120	240	120
Oil Tank	-	90	190	90
Trough & others	-	180	80	520
Bushing	-	720	720	720
Arrester	-	80	60	60
Optical Fiber	-	240	240	240
Water pipe replace	-	-	-	900
Erection	520	804	1200	840
TOTAL	928	5743	10230	4528
Construction Work	Lowest Conductor clearance from sea level : 80' m Tower's height : 188' m	Depth of pit (both side) : 50' m Tunnel length: 800' m Diam. of the inside tunnel : 3' m	Additional excavation : 500' m length : 250' m width : deepest point: 40' m	Replace the water pipes. Two circuits lay in the air ducts, the others lay in the central duct.
Construction Period	10 months	26 months	40 months	8 months
Operation	No problem	No problem	If a trouble occurs it is very difficult to repair Cables	No problem


Table 5-20 (2) Comparison of Construction Cost for T/L

ITEMS	CASE 5-1	CASE 5-2	CASE 5-3	CASE 6	CASE 7
Conductor or Cable	New Duct 2 circuits 2000 sq. mm 1/ Phase OF Cable	Ahmed Headl Tunnel 2 Cir. 2000 sq. mm x1/ Phase OF Cable	Submarine 2 circuits 1400 sq. mm x2/ Phase OF Cable	(CASE 5-1)- (CASE 5-2) 2000sq. mm x1/ Phase OF Cable	(CASE 5-2) + (CASE 5-3) 2000sq. mm & 1400sq. mm OF
No. of circuits.	2	2	2	4	4
Length (m)	1000	2000	1000	1000 & 2000	1000 & 2000
Construction Cost (mil. \$)					
Steel Tower	-	-	-	-	-
Tunnel	830	-	-	830	-
Excavation	-	200	2500	200	2700
Civil Work	700	60	200	760	260
Oil Box	-	-	290	-	290
Duct Both End	150	100	120	250	220
Cable or Conductor	252	504	740	756	1244
Cable Head	60	60	120	120	180
Oil Tank	48	48	48	96	96
Trough & others	90	260	73	350	333
Bushing	360	360	360	720	720
Arrester	30	30	30	60	60
Optical Fiber	120	120	120	240	240
Water pipe replace	-	100	-	100	100
Erection	450	440	720	990	1180
TOTAL	3020	2282	5771	5372	7603

Fig. 5-65 CANAL CROSSING TOWER (PRELIMINARY DRAWING)

UNIT: meter

CASE A Three (3) Towers



CASE B Two (2) Towers





Fig. 5-66 Cross-section of Ahmed Hamdi Tunnel



Scale unit: cm




Fig. 5-67

Case New Duct.  
220KV OF Cable 2,000mm<sup>2</sup> 1/phase, 4 circuit




Fig. 5-68: Figure of Cable layout






Fig. 5-69 Figure Dregin Duct for 220 kV 2 Circuit Submarine Cable


Plane figure




Vertical Section "B-B"



Vertical Section "C-C"



Vertical Section "A-A"





5-3-2 Substation

1) New Suez Substation

The substation will be constructed as an interconnecting station between Ayun Musa PS and a unified power system. But, as long as Ayun Musa PS's output is 600 MW only, the substation will be operated as a 220 kV switching station.

a. No. of 220 kV line

For Ayun Musa PS : four circuits

For branch point on the existing line: four circuits

b. Busbar Configuration

Double busbar system incorporating with EEA's tie circuit breaker system will be adopted and a circuit breaker is used for one line.

c. Protective Relay System

Two protection systems are installed for each circuit. a micro wave system and an optical fiber system are used for signal communication on Ayun Musa line. The power line carrier system is only used for Sakr SS and Suez SS line.

Fault localizer and fault recorder sets will be installed.

Relay maintenance set, station and portable types, will be procured.

The same type of protective relays used at Sakr SS and Suez SS, counter substation for branch line, shall be procured.

## d. Future Extension Plan

When Ayun Musa PS becomes 1,200 MW station, one 500 kV line and two 500/220 kV transformers will be installed. For the 220 kV lines, the space for additional 6 circuits of drawing out line will be provided.

## e. Others

Residential houses for employee will be constructed in the site.

## 5-3-3 Communication Facilities

## 1) Microwave Communication System

The microwave routes from the energy center to Ayun Musa PS are two ways as shown in Fig. 5-70. One is via Manayef SS and Abu Sultan PS, and another is via Abu Zaabal SS and Sakr SS. Facilities needed for two alternative plans are shown in Table 5-21.

Table 5-21 Communication Facilities for Microwave

<u>Name of Station</u>	<u>Output</u>	<u>Dia. of Antena</u>	<u>Height of Tower</u>
<u>FIRST PLAN</u>			
Abu Sultan PS	1 W	3 m	50 m
Repeater Station	1 W	2.4 m	30 m
	1 W	4 m x 2	30 m
Ayun Musa PS	1 W	3 m x 2	70 m
<u>SECOND PLAN</u>			
Sakr SS	1 W	8 m	120 m
Repeater Station	1 W	8 m	120 m
	1 W	3 m	120 m
New Suez SS	1 W	3 m	80 m
	1 W	3 m	80 m
Ayun Musa PS	1 W	3 m	105 m

Fig. 5-70 MICRO CHANNEL ROUTE FOR CAIRO--SUEZ AREA





Fig. 5-74 FIGURE OF VISTA FOR SAKR SS ... NEW SUEZ SS CHANNEL



The 2nd plan is more expensive than the 1st plan. But, the data communication between Ayun Musa PS and Abu Sultan PS depends on a single route of micro channel in the 1st plan. In the 2nd plan, two different microwave routes for the two power stations will be established. In future, therefore, the system formed in the 2nd plan will be easy to making a loop system for both the channels with higher reliability of operation.

Considering the reliability and future extension, the system in the 2nd plan is recommendable.

## 2) Power Line Carrier Facilities

### a. Between New Suez Substation and Suez Tr. Substation

"Inter-circuit coupling PLC" system is used for protectional signal, voice and data transmission system.

### b. Between New Suez SS and Sakr SS

Existing sets of Suez SS for Sakr SS will be transferred to New Suez SS and used as a set of communication for Sakr SS. But an additional channel will be installed to the existing set for the protectional relay signal.

### c. Optical communication system between Ayun Musa PS and New Suez SS

The interconnecting lines include a 2 km cable system. And the load flow on the line is very heavy even in normal conditions. To prevent the electro-magnetic induction to the carrier communication system, the optical communication system shall be used between Ayun Musa PS and New Suez SS.

3) Instruments for Maintenance and Testing

Portable instruments for maintenance and testing for microwave and power line carrier set should be installed at Ayun Musa PS and New Suez SS.



CHAPTER 6  
SPECIFICATIONS OF MAJOR FACILITIES

(1st Stage 300 MW x 2 Units)





## CHAPTER 6 SPECIFICATIONS OF MAJOR FACILITIES

## 6-1 POWER GENERATING FACILITIES

Outline of the specifications for major facilities will be as follows:

## 6-1-1 Power Plant

## 1) Boiler

## a. Boiler Proper

a) Type : Either natural or forced circulation drum-type, sub-critical, reheat, outdoor type

b) Maximum continuous rating (MCR) : Suitable capacity with 300 MW net output at the high voltage side of the step-up transformer (220 kV)

## c) Steam conditions

Main steam pressure at boiler outlet : Corresponding pressure  
Pressure drop between steam generator and turbine inlet less than 4% atmosphere

## Main steam temperature

at boiler outlet : 541°C

Reheated steam pressure at RH outlet : Corresponding pressure  
Pressure drop between reheater and stop valve less than 10% atmosphere

## Reheated steam temperature

at RH outlet : 541°C

d) Number of unit : 2 units/plant

- e) Fuel : Coal and oil
- f) Draft system : Balanced draft system
- b. Boiler Auxiliaries
- a) Air preheater
- Type : Vertical, regeneration type
- Number : 2 sets/unit
- b) Steam air preheater
- Type : Fin-tube type
- Number : 2 sets/unit
- c) Boiler feed water pump
- Turbine-driven boiler feed water pump
- Capacity : 55%
- Number : 2 sets/unit
- Motor-driven boiler feed water pump
- Capacity : 55%
- Number : 1 set/unit
- d) Soot-blowers
- Type : Air-jet type
- Number : 1 set/unit
- e) Draft equipment
- Forced draft fan
- Type : Turbo vane, motor-driven
- Number : 2 sets/unit
- Induced draft fan
- Type : Scirroco type, motor-driven
- Number : 2 sets/unit

## f) Coal firing equipment

## Coal burners

Number : 1 lot/unit

## Mill

Type : Vertical bowl mill motor-driven

Number : 5 sets/unit

## Primary air fan

Type : Centrifugal type

Number : 2 sets/unit

## g) Oil firing equipment

## Oil burner

Number : 1 lot/unit

## Heavy oil pump

Type : Screw type motor-driven

Number : 3 sets/unit

## h) Light oil firing equipment

Number : 1 lot/unit

## i) Compressed air equipment

## Instrument air compressors

Type : Water-cooled oil-less type

Number : 2 sets/unit

## House service air compressors

Type : Water-cooled oil-less type

Number : 1 set/plant

## Soothblowing air compressors

Type : Water-cooled type

Number : 3 sets/plant

## j) Dust collector

Type : Electrostatic type

Number : 1 set/unit

## k) Ash handling equipment

## Bottom ash

Type : Water sluice type

Number : 1 set/unit

## Fly ash

Type : Vacuum type

Number : 1 set/unit

## Ash handling pump

Type : Vertical, motor-driven

Number : 2 sets/unit

## l) Stacks

Type : Steel-made collective type  
(for 2 units)

Number : 1 lot/plant

## m) Desalination plant

Type : Steam type

Number : 1 lot/plant

## n) Water treating equipment

Number : 1 lot/plant

## o) Waste water treating plant

Number : 1 lot/plant

## p) Fire Fighting System : 1 lot/plant

## 2) Turbine

## a. Turbine Proper

- a) Type : Reheat, condensing, tandem compound type
- b) Rated output at generator sent out : Suitable capacity with 300 MW net output at the high voltage side of the step-up transformer (220 kV)
- c) Steam conditions
- Main steam pressure
- at turbine inlet : 169 kg/cm<sup>2</sup>
- Main steam temperature
- at turbine inlet : 538°C
- Reheated steam temperature
- at IP turbine inlet : 538°C
- d) Number of unit : 2 units/plant
- e) Rated condenser vacuum : 710 mmHg
- f) Rated speed : 3,000 rpm

## b. Turbine Auxiliaries

## a) Condenser equipment

## Condenser

Type : Surface type

Number : 1 set/unit

## Cooling water

Temperature : 27°C

## Cooling water pump

Type : Vertical, motor-driven

Number : 2 sets/unit

Condensate pump

Type : Vertical, motor-driven

Capacity : 50% MCR

Number : 3 sets/unit

Condenser cleaning device

Number : 1 lot/unit

Seawater electrolysis facility

Number : 1 lot/unit

b) Feed water heater

LP heater

Type : Horizontal surface type

Number : 4 sets/unit

Deaerator

Type : Horizontal surface type

Number : 1 set/unit

HP heater

Type : Horizontal surface type

Number : 3 sets/unit

c) Bearing cooling water equipment

Number : 1 lot/plant

d) Overhead travelling crane

Number : 1 lot

3) Electrical Equipment and Control System

a. Electrical Equipment

a) Generator

i. Generator Proper

i) Type : Horizontal-shaft, totally enclosed, hydrogen cooled type

- ii) Capacity : about 400 MVA
  - iii) Number of unit: 2 units/plant
  - iv) Power factor : 0.8
  - v) Short-circuit ratio : 0.58
  - vi) Rated voltage : about 18.3 kV or appropriately
  - vii) Number of phase: 3
  - viii) Frequency : 50 Hz
  - ix) Number of pole: 2
  - x) Rated speed : 3,000 rpm
- ii. Generator auxiliaries: 2 sets
- i) Exciter
    - Type : Static excitation
  - ii) Isolated phase bus
    - Type : Self-cooled continuous grounding
  - iii) PT and SA
    - Type : Self-standing, phase isolated type
  - iv) Neutral grounding device
    - Type : Pole transformer, 2ry resistor type
  - v) Automatic voltage regulator
    - Type : Quick-response excitation system
  - vi) Hydrogen cooler system
    - Type : Water cooled type



## b) Transformers

## i. Main transformer with off-load tap changer

Type : 3-phase, OFAF, outdoor type  
 Capacity : about 380 MVA  
 Number : 1 set/unit  
 Voltage : 18.3 kV or appropriately/230 kV

## ii. House transformer with off-load tap changer

Type : 3-phase ONAF, outdoor type  
 Capacity : about 25 MVA  
 Number : 1 set/unit  
 Voltage : 18.3 kV or appropriately/6.9 kV

## iii. Starting transformer with on-load tap changer

Type : 3-phase, ONAF, outdoor type  
 Capacity : about 30 MVA  
 Number : 1 set/plant  
 Voltage : Primary 220 kV 125 kV  
 Secondary 6.9 kV

## iv. Aux. transformer

Type : 3-phase AN indoor dry type  
 Capacity : about 1,500 kVA  
 Number : 7 sets/plant  
 Voltage : 6.6 kV/380 V

## c) Station service power supply switchgear equipment

## i. 6.9 kV switchgear

Type : Metal-clad, draw-out, indoor  
 type, 3-pole single throw,  
 magnetic-blast breaker

## ii. 380 V switchgear

Type : Metal-clad, 3-pole single  
 throw, draw-out, indoor type

iii. Motor control center

Type : Steel sheet, self-supporting,  
collective switchgear panel  
type

iv. 220 V distribution panel

d) Uninterrable power supply unit

Voltage : AC 120 V 1-phase  
CVCF : 2 sets/unit

e) DC system

Voltage : DC 125 V  
Battery : 1 set/unit  
Charger : 3 sets/plant

f) Cable

i. Power cable

ii. Control cable

iii. Instrument cable

g) Emergency generating facilities

Type : Package type gas turbine  
driven

Number : 1 set/plant

Rating:

Gas turbine : 17,500 kW (at 40°C)

Generator : 35,000 kVA 6.6 kV or  
appropriately

Fuel : Light oil

h) Hydrogen Generator System: 1 set/plant

b. Control System

a) Control panel : 1 set/unit

i. BTG control panel

ii. Auxiliary control panel

iii. Electrical control panel

iv. Local control panel

b) Control equipment : 1 set/unit

i. Automatic boiler control system

ii. Automatic burner control system

iii. Turbine automatic starting system

iv. Automatic synchronizing system

v. Sequential control system

vi. Data logger system

vii. Local loop control system

c. Station Service Communication System

a) Telephone sets : 200

b) Automatic exchange : 200 circuits

c) Power source : 1 set

d) Paging system : 1 set

e) Alarm system : 1 set

d. Lighting Facilities

a) Indoor lighting facilities

b) Outdoor lighting facilities

## 4) Fuel Handling Facilities

## a. Coal Handling

Storage capacity : about 335,000 tons (full load operation of 600 MW for 60 days)

Unloader : 1,300 t/h x 2 sets

Stacker/reclaimer : 3,200 t/h/1,200 t/h x 1 set

Stacker : 3,200 t/h x 1 set

Reclaimer : 1,200 t/h x 2 sets

## Conveyor

Unloading conveyor: 1,600 t/h x 2 systems

Stacker conveyor : 3,200 t/h x 3 lines

Reclaimer conveyor: 1,500 t/h x 2 lines

Supply conveyor : 1,500 t/h x 1 line

(incl. conveyor 600 t/h x 2 lines

house) 1,500 t/h x 2 systems

500 t/h x 2 systems

Mix bin : 300 t x 2 sets

Screen : 500 t/h x 2 sets

Crusher : 75 t/h x 2 sets

## b. Heavy Oil

Loading arm : 1 set

Unloading facilities : 1 set

(Air separator, strainer, flow meter)

Unloading pump : 1,000 k/h x 1 set

Storage tank : 36,000 k x 3 sets

## c. Light Oil

## Unloading facilities (Strainer, flow meter)

Bulldozer (Coal  
storage yard) : 1 set  
Bulldozer (Coaler): 1 set

## Storage tank

Bulldozer  
(Cool storage yard): 50 k/ x 1 set  
Bulldozer (Coaler): 5 k/ x 1 set

## 5) 220 kV Switchyard in Ayun Musa Power Station

## a. Main Equipment

- a) 240 kV SF<sub>6</sub> circuit breaker, with built-in bushing  
current transformer (outdoor use, puffer-type)

For main transformer, starting transformer, distri-  
bution transformer and transmission line

: 16 units

Rated voltage : 240 kV

Rated current : 2,000 A

Rupturing capacity: 40 kA

- b) 240 kV Disconnecting switch (outdoor use)

- i. For main transformer, starting transformer, distri-  
bution transformer, bus section and transmission  
line (pneumatic operating type)

Pantograph type : 12 units

Horizontal center

break type : 24 units

Rated voltage : 240 kV

Rated current : 2,000 A

Rated short-time

current : 40 kA

ii. For lightning arrester (outdoor use, manual operating type)

Horizontal center

break type : 4 units

Rated voltage : 240 kV

Rated current : 1,200 A

Rated short-time

current : 31.5 kA

iii. 220 kV bus earthing device (outdoor use, manual operating type) single-phase

: 6 units

Rated voltage : 240 kV

Rated short-time

current : 31.5 kA

c) Capacitance potential device

i. For 220 kV bus

(single-phase) : 6 units

Rated voltage

Primary :  $220/\sqrt{3}$  kV

Secondary :  $110/\sqrt{3}$  V

Tertiary : 110 V

Rated burden

Secondary : 500 VA

Tertiary : 100 VA

ii. For 220 kV line

(single-phase) : 4 units

Rated voltage

Primary :  $220/\sqrt{3}$  kV

Secondary :  $110/\sqrt{3}$  v

Rated burden

Secondary : 50 VA

d) Power transformer with on-load tap changer for distribution, three-phase outdoor type

: 1 unit

Rated capacity : 40 MVA

Rated voltage

Primary : 220 kV  $\pm$ 25 kV

Secondary : 22 kV

Cooling system : ONAF

e) Lightning arrester, gapless type

: 12 units

Rated voltage : 210 kV

Nominal discharge

current : 10 kA

f) 24 kV metal clad switchgear

i. Main circuit switchgear: 1 set

Rated voltage : 24 kV

Rated current : 1,200 A

Repturing

capacity : 20 kA

ii. Feeder circuit switchgear: 4 sets

Rated voltage : 24 kV

Rated current : 600 A

Interrupting

current : 20 kA

iii. Auxiliary metal clad switchgear: 1 set

Contained grounding type potential transformer  
and lightning arrester

b. Other Equipment

a) Supervisory control panel, operator-console desk, 220  
kV system panel and auxiliary panels

b) AC power source (station service panels)

c) DC power source (battery and battery charger)

d) Outdoor steel structure and bus support

e) Hot-line insulator washing apparatus

Water screen type washing apparatus (water tank, pump-  
ing set, nozzle, piping and control board)

f) 220 kV conductor

Aluminium pipe conductor (180  $\phi$  x 10 t, 100  $\phi$  x 6 t)  
and hard-drawn aluminium conductor (HAL 510 mm<sup>2</sup>)

g) 220 kV insulator

Suspension insulators and station post insulators

h) Air compressor (air reservoir and control panel)

i) Control cable, 22 kV power cable and optical fiber  
cable

j) Ground mat materials (annealed copper wire 100 mm<sup>2</sup> and  
conductor)



k) Communication system

Optical fiber communication terminal set: 2 sets

Automatic exchange: 200 cct 1 set

DC power source

48 V 20 A 210 AH : 1 set

24 V 300 A 1,000 AH : 2 sets

Information transmission unit

63 W C.D.T : 1 unit

15 W C.D.T : 1 unit


Wireless telephone

2 GHz PCM 0.2 W 24 CH: 2 units

Steel tower, 105 m : 1 set

### Ayun Musa P/S Outdoor Switchyard

#### Single line Diagram



6-1-2 Civil Facilities


1) Land Reclamation

Area of Land Reclamation (1,200 m x 500 m)	600,000 m <sup>2</sup>
Compacted Fill	1,400,000 m <sup>3</sup>
Protection of Slope	14,000 m <sup>2</sup>
Asphaltic Pavement	
Access Road (Width 4.000 m x 2 lanes with green belt in between)	
L = 1,625.000 m	13,000 m <sup>2</sup>
Road in Plant (Width 8.000 m, 12.000 m)	41,000 m <sup>2</sup>
Specified Ground Level	EL +4.000

2) Circulating Water System

a. Inlet

Bottom level of inlet channel	EL-5.500
Dimensions of inlet channel	



Required Discharge (for 1,200 MW)	61.4 m <sup>3</sup> /s
Length of inlet channel	1,472.000 m
Rubble stone	32,000 m <sup>3</sup>
Stone pitching	131,000 m <sup>2</sup>
Compacted fill	81,000 m <sup>3</sup>

## b. Intake Pumping Pit

Bottom slab of intake pumping structure	EL-5.500
Reinforced concrete	
30.800 m x 21.400 m x 10.500 m	
(Length) (Width) (Depth)	
Level of top slab	EL+4.000
Gate	8 pcs
Bar screen	4 pcs
Travelling screen	4 pcs
Sheet type wing wall	19.000 m x 20.000 m
Excavation	25,000 m <sup>3</sup>
Concrete	2,900 m <sup>3</sup>

## c. Circulating Water Pipe Line

Level of circulating water pipe line	EL+0.580
Width of Excavation	12.000 m
Material of circulating water pipe line	
Core type prestressed concrete pipe	
( $\phi = 2.000$ m, $t = 0.110$ m)	
Length of pipe line = 700 m	
Excavation	71,000 m <sup>3</sup>
Gravel	9,600 m <sup>3</sup>
Backfill	30,000 m <sup>3</sup>

## d. Discharge Culvert (for 1,200 MW)

Reinforced concrete	
12.700 m x 4.500 m x 250.000 m	
(Width) (Depth) (Length)	
Level of bottom slab	EL+0.000
Level of top slab	EL+4.000

Discharge channel

16.000 m x 4.000 m x 300.000 m  
 (Width) (Depth) (Length)

Retaining wall

Height	4.000 m
Slope	1 : 0.5
Level of footing	EL+0.000
Level of top	EL+4.000
Excavation	35,000 m <sup>3</sup>
Concrete	2,400 m <sup>3</sup>

e. Discharge Weir

EL±0.000 (Upstream)

16.000 m x EL+1.000 x


(Width) (Weir) EL-1.000 (Downstream)

Sheet type wing wall 16.000 m, 18.000 m  
 (left bank, right bank)

f. Outlet

Bottom level of outlet channel EL-1.000

Dimensions of outlet channel L=600.000 m



Excavation	20,000 m <sup>3</sup>
Compacted fill	17,000 m <sup>3</sup>
Stone pitching	30,000 m <sup>2</sup>

## 3) Fuel Oil Storage Tank Foundation &amp; Oil Dyke

## a. Heavy Oil Storage Tank Foundation

Diameter of ring wall	$\phi$ 54.160 m
Dimensions of ring wall	0.400 m x 0.900 m
	(Width) (Height)
Thickness of asphaltic pavement	t = 0.050 m
Thickness of oil sand	t = 0.100 m
Slope of mound	i = 1/120, 1/20
Drain pipe	$\phi$ = 0.050 m, @1.500 m
Depth of displacement	2.000 m
Excavation	13,000 m <sup>3</sup>
Concrete	180 m <sup>3</sup>
Gravel	5,000 m <sup>3</sup>
Compacted soil	10,000 m <sup>3</sup>

## b. Oil Dyke

Reinforced concrete	
2.000 m	x 0.300 m x 800.000 m
(Height from GL)	(Width) (Length)
Expansion joint	One (1) per 20.000 m
Excavation	3,000 m <sup>3</sup>
Concrete	1,200 m <sup>3</sup>

## c. Intermediate Dyke

Compacted fill (Width of bottom 3.000 m x Width of top	
1.000 m x Height 0.800 m)	L = 200.000 m
Asphaltic pavement above compacted fill	t = 0.050 m
Compacted fill	300 m <sup>3</sup>
Gravel	70 m <sup>3</sup>
Asphaltic pavement	30 m <sup>2</sup>

## 4) Coal Handling &amp; Coal Storage Yard

## a. Coal Handling (Conveyer foundation, berth to coal storage yard)

L = 3,100.000 m

Excavation 37,000 m<sup>3</sup>Concrete 20,000 m<sup>3</sup>

## b. Coal Storage Yard

Area of coal storage yard 420,000 m x 300,000 m

Stacker and reclaimer foundation

Compacted fill shall be made between original surface and EL+4.000 m.

20.000 m x 2.000 m x 4 lanes

(Width of foundation) (Height of compacted fill)

Ballast (EL+4.500 m)

Stacker foundation 10.000 m x 380.000 m x 1 lanes

(Width) (Length)

Reclaimer and stacker-reclaimer foundation

12.000 m x 380.000 m x 3 lanes

(Width) (Length)

Compacted fill 110,000 m<sup>3</sup>Ballast 10,000 m<sup>3</sup>Concrete 2,400 m<sup>3</sup>

## 5) Ash Disposal Facility

## a. Planned Ash Disposal (600 MW for ten (10) years)

Level of dyke for ash pond EL+4.000

Rubble dyke sloping type (ash pond) L = 2,700 m

Slope of rubble 1 : 1.2, Stone pitching 1 : 2.0

Area of ash pond 950,000 m<sup>2</sup>

Volume of ash pond (EL+4.000)	3,700,000 m <sup>3</sup>
Rubble	27,000 m <sup>3</sup>
Stone pitching	22,000 m <sup>2</sup>
Compacted fill	165,000 m <sup>3</sup>
Concrete pavement	14,000 m <sup>2</sup>
Water-proofing sheet	40,000 m <sup>2</sup>

b. Planned Ash Disposal (Reference)

600 MW for two (2) years

1,200 MW for eight (8) years

Level of dyke for ash pond EL+4.000

Rubble sloping type (ash pond) L = 2,190 m

Slope of rubble 1:1.2, stone pitching 1:2.0

Area of ash pond 1,616,000 m<sup>2</sup>

Volume of ash pond (EL+4.000) 6,198,000 m<sup>3</sup>

Rubble 21,000 m<sup>3</sup>

Stone pitching 18,000 m<sup>2</sup>

Compacted fill 140,000 m<sup>3</sup>

Concrete pavement 12,000 m<sup>2</sup>

Water-proofing sheet 34,000 m<sup>2</sup>

c. Planned Ash Disposal (Reference)

600 MW for two (2) years

1,200 MW for twenty eight (28) years

Level of dyke for ash pond EL+4.000

Rubble sloping type (ash pond) L = 6,000 m

Slope of rubble 1:1.2, stone pitching 1:2.0

Area of ash pond (EL+4.000) 4,819,000 m<sup>2</sup>



Volume of ash pond	14,908,000 m <sup>3</sup>
Rubble	46,000 m <sup>3</sup>
Stone pitching	48,000 m <sup>2</sup>
Compacted fill	402,000 m <sup>3</sup>
Concrete pavement	42,000 m <sup>2</sup>
Water-proofing sheet	95,000 m <sup>2</sup>

d. Unloading Jetty

Level of unloading jetty	EL+3.000
Length of unloading jetty	L = 50.000 m
Concrete block type jetty	
Rubble	10,000 m <sup>3</sup>
Stone pitching	9,000 m <sup>2</sup>
Dredge	28,000 m <sup>3</sup>

6) Miscellaneous Works

a. Lighting Pole Foundation

In the coal storage yard	10 pcs
Road in the plant	One (1) per 40.000 m

b. Ash Sluicing Pipe Foundation


Concrete pipe  $\phi$ 0.350 m x 5 lines  
 L = 600.000 m x 5 lines

c. Cable Trench

Reinforced concrete (with cover)  
 2.000 m x 1.500 m x 1,500.000 m  
 (Width) (Depth) (Length)

d. Oil Pipeline Foundation

L = 4,000 m



## e. Neutralization Pit

25.000 m x 40.000 m x 1.700 m

(Width) (Length) (Depth)

f. Demineralized Water Tank Foundation  $\phi$ 8.240 mg. Raw Water Tank Foundation  $\phi$ 14.160 m

h. Desalination Plant Foundation 22.000 m x 25.000 m

i. Landscaping 34,000 m<sup>2</sup>j. Gravel Pavement t = 0.100 m, Area: 20,000 m<sup>2</sup>

## 6-1-3 Harbor facilities

## 1) Berthing Facilities

## a. Kind of Harbor Facilities

<u>Kind of Facilities</u>	<u>Size of Ship</u>	<u>Number of Berth</u>	<u>Length of Berth</u>	<u>Water Depth</u>	<u>Width of Berth</u>
Coaler berth	60,000 DWT	1	300 m	EL-16 m (C.D.L -14.855 m)	25 m
Oil tanker berth	5,000 DWT	1	140 m	EL-8.5 m (C.D.L -7.355 m)	10 m
Small craft berth	500 GT	1	50 m	EL-5 m (C.D.L -3.855 m)	5 m

## b. Height of Wharf Crown

- a) Coaler wharf : EL+3 m
- b) Oil tanker wharf : EL+3 m
- c) Small craft wharf : EL+2 m

## c. Structure Type of Mooring Facilities

## a) Coaler wharf

Open-type wharf with coupled battered piles

Materials: Steel pipe pile

Upper parts of the piles (above LWL -1 m) will be covered with fiber glass reinforced plastic (F.R.P) for corrosion prevention, and other parts (from LWL -1 M to GL -1 m) will be protected with corrosion preventive paint and electrolytic protection, or other corrosion preventive method equivalent to the above method will be made.

## b) Oil tanker wharf

Gravity quaywall (Concrete block type)

## c) Small craft wharf

Gravity quaywall (concrete block type)

## 2) Channel and Basin

## a. Channel

- a) Water depth : EL-16 m (C.D.L. -14.855 m)
- b) Width : 200 m
- c) Length : 1,300 m
- d) Area : About 320,000 m<sup>2</sup>
- e) Side slope : 1:3

## b. Anchorage Basin

## a) Coaler ship

- i. Water depth : EL-16 m (C.D.L. -14.855 m)
- ii. Area : About 500 m x 550 m  
= 275,000 m<sup>2</sup>
- iii. Side slope of dredged area : 1:3

## b) Oil tanker

- i. Water depth : EL-8.5 m (C.D.L. -7.355 m)
- ii. Area : About 350 m x 380 m  
= 133,000 m<sup>2</sup>
- iii. Side slope of dredged area : 1:3

## c) Small craft

- i. Water depth : EL-5 m (C.D.L. -3.855 m)
- ii. Area : About 140 m x 150 m  
= 21,000 m<sup>2</sup>
- iii. Side slope of dredged area : 1:3

## 3) Causeway

- a. Length of causeway : 2,700 m
- b. Height of causeway crown : EL+3 m

- c. Width of causeway : 20 m
- 4) Beacon, Range Light and Buoy
  - a. Beacon : 5 sets (2 sets on the channel inlet, 2 sets on the channel end and 1 set on the bend point at the middle of the channel)
  - b. Range Light : 2 poles (on the shoreline and land on the center line of the channel)
  - c. Buoy light : 8 sets (Bend points of basin) (2 sets without light)
- 5) Others
  - a. Water hydrant : 5 points (3 points on the coaler wharf, 1 point on the oil tanker wharf and 1 point on the small craft wharf)
  - b. Lighting facilities for night works on the causeway and berth : 1 set
  - c. Electric power source for repair works of ships : 1 set
  - d. Harbor administration office : 1 (100 m<sup>2</sup>)
  - e. Miscellaneous warehouse : 1 (150 m<sup>2</sup>)
  - f. Communication system between powerplant and berth : 1 set
  - g. Fire boat : 1 (50 ton class)

## 6-1-4 Architectural Facilities

## 1) Powerhouse

## a. Building Area, Floor Area and Building Volume

Turbine-generator bay	:	2,990 m <sup>2</sup> (height 30 m)
Heater bay	:	1,280 m <sup>2</sup> (height 24 m)
Control bay	:	1,230 m <sup>2</sup> (height 18 m)
<u>Bunker bay</u>	:	<u>1,380 m<sup>2</sup> (height 43.5 m)</u>
Total building area	:	6,880 m <sup>2</sup>
Total floor area	:	19,730 m <sup>2</sup>
Building volume	:	142,020 m <sup>3</sup> (excl. bunker bay)
		51,320 m <sup>3</sup> (bunker bay)
Total building volume	:	193,340 m <sup>3</sup>

## b. Substructure

a) Pile	:	High strength prestressed concrete pile or bored pile $\phi = 600$ mm Bearing Capacity 120 t/pile Number of pile 700 piles
b) Foundation	:	Reinforced concrete, concrete tie beam Excavation Volume 53,000 m <sup>3</sup> Concrete Volume 11,000 m <sup>3</sup>

## c. Superstructure

a) Frame	:	Steel structure Weight of steel structure 5,700 ton
----------	---	---

- b) Roof : Corrugated resin coated steel sheet with insulation material and partly reinforced concrete structure, asphalt water-proofing
- c) Floor : Reinforced concrete structure, tile and mortar finish and partly steel grating floor  
Concrete Volume 2,000 m<sup>3</sup>
- d) Exterior wall : Corrugated resin coated steel sheet with insulation materials and partly Hollow concrete block, and sand textured coating
- e) Interior wall : Hollow concrete block, paint on plastered and partly metal partition wall
- f) Ceiling : Suspended ceiling, acoustic board, asbestos board and partly exposed concrete
- d. Appurtenant Facilities
- a) Air conditioning System: Air conditioning unit  
Cooling capacity 230,000 kcal/h  
Air volume 29,700 m<sup>3</sup>/h
- b) Ventilating system : Ventilating unit and roof ventilating fan  
Ventilating unit 4 sets  
Capacity 187,000 m<sup>3</sup>/h/set

c) Water supply, drainage, sanitary and hot water supply system

d) Lightening Lod

e) Elevator system : 2 sets

Lifting capacity : 1,000 kg

Capacity : 15 persons

## 2) Service Building

### a. Floor Area

Ground floor : 1,370 m<sup>2</sup>

First floor : 1,370 m<sup>2</sup>

Total floor area : 2,740 m<sup>2</sup>

b. Substructure : Reinforced concrete, spread foundation

Excavation volume 3,000 m<sup>3</sup>

Concrete volume 700 m<sup>3</sup>

### c. Superstructure

a) Structural frame : Reinforced concrete structure

b) Roof : Reinforced concrete structure, asphalt water-proofing

c) Floor : Reinforced concrete structure, tile and mortar finish

Concrete volume 1,400 m<sup>3</sup>

d) Exterior wall : Hollow concrete block, sand textured coating

e) Interior wall : Hollow concrete block, paint on plastered and partly metal partition wall



f) Ceiling : Suspended ceiling, acoustic board, asbestos board

d. Appurtenant Facilities

- a) Air conditioning system: Air conditioning unit  
Cooling capacity 300,000 kcal/h  
Air volume 25,360 m<sup>3</sup>/h
- b) Ventilating system
- c) Water supply, drainage, sanitary and hot water supply system
- d) Lighting, wall receptacle and other electric system
- e) Fire fighting system
- f) Kitchen facilities

## 3) Auxiliary Buildings

Buildings	Houses	Structure	Total floor area	Quantities of major material		Air conditioning	Ventilating	Lighting	Water & hot water supply	Sanitary
				Concrete	Structural Steel					
Electric, instrument & control maintenance workers house	1	Reinforced concrete structure	390m <sup>2</sup>	250m <sup>3</sup>		o	o	o	o	o
Coal handling workers house	1	Reinforced concrete structure	340m <sup>2</sup>	220m <sup>3</sup>		o	o	o	o	o
Store house	4	Reinforced concrete structure	1,380m <sup>2</sup>	700m <sup>3</sup>		o	o	o	o	o
Coal handling control house and coal reduction house	1	Steel structure	3,200m <sup>2</sup>	240m <sup>3</sup>	380 t	o	o	o		
Seawater electrolysis house	1	Reinforced concrete structure	50m <sup>2</sup>	30m <sup>3</sup>		o		o		
Switchyard control house	1	Reinforced concrete structure	450m <sup>2</sup>	300m <sup>3</sup>		o		o		
Machine shop	3	Steel structure	900m <sup>2</sup>	270m <sup>3</sup>	80 t	o	o	o	o	o
Water treatment control house	1	Reinforced concrete structure	75m <sup>2</sup>	40m <sup>3</sup>		o		o		
Fire fighting pump house	1	Reinforced concrete structure	75m <sup>2</sup>	40m <sup>3</sup>			o	o		
Cylinder house	1	Reinforced concrete structure	100m <sup>2</sup>	50m <sup>3</sup>			o	o		
Guard house	3	Reinforced concrete structure	300m <sup>2</sup>	150m <sup>3</sup>		o		o	o	o
Oil fence house and harbor workers house	1	Reinforced concrete structure	90m <sup>2</sup>	45m <sup>3</sup>		o	o	o	o	o
Garage	1	Reinforced concrete structure	440m <sup>2</sup>	150m <sup>3</sup>				o		
Bulldozer house	2	Reinforced concrete structure	75m <sup>2</sup>	40m <sup>3</sup>				o		
Intake pump house	1	Steel structure	220m <sup>2</sup>		50 t		o	o		
Lube oil storage house	1	Reinforced concrete structure	100m <sup>2</sup>	50m <sup>3</sup>			o	o		
Oil pump house	3	Reinforced concrete structure	150m <sup>2</sup>	75m <sup>3</sup>			o	o		
Neutralization control house	1	Reinforced concrete structure	50m <sup>2</sup>	25m <sup>3</sup>		o		o		

## 4) Major Equipment Foundations

Major equipment foundations will be made by reinforced concrete and will be supported by high strength prestressed concrete pile or bored pile.

## a. Turbine-Generator Foundation

Excavation volume : 3,000 m<sup>3</sup>  
 Pile : Dia. 600  $\phi$   
 Bearing capacity 120 t/pile  
 Quantity 200 piles  
 Concrete volume : 7,000 m<sup>3</sup>

## b. Boiler Foundation

Excavation volume : 15,000 m<sup>3</sup>  
 Pile : Dia. 600  $\phi$   
 Bearing capacity 120 t/pile  
 Quantity 650 piles  
 Concrete volume : 8,000 m<sup>3</sup>

## c. Stack Foundation

Excavation volume : 7,000 m<sup>3</sup>  
 Pile : Dia. 600  $\phi$   
 Bearing capacity 120 t/pile  
 Quantity 70 piles

## 5) Planning of Residential Quarters

Housing, recreation facilities and community service facilities for power plant personnel and their families will be planned. (Construction cost of residential quarters will be excluded in the construction cost of this project.)

a. Housing

Type A	6 flats	150 - 170 m <sup>2</sup> /flat
Type B	132 flats	100 - 110 m <sup>2</sup> /flat
Type C	162 flats	<u>80 - 90 m<sup>2</sup>/flat</u>
Total	300 flats (for 300 MW x 2 units)	

In the future expansion of power generating facilities, it is necessary to expand housing 250 - 300 flats more.



b. Community Service

Hospital, post office, shop, bank, school, mosque, park, etc. will be planned for community.

c. Recreation Facilities

Athletic facilities such as tennis court, football ground, swimming pool, etc. and club house with accommodations for guests will be planned.

Public facilities such as road, waterworks, sewage, electric power supply facilities, lighting facilities will be planned.



- 1 HOUSING TYPE A
- 2 HOUSING TYPE B
- 3 HOUSING TYPE C
- 4 MOSQUE
- 5 COMMUNITY SERVICE
- 6 GATE & GATE HOUSE
- 7 ELEVATED WATER TANK
- 8 SEWAGE TREATMENT PLANT
- 9 PARKING
- 10 FOOTBALL GROUND
- 11 SWIMMING POOL
- 12 TENNIS COURT
- 13 SCHOOL

\* Club house, Hospital, Shop, Post office, Bank, Guest room, etc. are including to COMMUNITY SERVICE.

## 6-2 TRANSMISSION LINE SYSTEM

## 6-2-1 Transmission Line

## 1) 220 kV Overhead Transmission Line

## a. Facility

Voltage	:	220 kV
Conductor	:	AAAC 620 mm <sup>2</sup> x 2
No. of circuits	:	4 circuits
Length	:	40 km
Steel tower	:	2 circuits/tower
Insulators	:	320 mm Fog type insulators 20 pc/string
Ground wire	:	130 mm <sup>2</sup> compound wire with optical fiber

## b. Steel Tower (see: Figs. 6-1, 6-2 and 6-3)

	Height	Weight	No. of Towers
A type tower (tangential)	44.4 m	14.3 t	188
B type tower (light angle)	43.6 m	16.3 t	12
C type tower (heavy angle)	43.6 m	18.4 t	14
D type tower (dead end)	43.6 m	22.9 t	8
<b>Total</b>			<b>222</b>

## 2) Canal Crossing Cable

## a. Facility

Voltage : 220 kV  
 Conductor : OF cable 2,000 mm<sup>2</sup>  
 No. of circuits : 4 circuits  
 Length : 2 km

## 3) 220 kV Branch Line

## a. Facility

Voltage : 220 kV  
 Conductor : AAAC 620 m<sup>2</sup> x 1  
 Length : 1.5 km  
 No. of circuits : 4 circuits  
 Steel tower : 2 circuits/tower  
 Insulators : 320 mm Fog type 20 pc/string  
 Ground wire : 108 mm<sup>2</sup> Zn coated steel  
 strand wire

## b. Steel Tower


A type tower Height: 44.4 m, Weight: 10.9 t, 6 pcs.  
 D type tower Height: 43.6 m, Weight: 17.0 t, 4 pcs.





Fig 6-2  
 220 KV AAAC 620mm<sup>2</sup> x 2: two circuits Tower: B&C Type

220 KV 2cct C Type




220 kv 2 cct B & C Type

Design Condition

No. of circuit	2
Span	350 m
Horizontal angle	30°
Vertical angle	0.1 T
Conductor	
Size	AAAC 620 mm <sup>2</sup> x 2
Dia	28.1 mm
Weight	1674 kg/km/one cond.
Max. tension	5500 kg
Gr. Wire	
Size	130 mm <sup>2</sup> Compound wire with Optical fiber
Dia	17.4 mm
Weight	785.8 kg/km
Max. tension	3200 kg
Insulator	
Type	320 mm Saog 20 pc 2 string
Weight	2200 kg/each
Wind pressure	560 kg/each
Wind pres. to wire	90 kg/m <sup>2</sup>
Wind pres. to tower	255 kg/m <sup>2</sup>

Fig 6-3  
220KV AAAC 620mm<sup>2</sup>x2 : two circuits D Type



**220 kv 2 cct D Type**  
**Design Condition**

No. of circuit	2
Span	350 m
Horizontal angle	Dead end
Vertical angle	0.1 I
Conductor	
Size	AAAC 620mm <sup>2</sup> x2
Dia	28.1 mm
Weight	1674 kg/kw/one cond.
Max. tension	5500 kg
Gr. Wire	
Size	130 mm <sup>2</sup> Compound wire
Dia	with Optical fiber 17.4 mm
Weight	785.9 kg/km
Max. tension	3200 kg
Insulator	
Type	320 mm Saag 20 pc 1/2 string
Weight	2200 kg/each
Wind pressure	580 kg/each
Wind pres. to wire	90 kg/m <sup>2</sup>
Wind pres. to tower	255 kg/m <sup>2</sup>

## 6-2-2 New Suez Substation.

## 1) Main Equipment

a. 240 kV SF<sub>6</sub> gas circuit breaker, with built-in bushing current transformer (outdoor use, Puffer-type)

a) For transmission line : 8 units

Rated voltage : 240 kV

Rated current : 2,000 A

Rupturing capacity: 40 kA

b) For bus coupler : 1 unit

Rated voltage : 240 kV

Rated current : 4,000 A

Rupturing capacity: 40 kA

b. 240 kV Disconnecting Switch (outdoor use)

a) For transmission line : 8 units

(pneumatic operating type)

Horizontal center break type, with earthing switch

Rated voltage : 240 kV

Rated current : 2,000 A

Rated short-time

current : 40 kA

b) For bus (pneumatic operating type)

- Pantagraph type : 16 units

- Horizontal center

break type : 4 units

(45-degree angle installation)

Rated voltage : 240 kV

Rated current : 2,000 A

Rated short-time

current : 40 kA

## c) For bus coupler (pneumatic operating type)

Pantograph type : 4 units  
 Rated voltage : 240 kV  
 Rated current : 4,000 A  
 Rated short-time  
 current : 40 kA

## d) For bus section (pneumatic operating type)

Horizontal center  
 break type : 2 units  
 Rated voltage : 240 kV  
 Rated current : 4,000 A  
 Rated short-time  
 current : 40 kA

## e) 220 kV bus earthing device

(outdoor use, manual operating type)

single phase : 12 units  
 Rated voltage : 240 kV  
 Rated short-time  
 current : 31.5 kA

## c. Capacitance Potential Device

## a) For 220 kV bus (single phase): 12 units

## Rated voltage

Primary :  $220/\sqrt{3}$  kV  
 Secondary :  $110/\sqrt{3}$  V  
 Tertiary : 110 V

## Rated burden

Secondary : 500 VA  
 Tertiary : 100 VA

b) For 220 kV line (single phase): 12 units

Rated voltage

Primary :  $220/\sqrt{3}$  kV

Secondary :  $110/\sqrt{3}$  V

Rated burden

Secondary : 50 VA

2) Other Equipment

- a. Supervisory control panel, operator-console desk, 220 kV system panel and auxiliary panels
- b. AC power source (station service panels and service transformer)
- c. Emergency diesel generator (battery starting system)
- d. DC power source (battery and battery charger)
- e. Outdoor steel structure and bus support
- f. 220 kV conductor  
Aluminium pipe conductor (180  $\phi$  x 10 t, 120  $\phi$  x 8 t)  
Refer to APPENDIX-B.
- g. 220 kV insulator  
Suspension insulators and station post insulators
- h. Air compressor (air reservoir and control panel)
- i. Ground mat materials (annealed copper wire 100 mm<sup>2</sup> and connector)

Fig.6-4 New Suez Substation  
Single line Diagram





Fig. 6-5 Machinery Arrangement Plan of New Suez Substation







6-2-3 Protecting Relay System

1) For Ayun Musa PS Line

a. Main Relay

#1 set Transient comparison or phase comparison based on wave deflection with micro wave system

#2 set Directional comparison distance relay with power line carrier system (three steps)

Distance relay.. Full scheme, No any switching is accepted earlier in zone or type of fault. Multi measuring scheme

b. Reclosing Relay System (one shot)

Three phase reclosing system (dead time adjustable up to 6 sec.)

c. Back-up Relay

Directional over current relay with voltage restraint

d. Others

a) A protection scheme of circuit breaker failure

b) Over-voltage relay blocked with reactive power

c) Low voltage relay

2) For Sakr SS and Suez Tr. SS Line (Other side's relay sets are same.)

a. Main Relay

#1 set Transient comparison or phase comparison with power line carrier system

#2 set Directional comparison distance relay with power line carrier system (Three steps)

b. Reclosing Relay System (one shot)

Three phase reclosing system (dead time adjustable up to 6 sec.)

c. Back-up Relay System

Directional over current relay with voltage restraint

3) For Bus Coupler Circuit Breaker

High speed differential relay and over current relay with voltage restraint

4) For Bus Protection

One protection scheme for bus protection

5) Fault Recorder Sets with sequential chart recorder

6) Fault Localizer

Pulse ejector system and impulse detecting system

7) Continuous Monitoring of Relay System

8) Testing instrument sets at protecting relay room and portable one

## 6-2-4 Communication Equipment

## 1) Micro Wave System

## a. Location of Site

Frequency : 2 GHz

Name of station	Distance (km)	Elevation (m)
Sakr SS		180
	66.2	
Repeater station		500
	32.3	
New Suez SS		70
	23.0	
Ayun Musa PS		5

## b. Equipment


Name of Station	Steel Tower (m)	Parabola Antena	Micro Set	Feeder (m)	D.C. source Battery (24 V)	Charger	Exchanger Battery (48 V)	Charger
Sakr SS	120	8 m $\phi$ x 2	2	270	-	-	-	-
Repeater station	120	8 m $\phi$ x 2 3 m $\phi$ x 2	2 2	410	14V 7.5kAh		-	-
New Suez SS	80	3 m $\phi$ x 2 3 m $\phi$ x 2	2 2	360	500Ah x 2	150 A	108 Ah	20 A
Ayun Musa P.S.	105	3 m $\phi$ x 2	2	405	500Ah x 2	150 A	210 Ah	50 A

## 2) Optical Communication System

Most parts of optical fiber are contained in ground wires of transmission lines. To use the optical fiber for signal transmission is mainly to avoid an induced interference from the heavy loaded cable system. PCM-1.5 M 12 channel is used for signal transmission at both terminals.


Item	Ayun Musa PS	New Suez SS	Ahmed Hamdi Tunnel
PCM-12 channel	2	2	
Optical transmitter	2	2	
Optical fiber cable	0.5 km	0.5 km	2 km
Optical fiber in the groundwire	40 km x 2		

Fig 6-6 MICRO-WAVE COMMUNICATION SYSTEM



	SAKA SS		REP		NEW SUEZ (B)		AYUNMUSAPS		REMARK
	I	W	TO SAKA	TO SUEZ (B)	TO REP	TO AYUNMUSAPS	I	W	
Out Put	(30 dBm)		(30 dBm)	(30 dBm)	(30 dBm)	(30 dBm)	(30 dBm)		
Dia. of ANTENA	8m x 2		8m x 2	3m x 2	3m x 2	3m x 2	3m x 2		
Length of FEEDER	SF-50-13 270m		SF-50-13 220m	SF-50-13 190m	SF-50-13 185m	SF-50-13 175m	SF-50-13 230m		
Received Input	-38. dBm		-38. dBm	-47. dBm	-47. dBm	-45. dBm	-45. dBm		
RELIABILITY	99.9999954		99.9999934		99.9999943				
Hight of TOWER	120m		120m	120m	80m	80m	105m		

Fig. 6-7 Optical fiber system



Note E/O, O/E Optical Signal/Electrical Signal Changer

## 2) Power Line Carrier


## a. Design of Channel

Section:	New Suez SS - Suez SS	New Suez SS - Sakr SS
Method	One phase of each circuit (two metallic ch.)	Two phase each circuit (two metallic ch.)
Channel	Data 2 ch. Voice 2 ch. Protection Ry. 2 ch	Transfer the existing Suez SS to Sakr SS set Addition of Ry. ch. 1 ch.
Band of Frequency	300 kHz - 390 kHz	250 kHz - 300 kHz

## b. Equipment

		New Suez SS	Suez Tr Station	Sakr SS
Coupling Filter	600:75 ohm 175 - 450 kHz	3	2	-
Division Filter	HF, LF 350 kHz HF, LF 340 kHz HF, LF 300 kHz	1 1 1	1 1 -	- - 1
Coaxial Cable		1,200 m	400 m	-
PLC set	2 ch. broad band output 27 dBm	2	2	-
	1 ch. broad band output 27 dBm	3	2	1
Power source		Common with micro set	Common with micro set	Common with existing set

Fig. 6-8 PLC Layout








CHAPTER 7  
PROJECT COST  
(1st Stage 300 MW x 2 Units)



## CHAPTER 7. PROJECT COST

## 7-1 BASIC CONCEPTION OF CONSTRUCTION COST ESTIMATE

- 1) The construction cost will be estimated in consideration of the weighted year of construction period.
- 2) The construction cost are composed of the following categories.



- 3) The construction costs are divided according to domestic currency requirements and foreign currency requirements, with the former including wages for domestic laborers, cost of engineers and technicians required for construction supervision, construction materials such as cement, aggregate, lumber, domestic fuel, etc., which can be produced in Egypt, and domestic transportation costs of imported equipment and materials. All other items are listed up as foreign currency requirements.
- 4) It is assumed that construction will be undertaken by contractors on a turn-key basis according to the specifications which are prepared by consultants under an engineering services contract concluded between EEA and consultants.

During the construction, the consultants are to assist EEA in the performance of supervisory work on the Project.

- 5) Procurement of funds required for construction will be carried out by EEA, the owner, with foreign currency requirements will be borrowed from international financing institutions and domestic currency requirements borrowed from domestic financing institutions.

7-2 SCOPE AND CONDITIONS FOR CONSTRUCTION COST ESTIMATE

1) The Scope of the Project

This Project consists of coal-fired thermal power plant of 300 MW x 2 units, harbor for imported coal, transmission lines from power plant site to interconnecting line and other necessary equipment.

That is to say, the following equipment will be included in this Project.

Access road, land reclamation, embankment, intake and discharge facilities of condenser cooling water system, seawater desalination facilities, boiler, turbine-generator and auxiliaries equipment, coal unloading and transportation facilities, ash treatment equipment, waste water treatment equipment, fuel oil facilities, coal storage yard, ash disposal pond, service building, central shop, warehouse, transmission line facilities, substation facilities, communication facilities, etc.

The minimum required facilities for future extension of 600 MW plant, namely, land reclamation, coal unloading facilities and intake and discharge facilities are considered.

2) Conditions for Construction Cost Estimate

a. The scope of construction cost estimate is summed up necessary costs for the Project with the limits as indicated below.

- a) Expenses for acquisition of land required for construction and for various kinds of indemnities required accompanying construction have not been listed up. However, the cost of leveling the land acquired is included.
- b) Duties and other taxes on imported equipment and materials, taxes on engineering fees, and income tax of foreign engineers are considered to be exempted and are not listed up.
- c) The expenses required for procedures to be taken by EEA, the owner, for loan from financing institution are not included.
- d) The expenses required for coal transportation facilities such as truck, coal cargo, etc., and construction cost of road for coal transportations are excluded.
- e) Cost for coaler and tanker of imported coal and fuel oil transportation are excluded. Accordingly, cost of facilities are listed up pier, unloading facilities, handling facilities from pier to coal storage yard and oil transportation facilities to oil storage tank.
- f) Offices required for construction and operation, access road for construction, spare parts, automobiles and a canteen are included, but staff housing, a guest house, schools are excluded.

b. Conditions for Calculation

a) Foreign Currency Portion

Price in Japan as of 1983 are used as basis and price increases up to the time of weighted year of construction period are considered. And ocean freight from Japan to Egypt is considered.

b) Domestic Currency Portion

Prices in Egypt as of 1982 are taken as reference basis and price increase up to the time of construction are considered.

c) Fuel costs required for trial operation are not included in the construction costs assuming they will be offset by electric power produced in trial operation.

d) The exchange rates for currencies are taken to be the following.

US\$ 1.00 = L.E. 0.823

US\$ 1.00 = 230 yen

L.E. 1.00 = 279.5 yen

e) Contingencies, about 4% for foreign currency and 5% for domestic currency of direct construction cost and 10% of engineering fee are listed on the assumption that these expenses are to be disbursed on the occasion of change in design for unavoidable reasons.

f) As an engineering fee, about 1.1% of direct construction costs are considered as being required for salaries, overhead costs, fee, and for direct expenses such as travelling and communications.

g) Conditions for fund requirement are as follows:

Foreign currency:

- For 80%, an interest rate of 4% and a repayment period of 30 years including grace period of 5 years
- For 20%, an interest rate of 9% and a repayment period of 15 years including grace period of 5 years

Local currency:

- An interest rate of 8% and a repayment period of 15 years including grace period of 3 years

h) Payment Conditions

i. Imported Equipment Cost

20% at conclusion of contract, 70% at lading on board, 10% on completion

ii. Construction Cost

90% of contracted amount paid out on a piece rate, 10% on completion

iii. Engineering Fee

These costs are allocated in proportion to man-month to be estimated according to work quantities by year.



## 7-3 CONSTRUCTION COST ESTIMATION

Construction cost estimation based on the conditions described in Section 7.1 and 7.2 is as shown in Table 7-1, total construction cost will be  $510.4 \times 10^6$  LE. Budget for each phase and budget for each year are shown in Table 7-2 and Table 7-3, respectively.

Table 7-1 Construction Cost

Items	Unit: $\times 10^6$ LE ( $\times 10^6$ US\$)					
	<u>F.C.</u>		<u>L.C.</u>		<u>Total</u>	
<b>1. Generating Facilities</b>						
1) Equipments	262.0	(318.3)	-		262.0	(318.3)
2) Erection	42.2	(51.3)	19.6	(23.8)	61.8	(75.1)
3) Civil works	10.4	(12.6)	18.3	(22.2)	28.7	(34.8)
4) Architectural works	34.0	(41.3)	16.1	(19.6)	50.1	(60.9)
5) Harbor facilities	28.3	(34.4)	7.6	(9.2)	35.9	(43.6)
Sub-total	376.9	(457.9)	61.6	(74.8)	438.5	(532.7)
Unit Construction Cost [LE/kW (US\$/kW)]	-	-	-	-	730.8	(887.8)
<b>2. Transmission Lines and Substation</b>						
1) Transmission lines	25.6	(31.1)	7.5	(9.1)	33.1	(40.2)
Unit Construction Cost [ $10^3$ LE/km ( $10^3$ US\$/km)]	-	-	-	-	760.9	(924.1)
2) Substation	10.8	(13.1)	2.3	(2.8)	13.1	(15.9)
Sub-total	36.4	(44.2)	9.8	(11.9)	46.2	(56.1)
<b>3. Engineering Fee</b>						
	5.4	(6.6)	-	-	5.4	(6.6)
<b>4. Total (1 + 2 + 3)</b>						
	418.7	(508.7)	71.4	(86.7)	490.1	(595.4)
<b>5. Contingency</b>						
	16.7	(20.3)	3.6	(4.4)	20.3	(24.7)
<b>6. Grand Total (4 + 5)</b>						
	435.4	(529.0)	75.0	(91.1)	510.4	(620.1)

Table 7-2 Budget for Each Phase

<u>Items</u>	Unit: $\times 10^6$ LE ( $\times 10^6$ US\$)					
	<u>F.C.</u>		<u>L.C.</u>		<u>Total</u>	
1st Phase	63.4	(77.0)	24.1	(29.3)	87.5	(106.3)
2nd Phase	207.5	(252.1)	32.6	(39.6)	240.1	(291.7)
3rd Phase	164.5	(199.9)	18.3	(22.2)	182.8	(222.1)
Total	435.4	(529.0)	75.0	(91.1)	510.4	(620.1)

Table 7-3 Budget for Each Year

	Unit: $\times 10^6$ LE ( $\times 10^6$ US\$)					
	<u>F.C.</u>		<u>L.C.</u>		<u>TOTAL</u>	
1984	4.0	(4.9)	1.2	(1.5)	5.2	(6.4)
1985	54.0	(65.6)	8.2	(10.0)	62.2	(75.6)
1986	121.6	(147.8)	19.0	(23.0)	140.6	(170.8)
1987	183.9	(223.4)	29.5	(35.8)	213.4	(259.2)
1988	58.7	(71.3)	15.9	(19.4)	74.6	(90.7)
1989	13.2	(16.0)	1.2	(1.4)	14.4	(17.4)
TOTAL	435.4	(529.0)	75.0	(91.1)	510.4	(620.1)

Table 7-4 Generating Cost for the Project

<u>Item</u>	<u>Unit</u>	<u>Formula</u>	<u>Value</u>
A. Unit Capacity	MW		320 x 2
B. Availability	%		80
C. Annual Gross kwh	$\times 10^6$ kWh	$A \times 8.760 \times B / 100$	4,485.1
D. Station Service Loss (kW)	%		6.25
E. Annual Available Energy at P/S Tr. End	$\times 10^6$ kWh	$C \times (1 - D / 100)$	4,204.8
F. Plant Efficiency	%		39
G. Construction Cost including T/L	$\times 10^6$ LE		510.4
H. Fuel Calorific Value	kcal/kg		6,500
I. Fuel Consumption	$\times 10^3$ ton	$\frac{860 \times C}{F \times H} \times 100$	1,521.5
J. Unit Price of Fuel	LE/ton		4.9
K. Fuel Cost	$\times 10^6$ LE	$I \times J \times 10^{-3}$	7.5
L. Operation Maintenance Cost	$\times 10^6$ LE	$G \times 0.02$	10.2
M. Administration Cost	$\times 10^6$ LE	$G \times 0.005$	2.6
N. Depreciation	$\times 10^6$ LE	$G / 30$	17.0
O. Annual Cost	$\times 10^6$ LE	$K + L + M + N$	37.3
P. Generating Cost at P/S Tr. End	Millimes/kWh	$O / E \times 10^3$	8.87
Q. T/L and D/L Loss	%		12
R. Salable Energy at Consumer End	$\times 10^6$ kWh	$E \times (1 - Q / 100)$	3,700.2
S. Salable Unit Price	Millimes/kWh	$33.646 \times 0.7$	23.55
T. Revenue/kWh	Millimes/kWh	$S - P$	14.68
U. Annual Revenue	$\times 10^6$ LE	$R \times T \times 10^{-3}$	54.3



CHAPTER 8  
EXECUTION OF THE PROJECT  
(1st Stage 300 MW x 2 Units)



## CHAPTER 8. EXECUTION OF THE PROJECT

## 8-1 PROJECT SCHEDULE

In performance of the Project, the following overall construction schedule will be considered.

## 8-1-1 Period of Preparatory Works for Execution of the Project

Immediately after the completion of the Feasibility Report, preparatory works such as procurement of finances, employment of a consultant, preparation of tender documents, tendering/contracting and other necessary official procedures will be needed. It will take about 13 (thirteen) months from the application of project finance to the award of contracts.

## 8-1-2 Construction Schedule

The Project will be divided into three phases.

In the first phase, construction of harbor facilities, power plant site reclamation works, detailed design of main equipments and materials of power plant for 300 MW X 2, foundation works of boiler, turbine and generator, and construction of powerhouse for No.1 Unit and New Suez Substation will be carried out.

In the second phase, erection works of two 220 kV outgoing transmission lines out of 4 lines as well as erection and installation works, and civil and architectural works for No. 1 Unit and foundation works and construction of powerhouse for No.2 Unit will be carried out uninterruptedly.

In the third phase, the erection works, civil and architectural works for No. 2 Unit, and erection works of the remaining two 220 kV outgoing transmission lines will be carried out following the second phase. The construction schedule for the Project is shown in Table 8-1 and 8-2.

8-1, 8-2, it takes 44 months from the first phase contract to the taking-over of the first unit, and 50 months from the first phase contract to the taking-over of the second unit, and the major events for each phase are summarized as follows:

1) First Phase

a. Harbor Facilities

<u>Major Events</u>	<u>After First Phase Contract Signing</u>
Dredging start	7 months
Piling start	14 months
Completion	38 months

b. Detailed Design for Power Plant, BTG Foundation and Powerhouse

<u>Major Events</u>	<u>After First Phase Contract Signing</u>
Foundation works start	9 months
Completion	43 months

c. New Suez Substation

<u>Major Events</u>	<u>After First Phase Contract Signing</u>
Foundation star	13 months
Completion	32 months

2) Second Phase

a. Power Plant (1st Unit)

<u>Major Events</u>	<u>After First Phase Contract Signing</u>
Drum lifting	22 month
Initial firing (Light off)	35 months
Steam admission	37 months
Operating test start	37 months
Commissioning (of 1st unit)	41 months
Taking over	44 months



## b. Transmission Line

<u>Major Events</u>	<u>After First Phase Contract Signing</u>
Foundation start	9 months
Erection start	17 months
Stringing start	24 months
Completion	30 months

## 3) Third Phase

## a. Power Plant (2nd Unit)

<u>Major Events</u>	<u>After First Phase Contract Signing</u>
Drum lifting	28 months
Initial firing (Light off)	41 months
Steam admission	43 months
Operating test start	43 months
Commissioning (of 2nd unit)	47 months
Taking over	50 months

## b. Transmission Line

<u>Major Events</u>	<u>After First Phase Contract Signing</u>
Foundation start	23 months
Erection start	30 months
Stringing start	39 months
Completion	45 months

- 4) The consultant will render the engineering services through the entire period of the Project until its completion after signing consultancy agreement.
- 5) The total Project period is 57 months after contract signing for consultant.



Table 8-2 SINGI COAL-FIRED THERMAL POWER PROJECT  
CONSTRUCTION PROGRAM (Tentative) 1st STAGE

ITEMS	YEAR & MONTHS																																
	1984			1985			1986			1987			1988			1989																	
	4	5	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12
Finance Schedule (L/N)	[Gantt chart bars for Finance Schedule]																																
Major Event Schedule	[Gantt chart bars for Major Event Schedule]																																
1. NO. 1 Unit	[Gantt chart bars for Unit 1]																																
NO. 2 Unit	[Gantt chart bars for Unit 2]																																
Overall Schedule	[Gantt chart bars for Overall Schedule]																																
Transmission Lines and Substations (1,2L)	[Gantt chart bars for Transmission Lines and Substations (1,2L)]																																
Transmission Lines and Substations (3,4L)	[Gantt chart bars for Transmission Lines and Substations (3,4L)]																																
Civil	[Gantt chart bars for Civil works]																																
1. Harbor Facilities	[Gantt chart bars for Harbor Facilities]																																
2. Land Reclamation	[Gantt chart bars for Land Reclamation]																																
3. Intake & Discharge Channels	[Gantt chart bars for Intake & Discharge Channels]																																
4. Coal Storage Yard	[Gantt chart bars for Coal Storage Yard]																																
5. Ash Disposal Area	[Gantt chart bars for Ash Disposal Area]																																
6. Desalination Plant Foundation	[Gantt chart bars for Desalination Plant Foundation]																																
7. Fuel Oil Tanks & Water Tanks Foundation	[Gantt chart bars for Fuel Oil Tanks & Water Tanks Foundation]																																
Architectural	[Gantt chart bars for Architectural works]																																
1. Powerhouse	[Gantt chart bars for Powerhouse]																																
2. Service Building	[Gantt chart bars for Service Building]																																
3. Appurtenant Buildings	[Gantt chart bars for Appurtenant Buildings]																																
4. Stack	[Gantt chart bars for Stack]																																
5. Boiler Foundation	[Gantt chart bars for Boiler Foundation]																																
6. Turbine-Generator Foundation	[Gantt chart bars for Turbine-Generator Foundation]																																
7. Misc. Equipment Foundation	[Gantt chart bars for Misc. Equipment Foundation]																																
Electro-Mechanical	[Gantt chart bars for Electro-Mechanical works]																																
1. Boiler	[Gantt chart bars for Boiler]																																
2. Turbine-Generator	[Gantt chart bars for Turbine-Generator]																																
Station Service Electrical Equipment	[Gantt chart bars for Station Service Electrical Equipment]																																
3. Instrument and Control	[Gantt chart bars for Instrument and Control]																																
Coal Unloading and Coal Handling	[Gantt chart bars for Coal Unloading and Coal Handling]																																
4. Equipment	[Gantt chart bars for Equipment]																																
5. Desalination Equipment	[Gantt chart bars for Desalination Equipment]																																
6. Fuel Oil Tank	[Gantt chart bars for Fuel Oil Tank]																																
7. Starting Gas Turbine Generator	[Gantt chart bars for Starting Gas Turbine Generator]																																
8. Main Transformer	[Gantt chart bars for Main Transformer]																																
Electrical	[Gantt chart bars for Electrical works]																																
1. 220 KV Transmission Line (1,2L)	[Gantt chart bars for 220 KV Transmission Line (1,2L)]																																
2. 220 KV Transmission Line (3,4L)	[Gantt chart bars for 220 KV Transmission Line (3,4L)]																																
3. 220 KV Ayun Musa P/S, S.Y.	[Gantt chart bars for 220 KV Ayun Musa P/S, S.Y.]																																
4. 220 KV New Suez S.Y.S.	[Gantt chart bars for 220 KV New Suez S.Y.S.]																																
5. Communication System	[Gantt chart bars for Communication System]																																



## 8-2 PROCUREMENT PROGRAM FOR THE PROJECT

As for the supply and construction it is desirable for procurement method to adopt one-package contract system on turnkey basis from the viewpoint of the matter of the Project.

Since this Project that is a public utility in Egypt is required high reliability for power supply, all of the construction works including civil and architectural works have to be high quality. Therefore, the contractor is with high sufficient qualification.

As a rule, equipment and materials for the Project which are able to procure in Egypt are to be adopted. Boiler, turbine, generator, main transformer and others procured at the outside of the Egypt by contractor will be shipped after pass of factory test.

As a rule, prime contractor will employ the local contractor for civil and architectural works and erection works for equipment. However, as mentioned above, since high quality for the construction works is required, foreign contractor may assist partially in case of a shortage of the construction technique in the part of local contractor.

And special construction technique and guidance by foreign engineers, technicians and skilled labor may be required for adjustment of overall construction schedule.

8-3 ORGANIZATION FOR THE PROJECT


8-3-1 Organization

EEA will employ the consultant to assist the construction works for promotion of the Project because this Project is the first coal fired thermal power project in Egypt and its completion date has been already decided.

On the other hand, it is desirable for construction works to be procured in a lump-sum amount to be made clear of the organization of the Project and to be promoted smoothly.

Organization chart among EEA, consultant and contractor is as follows.

Fig. 8-1 Organization Chart



8-3-2 Duties

Major duties carried out by EEA and by consultant to complete this Project are as follows.

1) Duties Performed by EEA

a. Selection of consultant

b. Investigation and Study Items

Examination and final decision of general conditions, special conditions, technical specifications, drawings, etc., for the contract

Study of site conditions

c. Tendering and Contracting

Tendering and Bid Evaluation with the assistance of consultant and L/C open and procedures.

d. Decision of execution method of the Project

Personnel organization, construction plan, construction supervision method, test program, acceptance method, etc.

e. Preparatory works of construction

Land procurement, compensation, other necessary investigation

f. Inspection and coordination of construction

g. Testing and test operation, evaluation of the performance and acceptance of power plant

h. Testing and test operation, evaluation of the performance and acceptance of T/L and S/S

i. Others

2) Duties Performed by Consultant

As assistance works for EEA;

a. Check of feasibility report

- b. Assistance in finance procurement and technical procedures based on the guideline of financing institution
- c. Field survey and basic design for overall items
- d. Preparation of bidding documents
- e. Assistance in tendering and contracting
- f. Check and review of approval drawings and data submitted by contractor
- g. Preparation of detailed instruction drawings for civil and architectural works
- h. Inspection and witness of factory test
- i. Construction supervision
- j. Preparation of test program
- k. Assistance in tests
- l. Witness of acceptance test and data analysis
- m. Training of EEA's engineers for operation and maintenance
- n. Compiling of operation/maintenance manuals
- o. Preparation of progress reports and completion report