

ANNEX 6

GROUNDWATER UTILIZATION CONDITIONS OF  
REFUGEE CAMPS






Fig. A6-2 Refugee Camp Buur Dhubo




Fig. A6-1 Refugee Camps in the Gedo Region




Fig. A6-4 Refugee Camp Suriya




Fig. A6-3 Refugee Camp Hila Marseer




Fig. A6-5 Refugee Camp Halba I and Halba II




Fig. A6-6 Refugee Camp Halgan




Fig. A6-8 Refugee Camp Amalo




Fig. A6-7 Refugee Camps in the Hiran Region




Fig. A6-10 Refugee Camp Sigalow




Fig. A6-9 Refugee Camp Boocoi




Fig. A6-12 Refugee Camp Jalalaqsi I, III and IV




Fig. A6-11 Refugee Camp Lug Jellow






Fig. A6-13 Refugee Camp Jalalagsi II



**ANNEX 7**

**COST ESTIMATE FOR WATER SUPPLY DECADE**



Table A7-1 Cost Estimates for an 80% Urban Water Supply Coverage by 1990 (based on 1983 dollars)

	68 Towns	Mogadishu	Hargeisa	Kismayo	Total
1. 1982 population	400,000	540,000	190,000 <sup>1/</sup>	50,000	1,180,000
2. 1990 population	536,000	700,000	254,000	80,000	1,570,000
3. 60% of 1982 pop.	240,000	324,000	114,000	30,000	708,000
4. 80% pop. coverage 1990	428,000	560,000	203,000	64,000	1,256,000
5. New population coverage by 1990 (4)-(3)	188,000	236,000	89,000	34,000	548,000
6. Unit costs					
a) New coverage item (5)	\$100/cap.	\$160/cap.	\$160/cap.	\$160.000	N.A.
b) Upgrade existing systems under item(3)	\$ 67/cap.	\$ 48/cap.	\$ 48/cap.	\$ 48.000	N.A.
7. Total cost					
a) New coverage item (5)	\$18.90 mio.	\$37.80 mio.	\$14.24 mio.	\$5.44 mio.	\$76.38 mio.
b) Upgrade item (3)	\$16.08 mio.	\$15.55 mio.	\$ 5.47 mio.	\$1.44 mio.	\$38.54 mio.
<b>Total</b>	<b>\$34.98 mio.</b>	<b>\$54.35 mio.</b>	<b>\$19.71 mio.</b>	<b>\$6.88 mio.</b>	<b>\$114.92 mio.</b>

1/ According to population data in chapter I, Hargeisa's 1981 population was reported to be 84,000. This is much lower than other estimates provided in interviews. Thus the figure adopted for 1982 is 190,000. Accordingly a downward adjustment was made in the population for the other 68 centres.

Table A7-2 Cost Estimates for a 50% Rural Nomadic Water Supply Coverage (based on 1983 dollars)

	Deep Drilled Wells	Dug Wells	Rainwater Catchments	Infiltration Galleries	Surface Water Slow Sand Filters	Total
1. Number of systems	88	1,000	750	450	150	2,438
2. Total population served	390,000	790,000	920,000	390,000	130,000	2,620,000
3. Ave. population served per system	4,430	790	1,230	870	870	N.A.
4. Ave. cost per system in US \$	220,000	10,000	222,500	70,000	60,000	N.A.
5. Ave. unit cost \$/capita	50	12.5	180	80.00	70.00	N.A.
6. Total cost in mio. US \$	19.36	10.00	166.93	31.50	9.00	236.78



**ANNEX 8**

**HYDROLOGICAL AND METEOROLOGICAL DATA**





Table A8-1 Mean Monthly and Annual Shabeelle River Flows cm<sup>3</sup>/sec)

Station number 15,  
Awdheegle

	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.	Annual Total
1963	2.84	-	-	-	-	62.04	38.61	65.76	73.81	69.71	37.50	67.33	-
64	33.34	13.28	4.59	11.27	28.08	14.85	19.49	59.07	74.72	33.68	66.30	23.32	421.99
65	39.59	11.34	3.12	1.73	35.10	9.08	2.47	6.72	46.43	57.01	74.31	43.62	330.52
66	8.26	1.49	-	-	59.74	29.85	24.56	36.99	66.96	68.21	64.13	15.86	-
67	1.51	0.0	-	-	-	-	-	-	-	-	-	-	-
68	-	-	-	52.35	74.29	71.97	-	-	-	-	-	-	-
71	-	-	-	-	-	-	-	83.97	87.07	76.83	-	-	-
77	11.65	11.30	14.40	43.11	99.20	70.86	-	99.70	93.47	88.84	96.37	97.54	-
78	37.58	-	-	60.14	81.08	72.36	-	-	-	-	85.63	40.65	-
81	0.0	0.0	13.23	77.90	85.24	64.07	39.28	67.98	83.33	83.23	60.52	25.03	599.81
83	54.90	39.28	33.54	29.39	-	88.71	70.22	83.70	84.72	82.83	83.80	58.62	-
84	32.97	26.08	26.49	17.05	25.74	61.33	50.08	72.35	71.12	69.87	32.21	-	-
Mean	22.26	12.85	15.90	36.62	60.93	54.51	34.96	72.39	75.74	74.47	66.25	46.50	573.88

Table A8-2 1977 Per Season Water Consumption

Canal	Gross area irrigated (ha)	Measured discharge (m <sup>3</sup> /s)					Approximate monthly consumption (Mm <sup>3</sup> )				
		Aug	Sep	Oct	Nov	Dec	Aug	Sep	Oct	Nov	Dec
Sigaale	290	0.00	0.00	1.80	1.06	0.68	0.0 (1)	0.0 (1)	4.8	2.8	1.8
Giddu	600	0.00	0.37	1.21	0.69	0.05	0.0 (1)	1.0 (2)	3.2	1.8	0.1
Asayle	7 550	1.67	1.23	4.13	2.02	1.03	2.8 (3)	2.9 (2)	11.1	5.2	2.8
Dhamme Yaasiin	9 630	3.20	2.75	6.23	6.37	3.25	8.6	7.1	16.7	16.5	8.7
Primo Secundario	13 690	5.13	6.66	6.98	5.73	4.64	13.8	17.3	18.7	14.8	12.4
Wadajir	2 890	0.88	0.91	0.86	0.77	0.44	2.4	2.4	2.3	2.0	1.2
Liibaan	1 230	0.12	0.00	0.11	0.00	0.07	0.3	0.0	0.3	0.0	0.2
Bokore	5 730	1.96	1.70	2.69	2.69	1.14	5.3	4.4	7.2	7.0	3.1
Sub-total of 8 main canals	41 620	12.96	13.62	24.01	19.33	11.3	33.2	35.1	64.3	50.1	30.3
TOTAL for complete irrigated area	54 180	16.87	17.73	31.26	25.16	14.71	43.2	45.7	83.7	65.2	39.4

Notes: (1) closed all month for weed clearance  
 (2) closed 6th - 9th for seepage test  
 (3) closed 13th - 25th for repair work

Table A8-3 Monthly and Annual Rainfall (mm)

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual Total
1929	?	?	?	?	?	122.0	64.0	52.9	196.9	26.2	117.8	19.1	(559.3)
1930	0.0	0.0	1.0	234.8	70.7	22.7	22.0	13.0	0.0	76.2	25.0	80.5	545.9
1931	0.0	2.0	0.0	33.5	276.6	42.6	45.2	30.7	0.0	3.6	61.1	2.5	497.8
1932	0.0	0.0	0.0	2.8	47.6	49.6	50.2	37.7	15.9	3.2	18.0	20.7	245.7
1933	21.1	0.0	0.0	99.2	13.8	39.4	39.3	34.0	14.7	42.8	41.5	40.2	386.0
1934	0.0	0.0	0.0	64.4	90.0	39.4	57.3	85.3	50.8	15.5	22.7	3.8	429.2
1935	0.0	0.0	0.0	24.1	114.0	77.2	58.2	58.0	10.4	14.0	30.2	34.6	420.7
1936	0.0	0.0	0.0	59.8	0.0	69.6	99.5	57.0	13.3	27.4	2.6	112.4	441.6
1937	0.4	0.0	11.1	204.0	66.0	111.1	110.0	21.7	61.0	70.5	54.8	14.0	724.6
1938	0.0	0.0	0.0	19.0	77.8	137.5	48.0	76.0	10.2	117.5	10.7	14.0	510.7
1939	0.0	0.0	0.0	35.5	28.0	79.9	0.0	24.7	3.0	94.7	29.3	8.0	303.1
1940	0.0	0.0	18.0	?	?	?	?	?	?	?	?	?	(18.0)
1944	0.0	0.0	5.0	78.5	29.5	41.0	35.5	88.0	3.5	31.7	2.0	7.5	322.2
1945	0.0	0.0	0.0	101.2	43.8	67.2	60.3	51.5	11.8	3.2	46.0	19.4	404.4
1946	0.0	0.0	0.0	9.0	51.0	164.6	49.5	34.5	9.0	45.0	?	0.0	(362.6)
1947	0.0	0.0	0.0	96.0	155.5	38.5	37.0	164.0	0.0	0.0	?	?	(491.0)
1948	?	?	?	?	7.0	112.2	?	?	?	?	?	?	(119.2)
1951	0.0	0.0	30.2	73.1	226.0	238.4	107.5	73.8	19.7	61.1	88.3	127.3	1,045.4
1952	0.0	0.0	0.0	53.2	31.0	105.8	5.4	0.0	0.0	35.8	69.1	0.0	300.3
1953	5.4	0.0	24.2	73.5	10.0	40.2	62.1	60.0	38.4	47.5	172.1	9.9	543.3
1954	0.0	0.0	0.0	76.7	60.2	76.3	20.2	37.9	11.6	10.0	61.2	33.0	387.1
1955	5.3	0.0	0.0	17.0	47.5	30.9	31.5	6.1	1.7	0.5	2.3	6.1	148.9
1956	0.0	0.0	0.0	111.7	31.5	65.5	72.3	7.6	1.2	5.9	108.4	0.2	404.3
1957	1.4	0.0	0.0	61.6	102.8	75.1	145.7	12.5	20.4	19.7	101.9	10.8	551.9
1958	0.5	0.0	0.2	141.9	118.7	84.0	39.5	63.5	0.6	0.6	38.8	12.2	500.5
(1929 ~ 1959)													
Mean	1.5	0.1	3.9	75.9	73.9	80.5	54.8	47.4	21.5	32.7	52.6	26.2	471.0
1980	0.0	0.0	0.0	?	?	?	?	68.5	0.0	58.5	66.5	0.0	244.0
1981	0.0	0.0	8.4	221.2	183.5	?	44.3	234.4	4.4	2.0	34.0	11.0	747.0
1982	0.0	0.0	0.0	111.6	71.0	114.0	102.0	10.0	1.0	77.2	50.2	26.6	569.6
1983	0.0	0.0	0.0	48.0	120.2	30.1	46.2	35.3	0.0	13.6	38.4	0.0	331.8
1984	0.0	0.0	0.0	12.0	54.0	94.7	40.4	0.0	0.0	0.0	112.6	0.0	313.7
(1980 ~ 1984)													
Mean	0.0	0.0	1.7	98.2	107.2	79.6	58.2	69.6	1.1	30.3	61.5	7.5	441.2
(1929 ~ 1984)													
Mean	1.2	0.1	3.5	79.3	76.0	80.4	55.3	51.4	17.9	32.3	54.3	22.7	465.0

Table A8-4 Monthly and Annual Absolute Maximum Temperatures (°C)

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
1930	?	?	39.0	39.0	35.0	35.0	34.0	35.0	36.0	35.0	35.0	34.0	(39.0)
1931	35.0	38.0	37.0	39.0	38.0	31.0	30.5	31.0	30.5	31.0	32.0	31.5	39.0
1932	33.0	32.0	32.5	32.0	32.5	31.5	29.5	29.0	29.5	31.0	31.0	32.0	33.0
1933	31.0	32.0	32.0	35.0	32.0	30.5	28.5	?	29.5	31.0	33.0	36.0	(36.0)
1934	38.0	37.0	37.0	33.0	33.0	30.5	30.0	29.8	30.8	30.8	32.0	33.0	38.0
1935	32.8	34.0	36.0	35.0	37.0	33.0	29.0	30.0	31.0	31.0	32.0	33.0	37.0
1936	33.0	33.0	33.0	33.5	33.0	31.0	30.0	31.0	31.5	32.0	33.0	33.5	33.5
1937	35.5	36.0	36.5	?	?	?	32.0	29.5	29.2	?	32.0	31.0	(36.5)
1938	31.8	33.0	34.5	32.8	31.5	30.5	27.5	28.0	30.0	29.6	30.5	33.4	34.5
1939	34.2	32.8	33.6	32.6	31.6	30.5	29.5	29.6	29.8	?	?	?	(34.2)
1953	35.0	35.4	38.5	38.0	33.6	33.2	30.0	29.0	30.0	31.5	32.2	33.7	38.5
1954	35.5	34.8	35.2	34.8	33.5	31.2	29.1	31.0	30.6	32.7	32.8	33.8	35.5
1955	34.5	35.0	35.1	35.0	34.2	31.8	30.6	30.2	30.4	32.4	34.2	34.9	35.1
1956	35.5	36.6	36.3	36.7	32.7	30.3	29.3	30.4	40.8	31.5	33.4	34.4	36.7
1957	37.2	35.2	36.2	36.1	34.0	32.5	30.5	30.2	30.2	31.6	33.6	33.3	37.2
1958	33.7	35.6	33.9	33.9	32.8	30.3	29.8	31.2	32.2	32.5	34.0	33.3	35.6
Max.	38.0	38.0	39.0	39.0	38.0	35.0	34.0	35.0	36.0	35.0	35.0	36.0	39.0

Table A8-5 Monthly and Annual Absolute Minimum Temperatures (°C)

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual
1930	?	?	21.0	23.0	23.0	21.0	20.0	21.0	20.0	23.0	21.0	21.0	(20.0)
1931	20.0	21.0	22.0	23.0	23.0	22.0	21.0	19.5	19.5	21.5	21.5	19.0	19.0
1932	29.9	18.0	21.5	21.0	22.0	20.0	19.0	19.0	20.0	21.5	20.5	20.5	18.0
1933	19.5	21.0	20.0	21.0	21.0	19.0	19.0	?	19.0	21.0	19.0	15.0	(15.0)
1934	13.0	18.0	19.0	22.0	21.5	19.0	18.5	18.9	18.0	20.2	19.0	18.1	13.0
1935	18.6	19.2	18.6	?	19.0	18.0	18.0	20.0	21.0	21.0	20.0	21.0	(18.0)
1936	20.0	20.5	22.0	22.5	23.0	21.5	20.5	19.5	19.5	20.5	21.0	20.0	19.5
1937	19.0	20.5	21.0	?	?	?	21.0	18.0	19.0	?	20.5	18.5	(18.0)
1938	18.0	18.0	18.0	21.0	22.0	20.0	19.0	17.0	18.8	19.6	19.4	18.8	17.0
1939	18.0	19.1	19.9	20.3	20.8	19.4	17.2	17.2	23.9	?	?	?	17.2
1953	17.5	18.0	21.4	21.7	21.0	19.5	19.4	19.4	18.0	19.5	21.0	19.5	17.5
1954	17.5	19.0	20.5	21.5	21.2	20.0	19.2	18.0	19.2	20.2	20.1	18.0	17.5
1955	18.0	17.0	19.1	21.0	20.5	19.4	19.1	18.2	19.3	20.5	20.7	20.0	17.0
1956	18.	18.6	21.0	21.2	21.2	19.8	18.4	18.9	20.1	20.6	20.0	19.2	18.4
1957	19.2	18.4	21.0	21.2	20.1	19.0	18.5	18.8	19.3	22.1	20.1	18.2	18.2
1958	18.9	19.2	20.1	20.0	22.6	21.5	19.0	20.0	20.3	20.6	19.8	20.0	18.9
Min	13.0	17.0	18.0	20.0	19.0	18.0	17.2	17.0	18.0	19.5	19.0	15.0	13.0

Table A8-6 Mean Monthly and Annual Average Daily Temperatures (°C)

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Mean annual
1930	?	?	29.7	30.0	28.4	27.4	26.6	28.2	28.6	29.1	27.9	27.8	(28.3)
1931	28.3	29.1	30.0	30.9	28.1	26.0	26.1	25.6	26.1	26.9	27.1	25.7	27.5
1932	26.7	25.5	27.2	27.3	27.1	25.6	24.7	24.5	25.4	26.2	26.3	26.5	26.0
1933	25.7	26.3	26.5	27.4	26.7	25.0	24.7	?	25.2	26.1	26.3	27.5	(26.1)
1934	26.1	27.9	28.8	27.8	27.4	25.1	25.1	25.1	25.4	26.3	26.2	26.5	26.5
1935	25.9	26.9	?	?	27.4	25.3	24.8	24.8	25.6	26.4	26.2	26.7	(26.0)
1936	26.9	26.6	27.4	27.9	28.2	26.3	25.2	25.2	26.1	26.8	27.0	26.9	26.7
1937	27.5	27.8	28.6	?	?	?	25.6	24.5	25.1	?	25.9	25.1	?
1938	25.5	26.3	26.9	27.4	26.5	24.9	23.7	23.5	24.9	25.1	25.4	25.7	25.5
1939	25.4	26.2	26.8	26.8	26.4	24.8	24.4	25.3	27.3	?	?	?	?
1953	26.4	27.9	28.9	29.3	27.8	25.7	24.8	24.6	25.4	25.9	26.6	27.0	26.6
1954	26.4	27.4	28.3	28.3	27.5	25.5	24.8	24.9	25.6	26.4	26.6	26.2	26.5
1955	27.1	27.2	28.3	28.4	27.3	25.5	25.0	24.9	25.4	26.9	27.3	27.8	26.8
1956	27.7	27.9	29.3	28.9	27.2	25.5	24.6	25.2	25.8	26.4	26.5	27.0	26.8
1957	27.3	27.3	28.8	28.7	27.1	25.9	24.4	24.9	25.2	26.6	26.5	26.2	26.6
1958	26.7	27.0	27.5	28.0	27.2	26.4	24.9	25.4	26.0	27.0	27.0	27.1	26.7
(1930 ~ 1958)													
Mean	26.6	27.2	28.2	28.3	27.4	25.7	24.9	25.1	25.8	26.6	26.6	26.6	26.6
1980	26.7	26.5	27.3	?	?	?	26.3	25.4	25.2	26.7	26.4	28.4	26.5
1981	26.8	26.8	27.3	26.5	26.7	26.5	26.7	26.4	27.1	28.1	28.0	27.2	26.8
1982	28.1	28.1	29.8	28.7	27.9	27.0	26.1	26.0	27.0	27.7	27.8	27.8	27.2
1983	28.0	28.8	29.5	29.6	28.3	27.3	26.8	26.4	27.4	27.7	28.3	28.4	28.0
1984	28.8	27.2	28.0	29.6	28.0	26.1	25.4	25.6	26.6	27.5	27.6	27.8	27.3
(1980 ~ 1984)													
Mean	27.7	27.7	28.4	28.6	27.7	26.7	26.3	26.0	26.7	27.5	27.6	27.9	27.2
(1930 ~ 1984)													
Mean	26.9	27.3	28.3	28.4	27.5	25.9	25.2	25.3	26.0	26.8	26.9	26.9	26.8

Table A8-7 Average and Design Reference Evaporation Rates

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Average reference evaporation rate (mm/d)	5.03	5.44	5.65	5.06	4.66	4.26	4.21	4.55	5.11	4.77	4.26	4.54	
Design reference evaporation rate (mm/d)	5.53	5.98	6.22	5.57	5.13	4.69	4.63	5.01	5.62	5.25	4.69	4.99	
(mm/month)	171.43	167.44	192.82	167.1	153.9	140.7	143.53	150.3	168.6	162.75	140.7	154.69	1,913.96 (Annual)





**ANNEX 9**

**DATA OF EXISTING WELLS**



Table A9-1 Summary of Well and Aquifer Characteristics

Well No.	Date	Q (m <sup>3</sup> /h)	Maximum draw-down (m)	SC (m <sup>3</sup> /h/m)	T (m <sup>2</sup> /s)	Method of analysis	S	Comments
M12	-	120	15	8.0				Failface data
M18	-	120	15	8.0				
M20	-	36	19	1.9				
M21	-	3	3	1.0				
M27	-	120	11	10.9				
M41	10/10/73	9.6	5.2	1.9	17	Boulton	-	r/b=0.1; recovery and drawdown data
M42	-	130	7	18.6				
M43	-	120	13.5	8.8				
M46	-	120	12.5	9.6				
M55	-	120	10.0	12.0				
M57	-	130	12.5	11.3				
M63	-	130	8	16.2				
M68	-	100	12	8.3				
M72	-	120	11.5	16.4				
M80	-	120	9.5	12.6				
M81	-	120	9	13.3				
M90	-	120	9.5	12.6				
M99	-	140	13.5	10.3				
M100	-	120	9.5	12.7				
M103	13/2/78	-	-	-	480	Boulton	6.8x 10 <sup>-3</sup>	r/b=1.0 (observation well)
M104	-	120	11.5	10.4				
M104	13/2/78	201	7.8	25.8	275	Boulton		r/b=0.1
M107	-	120	7.8	15.4				
M109	-	100	9	11.0				
M114	-	120	10	12.0				
M117	-	110	9	12.0				
M121	-	110	13	8.4				
M122	-	100	17	5.8				
M123	-	120	11.5	10.0				
M125	-	120	16.5	7.2				
M126	30/10/73	206	11.7	17.6	58	Boulton	-	r/b=0.6; drawdown data
M127	-	110	11.5	9.5				
M128	-	100	25.5	4.0				
M142	14/10/73	25	8.1	3.1	29	Boulton	-	r/b=0.1; recovery and drawdown data
M143	13/10/73	195	5.2	37.5	759	Theis	-	Recovery and drawdown data
M144	-	100	12.5	8.0				
M145	9/10/73	200	8.4	23.8				Data inconsistent
M148	10/10/73	247	9.4	26.3	262	Boulton	-	r/b=0.1; recovery and pumping data
M149	June/73	194	9.2	21.0	212	Boulton	-	r/b=0.1; recovery data
M149	Oct/73	238	12.3	19.3	245	Boulton	-	r/b=0.05; pumping and recovery data
M150	20/10/73	169	12.0	14.1	147	Boulton	-	r/b=0.1; pumping and recovery data
M154	-	120	12.0	10.0				
M155	24/6/73	187	5.8	32.2	210	Boulton	-	r/b=0.2; recovery data
M155	17/10/73	271	5.0	54.2	157.3	Boulton	-	r/b=0.6; recovery and drawdown data
M156	June/73	187	3.6	51.9	235	Boulton	-	r/b=0.5; recovery data
M156	16/10/73	288	13.2	21.8	250	Boulton	-	r/b=0.1; recovery and drawdown data
M158	-	120	7	17.0				
M169	11/10/73	203	12.4	16.4				Data inconsistent
M170	11/10/73	257	13.7	18.8	135	Boulton	-	r/b=0.5; drawdown data
M170	18/6/73	187	8.0	23.4	319	Theis	-	Recovery data
M171	19/6/73	130	14.1	9.3	42	Boulton	-	r/b=0.4; recovery data
M174	29/10/73	222	7.4	30.0	232.1	Boulton	-	r/b=0.1; recovery and drawdown data
M174	June/73	202	8.9	22.7	68.8	Boulton	-	r/b=0.6; recovery data
M176	-	120	12.0	10.0				
M178	-	120	9.5	12.6				
M185	18/10/73	231	10.9	21.2	67	Boulton	-	r/b=0.6; recovery data

(Cont.)

Well No.	Date	Q (m <sup>3</sup> /h)	Maximum draw-down (m)	SC (m <sup>3</sup> /h/m)	T (m <sup>2</sup> /d)	Method of analysis	S	Comments
M186	-	100	11	9.0				
M187	-	120	11	10.9				
M194	-	100	12	7.9				
M194	17/ 6/73	137	11.8	11.6	73	Boulton	-	r/h = 0.8; recovery data show barrier effect
M194	24/10/73	205	18.5	11.1	341	Theis	-	Shows barrier effect. Recovery and drawdown data
M194	15/10/77	158	26.0	6.1	138	Theis	-	First 10 minutes valid pumping
M194	15/10/77	-	-	-	116	Theis	-	Recovery
M196	16/ 6/73	98	4.2	23.3	216	Boulton	-	r/b=0.6; recovery data show barrier effect
M197	-	100	10	10.0				
M198	-	110	10.5	10.5				
M199	21/ 6/73	151	2.3	65.6	535	Boulton	-	r/b=0.2; recovery data
M199	10/10/73	110	4.7	23.4	207	Boulton	-	r/b=0.1; pumping and recovery data
M202	29/10/73	241	10.5	23.0	419	Theis	-	Recovery and drawdown data
M205	25/ 6/73	112	7.6	14.7	234	Theis	-	Recovery data
M206	15/10/73	119	10.3	11.6	38	Boulton	-	r/b=0.6; recovery and drawdown data
M207	Oct/73	83	8.3	10.0	62	Boulton	-	r/b=0.4; drawdown and recovery data
M209	-	100	18.0	5.5				
M210	11/12/73	-	-	-	43	Boulton	-	r/b=0.4; recovery with barrier
M210	11/12/73	51.4	8.2	6.3	58	Boulton	-	r/b=0.1; affected by changes in pumping rate
M212	12/ 1/73	198	4.8	41.3	382	Boulton	-	r/b=0.1; recovery data
M212	-	120	11	10.9				
M217	-	100	12	8.3				
M220	-	100	11	9.0				
M221	-	110	8.5	14.6				
M223	-	100	9	11.1				
M226	-	100	11.5	8.6				
M231	1/ 7/73	194	13.7	14.2	206	Theis	-	Recovery
M231	13/10/73	262	13.3	19.7	137	Boulton	-	r/b=0.2; recovery and pumping data
M232	30/ 6/73	187	7.9	23.7	238	Boulton	-	r/b=0.1; recovery data
M233	14/ 6/73	158	3.3	47.9	350	Boulton	-	r/b=0.2; recovery data
M233	14/10/73	240	7.0	34.3	358	Boulton	-	r/b=0.1; recovery and pumping data
M235	-	110	14.0	8.0				
M236	10/ 6/73	169	25.0	6.8	150	Boulton	-	r/b=0.1; recovery data
M236	Oct/73	195	22.9	8.5	120	Theis	-	Recovery and drawdown values differ
M241	Jan/78	-	-	-	374	Boulton	0.38 x 10 <sup>-3</sup>	r/b=0.1; (observation well, Agrotec test M240)
M252	-	100	15.0	6.6				
M256	-	140	7.0	20.0				
M265	-	100	8.0	12.5				
M267	30/10/73	14.7	2.2	6.7	85	Boulton	-	r/b=0.05; recovery and drawdown
M295	18/10/77	-	-	-	687	Theis	1.7 x 10 <sup>-3</sup>	Piezometer for M194; recovery shows barrier boundary
M296	-	100	11.0	9.0				
M300	-	100	10.0	10.0				
M301	-	100	12.0	8.0				
M302	-	100	11.0	9.0				
M303	-	100	8.0	12.5				
M304	-	120	13.5	9.0				
M305	-	120	12.0	10.0				
M306	-	120	8.0	15.0				
M307	-	120	10.5	10.4				
M308	-	110	11.0	10.0				
M309	-	110	12.5	8.8				

ANNEX 10

DEMOGRAPHIC SURVEY OF REFUGEE CAMPS



### Demographic Survey of the Refugee Camps

According to officially announced data, the refugee camps have a population of 41,000.

It is estimated, as a result of the preliminary survey however, that the refugee camps have approximately 20,000 population.


In this survey the population of the refugee camps as a whole was estimated based on the results of the field survey covering a number of houses and family compositions carried out at refugee camp 1 and the examination of the ledger of distribution cards for food relief of UNHCR.

From the results of the survey of a number of houses, there are 2,040 houses in refugee camp 1 as shown in Fig. A10-1. On the other hand, there are 1,831 cards of refugee camp 1 registered in the relief food distribution card ledger, as shown in Table A10-1. The distribution card is given to each refugee above a certain age, instead of one card per family. Therefore, one family may have various distribution cards. Furthermore, one family may occupy various houses. Under the circumstances, it is presumed that refugee camp 1 has a population of approximately 8,000, because the number of cards is practically the same as the number of houses. Therefore, it is presumed that the 3 camps have approximately 41,000 population.

Table A10-1 Demographic Survey of the Refugee Camps

	Camp 1		Camp 2A		Camp 2B		Camp 3	
	No. of Cards	No. of Refugees	No. of Cards	No. of Refugees	No. of Cards	No. of Refugees		No. of Refugees
1	83	83	262	262	403	403		
2	399	798	500	1,000	716	1,432		
3	231	693	405	1,215	382	1,146		
4	434	1,736	414	1,656	429	1,716		
5	138	690	274	1,370	260	1,300		
6	206	1,236	384	2,304	388	2,328		
7	174	1,218	55	385	52	364		
8	77	616	29	232	21	168		
9	43	387	9	81	2	18		
10	46	460	79	790				
Total	1,831	7,917	2,411	9,295	2,653	8,875		14,913
Refugees per card	4.3		3.86		3.35			

Fig. A10-1 Refugee House Quantity





**ANNEX 11**

**DATA OF PUMPING TEST**



1. Result of stepped pumping test

The test results are shown in the following table.

For a relation of the water level to the time that has passed, refer to Fig. All-1, 2.

Well No.	Test step	Initial level (GL-m)	Moving level (GL-m)	Drawdown (m)	Intaken water quantity (m <sup>3</sup> /hr)	Specific rate of springing (m <sup>3</sup> /hr/m)	Water level recovered?
M41	Step 1	5,520	9,170	3,650	102.86	28.2	When measured 55 min after a draw-down of 4.93m, the unrecovered portion was 46 cm.
	Step 2	5,520	10,020	4,500	144.00	32.0	
	Step 3	5,520	10,450	4,930	180.00	36.5	
M38	Step 1	4,845	9,300	4,455	160.00	35.9	When measured 85 min after a draw-down of 8.295m, the unrecovered portion was 11.5 cm.
	Step 2	4,845	11,300	6,455	180.00	27.9	
	Step 3	4,845	13,140	8,295	240.00	28.9	

2. Result of quantitative pumping test

The test results are shown in the following table.

For a relation of the water level to the time that has passed, refer to Fig. All-3, 4.

Well No.	Initial level (GL-m)	Moving level (GL-m)	Drawdown (m)	Intaken water quantity (m <sup>3</sup> /hr)	Specific rate of springing (m <sup>3</sup> /hr/m)	Water level recovered?
M41	5,550	9,050	3,500	122.76	35.1	When measured 90 min after a drawdown of 3.5m, the unrecovered portion was 15 cm.
M38	4,690	13,135	8,445	237.60	28.1	When measured 120 min after a drawdown of 8.445m, the unrecovered portion was 10 cm.

### 3. Water level recovery

In order to examine how the water level recovers after a certain break in operation, the relation of the unrecovered portion (level difference from the initial one) to the recovery time is made up from the results of the quantitative pumping test and exhibited in Fig. A11-5. As indicated in Fig. A11-3, 4, the two existing wells M41 and M38 differ little from each other, but a recovery time of two hours allows the water surface in both cases to rise to within 10 cm of the initial level. Accordingly it can be judged that the water level is restituted substantially two hours after stopping the pumping operation.

Fig. All-1 Step Pumping Test Curve (M41)




Fig. All-2 Step Pumping Test Curve (M38)




Fig. All-3 Pumping Test Curve (M41)




Fig. All-4 Pumping Test Curve (M38)





Fig. All-5 Relation of Unrecovered Water Level to the Recovery Level







ANNEX 12

TABLE OF COMPARISON BY CLASS OF PIPE



Table A12-1 Comparison by Class of Pipe

(1)

	Ductile Pipe	Steel Pipe	Reinforced Plastic Pipe	Vinyl Chloride Pipe	
Safety	<p>1. Pipe strength</p> <p>Pipe diameter: <math>\phi</math>250, <math>\phi</math>700</p> <p>Tensile strength: 42 or over (kgf/mm)</p> <p>Bending strength: 60 or over (kgf/mm)</p> <p>Elongation : 10 or over (%)</p>	<p>Pipe diameter: <math>\phi</math>200, <math>\phi</math>300</p> <p>Tensile strength: 30 or 30 or over (kgf/mm)</p> <p>Bending strength: 30 or 41 or over (kgf/mm)</p> <p>Elongation : 20 18 (%)</p>	<p>Pipe diameter:</p> <p>Tensile strength: 20 or over (kgf/mm)</p> <p>Bending strength: 20 or over (kgf/mm)</p> <p>Elongation : (%)</p>	<p>Pipe diameter:</p> <p>Tensile strength: (kgf/mm)</p> <p>Bending strength: (kgf/mm)</p> <p>Elongation : (%)</p>	
	<p>2. Impact resisting characteristic</p> <ul style="list-style-type: none"> <li>This pipe is durable against the impact and has a resiliency to absorb the impact.</li> <li>This pipe is covered by a mortar lining at its inner surface and so it is desirable not to apply a high impact force.</li> <li>This pipe has a high safety due to a result of calculation of inner pipe pressure and outside pressure as well as a margin of casting and a surplus distance for corrosion.</li> </ul>	<ul style="list-style-type: none"> <li>Although this pipe has a high flexibility, it has a low environmental deflected collage load, so that it has a low capacity of absorption of impact energy under the same flexing condition.</li> <li>The outer surface of this pipe is apt to have its coating damaged, so a sufficient care should be made for its handling.</li> </ul>	<ul style="list-style-type: none"> <li>Although this pipe has a sufficient toughness and is relatively durable against an impact, it should be avoided to accept large stones dropped from the above or a concentrated backfill of earth from a dump truck from a high position.</li> </ul>	<ul style="list-style-type: none"> <li>This pipe has a sufficient mechanical strength against the inner and outer pressures, bending and shock or the like. This pipe has a sufficient flexibility and is durable against the flexibility as well as a vehicle load or a certain variation in displacement of the ground.</li> <li>It should be avoided to accept the dropping stones or an instantaneous feeding of the back-fill from the high position.</li> </ul>	
	<p>3. Water-sealing characteristic of coupling</p>	<ul style="list-style-type: none"> <li>A superior water-sealing characteristic is kept by a self-sealing mechanism of rubber ring and so no leakage of water occurs until the pipe is broken.</li> </ul>	<ul style="list-style-type: none"> <li>This requires a high skill in welding operation and a better welding condition.</li> </ul>	<ul style="list-style-type: none"> <li>This has a superior accuracy in size of the pipe coupling and also has a superior water pressure resistance.</li> </ul>	<ul style="list-style-type: none"> <li>This has an easy adhesion of the pipe and better connection of rubber rings, and has a high grade of water-proof characteristic.</li> </ul>
	<p>4. Elongation, shrinkage and flexibility</p>	<ul style="list-style-type: none"> <li>This pipe enables a smooth adaptation to the displacement in the ground or variation in temperature without generating any stress in the pipe.</li> </ul>	<ul style="list-style-type: none"> <li>When a variation in temperature or variation in soft ground or the like occurs, an excessive stress is generated in the pipe. In order to eliminate the stress, expensive elongated, retracted and flexible pipes are placed at some places.</li> </ul>	<ul style="list-style-type: none"> <li>A coupling itself has an elongation or retraction characteristic and so the expansion joint is not particularly required.</li> </ul>	<ul style="list-style-type: none"> <li>No expansion joint is required when rubber ring joint is used, because the pipe joint itself has flexibility.</li> </ul>

	Ductile Pipe	Steel Pipe	Reinforced Plastic Pipe	Vinyl Chloride Pipe
1. Service life	<ul style="list-style-type: none"> <li>• 40 years (enforced by the Law of Local Public Enterprise of the Ministry of Home Affairs).</li> <li>• This pipe may be considered as a semi-permanent unit so long as fluid is not acid.</li> <li>• Real use of the rubber ring continues more than 30 years.</li> </ul>	<ul style="list-style-type: none"> <li>• Real result of about 25 years.</li> <li>• There are some claims caused by the process of welding of a coupling at site and coating it, and further a small diameter pipe where a coating of the inner surface of the coupling is difficult shows a substantial care of corrosion.</li> </ul>	<ul style="list-style-type: none"> <li>• Real result of about 15 years.</li> <li>• Since this pipe has a superior corrosion-proof characteristic due to its physical properties, it has a long-years durability.</li> <li>• Service life of the pipe is more than 60 years in reference to the result of test of fatigue performed by the association of FRPM.</li> </ul>	<ul style="list-style-type: none"> <li>• Real result of 20 years.</li> <li>• Due to physical properties of the pipe itself, the pipe has a superior corrosion-proof characteristic, has no secular change and it has a low friction resistance and has scarcely adhered scales.</li> </ul>
Durability	<ul style="list-style-type: none"> <li>• Outer surface Since this pipe has a superior corrosion-proof characteristic in view of its material quality and has a coating of tar epoxy resin on its surface, it has a superior corrosion-proof characteristic. For the ground with a high corrosion, a process of using polyethylene sleeve is applied.</li> <li>• Inner surface A mortar lining is hard and well adhered to the inner surface of the pipe, and it has a coefficient of roughness of 0 and this value will not be changed in the future. The mortar lining has an effect of making a passive state of iron under an alkalization of cement and has the most effective effect for corrosion-proof feature.</li> </ul>	<ul style="list-style-type: none"> <li>• Outer surface This pipe is apt to have a damage during its handling and the coupling is applied to the pipe on site, resulting in that an incomplete assembling of the pipe is made.</li> <li>• Inner surface Tar epoxy resin coating under the standard (JWA K115) has a thickness of 0.3mm and this thickness is not sufficient, but has a corrosion-proof effect as compared with that of the ductile pipe. H<sub>2</sub> gas from the welding beads may apply a bad influence generate a disturbance under a weather condition.</li> </ul>	<ul style="list-style-type: none"> <li>• This plastic pipe has no influence for its anti-corrosion and acid ground which is found in anti-sea water characteristic and which becomes a problem in iron and steel pipe system.</li> </ul>	<ul style="list-style-type: none"> <li>• This pipe has a superior characteristic against anti-acid and anti-alkali and this pipe is not decayed by strong acid such as sulfuric acid and hydrochloric acid and strong alkali such as caustic soda.</li> </ul>

	Ductile Pipe	Steel Pipe	Reinforced Plastic Pipe	Vinyl Chloride Pipe
Execution	1. Workability	<ul style="list-style-type: none"> <li>• Welding on site and coating operations require a high skill and the work by the qualified person is required.</li> <li>• There are many steps such as indexing, temporary fixing, welding, gas removal, inspection and coating or the like and these make a long working period.</li> <li>• Since a low temperature and a moisture may affect bad influence against welding or coating operation, so a complete drying is required.</li> </ul>	<ul style="list-style-type: none"> <li>• Since a weight of the pipe is relatively light, its transportation by a person can be performed and no damage may occur even at a low temperature. However, be sure not to apply any impact to the pipe end where a machining is made.</li> </ul>	<ul style="list-style-type: none"> <li>• A pipe weight is 1/8 of a lead pipe and 1/5 of an iron pipe and is the lightest in all the classes of pipe.</li> <li>• This pipe can be treated with a simple facility and tool.</li> <li>• This pipe can easily be installed in the soft ground.</li> </ul>
	2. Foundation work, back-fill	<ul style="list-style-type: none"> <li>• In general, this pipe does not require any foundation work and a fixing may not be required when the back-fill is to be made.</li> <li>• Since this pipe has a superior strength and ductility, a high safety can be assured under the back-fill operation. Therefore, less restriction is made for the back-fill in the normal ground.</li> </ul>	<ul style="list-style-type: none"> <li>• In order to prevent a flexing of the pipe and damage of a coating of the outer surface of the pipe, both fixing of the bottom of this pipe and the back-fill around the pipe with sand are a condition.</li> <li>• The connected part should be kept large in order to have a working space.</li> </ul>	<ul style="list-style-type: none"> <li>• A sand foundation is an essential foundation in principle.</li> <li>• A ground above the pipe about 20 to 30 cm is back filled with earth of good quality.</li> </ul>

(4)

	Ductile Pipe	Steel Pipe	Reinforced Plastic Pipe	Vinyl Chloride Pipe
Construction Cost	<p>1. Earth work cost</p> <ul style="list-style-type: none"> <li>A special foundation work is not required and a duration of the back-fill is 10 minutes with excavated earth. The cost for working with remained earth and the back-fill is less expensive.</li> </ul>	<ul style="list-style-type: none"> <li>A working step requires a longer period of time, so that a sheathing period also becomes elongated and a cost of the damage becomes high.</li> </ul>	<ul style="list-style-type: none"> <li>Under a normal condition, an angle of supporting the work of sand foundation is sufficient with 120° and the purchased sand is less in volume. This pipe does not require such a coupling graving as found in the other classes of pipes, and a working cost is less expensive.</li> </ul>	<ul style="list-style-type: none"> <li>A surplus excavation at the connected part is not required.</li> <li>An angle of supporting of the work for the sand foundation is sufficiently 120° and a small amount of sand is required.</li> </ul>
Maintenance Control	<p>2. Maintenance control</p> <ul style="list-style-type: none"> <li>Cutting, branching and connecting pipes are easily performed, so that a fast treatment for unexpected troubles can be performed.</li> <li>Since an inner diameter and a coefficient of flow rate are small, a cost of power for the pump during its feeding operation becomes expensive.</li> </ul>	<ul style="list-style-type: none"> <li>Inner surface welding and inner surface coating at the connected parts are nearly impossible.</li> <li>Maintenance cost such as one for preventing electrical corrosion or the like is required.</li> </ul>	<ul style="list-style-type: none"> <li>Cutting of the pipe is easier than that of the ductile pipe.</li> <li>A fast treatment can be attained at a layered part of FRP even for the unexpected trouble.</li> </ul>	<ul style="list-style-type: none"> <li>Even if the pipe is damaged, its repair is easily performed.</li> </ul>

Conclusion: As for costs of material, working and maintenance or the like, the reinforced plastic pipe and the vinyl chloride pipe show the most economical costs. Working characteristic and the maintenance work are facilitated, its strength and anti-corrosion are approximately the same as that of the ductile pipe and the steel pipe, and so the reinforced plastic pipe and the vinyl chloride pipe are used.

## **ANNEX 13**

### **UNIT WATER CONSUMPTION**





### Investigation Data of Unit Water Consumption

Camp 1	10 liter x 2 times/2 person	= 10.0 lcd
	20 liter x (3 - 4) times/5 person	= 14.0
	20 liter x (2 - 4) times/4 person	= 12.5
	10 liter x 4 times/4 person	= 10.0
	20 liter x 3 times/5 person	= 12.0

---

Average	11.7
---------	------

Qoryooley Town	20 liter x 2 times/3 person	= 13.3
Public Water	20 liter x (3 - 4) times/6 person	= 11.7
Filling Station	20 liter x 6 times/5 person	= 24.0
No.4	20 liter x (6 - 8) times/5 person	= 23.3
	10 liter x (6 - 8) times/3 person	= 23.3

---

Average	19.1
---------	------

Qoryooley Town	20 liter x (3 - 4) times/5 person	= 14.0
Public Water	20 liter x (5 - 6) times/6 person	= 18.3
Filling Station	15 liter x (4 - 6) times/4 person	= 18.75
No.2	10 liter x 7 times/10 person	= 7.0
	20 liter x 4 times/10 person	= 8.0

---

Average	13.2
---------	------

Qoryooley Town	18 liter x 9 times/8 person	= 20.25
Public Water	20 liter x 2 times/2 person	= 20.0
Filling Station	15 liter x (4 - 6) times/6 person	= 12.5
No.6		

---

Average	17.6
---------	------

Total Average	15.2 lcd
---------------	----------



**ANNEX 14**

**ANALYSIS OF SCALE OF WATER SUPPLY FACILITIES**



As mentioned in section 4-2-14, there are two alternatives. The system in which water is pumped once to an elevated tank and then distributed by gravity to the ends of the system and the system provided with overhead relay tank. These systems are taken into consideration for examining the optimum scale of the water supply facilities. The parameters of the system, such as pipe diameter of the water supply facilities, pump capacity, peak-cut capacity of the elevated tank, etc., depend on the variation of the hourly water consumption (time coefficient). Results of the relevant survey for time coefficients are shown in Table 4-10 and Figures 4-10 to 4-13 of section 4-2-13.

The water supply proportions, by pattern, in the served area as a whole are pattern (1) 33%, (2) 34.2%, (3) 8.5% and (4) 24.3%, respectively, as mentioned in section 4-2-13. On the other hand, in the served area after Qoryooley Town the said proportions are (1) 45.7%, (2) 28.3%, (3) 20% and (4) 19.0%, respectively. The variation of patterns of hourly water consumption of the said proportions do not necessarily have the same tendency and as a consequence the time coefficient in the served area is levelled off. The time coefficient of the served area as a whole is shown in Table 4-10, and the time coefficient of the served area after Qoryooley Town is shown in Table A12-1. Therefore, the pipe diameter, pump capacity, peak-cut capacity, etc., must be designed based on the said time coefficient. As shown in Table 2-5 in Section 2-3, however, the time coefficient for house connections in small urban areas for which the target value is set at 30% (i.e. the water supply amount for house connections aimed at by the Project accounts for 30% of the water supply amount in Qoryooley Town), has not been investigated yet. Therefore, as for the water supply amount for house connections, the maximum time coefficients, 1.64 and 1.31, of patterns (2) and (3), respectively, were adopted, while for water supply amounts other than for house connections, the time coefficients shown in Tables 4-10 and A12-1 mentioned above, were adopted.

Undermentioned cases examined by using this relation are mainly in connection with economical efficiency.

(1) Cases submitted comparative examination

Broadly speaking, two cases are taken into consideration, case (1) with relay facilities and case (2) without relay facilities.

- Case (1)

Well pump --- Elevated tank --- Pipeline (by gravity flow) ---  
Relay facilities --- Pipeline (by gravity flow).

- Case (2)

Well pump --- Elevated tank --- Pipeline (by gravity flow).

There are three distinct alternatives with different elevated tank heights, Case (2)-1, Case (2)-2 and Case (2)-3 are submitted for comparative examination in connection with Case (2).

- Case (2)-1

The elevated tank height shall be sufficient to secure the head required to convey the water demand amount to the end of the transmission pipeline, when the pipeline diameter is assumed to be the same as that of Case (1), the height shall be approximately 40m.

- Case (2)-2

In this case the elevated tank height is assumed to be 30m, which is presumed to be the construction limit in view of the technical capability of local contractors.

- Case (2)-3

In this case it is assumed that the elevated tank height is determined by the capacity of the well pump which is assumed to be the same as that one used in Case (1). Therefore, this height shall be approximately 23m. In this case the construction is relatively easy.

(2) Method of study

The well pump, relay pump (when the system taken into consideration is provided with relay facilities), elevated tank (capacity and height), pipeline caliber, operation time of well pump and relay pump, etc., are designed for the 4 cases mentioned above. Then, the construction cost, operation and maintenance cost and the annual expenses (summation of the annual reimbursement, based on annual interest rate at 3% and a 20-year reimbursement period, and annual operation & maintenance cost) are submitted to comparative examination.

The maximum time coefficient for peak-cut capacities of 3%, 6% and 9% of each case are shown in Table A14-1.

Table A14-1 Relation between Peak-cut Capacity and Maximum Time Coefficient

Peak-cut Capacity	Case (1)		Case (2)-1	Case (2)-2	Case (2)-3
	Before Relay Point	After Relay Point			
3%	1.23	1.25	1.23	1.23	1.23
6%	1.16	1.17	1.16	1.16	1.16
9%	1.09	1.11	1.09	1.09	1.09

Figures A14-1 to A14-3, Figures A14-4 to A14-5, Figures A14-7 to A14-9 and Figures A14-10 to A14-12 are the design analysis diagrams of the scale of the water supply facilities for Case (1), Case (2)-1, Case (2)-2 and Case (2)-3, respectively.

(3) Results

The construction scope, construction cost, operation & maintenance cost and annual cost of the water supply facilities of each case are shown in Table A14-4 (Case 1), Table A14-5 (Case 2-1), Table A14-6 (Case 2-2) and Table A14-7 (Case 2-3). Comparing the case with

relay facilities (Case 1) and the case without relay facilities (Case 2), it is concluded that the former one is more advantageous from the standpoint of economical efficiency. Of the said cases, the alternative, assuming 6% peak cut capacity, maximum time coefficient 1.16 before relay point and maximum time coefficient 1.17 after relay point, has the optimum scale of facilities.

As for the alternatives of Case (2), which are not provided with relay facilities, the Case (2)-3 is economically disadvantageous because it requires a larger pipeline diameter compared with Case (2)- and Case (2)-2.

In Case (2)-1 the water supply tower height becomes GL+41.5m, and considerable difficulty is expected in connection with the practicality of the construction work. Therefore, it is concluded that Case (2)-2 is the most advantageous one from the standpoints of economical efficiency and workability.



Table A14-2 Relations between Peak-cut Capacity and Time Coefficient

Served Area After Relay Point


	House Connection		Served Area by Public Water Filling Station		Time Coefficient	
	Pattern 2	Pattern 3	0.894			
	0.265 x 0.3	0.088 x 0.3				
			Peak-cut Capacity	Time Coefficient	Peak-cut Capacity	Time Coefficient
7	1.64	1.31	9%	1.059	9%	1.112
8	"	"	6%	1.124	6%	1.170
9	"	"	3%	1.209	3%	1.246
10	"	"	0%	1.346	0%	1.368
11	"	"	0.932		1.156	
12	"	"	0.784		1.053	
13	"	"	0.700		0.994	
14	"	"	0.664		0.969	
15	"	"	0.850		1.099	
16	"	"	0.938		1.161	

Table A14-3 Relations between Peak-cut Capacity and Time Coefficient

Total Served Area

	House Connection		Served Area by Public Water Filling Station		Time Coefficient	
	Pattern 2	Pattern 3	0.923			
	0.192 x 0.3	0.064 x 0.3				
			Peak-cut Capacity	Time Coefficient	Peak-cut Capacity	Time Coefficient
7	1.64	1.31				
8	"	"	12%	0.978	12%	1.023
			9%	1.053	9%	1.092
9	"	"	6%	1.128	6%	1.161
			3%	1.203	3%	1.230
10	"	"	0%	1.394	0%	1.407
11	"	"		0.902		0.952
12	"	"		0.791		0.850
13	"	"		0.722		0.786
14	"	"		0.684		0.751
15	"	"		0.839		0.894
16	"	"		0.759		1.005

Fig. A14-1(1) Case (1) (Peak-Cut Capacity 9%) Sectional Head Loss




\* Hourly Maximum Supply

No.	Area	*
16	Jaslina	27.1
17	Farkaan	256.0
18	Dharganley	5.1
19	Bandar	46.8
20	Hanyofatak	57.7
21	Farkero	3.4
22	Gorqaol	74.5
23	Aranay	23.2
24	Cabdi Calli	100.6

No.	Area	*
9	Bule Sheekh	52.5
10	Haduuman	17.0
11	Gaywartow	205.2
12	Goryoley	631.0
13	Camp 1	157.1
14	Camp 2	357.9
15	Camp 3	288.2

No.	Area	*
1	Belet Amin	6.2
2	Dijena	11.4
3	Medlina	5.2
4	Azienda Cass	4.6
5	Dyugle	2.2
6	Musharai	0.8
7	Bulow Cusbooley	45.7
8	Dhanada	6.2

Fig. A14-1 (2) Case (1) (Peak-Cut Capacity 9%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
16	Jasiina	27.1
17	Farxaan	256.0
18	Dharganley	5.2
19	Bandar	46.8
20	Mannyofarax	57.7
21	Farkeero	1.9
22	Gorgool	24.5
23	Aranay	23.2
24	Cabdi Cali	100.6

Indirect Water Served Area

No.	Area	*
9	Bule Sheekh	52.5
10	Haduuman	69.0
11	Cayvazow	205.8
12	Qoryoley	637.0
13	Camp 1	152.1
14	Camp 2	357.8
15	Camp 3	282.2

Direct Water Served Area

No.	Area	*
1	Belet Amin	6.7
2	Dijena	11.4
3	Medina	5.2
4	Azianda Gaas	1.6
5	Dyugle	2.8
6	Musharai	0.8
7	Bulow Gusbooley	45.7
8	Dhanada	6.2

Direct Water Served Area

Fig. A14-2(1) Case (1) (Peak-Cut Capacity 6%) Sectional Head Loss





Fig. A14-2 Case (1) (Peak-Cut Capacity 6%) Dynamic Water Pressure at Each Point




\* Hourly Maximum Supply

No.	Area	"
16	Jasina	28.5
17	Farxaan	272.5
18	Dharganley	6.2
19	Bandar	48.4
20	Mannyofarax	62.8
21	Farkeero	2.6
22	Corgool	78.5
23	Aranay	29.4
24	Cabdi Cali	106.0

No.	Area	"
9	Bule Sheekh	55.9
10	Haduuman	71.4
11	Gaywarow	21.0
12	Ooryoley	68.7
13	Camp 1	167.7
14	Camp 2	277.2
15	Camp 3	214.4

No.	Area	"
1	Balet Amin	6.7
2	Diijena	62.2
3	Mediina	5.6
4	Azienda Gaas	7.2
5	Uyugle	2.0
6	Musharai	6.8
7	Bulow Cusbooley	48.6
8	Bhanada	6.6

Fig. A14-3(1) Case (1) (Peak-Cut Capacity 3%) Sectional Head Loss



\* Hourly Maximum Supply

No.	Area	*
16	Jasina	30.5
17	Farakan	289.9
18	Dharqanley	1.6
19	Bandar	52.7
20	Haanyofarax	65.0
21	Farkeero	3.9
22	Gorqool	83.9
23	Aranay	26.1
24	Gabdi Call	113.2

Indirect Water Served Area


No.	Area	*
9	Bule Sheekh	51.3
10	Haduuman	72.1
11	Gaywarrow	272.2
12	Goryoley	710.6
13	Camp 1	175.1
14	Camp 2	402.0
15	Camp 3	225.9

Direct Water Served Area

No.	Area	*
1	Belet Amin	7.7
2	Djeha	12.9
3	Medina	5.9
4	Azienda Gaas	9.7
5	Dyugle	2.2
6	Musharal	0.7
7	Bulow Cusbooley	51.5
8	Dhanada	2.0

Direct Water Served Area

Fig. A14-3 (2) Case (1) (Peak-Cut Capacity 3%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
16	Jasina	20.5
17	Farkaan	287.7
18	Dhargenley	4.6
19	Bandar	52.7
20	Mennyofarax	65.0
21	Farkeero	2.7
22	Goryaol	13.7
23	Aranay	26.1
24	Cabdi Cali	112.2

Indirect Water Served Area

No.	Area	*
9	Bule Sheekh	57.7
10	Haduuman	77.7
11	Gaywarow	232.2
12	Goryoley	710.1
13	Camp 1	177.1
14	Camp 2	403.0
15	Camp 3	335.5


Direct Water Served Area

No.	Area	*
1	Belet Amin	7.1
2	Dijena	122.5
3	Medilina	57.7
4	Azienda Gaas	7.7
5	Uyugle	3.2
6	Musharai	0.7
7	Bulow Cusbooley	57.5
8	Dhanada	7.0

Direct Water Served Area



Fig. A14-4(1) Case (2)-1 (Capacity 9%) Sectional Head Loss



\* Hourly Maximum Supply

No.	Area	*
16	Jesilna	26.6
17	Farxaan	256.0
18	Dharganley	5.8
19	Bandar	46.0
20	Maanyofarax	57.7
21	Farkeero	3.4
22	Gorgaol	73.1
23	Aranay	22.8
24	Cabdi Cali	92.7

Indirect Water Served Area


No.	Area	*
9	Bule Sheekh	52.5
10	Naduuman	69.0
11	Gaywarow	205.8
12	Ooryoley	61.7
13	Camp 1	156.2
14	Camp 2	357.6
15	Camp 3	272.9

Direct Water Served Area

No.	Area	*
1	Belet Amin	6.3
2	Dijena	11.4
3	Mediina	5.2
4	Azienda Gaas	2.6
5	Uyugle	2.2
6	Musharai	0.8
7	Bulow Cusbooley	45.7
8	Dhanada	6.2

Direct Water Served Area


Fig. A14-4 (2) Case (2)-1 (Capacity 9%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

NO.	Area	*
1	Belet Amin	4.2
2	Dijena	11.4
3	Medina	5.2
4	Azienda Gaas	0.6
5	Uyugle	2.8
6	Musharai	0.8
7	Bulow Ousbooley	45.7
8	Dhanada	6.2
Direct Water Served Area		
9	Bule Sheekh	52.8
10	Haduuman	19.0
11	Gaywarow	205.5
12	Qoryoley	617.2
13	Camp 1	156.2
14	Camp 2	251.4
15	Camp 3	272.5
Direct Water Served Area		
16	Jablina	26.6
17	Farxaan	256.0
18	Dharqanley	5.8
19	Bandar	46.0
20	Maanyofarak	56.7
21	Farkeero	2.4
22	Corqool	73.1
23	Aranay	22.8
24	Cabdi Cali	58.7
Indirect Water Served Area		

Fig. AL4-5(1) Case (2)-1 (Capacity 6%) Sectional Head Loss



Q	437.7
L	1870
D	200
V	0.39
hf	2.02
	2.130
	250
	0.25
	0.92

Q	1179.1
L	4000
D	300
V	0.46
hf	4.50

Q	202.7
L	2500
D	150
V	0.46
hf	6.24

Q	2488.8
L	3450
D	400
V	0.55
hf	3.80

Q	2547.9
L	800
D	400
V	0.56
hf	0.92

Q	2557.1
L	800
D	400
V	0.57
hf	0.92

Q	1867.5
L1	1520
D1	300
V1	0.73
hf1	4.00
L2	480
D2	250
V2	1.06
hf2	3.07

Q	272.7
L	4000
D	200
V	0.24
hf	2.16

Q	2100.2
L	3000
D	350
V	0.62
hf	4.80

Q	2544.1
L	800
D	400
V	0.56
hf	0.92

Q	2544.9
L	1600
D	400
V	0.56
hf	1.94

Q	2563.8
L	2750
D	400
V	0.57
hf	3.20

No.	Area	*
1	Belet Amin	6.7
2	Dijona	12.2
3	Mediina	5.6
4	Arienda Gaas	9.2
5	Dyugie	3.0
6	Musharal	0.8
7	Bulow Cusbooley	48.6
8	Dhanada	6.6

Direct Water Served Area

No.	Area	*
9	Rule Sheekh	55.5
10	Haduuman	72.4
11	Caywarrow	217.0
12	Qoryoley	159.5
13	Camp 1	166.2
14	Camp 2	324.0
15	Camp 3	311.7


Indirect Water Served Area

No.	Area	*
16	Jasina	26.3
17	Farkaan	272.5
18	Dhargenley	6.2
19	Bandar	48.9
20	Maanyofarax	60.3
21	Farkero	3.6
22	Gorgaal	77.8
23	Arenay	25.2
24	Cabdi Cali	10.5

Indirect Water Served Area

\* Hourly Maximum Supply

Fig. A14-5 (2) Case (2)-1 (Capacity 6%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
1	Belet Amin	6.7
2	Dijena	12.2
3	Medina	5.6
4	Azenda Gaas	9.2
5	Oyugle	3.2
6	Musharai	0.8
7	Bulow Qusbooley	42.6
8	Dhenade	6.6
Direct Water Served Area		
9	Bule Sheekh	55.9
10	Haduunan	22.6
11	Gaywarow	217.0
12	Qoryoley	157.5
13	Camp 1	166.2
14	Camp 2	374.0
15	Camp 3	211.7
Direct Water Served Area		
16	Jasina	22.3
17	Farsoen	272.5
18	Dhaxtanley	6.2
19	Bandar	48.9
20	Maanyofarax	60.2
21	Farkeero	3.6
22	Gorgaal	27.2
23	Aranay	24.2
24	Cabdi Cali	105.1
Indirect Water Served Area		

Fig. A14-6(1) Case (2)-1 (Capacity 3%) Sectional Head Loss






Fig. A14-6 (2) Case (2)-1 (Capacity 3%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
1	Belet Amin	7.7
2	Dijena	12.2
3	Medina	5.8
4	Azienda Caas	8.7
5	Dyugle	2.2
6	Musharal	8.8
7	Bulow Qasbooley	51.5
8	Dhameda	7.0
<b>Direct Water Served Area</b>		
9	Bule Sheekh	59.3
10	Haduuman	72.9
11	Gaywarrow	232.2
12	Qooyoley	188.2
13	Camp 1	176.2
14	Camp 2	376.6
15	Camp 3	130.5
<b>Direct Water Served Area</b>		
16	Jasina	30.0
17	Farkaan	288.8
18	Dharganley	6.5
19	Bandar	51.9
20	Maanyofarax	144.0
21	Farkeero	2.8
22	Corgaal	82.5
23	Aranay	25.7
24	Cabdi Cali	114.6
<b>Indirect Water Served Area</b>		

Fig. A14-7(1) Case (2)-2 (Capacity 9%) Sectional Head Loss



\* Hourly Maximum Supply

No.	Area	*
16	Jasina	36.6
17	Farkaan	256.2
18	Dharganley	r.f.
19	Bandar	46.0
20	Maanyofarax	56.7
21	Farkero	2.4
22	Gorgaal	73.7
23	Araney	22.8
24	Gabdi Cali	98.7

Indirect Water Served Area


No.	Area	*
9	Bule Sheekh	52.5
10	Maduuman	17.0
11	Caywarow	205.8
12	Doryolny	62.7
13	Camp 1	256.2
14	Camp 2	251.0
15	Camp 3	272.9

Direct Water Served Area

No.	Area	*
1	Belet Amin	6.3
2	Dijena	11.6
3	Medina	5.2
4	Azienda Gaas	8.6
5	Dyugle	2.8
6	Musharai	0.8
7	Bulow Cusbooley	45.7
8	Dhanada	6.2

Direct Water Served Area

Fig. A14-7 (2) Case (2)-2 (Capacity 9%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
16	Jasina	26.6
17	Farkaan	256.0
18	Dharganley	5.8
19	Bandar	98.0
20	Maanyofarax	56.7
21	Parkero	3.0
22	Gorgool	23.1
23	Aranay	22.8
24	Cabdi Cali	99.7

Indirect Water Served Area

No.	Area	*
9	Bule Sheekh	6.1
10	Haduuman	88.0
11	Gaywarow	205.8
12	Qoryoley	81.7
13	Camp 1	156.2
14	Camp 2	257.4
15	Camp 3	299.8


Direct Water Served Area

No.	Area	*
1	Belet Amin	6.3
2	Dijena	11.4
3	Medina	5.2
4	Azienda Gaas	8.6
5	Uyogle	2.8
6	Musharai	2.8
7	Sulloow Cusbooley	95.7
8	Dhanada	6.2

Direct Water Served Area




Fig. A14-8(1) Case (2)-2 (Capacity 6%) Sectional Head Loss



\* Hourly Maximum Supply

No.	Area	*
1	Belet Amin	6.7
2	Dijena	1.2
3	Medina	5.6
4	Azienda Gaas	2.2
5	Dyugle	3.0
6	Mushatal	0.8
7	Bulow Cusbooley	48.6
8	Dhanaga	6.6
Direct Water Served Area		
No.	Area	*
9	Bule Sheekh	55.7
10	Haduuman	73.4
11	Gaywarow	215.0
12	Qoryoley	659.5
13	Camp 1	166.2
14	Camp 2	374.0
15	Camp 3	311.7
Direct Water Served Area		
No.	Area	*
16	Jasina	38.3
17	Farxan	272.5
18	Dharqanley	6.2
19	Bander	48.9
20	Maanyofarax	60.3
21	Farkeero	3.6
22	Gorgaal	77.8
23	Aranay	24.2
24	Cabdi Cali	105.1
Indirect Water Served Area		

Fig. A14-8 (2) Case (2)-2 (Capacity 6%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
1	Belet Amin	6.7
2	Dijena	13.2
3	Medina	5.6
4	Azienda Gaa	9.2
5	Yugle	3.0
6	Musharai	0.8
7	Bulow Cusbooley	48.6
8	Dhanada	6.6


  

Direct Water Served Area		
No.	Area	*
9	Bule Sheekh	55.7
10	Haduuman	22.0
11	Caywarow	27.0
12	Qoryoley	65.5
13	Camp 1	16.2
14	Camp 2	27.0
15	Camp 3	31.7

Indirect Water Served Area		
No.	Area	*
16	Jasina	28.3
17	Farxan	22.5
18	Dharqanley	6.2
19	Bandar	48.8
20	Maanyofarax	60.2
21	Farkeero	3.6
22	GORGOL	22.8
23	Aramay	25.2
24	Cabdi Cali	10.5

Fig. A14-9(1) Case (2)-2 (Capacity 38) Sectional Head Loss



\* Hourly Maximum Supply

No.	Area	*
16	Jasina	22.2
17	Faxsan	288.2
18	Dharganley	6.5
19	Bandar	51.2
20	Maanyofarax	64.0
21	Farkeero	2.8
22	Gorgaal	2.5
23	Araney	25.7
24	Cabdi Cali	111.4


No.	Area	*
9	Bule Sheekh	57.2
10	Haduuman	77.2
11	Gaywarrow	232.2
12	Goryoley	171.2
13	Camp 1	176.2
14	Camp 2	226.6
15	Camp 3	230.5

No.	Area	*
1	Belet Amin	7.1
2	Dijena	124.2
3	Mediina	5.1
4	Asianda Gaas	2.7
5	Ouygile	3.2
6	Musharai	0.2
7	Bulow Cusbooley	56.5
8	Dhanada	7.0

Water Served Area

Elevated Tank

Fig. A14-9 (2) Case (2)-2 (Capacity 3%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
1	Belet Amin	7.7
2	Dijene	12.7
3	Medilina	5.9
4	Asianda Caas	3.7
5	Uyugle	3.2
6	Musharai	0.9
7	Bulow Cusbooley	5.5
8	Dhanada	7.0


  

No.	Area	*
9	Bule Sheekh	23.3
10	Maduuman	72.1
11	Geywarow	232.2
12	Goryoley	699.2
13	Camp 1	176.2
14	Camp 2	226.6
15	Camp 3	370.5

No.	Area	*
16	Jasina	20.0
17	Parkaan	288.9
18	Dharganley	1.5
19	Bandar	51.9
20	Maanyofarax	144.2
21	Farkeero	3.8
22	Gorgool	61.5
23	Aranay	25.7
24	Cabdi Cali	111.4

Fig. A14-10(1) Case (2)-3 (Capacity 9%) Sectional Head Loss




\* Nourly Maximum Supply

No.	Area	*
16	Jaslina	26.6
17	Parxan	25.0
18	Dharganley	5.9
19	Bandar	46.0
20	Mannyofarax	56.7
21	Parkeero	3.4
22	Gorgaal	73.1
23	Aranav	22.8
24	Cabdi Cali	77.7

No.	Area	*
9	Bula Sheekh	52.5
10	Haduuman	17.0
11	Gaywartow	29.5.2
12	Qooyoley	61.7
13	Camp 1	156.2
14	Camp 2	35.14
15	Camp 3	29.2

No.	Area	*
1	Belet Amin	6.2
2	Dajena	14.4
3	Medina	5.2
4	Azienda Gaas	1.6
5	Gyugle	2.8
6	Musharai	0.8
7	Bulow Cusbooley	45.7
8	Dhanada	1.2

Fig. A14-10 (2) Case (2)-3 (Capacity 9%) Dynamic Water Pressure at Each Point




\* Hourly Maximum Supply

No.	Area	*
16	Jasina	26.1
17	Ferxaan	256.2
18	Dharganley	5.8
19	Bandar	46.2
20	Maanyofarak	56.7
21	Farkero	3.4
22	Gergool	21.1
23	Araasy	22.8
24	Cabdi Cali	98.7

No.	Area	*
9	Bule Sheekh	52.5
10	Haduuman	19.2
11	Gaywarow	205.8
12	Qoryoley	41.7
13	Camp 1	136.2
14	Camp 2	351.6
15	Camp 3	292.9

No.	Area	*
1	Belet Amin	6.2
2	Dijena	11.4
3	Medina	5.2
4	Azienda Gaas	1.6
5	Dyugle	2.8
6	Musharai	0.8
7	Bulow Cusbooley	45.7
8	Dhanada	6.2

Fig. A14-11(1) Case (2)-3 (Capacity 6%) Sectional Head Loss



\* Hourly Maximum Supply

No.	Area	*
16	Jasina	21.2
17	Farkhan	272.5
18	Dharganley	6.2
19	Bandar	98.7
20	Maanyofarak	60.2
21	Farkhero	2.6
22	Gorgaol	72.8
23	Aranav	54.2
24	Cabdi Cali	105.1

Indirect Water Served Area


No.	Area	*
9	Bule Sheekh	55.1
10	Raduuman	72.4
11	Gaywarrow	217.0
12	Qoryoley	152.2
13	Camp 1	166.2
14	Camp 2	274.0
15	Camp 3	211.2

Direct Water Served Area

No.	Area	*
1	Belet Amin	6.7
2	DLjerna	12.2
3	Mediina	5.6
4	Azienda Gaas	2.2
5	Dyugle	2.0
6	Musharal	0.8
7	Bulow Cusbooley	48.6
8	Dhanada	6.1

Direct Water Served Area

Fig. A14-11 (2) Case (2)-3 (Capacity 6%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
16	Jasline	28.2
17	Faraan	272.5
18	Dharqanley	6.2
19	Bandar	48.9
20	Maanyofarek	10.2
21	Farkero	2.6
22	Cosgaol	72.8
23	Aranay	24.2
24	Cabdi Cali	105.1

Indirect Water Served Area

No.	Area	*
9	Bule Sheekh	55.9
10	Haduuman	72.4
11	Gaywarro	219.0
12	Qoxyoley	659.5
13	Camp 1	116.2
14	Camp 2	274.0
15	Camp 3	211.7


Direct Water Served Area

No.	Area	*
1	Belet Amin	6.7
2	Dijena	22.2
3	Mediina	5.6
4	Azienda Gaas	7.2
5	Dyugle	21.0
6	Musharai	20.8
7	Balwo Cusbooley	68.6
8	Dhanada	6.6

Direct Water Served Area



Fig. A14-12(1) Case (2)-3 (Capacity 3%) Sectional Head Loss




\* Hourly Maximum Supply

No.	Area	*
16	Jasina	22.0
17	Farxaan	28.9
18	Dharganley	4.5
19	Bandar	51.9
20	Maanyofarak	64.0
21	Farkeero	1.8
22	Gorgaol	21.5
23	Aranav	25.7
24	Cabdi Cali	111.4

No.	Area	*
9	Bule Sheekh	57.7
10	Haduuman	77.7
11	Gaywarow	22.2
12	Qoryoley	177.3
13	Camp 1	172.2
14	Camp 2	176.6
15	Camp 3	170.5

No.	Area	*
1	Belet Amin	7.1
2	Dijena	12.2
3	Medina	5.9
4	Azienda Gaas	9.7
5	Uyugle	3.2
6	Musharal	8.9
7	Bulow Cusbooley	51.5
8	Dhanada	7.0

Fig. A14-12 (2) Case (2)-3 (Capacity 3%) Dynamic Water Pressure at Each Point



\* Hourly Maximum Supply

No.	Area	*
16	Jasina	20.0
17	Farkaan	22.2
18	Dharganley	6.6
19	Bandar	51.8
20	Maanyofarax	54.0
21	Parkero	3.8
22	Gorgaal	24.5
23	Aranay	25.7
24	Cabdi Cali	111.4

No.	Area	*
9	Bule Sheekh	51.3
10	Raduuman	22.3
11	Goyarrow	22.2
12	Goryoley	177.2
13	Camp 1	174.2
14	Camp 2	226.6
15	Camp 3	339.5

No.	Area	*
1	Belet Amin	7.7
2	Dijena	12.7
3	Medina	5.5
4	Azenda Gaas	9.7
5	Dyugle	2.2
6	Musharaf	0.9
7	Bulow/Cusbooley	51.5
8	Dhanada	7.8

Table A14-4 Comparison by Annual Cost (Case 1)

Case	Construction Cost (¥1000)										Annual Cost (¥1000/year)			
	Pipeline			Overhead Tank			Pump Facilities			Grand Total				
	Pipe Diameter	Length (m)	Cost	Scale	Cost	Scale	Cost	Scale	Cost					
5%	ø400 (Paved)	4,000	170,560											
	ø400 (Unpaved)	2,750	98,686.5	H <sub>1</sub> =25.0m V <sub>1</sub> =240m <sup>3</sup>		183,000	2.03m <sup>3</sup> /min x55m x3Units (ø200)	27,000						
	ø350 (Paved)	6,450	233,677.05											
	ø300 ( " )	1,250	31,418.75											
	ø300 (Unpaved)	4,000	77,116	H <sub>2</sub> =18.5 V <sub>2</sub> =160m <sup>3</sup>										
	ø250 (Paved)	750	14,850			82,000	1.49m <sup>3</sup> /min x39m x3Units (ø150 x ø100)	12,600						
	ø200 ( " )	600	8,241.6											
ø150 ( " )	7,400	68,908.8												
	Total	2,500	15,480			265,000	Total	39,600						
			718,938.7									1,003,538.7		
												Grand Total + 15,337 = 65,432.5	23,439.8	
													88,872.3	
6%	ø400 (Paved)	7,450	317,668											
	ø400 (Unpaved)	2,750	98,686.5	H <sub>1</sub> =23.5m V <sub>1</sub> =160m <sup>3</sup>		86,000	2.15m <sup>3</sup> /min x53.5m x3Units (ø200)	27,000						
	ø350 (Paved)	3,000	108,687											
	ø300 ( " )	1,520	38,205.2											
	ø300 (Unpaved)	4,000	77,116	H <sub>2</sub> =18.0m V <sub>2</sub> =120m <sup>3</sup>										
	ø250 (Paved)	480	9,504			70,000	1.57m <sup>3</sup> /min x38.5m x3Units (ø150 x ø100)							
	ø200 ( " )	2,130	29,257.68											
ø150 ( " )	5,870	54,661.44												
	Total	2,500	15,480			156,000	Total	39,600						
			749,265.82											
													944,865.8	
													Grand Total + 15,337 = 61,607.0	23,639.8
													85,246.8	
3%	ø450 (Paved)	1,600	79,952											
	ø450 (Unpaved)	2,750	118,087.75	H <sub>1</sub> =21.0m V <sub>1</sub> =80m <sup>3</sup>		67,000	2.61m <sup>3</sup> /min x51m x3Units (ø200)	27,000						
	ø400 (Paved)	8,850	337,364											
	ø300 ( " )	1,550	38,959.25	H <sub>2</sub> =20.5m V <sub>2</sub> =17.0m										
	ø300 (Unpaved)	4,550	87,719.45											
	ø250 (Paved)	450	8,910			60,000	1.67m <sup>3</sup> /min x38m x3Units (ø150 x ø100)	12,600						
	ø250 (Unpaved)	3,450	47,389.2											
ø200 ( " )	6,500	60,528												
	Total		818,909.65			127,000	Total	39,600						
													983,509.7	
													Grand Total + 15,337 = 64,126.6	23,839.8
													87,966.4	

Table A14-5 Comparison by Annual Cost (Case 2-1)

Case	Construction Cost (\$1000)										Annual Cost (\$1000/year)
	Pipeline			Overhead Tank		Pump Facilities		Grand Total	Cost for Maintenance and Management (\$1000/year)		
	Pipe Diameter	Length (m)	Cost	Scale	Cost	Scale	Cost				
9%	ø400 (Paved)	4,000	170,560	H <sub>1</sub> =41.5m V <sub>1</sub> =240m <sup>3</sup>	300,000	2.03m <sup>3</sup> /min x70m x3Units	34,800	1,053,778	21,721.7	90,427.4	
	ø400 (Unpaved)	2,750	98,686.5								
	ø350 (Paved)	6,450	233,677.05								
	ø300 ( " )	1,250	31,418.75								
	ø300 (Unpaved)	4,000	77,116								
	ø250 (Paved)	750	14,850								
	ø250 (Unpaved)	600	8,241.6								
	ø200 ( " )	7,400	68,908.8								
	ø150 ( " )	2,500	15,480								
Total		718,938.7									
6%	ø400 (Paved)	7,450	317,668	H <sub>1</sub> =40.0m V <sub>1</sub> =160m <sup>3</sup>	196,000	2.15m <sup>3</sup> /min x68.5m x3Units	34,800	980,061.8	21,921.7	85,823.8	
	ø400 (Unpaved)	2,750	98,686.5								
	ø350 (Paved)	3,000	108,687								
	ø300 ( " )	1,520	38,205.2								
	ø300 (Unpaved)	4,000	77,116								
	ø250 (Paved)	480	9,504								
	ø250 (Unpaved)	2,130	29,257.68								
	ø200 ( " )	5,870	54,661.44								
	ø150 ( " )	2,500	15,480								
Total		749,265.82									
3%	ø450 (Paved)	1,600	79,952	H <sub>1</sub> =39.0m V <sub>1</sub> =80m <sup>3</sup>	156,000	2.61m <sup>3</sup> /min x67.5m x3Units	34,800	1,009,709.7	22,121.7	87,956.6	
	ø450 (Unpaved)	2,750	118,087.75								
	ø400 (Paved)	8,850	377,364								
	ø300 (Paved)	1,550	38,959.25								
	ø300 (Unpaved)	4,550	87,719.45								
	ø250 (Paved)	450	8,910								
	ø250 (Unpaved)	3,450	47,389.2								
	ø200 ( " )	6,500	60,528								
	Total		818,909.65								

Table A14-6 Comparison by Annual Cost (Case 2-2)

Case	Construction Cost (\$1000)										Annual Cost (\$1000/Year)
	Pipeline			Overhead Tank		Pump Facilities		Grand Total	Cost for Maintenance and Management (\$1000/Year)		
	Pipe Diameter	Length (m)	Cost	Scale	Cost	Scale	Cost				
9%	ø400 (Unpaved)	2,750	98,686.5	H=30.0m	199,000	2.03m <sup>3</sup> /min x60m x30units (ø200)	34,800	1,031,065.6	21,070	88,297.3	
	ø400 (Paved)	10,450	445,588	V=240m <sup>3</sup>							
	ø350 ( " )	2,000	72,458								
	ø350 (Unpaved)	780	23,262.72								
	ø300 ( " )	3,220	62,078.38								
	ø250 ( " )	4,000	54,944								
ø150 ( " )	6,500	40,248									
	Total		797,265.6								
6%	ø400 (Unpaved)	2,750	98,686.5	H=30.0m	118,000	2.15m <sup>3</sup> /min x60m x30units (ø200)	34,800	983,977.6	21,270	85,427.1	
	ø400 (Paved)	12,450	530,868	V=160m <sup>3</sup>							
	ø350 (Unpaved)	2,780	82,910.72								
	ø300 ( " )	1,220	23,520.38								
	ø250 ( " )	4,000	54,944								
	ø150 ( " )	6,500	40,248								
	Total		831,177.6								
3%	ø450 (Unpaved)	2,750	118,087.75	H=30.0m	99,000	2.61m <sup>3</sup> /min x60m x30units	34,800	997,243.75	21,470	86,492.1	
	ø400 (Paved)	12,450	530,868	V=80m <sup>3</sup>							
	ø350 (Unpaved)	4,000	119,296								
	ø250 ( " )	4,000	54,944								
	ø150 ( " )	6,500	40,248								
		Total		863,443.75							

Table A14-7 Comparison by Annual Cost (Case 2-3)

Case	Construction Cost (¥1000)										Annual Cost (¥1000/year)
	Pipeline			Overhead Tank		Pump Facilities		Grand Total	Cost for Maintenance and Management (¥1000/year)		
	Pipe Diameter	Length (m)	Cost	Scale	Cost	Scale	Cost				
2%	ø450 (Paved)	3,200	159,904	H=25.0m V=240m³	177,000	2.03m³/min x 55m x 30units (ø200)	27,000	1,088,466.6	20,480.2	91,450.2	
	ø450 (Unpaved)	2,750	118,087.75								
	ø400 (Paved)	9,250	394,420								
	ø350 (Unpaved)	4,000	119,296								
	ø250 ( " )	3,450	47,389.2								
	ø200 ( " )	550	5,121.6								
	ø150 ( " )	6,500	40,248								
Total		884,446.55									
6%	ø450 (Paved)	10,450	522,186.5	H=23.5m V=160m³	86,000	2.15m³/min x 53.5m x 30units (ø200)	27,000	1,051,272.7	20,680.2	89,942.3	
	ø450 (Unpaved)	2,750	118,087								
	ø400 (Paved)	2,000	85,280								
	ø350 (Unpaved)	4,000	119,296								
	ø250 ( " )	3,600	49,449.6								
	ø200 ( " )	400	3,724.8								
	ø150 ( " )	6,500	40,248								
Total		1,027,204.00									
3%	ø500 (Unpaved)	2,750	133,075.25	H=21.0m V=80m³	67,000	2.5m³/min x 46m x 20units (ø200)	27,000	768,021.1	20,880.2	99,984.7	
	ø450 (Paved)	12,450	622,126.5								
	ø400 (Unpaved)	4,000	143,554								
	ø300 ( " )	3,750	72,296.25								
	ø250 ( " )	250	3,434								
	ø200 ( " )	4,000	37,248								
	ø150 ( " )	2,500	15,480								
Total		1,027,204.00									

**ANNEX 15**

**CALCULATION OF N-VALUE**





- o Relation between unconfined compression strength  $q_u$  and N-value

$$q_u = \frac{N}{8} \quad (1)$$

where:  $q_u$  : Kg/cm<sup>2</sup>

- o Relation between  $q_c$  and  $q_u$  (Soil exploration method)

$$q_c = 5 \cdot q_u = 10 \cdot c \quad (2)$$

(cohesion)

where:  $c$  : Kg/cm<sup>2</sup>

- o Relation between  $q_c$  and N-value ( from expressions (1) and (2) )

$$q_c = 5 \cdot \frac{N}{8} \quad (3)$$

$$\therefore N = \frac{8q_c}{5} = 1.6q_c \quad (4)$$

Estimation of the N-value for design.

Test results indicate that  $q_c = 15$  at the water supply tower construction site. Therefore, the N-value is:

$$N = 1.6 \times 15 = 24.0$$

The N-value adopted for the sake of design is 75% of the value estimated from the measurement results.

$$N\text{-value for design} = 24 \times 0.75 = 18.0$$



**ANNEX 16**

**CALCULATION FOR FOUNDATION AND STRUCTURE OF  
ELEVATED TOWER**



## 1. Calculation for Foundation of Elevated Tower

### (1) Selection of the foundation work method

The direct foundation, pile foundation, caisson foundation, soil improvement works, are the possible alternatives of foundation work method. From the standpoint of the scale of the structure and result of soil investigation data, the direct foundation or the pile foundation seems appropriate for this project in view of the workability, economical efficiency and state of things at the construction site. There are three alternatives for the pile foundation, factory pre-fabricated concrete pile, steel pipe pile and cast-in-place concrete pile. Factory pre-fabricated concrete pile and steel pipe pile are not appropriate from the standpoint of construction cost because the former one is not manufactured in Somalia and the later one consists of imports. Foundation consisting of cast-in-place concrete foundation can be constructed by using machinery for well drilling, and is more economical compared with importing pile-driving machine for steel pipe pile and factory pre-fabricated concrete pile.

In view of the aforesaid considerations the cast-in-place concrete foundation shall be adopted in the Project.

### (2) Estimation of the bearing capacity and the allowable stress of the cast-in-place concrete pile

The design N-value taken into consideration in ANNEX 14 is 18, and the permissible bearing capacity is  $q_a = 15.0 \text{ t/m}^2$ .

Assuming a pile length of  $L = 8,000$ , the permissible bearing capacity of the cast-in-place concrete pile in the form of friction pile will assume  $8.8T/\text{pile}$  (long term = short term).

### (3) Foundation of the elevated tank

- 1) No boring test was carried out at the foundation ground, but results of tests carried out with cone penetrometer at 5 m depth from the existing ground level indicate that the permissible bearing capacity is relatively high,  $q_a = 15.0 \text{ t/m}^2$ , and therefore it is decided to adopt the direct foundation.

2) Stability of the Elevated Tank

In general the stability is examined in terms of wind load and earthquake load, but in this case the earthquake load is not taken into consideration because there are no earthquakes in Somalia, and the stability is examined only in terms of wind load. The maximum wind speed recorded in the Lower Shabelle district is 3.5 m/sec, and the wind load is relatively small. The stability was examined by taking into consideration thrice that value, 10.5 m/sec., for the sake of safety. The number of piles, the maximum load, etc., of the elevated tank calculated on the said premises are summarized in the following table.

Permissible Bearing Capacity 11.25 T/m<sup>2</sup>

	Effective volume 160 m <sup>3</sup> (Nominal volume 200 m <sup>3</sup> )
Dead weight (t)	2,327.3 t
Water weight (t)	200
Vertical load (t)	2,527.3
Wind load (horizontal load, t)	2.3
Number of piles (units)	16
Overturning moment (t.m)	50.5
Resisting moment (t.m)	218.4
Safety factor	4.3
Pile reaction (Maximum 1 pile , t/pile)	16.8 (short term)
Contact pressure (full, t/m <sup>2</sup> )	13.6
Contact pressure (empty, t/m <sup>2</sup> )	12.5

In view of the aforesaid considerations, it is concluded that a foundation consisting of 16 piles sized  $\phi 400$  mm and L = 8,000 length will be sufficient to support the elevated tank.

## 2. Calculation for Structure of Elevated Tower

### (1) Outline of the construction

- a) Use: Elevated Tank (capacity 200 tons)
- b) Maximum height: GL + 34.5 m
- c) Water tank unit: Diameter D = 10 m, Height H = 4.5 m
- d) Supporting unit: Diameter D = 4.0 m (provided with rib)
- e) Main structure: Reinforced concrete structure
- f) Construction system: Independent shaft construction
- g) Foundation system: Independent foundation + cast-in-place concrete piles

### (2) Design policy

#### a) Water tank unit

The design of the water tank unit will be examined by taking into consideration the bending of the water tank bottom slab and the like due to the water pressure, in conformity with the Shell Theory.


#### b) Tower unit

In principle, the tower body design will be examined in terms of an independent shaft with 4.0 m diameter and wall thickness  $t$  of the order of 30 mm to 40 mm, and the 4 ribs will be examined in terms of their reinforcement effect to cope with twists, vibrations, etc.

#### c) Foundation

The foundation will be designed by assuming that the vertical loads will be supported by the bearing capacity of the ground, because the extent of subsurface exploration reaches only GL-5.0 m, the construction in question is a typical tower-type structure, and furthermore it has a huge weight mounting to 2,000 tons or more. On the other hand, in connection with such horizontal loads as wind and the like, it is assumed that cast-in-place concrete piles will be used to cope with the said external disturbances.

(3) Outline of the construction





(4) Loads and external forces

a) Fixed load	Total
i) Roof	
- Finishing 25	845 → 850 kg/m <sup>2</sup>
- Concrete slab (t = 300) 720	
- Waterproofing 100	
ii) Water tank floor	
- Water proofing 100	1,300 kg/m <sup>2</sup>
- Concrete slab (t = 500) 1,200	
iii) Tower body intermediate floor	
- Concrete slab (t = 300) 720	820 kg/m <sup>2</sup>
- Applied load 100	
iv) External shaft wall	
- t = 300 720	840 kg/m <sup>2</sup>
- Finishing 50 120	
- t = 400 960	1,080 kg/m <sup>2</sup>
- Finishing 50 120	

b) Water pressure  $W_w = 200$  ton

Water tank surface area  $S_T = 56.5$  m<sup>2</sup>

$$\text{Pressure at the deepest part } W_p = \frac{W_w}{S_T} = \frac{200}{56.5} = 3.55 \text{ t/m}^2$$

c) Wind load

The velocity pressure  $q$  is calculated by taking into consideration the wind speed data at the project site ( $V_{\max} = 3.5$  m/s) and a safety factor of 3 times, which results into  $V_{\text{design}} = 3 \times 3.5$  m/s = 10.5 m/s.

$$q = \frac{1}{2} \cdot \rho \cdot v^2 \quad (\rho: \text{air density} = 0.125)$$

$$= \frac{1}{2} \times 0.125 \times 10.5^2 = 6.9 \text{ kg/m}^2 \quad \rightarrow 7.0 \text{ kg/m}^2$$

The wind load  $P_w$  is calculated with the following formula.

$$P_w = q \cdot C \cdot G_f \cdot A$$

where:

- q: Wind speed pressure ( $\text{kg}/\text{m}^2$ )
- C: Wind force coefficient
- $G_f$ : Gustonde influence coefficient (2.2)
- A: Apparent aprea ( $\text{m}^2$ )

$$P_w = 7.0 \times 1.2 \times 2.2 \times A = 18.5A \text{ (kg)}$$

(5) Permissible stress intensity of the used materials

a) Concrete

- 4-week compressive strength  $F_{28} \geq 210 \text{ kg}/\text{cm}^2$
- Long-term permissible compressvie stress intensity  
 $Lfc = 70 \text{ kg}/\text{cm}^2$
- Short-term permissible compressive stress intensity  
 $Sfc = 140 \text{ kg}/\text{cm}^2$
- Long-term permissible shearing stress intensity  
 $Lfs = 7.0 \text{ kg}/\text{cm}^2$
- Short-term permissible shearing stress intensity  
 $Sfs = 10.5 \text{ kg}/\text{cm}^2$
- Long-term permissible adhesion stress intensity
  - Uppermost node  $Lfa = 14.0 \text{ kg}/\text{cm}^2$
  - Other reinforcement  $Lfa = 21.0 \text{ kg}/\text{cm}^2$
- Short-term permissible adhesion stress intensity
  - Uppermost node  $Sfa = 21.0 \text{ kg}/\text{cm}^2$
  - Other reinforcement  $Sfa = 30.5 \text{ kg}/\text{cm}^2$

b) Reinforcement: Material (SD 30)

- Long-term permissible tensile stress intensity  
 $Lft = 2,000 \text{ kg}/\text{cm}^2$
- Short-term permissible tensile stress intensity  
 $Sft = 3,000 \text{ kg}/\text{cm}^2$
- Long-term permissible shearing stress intensity  
 $Lfs = 2,000 \text{ kg}/\text{cm}^2$
- Short-term permissible shearing stress intensity  
 $Sfs = 3,000 \text{ kg}/\text{cm}^2$

c) Permissible bearing capacity:

$$\begin{aligned}
 \text{N-value } 18 \quad D_f &= 3.5 \text{ m} \quad \gamma = 1.7 \\
 q_a &= \frac{1}{3} (\alpha C N_c + \beta \gamma_1 B N_r + \gamma_2 D_f \cdot N_q) \text{ (t/m}^2\text{)} \\
 &= \frac{1}{3} (1.3 \times 11.2 \times 5.3 + 0.3 \times 1.7 \times 0 + 1.7 \times 3.5 \times 3.0) \\
 &= \frac{1}{3} (77.1 + 17.85) = 31.6 \text{ t/m}^2
 \end{aligned}$$

Therefore long-term permissible bearing capacity is  $15.0 \text{ t/m}^2$ .

d) Calculation of the bearing power of the cast-in-place concrete pile

Diameter of pile:  $400 \phi$  ( $W = 0.2^2 \times \pi \times 24 \times 8.0 = 25 \text{ t}$ )

Bearing power of ground: Sandy clay of N-value 18

$$\begin{aligned}
 \text{Bearing capacity of pile: } R_a &= \frac{1}{3} \times 15 \times N \times A_p - W \\
 &= \frac{1}{3} \times 15 \times 18 \times 0.126 - 25 \text{ t} \\
 &= 11.3 - 25 = 8.8 \text{ t/1 pile}
 \end{aligned}$$

(6) Calculation of the vertical stress

a) Calculation of the tower weight

i)  $Z_4$  to  $Z_3$

Roof:	$0.85 \times 5.12 \times \pi$	= 69.5
Water tank floor:	$1.3 \times 5.12 \times \pi$	= 106.2
Wall:	$0.94 \times 9.9 \times \pi \times 3.5$	= 102.3
	$0.92 \times 3.7 \times \pi \times 3.93$	= 42.0
	$0.92 \times (2.8 \times 3.7 \times 4 + 3.7 \times 4.08 \times 2)$	= 66.0
Water:		= 200.0
		<u>586.0</u>
		( $EN_3 = 586.0 \text{ t}$ )

ii)  $Z_3$  to  $Z_2$

Floor:	$0.82 \times 1.72 \times \pi \times 3$	= 22.4
Wall:	$0.84 \times 3.7 \times \pi \times 19.5$	= 190.4
	$1.08 \times (1.0 \times 19.5 \times 4 + 2.12 \times 4/2)$	= 93.8
		<u>306.6</u>
		( $EN_2 = 892.6 \text{ t}$ )

iii)  $Z_2$  to  $Z_1$


Floor:  $0.82 \times 1.6^2 \times \pi \times 2 = 13.2$   
 Wall:  $1.08 \times (3.6 \times \pi \times 10 + 1.0 \times 10 \times 4) = 165.4$   
 178.6  
 ( $EN_1 = 1,071.2 \text{ t}$ )

iv)  $Z_1$  to  $Z_0$

Foundation:  $2.4 \times 3.5 \times 0.828 \times 6.0^2 = 250.5$   
 $2.2 \times 3.5 \times 0.828 \times (15.0^2 - 6.20) = 1,205.6$   
 1,456.1  
 ( $EN_0 = 2,527.3 \text{ t}$ )

b) Stress in the water tank due to water pressure

i) Membrane stress working on the side wall




Water pressure

$$W_p = 3.55 \text{ t/m}^2$$

$$N_x = \frac{1}{2} W_p \cdot r = \frac{1}{2} \times 3.55 \times 5.0 = 8.9 \text{ t}$$


$$N_\phi = W_p \cdot r = 3.55 \times 5.0 = 17.8 \text{ t}$$

ii) Bending stress in the direction of the circumference and shearing stress working on the side wall





$$M_a = 1.1 \text{ t} \cdot m$$

$$M_b = 0.51 \text{ t} \cdot m$$



$$Q_A = Q_{\max} = 2.8 \text{ t}$$

iii) Stress of the water tank floor slab



$$W = 1.3 + 355 = 485 \text{ t/m}^2$$

$$W_e = 5.0 \text{ t/m}^2$$

$$\lambda = \frac{L_{ye}}{L_x} = \frac{5.0}{3.0} = 1.67$$

$$\max M_x = 0.074 \times 5.0 \times 3.0^2 = 3.33$$

$$\max M_y = 0.042 \times 5.0 \times 3.0^2 = 1.89$$

$$W_s Q_{\max} = 0.52 \times 5.0 \times 3.0 = 7.8 \text{ t/m}$$


iv) Stress of the roof slab (In conformity with iii)

$$\max M_x = 0.074 \times 0.85 \times 3.0^2 = 0.57 \text{ t} \cdot \text{m/m}$$

$$\max M_y = 0.042 \times 0.85 \times 3.0^2 = 0.33 \text{ "}$$

$$R_s Q_{\max} = 0.52 \times 0.85 \times 3.0 = 1.4 \text{ t/m}$$

v) The stress is calculated by regarding the external peripheral wall of the water tank as a bending beam



$$\Sigma W = N_x + w_s Q_{\max} + R_s Q_{\max} + W_d$$

$$= 89 + 7.8 + 1.4 + 3.6 = 21.7 \text{ t/m}$$

$$B \lambda D = 30 \times 4 \phi 0 \quad W_d = 0.84 \times 4.3 \div 3.6 \text{ t/m}$$

$$\phi_0 = 45^\circ (= \frac{\pi}{4})$$

$$M_B = X \cos \phi_0 - \Sigma W \cdot r^2 (1 - \cos \phi_0)$$

$$M_T = X \sin \phi_0 - \Sigma W \cdot r^2 (\phi_0 - \sin \phi_0)$$

$$X = \Sigma W \cdot r^2 \times \frac{(4 \sin \phi_0 - 2 \phi_0)(U+1) + \sin 2 \phi_0 (U-1) - 4 U \phi_0 \cos \phi_0}{2 \phi_0 (U+1) - \sin 2 \phi_0 (U-1)}$$

$$= 0.071 \Sigma W \cdot r^2 - 0.071 \times 21.7 \times 5^2 = 38.52$$


$$U = \frac{22 \left\{ \left[ 1 + \left( \frac{430}{30} \right)^2 \right] \right\} (3.645 - 0.06 \frac{430}{30})}{12} = 105.2$$

$$\text{Therefore } M_B = 38.52 \times 0.707 - 21.7 \times 5.0^2 \times (1 - 0.707) = -131.81 \cdot \text{m}$$

$$M_T = 38.52 \times 0.707 - 21.7 \times 5.0^2 \times (0.785 - 0.707) = 16.21 \cdot \text{m}$$

$$G Q_{\max} = \frac{1}{2} \times 2W \times \frac{\pi D}{4} = \frac{1}{2} \times 21.7 \times 7.85 = 85.3 \text{ t}$$

vi) Stress of the rib wall of the water tank



$$W_B = 0.3 \times 5.35 \times 24 = 39 \text{ t/m}$$

$$P = 85.3 \text{ t} (= GQ_{\max}) \cdot 2 = 170.6 \text{ t}$$

$$\begin{aligned} M_E &= P \times 21 + W \times 1.05 + \frac{1}{2} \times W_d \times 21^2 + M_T \\ &= 170.6 \times 21 + (1.05^2 \times 2 \times 5.7) \times 105 + \frac{1}{2} \times 39 \times 21^2 + 16.2 \\ &= 3583 + 132 + 86 + 16.2 = 3963 \text{ t} \cdot \text{m} \end{aligned}$$

$$Q_E = P + W + W_d \times 21$$

$$= 170.6 + 126 + 39 \times 21 = 1914 \text{ t}$$

(7) Calculation of the horizontal stresses

a) Calculation of the compressed area

$$\begin{aligned} \text{i)} \quad A_{z_3 \sim 4} &= 1.02 \times 0.7 / 2 = 3.57 \text{ m}^2 & \} \\ &1.02 \times 4.3 = 4.386 \text{ m}^2 & \} \quad 4.75 \text{ m}^2 \end{aligned}$$

$$\begin{aligned} \text{ii)} \quad A_{z_2 \sim 3} &= 6.0 \times 1.95 = 11.70 \text{ m}^2 & \} \\ &2.1 \times 2.1 \times \frac{1}{2} \times 2 = 4.41 \text{ m}^2 & \} \quad 12.15 \text{ m}^2 \end{aligned}$$

$$\text{iii)} \quad A_{z_1 \sim 2} = 6.0 \times 1.0 = 6.00 \text{ m}^2$$


b) Calculation of the wind pressure

$$\text{i)} \quad P_{w_3 \sim 4} = 185 \times A_{z_3 \sim 4} = 185 \times 4.75 = 880 \text{ kg} \rightarrow 0.9 \text{ t}$$


$$\text{ii)} \quad P_{w_2 \sim 3} = 185 \times A_{z_2 \sim 3} = 185 \times 12.15 = 2250 \text{ kg} \rightarrow 2.3 \text{ t}$$

$$\text{iii)} \quad P_{w_1 \sim 2} = 185 \times A_{z_1 \sim 2} = 185 \times 6.0 = 1110 \text{ kg} \rightarrow 1.2 \text{ t}$$


c) Calculation of the stress of the tower due to the wind pressure



$$\begin{aligned} M_0 &= 0.9 \times 35.5 \\ &+ 2.3 \times 23.5 \\ &+ 1.2 \times 8.5 = 96.2 \text{ t} \cdot \text{m} \\ Q_0 &= 0.9 + 2.3 + 1.2 = 4.4 \text{ t} \end{aligned}$$



d) Calculation of the pile reaction due to the wind pressure



$$M_F = \frac{1}{2} M_0 = 96.2 / 2 = 48.1 \text{ t}\cdot\text{m}$$

$$R_F = \frac{M_F}{6.5} = \frac{48.1 \text{ t}\cdot\text{m}}{6.5} = 7.4 \text{ t} < 8.8 \text{ t}$$

e) Calculation of  $J_P$  due to twist of the water tank external wall

$$J_P = \frac{1}{3} \times 430 \times 35^2 + \frac{1}{3} \times 120 \times 30^2 + \frac{1}{3} \times 120 \times 50^2$$

$$= 1.75 \times 10^5 + 0.36 \times 10^5 + 1.0 \times 10^5$$

$$= 3.11 \times 10^5$$

$$\tau_{\max} = \frac{M_t}{J_P} = \frac{1.62 \times 10^5}{3.11 \times 10^5} = 5.2 \text{ kg/cm}^2 < 7.0 \text{ kg/cm}^2$$

f) Examination of the cross-shaped internal wall of the water tank

1) Examination of the bend reinforcing

$$B \times D = 30 \times 570 \quad j = 481.2 \text{ cm}$$

$$M_{\text{design}} = 39630 \text{ t}\cdot\text{m}$$

$$Q_{\text{design}} = 191.4 \text{ t} \quad \alpha = \frac{4}{\frac{39630}{191.4 \times 55.0} + 1} = 2.9 \rightarrow 2.0$$

$$a_t = \frac{39630}{20 \times 481.2} = 41.2 \text{ cm} \quad 9 - D25 \phi$$

$$\tau = \frac{Q}{b \cdot j} = \frac{191.4 \times 10^3}{30 \times 481.2} = 13.3 \text{ kg/cm}^2$$

$$\text{slip } D13 - 200 @ \quad PW = 0.0042$$


$$Q_{\text{design}} = 30 \times 481.2 \{ 20 \times 7.0 + 1000(0.0042 - 0.002) \} = 233,863.2 \text{ kg} > 191,400 \text{ kg} \text{ O.K}$$

g) Design of water tower body

1)  $Z_2$  level  $N_L = 8926 \text{ t}$   $N_H^W = 0.9 \times 27 + 23 \times 15 = 58.8 \text{ t} \cdot m$

$Q_H^W = 0.9 \times 23 = 3.2 \text{ t}$

**Cross Section**



$$A = \pi \left\{ \left( \frac{D_1}{2} \right)^2 - \left( \frac{D_2}{2} \right)^2 \right\} = \pi \times (200^2 - 170^2) = 34,870 \text{ cm}^2$$

$$Z = \frac{\pi}{32} (D_1^3 - D_2^3) = \frac{\pi}{32} (400^3 - 310^3) = 242 \times 10^6 \text{ cm}^3$$

$$L\sigma_c = \frac{8926 \times 10^3}{34.87 \times 10^3} = 25.6 \text{ kg/cm}^2 < 70 \text{ kg/cm}^2$$

$$H\sigma_b = \pm \frac{58.8 \times 10^5}{242 \times 10^6} = \pm 2.5 \text{ kg/cm}^2$$

Therefore water tower body's stress condition under the wind load is as follows.

$$\max \sigma_c = 25.6 + 2.5 = 28.1 \text{ kg/cm}^2 < 70 \text{ kg/cm}^2$$


$$\min \sigma_c = 25.6 - 2.5 = 23.1 \text{ kg/cm}^2 < 70 \text{ kg/cm}^2$$

Accordingly concrete is always in pressed condition and never occur bending moment. That is to say, supporting reinforcing bar is sufficient.

ii)  $Z_6$  level  $N_0 = 1,071.2 \text{ t}$   $M_{II}^W = 96.2 \text{ t} \cdot m$

$Q_H^W = 4.4 \text{ t} \cdot m$

**Cross Section**



$D_1 = 400 \text{ cm}$   $D_2 = 320 \text{ cm}$

$$A = \pi (200^2 - 160^2) = 45.2 \times 10^4 \text{ cm}^2$$

$$Z = (400^3 - 320^3) = 3.06 \times 10^6 \text{ cm}^3$$

$$L\sigma_c = \frac{1,071.2 \times 10^3}{45.2 \times 10^3} = 23.7 \text{ kg/cm}^2$$

$$L\sigma_b = \pm \frac{96.2 \times 10^5}{3.06 \times 10^6} = \pm 3.2 \text{ kg/cm}^2$$

$$\max \sigma_c = 23.7 + 3.2 = 26.9 \text{ kg/cm}^2 < 70.0 \text{ kg/cm}^2$$

$$\min \sigma_c = 23.7 - 3.2 = 20.5 \text{ kg/cm}^2$$

Therefore same above  $Z_2$  level supporting reinforcing bar is quite enough.



h) Design of tooting

1) Calculation of contact pressure (full tank)

$$N_L = 2527.3 \text{ t} \quad A_f = 186.4 \text{ m}^2$$


$$\sigma_c = \frac{N_L}{A_f} = \frac{2527.3}{186.4} = 13.6 \text{ t/m}^2 < 15.0 \text{ t/m}^2$$

2) Calculation of contact pressure (empty)

$$N_L = 2327.3 \text{ t} \quad A_f = 186.4 \text{ m}^2$$


$$\sigma_2 = \frac{N_L}{A_f} = \frac{2327.3}{186.4} = 12.5 \text{ t/m}^2 < 15.0 \text{ t/m}^2$$

3) Design of pressure slab



$$W = 1.0712 / 186.4$$

$$W_s = 4.59, 1.84, 1.23$$



A.

$$M_B(L) = \frac{5.75 \times 4.5^2}{2} = 58.2 \text{ t} \cdot \text{m} \quad Q = 25.9$$

$$M_B(S) = 58.2 + \frac{1.84}{2} \times 4.5^2 + \frac{2.35 \times 4.5 \times 2}{2 \times 1} = 58.2 + 18.6 = 76.8$$

$$Q = 25.9 + 14.5 = 40.4$$

$$M_C(L) = 87.0 \quad Q = 31.6$$

$$M_C(S) = 87.0 + \frac{1.23}{2} \times 5.5^2 + \frac{3.36 \times 5.5^2 \times 2}{2 \times 3} = 87.0 + 18.6 + 33.9 = 139.5$$

$$Q = 31.6 + 16.0 = 47.6$$

$$Q = 31.6 + 16 = 47.6$$

B.

$$b = 250 \quad d = 240 \quad j = 210$$

$$(L) \text{ at } = 13.9$$

$$(S) = 15.15 \quad \text{D22-200C}$$

$$\varphi = 6.1$$

$$\tau = 1.92 < 7.0$$

$$c. \quad D = 350 \quad d = 340 \quad j = 297$$

$$L_{at} = 14.7$$

$$S_{at} = 15.7 \quad D22-200C$$

$$\varphi = 7.7$$

$$\tau = 1.6$$

(8) Calculation of the cross sections of the members

a) Water tank roof

$$D = 30 \text{ cm} \quad d = 25 \text{ cm} \quad j = 21.8 \text{ cm}$$

$$M_{\text{design}} = 1.5 \times \max M_x = 1.5 \times 0.57 = 0.86 \text{ t}\cdot\text{m}/\text{m}$$

$$Q_{\text{design}} = 1.5 \times R_s Q_{\text{max}} = 1.5 \times 1.4 = 2.1 \text{ t}/\text{m}$$

$$a_t = \frac{M}{f_t \cdot j} = \frac{86}{20 \times 21.8} = 1.98 \text{ cm}^2 \quad D13-643Q \rightarrow 200 \text{ @}$$

$$\tau = \frac{Q}{b \cdot j} = \frac{21 \times 10^3}{1 \times 21.8} = 0.97 \text{ kg/cm}^2 < 7.0 \text{ kg/cm}^2 \quad \text{O.K.}$$

b) Water tank floor

$$D = 50 \text{ cm} \quad d = 45 \text{ cm} \quad j = 39.3 \text{ cm}$$

$$M_{\text{design}} = 1.5 \times \max M_x = 1.5 \times 3.33 = 5.0 \text{ t}\cdot\text{m}/\text{m}$$

$$Q_{\text{design}} = 1.5 \times W_s Q_{\text{max}} = 1.5 \times 7.8 = 11.7 \text{ t}/\text{m}$$

$$a_t = \frac{M}{f_t \cdot j} = \frac{500}{20 \times 39.3} = 6.4 \text{ cm}^2 \quad D15-199 \text{ @}$$

$$\tau = \frac{Q}{b \cdot j} = \frac{11.7 \times 10^3}{100 \times 39.3} = 3.0 \text{ kg/cm}^2 < 7.0 \text{ kg/cm}^2 \quad \text{O.K.}$$

c) Water tank wall

$$D = 30 \text{ cm} \quad d = 27 \text{ cm} \quad j = 23.6 \text{ cm}$$

i) Vertical  $M_{\text{design}} = 3.33 \text{ t}\cdot\text{m}$

$$Q_{\text{design}} = 7.8 \text{ t}$$

$$a_t = \frac{M}{f_t \cdot j} = \frac{333}{20 \times 23.6} = 7.1 \text{ cm}^2 \quad D13-180 \text{ @}$$

$$\tau = \frac{Q}{b \cdot j} = \frac{7.8 \times 10^3}{100 \times 23.6} = 3.3 \text{ kg/cm}^2 < 7.0 \quad \text{O.K.}$$

ii) Longitudinal

$$\text{Outside at} = \frac{N\phi}{20} = \frac{17.8}{20} = 8.9 \text{ cm} \quad \text{D13-142@}$$

$$\text{Inside at} = \frac{Ma}{20 \times 236} = \frac{110}{472} = 2.4 \text{ cm} \quad \text{D13-544@}$$

d) Calculation of the bend reinforcing bar of the water tank external wall.

$$B \times B = 35 \times 430 \quad j = 350$$

$$M_{\text{design B}} = 131.8 \text{ t}\cdot\text{m} \quad Q_{\text{design}} = 85.3 \text{ t}$$

$$a_t = \frac{M}{f_t \cdot j} = \frac{13180}{20 \times 350} = 18.9 \text{ cm} \quad \text{S-D22}\phi$$

$$\tau = \frac{Q}{b \cdot j} = \frac{85300}{35 \times 350} = 6.97 \text{ kg/cm} < 7.0 \text{ kg/cm}$$



**ANNEX 17**

**BREAKDOWN OF COSTS TO BE BORNE BY  
THE GOVERNMENT OF SOMALIA**



Breakdown of the Project Cost Portion to Be Borne by the Government of Somalia

1. Cost to Lay Gravel on the Rural Roads to Be Used as Pipeline Route

Access roads	Removal and Construct anew	1 set	2,626,733 So. Sh. (¥1,776,600)
Peripheral roads of wells and water supply towers	"	"	2,000,050 So. Sh. (¥5,670,000)
			4,626,783 So. Sh. (¥7,446,600)

2. Cost to be Borne Regarding Custom Charges and the Like Imposed on Materials and Equipment Imported from Japan

(Unit: Yen)					
	<u>Name</u>	<u>Purchase Price</u>	<u>CIF</u>	<u>Tax Rate</u>	<u>Total</u>
(1)	Cement	8,050,000	37,720,000	60%	22,632,000
(2)	Reinforcing Bars	11,220,000	20,700,900	35%	7,245,315
(3)	Form Materials	15,045,000	30,957,000	50%	15,478,500
(4)	Vehicles	15,465,935	19,962,773	52 - 120	16,862,935
(5)	Articles for Field Management	1,478,080	1,775,000	10	177,500
(6)	Scaffolding and Timbering Materials	12,045,100	45,474,148	30	13,642,244
(7)	Materials for General Purpose Temporary Facilities	2,871,750	2,996,550	10	299,655
	Electric Equipment for Temporary Facilities	4,201,960	4,888,360	35 - 86	3,320,736
	Materials for temporary Facilities	4,574,250	10,096,650	50	5,048,325

<u>Name</u>	<u>Purchase Price</u>	<u>CIF</u>	<u>Tax Rate</u>	<u>Total</u>
(8) Pump House Machinery	36,000,000	38,815,440	35	13,585,404
(9) Well Digging	798,150	1,354,650	30	406,395
(10) Machinery for Working Reinforcing Bars	3,754,000	4,066,000	62	2,520,920
(11) Other Miscellaneous Materials	1,254,570	3,407,370	30	1,022,211
(12) Pipes	346,524,370	606,415,570	60	363,849,342
<b>TOTAL</b>				<b>(466,091,482)</b>
				<b>164,410,329 So. Sh.</b>

### 3. Cost of Maintenance and Administrative Equipment

(Unit: Yen)

(1) Vehicles			
Bulldozer	1 unit		1,950,000
Pick-up	1 unit		1,250,000
(2) Transportation Cost (Ocean and Inland Transportation)	1 set		1,378,600
(3) Import Tax (83%)	1 set		3,796,918
<b>(8,375,518)</b>			
<b>2,954,402 So. Sh.</b>			
<b>Total of aforementioned cost items</b>			<b>171,991,514 So. Sh.</b>



**ANNEX 18**

**BREAKDOWN OF COST FOR  
OPERATION AND MAINTENANCE**



## Operation and Maintenance Cost

### Breakdown

#### (1) Personnel expenditure

Superintendent	1 x 20,000 =	20,000 Shilling
Section Chief	2 x 15,000 =	30,000 "
Pump Operator	4 x 12,000 =	48,000 "
Maintenance Personnel	3 x 12,000 =	36,000 "
P.R. Supervisor	2 x 9,000 =	18,000 "
Driver	2 x 7,500 =	15,000 "
Water Supply Center Caretaker	36 x 9,000 =	324,000 "
Total		491,000 Shilling/month
		5,892,000 Shilling/year
		(16,674,360 Yen/year)

#### (2) Operation and maintenance annual cost

##### 1) Pump fuel

- Production well pump

$$160 \text{ g/ps/hr} \times 60 \text{ ps} \times \frac{1}{830} = 11.6 \text{ liter/hr}$$

$$11.6 \text{ liter/hr} \times 17.95 \text{ hr/day} = 208.2 \text{ liter/day}$$

$$208.2 \text{ liter/day} \times 14.84 \text{ Shilling/liter} \times 365 \text{ days} \\ = 1,127,736 \text{ Shilling/year} \quad (3,191,493 \text{ Yen/year})$$

##### 2) Oil

- Production well pump

$$52.9 \text{ Shilling/hr} \times 17.95 \text{ hr/day} \times 365 \text{ days}$$

$$= 346,587 \text{ Shilling/year} \quad (980,841 \text{ Yen/year})$$

##### 3) Chemicals

$$= 29,400 \text{ Yens/year}$$

$$(10,389 \text{ Shilling/year})$$

4) Vehicle operation and maintenance cost

(a) Vehicle fuel cost

- Gasoline for round trip to construction site

$$5 \text{ times/day} \times 30 \text{ km} \frac{1}{5 \text{ km/liter}} \times 14.84 \times 365 \text{ days} \\ = 162,498 \text{ Shilling/year (459,869 Yen/year)}$$

- Gasoline for patrolling work site

$$4 \text{ times/day} \times 60 \text{ km} \frac{1}{5 \text{ km/liter}} \times 14.84 \times 365 \text{ days} \\ = 259,997 \text{ Shilling/year (735,791 Yen/year)}$$

- Change of lubricating oil of vehicles

$$= 84,499 \text{ Shilling/year (29,828 Yen/year)}$$

(b) Spare parts

$$= 640,000 \text{ Yen/year (226,148 Shilling/year)}$$

(c) Vehicle depreciation cost (2 units, 5-year life)

$$\frac{2,985,000 - 298,500}{5} = 537,300 \text{ Shilling/year} \\ (1,520,559 \text{ Yens/year})$$

5) Expendables of pumps and the like

$$30,580,000 \text{ Yens} \times 5\% = 1,529,000 \text{ Yens}$$

$$(540,283 \text{ Shilling/year})$$

TOTAL

$$9,187,437 \text{ Shilling/year}$$

$$(26,000,447 \text{ Yen/year})$$

**ANNEX 19**

**PLAN FOR PROCUREMENT OF  
MATERIALS AND EQUIPMENT**



Table A19-1 Plan for Procurement of Materials and Equipment

Study on the price and various conditions		
	Purchased from Japan	Purchased on site or lease
Iron bars	<ul style="list-style-type: none"> <li>◦ Materials + packing + transportation  <math>60,000 + 3,300 + 66,000 = 129,300</math>                      yen/T</li> <li>◦ Standard of quality is unified.</li> <li>◦ Few variations in prices.</li> </ul>	<ul style="list-style-type: none"> <li>◦ Purchased on site: 183,600 yen/T</li> <li>◦ Due to importing from each of European countries, a standard, price and quality are not uniform and have a variation.</li> <li>◦ Required amount of materials may not be attained.</li> </ul>
Result of study	○	△
Cement	<ul style="list-style-type: none"> <li>◦ Materials + packing + transportation  <math>14,000 + 4,200 + 66,000 = 84,200</math>                      yen/T</li> <li>◦ Standard of quality is unified.</li> <li>◦ Few variations in price.</li> </ul>	<ul style="list-style-type: none"> <li>◦ Purchased on site: 63,600 yen/T</li> <li>◦ Similar as the iron bars, the product has less reliability and its variation in price is also high.</li> </ul>
Result of study	○	△
Plywood & Wooden material	<ul style="list-style-type: none"> <li>◦ Materials + packing + transportation  <math>59,200 + 15,000 + 66,000 = 140,200</math>                      yen/T</li> <li>◦ Product of required amount and quality can be obtained with a low price.</li> </ul>	<ul style="list-style-type: none"> <li>◦ Purchased on site: 250,000 yen/m<sup>3</sup></li> <li>◦ Due to imported products, their price is high, a lack of products occurs and obtaining of products is difficult.</li> </ul>
Result of study	○	△
Ram	<ul style="list-style-type: none"> <li>◦ 8,235,000 yen/unit</li> <li>◦ Easy maintenance is assured.</li> <li>◦ Standards can be unified and quality of the product can be assured.</li> </ul>	<ul style="list-style-type: none"> <li>◦ 9,350,000 yen/unit.</li> <li>◦ Purchasing of spare parts is difficult.</li> <li>◦ Due to a lack of spare parts, sufficient maintenance is not assured.</li> </ul>
Result of study	○	△

(Cont.)

	Purchased from Japan	Purchased on site or lease
Water plug	<ul style="list-style-type: none"><li>◦ Universal water plug 20 mm ¥2,660</li><li>◦ Standards can be unified.</li></ul>	<ul style="list-style-type: none"><li>◦ Universal water plug 20 mm ¥6,000</li><li>◦ Price is high and its purchasing is difficult. Some variation in standards.</li></ul>
Result of study	○	△
Valves	<ul style="list-style-type: none"><li>◦ Partition valve ¥112,000/pc.</li><li>◦ Standards can be unified.</li></ul>	<ul style="list-style-type: none"><li>◦ Partition valve ¥250,000/pc.</li><li>◦ Price is high and purchasing is difficult. Some variation in standards.</li></ul>
Result of study	○	△
Construction machines	<ul style="list-style-type: none"><li>◦ Unit price of excavation in case that the excavators are imported from Japan and then the machines are sent back to Japan: 668 yen/m<sup>3</sup></li><li>◦ It is expensive. See the attached data.</li></ul>	<ul style="list-style-type: none"><li>◦ Unit price of excavation: 326 yen/m<sup>3</sup> (lease)</li><li>◦ Entire management is performed by a leasing company and plentiful types of machines are available.</li></ul>
Result of study	○	△