

資料-6 ザンビア国的主要指標

Appendix-6 COUNTRY DATA

TABLE I—SELECTED INDICATORS
(ANNUAL AND QUARTERLY FIGURES)

	Unit	1977	1978	1979	1980	1981	1982	1983	1984	1984			
										Quarter	III	IV	I
1. Population (Mid-year est.)	million	5.20	5.36	5.52	5.68	5.87	6.05	6.22	6.42	16
2. Gross Domestic Product													
At current purchasers' values	...	K'million	1,984.4	2,250.7	2,660.4	3,063.6	3,485.4	3,595.3	4,181.2	4,733.3	16
At 1977 purchasers' values ^a	...	K'million	1,986.4	1,997.8	1,937.0	1,995.8	2,118.5	2,059.3	2,018.2	1,992.1	16
At 1977 purchaser's values	...	K'million	1,984.4	1,983.4	2,068.8	2,010.7	1,982.0	1,773.1	1,821.0	1,814.7	16
3. Per Capita Gross Domestic Product													
At current prices	...	Kwacha	382.0	419.9	482.0	539.4	596.8	594.3	672.2	737.3	16
At 1977 prices	...	Kwacha	382.0	372.0	350.9	351.4	362.8	340.4	324.6	310.3	16
At 1977 prices (Adjusted for terms of trade)	...	Kwacha	382.0	370.0	374.8	354.0	339.4	292.9	292.8	282.7	16
4. National Income													
At current market prices	...	K'million	1,607.4	1,809.8	2,124.3	2,495.9	3,004.1	2,870.3	3,508.3	3,910.3	16
At 1977 market prices (unadjusted)	...	K'million	1,607.4	1,616.9	1,575.5	1,671.2	1,856.6	1,778.2	1,773.2	1,770.1	16
At 1977 market Prices (adjusted)	...	K'million	1,607.4	1,512.5	1,707.3	1,686.1	1,719.7	1,492.0	1,595.5	1,592.7	16
5. Per Capita National Income													
At current prices	...	Kwacha	309.1	337.6	384.8	439.4	514.4	474.4	564.0	609.1	16
At 1977 prices ^b	...	Kwacha	309.1	301.7	285.4	294.2	317.9	293.9	285.1	275.7	16
At 1970 prices	...	Kwacha	309.1	282.2	309.3	296.8	294.5	246.5	253.3	248.1	16
6. Gross National Product													
At current prices	...	K'million	1,898.3	2,109.4	2,431.8	2,835.0	3,387.5	3,276.1	3,935.0	4,358.0	16
At constant 1977 prices	...	K'million	1,898.3	1,830.5	1,788.6	1,879.1	2,078.2	1,981.5	1,945.0	1,915.7	16
At constant 1977 prices (Unadjusted)	...	K'million	1,898.3	1,866.1	1,920.4	1,894.0	1,941.3	1,695.3	1,747.2	1,738.3	16
7. Copper production, exports, price													
Production	'000 tonnes	659.8	655.6	584.5	610.2	560.6	584.8	576.1	523.3	143.6	129.7	131.5
Exports	'000 tonnes	666.6	589.4	631.1	621.7	581.8	605.6	550.6	530.4	142.0	138.7	138.7
LME Cash and Settlement Price per tonne		Kwacha	1,91.6	1,09.0	1,572	1,719	1,514	1,374	1,985	2,500	2,478	2,733	32.4
8. Index of Production													
Mineral Production	1973=100	94.2	95.4	86.1	89.3	82.0	86.0	84.4	77.0	83.3	75.2	78.1
Manufacturing	1973=100	98.5	102.6	96.2	99.2	104.9	100.1	94.5	94.9	99.6	93.7	107.1
Electricity	1973=100	265.0	240.7	248.4	280.7	293.8	323.5	308.5	293.5	299.9	275.4	294.1
9. External Trade													
Exports	K'million	708.0	686.8	1,090.0	1,023.3	936.5	950.5	1,047.5	1,188.1	332.2	316.3	...
Imports	K'million	530.0	492.6	593.7	676.7	924.4	930.0	893.3	1,107.9	313.6	316.9	...
10. Prices													
Index Numbers of Consumer Prices													
High Income	1975=100	136.8	152.6	169.8	189.4	209.1	236.6	278.6	336.8	342.0	359.3	390.3
Low Income	1975=100	142.3	165.6	181.6	202.9	231.3	260.2	311.2	373.5	378.2	399.5	449.7
Index Numbers of Wholesale Prices													
Including Copper	1966=100	211.6	246.4	306.2	324.3	352.1	373.5	465.8	596.2	612.9	646.0	710.8
Excluding Copper	1966=100	274.9	333.7	399.6	439.2	467.5	541.9	653.3	830.6	861.4	897.0	967.1
11. Employment and Earnings													
Number of employees as on 31st December													
Zambian	'000	344	343	381	359	355	350	348	351
Non-Zambian	'000	26	23	23	20	19	17	16	14
Total	'000	370	367	374	379	373	368	364	365
Average annual earnings													
Zambian	Kwacha	1,566	1,742	1,657	2,301	2,392	2,556	2,647
Non-Zambian	Kwacha	7,066	6,987	6,122	8,715	8,111	8,258	8,071
12. Government Finance													
Receipts	K'million	630	686	856	1,174	1,220	1,191	1,208	1,084	220	352	...
Payments	K'million	521	815	756	1,630	1,389	1,643	1,337	...	329
13. Money Supply	K'million	418	420	551	553	599	737	627	872	929	872	859


Note: Figures on Employment and Earnings for 1981 to 1984 are for the Quarter ending June.

1980 population figure is from the 1980 Census.

^aUnadjusted for changes in terms of trade.

[Source: Monthly Digest of Statistics, August/September, 1985]


以下の資料は、表示してあるものを除き、Selected Socio-Economic Indicators, 1984,
Central Statistical Office, Zambia の抜粋である。



	<u>1969</u>	<u>1980</u>
1.1 Population enumerated (million)	4.06	5.68
1.2 Projected population (million)	1984	1989
	<u>6.44</u>	<u>7.53</u>
	<u>1969</u>	<u>1979-84</u>
1.3 Crude birth rate (per 1,000 population)	47.7	48
1.4 Crude death rate (per 1,000 population)	19.7	17
	<u>1963-69</u>	<u>1969-80</u>
1.5 Growth rate (%)	2.5	3.1
	<u>1969</u>	<u>1980</u>
1.6 Sex ratio (males per 100 females)	96.0	96.0
1.7 Total fertility rate (average number of children born to a woman)	6.9	-
1.8 Gross reproduction rate (average number of female births to a woman)	3.6	-
	<u>1979-84</u>	
1.9 Life expectancy at birth, total	43.4	48.3
males	41.8	46.7
females	45.0	50.0
	<u>1980</u>	
1.10 Infant mortality rate (per 1,000 live births)	141	-
1.11 Child population (0-14) (%)	46.3	46.3
1.12 Dependency ratio (per 100 population)	94.3	94.3
1.13 Child dependency ratio (per 100 population)	90.0	90.0
1.14 Population density (persons per sq. km)	5.4	7.5

		<u>1980</u>
1.15	Urban population (%)	29.4
1.16	Population in large urban areas (> 50,000 inhabitants) (%)	27.6
1.17	Rural population (%)	70.6

		<u>1963-69</u>	<u>1969-80</u>
1.18	Growth rate urban population (%)	8.9	6.7
1.19	Growth rate rural population (%)	0.5	1.1
		<u>1969</u>	<u>1980</u>
1.20	Average household size total	4.6	-
1.21	Female headed households (%)	23.8	-



		<u>1969</u>	<u>1980</u>
2.1	Population with no schooling (%)		
	Total	52	-
	Males	39	-
	Females	65	-
	<u>Primary Schools</u>	<u>1971</u>	<u>1980</u>
2.2	Number of primary school pupils ('000')	730	1,042
	% females	44.9	46.8
2.3	% of school age children (7-14) enrolled in primary schools		
	Total	79.4	83.7
	Males	86.8	88.3
	Females	71.9	79.0
2.4	% of 7 years old enrolled in Grade 1	N.A.	95.4

		<u>1971</u>	<u>1980</u>
2.5	Progression rate from Grade 4 to Grade 5 (%)	72	86
2.6	Progression rate from Grade 7 to Form I (%)	23	20
2.7	Pupil/teacher ratio in primary schools	49.6	49.2

Secondary Schools

2.8	Number of secondary school pupils ('000)	56	95
2.9	% females of total enrolment in secondary schools	33.0	35.1
2.10	% of population 15-19 enrolled in secondary schools	12.3	15.9
2.11	Progression rate from Form III to Form IV (%)	N.A.	49.1
2.12	Pupil/teacher ratio in secondary schools	21.7	22.0

Teachers

2.13	% trained teachers in primary schools	85.1	87.1
2.14	% trained teachers in secondary schools	83.3	95.5
2.15	% Zambian teachers in primary schools	94.1	98.7
2.16	% Zambian teachers in secondary schools	13.0	58.1



Access to Health Facilities


		<u>1972</u>	<u>1980</u>
3.1	Population within 12 km of a health unit	Total %	75
		Rural %	N.A.

		<u>1972</u>	<u>1980</u>
3.2	Population within 12 km of a health centre	N.A.	68
3.3	Population within 30 km of a hospital	N.A.	59
<u>Health Facilities</u>			
3.4	Number of hospitals	76	81
3.5	Beds and cots in hospitals	12,870	15,326
3.6	Hospital beds per 1,000 population	2.9	2.6
3.7	Number of health centres/clinics % in rural areas	595 74	758 75
3.8	Beds and cots in health centres/ clinics	4,530	5,931
3.9	Total beds and cots per 1,000 population Rural Urban	3.9 N.A. N.A.	3.6 1.7 5.8
<u>Health Personnel</u>			
3.10	Number of doctors	N.A.	821
3.11	Doctors per 100,000 population	N.A.	14.0
3.12	Number of nurses	N.A.	5131
3.13	Nurses per 100,000 Population	N.A.	87.4
3.14	Number of health workers per 1,000 population	N.A.	1.4
<u>Nutrition</u>			
3.15	Per Capita Calorie Consumption (recommended levels in brackets)	<u>1967-72</u>	
	Urban	2,047 (2,060)	
	Wage earners in small townships	1,955 (2,030)	
	Rural subsistence farmers	1,357 (2,030)	
	Wage earners in rural areas	1,720 (2,030)	

1970-71

3.16 Percentage malnourished children
(0-4 years)

below 80% weight-for-age standard	55
below 90% weight-for-height standard	58



1969 1980

4.1 Average number of persons per room

2.6

4.2 % of dwellings with durable

roofs	27.2
walls	46.9

4.3 % of dwellings with electricity

12.4

4.4 % of households using wood, coal or charcoal as cooking fuel

84.2

4.5 Water supply

Piped water (%)	27.6
Well/borehole (%)	34.6
River or stream (%)	32.3
Other (%)	5.5

4.6 Water disposal method

Flush, aqua, pit, bucket (%)	50.1
None (%)	49.9


INFRASTRUCTURE

社会基盤施設

1977 1981

5.1 Total number of telephones ('000')	56	61
5.2 Telephones per 10,000 population	107	104
5.3 Total number of post offices/postal agencies	254	344


	<u>1977</u>	<u>1981</u>
5.4 Population per post office/postal agencies ('000')	20	17
5.5 Total number of vehicles ('000')	149	124
5.6 Number of vehicles per 10,000 population	286	211
	<u>1978</u>	<u>1982</u>
5.7 Road network ('000 km)		
of which	36	37
% bitumen	14.7	15.1
% gravel	21.5	23.5
	<u>1977</u>	<u>1981</u>
5.8 Railway passenger - kilometres per capita	57	63
	<u>1978</u>	<u>1981</u>
5.9 Electricity production (mill. Kw)	7,883	9,793



	<u>1975</u>	<u>1981</u>	<u>1982</u>
6.1 Labour force ('000')	1,479	1,824	1,880
6.2 Number of persons employed by the formal sector ('000')	393	374	368
6.3 Formal sector employment as percent of total labour force	27	21	20
	<u>1975</u>	<u>1979</u>	<u>1980</u>
6.4 % females of total formal sector employment	6.3	7.7	7.6

	<u>1975</u>	<u>1979</u>	<u>1980</u>
6.5 Sectoral distribution of formal sector employment			
agriculture (%)	9.2	9.7	9.6
mining and quarrying (%)	16.5	16.2	16.2
manufacturing (%)	11.3	12.8	13.2
community, social and personal services (%)	24.8	28.4	29.0

	<u>1977</u>	<u>1979</u>	<u>1980</u>
6.6 Average annual earnings of Zambians employed in the formal sector (Kwacha) 2nd quarter			
Agriculture	1,657	2,000	2,194
Mining and quarrying	647	878	995
Manufacturing	2,344	2,636	2,935
Personal services	1,624	1,890	2,082
	1,660	2,016	2,145



National Income

7.1 Gross Domestic Product (GDP)			
at current prices (K'million)	2,240	3,449	3,564
at 1970 prices (K'million)	1,484	1,484	1,454

7.2 Per Capita GDP			
at current prices (K)	418	588	589
at 1970 prices (K)	277	253	240

	<u>1978/79</u>	<u>1981/82</u>
7.3 Growth rate GDP (%)	-7.7	-2.0

	<u>1978</u>	<u>1981</u>	<u>1982</u>
7.4 Sectoral contribution to GDP			
agricultural sector			
K'million	169.2	180.0	159.0
%	11.4	12.1	10.9






		<u>1978</u>	<u>1981</u>	<u>1982</u>
	mining and quarrying			
	K'million	494.1	433.3	433.4
	%	33.3	29.2	29.8
	manufacturing			
	K'million	159.6	180.0	173.0
	%	10.8	12.1	11.9
7.5	National Income			
	at current prices (K'million)	1,809	2,917	2,881
	at 1970 prices (K'million)	1,326	1,368	1,328
7.6	Per Capita National Income			
	at current prices (K)	338	497	477
	at 1970 prices (K)	248	233	219
7.7	Gross fixed capita formation			
	at current prices (K'million)	437	610	618
	at 1970 prices (K'million)	164	150	132
	<u>Income Distribution</u>		<u>1974/75</u>	
7.8	Percentage of total income accruing to:			
	0-19% of the population	3		
	20-39% of the population	6		
	40-59% of the population	11		
	Urban			
	0-19% of the population	6		
	20-39% of the population	9		
	40-59% of the population	12		
	Rural			
	0-19% of the population	4		
	20-39% of the population	8		
	40-59% of the population	15		
			<u>1976</u>	
7.9	Average annual income per capita (K)	136	193	
	Urban	255	354	
	Squatter	170	238	
	Low income	186	270	
	High income	1,054	1,433	
	Rural	74		

	<u>Inflation</u>	<u>1978</u>	<u>1981</u>	<u>1982</u>
7.10	Increase in the index of consumer prices (%)	15.8	13.6	12.6
7.11	Index of consumer prices (1975 = 100)	163.9	228.5	257.2
<u>Government Revenue and Expenditure</u>				
7.12	Total Government revenue (K'million)	584.3	852.1	878.7
7.13	Total Government expenditure (K'million)	815.4	1,388.6	1,643.2
	current	647.1	1,230.5	1,323.0
	capital	168.3	158.1	320.2
7.14	% Government expenditure			
	health, total	6.5	5.6	7.2
	current	7.6	5.9	6.5
	capital	2.0	3.2	3.7
	education, total	13.6	11.0	13.0
	current	15.4	11.9	14.9
	capital	4.7	2.6	4.6
<u>Money and Banking</u>				
7.15	International reserves (net) (K'million)	236.8	383.2	192.4
7.16	Currency in circulation (K'million)	154.8	224.2	242.7
7.17	Private deposits (Demand, Savings and Time Deposits)	567.3	843.1	1,159.5
7.18	Government deposits (with Bank of Zambia) (K'million)	7.5	-462.6	-944.4
7.19	Commercial bank loans and advances	301.6	699.8	747.7
<u>Consumption/Investments</u> <u>(Current Prices)</u>				
7.20	Government final consumption (K'million)	575	1,054	1,072
7.21	Private final consumption (K'million)	1,203	2,166	2,254


		<u>1978</u>	<u>1981</u>	<u>1982</u>
7.22	Gross domestic investment (K'Million)	537	673	603
7.23	Gross domestic savings (K'Million)	-18.5	-417.5	-480.8
7.24	<u>Copper Production, Export, Price</u>			
	Production ('000 tonnes)	655.6	560.6	614.9
	Exports ('000 tonnes)	589.2	551.8	603.5
	Price per ton (LME Cash and Settlement Price) (K)	1,572	1,514	1,374
7.25	<u>Index of Production (1973 = 100)</u>			
	Mineral production	95.4	82.0	86.0
	Manufacturing	102.6	104.9	100.1
	Electricity	240.7	293.8	323.5
	<u>International Trade</u>	<u>1977</u>	<u>1980</u>	<u>1981</u>
7.26	Value of imports (K'million)	530	877	924
	% machinery and equipment	38.7	34.5	34.0
	% electricity and mineral fuels	15.3	22.6	21.9
	% food	5.4	4.4	5.5
7.27	Total exports (K'million)	708.0	1,023.3	936.5
7.28	Balance of trade (export surplus) (K'million)	178	147	12
7.29	Direction of foreign trade			
	% imports from			
	EEC	22	38	-
	U.K.	23	23	-
	% exports to			
	EEC	39	51	-
	U.K.	16	14	-
	Japan	18	16	-
	U.S.A.	10	11	-

Economic Trends in Zambia


[Source: Economic Review, 1985, EIU]




MONEY SUPPLY




RESERVES



DISBURSED PUBLIC FOREIGN DEBT



ZAMBIAN IMPORTS: 1982



[Source: Economic Review, 1985, EIU]

	<u>Balance of Payments</u>	<u>1977</u>	<u>1980</u>	<u>1981</u>
7.30	Overall balance of payments (K'million)	-224.3	-214.0	-341.4
7.31	Inflow of private capital (net) (K'million)	27.9	-67.7	91.7
7.32	Current account balance (K'million)	-208.1	-490.3	-656.7



	<u>1975</u>	<u>1978</u>
8.1	Arable land (million ha)	N.A.
8.2	Arable land per agricultural population (ha)	N.A.
8.3	Number of traditional households engaged in farming ('000')	614 626
8.4	Number of commercial farmers	1,530 1,580
	<u>1975/76</u>	<u>1976/77</u>
8.5	Loans released to farmers by financial institutions (K'million)	41 51 63
	Credit per farmer (K'000)	2.2 2.7 2.6
	<u>1975</u>	<u>1981</u>
8.6	Marketed production of selected crops	<u>1982</u>
	Sugarcane ('000 tonnes)	768 893 1,010
	Maize ('000 tonnes)	559 693 510
	Wheat ('000 tonnes)	0.9 11 13
	Rice ('000 tonnes)	1.0 2.7 2.9
	Sunflower ('000 tonnes)	8.2 19 21
	Seed cotton ('000 tonnes)	2.6 17 13
	Cotton lint ('000 tonnes)	0.9 6.3 4.9
	Tobacco ('000 tonnes)	7.0 3.0 2.6

	<u>1975</u>	<u>1980</u>	<u>1981</u>
8.7 Percentage contribution of traditional farmers in marketed maize	60	60	46
8.8 Imports			
of maize ('000 tonnes)	0.04	43	81
of wheat ('000 tonnes)	157	35	79
of rice ('000 tonnes)	3.9	4.6	2.4
8.9 Production of meat and milk (commercial sector)			
Cattle ('000 heads)	72	92	100
Pigs ('000 heads)	55	48	38
Poultry ('000 tonnes)	11	18	12
Milk ('million litres)	12	9	11
	<u>1975</u>	<u>1978</u>	<u>1979</u>
8.10 Production of major fisheries ('000 tonnes)	41	43	50
	<u>1975</u>	<u>1981</u>	<u>1982</u>
8.11 Percentage share of commercial and subsistence agricultural sector to GDP			
Commercial sector			
at current prices	4.0	6.0	5.3
at 1970 prices	3.9	4.8	4.1
Subsistence sector			
at current prices	9.1	9.8	8.3
at 1970 prices	7.0	7.3	6.9

WATER ANALYSES OF UNTREATED WATER
FROM KAFUE RIVER AT IOLANDA INTAKE
(1974 - 1976)

資料7 水質データ

Appendix-7 DATA ON WATER QUALITY

Characteristic	9-1-74	15-2-74	20-3-74	17-4-74	15-5-74	12-6-74	18-9-74	9-10-74	6-11-74	4-12-74	8-1-75	12-2-75	6-3-75	7-5-75	11-6-75	10-9-75	8-10-75	5-11-75	5-12-75	11-2-76
Appearance	Dirty Brown	Greenish Brown	Greenish Brown	Brownish Green	Greenish	Brownish	Greenish	Greenish	Greenish Brown	Brownish	Brownish	Brownish	Greenish	Greenish	Brownish	Greenish	Brownish	Greenish	Greenish	
Odour	Musty	Musty	Musty	Musty	Musty	Musty	Musty	Musty	Musty	Musty	Earthy	Musty	Earthy	Earthy						
Turbidity	8	3	7	4	2	2	3	2.4	4	6	5	4	6	4	3	3	3	3	4	6
Color °Hazen	30	50	40	40	20	8	15	15	15	35	20	35	25	15	15	10	12	10	10	25
pH	7.4	7.2	7.2	7.2	7.0	7.1	7.5	7.5	7.6	7.7	-	7.4	7.3	7.6	7.3	7.7	7.8	7.7	7.7	7.7
Total Dissolved Solids	93	153	141	136	99	122	115	167	191	224	194	87	152	136	129	166	130	133	152	160
Electrical Conductivity (micro mhos/cm)	240	160	150	135	110	110	190	200	210	240	230	180	170	110	110	160	190	220	240	220
Alkalinity as CaCO ₃	116	74	80	82	74	80	106	120	130	120	94	86	88	80	80	100	105	124	132	112
Hardness as CaCO ₃																				
Carbonate			80		64	80	106	104	0	120						0				
Non-Carbonate	8	6		6			0	0	130	10	6	0	8	0		0	-	-	0	10
Total	124	80	80	88	64	80	104	104	120	130	100	80	80	64	64	92	108	110	130	122
Calcium	106	64	64	68	64	65	94	100	120	126	80	64	60	60	52	86	90	104	88	89
Magnesium	18	16	16	20	0	15	10	4	0	4	20	16	20	-	12	6	18	6	42	33
Sodium Na	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Potassium K	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Chloride Cl	12	4	6	2	4	4	4	4	6	4	16	6	6	6	4	4	4	6	8	6
Sulphate SO ₄	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Nitrate N	0.06	0.08	0.01	0.10	0.06	0.08	0.1	0.08	0.10	0.08	0.08	0.14	0.10	0.06	0.06	0.01	0.02	0.04	0.03	0.05
Nitrite N	0	0	0	0	0	0	0	0	0	0	0	0	0	0	-	0	-	-	0	-
Free Ammonia N	0.44	0.18	0.02	0.03	0.10	0.03	0.30	0.24	0.02	0.20	0.08	0.28	0.28	0.04	0.02	0.50	0.54	0.64	0.20	0.76
Albuminoid Ammonia N	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Oxygen absorbed	35	1.6	1.5	5.1	3.7	2.9	6.8	9.0	3.9	5.4	4.1	4.1	2.2	2.5	4.0	4.6	2.8	3.6	4.0	4.0
Silica SiO ₂	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Phosphate PO ₄	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Fe Total	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Manganese Mn Total	0	0	-	0	+	0	0	0	-	0	-	-	0	-	-	-	-	-	-	-
Free Chlorine	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Suspended Solids	10	-	-	-	-	-	-	-	-	3.0	-	-	5	-	-	-	-	-	-	-
BOD (5 days)	20	5.6	5.6	1.3	0.5	0.8	1.25	0.7	1.3	1.7	-	1.5	1.7	0.9	0.3	2.0	0.9	0.8	1.7	1.8
Temperature	26	26	27	28	25	23	24	27	27	27	28	25	25	26	26	26	27	30	28	28.5
Dissolved Oxygen	2.8	1.8	0.1	1.1	1.0	1.5	2.7	2.7	2.0	2.7	2.6	1.5	1.5	1.2	2.5	6.5	7.7	7.0	10.0	7.3
Saturation	40	25.7	1.4	15.7	14.5	21.5	38.5	38.5	28.9	39.1	37.7	21.7	21.7	17.1	35.7	92.8	110.0	101.4	146.0	105.8


in mg/l except where shown otherwise.

[Source: Zambia Water Wastage Study, 1977]

WATER ANALYSES OF TREATED WATER
AT OUTLET OF STEWART PARK SERVICE RESERVOIR
(1974 - 1976)

Characteristic	10-1-74	17-2-74	14-3-74	17-4-74	16-5-74	13-6-74	17-9-74	10-10-74	7-11-74	5-12-74	9-1-75	13-2-75	5-3-75	13-5-75	12-6-75	11-9-75	10-10-75	6-11-75	8-12-75	12-2-76
Appearance	Clear	Bright	Clear	Greenish	Clear	Clear	Clear	Clear	Bright	Clear	Clear	Clear	Clear	Clear						
Odour	None	None	None	None	None	None	Chlorinous	Chlorinous	None	None	None	None	None	None	None	None	None	None	None	None
Turbidity	Clear	Clear	1.0	1	0.0	Clear	None	Clear	1.2	Nil	Nil	None	Nil	Clear	Clear	Clear	Clear	Clear	Clear	Clear
Color °Hazen	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5	-5
pH	7.0	6.9	7.1	7.0	7.0	6.6	6.6	7.1	7.2	6.9	6.9	7.0	6.8	7.0	7.2	7.0	7.5	7.5	7.5	7.5
Total Dissolved Solids	124	188	191	111	102	124	149	189	215	348	244	123	165	117	134	128	106	161	229	156
Electrical Conductivity (micro mhos/cm)	280	180	180	160	140	120	230	240	250	260	260	200	185	175	120	180	200	230	250	240
Alkalinity as CaCO ₃	84	50	66	68	70	80	48	60	114	120	100	62	70	62	54	70	92	94	114	110
Hardness as CaCO ₃																				
Carbonate			66		70	76	48	60	114						16					
Non-Carbonate	50	46	40	28	10	4	64	60	28	20	10	48	14	14	26	8	26	22	19	
Total	134	96	106	96	80	76	112	120	142	140	110	110	84	76	70	96	100	120	136	126
Calcium	118	80	76	78	70	64	84	106	104	90	88	100	60	64	60	82	88	90	92	84
Magnesium	16	16	30	18	10	12	28	14	38	50	22	10	24	12	10	14	12	30	44	14
Sodium Na	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Potassium K	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Chloride Cl	16	16	8.0	6.0	6	6	40	36	8	6	12	4	8.0	4	6	6	8	10	10	15.0
Sulphate SO ₄	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Nitrate N	0.12	0.04	0.0	0.01	0.00	0.0	0.08	0.05	0.08	0.14	0.09	0.1	0.06	0.04	0.04	0.01	0.04	0.04	0.02	0.05
Nitrite N	0.00	0.00	0.0	0.00			0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Free Ammonia N	0.08	0.02	0.01	0.01	0.02	0.0	0.06	0.01	0.04	0.2	0.56	0.31	0.02	0.02	0.91	0.1	0.64	0.52	0.04	0.14
Aluminoid Ammonia N	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Oxygen Absorbed (4 Hrs, 27°C)	1.0	1.5	0.75	2.2	1.2	1.3	0.25	0.15	2.0	1.4	1.7	1.4	1.9	3.5	0.8	0.7	1.8	1.5	1.2	2.4
Silica SiO ₂	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Phosphate PO ₄	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Iron Fe Total	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Manganese Mn Total	0.00	-	-	0.00	-	-	-	0.0	-	-	-	-	-	-	-	-	-	-	-	-
Free Chlorine	Nil	Trace	Trace	Trace	Trace	Trace	0.7	1.2	Trace	Nil	Trace	Nil	Trace	Nil	Nil	Trace	Nil	Nil	Trace	Nil

Units in mg/l except where shown otherwise.



BACTERIOLOGICAL ANALYSIS

SOURCE	DATE SAMPLED	COLIFORM ORGANISMS/100ML	95% CONFIDENCE LIMIT		CONFIRMED E. COLI	TOTAL BACTERIAL COUNT	REMARKS
			LOWER LIMIT	UPPER LIMIT			
1 CHELSTON	24/12/85	3	< 0.5	9	+	-	UNSATISFACTORY
2 NORTHMEAD	24/12/85	1	< 0.5	4	+	-	UNSATISFACTORY
3 KALAMBO ROAD WORKSHOP	24/12/85	N.I.	-	-	-	-	SATISFACTORY
4 CHUNGA	24/12/85	N.I.	-	-	-	-	SATISFACTORY
5 CHAWAMA	24/12/85	N.I.	-	-	-	-	SATISFACTORY
6 WATER DISTRIBUTION RESERVOIR	24/12/85	N.I.	-	-	-	-	
7 KAFUE TREATMENT PLANT	27/12/85	N.I.	-	-	-	-	
8 CHILANGA PUMPING STATION	27/12/85	6	1	15	+	+	UNSATISFACTORY

BACTERIOLOGICAL ANALYSES

SOURCE	DATE SAMPLED	COLIFORM ORGANISMS / 100ML	95% CONFIDENCE LIMIT		CONFIRMED E. COLI	TOTAL BACTERIAL COUNT	REMARKS
			LOWER LIMIT	UPPER LIMIT			
1. Intercontinental	2/01/86	18+	5	55	+		Unsatisfactory
2. Chelston	2/01/86	18+	5	55	+		Unsatisfactory possible source reservoir
3. Northmead	2/01/86	10+	5	55	+		Unsatisfactory
4. Matero Police	2/01/86	6	1	15	+		Unsatisfactory
5. Kalambo Road Workshop	2/01/86	Nil	0	0	-		Satisfactory
6. Woodlands	2/01/86	Nil	0	0	-		Satisfactory
7. Rhodes Park	2/01/86	Nil	0	0	-		Satisfactory
8. Chilanga Pumping Station	4/01/86	9	2	21	+		Unsatisfactory
9. Kafue Laboratory	4/01/86	2	≤ 0.5	6	-		Satisfactory

BACTERIOLOGICAL ANALYSIS

SOURCE	DATE SAMPLED	COLIFORM ORGANISMS / 100ML	99% CONFIDENCE LIMIT		CONFIRMED UPPER LIMITS	TOTAL E. COLI	TOTAL BACTERIAL COUNT	REMARKS
CIVIC CENTRE	12/02/86	N.I.	0	0	-	-	No	Satisfactory
RIDGEWAY (OUTSIDE TAP)	12/02/86	3	0.5	9	+	2		Unsatisfactory
RIDGEWAY (INSIDE TAP)	12/02/86	18+	5	55	+	2		Unsatisfactory Gross pollution
NORTHEAD PRIMARY SCHOOL	12/02/86	N.I.	0	0	-	0		Satisfactory
WATERCLO POLICE STATION	12/02/86	0	0	0	-	0		
LUMUMBA PARK RESERVOIR	12/02/86	N.I.	0	0	-	0		
CHAMAKA RESERVE/TCS	12/02/86	0	0	0	-	0		

BACTERIOLOGICAL ANALYSIS

S O U R C E	DATE SAMPLED	COLIFORM ORGANISM / 100ML	99% CONFIDENCE LIMIT		CONFIRMED E. COLI	TOTAL BACTERIAL COUNT	REMARKS
			LOWER LIMITS	UPPER LIMITS			
CIVIC CENTRE	25/02/86	0	-	-	-	ND	Satisfactory
WATER DISTRIBUTION	"	0	-	-	-	ND	Satisfactory
STUART PARK	"	0	-	-	-	ND	Satisfactory
KELINGKING	"	184	5	55	-	ND	Insatisfactory
CHESTER	"	3	2.5	9	-	ND	Insatisfactory
LAWANG KEDUA	"	6	1	15	+	ND	Insatisfactory
CHAMINA	"	9	2	21	-	ND	Unsatisfactory
CHATILIE	"	0	-	-	-	ND	Satisfactory

BACTERIOLOGICAL ANALYSIS

S O U R C E	DATE SAMPLED	C O L I F O R M O R G A N I S M / 100ML	95% CONFIDENCE LIMIT		C O N F I R M E D E. C O L I	T O T A L B A C T E R I A L C O U N T	R E M A R K S
			L O W E R L I M I T S	U P P E R L I M I T S			
CIVIC CENTRE	6/03/86	0	-	-	-	ND	Satisfactory
DISTRIBUTION	"	0	-	-	-	ND	Satisfactory
COLONIAL	"	16	4	40	4	ND	Unsatisfactory
KALINGALINGA	"	18+	5	55	4	ND	Unsatisfactory
CHALATION	"	16	6	40	+	ND	Unsatisfactory
DRUGS	"	5	1	13	-	ND	Unsatisfactory
MATERIO POLICE STATION	"	3	< 0.5	9	-	ND	Unsatisfactory
TRANSA PROD.	"	0	-	-	-	ND	Satisfactory
CHAVARA	"	4	-	-	-	ND	Unsatisfactory
CHI-NASA SUPPLY STATION	7/2/86	3	< 0.5	9	-	ND	Unsatisfactory

Appendix 8 Hydraulic Calculation of Kafue Treatment Plant

Hydraulic analysis is carried out in order to check whether 110,000 m³/day of water can flow through the existing water treatment plant without any hydraulic problem. Results of the analysis presented in Table 8.2 and Fig. 8.1 show a satisfactory allowance of water table (1.8 ft.) in the receiving well and that of some 7 ft. for the filter run.

Table 8.2. Results of Hydraulic Analysis in the Plant

Items	Water Level in Original Work (feet)	Water Level, etc. at the Flow of 110,000cmd		Allowance (feet)	Remarks
		Head Loss (feet)	Water Level (feet)		
Clear Water Reservoir	3,298.8	---	3,298.8	0.0	
Connecting Pipe (Clear Water Reservoir and Filter)		4.07	---	---	
Outlet of Filter	3,303.0	---	3,302.9	0.1	$3298.9 + 4.07 = 3302.9$
Filter		6.77	---	---	Head loss due to filtration is 5.8 feet
Inlet of Filter	3,309.67	---	3,309.67	---	
Connecting Conduit (Filter and Sedimentation Basin)		0.23	---	---	
Sedimentation Basin	3,312.0	---	3,310.2	1.8	
Connecting Conduit (Sedimentation Basin and Receiving Well)	0.22	---	---	---	
Receiving Well	3,314.5	---	3,312.22	2.3	




図 8.1 カフエ系水位高低図(本計画)
Fig 8.1 Water Table of Kafue System
(This Project)

(1) Loss between Clear Water Reservoir and Outlet of Filter $H = h_1 + h_2 + h_3 + h_4$

$\phi 900 \text{ mm}$, $L = 460 \text{ ft.} = 140 \text{ m}$

$$Q = 110,000 \text{ m}^3/\text{day} = 1.2731 \text{ m}^3/\text{sec}$$

$$V = Q/A = 1.2731 / \frac{\pi}{4} (0.9)^2 = 2.0 \text{ m/sec}$$

$$\textcircled{1} \quad \text{Inlet } h_1 = f_e \frac{V^2}{2g} = 0.5 \times \frac{(2.0)^2}{2 \times 9.8} = 0.10 \text{ (m)}$$

$$\textcircled{2} \quad \text{Outlet } h_2 = f_o \frac{V^2}{2g} = 1.0 \times \frac{(2.0)^2}{2 \times 9.8} = 0.20 \text{ (m)}$$

$$\textcircled{3} \quad \text{Bend } h_3 = f_{b1} f_{b2} \frac{V^2}{2g}$$

$45^\circ \sim 2 \text{ Nos.}$ $90^\circ \sim 2 \text{ Nos.}$ $f_{b1} f_{b2} : 45^\circ \text{ bend } 0.15, 90^\circ \text{ bend } 0.20$

$$h_3 = (0.15 \times 2 + 0.20 \times 2) \frac{(2.0)^2}{2 \times 9.8} = 0.14 \text{ (m)}$$

$$\textcircled{4} \quad \text{Friction } h_4 = 10.294 n^2 D^{16/3} Q^2 L \quad (\text{Manning Formula})$$

$$n = 0.014 \quad D = 0.9 \quad Q = 1.2731 \quad L = 140 \text{ m}$$

$$h_4 = 0.80 \text{ m}$$

$\textcircled{5} \quad \text{Total}$

$$\begin{aligned} H &= 0.10 + 0.20 + 0.14 + 0.80 \\ &= 1.24 \text{ m} \\ &= 4.07 \text{ ft.} \end{aligned}$$

(2) Loss in the Filter

$$H_2 = h_1 + h_2 + h_3 + h_4 + h_5 + h_6$$

$$Q = 110,000 \text{m}^3/\text{day} \div 20 \text{ filter} = 5,500 \text{m}^3/\text{day} = 0.0637 \text{ m}^3/\text{sec/filter}$$

① Inlet (h_1)

$$V = 0.0637 \div 0.14 = 0.455 \text{ m/sec}$$

$$h_1 = (0.5 + 1.0) \frac{(0.455)^2}{2g} = 0.02 \text{m}$$

Where, 0.5:Inlet, 1.0:Outlet

② Sand (h_2)

Loss in clear sand (Fair-Hatch formula)

$$h_2' = 0.178 L \cdot \frac{v}{g} \cdot \frac{\alpha}{\beta} \cdot \frac{1}{\xi^4} \cdot \frac{24 \mu}{\rho} \cdot \sum \frac{P_1}{D_1^2}$$

L : Thickness 0.6m v : velocity m/sec, α/β : coefficient 5.5

ξ : Porous ratio 0.35 μ : Viscosity $10^{-3} \text{kg/m} \cdot \text{sec}$

ρ : Specific gravity 10^3 kg/m^3 D_1 : Diameter m

P_1 : Ratio of D_1

$$\text{Where } \sum \frac{P_1}{D_1^2} = 1.5 \times 10^6$$

$$h_2' = 0.178 \times 0.6 \times \frac{120}{86,400} \times \frac{1}{9.8} \times 5.5 \times \frac{1}{0.35^4} \times \frac{24 \times 10^{-3}}{10^3} \times 1.5 \times 10^6 \\ = 0.2 \text{m}$$

Allowance of 1.56m is assumed.

$$h_2 = 0.2 + 1.56 = 1.76 \text{m}$$

③ Gravel (h_3) $h_3 = 0.1 \text{m}$

$$④ \text{Collection } (h_4) \quad h_4 = \frac{1}{2g} \cdot \frac{100}{0.6} \times \frac{120}{86,400}^2 = 0.003 \text{m}$$

$$\textcircled{5} \text{ Outlet } (h_5) \phi 375, V = 0.0637 / (0.375^2 \frac{\pi}{4}) = 0.577 \text{ m/sec}$$

$$h_5 = (0.5 + 1.0) \times \frac{(0.577)^2}{2g} = 0.03 \text{ m}$$

Where 0.5: Inlet, 1.0: Outlet

\textcircled{6} Loss of venturi, valve etc.

$$h_6 = 0.14 \text{ m}$$

\textcircled{7} Total

$$\begin{aligned} H_2 &= 0.02 + 1.76 + 0.1 + 0.01 + 0.03 + 0.14 \\ &= 2.06 \text{ m} \\ &= 6.77 \text{ ft.} \end{aligned}$$

(3) Loss between filter and sedimentation basin

Open channel (Width 3ft. = 0.91m, Depth 2.17ft. = 0.66m, L = 490ft. = 150m)

$$\begin{aligned} H_3 &= (N^2 \times V^2 \times L) \div (R^{4/3}) \\ &= (0.015^2 \times 0.71^2 \times 150) \div (0.337^{4/3}) \\ &= 0.07 \text{ m} \\ &= 0.23 \text{ ft.} \end{aligned}$$

Where,

N : Roughness (concrete 0.015)

V : Velocity $(1.2731 \div 3) \div (0.66 \times 0.91) = 0.71$

R : Hydraulic radius $(A/S = 0.66 \times 0.91 \div (0.66 \times 2 + 0.91) = 0.337)$

S : Wetted perimeter $(= 0.66 \times 2 + 0.91 = 1.78)$

A : Sectional area $(= 0.66 \times 0.91 = 0.60)$

(4) Loss between sedimentation basin and receiving well

Open channel (Width 3ft. = 0.91m, Depth 2.17ft. = 0.66m, L = 330ft. = 100m)

$$\begin{aligned} H_4 &= (N^2 \times V^2 \times L) \div (R^{4/3}) \\ &= (0.015^2 \times 0.71^2 \times 100) \div (0.337^{4/3}) \\ &= 0.068 \text{ m} \\ &= 0.22 \text{ ft.} \end{aligned}$$

Appendix - 9 Calculation for Drain Trough of Filter

(1) Depth of Trough

$$H = \frac{Q^{2/3}}{1.838B}$$
$$= \frac{0.52}{1.838 \times 4.5 \times 5 \times 2}$$
$$= 0.034 \text{ m}$$

Where,

$$Q : \text{Rate of discharge } 47.25 \text{ m}^2 \times 0.66 \text{ m/min}$$
$$= 31.185 \text{ m}^3/\text{min}$$
$$= 0.52 \text{ m}^3/\text{sec}$$

$$B : \text{Length of trough} : 4.5 \text{ m} \times 5 \text{ Nos./filter} \times 2$$

$$H : H (\text{m})$$

(2) Dimension of Trough

Section of Trough W 0.35 × D 0.4

Number of Trough 5 Nos./filter

Rate of discharge per trough

$$Q_0 = \frac{0.52}{5} = 0.104 \text{ m}^3/\text{sec}$$

Critical depth h_{co}

$$h_{co} = \left(\frac{\alpha Q_0^2}{g B^2} \right)^{1/3}$$

$$\alpha = 1.1$$

$$Q_0 = 0.104 \text{ m}^3/\text{sec}$$

$$B = 0.35 \text{ m}$$

$$h_{co} = \left(\frac{1.1 \times (0.104)^2}{9.8 \times (0.365)^2} \right)^{1/3}$$

$$= 0.215 \text{ m}$$

When discharge is free, depth in the upstream is,

$$h_o = \sqrt{3} h_{co}$$

$$h_o = \sqrt{3} \times 0.215$$

$$= 0.372 \text{ m} < 0.40 \text{ m}$$

Then, trough section of 350 W × 400 H is OK.

APPENDIX 10 CALCULATION FOR SPECIFICATION OF TRANSFER PUMP

The specification of transfer pump shall be determined by using the loss coefficient of existing pipeline.

1. Loss coefficient of existing pipeline

Loss coefficient of existing pipeline calculated by using Hazen-Williams Formula and existing pipeline profile drawing is shown in clause a.

In Table a., loss coefficient C value will be 120-125. Hazen-Williams Formula is defined as follows:

$$C = \{10.66 \times l \div hf \div d^{4.87}\}^{1/05} \times Q$$

where l = pipe length in m

hf = friction loss in m


d = pipe inner diameter

Q = Capacity in m³/sec


a. Data for Calculation

- i) Hydraulic gradient of existing pipeline (from pipeline profile)
 (Delivered capacity is assumed as $Q = 16,680 \text{ IGP}M = 109,208 \text{ m}^3/\text{day}$).

No.1 PS ~ No.2 PS



No.2 PS ~ Terminal Reservoir



ii) Loss coefficient of existing pipeline

No.1 P.S ~ No.2 P.S

$$\begin{aligned}
 Q &= 16,680 \text{ GPM} \\
 &= 16,680 \times 0.0045465/60 \text{ m}^3/\text{sec} \\
 &= 1.2640 \text{ m}^3/\text{sec}
 \end{aligned}$$

Block	l	hf	d	c
1	1,584.96	(18.21) 5.547	0.908	124
2	982.68	(11.21) 3.414	1.0636	82
3	540.99	(63.21) 1.890	0.908	124
4	4,524.76	(52.0) 15.850	0.9112	123
5	9,220.20	(104.71) 31.913	0.9144	122
6	6,656.83	(77.41) 23.592	0.9176	120

No.2 P.S ~ Terminal Reservoir

$$Q = 1.2640 \text{ m}^3/\text{s}$$

Block	T	hf	d	c
3	1,313.7	(15.051)	4.587	0.9112
4	3,197.4	(36.751)	11.201	0.9144
5	14,508.5	(168.21)	51.267	0.9176

2. Loss coefficient to be used and pipeline head loss

According to, loss coefficient C value can be 130 for straight pipe not including elbow etc. and can be 110 for pipe including elbow loss.

However, in consideration of calculated C value for existing pipeline, the C value to be used in this design shall be 120.

Pipeline head loss is calculated by the following Hazen-Williams Formula and calculated data is shown in Table 2-1.

$$H_f = 10.666 \times (Q - PH) \times C^{1.85} \times (l + d^{4.87}) \times 1$$

As results, each pipeline head loss for both No. 1 and No. 2,

No. 1 High-light pump

$H_f = 84.81\text{m}$

No. 2 High-light pump

$H_f = 84.17\text{m}$

Table 2.1 Calculated data of pipeline head loss ($C = 120$)

$$Q = 76.5 \text{ m}^3/\text{min} = 1.275 \text{ m}^3/\text{sec}$$

Block	No.1 P.S ~ No.2 P.S			No.2 P.S ~ Terminal Reservoir		
	d	e	hf	d	e	hf
1	0.908	1,584.96	6.037	0.908	2,013.7	7.671
2	1.0636	982.68	1.732	0.9112	1,950.7	7.304
3	0.908	540.99	2.061	0.9112	1,313.7	4.919
4	0.9112	4,524.76	16.943	0.9144	3,197.4	11.769
5	0.9144	9,220.2	33.940	0.9176	14,508.5	52.506
6	0.9176	6,656.83	24.091	0.9176	24.4	0.027
Total	$H_f = \Sigma hf = 84.805$			$H_f = \Sigma hf = 84.169$		

3. Total head of pump

Total head for both No. 1 and No. 2 high lift pump are accumulated as follows:

	No. 1 High Lift Pump	No. 2 High Lift Pump
Water Level		
Condition		
Suction water level	3,298.8'	3,789'
Discharge water level	3,789'	4,298.2'
Static head	149.5m (490.5 feet)	155.2m (509.2m)
Pipeline head loss	84.81	84.17
Station head loss	2.0m	2.0m
Total head	236.3m	241.37m

Though, as shown above, each total head for No. 1 and No. 2 high lift pump has 5m difference, both total head shall be determined 242m as same in consideration of the convenience to be changeable each other between No. 1 and No. 2 pumping station.

4. Motor output

$$\text{Motor output} = (0.163 \times 25.5\text{m}^3/\text{min} \times 242\text{m} \times 1.15) - \text{PH: 0.86}$$
$$= 1,345 \doteq 1,350\text{kW}$$

where Q = Discharge capacity: $22.5\text{m}^3/\text{min}$

H = Total head: 242m

= Pump efficiency: 86%

APPENDIX 11 WATER HAMMER ANALYSIS

The water hammer analysis in case of being tripped main pump was carried out to operate and maintain safety after rehabilitaton of No. 1 and No. 2 High Lift Pumping Station.

1. Boundary condition

	Unit	No. 1 Pumps	No. 2 Pumps
<u>Pump</u>			
Nos. installed		4	4
Nos. Operated		3	3
Discharge Capacity m^3/min	22.5		22.5
Total Head	m	242	242
Rotating Speed	rpm	1,490	1,490
Pump Efficiency	%	86	86
GD 2	$Kg.m^2$	160	160
<u>Motor</u>			
Output	kW	1,350	1,350
Type		Squirrel cage	squirrel cage
Voltage	V	3,000	3,000
Frequency	Hz	50	50
No. of Poles	P	4	4
GD 2	$Kg.m^2$	57	57
<u>Non-return valve</u>			
Nominal dia	$mm\phi$	450	450
Type	Rapid Closure Type	Rapid closure type	
<u>Pipeline</u>			
Material		Steel	Steel
Loss Coefficient	C = 120		C = 120
K/E Value	0.01		0.2
	(K: Volume modulus of water ... $2.07 \times 10^10 kg/m^2$)		(E: Young modulus for pipe material ... $2.1 \times 10^10 kg/m^2$)
Other condition	Refer to	Table 11.1 11.2 11.3	Table 11.4 11.5 11.6
Conditions at operating			
Discharge Capacity	$76.5 m^3/min$ $= 1.275 m^3/s$		$76.5 m^3/min$ $= 1.275 m^3/s$
Suction water level	m	1005.47	1154.88
Discharge water level	m	1154.89	1310.09
Static head	m	149.42	155.21
Pipeline head loss	m	84.8	84.26
Station Head loss	m	7.81	2.53

2. Specification for Water Hammer Protection Devices

By-pass pipeline	Kafue	Chilanga
Initial water level m	1005.47	1154.88
Diameter of assumed tank m	30	30
Diameter of by-pass pipe m	450	450
Loss coefficient to flow out $m/(m^3/s)$	6,526	6,526
Flywheel GD 2 Kg.m ²	1,0000	1,000
Type	Coupling type	Coupling type
Air Valve Type	5" inlet and outlet type	
Set level	Shown in Table 11-1	Shown in Table 11-4
Nos.	Ditto	Ditto
Loss coefficient to flow in $m/(3s)^2$	130 (assumed)	130 (assumed)
Loss coefficient to flow out $m/(3s)^2$	6.4 (assumed)	6.4 (assumed)
One-way surge vessel Location point (Distance from pumping station) (Km)	Chilanga No. 1 12.0112	Chilanga No. 2 13.5352
Location level (ground level) (m)	1293.98	1304.4
Initial water level (m)	1295.86	1306.86
Size (m)	3 x 3.5 x 3m	7 x 7 x 4m
Nozzle diameter (m)	250	400
Loss coefficient to flow out (mm)	88.9	14.53

Table 11.1 (1)

表 11.1 (1)

(Kafue)

NODE	Chainage (10^3 ft.)	Chainage (m)	Trench Invent Level(ft)	Trench Invent Level(m)
1	0	0	3289.5	1002.6
2	10	304.8	3225.5	992.3
3	44	1341.12	3257.18	992.79
4	52	1585	3254.5	992
5	74+24	2262.8	3290.0	1002.79
6	83+24	2537.2	3320.0	1011.94
7	84+24	2568	3320.3	1012
8	92+24	2811.5	3336.62	1017.00
9	101+33.9 , 0+65	3108.6	3378.0	1029.614
10	101+33.9 , 4+70	3232.07	3397.89	1035.677
11	101+33.9 , 30	4003.2	3356	1022.909
12	101+33.9 , 42	4369	3362	1024.738
13	101+33.9 , 45	4460.5	3370	1027.176
14	101+33.9 , 48	4551.9	3374	1028.395
15	101+33.9 , 55+28	4773.7	3372	1027.786
16	101+33.9 , 67	5131.0	3372	1027.786
17	101+33.9 , 86	5710.1	3382	1030.834
18	101+33.9 , 102	6197.8	3458	1053.998
19	101+33.9 , 120	6746.4	3417.07	1041.523
20	101+33.9 , 140	7356.0	3498.81	1066.468
21	101+33.9 , 149+10	7633.38	3464.70	1056.04
22	101+33.9 , 163	8057.05	3494.50	1065.124
23	101+33.9 , 176	8453.3	3451.45	1052.002

Table 11.1 (2)
表 11.1 (2)

NODE	Chainage (10^3 ft)	Chainage (m)	Trench Invent Level(ft)	Trench Invent level (m)
24	101+33.9, 194	9001.8	3510	1069.848
25	218	9733.5	3526.84	1074.981
26	240	10404	3545.33	1080.617
27	258	10952.7	3561.83	1085.646
28	270	11318.4	3551.08	1082.369
29	292	11989	3497.20	1065.947
30	314+97.4	12689.2	3510.85	1070.107
31	332	13208.2	3486.43	1062.664
32	346	13634.9	3506.48	1068.775
33	374	14488.3	3531.54	1076.413
34	402	15341.8	3532	1076.554
35	417	15799	3555.13	1083.604
36	446	16682.9	3566.55	1087.084
37	451+60	16853.58	3564.42	1086.435
38	503+50	18435.5	3610.00	1100.328
39	533	19334.7	3602.03	1097.899
40	557	20066.2	3620.28	1103.461
41	584	20889.1	3676.04	1120.457
42	594	21194	3697.98	1127.144
43	606	21560	3681.12	1122.005
44	624	22108.5	3710.86	1131.07
45	643	22687.5	3721.00	1134.161
46	658	23144.7	3733.83	1138.071
47	670	23510.42	3784.45	1153.5

Table 11.2

表 11.2

(Kafue)

Pipe No.	Node No.	Diameter di (mm)	Thickness t (mm)	a (m/s)	Length l (m)	Head loss(m)
1	1 → 2	908.05	12.7	1088.1	304.8	1.16
2	2 → 3	"	"	"	1036.32	3.95
3	3 → 4	"	"	"	243.88	0.93
4	4 → 5	1063.63	14.3	1079.1	677.8	1.19
5	5 → 6	"	"	"	274.4	0.54
5	6 → 7	"	"	"	30.8	0
6	7 → 8	908.05	12.7	1088.1	243.5	0.93
7	8 → 9	"	"	"	297.1	1.13
8	9 → 10	911.23	11.11	1056.2	123.47	0.46
9	10 → 11	"	"	"	771.13	2.88
10	11 → 12	"	"	"	365.8	1.37
11	12 → 13	"	"	"	91.5	0.34
12	13 → 14	"	"	"	91.4	0.34
13	14 → 15	"	"	"	221.8	0.83
14	15 → 16	"	"	"	357.3	1.33
15	16 → 17	"	"	"	579.1	2.19
15	17 → 18	"	"	"	487.7	1.82
16	18 → 19	"	"	"	548.6	2.05
17	19 → 20	"	"	"	609.6	2.28
18	20 → 21	"	"	"	277.38	1.04
19	21 → 22	914.40	9.53	1018.0	423.67	1.56
20	22 → 23	"	"	"	396.25	1.45
21	23 → 24	"	"	"	548.60	2.02
22	24 → 25	"	"	"	731.6	2.69

Table 11.3

表 11.3

No.	Pipe Node	di (mm)	t (mm)	a (m/s)	l (m)	loss(m)	備考
23	25 → 26	914.40	9.53	1018.0	670.5	2.47	
24	26 → 27	↓	↓	↓	548.7	2.02	
25	27 → 28	↓	↓	↓	365.7	1.35	
26	28 → 29	↓	↓	↓	670.6	2.47	29をなしとする
26	29 → 30	↓	↓	↓	700.2	2.57	29をなしとする
27	30 → 31	↓	↓	↓	519.0	1.91	
28	31 → 32	↓	↓	↓	426.7	1.57	
29	32 → 33	↓	↓	↓	853.4	3.15	
30	33 → 34	↓	↓	↓	853.5	3.15	
31	34 → 35	↓	↓	↓	457.2	1.68	35をなしとする
31	35 → 36	↓	↓	↓	883.9	3.25	35をなしとする
32	36 → 37	↓	↓	↓	170.68	0.63	
33	37 → 38	917.6	7.94	970.6	581.92	5.73	
34	38 → 39	↓	↓	↓	899.2	3.26	
35	39 → 40	↓	↓	↓	731.5	2.65	
36	40 → 41	↓	↓	↓	822.9	2.98	41をなしとする
36	41 → 42	↓	↓	↓	304.9	1.10	41をなしとする
37	42 → 43	↓	↓	↓	366.0	1.32	
38	43 → 44	↓	↓	↓	548.5	1.98	
39	44 → 45	↓	↓	↓	579.0	2.10	45をなしとする
39	45 → 46	↓	↓	↓	457.2	1.65	45をなしとする
40	46 → 47	↓	↓	↓	365.72	1.32	

Table 11.4 (1)

表 11.4 (1)

NODE	Chainage (10^3 ft)	Chainage (m)	Trench Invent Level(ft)	Trench Invent level (m)
1	672-206.9	0	3776.42	1151.05
2	678	245.9	3805	1159.76
3	698	855.5	3785.28	1153.75
4	704	1038.38	3769.56	1148.96
5	718	1465.1	3794.36	1156.52
6	736	2013.7	3880.5	1182.776
7	752	2501.4	3876	1181.405
8	766	2928.1	3904	1189.9
9	777	3263.4	3955	1205.48
10	800	3964.46	3979.60	1212.98
11	803+50	4071.1	3983.50	1214.171
12	820	4574.1	3921.58	1195.3
13	829+40	4860.6	3947.85	1203.305
14	843+10	5278.15	3989.50	1216.00
15	846+60	5384.8	4039.00	1231.087
16	858	5732.3	4023.72	1226.43
17	870	6098.1	4036.62	1230.362
18	877+50	6326.7	4075.50	1242.212
19	904/1	7134.4	4078.0	1242.974
20	914/1	7339.2	4138	1261.3
21	916/1	7500.1	4139	1261.567
22	926/1	7804.9	4096	1248.461
23	934/1	8048.8	4106	1251.509

Table 11.4 (2)

表 11.4 (2)

NODE	Chainage (10^3 ft)	Chainage (m)	Trench Invent Level(ft)	Trench Invent level (m)
24	948/1	8475.5	4127.0	1257.91
25	976/1	9328.9	4151.0	1265.225
26	996/1	9938.5	4164	1269.187
27	1024/1	10792.0	4190	1277.112
28	1040/1	11279.7	4208	1282.598
29	1064/1	12011.2	4238	1291.742
30	1086/1	12681.7	4248	1294.79
31	1106/1	13291.3	4265	1299.972
32	1114/1	13535.2	4272	1302.106
33	1168	15181.1	4234.71	1290.740
34	1192	15912.6	4218.68	1285.853
35	1194	15973.6	4217.34	1285.4
36	1218	16705.1	4218.82	1285.896
37	1244	17497.6	4212.11	1283.851
38	1280	18594.9	4212.89	1284.089
39	1306	19387.3	4209.61	1283.089
40	1328	20057.9	4213	1284.122
41	1348	20667.5	4207.25	1282.37
42	1366	21216.1	4213	1284.122
43	1390	21947.7	4227	1288.39
44	1400	22252.5	4244	1293.6
45	1410	22557.3	4273	1302.4
46	1420	22862.1	4280	1304.5
47	1424+80.1	23008.4	4280	1304.5

Table 11.5

表 11.5

(Chilanga)

No.	Pipe Node	d_i (mm)	t (mm)	a (m/s)	l (m)	Loss (m)
1	1 → 2	908.05	12.7	1088.1	245.9	0.94
2	2 → 3	"	"	"	609.6	2.32
3	3 → 4	"	"	"	182.88	
3	4 → 5	"	"	"	426.72	2.32
4	5 → 6	"	"	"	548.6	2.09
5	6 → 7	911.23	11.12	1056.2	487.7	1.83
6	7 → 8	"	"	"	426.7	
6	8 → 9	"	"	"	335.3	2.85
7	9 → 10	"	"	"	701.06	
7	10 → 11	"	"	"	106.64	3.03
8	11 → 12	"	"	"	503	
8	12 → 13	"	"	"	286.5	2.95
9	13 → 14	"	"	"	417.55	1.56
10	14 → 15	914.40	9.53	1018.0	106.65	0.39
11	15 → 16	"	"	"	347.5	1.27
12	16 → 17	"	"	"	365.8	1.35
13	17 → 18	"	"	"	228.6	0.84
14	18 → 19	"	"	"	807.7	2.99
15	19 → 20	"	"	"	204.8	
15	20 → 21	"	"	"	160.9	1.35
16	21 → 22	"	"	"	304.8	1.12
17	22 → 23	"	"	"	243.9	0.89
18	23 → 24	"	"	"	426.7	1.57
19	24 → 25	917.6	7.94	970.6	853.4	3.09

Table 11.6

表 11.6

(Chilanga)

No.	Pipe Node	d _i (mm)	t (mm)	a (m/s)	l (m)	loss(m)	備 考
20	25 → 26	917.6	7.94	970.6	609.6	2.21	
21	26 → 27	"	"	"	853.5	3.09	
22	27 → 28	"	"	"	487.7	1.76	
23	28 → 29	"	"	"	731.5	2.65	
24	29 → 30	"	"	"	670.5	2.42	
25	30 → 31	"	"	"	609.6	2.21	
26	31 → 32	"	"	"	243.9	0.88	
27	32 → 33	"	"	"	1645.9	5.98	
28	33 → 34	"	"	"	731.5	2.64	
29	34 → 35	"	"	"	61.0	2.86	
29	35 → 36	"	"	"	731.5		
30	36 → 37	"	"	"	792.5	2.86	
31	37 → 38	"	"	"	1097.3	3.98	
32	38 → 39	"	"	"	792.4	2.86	
33	39 → 40	"	"	"	670.6	2.43	
34	40 → 41	"	"	"	609.6	2.21	
35	41 → 42	"	"	"	548.6	1.98	
36	42 → 43	"	"	"	731.6	2.64	
37	43 → 44	"	"	"	304.8	3.85	
37	44 → 45	"	"	"	304.8		
37	45 → 46	"	"	"	304.8		
37	46 → 47	"	"	"	146.3		

3. Result and Recommendation
The result and recommended protection devices are shown below:

No. 1 P.S (Kafue) - No.2 P.S (Chilanga)				
C a s e	1	2	3	4
Countermulture				
Existing bypass-pipe				
Water level 1,005.47	0	0	0	0
pipe Q450				
Existing				
Air valve				
5 double orifice				
type air valve				
Fly wheel	0	0	0	0
				$GD2=5,000 \text{kg-m}^2$
Air chamber				
		0	Volume=30m ³	
			Nos. 2 Nos.	
One-way surge tank				
Result	Negative pressure is exceeded 10m in whole pipeline	Negative pressure is exceeded 10m in whole pipeline and mass of flywheel is too big to manufacture	Negative pressure is not exceeded 6m, However, it is very difficult to keep the space to install the air chamber facilities and to maintain easily	Negative pressure is not exceeded 7m. This method is recommended under the condition that good maintenance for air valve shall be carried out.
				Not recommendable.
				Not Acceptable.


(Refer to Fig. 11.1)


No.2 P.S (Chilanga) - Terminal Reservoir (Lusaka)

Case	1	2	3	4	5	6
Countermeasure						
Existing Bypass-pipe Water level 1,154.88 pipe Ø450	0	0	0	0	0	0
Existing Air Valve 5 double orifice type air valve	0	0	0	0	0	0
	0	0	0	0	0	0
	It is assumed that the air valve at 13.5 Km from pumping station is only available					
Fly Wheel	GD2=5,000 Kgm ²	GD2=1,000 Kgm ²	GD2=1,000 Kgm ²	GD2=1,000 Kgm ²	GD2=1,000 Kgm ²	GD2=1,000 Kgm ²
Air Chamber	0	Volume 30m ³ Nos. 3NOS				
One-Way Surge Tank						


C a s e	1	2	3	4	5	6
Countermeasure						
Result	Negative pressure is exceeded 10m in whole pipeline.	Negative pressure is not exceed 10m in the pipe-line between 5~22km distance from pumping station.	Negative pressure is exceeded 10m however, it is very difficult to keep the space to install the air chamber facilities.	Negative pressure is exceeded 10m at the point of 13KM from pumping station.	Negative pressure is not exceeded 10m at the point of 13KM from pumping station.	Negative pressure is not exceeded 7m at the point of 13KM from pumping station.
	Negative pressure is exceeded 10m in whole pipeline.	Negative pressure is exceeded 10m however, it is very difficult to keep the space to install the air chamber facilities.	Negative pressure is exceeded 10m at the point of 13KM from pumping station.	Negative pressure is not exceeded 10m at the point of 13KM from pumping station.	Negative pressure is not exceeded 10m at the point of 13KM from pumping station.	Negative pressure is not exceeded 7m at the point of 13KM from pumping station.
	Not Acceptable.	Not Acceptable.	Not Acceptable.	Not Acceptable.	Not Acceptable.	Acceptable.


(Refer to Fig. 11.2)





WATER HAMMER ANALYSIS (NO. 2 P/S → Terminal Reservoir)





APPENDIX 12 DETERMINATION OF DISCHARGE VALVE DIAMETER

(1) Selection diameter by maximum flow velocity through discharge valve.

Generally, maximum flow velocity through discharge valve will be below 6m/sec.

Maximum capacity for one unit is 31.0m/min in the case of 2 pumps operating and discharge valve 100% opening condition as shown in pump characteristic curve. At the above condition, minimum diameter of discharge valve will be as below

$$(\pi/4) d^2 \times v \times 60 = Q$$
$$d = \{ (4 \times Q) / (\pi \times v \times 60) \}^{1/2}$$

$$= 0.331\text{mm.}$$


d mm	350	400	450
v m/s	5.37	4.11	3.25

On the other hand, as maximum flow velocity through non-return valve being installed between pump and discharge cone valve should be below 4m/sec, the diameter of non-return valve is selected 450mm dia. The diameter of cone valve is selected 400mm dia. in consideration of the space for installation.

(2) Selection diameter by pump operating range

In this clause, C value is used both 120 and 130 (C ≠ 30 is the worst case).

Discharge capacity in case of 2 pumps operation condition and C = 130 will be $69\text{m}^3/\text{min}/2\text{ unit}$, $34.5\text{m}^3/\text{min}/\text{one unit}$. But at this operating point pump can not be operated continuously because of the valve of NPSH required. Maximum capacity shall be limited $31.0\text{m}^3/\text{min}$.



Valve opening ratio to control the discharge capacity to $31\text{m}^3/\text{min}$ and the safety against cavitation at this capacity are confirmed as follows:

	$C = 120$	$C = 130$
Discharge Capacity for one unit	25.5	31.0
Loss head	82.6	61.3
Pressure at primary side	242	225
Pressure at secondary side	$149.5 + 9.9 = 159.4$	$149.5 + 14.2 = 163.7$
Valve opening ratio	27	35
Cavitation coefficient	2.05	2.83
Critical cavitation coefficient	1.05	1.2
Result (KAV > Kreg)	Safety	Safety

(NOTES) In Fig.12-1, the relation between C_v and valve opening ratio, and the relationship between valve opening ratio and cavitation coefficient are shown.

In Fig.12-2 the system curve to show pump operating point is shown.





Fig. 12 - 1




Fig. 12.-2

Appendix 13 Calculation of 33/3.3kV Power Transformer Capacity

1. Conditions of Calculation

1) 2 bank system

1..... normally use

1..... stand-by

2) Main loads are following:

- a. High lift pumps $1,350\text{kW} \times 4$ sets (1 set stand-by)
Motor characteraristic

Efficiency at full load 95%

Power factor at full load 95%

Starting power factor 0.3

Starting current 6 times of full load current.

- b. 300kVA auxiliary transformer 2 sets

- c. Intake pumps $315\text{kW} \times 4$ sets

Motor characteraristic

Efficiency at full load 93%

Power factor at full load 86%

3) Starting system for high lift pump is reactor (65% Top)

2. Calculation

Total capacity: T (kVA)

$$= [1,350/(0.95 \times 0.95)] \times 3 + 300 \times 2 + [315/(0.93 \times 0.86)] \times 4 \\ = 6,663$$

Expecting 10% allowance

$$T = 6,663 \times 1.1 = 7,329 \text{ (kVA)}$$

i.e., transformer capacity shall be 7,500 (kVA)

3. Examination for Voltage Drop

Voltage drop (E) at the secondary terminal of the transformer shown following calculation formula

$$E = 1/T [R (Sbcos \theta_b + Smcos \theta_m) + (Sbsin \theta_b + Smsin \theta_m)]$$

E: voltage drop rate (%)

T: transformer capacity

R: percent resistance of transformer

X: percent reactance of transformer

S_b: basic load capacity

S_m: starting capacity

cos θ_b: basic load power factor

cos θ_m: starting load power factor

1) percent impedance of the transformer 7.5%

percent resistance R: 1.47

percent reactance X: 7.35

2) basic load capacity S_b and starting capacity S_m

$$S_b = [1,350 / (0.95 \times 0.95)] \times 2$$

$$+ [315 / (0.93 \times 0.86)] \times 4$$

$$= 5.147 [\text{KVA}]$$

$$S_m = 1,350 / (0.95 \times 0.95) \times 6 \times 0.65$$

$$= 5.834 [\text{KVA}]$$

3) basic load power factor cos b = 0.8, cos m = 0.3 × 0.65

$$= 0.195$$

voltage drop rate E is as follows:


$$E = 1/7,500 [1.47 (5.167 \times 0.8 - 5.834 \times 0.195)$$

$$+ 7.35 (5.167 \times 0.6 - 5.834 \times 0.98)]$$

$$= 9.67 [\%]$$

starting voltage drop of less than 10% is OK.

Therefore, transformer of 7.5 MVA is used.



JICA