

KINGDOM OF THAILAND

**MASTER PLAN STUDY REPORT
ON
NAM YUAM RIVER BASIN
HYDROELECTRIC DEVELOPMENT
PROJECT**

KINGDOM OF THAILAND
MASTER PLAN REPORT ON NAM YUAM RIVER BASIN
HYDROELECTRIC DEVELOPMENT PROJECT

MARCH 1987

MAR 87

JICA

MPN



JAPAN INTERNATIONAL CORPORATION AGENCY

122

64.3

MPN

LIBRARY

M P N
C R (3)
87 - 28

KINGDOM OF THAILAND

**MASTER PLAN STUDY REPORT
ON
NAM YUAM RIVER BASIN
HYDROELECTRIC DEVELOPMENT
PROJECT**

JICA LIBRARY



1000813[8]

16578

MARCH 1987

JAPAN INTERNATIONAL CORPORATION AGENCY

国際協力事業団		
入 目 日	'87. 6. 22	122
登 録 No.	16578	643
		MPN

PREFACE


In response to the request of the Government of the Kingdom of Thailand, the Japanese Government has decided to conduct a Master Plan survey on the Nam Yuam River Basin Hydroelectric Development Project and entrusted the survey to the Japan International Cooperation Agency. JICA sent to Thailand a survey team headed by Mr. Yasuo Takashima, Electric Power Development Co., Ltd., four times from July, 1985 to December, 1986.

The team had discussions with the officials concerned of the Government of Thailand and conducted a field survey in the Nam Yuam basin in Northern Thailand. After the team returned to Japan, further studies were made and the present report has been prepared.

I hope that this report will serve for the development of the Project and contribute to the promotion of friendly relations between our two countries.

I wish to express my deep appreciation to the officials concerned of the Government of the Kingdom of Thailand for their close cooperation extended to the team.

March, 1987

A handwritten signature in black ink, reading "Keisuke Arita", is written over a horizontal line.

KEISUKE ARITA


President

Japan International Cooperation Agency



Nam Mae Ngao Dam Site

**View from upstream
(End of rainy season)**



Nam Mae Rit Dam Site

**View from down stream
(End of rainy season)**






Upper Yuam 1 Dam Site

**View from down stream
(End of rainy season)**



Upper Yuam 2 Dam Site

**View from up stream
(End of rainy season)**



CONTENTS

	Page
Conclusion and Recommendation	- 1 -
CHAPTER 1. INTRODUCTION	
1.1 Outline of the Project Area	1-1
1.2 Background of the Project	1-2
1.3 Outline of the Project	1-3
1.4 Contents of the Investigation Works	1-4
1.5 Acknowledgement	1-7
CHAPTER 2. LOAD FORECAST	
2.1 Load Forecast Review for Whole EGAT System	2-1
2.2 Load Forecast Review for Whole PEA's Service Area	2-2
2.3 Load Forecast for Northern Region	2-2
2.4 Main Power Supply Area of Nam Yuam Hydroelectric Projects	2-5
2.5 Daily Load Factor	2-16
2.6 Standard Deviation of Load Duration Curve	2-42
2.7 Estimation of Daily Load Duration Curve	2-51
2.8 Integrated Load Function	2-57
2.9 Daily Plant Factor	2-64
CHAPTER 3. GEOLOGY	
3.1 Introduciton	3-1
3.2 Geological Investigation Works	3-2
3.3 Topography and Geology of Project Area	3-6
3.4 Site Geology	3-8
3.5 Construction Materials	3-28

CHAPTER 4. METEOROLOGY AND HYDROLOGY

4.1 Meteorological Outline in the Project Area	4-1
4.2 Gaging Stations and Weather Observatory Station in the Yuam River Basin	4-2
4.3 Meteorology	4-3
4.4 Runoff Discharge	4-6
4.5 Sedimentation	4-15
4.6 Flood Analysis	4-16

CHAPTER 5. DEVELOPMENT PLAN

5.1 Basic Items	5-1
5.2 Procedure for Study of Development Plan	5-3
5.3 Individual Development Plan (First Stage Study)	5-5
5.4 Selected Main Projects (Second Stage Study)	5-26
5.5 Additional Study	5-46
5.6 Incremental Benefit of the Lower Yuam Project	5-53

CHAPTER 6. PRELIMINARY DESIGN

6.1 Civil Main Structure	6-1
6.2 Electrical Equipment	6-4

CHAPTER 7. POWER TRANSMISSION LINE SYSTEM PLAN

7.1 Outline of Thailand Power System	7-1
7.2 Outline of Power Transmission Line System Plan	7-4
7.3 Economic Comparison of Power Transmission Scheme	7-8
7.4 Power System Analysis	7-8
7.5 Preliminary Design of Transmission Line	7-10
7.6 Additional Study	7-12

CHAPTER 8. CONSTRUCTION PLANNING AND COST ESTIMATION

8.1 Construction Planning	8-1
8.2 Construction Cost and Financial Program	8-10

CHAPTER 9. ECONOMIC EVALUATION

9.1 Basic Concept and Methodology adopted in the Study	9-1
9.2 Alternative Thermal Power Plants	9-16
9.3 Benefits of the Hydro Power Projects	9-28
9.4 Costs of the Hydro Power Projects	9-36
9.5 B - C and B/C	9-37
9.6 Equalizing Discount Rate (EDR)	9-39
9.7 Sensitivity Analysis	9-42

CHAPTER 10. IMPACT ON IRRIGATION PROJECTS

10.1 Purpose of Field Investigation	10-1
10.2 Result of Field Investigation	10-2
10.3 RID Nam Yuam Irrigation Project (existing)	10-2
10.4 Incremental Benefit	10-3

CHAPTER 11. ENVIRONMENTAL PROBLEM

11.1 Environmental Background	11-1
11.2 Environmental Implication	11-4

CONCLUSION AND RECOMMENDATION

CONCLUSION AND RECOMMENDATION

(1) Conclusion

The total installed capacity of electric power generating plants in Thailand is about 6,500 MW as of 1985. The annual increasing rates of the energy demands for the next 10 years are estimated to be 6% for the whole EGAT system and 10% for the Northern Region where the proposed projects are situated.

According to the load forecast, made by "the Load Forecast Working Group in Thailand", the peak power generation in 2000 will be 10,154 MW and the energy generation in the same year will reach 62,780 GWH in the EGAT whole system.

Further, EGAT forecast that the power and energy demand of Northern Region of Thailand in 1994 will reach 855 MW and 3,700 GWH level respectively. Extrapolating on the basis of these forecasts, the JIGA team estimated that the power and energy demands of the region in 2000 would be grown up to 1,220 MW and 5,500 GWH respectively.

The present master plan study is concerned with the study on the hydroelectric power development plan in the Nam Yuam River Basin. (the Yuam River, the Ngao River and the Rit River).

Among nine projects preset by EGAT, four projects; Upper Mae Yuam 1, Nam Mae Rit, Upper Mae Rit 2a and Nam Mae Ngao were firstly ranked higher than others through the first stage study. The ensuing detailed stages of the study have revealed that Nam Mae Ngao No.2 Project was the most promising project from both technical and economical view points.

According to the final result, the installed capacity and the annual energy generation of Nam Mae Ngao No.2 Project are 120 MW and 250 GWH respectively.

This project has many prominent features that the runoff quantity of the Ngao River is plentiful (specific runoff 50 lit/sec/km² of this river is a rare value observable in rivers in Thailand), that the peak power supply capacity can be obtained without construction of a

downstream equalization pondage, that the access road to the project site is already completed and that there are no significant environmental nor submergence problems foreseen in the project area. These considerations lead to the conclusion that the construction of this project can be started immediately after the usual steps will be taken properly.

Therefore, it is an urgent need to proceed into the feasibility study with a provision that the high water level, tail water level, maximum turbine discharge, installed capacity, etc. should be re-examined in more detail.

Since the remaining three projects have less economic feasibility judging from the present study result, it is expected that these projects will be implemented in future when the economic circumstances will be improved.

(2) Recommendation

It is concluded that the feasibility study should be started as early as possible. In order to conform with this conclusion, the following works are recommended to be performed continuously.

- 1) Detailed survey of the Nam Mae Ngao Project area, in particular, levelling survey between Nam Mae Ngao Project and Lower Yuam Project.
- 2) Hydrological observation and/or data collection
 - (a) for gaging stations at Ban Mae Ngao, Ban Mae Suat and Ban Wang Khan (EGAT)
 - (b) for gaging stations at Ban Tha Rua and Sop Han (NEA)
 - (c) for irrigation water-take and spilled water over the weir of the Mae Sariang irrigation facility (RID)
- 3) Geological test boring

The location and quantities of the bore holes are shown on Fig. 3-5 and Table 3-2.

CHAPTER 1. INTRODUCTION

CHAPTER 1 INTRODUCTION

CONTENTS

	Page
1.1 Outline of the Project Area	1 – 1
1.2 Background of the Project	1 – 2
1.3 Outline of the Project	1 – 3
1.4 Contents of the Investigation Works	1 – 4
1.5 Acknowledgement	1 – 7

CHAPTER 1. INTRODUCTION

1.1 Outline of the Project Area

The Yuam river is a tributary of the Moei river which forms the boundary between Thailand and Burma. After merging the Yuam river, the Moei river joins with the Salawin river which rises from Tibet, flows down through Burma and finally drains into the Andaman Sea.

The Yuam river basin, therefore, is located in the northwestern corner of Thailand, and ranges over approximately 60 km in the east and west and 160 km in the north and south directions, having the catchment area of slightly more than 6,000 square kilometers.

Mountains of 1,000 m high class lie in a row in the north and south direction of the Yuam river basin, forming the topographic feature of a long basin. The center town is Mae Sariang (about 20,000 of population) belonging to the district of Changwat Mae Hong Son. The Yuam river originates at the northern end of the basin, flows south and merges the Rit river at the point of about 35 km south to Mae Sariang. After merging the Rit river, the Yuam river flows down south more 5 km to a confluence point of the Ngao river which is also a tributary but running up from the opposite direction, south to north. The Yuam river then turns the flows to west almost in right angle and joins with the Moei river near Hoi Varieu, a downstream hamlet of the Lower Yuam project site.

The national highway No. 108 connecting Changwat Chiang Mai and Amphoe Mae Sariang runs the east foot of Mt. Doi Inthanon (2,595 m high), which is the highest in Thailand, passes Amphoe Chom Thong, goes over the plateau in the east side of the Yuam river basin along the Chaem river, a tributary of the Ping river. The total distance between Changwat Chiang Mai and Amphoe Mae Sariang is approximately 200 km.

The midstream area of the basin is well developed in various irrigation facilities. Particularly, intake facilities have been constructed by the Royal Irrigation Department (RID) across the main river at the point about 13 km upstream of Amphoe Mae Sariang and a main irrigation canal, which has the capacity of about 3 m³/sec, runs down on the right-bank tableland.

1.2 Background of the Project

Thailand's economic growth rate in 1970's marked at 7.4%, following Hong Kong, South Korea, Taiwan, Singapore, etc., being prominent in the Asian developing nations. Particularly, the growth of its industrial sector was significant, doubling the share in the whole economy compared with that in 1960's.

The installed capacity of electric power generating facilities of EGAT is 6,460 MW and the generated energy is 23,357 GWh in 1985. Composition of power source consists of 1,814 MW in hydro plant (28.1%) and 4,646 MW in thermal plant (71.9%).

Electricity demand increasing rates in the future, according to estimation by the "Load Forecast Working Group for Power Tariff Sub-committee", will reduce gradually from the estimated annual rate of 14% in 1983, to 6.5% in 1991, and afterwards it will continue almost constantly at the annual rate of 6%.

The electricity demand in 1991 is estimated to be 6,199 MW of power and 37,349 GWh of energy being about double of 3,204 MW and 19,066 GWh of those in 1983. Even after 1991, an annual increase of demand is considered to be 400 MW to 500 MW and 2,400 GWh to 3,200 GWh respectively.

The oil fired power generation shares large portion of the current electricity generation.

It is, therefore, significant for economic stability of the country to develop oil substitutive projects by utilizing indigeneous energy sources such as natural gas, lignite, hydropower etc., suppressing the increase of oil importation as much as possible under the government policy.

The main hydroelectric power resources development in Thailand has been carried out in large-scale projects such as Bhumibol (420 MW) on the Ping river, Sirikit (375 MW) on the Nam river, Srinagarind (360 MW) on the Quae Yai river and Khao Laem (300 MW) on the Quae Noi river. At present Chiew Larn (240 MW) is almost completed, and moreover Nam Chon (580 MW) which is planned in the upstream of

Srinagarind Dam is awaiting for the commencement of construction. As a result of these developments, it may be that the remaining possible large-scale hydroelectric power resources are limited mainly in the basin of the international rivers such as the Mae Khong river and the Salawin river, existing along the boundary. However, the Mae Khong river projects include internationally-complicated factors, so that it is very hard to imagine that the development will be realized in the near future. Under such circumstances, keen attention has been focussed recently to the Salawin river basin especially to the Yuam river basin, a tributary of the Salawin river and the investigation works necessary for the development has been carried out in these years.

Standing on the abovementioned background, the Master Plan has been projected by EGAT to formulate the Yuam river basin hydroelectric development as a whole thereby taking into consideration of the Lower Yuam project which has already been studied by NEA under the cooperation of JICA.

1.3 Outline of the Project

The study on the development plan was proceeded in two stages and an additional stage.

At the first stage, 9 sites for the master plan study were selected and the first field investigation and desk study on the basis of topographical maps of 1:50,000 were carried out. As the result of the first stage study, the 4 sites, Nam Mae Ngao, Nam Mae Rit, Upper Mae Rit 2a and Upper Mae Yuam 1, were found to be of high priority from economical point of view.

The second stage included the second field investigation for the 4 sites and the detailed study. Nam Mae Ngao site turned out to be of the highest priority.

The outline of the 9 sites is presented as follows.

Project Name	Dam Height (m)	HWL (m)	Total Storage (MCM)	Installed Capacity (MW)	Annual Energy Production (GWh)
Upper Mae Yuam 1	62	325	421.4	18.5	54.5
Upper Mae Yuam 2	65	380	178	11.4	37.0
Upper Mae Yuam 3	62	477	67.6	4.1	13.0
Nam Mae Rit	87	270	85.7	24.0	61.5
Upper Mae Rit 1	66	407	19.4	10.3	42.5
Upper Mae Rit 2					
Original	63	585	13.5	6.1	28.0
Alternative A	38	560	3.2	11.2	43.6
Upper Mae Rit 3	64	490	15.8	10.4	42.7
Nam Mae Ngao	114	260	661.2	116.9	245.2
Upper Mae Ngao	80	340	43.2	9.1	33.2

1.4 Contents of the Investigation Works

The investigation works consisted of the three sectors; the engineering sector to judge the technical feasibility, the economic sector to evaluate the project economy and the irrigation sector to define the effects on the existing agriculture in the project area.

The following items were the subjects to be investigated for the Master Plan Study.

- (1) Civil engineering investigations (topography, geology, hydrology and meteorology, site survey of main structures and construction materials, cost for similar projects, etc.)
- (2) Electric power investigations (electric power demand, power system planning, transmission line, etc.)
- (3) Irrigation investigation (irrigation facilities, irrigated agriculture, etc.)

- (4) Other investigations (environment, transportation facilities, etc.)
- (5) Data collection (including population, GDP, price index, tariff rates, etc.)

The Field Investigation Works of JICA Survey Team have been carried out four times for the above five items.

The outline of the individual field works were as follows.

(a) First Field Investigation Work

First Field Investigation works were carried out from July 8, 1985 to August 6, 1985.

During the field survey, JICA Survey Team held discussion with EGAT's engineers concerned for the implementation plan of the field investigations and the studies, based on "the Inception Report" submitted by JICA Survey Team.

The results of the discussion are concluded in "the Minutes of Meeting on Discussion of First Reconnaissance (July 1985)".

Further, the reconnaissance survey for the project sites including the three main projects; Nam Mae Ngao, Nam Mae Rit and Upper Mae Yuam 1, was carried out by EGAT engineers and the Team.

The participants of the both parties are listed in the participants list 1.

(b) Second Field Investigation Work

Second Field Investigation Works were carried out from October 28, 1985 to December 26, 1985 (one geologist stayed in the field up to January 10, 1986).

During JICA Survey Team staying in Thailand, the team presented "the Interim Report" including the Supplementary Report dated November 1985, and held discussion on the report.

The results of the discussion were concluded in "the Second Minutes of Meeting for the Master Plan on the Nam Yuam River

Basin Hydroelectric Development Project, December 1985".

Following items were the remarkable points in the second field investigation works.

- 1) The projects to be studied on the second stage were selected as follows;

Nam Mae Ngao

Upper Mae Rit 2a

Nam Mae Rit

Upper Mae Yuam 1 (See the attached Table 5-14-2)

- 2) The locations, work quantities and specifications of the drilling and material investigation at the projects site have been decided.

Some of the investigation works were being executed at the site.

- 3) The boring accessories supplied by JICA were handed over to EGAT as shown in the list.

In addition to the above, EGAT engineers and the team conducted the site survey including the Lower Yuam Site studied already by JICA as the related project to the Master Plan.

The participants of the second field investigation works are listed in the participants list 2.

(c) Third Field Investigation Work

The third field investigation works were carried out by JICA Survey Team from 26th of June to 8th of July, 1986.

During the team staying in Thailand, the team presented and held discussion on the second stage study results and carried out the field survey works for the selected and related projects (Lower Yuam project) with EGAT's engineers.

The study results were generally accepted by EGAT and concluded in the third minutes of meeting. The details of the conclusion

are described in "the third minutes of meeting, July 1986". The participants in the field are listed in the participant list 3.

Meanwhile, in the field investigation works, topographical mapping, drilling work with permeability test for geological survey and laboratory test of soil material for the selected sites were performed by EGAT.

As for the environmental impact coming up from the implementation of these projects, the study has been performed and reported by EGAT to the Master Plan Study.

Therefore, it should be noted that the environmental study described in the Chapter 11 "Environmental Problem" are the summary of the study for which the permission by EGAT to compile in this report has been given and which the team has considered to be appropriate.

(d) Fourth Field Investigation Work

Fourth field investigation works were carried out by JICA survey team from 6th of December to 20th of December 1986. During the team staying in Thailand, the team presented and held discussion on the final draft of the mater plan study. The study results were fundamentally accepted by EGAT and concluded in "the fourth minutes of meeting, 19th of December, 1986. The participants are listed in the participant list 4.

1.5 Acknowledgement

The team wishes to express his sincere appreciation and thanks to EGAT and many other Thai officials concerned for their faithful and warm cooperation in conducting this study.

Participants List 1 (First Investigation)

EGAT

<u>Name</u>		<u>Position</u>
1. Mr. Sommart	Boonpiraks	Director, Project Planning and Investigation Department
2. Mr. Payak	Ratnarathorn	Chief, Water Resources Planning and Development Division
3. Mr. Prasit	Srisaichua	Assistant Chief, Water Resources Planning and Development Division (Team Leader)
4. Mr. Niwat	Patanasemakul	Head, Water Resources Development Section (Civil Engineer)
5. Mr. Peerawat	Pumthong	Engineer Class 1 (Water Resources Engineer)
6. Mr. Peradeth	Nidhinandana	Geologist Class 2 (Coordinator)
7. Mr. Chutha	Promchinavongs	Engineer Class 1 (Hydrologist)
8. Mr. Piyachat	Nithipaibool	Engineer Class 1 (Soil Engineer)
9. Mr. Punpong	Vivattananon	Geologist Class 1 (Geologist)
10. Mr. Amphon	Sutthibutra	Chief, Survey Division
11. Mr. Somchai	Kokkemhaeng	Head, Material Testing Section
12. Mr. Junichi	Tani	Expert of JICA

JICA Survey Team

1. Mr. Yasuo	Takashima	Leader
2. Mr. Tetsuo	Nishigori	Assistant Leader
3. Mr. Yoshihiro	Nakazawa	Civil Engineer (Planning)
4. Mr. Senzo	Hakoshima	Civil Engineer (Cost Estimation)
5. Mr. Junya	Takimoto	Hydrologist
6. Mr. Kazuhisa	Takeda	Geologist
7. Mr. Makoto	Tanaka	Economist

Participants List 2 (Second field investigation)

EGAT

1. Mr. Sommart	Boonpiraks	Director, Hydro-Power Engineering Department
2. Mr. Wuthi	Poonudom	Assistant Director, Hydro-Power Engineering Department
3. Mr. Payak	Ratnarathorn	Chief, Water Resources Planning and Development Division
4. Mr. Prasit	Srisaichua	Assistant Chief, - ditto -
5. Mr. Niwat	Patanasemakul	Head, Water Resources Development Section
6. Mr. Songpan	Panvanich	Engineer
7. Mr. Peerawat	Pumthong	Engineer
8. Mr. Chamnan	Tanakorn	Assistant Chief, Survey Division
9. Mrs. Supawan	Klaipongpan	Head, Geology Section
10. Mr. Punpong	Vivatlananon	Geologist
11. Mr. Nopporn	Prapaitrakul	Head, Dam and Foundation Section
12. Mr. Nipon	Pienpucta	Head, Powerhouse and Structure Section
13. Mr. Manop	Manawatana	Head, Site Engineer
14. Mr. Chutha	Promchinavongs	Engineer
15. Mrs. Siriluck	Srivichit	Scientist
16. Dr. Virawan	Sombutsiri	Assistant Head, Environmental Evaluation Section
17. Mr. Prakob	Dhienhirunya	Assistant Chief, Power System Planning Division
18. Mr. Thawat	Pinta	Assistant Head, Transmission System Planning Section
19. Mr. Wiboon	Pongtepupathun	Engineer
20. Miss/Sarinthip		Engineer
21. Mr. Junichi	Tani	JICA expert

JICA

1. Mr. Yasuo	Takashima	Leader, JICA Survey Team
2. Mr. Tetsuo	Nishigori	Assistant Leader
3. Mr. Akiyoshi	Noda	Irrigation Engineer
4. Mr. Yoshihiro	Nakazawa	Civil Engineer
5. Mr. Koichi	Tanaka	Civil Engineer
6. Mr. Hiromichi	Somukawa	Geologist
7. Mr. Seiji	Oda	System Engineer

Participants List 3 (Third field investigation)

EGAT

1. Mr. Sommart	Boonpiraks	Director, Hydro-Power Engineering Department
2. Mr. Wuthi	Poonudom	Assistant Director, Hydro-Power Engineering Department
3. Mr. Payak	Ratnarathorn	Chief, Water Resources Planning and Development Division
4. Mr. Prasit	Srisaichua	Assistant Chief, Water Resources Planning and Development Division
5. Mr. Niwat	Patanasemakul	Head, Water Resources Development Section
6. Mr. Chokchai	Watcharasansap	Assistant Head, Water Resources Development section
7. Mr. Peerawat	Pumthong	Engineer
8. Mr. Peeradej	Nidhinandana	Geologist
9. Mr. Piew	chitrakorn	Geologist
10. Mr. Punpong	Vivatlananon	Geologist
11. Mr. Manop	Manawatana	Head, Site Engineer
12. Mr. Kittti	Naparaksvong	Chief, Meteorological and Hydrological Division
13. Mr. Chutha	Promchinavongs	Hydrologist
14. Mr. Junichi	Tani	JICA Expert

JICA

- | | | |
|----------------|-----------|--------------------------|
| 1. Mr. Yasuo | Takashima | Leader, JICA Survey Team |
| 2. Mr. Tetsuo | Nishigori | Assistant Leader |
| 3. Mr. Haruo | Suzuki | JICA Official |
| 4. Mr. Kiyoshi | Ishikawa | Geologist |

Participants List 4 (Fourth field investigation)

EGAT

- | | | |
|-------------------|---------------|--|
| 1. Mr. Swarng | Champa | Assistant General Manager-Hydro Power Development |
| 2. Mr. Sommart | Boonpiraks | Director, Hydro-Power Engineering Department |
| 3. Mr. Wuthi | Poonudom | Assistant Director, Hydro-Power Engineering Department |
| 4. Mr. Payak | Ratnarathorn | Chief, Water Resources Planning and Development Division |
| 5. Mr. Prasit | Srisaichua | Assistant Chief, Water Resources Planning and Development Division |
| 6. Mr. Niwat | Patanasemakul | Head, Water Resources Development Section |
| 7. Mr. Peerawat | Pumthong | Engineer Class 2 |
| 8. Mr. Peradeth | Nidhinandana | Geologist Class 2 |
| 9. Mr. Chamnan | Tanakorn | Assistant Chief, Survey Division |
| 10. Mr. Thongjier | Thong-Aun | Head, Applied Hydrology and Research Section |
| 11. Mrs. Supwawan | Klaipongpan | Assistant Chief, Geology and Soil Engineering Division |
| 12. Mr. Piew | Chittrakarn | Geologist |
| 13. Mr. Somchai | Kokkemhaeng | Head, Material Testing Section |
| 14. Mr. Piyachat | Nithipaibool | Engineer Class 1 |
| 15. Mr. Saman | Pongprapapan | Engineer Class 5 |

- | | | |
|-------------------|--------------------|---|
| 16. Dr. Virawan | Sombutsiri | Assistant Head, Environmental
Evaluation Section |
| 17. Mrs. Siriluck | Srivichit | Scientist Class 1 |
| 18. Miss Sopa | Wongratanakornkrai | Engineer Class 1 |
| 19. Mrs. Kanya | Suntharak | Publication Relation Officer |
| 20. Mr. Junichi | Tani | JICA Expert |

JICA

- | | | |
|------------------|-----------|-------------------|
| 1. Mr. Yasuo | Takashima | Leader, JICA Team |
| 2. Mr. Tetsuo | Nishigori | Assistant Leader |
| 3. Mr. Yoshihiro | Nakazawa | Civil Engineer |
| 4. Mr. Koichi | Anada | JICA Official |

Boring Accessories

<u>Description</u>	<u>Quantity</u>
1. Triple Core Barrel, 3 m (NMLC Size) Set O.D. of Bit 75.3 mm Set I.D. of Bit 51.9 mm Set Reaming Shell O.C. of Bit 75.7 mm	3 sets
2. Triple Core Barrel, 1.5 m (NMLC Size) The same as the above	3 sets
3. Diamond Core Bit, 20 cts. Size 1/25 - 1/40 Hard Matrix Grade AAA Semi round Crown Design	36 pieces
4. Reaming Shell, 10 cts. Size 1/15 - 1/20 Grade AA Ring set type	9 pieces
5. Diamond Casing Shoe Bit, 16 cts. Size 1/15 - 1/20 NW. Grade AA, Hard Matrix	9 pieces
6. Metal Casing Shoe Bit NW. Tungsten	18 pieces
7. Water Swivel Roller bearing type with drillrod adaptor NW, Heavy Duty	3 pieces
8. Core Spring (Locating Washer) Spare part	24 pieces
9. Core Lifter Case Spare part	24 pieces
10. NW. Casing 3 m	20 pieces
11. NW. Casing 1.5 m	20 pieces
12. NW. Rod 3 m	50 pieces
13. NW. Rod 1.5 m	10 pieces

CHAPTER 2. LOAD FORECAST

CHAPTER 2 LOAD FORECAST

CONTENTS

	Page
2.1 Load Forecast Review for Whole EGAT System	2 – 1
2.2 Load Forecast Review for Whole PEA's Service Area	2 – 2
2.3 Load Forecast for Northern Region	2 – 2
2.4 Main Power Supply Area of Nam Yuam Hydroelectric Projects	2 – 5
2.5 Daily Load Factors	2 – 16
2.6 Standard Deviation of Load Duration Curve	2 – 42
2.7 Estimation of Daily Load Duration Curve	2 – 51
2.8 Integrated Load Function	2 – 57
2.9 Daily Plant Factor	2 – 64

Table List

		Page
Table 2-1	EGAT Total Generation Requirement	2-7
Table 2-2	PEA's Demand	2-8
Table 2-3	Region 4 Generation Requirement (EGAT)	2-9
Table 2-4	Load Forecast (1995-2020), Northern Region Scenario 1	2-10
Table 2-5	Load Forecast (1995-2020), Northern Region Scenario 2	2-11
Table 2-6	Regression of Annual Load Factors of Northern Region on Years	2-12
Table 2-7	Relation between Annual and Daily Load Factors EGAT Whole System .. (1970-1985)	2-18
Table 2-8	Annual Power Demand and Annual Load Factors of Northern Region .. (EGAT-R4)	2-19
Table 2-9	Demand of Northern Region (EGAT-R4) Coincident to Peak Load	2-21
	and Daily Load Factors	
Table 2-10	Daily Load Factors of Northern Region	2-22
Table 2-11	Maximum Demand of System, Coincident to Peak Load in EGAT	2-47
	Whole Supply Area	
Table 2-12	Maximum Demand of System Coincident to Peak Load in Northern	2-48
	Region (EGAT-R4)	
Table 2-13	Parameters of Daily Load Duration Curves Northern Region	2-50
Table 2-14	Estimated Load Duration Curves of Northern Region	2-56
Table 2-15	Integrated Load Function of Northern Region	2-58

Figure List

		Page
Fig. 2-1	Annual Load Factor	2-13
Fig. 2-2	Load Forecast, Northern Region	2-14
Fig. 2-3	Annual Load Factors, Actual and Estimated for Northern Region	2-15
Fig. 2-4	Daily Load Factor vs. Annual Load Factor, Whole EGAT and Northern Region	2-23
Fig. 2-5	Hourly Load Curve and Load Duration Curve	2-24
	EGAT (whole) 24 Sep., 1975	
Fig. 2-6	Hourly Load Curve and Load Duration Curve	2-25
	EGAT (whole) 21 Sep., 1976	
Fig. 2-7	Hourly Load Curve and Load Duration Curve	2-26
	EGAT (whole) 9 Jun., 1977	
Fig. 2-8	Hourly Load Curve and Load Duration Curve	2-27
	EGAT (whole) 6 Sep., 1978	
Fig. 2-9	Hourly Load Curve and Load Duration Curve	2-28
	EGAT (whole) 23 Aug., 1979	
Fig. 2-10	Hourly Load Curve and Load Duration Curve	2-29
	EGAT (whole) 28 Mar., 1980	
Fig. 2-11	Hourly Load Curve and Load Duration Curve	2-30
	EGAT (whole) 29 Sep., 1981	
Fig. 2-12	Hourly Load Curve and Load Duration Curve	2-31
	EGAT (whole) 20 Sep., 1982	
Fig. 2-13	Hourly Load Curve and Load Duration Curve	2-32
	EGAT (whole) 19 May, 1983	
Fig. 2-14	Hourly Load Curve and Load Duration Curve	2-33
	EGAT (whole) 28 May, 1984	
Fig. 2-15	Hourly Load Curve and Load Duration Curve	2-34
	EGAT (whole) 29 Mar., 1985	
Fig. 2-16	Hourly Load Curve and Load Duration Curve	2-35
	Northern Region (EGAT-R4) 1979	
Fig. 2-17	Hourly Load Curve and Load Duration Curve	2-36
	Northern Region (EGAT-R4) 1980	
Fig. 2-18	Hourly Load Curve and Load Duration Curve	2-37
	Northern Region (EGAT-R4) 1982	
Fig. 2-19	Hourly Load Curve and Load Duration Curve	2-38
	Northern Region (EGAT-R4) 1983	
Fig. 2-20	Hourly Load Curve and Load Duration Curve	2-39
	Northern Region (EGAT-R4) 1984	

Fig. 2-21	Hourly Load Curve and Load Duration Curve	2-40
	Northern Region (EGAT-R4) 1985	
Fig. 2-22	Load Curve of Peak Demand Days in Northern Region (EGAT-R4)	2-41
Fig. 2-23	Deviation of Load Duration Curve from Expected Line P-Q	2-46
Fig. 2-24	Standard Deviation of Hourly Loads vs Daily Load Factor	2-49
Fig. 2-25	Evaluation of Load Duration Curve	2-52
Fig. 2-26	Load Duration Curve Northern Region 1995	2-53
Fig. 2-27	Load Duration Curve Northern Region 2000	2-53
Fig. 2-28	Load Duration Curve Northern Region 2005	2-54
Fig. 2-29	Load Duration Curve Northern Region 2010	2-54
Fig. 2-30	Load Duration Curve Northern Region 2015	2-55
Fig. 2-31	Load Duration Curve Northern Region 2020	2-55
Fig. 2-32	Integrated Load Function of Peak Demand Day Northern Region 1995 ..	2-61
Fig. 2-33	Integrated Load Function of Peak Demand Day Northern Region 2000 ..	2-61
Fig. 2-34	Integrated Load Function of Peak Demand Day Northern Region 2005 ..	2-62
Fig. 2-35	Integrated Load Function of Peak Demand Day Northern Region 2010 ..	2-62
Fig. 2-36	Integrated Load Function of Peak Demand Day Northern Region 2015 ..	2-63
Fig. 2-37	Integrated Load Function of Peak Demand Day Northern Region 2020 ..	2-63

CHAPTER 2. LOAD FORECAST

2.1 Load Forecast Review for Whole EGAT System

Electric power demand in the EGAT system has been increased at a surprising rate during the past 15 years. A peak power generation at 743 MW in 1970 has grown up to 3878 MW (5.2 times) in 1985 and an annual energy generation increased from 4095 GWh to 23357 GWh (5.7 times) during the same period. (see Table 2-1)

The average annual growth rate of the peak power and energy generation are therefore 11.6% and 12.3% respectively. Considering the fact that during this period the oil crises hit the world twice and the economic activities in many other countries in the world had been stagnated quite a long time, these growth rates are very dominant and reflect the viability of Thailand's economy.

Based on these actual growth records, the load forecast for the next 16 years (1986 - 2001) has been made by the Load Forecast Working Group in Thailand. (Table 2-1) According to this forecast the peak power generation in 2001 will be 10154 MW (i.e. 2.6 times that of 1985) and energy generation in the same year will reach 62780 GWh (i.e. 2.7 times that of 1985). The average growth rates correspond to 6.2% and 6.4% respectively. Although decreased a little, these growth rates imply that the economic activities in this country for the next 16 years will still go up as vigorously as it has been.

The annual load factor of the whole EGAT system was 62.47% in 1970. It rose up to 70.69% in 1979 and after that stays within a 67% - 71% band width. (see Table 2-1 & Fig. 2-1)

These show that a pattern of power consumption in this country, especially in the greater Bangkok area is approaching to that of a developed country.

However as the country as a whole, a potential power demand seems still great. The load factor for the next 16 years will not be improved so much. This is reflected in the load forecast that the factor will remain at around 67 - 71% level increasing slightly from 68.75% in 1985 to 70.58% in 2001. (see Table 2-1 & Fig. 2-1)

2.2 Load Forecast Review for Whole PEA's Service Area

PEA (Provincial Electricity Authority) supplies electric power to the whole country except Greater Bangkok area. The growth rate of PEA is much more than that of EGAT whole system. A power demand of 318 MW in 1973 was boosted to 1684 MW in 1984. (Table 2-2) This is in fact 5.1 times that of 1973 or an average 16.0% annual growth rate during these 11 years. The annual load factors also come up from 54.81% in 1973 to 55.25% in 1984.

In the past, many non-electrified rural areas were existed in Thailand, and only for very limited areas were supplied power by isolated diesel power plants.

From the mid 70's, EGAT and PEA poured an especial effort to expand the power supply capabilities and to eliminate the non-electrified areas. As the results, almost 80% of the non-electrified villages had then been energized up to 1984.

The expansion program also included those areas which are nearer and surrounding the main demand centers as well as powering up the demand centers themselves.

All of these efforts have resulted in the miraculous growth rate as above described.

Standing on these achievements, the working group forecasts power demands for next 10 years (1985 - 1994) as shown in Table 2-2. The power and energy demand in 1994 will be 4123 MW and 21876 GWh or 2.4 times and 2.7 times those of 1984 respectively. The corresponding average growth rates are 9.3% and 10.3% annually. (See Fig. 2-1) Annual load factors will also go up from 55.25% in 1984 to 60.57% in 1994 which is a faster improvement than that of the whole EGAT system.

2.3 Load Forecast for Northern Region

According to the PEA's classification, Northern Region consists of 3 sub-regions, i.e. Northern Region I, Northern Region II and Northern Region III.

This area is almost the same region which is classified as Region 4 according to the EGAT definition, consisting of 16 provinces in the north and the northern part of the central areas.

The main load centers in the Northern Region are Chiang Mai, Nakhon Sawan, Chiang Rai, Phitsanulok, Phrae, etc. of which the biggest one is Chiang Mai, the second largest city in Thailand.

Since the Nam Yuam hydro power projects situate within this region, it is of especial necessity to study the power demand in the region. Actual records and forecast values by EGAT are shown in Table 2-3 and Fig. 2-2.

According to these information, power and energy demands in the Northern Region have soared up from 68.66 MW and 282.92 GWh in 1972 to 335.62 MW and 1350.04 GWh in 1984 or 4.9 times and 4.8 times respectively. These correspond to an average annual growth rates of 14.1% and 13.9% respectively which are almost comparable with PEA's whole service area as described in the foregoing section.

The annual load factor was fluctuated from 47.03% in 1972 to 45.93% in 1984. (Table 2-3 and Fig. 2-1)

Note that the absolute values themselves of these factors are still pretty lower than those of PEA's whole service area.

As for the forecast, the power and energy demands will grown up to the levels of 855 MW and 3700 GWh in 1994 respectively or the expected average annual growth rates of 9.8% and 10.6% for the following 10 years. (1984 - 1994).

At the same time, annual load factor will be raised from 45.93% in 1984 to 49.41% in 1994.

But the growth rates for both power and energy will gradually slow down to around 7% in 1994 and the annual load factor approaches 50%.

So far as we have reviewed, the forecast up to 1994 have been confirmed to be reasonable.

Now therefore basing upon these forecasts, we will extend them further by the simple extrapolation method which will be highly supported by judgement.

We will consider two scenarios, scenario 1 and scenario 2, differing one another in terms of the annual growth rates of energy demands as follows:

(i)	Scenario 1	
	from 1995 to 1999,	7%
	from 2000 to 2004,	6%
	from 2005 to 2010,	5%
	from 2011 to 2020,	4%

(ii)	Scenario 2	
	from 1995 to 1999,	6%
	from 2000 to 2004,	5%
	from 2005 to 2010,	4%
	from 2011 to 2020,	3%

The results of forecasts are shown in Table 2-4 and Table 2-5 and are plotted on Fig. 2-2.

Next step to be taken is to forecast the annual load factors. As we have already seen in the previous sections, it is a definite tendency that the annual load factors are improved if a system grows up and also the character of the demand become matured. (i.e. the pattern of power consumption approaches towards that of a developed country).

On Fig. 2-3, the recorded annual load factors and those estimated by the Working Group (taken from Table 2-2 and Table 2-3) are plotted.

A regression line,

$$Y = b_0 + b_1X \dots\dots\dots (1)$$

Where

- Y: annual load factor (%)
- X: fiscal year
- b_0, b_1 : parameters

was assumed and the values of b_0 and b_1 ,

$$b_0 = -531.638 \text{ and } b_1 = 0.291544$$

were obtained by using the least square method. (see Table 2-6)

The correlation coefficient obtained was 0.902.

Now by employing this regression line, the future values of annual load factors of Northern Region are estimated by substituting the annual energy demands in Table 2-4 and Table 2-5 into X.

The results are shown on the same tables and plotted on Fig. 2-2 too.

According to this estimation, the annual load factors of the Northern Region will be 50% in 1995, 51.5% in 2000, 52.9% in 2005 and 54.4% in 2010, and 57.3% in 2020 in case of scenario 1.

The estimation of peak demand in the Northern Region is now possible by using the formula

$$\text{Peak demand} = \frac{\text{Annual energy demand}}{\text{Annual load factor} \times 8760} \dots\dots\dots (2)$$

Substituting the already obtained values of annual energy demands and annual load factors (in Table 2-4 and Table 2-5) into (2), Peak demands in the Northern Region were calculated as shown in Table 2-4 and Table 2-5 and plotted on Fig. 2-2.

According to these results, the power demands of the Northern Region will be 904 MW in 1995, 1221 MW in 2000, 1573 MW in 2005, 1935 MW in 2010 and 2719 MW in 2020 in case of scenario 1.

2.4 Main Power Supply Area of Nam Yuam Hydroelectric Projects

The proposed installed capacities of Nam Yuam hydropower plants, Nam Mae Ngao, Nam Mae Rit, Upper Mae Yuam, etc. will range from about 10 MW to 120 MW as will be studied in later chapters.

It is tentatively assumed that the first target year is 2000 and that at least two of the Nam Yuam hydroelectric projects will have been operated.

As we have studied in the previous sections, power demands in 2000 will be 9680 MW in the whole EGAT system and 1,220.5 MW in the Northern Region. (See Table 2-1 & Table 2-4)

Thus the proposed installed capacities of the Nam Yuam hydroelectric projects are very small if compared to the power demand of the whole EGAT system and even if they are compared with that of the Northern Region, they are only a fraction of it.

The Yuam river basin situates in the north-western part of Thailand, remotes about 700 km from Bangkok.

The electric power generated by the Nam Yuam hydroelectric projects will be transmitted to the Lamphun Substation over a 230 KV transmission line. The distance from the Yuam river basin to Lamphun is about 200 km and from Lamphun to Bangkok is about 500 km.

Since the Chiang Mai area is the biggest demand center in the Northern Region, it is most probable that the energy generated by the Nam Yuam hydroelectric projects will be absorbed in this region.

This supposition is also the most economical way with regard to the power flow because otherwise the power shall be transmitted to the Bangkok area over 700 Km long transmission line.

The power demand in the greater Bangkok area will be supplied mainly by Bhumibol (535 MW), Sirikid (375 MW), Srinagarind (360 MW) and Khao Laem (300 MW), all are situated nearer to the metropolitan area than the Nam Yuam hydroelectric projects. Thus in the following study, the Northern Region is set as the power supply area of the Nam Yuam hydroelectric projects.

Table 2-1 EGAT Total Generation Requirement

Fiscal Year	Peak Generation		Energy Generation		Load Factor %
	MW	% Increase	GWh	% Increase	
ACTUAL					
1970	743.35	0.00	4,095.32	0.00	62.47
1971	872.70	16.62	4,792.88	17.03	62.69
1972	1,023.80	17.89	5,711.16	19.16	63.37
1973	1,199.30	16.57	6,872.84	20.34	65.42
1974	1,256.30	4.75	7,258.62	5.61	65.96
1975	1,406.60	11.96	8,211.57	13.13	66.64
1976	1,652.10	17.45	9,414.48	14.65	65.05
1977	1,873.40	13.40	10,950.62	16.32	66.73
1978	2,100.60	12.13	12,371.67	12.98	67.23
1979	2,255.00	7.35	13,964.56	12.88	70.69
1980	2,417.40	7.20	14,753.73	5.65	69.67
1981	2,588.70	7.09	15,959.97	8.18	70.38
1982	2,838.00	9.63	16,881.95	5.78	67.91
1983	3,204.30	12.91	19,066.30	12.94	67.92
1984	3,547.30	10.70	21,066.44	10.49	67.79
1985	3,878.40	9.33	23,356.74	10.87	68.75
FORECAST					
1986	4,346.00	12.06	25,747.00	10.23	67.63
1987	4,764.00	9.62	28,261.00	9.76	67.72
1988	5,162.00	8.35	30,620.00	8.35	67.71
1989	5,500.00	6.55	32,975.00	7.69	68.44
1990	5,858.00	6.51	35,203.00	6.76	68.60
1991	6,199.00	5.82	37,349.00	6.10	68.78
1992	6,539.00	5.48	39,518.00	5.81	68.99
1993	6,881.00	5.23	41,728.00	5.59	69.23
1994	7,226.00	5.01	43,967.00	5.37	69.46
1995	7,594.00	5.09	46,306.00	5.32	69.61
1996	7,977.00	5.04	48,751.00	5.28	69.77
1997	8,376.00	5.00	51,308.00	5.25	69.93
1998	8,792.00	4.97	53,983.00	5.21	70.09
1999	9,227.00	4.95	56,782.00	5.18	70.25
2000	9,680.00	4.91	59,712.00	5.16	70.42
2001	10,154.00	4.90	62,780.00	5.14	70.58

Remark: Working Group Load Forecast
September, 1985

Table 2--2 PEA's Demand

Fiscal Year	Peak Demand		Energy Received from EGAT		Annual Load Factor %
	MW	% Increase	GWh	% Increase	
<u>ACTUAL</u>					
1973	328.00	15.78	1,574.80	27.47	54.81
1974	385.00	17.38	1,797.10	14.12	53.29
1975	455.50	18.31	2,124.60	18.22	53.25
1976	575.50	26.34	2,655.30	24.98	52.53
1977	681.80	18.47	3,314.70	24.83	55.50
1978	790.00	15.87	3,916.10	18.14	56.59
1979	889.30	12.57	4,542.20	15.99	58.31
1980	973.90	9.51	4,966.10	9.33	58.05
1981	1,115.36	14.53	5,569.22	12.14	57.00
1982	1,261.75	13.12	6,189.70	11.14	56.00
1983	1,493.38	18.36	7,287.34	17.73	55.71
1984	1,684.10	12.77	8,173.90	12.17	55.25
<u>FORECAST</u>					
1985	1,980.80	17.62	9,643.60	17.98	55.58
1986	2,228.50	12.51	11,037.10	14.45	56.54
1987	2,531.00	13.57	12,658.70	14.69	57.09
1988	2,811.30	11.07	14,115.70	11.51	57.16
1989	3,028.40	7.72	15,556.20	10.20	58.64
1990	3,265.50	7.83	16,874.50	8.47	58.99
1991	3,482.40	6.64	18,102.60	7.28	59.34
1992	3,695.00	6.10	19,337.60	6.82	59.58
1993	3,909.00	5.79	20,597.90	6.52	60.15
1994	4,123.00	5.47	21,876.00	6.20	60.57

Remark: FY.1977-1982 demand including Siam Metal Enterprises' demand.

Table 2-3 Region 4 Generation Requirement (EGAT)

Fiscal Year	Peak Generation		Energy Generation		Load Factor %
	MW	% Increase	GWh	% Increase	
Actual					
1972	68.66	0	282.92	0	47.03
73	74.96	9.18	333.59	17.9	50.8
74	82.44	9.98	358.62	7.5	49.66
75	94.13	14.18	397.92	10.96	48.26
76	121.77	29.36	481.54	21.01	45.14
77	155.56	27.75	616.71	28.07	45.26
78	176.56	13.5	719.20	16.62	46.5
79	185.19	4.89	735.76	2.30	45.35
1980	199.03	7.47	799.05	8.60	45.83
81	231.34	16.23	894.85	11.99	44.16
82	256.33	10.80	997.57	11.48	44.43
83	292.06	13.94	1,178.85	18.17	46.08
84	335.62	14.91	1,350.04	14.52	45.93
Forecast					
1985	416.51	24.1	1,713	26.89	46.96
86	466.56	12.02	1,930	12.67	47.24
87	514.47	10.27	2,172	12.54	48.21
88	557.30	8.33	2,363	8.79	48.41
89	601.91	8.0	2,565	8.55	48.64
90	647.61	7.59	2,772	8.07	48.86
91	696.95	7.62	2,998	8.15	49.1
92	747.06	7.19	3,230	7.74	49.35
93	799.53	7.02	3,474	7.55	49.6
94	854.74	6.91	3,700	6.51	49.41

Table 2-4 Load Forecast (1995-2020), Northern Region Scenario 1

Year	Energy demand		Annual load factor %	Peak demand	
	GWH	Increase %		MW	Increase %
1994	3,700		49.41	854.74	
1995	3,959	7.0	49.99	904.06	5.8
96	4,236	7.0	50.28	961.74	6.4
97	4,533	7.0	50.58	1,023.06	6.4
98	4,850	7.0	50.87	1,088.37	6.4
99	5,189	7.0	51.16	1,157.84	6.4
2000	5,501	6.0	51.45	1,220.54	5.4
01	5,831	6.0	51.74	1,286.51	5.4
02	6,181	6.0	52.03	1,356.13	5.4
03	6,552	6.0	52.32	1,429.56	5.4
04	6,945	6.0	52.62	1,506.67	5.4
05	7,292	5.0	52.91	1,573.28	4.4
06	7,656	5.0	53.20	1,642.81	4.4
07	8,039	5.0	53.49	1,715.64	4.4
08	8,441	5.0	53.78	1,791.72	4.4
09	8,863	5.0	54.07	1,871.20	4.4
2010	9,213	4.0	54.37	1,935.41	3.4
11	9,587	4.0	54.66	2,002.21	3.5
12	9,970	4.0	54.95	2,071.21	3.4
13	10,369	4.0	55.24	2,142.79	3.5
14	10,784	4.0	55.53	2,216.91	3.5
15	11,215	4.0	55.82	2,293.53	3.5
16	11,664	4.0	56.11	2,373.03	3.5
17	12,130	4.0	56.41	2,454.71	3.4
18	12,615	4.0	56.70	2,539.80	3.5
19	13,120	4.0	56.99	2,628.03	3.5
2020	13,645	4.0	57.28	2,719.36	3.5

Note: Annual load factor is estimated by the model

$$LF = -531.638 + 0.291544 \cdot \text{Year}$$

see. Table 2-6

Table 2-5 Load Forecast (1995-2020), Northern Region Scenario 2

Year	Energy demand		Annual load factor %	Peak demand	
	GWH	Increase %		MW	Increase %
1994	3,700		49.41	854.74	
1995	3,922	6.0	49.99	895.61	4.8
96	4,157	6.0	50.28	943.80	5.4
97	4,407	6.0	50.58	994.63	5.4
98	4,671	6.0	50.87	1,048.20	5.4
99	4,951	6.0	51.16	1,104.74	5.4
2000	5,199	5.0	51.45	1,153.53	4.4
01	5,459	5.0	51.74	1,204.43	4.4
02	5,732	5.0	52.03	1,257.62	4.4
03	6,018	5.0	52.32	1,313.05	4.4
04	6,319	5.0	52.62	1,370.86	4.4
05	6,572	4.0	52.91	1,417.93	3.4
06	6,835	4.0	53.20	1,466.64	3.4
07	7,108	4.0	53.49	1,516.95	3.4
08	7,393	4.0	53.78	1,569.26	3.4
09	7,689	4.0	54.07	1,623.34	3.4
2010	7,919	3.0	54.37	1,662.67	2.4
11	8,157	3.0	54.66	1,703.56	2.5
12	8,401	3.0	54.95	1,745.26	2.4
13	8,654	3.0	55.24	1,788.38	2.5
14	8,913	3.0	55.53	1,832.28	2.5
15	9,181	3.0	55.82	1,877.57	2.5
16	9,456	3.0	56.11	1,923.81	2.5
17	9,740	3.0	56.41	1,971.06	2.5
18	10,032	3.0	56.70	2,019.76	2.5
19	10,333	3.0	56.99	2,069.78	2.5
2020	10,643	3.0	57.28	2,121.08	2.5

Note: Annual load factor is estimated by the model

$$LF = -531.638 + 0.291544 \cdot \text{Year}$$

see. Table 2-6

Table 2--6 Regression of Annual Load Factors
of Northern Region on Years

Year X	L.F. Y
<u>Actual</u>	
1976	45.14
77	45.26
78	46.50
79	45.35
80	45.83
81	44.16
82	44.43
83	46.08
84	45.93
<u>Forecast</u>	
1985	46.96
86	47.24
87	48.21
88	48.41
89	48.64
90	48.86
91	49.10
92	49.35
93	49.60
94	49.41

Regression

Model:

$$Y = b_0 + b_1 \times X$$

Coeffs of Normal
Equations:

$$A_{11} = 19$$

$$A_{12} = 37715$$

$$B_1 = 894.46$$

$$A_{21} = 37715$$

$$A_{22} = 74864845$$

$$B_2 = 1775669.28$$

Solution

$$b_0 = -531.63769$$

$$b_1 = .29154383$$

Error

$$Err_1 = .0005615$$

$$Err_2 = 1.1146$$

Correlation
Coefficient

$$R^2 =$$

$$.813725704214$$

$$\text{Corr. Coeff.} =$$

$$.902067461027$$

Obtained regression model:

$$LF = -531.638 + 0.291544 \cdot \text{Year}$$




Fig. 2-1 Annual Load Factor

Source: EGAT: POWER DEVELOPMENT PLAN (1986-2001), Nov. 1985, Table 3-2, P.9, and LOAD FORECAST WORKING GROUP: LOAD FORECAST, Sep. 1985, Table 2-4, P.8.




Fig. 2-2 Load Forecast, Northern Region




Fig. 2-3 Annual Load Factors, Actual and Estimated for Northern Region

2.5 Daily Load Factors

The annual load factors and daily load factors of the whole EGAT system recorded from 1970 to 1985 are shown on Table 2-7 together with the peak demands and annual energy generations.

The annual load factors of Northern Region (EGAT-R4) are summarized on Table 2-8 and daily load factors of Northern Region (EGAT-R4) on Table 2-9. Four kinds of load factors, i.e. annual load factors and daily load factors of whole EGAT, annual load factors of Northern Region (EGAT-R4) and daily load factors of Northern Region (EGAT-R4) as above tabulated are plotted on the same graph as shown on Fig. 2-4.

Daily load curves and daily load duration curves of the peak demand days of the whole EGAT system from 1975 to 1985 are plotted on Fig. 2-5 through Fig. 2-15 and those of Northern Region (EGAT-R4) from 1979 through 1985 are shown on Fig. 2-16 through Fig. 2-21. Also, all the daily load curves of the Northern Region are superposed on the same graph as shown on Fig. 2-22.

It is interesting to see from this graph that the peak demands increased very rapidly year by year and the deviations between the maximum and minimum demands within the same days were also increased conspicuously.

This tendency of the Northern Region is rather exceptional because, in general, as a system grows or becomes matured, a value of load factor goes up, but the contrary tendency has occurred in this region.

One of the reasons for this situation is that EGAT and PEA have accelerated power expansion programs these years. As the results, not only formerly non-electrified areas but also already electrified areas have been strengthened or expanded and the latent demands sharply come true.

As can be seen from Fig. 2-22, the rates of demand increases in the early morning and in the evening peak hours are greater than those in the off-peak hours.

However, since the accelerated program is expected to complete by 1986, the shapes of the load curves and load duration curves after 1987 will gradually be improved toward the matured ones.

As for the whole EGAT system, as we have seen on Fig. 2-4, the annual load factors and daily load factors are approximately paralleled with each other. Also, the annual load factors of the Northern Region is paralleled with that of the whole EGAT system.

From these findings, it will be admissible to assume that the daily load factors of the Northern Region will be paralleled with the annual load factors of this region in future.

Basing upon this assumption, the values of the daily load factors of the region are estimated as follows:

- i) the values in 1986 are 61.88% which is the same level as 1985 (i.e. assumed to remain at the same level as 1985 due to the effects of the accelerated electrification projects.)
- ii) the values after 1987 go up parallel with those of the annual load factors of Northern Region.

The estimated results are shown on Table 2-10 which says that the daily load factors will be 67.3% in 1995, 68.8% in 2000, 70.2% in 2005, 71.7% in 2010, 73.1% in 2015 and 74.6% in 2020 respectively.

Table 2-7 Relation between Annual and Daily Load Factors EGAT
Whole System (1970-1985)

	* Annual LF %	Daily LF (Peak Day) %	Date of Peak Day	Annual Energy Generation GWH	Peak Demand MW
1970	62.5	75.0	Sep. 24, 70	4,095.32	748.35
1971	62.7	70.5	Sep. 29, 71	4,792.88	872.70
1972	63.4	74.4	Sep. 14, 72	5,711.16	1,028.80
1973	65.4	75.9	Sep. 6, 73	6,872.84	1,199.30
1974	66.0	77.7	Sep. 6, 74	7,258.62	1,256.30
1975	66.0	75.4	Sep. 24, 75	8,211.57	1,406.60
1976	61.1	76.0	Sep. 21, 76	9,414.48	1,652.10
1977	66.7	78.2	Jun. 9, 77	10,950.62	1,873.40
1978	67.2	74.4	Sep. 8, 78	12,371.67	2,100.60
1979	70.7	76.2	Aug. 23, 79	13,964.55	2,255.0
1980	69.7	79.8	Mar. 28, 80	14,753.73	2,417.4
1981	70.3	78.0	Sep. 29, 81	15,959.97	2,588.7
1982	67.9	75.2	Sep. 20, 82	16,881.94	2,838.0
1983	67.9	80.4	May 18, 83	19,066.30	3,204.3
1984	67.8	78.75	Mar. 28, 84	21,066.44	3,547.3
1985	68.8	79.0	Mar. 29, 85	23,356.74	3,878.4

* Source: EGAT Power Development Plan (1985 - 2001)

Nov. 1985, Table 3-2, P. 9

Table 2--8 Annual Power Demand and Annual Load Factors of Northern Region (EGAT-R4)

Fiscal year	Peak demand MW	Annual energy demand GWH	Annual load factor %	
	(Actual)			
1972	68.66	282.92	47.03	} from Table 2-3
73	74.96	333.59	50.8	
74	82.44	358.62	49.66	
75	94.13	397.92	48.26	
76	121.77	481.54	45.14	
77	155.56	616.71	45.26	
78	176.56	719.20	46.5	
79	185.19	735.76	45.35	
80	199.03	799.05	45.83	
81	231.34	894.85	44.16	
82	256.33	997.57	44.43	
83	292.06	1,178.85	46.08	
84	335.62	1,350.04	45.93	
	(Forecast)			
85	416.51	1,713	46.96	} Forecast "scenario 1" from Table 2-4
86	466.56	1,930	47.24	
87	514.47	2,172	48.21	
88	557.30	2,363	48.41	
89	601.91	2,565	48.64	
90	647.61	2,772	48.86	
91	696.95	2,998	49.1	
92	747.06	3,230	49.35	
93	799.53	3,474	49.6	
94	854.74	3,700	49.41	
95	904.06	3,959	49.99	} Forecast "scenario 1" from Table 2-4
96	961.74	4,236	50.28	
97	1,023.06	4,533	50.58	
98	1,088.37	4,850	50.87	
99	1,157.84	5,189	51.16	
2000	1,220.54	5,501	51.45	
01	1,286.51	5,831	51.74	
02	1,356.13	6,181	52.03	
03	1,429.56	6,552	52.32	
04	1,506.67	6,945	52.62	

(Continued to next page)

Table 2--8 (Continued)

Fiscal year	Peak demand MW	Annual energy demand GWH	Annual load factor %
2005	1,573.28	7,292	52.91
06	1,642.81	7,656	53.20
07	1,715.64	8,039	53.49
08	1,791.72	8,441	53.78
09	1,871.20	8,863	54.07
10	1,935.41	9,218	54.37
11	2,002.21	9,587	54.66
12	2,071.21	9,970	54.95
13	2,142.79	10,369	55.24
14	2,216.91	10,784	55.53
15	2,293.53	11,215	55.82
16	2,373.03	11,664	56.11
17	2,454.71	12,130	56.41
18	2,539.80	12,615	56.70
19	2,628.03	13,120	56.99
2020	2,719.36	13,645	57.28

Table 2-9 Demand of Northern Region (EGAT-R4) Coincident to Peak Load and Daily Load Factors

Fiscal year	Peak demand	Energy supplied in peak day	Daily L.F.	Date of peak day	Substations for which date are not available
	MW	MWH	%		
1975	17.49	289	68.7	24 Sep. 1975	LP1, TA1, PL1, CM1, CM2, MR, LN1, TE, ST
76	24.55	396	67.3	21 Sep. 1976	LP1, TA1, PL1, CM1, CM2, MR, LN1, TE, ST
77	37.54	548	60.8	26 Sep. 1977	PR, PY, LP1, PL1, CM1, CM2, MR, LN1, TE, ST
78	56.15	808	60.0	6 Sep. 1978	PR, PY, PL1, CM1, CM2, MR, LN1, TE, ST
79	72.56	1,114.1	63.98	20 Apr. 1979	PR, PY, LP1, PL1, CM1, LN1, ST
80	96.89	1,590.7	68.41	13 Aug. 1980	PY, LP1, PL1, TK2, TE, ST
81	NA				
82	187.13	2,806.2	62.48	12 May 1982	PL1, CM1, TK2, LN1, TE
83	223.62	3,242.7	60.42	6 Jul. 1983	(UT), TK2, LN1, TE, ST
84	266.60	3,621.9	56.61	17 Sep. 1984	TK2, TE, ST
85	367.80	5,462.2	61.88	29 Mar. 1985	TK2, SK

Source: "Demand of substation coincident to peak load in Northern Region (EGAT-R4)" which is one of the answers for JICA team's questionnaire to EGAT.

Note : Above data are missing several substations, in the region. Especially those from 1975 to 1978 are missing Chiang Mai 2 substation which is a major substation in Northern Region. Hence the Peak demands in this table do not coincide with those shown in Table 2-3.

Table 2-10 Daily Load Factors of Northern Region

Fiscal year	Annual load factor ¹⁾ LFyear	Daily load factor ²⁾ LFday	LFday-LFyear	Fiscal year	Annual load factor LFyear	Daily load factor Lyday	LFday-LFyear	
	%	%	%		%	%	%	
1975	48.26	68.7	20.44	1985	46.96	61.88	14.92	
76	45.14	67.3	22.16	86	47.24	61.88		
77	45.26	60.8	15.54	87	48.21	65.53		
78	46.5	60.0	13.50	88	48.41	65.73		
79	45.35	63.98	18.63	89	48.64	65.96		
80	45.83	68.41	22.58	90	48.86	66.18		
81	44.16	NA	-	91	49.10	66.42		
82	44.43	62.48	18.05	92	49.35	66.67		
83	46.08	60.42	14.34	93	49.60	66.92		
84	45.93	56.61	10.68	94	49.41	66.73		
		Total=	155.92	95	49.99	67.31		
		Mean =	17.32	96	50.28	67.60		
				97	50.58	67.90		17.32
				98	50.87	68.19		
				99	51.16	68.48		
				2000	51.45	68.77		
				01	51.74	69.06		
				02	52.03	69.35		
				03	52.32	69.64		
				04	52.62	69.94		
				05	52.91	70.23		
				06	53.20	70.52		
				07	53.49	70.81		
				08	53.78	71.10		
				09	54.07	71.39		
				10	54.37	71.69		
				11	54.66	71.98		
				12	54.95	72.27		
				13	52.24	69.56		
				14	55.53	72.85		
				15	55.82	73.14		
				16	56.11	73.43		
				17	56.41	73.73		
				18	56.70	74.02		
				19	56.99	74.31		
				2020	57.28	74.60		

1) Northern Region (EGAT-R4) from Table 8

2) Northern Region (EGAT-R4) from Table 9




Fig. 2-4 Daily Load Factor vs. Annual Load Factor, Whole EGAT and Northern Region





Fig. 2-5 Hourly Load Curve and Load Duration Curve
EGAT (whole) 24 Sep., 1975





Fig. 2-6 Hourly Load Curve and Load Duration Curve
EGAT (whole) 21 Sep., 1976





Fig. 2-7 Hourly Load Curve and Load Duration Curve
EGAT (whole) 9 Jun., 1977





Fig. 2-8 Hourly Load Curve and Load Duration Curve
EGAT (whole) 6 Sep., 1978





Fig. 2-9 Hourly Load Curve and Load Duration Curve
EGAT (whole) 23 Aug., 1979





Fig. 2-10 Hourly Load Curve and Load Duration Curve
EGAT (whole) 28 Mar., 1980





Fig. 2-11 Hourly Load Curve and Load Duration Curve
EGAT (whole) 29 Sep., 1981





Fig. 2-12 Hourly Load Curve and Load Duration Curve
EGAT (whole) 20 Sep., 1982





Fig. 2-13 Hourly Load Curve and Load Duration Curve
EGAT (whole) 19 May, 1983





Fig. 2-14 Hourly Load Curve and Load Duration Curve
EGAT (whole) 28 May, 1984





Fig. 2-15 Hourly Load Curve and Load Duration Curve
EGAT (whole) 29 Mar., 1985





Fig. 2-16 Hourly Load Curve and Load Duration Curve, Northern Region (EGAT-R4) 1979





Fig. 2-17 Hourly Load Curve and Load Duration Curve Northern Region (EGAT-R4) 1980





Fig. 2-18 Hourly Load Curve and Load Duration Curve
Northern Region (EGAT-R4) 1982





Fig. 2-19 Hourly Load Curve and Load Duration Curve
Northern Region (EGAT-R4) 1983





Fig. 2-20. Hourly Load Curve and Load Duration Curve
Northern Region. (EGAT-R4) 1984





Fig. 2-21 Hourly Load Curve and Load Duration Curve
Northern Region (EGAT-R4) 1985




Fig. 2-22 Load Curve of Peak Demand Days in Northern Region (EGAT-R4)

2.6 Standard Deviation of Load Duration Curve

Before going into the captioned study let us take a look again at the load duration curves of EGAT (whole) and Northern Region (EGAT-R4) studied in the preceding section.

Take Fig. 2-15 and Fig. 2-21 up for example and compare them. The former is the load duration curve of the EGAT (whole) and the latter is the one of the Northern Region (EGAT-R4). It is clearly seen from this comparison that the shape of the former is less fluctuated than the latter, that is, the deviations of the curves from a certain intuitively drawn line (the line will be defined later) are much less in case of the former than the one of the latter case.

This is a reflection of the load characters that the scale of the demand of the whole EGAT (peak = 3,880 MW) is much bigger than that of the Northern Region (peak = 368 MW) and the pattern of consumption of the former is much more matured than the latter. The similar tendencies are discernable in the other year's comparisons too.

Thus we can assume almost certainly that, a shape of a load duration curve will approach to a certain line as the scale of the demand increase and the pattern of consumption become matured. Therefore, if we have a measure of the deviations of the load duration curves from the line, it will be a new additional index (additional to the daily load factor) with which the characters of the load duration curve are more precisely indicated.

In order to proceed the study along this idea, we must first define the line appropriately and uniquely. On Fig. 2-23, a conceptual load duration curve is drawn on the X-Y coordinates axes, where X represents the time (hour) in a day and Y the power demand (MW) at time X.

The top point P on the Y axis shows the peak demand (MW) of the day and T is the total hours (=24 hours) in the day. Now we draw a line P-Q on this figure such that

- (i) the area (under this line but above the X-axis and bounded laterally by Y-axis and a line $X = T$) is equal to the area (under the load duration curve but above the X-axis and bounded laterally by Y-axis and a line $X = T$), and
- (ii) the line P-Q starts at the point P on the Y-axis.

Then the line P-Q is defined uniquely provided that the load duration curve is given. Note that this is the line which is used as a substitute of the load duration curve in a quick study of the load character, because, in a sense, the line can be regarded as an expected load duration curve.

In a mathematical term, this line is expressed as

$$Y = a - mX \quad (3)$$

where a and m are parameters. Next, put

E = total energy demand (MWH) in the day,

L_f = daily load factor of the day and

Q = ordinate value (MW) of a point Q as shown on Fig. 2-23.

Since the line (3) passes the points P and Q, the parameters a and m are calculated by

$$a = P \text{ and } m = (P-Q)/T \quad (4)$$

But by the definition of the load factor, the relation

$$E = P \cdot L_f \cdot T \quad (5)$$

exists and by the definition of the line P-Q,

$$E = (P+Q)T/2. \quad (6)$$

Then from (3), (4), (5) and (6), the following equations are easily obtained.

$$Y = P - \frac{2P(1-L_f)}{T} X \quad (7)$$

$$Q = P(2L_f - 1) \quad (8)$$

Hence, given the values P and L_f , the equation (7) uniquely define the line P-Q.

Now that the expected line P-Q has been determined uniquely, we proceed to obtain the index to represent the deviations of the load duration curve from the line as originally aimed at. Let A_t be a point on the line P-Q and B_t be a point on the load duration curve such that both points stand on the common abscissa at t (See Fig. 2-23).

Then the deviation D_t between B_t and A_t is expressed as

$$D_t = A_t - B_t \quad (9)$$

where A_t and B_t represent the values of ordinates of points A_t and B_t respectively.

Since A_t is a point on P-Q line, we get from (7)

$$A_t = P - \frac{2P(1-L_f)}{T} t \quad (10)$$

It will be convenient that A_t , B_t and D_t are normalized as A_t/P , B_t/P and D_t/P with respect to P and used A_t/P , B_t/P and D_t/P instead of A_t , B_t and D_t in the following study.

Now on the analogy of the concept of the variance which is commonly used in a field of the statistics, put

$$D_2 = \sum_{t=0}^T \left(\frac{D_t}{P} \right)^2 \quad (11)$$

and define the standard deviation s of the load duration curve from the expected line P-Q as

$$s = \sqrt{\frac{D_2}{T+1}} \quad (12)$$

The summation of D_t^2 should be made on all the equally spaced t 's between and including time 0 and T . The actual values of s calculated for each daily load duration curve of EGAT (whole) and Northern Region (EGAT-R4) are plotted on Fig. 2-5 through Fig. 2-21 in the foregoing section and listed in Table 2-11 and Table 2-12 too. Thus the new indices as above proposed are obtained numerically.

Our next target is to obtain some empirical formula to relate the standard deviation s with the daily load factor L_f .

Fig. 2-24 shows the scattergram of these two values which are taken from Table 2-11 and Table 2-12. All-together 21 points are plotted on the scattergram of which 11 points represent EGAT (whole) and 10 points come from Northern Region. It is interesting to see that although the points come from the different load systems, these points are approximately aligned on a certain imaginable line.

Thus a regression analysis of s on L_f is attempted to estimate the imagined line. The result of the analysis give us a line

$$s = 0.421619 - 0.5035193 L_f \quad (13)$$

as shown on Fig. 2-24, too.

The line (13) gives the linear relation of s to L_f as if all the values of s and L_f come from the same system.

Thus a future value of the standard deviation s can be estimated by (13) if the value of L_f in that future time is given. The values of s of the Northern Region in 1985, 1995, 2000, 2005, 2010, 2015 and 2020 are estimated using (13) and are shown in Table 2-13. According to this result, the standard deviation at 0.1100 in 1985 will be decreased to 0.046 in 2020 as the load factor will be improved from 0.619 to 0.746.




Fig. 2-23 Deviation of Load Duration Curve from Expected Line P-Q

Table 2-11 Maximum Demand of System, Coincident to Peak Load in EGAT
Whole Supply Area

Fiscal year & peak demand day		Peak load MW	Energy demand MWH	Daily load factor Lf	Sum of squares D2	Standard deviation (N=T+1=49) S	
1975	24 Sep	1,406.6	25,387.1	0.752022	.056044	.0338194	
76	21 Sep	1,652.1	30,005.8	0.756744	.056272	.0338883	
77	9 Jun	1,873.4	34,982.5	0.778053	.033945	.0263204	
78	6 Sep	2,100.6	38,389.0	0.761468	.047856	.0312515	
79	23 Aug	2,255.0	42,839.1	0.791558	.021984	.0211817	
80	28 Mar	2,417.4	46,173.3	0.795849	.026154	.0231032	
81	29 Sep	2,588.7	47,817.8	0.769656	.040434	.0287262	
82	20 Sep	2,838.0	51,821.0	0.760820	.053106	.0329210	
83	19 May	3,204.3	62,021.1	0.806482	.025765	.0229308	
84	28 May	3,547.3	67,798.9	0.796367	.025739	.0229191	
85	29 Mar	3,880.0	73,532.5	0.789653	.035831	.0270415	

Table 2-12 Maximum Demand of System Coincident to Peak Load in Northern Region (EGAT-R4)

Fiscal year & peak demand day		Peak ¹⁾ load MW	Daily energy demand MWH	Daily load factor Lf	Sum of squares D2	Standard deviation (N=T+1=49) S	Numbers of Substations for which load data are available
1975	24 Sep.	17.49	288.1	0.686410	.427554	.0934109	3
76	21 Sep.	24.55	395.4	0.671118	.484564	.0994437	3
77	26 Sep.	37.54	547.6	0.607804	.831603	.1302747	6
78	6 Sep.	56.15	807.7	0.599360	.913062	.1365061	7
79	20 Apr.	72.56	1,114.1	0.639762	.619042	.1123088	8
80	13 Aug.	96.89	1,590.7	0.684065	.247681	.0710965	11
81		N.A.					
82	12 May	187.13	2,806.2	0.624826	.547389	.1056939	15
83	6 Jul.	223.62	3,242.6	0.604185	.517767	.1027943	15
84	17 Sep.	266.60	3,621.9	0.566067	.608219	.1114120	18
85	29 Mar.	367.8	5,462.2	0.618786	.530299	.1040309	21

Note: 1) Peak load in this column is a total peak loads of the substations for which hourly loads in the coincidental peak demand day are available. Since the data for several substations in the region are missing, the values of peak load do not coincide with those shown on Table 2-3.




Fig. 2-24 Standard Deviation of Hourly Loads vs Daily Load Factor

Table 2-13 Parameters of Daily Load Duration Curves Northern Region

Fiscal year	1)	2)	3)	Ratio Su/Sv C
	Peak load P MW	Daily load factor Lf	Standard deviation S 4)	
1985 base year	416.5	0.6188	0.11004	1.000
1995	904.0	0.6731	0.08270	0.752
2000	1,220.5	0.6877	0.07535	0.685
2005	1,573.3	0.7023	0.06800	0.618
2010	1,935.4	0.7169	0.06065	0.551
2015	2,293.5	0.7314	0.05792	0.527
2020	2,719.4	0.7460	0.04599	0.418

Note: 1) Values in this column come from Table 2-3 and Table 2-4.

2) Value in this column come from Tabel 2-10.

3) Calculated by $s=0.421619-0.5035193 Lf$

4) This value is slightly different from the corresponding value 0.10403 in Table 12, because the former is a value on the regression line whereas the latter is a value calculated from the actual record.

2.7 Estimation of Daily Load Duration Curve

The future load duration curve can now be estimated as follows.

As we have seen in the previous section, the deviations of the load duration curve from the expected load duration line will decrease as the system grows and becomes matured.

One of the ways to express this tendency is to set up the equation:

$$\frac{D_u}{P_u} = C \frac{D_v}{P_v} \quad (14)$$

where D_u and P_u are the deviation and the peak demand in a target year respectively and D_v and P_v are those in a base year respectively. (see Fig. 2-25)

C is a constant to be estimated which indicates the reduction ratio of the deviations.

From (11),

$$D_{2v} = \sum_{t=0}^T \left(\frac{D_{vt}}{P_v} \right)^2 \quad (15)$$

$$D_{2u} = \sum_{t=0}^T \left(\frac{D_{ut}}{P_u} \right)^2$$

and from (14),

$$\sum_{t=0}^T \left(\frac{D_{ut}}{P_u} \right)^2 = C^2 \sum_{t=0}^T \left(\frac{D_{vt}}{P_v} \right)^2 \quad (16)$$

where the subscript v and u indicate the base year and the target year respectively. Combining (15) and (16),

$$C^2 = \frac{D_{2u}}{D_{2v}} \quad (17)$$

and substituting (12) into (17), we get,

$$C = \frac{S_u}{S_v} \quad (18)$$

Hence C is in fact the reduction ratio of the standard deviation of the target year to that of the base year. Moreover, from (14) the deviation D_u can be expressed as

$$D_u = C \frac{D_v}{P_v} \cdot P_u \quad (19)$$

Therefore, by using the value C , calculated by (18), the shape and magnitude of the load duration curve of the target year can be estimated by (19) basing upon the load duration curve in the base year.

The values of C of the Northern Region are calculated for 1995, 2000, 2005, 2010, 2015 and 2020, taking 1984 as the base year, and are listed on Table 2-13.

Then, the load duration curves of Northern Region are estimated using (19). The calculated results are shown in Table 2-14 and the curves are plotted on Fig. 2-26 through 2-31.




Fig. 2-25 Evaluation of Load Duration Curve




Fig. 2-26 Load Duration Curve Northern Region 1995




Fig. 2-27 Load Duration Curve Northern Region 2000




Fig. 2-28 Load Duration Curve Northern Region 2005




Fig. 2-29 Load Duration Curve Northern Region 2010




Fig. 2-30 Load Duration Curve Northern Region 2015




Fig. 2-31 Load Duration Curve Northern Region 2020

Table 2-14 Estimated Load Duration Curves of Northern Region

	1985			1995			2000			2005			2010		
	LDC	Norma- lized LDC	Dt P	LDC	Norma- lized LDC	Dt P	LDC	Norma- lized LDC	Dt P	LDC	Norma- lized LDC	Dt P	LDC	Norma- lized LDC	Dt P
	MW	%		MW	%		MW	%		MW	%		MW	%	
0.0	367.80	100.00	0	990.70	100.00	0	1334.00	100.00	0	1771.80	100.00	0	2313.10	100.00	0
0.5	366.30	99.92	-0173	989.18	99.85	-0152	1331.34	99.80	-0139	1767.11	99.74	-0120	2304.85	99.64	-0094
1.0	356.80	97.08	-0070	963.66	97.27	-0061	1299.18	97.39	-0056	1728.53	97.56	-0048	2262.06	97.79	-0038
	345.80	95.09	-0051	945.47	95.43	-0048	1276.04	95.66	-0041	1700.31	95.97	-0035	2229.83	96.40	-0028
2.0	340.20	93.09	-0032	927.28	93.60	-0028	1252.90	93.92	-0026	1672.09	94.37	-0022	2197.59	95.01	-0018
	327.80	86.24	-0472	866.86	87.50	-0414	1177.87	88.30	-0378	1584.24	89.41	-0327	2104.60	90.99	-0255
3.0	309.80	84.33	-0482	849.44	85.74	-0423	1155.67	86.63	-0386	1557.11	87.88	-0334	2073.47	89.64	-0261
	301.25	79.39	-0796	805.61	81.32	-0698	1101.03	82.54	-0637	1492.68	84.25	-0551	2004.34	86.65	-0430
4.0	289.85	68.66	-1687	711.49	71.82	-1481	984.62	73.81	-1351	1357.29	76.61	-1169	1862.68	80.54	-0913
	269.90	67.71	-1602	702.38	70.90	-1406	972.62	72.91	-1283	1341.87	75.74	-1110	1843.70	79.71	-0866
5.0	262.30	67.65	-1427	701.03	70.76	-1253	970.16	72.73	-1143	1337.42	75.48	-0989	1835.69	79.36	-0772
	253.00	66.64	-1347	691.39	69.79	-1183	957.52	71.78	-1079	1321.26	74.57	-0934	1815.75	78.50	-0729
6.0	252.25	64.37	-1393	670.85	67.71	-1223	931.50	69.83	-1116	1289.72	72.79	-0965	1780.14	76.96	-0754
	242.20	62.39	-1411	652.73	65.89	-1239	908.43	68.10	-1130	1261.59	71.20	-0978	1748.00	75.57	-0763
7.0	236.10	58.13	-1656	614.90	62.07	-1454	861.17	64.56	-1326	1205.65	68.05	-1147	1687.51	72.95	-0896
	231.30	56.72	-1616	601.82	60.75	-1419	844.30	63.29	-1294	1184.63	66.86	-1120	1662.62	71.88	-0874
8.0	220.40	56.04	-1504	595.00	60.06	-1320	835.12	62.60	-1204	1172.46	66.17	-1042	1646.75	71.19	-0813
	219.10	55.90	-1337	592.96	59.85	-1174	831.82	62.36	-1071	1167.04	65.87	-0926	1637.75	70.80	-0723
9.0	217.80	55.27	-1218	586.70	59.22	-1070	823.33	61.72	-0976	1155.65	65.22	-0844	1622.67	70.15	-0659
	216.90	53.66	-1199	571.86	57.72	-1052	804.30	60.29	-0960	1132.15	63.90	-0831	1595.25	68.97	-0648
10.0	216.00	53.33	-1051	568.12	57.35	-0923	798.91	59.89	-0842	1124.33	63.46	-0729	1583.81	68.47	-0569
	213.20	52.99	-0904	564.39	56.97	-0794	793.53	59.48	-0724	1116.51	63.02	-0626	1572.37	67.98	-0489
11.0	209.55	51.41	-0881	549.77	55.49	-0774	774.77	58.08	-0706	1093.33	61.71	-0611	1545.28	66.81	-0477
	208.20	51.26	-0715	547.66	55.28	-0628	771.37	57.82	-0573	1087.80	61.39	-0496	1536.17	66.41	-0387
12.0	207.00	51.18	-0542	546.16	55.13	-0476	768.73	57.63	-0434	1083.13	61.13	-0376	1527.94	66.06	-0293
	207.00	51.11	-0369	544.66	54.98	-0324	766.09	57.43	-0296	1078.47	60.87	-0256	1519.72	65.70	-0200
13.0	205.80	50.47	-0253	538.25	54.33	-0222	757.42	56.78	-0202	1066.87	60.21	-0175	1504.43	65.04	-0137
	205.65	50.40	-0078	536.83	54.19	-0069	754.88	56.59	-0063	1062.32	59.96	-0054	1496.32	64.69	-0043
14.0	203.10	49.82	-0045	531.01	53.60	-0039	746.93	55.99	-0036	1051.56	59.35	-0031	1481.88	64.06	-0024
	200.80	49.53	-0196	527.64	53.26	-0173	741.98	55.62	-0157	1044.25	58.94	-0136	1470.96	63.59	-0106
15.0	200.50	49.07	-0332	522.82	52.77	-0291	735.27	55.12	-0266	1034.91	58.41	-0230	1457.97	63.03	-0179
	195.20	47.80	-0385	510.93	51.57	-0338	719.87	53.96	-0309	1015.57	57.32	-0267	1434.80	62.03	-0208
16.0	194.15	47.02	-0488	503.29	50.80	-0428	709.67	53.20	-0391	1002.23	56.57	-0338	1417.73	61.29	-0264
	193.10	46.23	-0590	495.64	50.03	-0518	699.48	52.43	-0473	988.88	55.81	-0409	1400.65	60.55	-0319
17.0	192.85	46.17	-0764	494.25	49.89	-0671	696.98	52.25	-0612	984.38	55.56	-0530	1392.59	60.20	-0414
	188.85	45.06	-0834	483.75	48.83	-0732	683.27	51.22	-0668	967.01	54.58	-0578	1371.42	59.29	-0451
18.0	185.00	44.76	-0985	480.32	48.48	-0865	678.27	50.84	-0789	959.63	54.16	-0683	1360.42	58.81	-0533
	181.70	43.64	-1054	469.74	47.41	-0925	664.47	49.81	-0844	942.13	53.17	-0730	1339.13	57.89	-0570
19.0	181.70	41.33	-1004	448.83	45.30	-0881	637.98	47.82	-0804	910.07	51.36	-0696	1302.97	56.33	-0543
	181.70	41.04	-1156	445.50	44.97	-1015	633.09	47.46	-0926	902.82	50.96	-0801	1292.12	55.86	-0625
20.0	178.35	36.99	-0931	409.40	41.32	-0817	587.95	44.07	-0746	849.32	47.94	-0645	1234.12	53.35	-0504
	176.90	36.99	-1112	408.57	41.24	-0976	586.13	43.94	-0891	845.60	47.73	-0771	1226.86	53.04	-0602
21.0	175.00	36.99	-1293	407.74	41.16	-1135	584.31	43.80	-1035	841.88	47.52	-0896	1219.60	52.73	-0699
	172.50	36.49	-1424	402.57	40.64	-1250	577.16	43.27	-1140	832.03	46.96	-0987	1206.09	52.14	-0770
22.0	170.05	36.40	-1596	401.01	40.48	-1401	574.44	43.06	-1278	827.28	46.69	-1106	1197.78	51.78	-0863
	168.40	35.82	-1718	395.10	39.88	-1509	566.39	42.46	-1376	816.40	46.08	-1191	1183.22	51.15	-0930
23.0	165.10	35.81	-1898	394.14	39.78	-1666	564.41	42.31	-1520	812.49	45.86	-1315	1175.77	50.93	-1027
	164.70	35.47	-2045	390.41	39.41	-1796	559.03	41.91	-1638	804.67	45.42	-1417	1164.33	50.34	-1106
24.0	164.30	35.12	-2191	386.55	39.02	-1924	553.48	41.49	-1753	796.67	44.96	-1518	1152.70	49.83	-1185

LDC = Load Duration Curve

2.8 Integrated Load Function

An integrated load function is a curve that loads (or required capacity) are plotted as ordinates and cumulative energies as abscissae, hence a certain value of cumulative energy corresponds to a certain load level such that from the peak load down to this load level the total energy required is equal to that cumulative energy.

On the load duration curve, this cumulative energy is represented by the area of the upper triangle-like portion (not exactly triangle but approximately shaped), as against the integrated load function on which it is represented by the length of the abscissa.

Therefore the integrated load function is obtained by integrating the areas under the load duration curves from the peak down to the corresponding load levels. The integrated load function is very useful for estimating the firm capacity and other related values of a proposed hydro power project.

The calculated integrated load function of Northern Region in 1995, 2000, 2005, 2010, 2015 and 2020 are shown on Table 2-15 and are plotted on Fig. 2-32 through Fig. 2-37.

Table 2-15 Integrated Load Function of Northern Region

Depth of load level from peak (MW)	Cumulative energy to meet load (MWH)			
	1995	2000	2005	2010
10.0	4.6	4.3	3.8	2.9
20.0	9.6	9.3	8.8	7.9
30.0	22.5	14.3	13.8	12.9
40.0	32.5	30.0	18.8	17.9
50.0	49.4	40.0	36.8	22.9
60.0	64.4	56.8	46.8	43.1
70.0	87.3	71.8	56.8	53.1
80.0	107.3	86.8	78.1	63.1
90.0	127.3	112.0	93.1	84.5
100.0	147.3	132.0	115.3	99.5
110.0	167.3	152.0	135.3	114.5
120.0	187.3	172.0	155.3	139.8
130.0	225.4	192.0	175.3	159.8
140.0	250.4	212.0	195.3	179.8
150.0	284.2	232.0	215.3	199.8
160.0	314.2	272.7	235.3	219.8
170.0	344.2	297.7	255.3	239.8
180.0	374.2	329.1	275.3	259.8
190.0	417.6	359.1	318.5	279.8
200.0	452.6	389.1	343.5	299.8
210.0	487.6	419.1	368.5	343.8
220.0	522.6	449.1	403.0	368.8
230.0	557.6	479.1	433.0	393.8
240.0	592.6	526.3	463.0	426.8
250.0	627.6	561.3	493.0	456.8
260.0	662.6	596.3	523.0	486.8
270.0	697.6	631.3	553.0	516.8
280.0	756.5	666.3	599.5	546.8
290.0	800.1	701.3	634.0	576.8
300.0	852.9	736.3	669.5	606.8
310.0	907.9	771.3	704.5	654.7
320.0	968.1	806.3	739.5	689.7
330.0	1028.1	841.3	774.5	724.7
340.0	1093.6	876.3	809.5	759.7
350.0	1158.6	940.7	844.5	794.7
360.0	1223.6	980.7	879.5	829.7
370.0	1288.6	1031.7	914.5	864.7
380.0	1365.2	1086.6	949.5	899.7
390.0	1439.0	1141.6	984.5	934.7
400.0	1519.5	1196.6	1019.5	969.7

(continued)

Depth of load level from peak (MW)	Cumulative energy to meet load (MWH)			
	1995	2000	2005	2010
410.0	1609.1	1261.9	1054.5	1004.7
420.0	1703.4	1321.9	1126.1	1039.7
430.0	1805.8	1389.8	1170.0	1074.7
440.0	1910.8	1454.8	1218.9	1109.7
450.0	2033.4	1519.8	1268.9	1144.7
460.0	2168.8	1584.8	1327.7	1220.0
470.0	2315.4	1649.8	1382.7	1265.1
480.0	2468.5	1730.2	1437.7	1313.4
490.0	2626.7	1804.6	1504.5	1363.4
500.0	2793.2	1882.5	1564.5	1419.7
510.0	2967.4	1967.2	1624.5	1474.7
520.0	3148.0	2059.0	1696.5	1529.7
530.0	3335.2	2153.9	1761.5	1584.7
540.0	3520.2	2252.7	1826.5	1652.1
550.0	3717.7	2358.8	1891.5	1712.1
560.0	3912.7	2468.9	1956.5	1772.1
570.0	4107.7	2588.1	2037.4	1842.6
580.0	4302.7	2718.1	2107.4	1907.6
590.0	4521.7	2856.5	2184.0	1972.6
600.0	4747.4	3004.1	2262.4	2037.6
(604.2)	4846.8	—	—	—
610.0		3154.1	2346.4	2102.6
620.0		3310.9	2436.2	2167.6
630.0		3471.3	2526.2	2249.9
640.0		3638.7	2622.2	2319.9
650.0		3808.7	2720.4	2389.9
660.0		3990.1	2824.7	2470.9
670.0		4173.8	2929.7	2551.7
680.0		4358.8	3041.3	2636.3
690.0		4543.8	3157.5	2721.3
700.0		4737.4	3282.0	2814.8
710.0		4933.2	3413.9	2904.8
720.0		5128.2	3548.9	3002.7
730.0		5323.2	3694.5	3101.0
740.0		5518.2	3843.4	3201.0
750.0		5728.6	3993.4	3308.5
760.0		5942.8	4150.1	3413.5
770.0		6166.7	4308.6	3526.3
780.0		6400.6	4468.6	3640.1
(780.5)		6414.2	—	—
790.0			4637.9	3759.6
800.0			4807.9	3885.0
810.0			4984.9	4014.5

(continued)

Depth of load level from peak (MW)	Cumulative energy to meet load (MWH)			
	1995	2000	2005	2010
820.0			5165.6	4148.1
830.0			5350.2	4283.1
840.0			5535.2	4426.1
850.0			5720.2	4572.8
860.0			5905.2	4723.4
870.0			6104.7	4873.4
880.0			6299.7	5030.1
890.0			6494.7	5185.1
900.0			6689.7	5346.7
910.0			6884.7	5506.7
920.0			7079.7	5674.7
930.0			7295.6	5846.5
940.0			7508.2	6016.5
950.0			7727.1	6195.9
960.0			7953.4	6377.3
970.0			8186.8	6357.3
(975.1)			8309.3	—
980.0				6745.7
990.0				6930.7
(990.7)	14123.9	—	—	—
1000.0				7115.7
1010.0				7300.7
1020.0				7499.6
1030.0				7696.9
1040.0				7891.9
1050.0				8086.9
1060.0				8281.9
1070.0				8476.9
1080.0				8686.9
1090.0				8890.6
1100.0				9100.6
1110.0				9315.5
1120.0				9534.9
1130.0				9758.6
1140.0				9986.8
1150.0				10220.3
1160.0				10455.3
(1160.4)				10467.6
1334.0	—	19697.7	—	—
1771.8	—	—	27429.5	—
2313.1	—	—	—	38132.4




Fig. 2-32 Integrated Load Function of Peak Demand Day Northern Region 1995




Fig. 2-33 Integrated Load Function of Peak Demand Day Northern Region 2000




Fig. 2-34 Integrated Load Function of Peak Demand Day Northern Region 2005




Fig. 2-35 Integrated Load Function of Peak Demand Day Northern Region 2010




Fig. 2-36 Integrated Load Function of Peak Demand Day Northern Region 2015




Fig. 2-37 Integrated Load Function of Peak Demand Day Northern Region 2020

2.9 Daily Plant Factor

This section deals with an estimation of a daily plant factor of a hydro power project. 1) In the previous section we have estimated the load duration curves and the integrated load functions of the Northern Region of the maximum demand days in 1995, 2000, 2005, 2010, 2015 and 2020.

- 1) The daily plant factor should not be confused with the daily load factor which is discussed in the previous sections. The former refers to an individual power plant, whereas the latter considers a power system as a whole.

In Chapter 5, the reservoir simulations were performed for various projects in the Yuam river basin and the daily firm energies were obtained for each alternative project.

Usually storage type and pondage type hydro power plants supply energy for the peak portion of the load duration curve. Since the proposed hydro power plants in this study are mainly of these types, their relative position should be higher in the load duration curve.

Hence, if there are no peaking power plants existed in the system and if only one hydro power plant is newly proposed, the firm capacity of the hydro power plant is easily determined by fitting its firm energy into the top portion of the load duration curve (i.e. let the area of the top portion equal to the firm energy) and read off the height (in MW) of this fit portion.

However, if there are several peaking power plants already existed or will come into operation in near future, we must take them all together into account and study the positions at which these peaking power plants occupy cooperatively under the load duration curve, because there are no reasons why the newly proposed hydro power plant should be positioned higher than other peaking hydro power plants.

Therefore the total firm energies of these conventional hydro power plants should fit to the load duration curve and the combined firm capacity should be read off, and the common plant factor to all of them will be calculated.

Then this plant factor should be adopted to the newly proposed hydro power plant. According to the EGAT hydro power development plan, several hydro power projects are proposed in the Northern Region other than the projects proposed in this study. Among those the Lower Yuam hydropower project is one of the most promising projects. Therefore, the plant factor of our projects should be determined on a base of the integrated development planning of the Yuam river basin as a whole. Although this is a purely theoretical procedure, we trially assume three daily plant factors, 15%, 20% and 25%, compare respective results and adopt the factor that will give the most economical one.

CHAPTER 3. GEOLOGY

CHAPTER 3 GEOLOGY

CONTENTS		Page
3.1	Introduction	3-1
3.2	Geological Investigation Works	3-2
3.2.1	Investigation Area	3-2
3.2.2	Investigation Method and Quantity	3-3
3.3	Topography and Geology of Project Area	3-6
3.3.1	Topography	4-6
3.3.2	Geology	3-7
3.4	Site Geology	3-8
3.4.1	Nam Mae Ngao No. 2	3-8
3.4.2	Nam Mae Ngao No. 3	3-15
3.4.3	Upper Mae Yuam 1	3-16
3.4.4	Upper Mae Yuam 2	3-20
3.4.5	Nam Mae Rit	3-22
3.4.6	Upper Mae Rit 2a	3-25
3.4.7	Further Investigation Works	3-26
3.5	Construction Materials	3-28
3.5.1	Impervious Core Materials	3-28
3.5.2	Rock Materials	3-32

Table List

	Page
Table 3-1 List of Drill Holes	3-5
Table 3-2 Additional Drill Hole in Nam Mae Ngao No. 2 Dam Site	3-14
Table 3-3-1 Results of Soil Test (Nam Mae Ngao No. 2)	3-34
Table 3-3-2 Results of Soil Test (Upper Mae Yuam 1)	3-35
Table 3-3-3 Results of Soil Test (Upper Mae Yuam 2)	3-36
Table 3-3-4 Results of Soil Test (Nam Mae Rit)	3-37

Figure List

	Page
Fig. 3-1 Geology, Catchment Area Plan	3-39
Fig. 3-2 Geology, Reservoir Area Plan (1-3)	3-41
Fig. 3-3 Geology, Reservoir Area Plan and Profile (2-3)	3-43
Fig. 3-4 Geology, Reservoir Area Plan and Profile (3-3)	3-45
Fig. 3-5 Geology, Nam Mae Ngao No. 2 Damsite Plan	3-47
Fig. 3-6 Geology, Nam Mae Ngao No. 2 Damsite Profile	3-49
Fig. 3-7 Geology, Nam Mae Ngao No. 3 Damsite Plan and Profile	3-51
Fig. 3-8 Geology, Upper Mae Yuam 1 Damsite Plan and Profile	3-53
Fig. 3-9 Geology, Upper Mae Yuam 2 Damsite Plan and Profile	3-55
Fig. 3-10 Geology, Nam Mae Rit Damsite Plan and Profile	3-57
Fig. 3-11 Geology, Nam Mae Ngao No. 2 Borrow Area and Quarry Site	3-59
Fig. 3-12 Geology, Upper Mae Yuam 1, 2 and Nam Mae Rit Borrow Area	3-61
and Quarry Site	

CHAPTER 3. GEOLOGY

3.1 Introduction

The investigation just made is a master plan study for the hydroelectric power development project described in Chapter 1, and was carried out from 1985 into 1986.

Field geological investigations for the purpose of obtaining basic data required for preparation of a master plan for the Project were carried out three times, from July to August 1985, from October 1985 to January 1986, and from June to July 1986.

The geological studies in this Report were made based on the results of the various investigations such as photogeological interpretation, surface geological reconnaissance, and drilling investigations carried out in the field during the abovementioned periods.

3.2 Geological Investigation Works

3.2.1 Investigation Area

The present hydroelectric power development project was studied considering following sites.

- Upper Mae Yuam 1
- Upper Mae Yuam 2
- Upper Mae Yuam 3
- Nam Mae Rit
- Upper Nam Mae Rit 1
- Upper Mae Rit 2
- Upper Mae Rit 2a (alternative to Upper Mae Rit 2)
- Upper Mae Rit 3
- Nam Mae Ngao No. 2
- Nam Mae Ngao No. 3 (alternative to Nam Mae Ngao No. 2)
- Upper Mae Ngao

Among the abovementioned sites, the six sites of Upper Mae Yuam 1, Upper Mae Yuam 2, Nam Mae Rit, Upper Mae Rit 2a, Nam Mae Ngao No. 2, and Nam Mae Ngao No. 3 were selected at the beginning of the study and field geological investigations were planned. However, a field reconnaissance could not be made for the Upper Mae Rit 2a site because of lack of access to the dam site, and topographic and geological conditions were grasped through photogeological interpretations and studies of existing data.

Of these individual dam sites, it was decided as a result of discussions between EGAT and JICA Survey Team during the second field investigations, that studies would be made mainly on the four sites of Upper Mae Yuam 1, Nam Mae Rit, Upper Mae Rit 2a, and Nam Mae Ngao No. 2. And of these four, the Nam Mae Ngao No. 2 site was recognized as being the most promising from an economic point of view.

3.2.2 Investigation Method and Quantity

The geological investigations in this project consist of photogeological interpretations, surface geological reconnaissances (including construction materials investigations), and core drillings, but surface geological reconnaissance and drilling works were not done at Upper Mae Rit 2a of the six sites mentioned previously, for the reason that it was inaccessible. Drilling works were planned at the other sites, but really executed at four site except Nam Mae Ngao No.3. In construction materials investigations, confirmations were made of locations where samples were collected for impervious core materials in geological reconnaissances, but geological reconnaissances could not be made of rock quarry sites and locations were selected based solely on photogeological interpretations.

As for borrow areas of impervious core materials, sample collection and laboratory tests were carried out by EGAT.

The methods of investigation and quantities in the present study are as follows:

a) Photogeological Interpretation

Photo scale: 1:20,000

Interpretation extent:

Yuam River Basin	100 km ²
Rit River Basin	120 km ²
Ngao River Basin	100 km ²

b) Surface Geological Reconnaissance

Reconnaissanced area:

- Dam site and surroundings
- Reservoir area and along neighboring streams

Topographic map scales

Nam Mae Ngao No. 2	1:5,000 (aerial map)
Nam Mae Ngao No. 3	1:5,000 (aerial map)
Upper Mae Yuam 1	1:50,000
Upper Mae Yuam 2	1:50,000
Nam Mae Rit	1:5,000 (aerial map)
Upper Mae Rit 2a	1:50,000

c) Core Drilling (Including Permeability Test)

Four project sites	17 holes	Total length 1,057.3 m
Nam Mae Ngao No. 2		7 holes 467 m
Upper Mae Yuam 1	2 "	100 m
Upper Mae Yuam 2	3 "	170 m
Nam Mae Rit	5 "	320.3 m

Details of the individual holes are given in Table 3.1.

d) Test Pits for Impervious Core Materials

Four project sites	51 pits	Total length 212.3 m
Nam Mae Ngao No.2	14 "	55 m
Upper Mae Yuam 1	12 "	57 m
Upper Mae Yuam 2	12 "	55.2 m
Nam Mae Rit	13 "	45.1 m

e) Chemical Analysis of Rocks

6 samples

f) Microscopic Observation of Rocks

4 samples

Table 3-1 List of Drill Holes

Site	Hole No.	Coordinate	Elevation (m)	Angle from Horizontal	Length (m)	Permeability Test (times)
Nam Mae Ngao No. 2	DR-0	1,967,292.658N 393,859.171E	271.906	90°	35.0	-
	DR-1	1,967,248.685N 393,919.829E	271.250	90°	90.0	11
	DR-2	1,967,208.138N 393,792.266E	223.833	90°	35.0	-
	DR-3	1,967,177.086N 393,668.690E	180.650	90°	55.0	9
	DR-4	1,967,131.422N 393,520.217E	161.050	90°	90.0	15
	DL-1	1,967,083.846N 393,344.150E	220.380	90°	70.0	7
	DL-2	1,967,051.193N 393,227.917E	302.412	90°	92.0	3
Sub Total (7 Holes)					467.0 m	45 times
Upper Mae Yuam 1	DR-1	--	344.785	90°	50.0	1
	DL-1	--	330.606	90°	50.0	--
Sub Total (2 Holes)					100.0 m	1 time
Upper Mae Yuam 2	DR-1	--	352.332	90°	60.0	9
	DR-2	--	337.192	90°	50.0	8
	DL-1	--	354.394	90°	60.0	10
Sub Total (3 Holes)					170.0 m	27 times
Nam Mae Rit	DR-1	1,981,543.079N 394,165.979E	334.894	90°	49.8	4
	DR-2	1,981,461.980N 394,246.574E	237.927	90°	70.0	10
	DL-1	1,981,408.528N 394,326.509E	193.697	90°	60.5	10
	DL-2	1,981,386.919N 394,360.166E	224.992	90°	70.0	10
	DL-3	1,981,301.726N 394,462.970E	299.616	90°	70.0	4
Sub Total (5 Holes)					320.3 m	38 times
Total (17 Holes)					1,057.3 m	111 times

3.3 Topography and Geology of Project Area

3.3.1 Topography

The Yuam river rises from the vicinity of Khun Yuam near 19° north latitude and 98° east longitude, flows south through the Mae Sariang basin for approximately 120 km, eventually changes its course to the west, merges with the Moei river which is a major tributary of the Salawin river, after which it merges with the Salawin river comprising the border between Thailand and Burma.

Meanwhile, the Rit river, which is one of the tributaries of the Yuam river, rises from the vicinity of 18°15' north latitude and 98°15' east longitude, changes its course from south to southwest, and then west, joining the Yuam river after running for about 50 km. As for the Ngao river which is the first of the tributaries of the Yuam river, it flows in the north-northwest direction for approximately 40 km from the vicinity of 17°40' north latitude and 98° east longitude to merge with the Yuam river.

A broad basin is developed along the Yuam river from near its fountainhead to the vicinity of about 25 km south of Mae Sariang, but downstream from this point and along the Ngao river is generally a steep gorge.

The catchment of the Yuam river basin of area approximately 6,000 km² extends north-south in a slender shape, being approximately 30 to 50 km in width and approximately 160 km in length.

The western boundary of the Yuam river basin consists of a mountainous terrains of around EL. 1,000 m which extends in a straight line southward from Mt. Wi Cho Lo (EL. 1,056 m), while the eastern boundary is the mountainous terrains extending southward at elevations of 1,500 to 1,800 m from Mt. Phate Do (EL. 1,821 m).

3.3.2 Geology

The project area, as shown in Fig. 3-1, consists mainly of Paleozoic and Mesozoic sedimentary rocks, and Mesozoic granite.

Paleozoic formations ranging from Cambrian to Carboniferous age may be divided into formations which are mainly non-calcareous rocks and the Ordovician formations which are mainly limestone. The former are widely distributed centered at the southern and eastern parts of the project area, while the latter are distributed in band-form in the north-south direction inside the formations that are mainly non-calcareous rocks.

Paleozoic formations ranging from Carboniferous to Permian age and Triassic formations are both mainly of non-calcareous rocks and are distributed making up most of the northwestern part of the project area.

Granite is intruded in Paleozoic formations at the entire eastern part of the project area and is distributed in the north-south direction as a slender rock body approximately 10 to 20 km in width.

Mesozoic orogenic movements of the two time phases of latest Triassic to Jurassic and Jurassic to Cretaceous have occurred in the northern part of Thailand including this area, the present geologic structure being dominated by this orogenic movement, and structures in the north-south to northwest-southeast directions are prominent. This project area, because of the influence of the above, has strikes of strata, strikes of folds, and strikes of remarkable faults that are chiefly north-south to northwest-southeast.