

the sediment are  $23.4 \times 10^6$ ,  $35.6 \times 10^6$ , and  $55.6 \times 10^6 \text{ m}^3$  respectively. They correspond to 3.6, 41.4 and 12.0% of the total storage volume of the each reservoir, respectively. The sediment levels of the each reservoir are EL. 191, 246, and 294m respectively, on the assumption that the sediment lies in horizontal.

#### 4.6 Flood Analysis.

Probable Maximum Precipitation analysis has been already performed in the Yuam river basin. The value of PMF (Probable Maximum Flood)  $6,200 \text{ m}^3/\text{s}$  at Lower Yuam project site is obtained as a result of it. Flood discharge of each dam site is calculated with Creager's method in this study. PMF at Lower Yuam site was taken into consideration for this analysis. PMF  $6,200 \text{ m}^3/\text{s}$  at Lower Yuam site is in the case of the coefficient C of Creager equation being 40. The comparison of design flood of various dam sites in Thailand is shown in Fig. 4-20.

The Ngao river has a lot of discharge and specific run-off is  $4.95 \text{ m}^3/\text{s} - \text{day}/100 \text{ km}^2$ . This is almost the same as 4.69 of Khao Laem site.

Coefficient C of Creager's equation at this site is 56. Design flood of the Ngao river basin is calculated by assuming the coefficient C 55. That of the Yuam river and the Rit river basin is assumed to be 30. Design flood of each dam site is shown in Table 4-19.

Table 4-1 Gaging and Observatory Stations of Nam Yuam River Basin

NO.	River	Station	Location	Code	Drainage Area ( km <sup>2</sup> )	Period
1	Nam Mae Yuam	Sop Han	Lat. 18°12.2' N Long. 97°56.1' E	NEA	2 496	1966-
2	Nam Mae Yuam	Ban Tha Rua Pha Lae	Lat. 17°50' N Long. 97°54.8' E	NEA	5 770	1968-
3	Nam Mae Rit	Ban Mae Suat	Lat. 17°53'30"N Long. 97°57'48"E	EGAT	1 376	ARR.1.1983-
4	Nam Mae Ngao	Ban Mae Ngao	Lat. 17°51' 18"N Long. 97°58'12"E	EGAT	935	MAY 1.1984-
5	Nam Mae Yuam	Ban Wang Khan	Lat. 18°23' 18"N Long. 97°58'12"E	EGAT	1974	MAY 12.1984-
6	Nam Mae Yuam	Rid Weir	Lat. 18°21'56"N Long. 97°56'06"E	RID	2 617	1976-
7		Mae Sariang	Lat. 18°9.8' N Long. 97°58' E	MD	—	1950-

Table 4-2 Monthly List of Daily Average Precipitation at Each Observatory Station

Mon. Obs. Station	(Unit: mm)												Annual Total	Annual Average
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.		
Mae La Luang ( '67 - '84)	0.44	0.07	0.18	1.47	5.95	6.13	6.92	9.57	7.40	3.68	1.25	0.53	1,334.9	3.66
Sop Han ( '67 - '84)	0.38	0.13	0.21	1.03	5.36	5.84	6.48	7.13	7.22	3.51	0.62	0.33	1,173.1	3.21
Chom Chaeng ( '69 - '84)	0.35	0.12	0.25	1.16	5.26	5.91	5.92	7.28	5.60	3.68	0.58	0.34	1,115.8	3.06
Ban Tha Rua ( '69 - '84)	0.54	0.08	0.20	1.48	7.35	10.46	10.46	11.90	6.95	3.81	0.97	0.33	1,669.7	4.57
Mae Sariang ( '52 - '84)	0.30	0.16	0.15	1.17	5.23	6.06	6.13	7.58	6.41	3.81	0.58	0.28	1,161.2	3.18

Table 4-3 Monthly List of Daily Average Evaporation at Each Observatory Station

Mon. Obs. Station	(Unit: mm)												Annual Total	Annual Average
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.		
Mae La Luang ( '70 - '83)	3.29	4.38	5.48	6.22	4.76	3.59	3.31	2.55	3.61	3.47	3.25	3.28	1,442.24	3.95
Sop Han ( '68 - '83)	2.72	4.19	5.65	6.55	5.10	3.20	2.66	2.57	3.27	3.15	2.75	2.47	1,344.69	3.68
Ban Tha Rua ( '68 - '83)	2.78	3.36	4.92	6.06	4.57	2.99	2.55	23.0	2.93	3.34	2.80	2.68	1,254.62	3.44

**Table 4-4 Estimated River Runoffs of  
The Yuam River at Sop Han in 1979  
in cms. day, CA = 2496 sq. km**

Month	Runoffs in 1979 cms. day
Jan	375.90
Feb	206.35
Mar	118.53
Apr	117.65
May	308.45
Jun	364.23
Jul	524.51
Aug	1106.00
Sep	907.28
Oct	919.22
Nov	312.59
Dec	182.35
<b>Total</b>	<b>5443.06</b>

Table 4-5 Estimated and Observed Monthly Runoff of  
The Yuam River at Sop Han

\*\*\*\*\*  
Estimated & Observed Monthly Runoff of Nam Yuam at Sop Han cms 2 495km2 1960-84 (6 0-66%79 estimate d)  
\*\*\*\*\*

cms. day

Note:

- 1) 1967-78 & 1980-84: Observed runoff at Sop Han.
- 2) 1979: Estimated runoff by regression on river runoff measured at RID weir, Mae Sariang.
- 3) CA=2496 km<sup>2</sup> unit=cms.day

Subfile Totals		1963	1966	1969	1972	1975	1978	1981	1984
Y1960									
MRJAN	284.100	278.300	281.900	189.600	276.250	388.600	434.720	216.490	176.320
MRFEB	133.500	223.600	167.000	122.350	187.330	191.250	238.100	136.770	128.830
MRMAR	95.300	155.200	439.500	123.600	151.800	136.000	171.480	104.950	172.970
MRAPR	96.300	110.700	88.000	104.100	157.590	90.000	125.310	84.120	114.540
MRMAY	327.200	113.500	288.800	172.350	144.520	194.450	475.090	108.240	129.930
MRJUN	407.300	333.200	355.200	359.850	264.690	389.050	212.260	262.890	536.940
MRJUL	727.800	737.800	859.300	643.300	721.820	734.300	1458.600	657.910	864.800
MRJUL	2936.200	1427.500	2287.600	3250.500	2158.400	2410.200	2427.800	1735.300	1595.400
MRSEP	1889.300	1991.800	1436.400	2360.800	1056.500	3629.300	3050.800	1222.700	1431.900
MRDCT	2249.400	915.300	1044.000	1044.000	842.300	2043.800	2000.600	753.000	1171.100
MRNOV	1103.100	1035.600	428.800	757.900	792.500	928.100	867.100	538.600	523.100
MRDEC	694.300	573.500	283.100	468.700	342.600	598.500	434.700	313.400	283.380
Y1961									
MRJAN	424.100	293.900	221.100	307.580	256.740	344.870	373.900	197.200	197.200
MRFEB	246.300	211.300	141.090	197.120	160.100	223.470	206.350	118.420	118.420
MRMAR	207.300	163.800	111.390	166.280	128.720	161.320	118.530	95.450	95.450
MRAPR	145.900	131.600	91.720	167.940	94.080	115.620	117.650	124.010	124.010
MRMAY	252.800	253.100	213.410	583.640	288.220	181.620	388.450	172.380	172.380
MRJUN	358.300	276.200	338.400	604.330	325.740	198.360	364.230	576.510	576.510
MRJUL	751.300	1009.700	532.820	790.700	1211.800	447.140	524.510	573.620	573.620
MRJUL	2518.100	1795.600	1527.000	2246.700	3816.700	1118.500	1106.000	1510.800	1510.800
MRSEP	2446.700	2395.800	2778.200	2276.000	3886.700	1577.100	907.280	2082.500	2082.500
MRDCT	1119.600	1085.100	1163.300	1523.800	1596.800	1425.100	919.320	1700.600	1700.600
MRNOV	539.200	611.900	518.400	706.700	584.500	678.100	312.590	633.500	633.500
MRDEC	598.100	394.000	280.980	575.300	332.380	512.300	182.350	383.880	383.880
Y1962									
MRJAN	469.100	213.200	196.590	313.430	318.900	326.100	134.710	260.750	260.750
MRFEB	205.300	251.700	123.980	207.140	211.070	167.300	91.820	168.160	168.160
MRMAR	141.800	173.400	111.040	186.110	156.780	127.080	72.820	120.600	120.600
MRAPR	119.800	126.200	127.360	136.350	123.480	158.020	67.510	97.200	97.200
MRMAY	307.100	216.800	250.850	365.190	276.510	183.340	306.970	76.090	76.090
MRJUN	412.900	366.200	408.980	606.550	339.820	240.700	585.730	175.210	175.210
MRJUL	847.000	607.400	801.000	1982.000	543.000	550.700	815.900	263.190	263.190
MRJUL	1773.900	1820.800	1629.100	2308.800	1347.100	1267.000	1328.300	574.200	574.200
MRSEP	2475.400	1396.200	1290.700	2019.500	1524.000	2837.600	2927.500	773.100	773.100
MRDCT	1761.300	1601.200	1405.700	1362.600	882.600	1570.000	1343.400	823.200	823.200
MRNOV	959.800	835.100	543.400	570.400	895.800	816.300	589.200	524.600	524.600
MRDEC	535.400	500.400	299.540	417.700	375.690	545.000	394.210	311.860	311.860

**Table 4-6 Estimated and Observed Monthly Runoff of  
The Yuam River at Ban Tha Rua**

cms. day

\*\*\*\*\*  
Estimated & Rest  
of Monthly Run  
off of Ban Yuam  
at Ban Tha Rua c  
ms 5770kw2 1960-  
84(1960-88estima  
ted)  
\*\*\*\*\*

Note:

- 1) 1976-84: Observed runoff at Ban Tha Rua + Irrigation water-take at RID weir, Mae Sariang.
- 2) 1969-75: Observed runoff at Ban Tha Rua.
- 3) 1960-68: Estimated runoff by Time Variant Unit Hydrograph method.
- 4) CA-5770 km<sup>2</sup> unit-rms.day

Subfile Totals

	1963	1966	1969	1972	1975	1978	1981	1984
Y1960								
MRJAN	891.800	970.300	834.500	1026.000	1204.100	1034.750	1024.740	786.250
MREFE	558.300	710.800	586.500	837.700	717.600	696.740	555.290	525.890
MRMAR	405.800	593.700	456.500	593.600	669.100	550.590	453.250	419.330
MRAPR	403.000	460.000	420.230	575.800	456.500	413.000	383.580	425.970
MRMAY	1084.300	811.900	865.200	573.600	774.300	706.340	477.670	415.130
MRJUN	1721.700	1716.100	2675.200	1030.200	2140.800	722.010	1743.780	3463.410
MRJUL	3339.700	4529.500	4334.100	6112.900	4381.700	4204.310	4302.350	3797.370
MRAUG	9796.700	8337.200	19332.200	9327.000	6337.900	7639.340	8152.940	7584.320
MARSEP	6570.300	5923.000	11475.000	5553.000	8244.000	6393.410	4553.120	6119.850
MRNOV	5372.200	4014.000	3986.600	5669.000	5669.000	4428.070	3421.530	4260.690
MRDEC	2347.400	1492.400	3231.000	2882.100	2578.900	1831.320	2286.480	1932.940
Subfile Totals	16855.900	1074.200	2200.300	1363.000	1537.900	1076.710	1451.270	1219.470
Y1961								
MRJAN	1475.400	742.000	1430.700	1241.800	1116.200	778.620	935.990	
MREFE	1029.500	458.000	920.300	743.200	761.500	535.900	575.420	
MRMAR	360.100	383.400	781.200	679.500	577.900	412.100	466.800	
MRAPR	586.300	344.200	739.400	481.500	418.400	363.350	406.950	
MRMAY	386.800	743.100	1326.800	589.500	327.800	587.000	835.720	
MRJUN	1719.200	1277.800	2078.900	1922.700	1566.800	728.060	3390.670	
MRJUL	3358.200	382.200	4483.900	4131.700	3578.400	1912.340	5447.160	
MRAUG	8754.800	7432.300	7661.000	8200.000	6854.000	7260.640	12434.700	
MARSEP	7541.100	6637.900	7878.000	8674.000	5659.000	3623.250	8222.560	
MRNOV	4233.600	4111.400	4519.000	5595.000	4802.100	3451.070	5427.610	
MRDEC	1330.300	1349.200	2316.200	2649.100	2503.040	1456.540	2284.930	
Subfile Totals	1512.900	1405.100	1727.500	1715.400	1520.090	890.570	1356.620	
Y1962								
MRJAN	1190.900	920.300	1054.600	1093.100	1632.810	614.920	905.270	
MREFE	862.000	658.700	714.600	793.400	720.930	441.550	547.680	
MRMAR	591.000	621.200	629.200	551.600	592.240	410.930	429.190	
MRAPR	493.100	404.400	508.000	441.300	543.090	352.280	320.290	
MRMAY	1050.700	750.300	924.300	964.600	633.690	1052.600	324.830	
MRJUN	1910.100	1070.700	2519.300	2166.000	901.710	1548.230	770.250	
MRJUL	4205.600	3861.700	1000.000	3957.600	2270.460	2989.730	904.870	
MRAUG	6709.400	6303.800	11150.000	7083.400	5343.940	4531.920	2902.270	
MARSEP	7296.200	4034.600	8033.300	5245.000	3633.240	2866.030	3678.590	
MRNOV	4835.500	3684.700	4433.600	3536.200	3639.530	5814.770	3732.230	
MRDEC	2338.900	1984.700	2281.500	2494.100	2221.300	2532.960	2214.450	
Subfile Totals	1701.300	1420.000	1466.700	1233.900	1391.020	1643.310	1232.610	

Table 4-7 Scattergram and Regression, Nam Mae Rit

Nam Mae Rit

Scattergram	Regression
Y=Daily Runoff of Nam Mae Rit at Ban Mae Suat cms EGAT APR83-MAR 85	Model: Y=b0+b1*X1+b2*X2
X1=Daily Runoff of Nam Yuam at S or Han cms CA=2496sakh JAN1983-D EC1984 (4days in 1984 is estimated)	Coeffs of Normal Equations:
X2=Recovered Daily Runoff of Nam Yuam at Ban Tha Rua cms CA=5770 sakh JAN1983-MAR 1985	A11= 641 A12= 10643.86 A13= 46939.115 B1= 7331.24 A21= 10643.86 A22= 399635.8064 A23= 1536443.63865 B2= 218666.112 A31= 46939.115 A32= 1536443.63865 A33= 7169910.36788 B3= 995177.57162
Period used for Scattergram Plot 2 years No of points= 641	Solution
Range of Y (cms) 1.84 - 76.4	b0= 2.3450941098 b1= .05734496051 b2= .11115810224
Range of X1 (cms) ) .68 - 217	Error
Range of X2 (cms) ) 7.3 - 580.041	Err1= .00000002 Err2= .000001 Err3= .000006
Y file:DRRit X1 file:DR113H X2 file:DR114W	Correlation Coefficient R2= .816817446532 Corr. coeff.= .903779534266

Table 4-8 Scattergram and Regression, Nam Mae Ngao

Nam Mae Ngao

Scattergram	Regression
Y=Daily Runoff of Nam Mae Ngao at Ban Mae Ngao cms EGAT CA=935sq km May1984-Mar1985	Model: $Y=b_0+b_1*X_1+b_2*X_2$
X1=Daily Runoff of Nam Yuan at Sop Han cms NEA C A=2496sqkm JAN1984-DEC1984	Coeffs of Normal Equations:
X2=Recovered Daily Runoff of Nam Yuan at Ban Tha Rua cms CA=5770 sqkm JAN1984-MAR 1985	A11= 245 A12= 6537.55 A13= 28793.171 B1= 15724.64 A21= 6537.55 A22= 319823.9567 A23= 1194144.48182 B2= 633339.139 A31= 28793.171 A32= 1194144.48182 A33= 5592099.61498 B3= 3134175.9769
Period used for Scattergram Plot 1 years	
No of points= 245	Solution
Range of Y (cms) 4 - 419	b0=-2.089383883 b1=-.54183348322 b2= .68692685984
Range of X1 (cms) 2.15 - 217	Error
Range of X2 (cms) 9.88 - 580.041	Err1=-.0000003 Err2=-.000012 Err3=-.00005
Y file:DRNgao X1 file:DR113y X2 file:DR114Y	Correlation Coefficient R2= .911485981406 Corr. coeff.= .954717749614



Table 4-9 Scattergram and Regression, Wang Khan

Wang Khan

Scattergram	Regression
Y=Daily Runoff of Nam Mae Yuan at Ban Wang Kan cms EGAT CA=1173s skm 12MAY1984-MAR1985	Model: Y=b0+b1*X
X=Daily Runoff of Nam Yuan at Sop Han cms NEA CA=2496s skm JAN1984-DEC1984	Coeffs of Normal Equations: A11= 234 A12= 6486.57 B1= 4900.93 A21= 6486.57 A22= 319574.4865 B2= 226957.126
Period used for Scattergram Plot 1 years	Solution b0= 2.8753818955 b1= .65182224758
Range of Y (cms) 1.42 - 142	Error Err1=-.000000004 Err2=-.0000002
Range of X (cms) 2.15 - 217	Correlation Coefficient R2= .886285621289 Corr. coeff. = .941427438149
Y file:DRWKan X file:DR113y	

Table 4-10 Estimated and Observed Monthly Runoff of The Rit River at Ban Mae Suat

Estimated & Observed Monthly Runoff of Nam Nae Rit at Ban Mae Suat at CMS CH=1376sq km JAN1960-DEC1984

File:NR7

	Y1960	Y1963	Y1966	Y1969	Y1972	Y1975	Y1978	Y1981	Y1984
JAN	186.42	214.87	194.97	181.89	202.67	228.83	212.65	199.02	146.81
FEB	141.49	189.32	159.28	138.46	156.31	156.39	156.76	135.23	119.13
MAR	121.19	153.00	144.66	131.64	147.38	153.87	143.73	129.10	175.95
APR	120.95	128.13	117.30	128.03	143.39	126.26	123.45	117.81	115.02
MAY	210.33	126.57	174.83	178.75	149.30	169.92	161.25	132.00	88.03
JUN	285.69	322.45	281.90	388.36	149.30	330.63	163.78	379.26	462.82
JUL	484.10	577.00	623.70	591.36	793.54	599.64	623.74	588.66	415.58
AUG	132.45	788.02	1133.82	2414.13	1266.59	217.64	1061.09	1078.47	275.20
SEP	911.99	879.69	822.86	1481.27	781.54	1206.92	955.98	646.58	908.60
OCT	801.41	621.77	483.75	746.60	564.14	831.52	679.72	436.55	898.60
NOV	452.43	411.99	251.69	473.63	433.94	410.24	323.64	355.39	394.00
DEC	342.79	292.29	236.53	344.15	293.99	279.99	217.31	251.99	251.89
Sum	5391.30	4705.01	4535.29	7199.27	5136.50	5411.16	4822.10	4410.06	4742.83

	Y1982	Y1985	Y1986	Y1987	Y1988
JAN	259.47	207.14	166.02	197.67	193.10
FEB	199.26	182.78	129.75	184.92	159.87
MAR	178.24	156.89	119.70	169.07	138.42
APR	144.23	136.64	114.17	162.17	134.45
MAY	182.96	175.85	165.68	235.89	171.54
JUN	282.43	228.62	226.55	335.97	305.53
JUL	542.87	779.81	521.12	618.13	534.98
AUG	1191.80	1001.61	1105.77	1053.11	835.38
SEP	1093.25	1094.30	992.65	1076.57	835.38
OCT	660.96	553.38	595.93	662.40	575.33
NOV	311.25	313.88	317.60	368.34	333.44
DEC	274.30	252.29	232.99	297.71	283.44
Sum	5282.02	5088.19	4710.93	5460.11	4837.84

	Y1989	Y1992	Y1995	Y1997	Y1998
JAN	259.47	207.14	166.02	197.67	193.10
FEB	199.26	182.78	129.75	184.92	159.87
MAR	178.24	156.89	119.70	169.07	138.42
APR	144.23	136.64	114.17	162.17	134.45
MAY	182.96	175.85	165.68	235.89	171.54
JUN	282.43	228.62	226.55	335.97	305.53
JUL	542.87	779.81	521.12	618.13	534.98
AUG	1191.80	1001.61	1105.77	1053.11	835.38
SEP	1093.25	1094.30	992.65	1076.57	835.38
OCT	660.96	553.38	595.93	662.40	575.33
NOV	311.25	313.88	317.60	368.34	333.44
DEC	274.30	252.29	232.99	297.71	283.44
Sum	5282.02	5088.19	4710.93	5460.11	4837.84

	Y1999	Y2002	Y2005	Y2007	Y2008
JAN	148.77	215.12	216.55	216.55	216.55
FEB	122.55	155.99	165.47	165.47	165.47
MAR	127.55	139.78	146.19	146.19	146.19
APR	113.38	139.78	123.43	123.43	123.43
MAY	207.30	153.63	175.13	175.13	175.13
JUN	226.04	184.04	251.44	251.44	251.44
JUL	226.04	184.04	496.10	496.10	496.10
AUG	451.82	173.97	898.71	898.71	898.71
SEP	62.34	129.37	789.83	789.83	789.83
OCT	41.82	62.34	688.21	688.21	688.21
NOV	134.91	267.29	387.47	387.47	387.47
DEC	182.15	271.04	271.04	271.04	271.04
Sum	3677.50	4609.62	4609.62	4609.62	4609.62

	Y1999	Y2002	Y2005	Y2007	Y2008
JAN	148.77	215.12	216.55	216.55	216.55
FEB	122.55	155.99	165.47	165.47	165.47
MAR	127.55	139.78	146.19	146.19	146.19
APR	113.38	139.78	123.43	123.43	123.43
MAY	207.30	153.63	175.13	175.13	175.13
JUN	226.04	184.04	251.44	251.44	251.44
JUL	226.04	184.04	496.10	496.10	496.10
AUG	451.82	173.97	898.71	898.71	898.71
SEP	62.34	129.37	789.83	789.83	789.83
OCT	41.82	62.34	688.21	688.21	688.21
NOV	134.91	267.29	387.47	387.47	387.47
DEC	182.15	271.04	271.04	271.04	271.04
Sum	3677.50	4609.62	4609.62	4609.62	4609.62

	Y1999	Y2002	Y2005	Y2007	Y2008
JAN	148.77	215.12	216.55	216.55	216.55
FEB	122.55	155.99	165.47	165.47	165.47
MAR	127.55	139.78	146.19	146.19	146.19
APR	113.38	139.78	123.43	123.43	123.43
MAY	207.30	153.63	175.13	175.13	175.13
JUN	226.04	184.04	251.44	251.44	251.44
JUL	226.04	184.04	496.10	496.10	496.10
AUG	451.82	173.97	898.71	898.71	898.71
SEP	62.34	129.37	789.83	789.83	789.83
OCT	41.82	62.34	688.21	688.21	688.21
NOV	134.91	267.29	387.47	387.47	387.47
DEC	182.15	271.04	271.04	271.04	271.04
Sum	3677.50	4609.62	4609.62	4609.62	4609.62

Table 4-11 Estimated and Observed Monthly Runoff of The Ngao River at Ban Mae Ngao

Estimated & Observed Monthly Runoff of Ban Mae Ngao  
 300 cc. Ban Mae N  
 300 cms. CA-33559  
 km JAN1960-DEC19  
 84

File:MR8

	Y1960	Y1966	Y1969	Y1972	Y1975	Y1978	Y1981	Y1984
JAN	394.21	449.51	440.10	490.90	551.81	410.49	521.86	279.80
FEB	254.02	333.81	272.75	317.00	330.82	291.11	248.85	230.86
MAR	163.02	268.22	188.72	260.75	314.99	230.54	189.73	183.75
APR	160.54	145.53	163.59	247.48	202.15	152.14	155.24	167.88
MAY	503.13	364.04	438.19	323.48	361.77	323.58	294.72	188.80
JUN	898.42	923.18	1580.02	542.80	1197.10	318.29	992.74	2163.24
JUL	1037.33	2584.66	2560.89	3743.68	2533.54	2082.43	2534.17	2417.70
AUG	5073.67	4438.60	1148.60	5378.80	2996.73	3867.45	4595.48	4714.20
SEP	3425.47	3238.22	6546.66	3385.47	3535.62	2676.11	2402.49	3006.00
OCT	2402.01	1661.37	3164.15	2217.36	2613.67	1893.56	1874.33	1807.50
NOV	1291.89	666.57	1787.35	1473.99	1205.97	725.49	1215.11	878.60
DEC	987.35	520.45	1192.73	1832.79	683.83	439.33	762.35	548.10
SUM	17391.02	15363.59	29818.73	19314.57	16528.00	13353.52	15698.97	16886.93

	Y1961	Y1967	Y1970	Y1973	Y1976	Y1979	Y1982
JAN	719.46	325.59	792.59	643.74	515.13	266.42	471.35
FEB	509.76	173.84	501.23	365.35	341.43	197.82	272.62
MAR	414.56	138.75	381.77	332.26	244.81	154.10	204.18
APR	259.61	122.54	354.35	217.11	162.89	123.18	170.33
MAY	407.96	335.77	667.31	463.44	405.47	171.34	415.33
JUN	923.62	593.85	1035.58	1031.59	878.65	240.65	1954.18
JUL	2181.72	2311.40	2597.23	2116.83	2151.87	964.68	3366.33
AUG	4585.38	4969.45	3980.45	3770.96	4037.40	4529.58	7658.41
SEP	3788.23	3321.53	4115.73	4066.96	2970.12	1388.78	4457.23
OCT	2575.74	2129.88	2213.32	2965.53	2461.77	1307.81	2742.17
NOV	935.25	994.16	1145.48	1440.37	1289.32	768.50	1163.66
DEC	649.71	749.64	810.19	933.50	701.85	448.20	659.14
SUM	17951.00	15941.18	18597.11	18348.63	16159.11	11611.04	23535.33

	Y1962	Y1968	Y1971	Y1974	Y1977	Y1980	Y1983
JAN	498.69	534.47	524.58	532.39	893.91	294.65	413.81
FEB	417.02	321.34	320.15	310.33	246.08	192.98	226.61
MAR	265.10	193.45	260.40	235.46	273.21	178.06	164.72
APR	210.16	215.84	166.59	197.06	224.77	142.74	110.19
MAY	491.07	333.33	373.35	443.03	271.20	431.97	117.13
JUN	1023.88	1030.50	1939.25	1249.52	426.33	693.48	377.00
JUL	1629.90	1571.31	5751.31	2059.61	1196.49	1546.93	414.23
AUG	3584.72	3555.35	6343.49	4050.51	2919.68	3331.33	1617.77
SEP	3693.70	3188.18	4368.26	2719.51	4412.57	1976.67	1976.67
OCT	2213.77	1504.11	2276.07	1927.35	1584.66	2050.30	2050.30
NOV	1020.21	857.72	1191.16	1164.68	1920.80	1335.14	1174.35
DEC	813.99	690.04	730.17	613.63	595.47	830.48	612.33
SUM	16612.14	14493.06	23643.71	15758.08	14165.09	16417.77	9257.62

Table 4-12 Estimated and Observed Monthly Runoff of The Yuam River at Wang Khan

Estimated & Observed Monthly Runoff of Nam Yuam at Wang Khan cms  
 CR=1173586 JRN  
 1960-DEC1984

File:MR9

	Y1960	Y1963	Y1966	Y1969	Y1972	Y1975	Y1978	Y1981	Y1984
JAN	271.90	288.11	270.46	212.71	269.19	342.42	372.49	220.24	294.05
FEB	173.44	232.35	195.34	166.77	205.61	205.16	235.70	169.65	167.35
MAR	148.47	187.69	177.37	189.69	188.07	177.77	200.90	157.59	136.89
APR	149.12	158.54	143.70	154.11	188.97	144.91	167.93	141.08	160.91
MAY	300.08	160.37	242.28	201.47	183.33	215.87	208.25	159.68	105.18
JUN	352.44	304.00	518.38	320.81	258.78	339.84	224.61	257.61	338.06
JUL	561.98	567.39	648.34	508.44	459.10	567.76	1040.52	517.97	636.33
AUG	2005.75	1019.41	1581.73	2214.39	1496.02	1660.15	1671.62	1220.29	1102.60
SEP	1321.32	1388.33	1925.23	1625.37	774.90	2582.14	2074.83	883.23	1114.60
OCT	1556.74	1240.26	684.36	1769.63	638.16	1551.68	1393.16	583.86	1009.50
NOV	887.33	756.67	366.50	580.27	692.82	691.31	651.45	437.92	414.80
DEC	540.47	465.92	271.25	394.63	312.44	475.38	372.47	293.41	244.72
SUM	8189.04	6748.66	5924.93	7317.99	5677.39	8954.69	8608.93	5051.81	5634.79

	Y1961	Y1964	Y1967	Y1970	Y1973	Y1976	Y1979	Y1982
JAN	363.43	278.31	233.24	289.61	262.99	213.32	334.15	217.66
FEB	247.32	224.31	172.47	203.39	184.86	229.04	215.01	157.69
MAR	231.63	193.35	161.73	197.51	173.03	194.28	166.33	151.34
APR	181.55	172.20	146.04	155.72	147.57	161.81	162.94	167.03
MAY	351.44	238.56	238.23	469.56	263.96	207.51	230.18	201.49
JUN	320.41	266.74	306.83	480.17	298.57	215.53	323.66	462.83
JUL	577.34	746.27	436.43	604.52	679.00	300.58	431.01	483.82
AUG	1732.41	1260.07	1084.46	1563.57	2251.02	818.19	318.64	1073.90
SEP	1635.73	1652.46	1097.14	1569.80	2374.22	1114.24	677.64	1443.67
OCT	818.12	795.57	847.36	1082.37	1129.35	1018.04	688.29	1197.61
NOV	438.68	486.30	424.16	546.39	467.24	528.25	290.00	499.18
DEC	477.10	343.75	272.27	464.12	305.78	423.05	297.98	339.35
SUM	7315.30	6657.69	6210.39	7662.83	8638.19	5604.26	4397.29	6374.02

	Y1983	Y1986	Y1971	Y1974	Y1977	Y1980
JAN	332.85	217.37	293.46	296.93	301.68	176.93
FEB	220.32	164.19	215.52	218.08	189.35	190.11
MAR	178.97	191.50	210.44	191.32	171.96	136.59
APR	163.96	169.27	175.13	166.74	186.25	130.26
MAY	286.94	352.64	327.11	269.36	289.22	138.72
JUN	356.11	325.57	481.52	307.23	243.14	468.04
JUL	639.30	483.26	1381.04	443.06	449.08	629.95
AUG	1704.89	1276.54	1594.05	967.20	951.68	463.40
SEP	1704.49	938.95	1402.60	1079.63	590.17	590.17
OCT	1238.03	1132.97	912.12	664.42	1112.43	964.78
NOV	713.65	632.12	463.26	670.80	618.46	428.36
DEC	436.19	410.31	361.39	334.01	444.37	292.40
SUM	7577.19	6335.09	7817.74	5808.78	6778.19	653.93

Table 4-13 Monthly Comparison of Daily Average Runoff, Observed and Estimated (by Tank Model)

(Unit: m<sup>3</sup>/s, exmp. Ann. Total (m<sup>3</sup>/s.day))

Mon. Year	(Unit: m <sup>3</sup> /s, exmp. Ann. Total (m <sup>3</sup> /s.day))												Annual Total (m <sup>3</sup> /s.day)	Annual Average
	Jan.	Feb.	Mar.	Apr.	May	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.		
1970	48.09	34.65	25.20	24.65	49.25	69.23	145.13	247.13	262.60	145.77	77.21	55.73	36,186	99.14
	30.03	23.25	16.53	12.05	26.10	43.88	54.76	163.55	258.70	219.09	111.33	64.93	31,254	85.63
1971	35.65	25.52	20.01	14.71	29.82	83.98	323.55	359.68	268.10	142.05	76.05	47.96	43,720	119.78
	40.90	33.16	29.04	20.41	14.81	18.36	154.76	181.15	230.67	133.48	64.29	39.31	29,338	80.38
1972	33.12	24.06	19.15	19.19	17.21	36.34	197.19	310.55	195.10	128.60	95.40	60.26	34,827	95.16
	31.56	24.31	17.32	13.40	13.20	12.70	24.17	116.09	129.23	159.28	92.61	55.62	21,078	57.59
1973	40.03	26.55	21.92	16.05	31.63	64.09	133.28	264.52	289.13	180.16	88.30	55.34	37,004	101.38
	32.43	26.15	19.56	13.59	16.58	22.38	51.21	147.37	196.02	136.46	65.19	36.94	23,305	63.85
1974	35.26	25.12	17.15	16.18	31.12	72.20	127.66	227.53	174.83	116.01	83.14	41.42	29,574	81.03
	28.89	22.15	15.54	12.70	12.50	30.84	87.48	191.97	142.29	116.48	70.65	40.30	23,603	64.66
1975	38.84	25.63	21.92	15.22	24.98	71.36	140.70	205.09	274.80	182.87	85.96	50.25	34,723	95.13
	41.86	28.53	22.70	15.79	13.95	36.55	83.14	113.47	132.39	94.92	51.15	31.57	20,325	55.69
1976	36.01	26.26	18.64	13.95	26.70	50.89	115.43	221.10	188.63	154.91	82.99	48.36	30,111	82.27
	25.97	20.24	14.84	12.82	12.70	14.53	44.54	112.68	104.83	75.40	46.11	26.90	15,639	42.73
1977	52.73	24.76	18.37	17.57	20.02	29.29	71.02	170.48	290.53	115.72	72.43	44.48	28,265	77.44
	31.45	20.60	15.45	15.62	12.14	15.01	30.71	77.67	174.65	119.01	63.53	39.28	18,738	51.34
1978	32.31	23.49	15.80	11.67	21.91	23.35	133.64	244.19	211.10	140.91	58.89	34.66	29,134	79.82
	30.03	24.60	19.17	13.38	13.53	13.96	83.26	133.52	184.34	171.03	82.15	44.01	24,835	68.04
1979	24.92	19.14	13.29	12.11	18.94	23.24	58.62	241.01	116.29	108.15	47.23	28.17	21,788	56.69
	32.19	24.84	17.75	12.72	12.00	27.33	32.79	129.39	144.22	130.45	59.01	32.84	20,004	54.80
1980	17.96	13.29	10.92	9.06	32.84	51.58	94.70	143.79	327.37	185.26	82.61	52.57	31,183	85.20
	25.58	19.04	13.25	12.00	66.20	47.05	69.28	110.32	279.99	197.98	106.01	63.82	30,843	84.27

Note: Upper line is observed runoff.  
Lower line is estimated runoff.

Table 4-14 Monthly Runoffs Estimated by Time Variant Unit Hydrograph Method

	Runoff Estimate of NAM YUAM at Ban Tha Rua (CA=4890km <sup>2</sup> ), m <sup>3</sup> /s day										
	1970	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980
JAN	31.99 991.7	32.97 1022.2	26.73 828.6	39.98 1239.4	28.02 868.5	38.89 1205.5	24.61 762.8	32.21 998.5	32.31 1001.7	27.42 850.0	22.89 709.7
FEB	23.91 669.5	25.37 710.4	19.97 579.2	23.45 656.7	21.90 613.2	25.67 718.8	18.90 548.0	24.66 690.5	27.00 756.0	21.21 593.8	15.94 462.2
MAR	17.01 527.4	27.84 863.0	15.48 479.9	21.91 679.2	13.86 429.7	19.31 598.5	14.43 447.2	21.55 668.1	17.36 538.2	14.51 449.9	11.53 357.3
APR	15.79 473.7	19.35 580.5	14.38 431.5	16.04 481.2	14.72 441.7	16.36 490.8	12.62 378.7	19.01 570.4	14.07 422.2	13.26 397.7	10.58 317.4
MAY	36.25 1123.9	28.83 893.8	17.16 532.1	29.20 905.3	24.71 766.1	27.26 845.1	20.99 650.6	27.68 858.1	25.10 778.2	22.51 697.9	32.87 1018.9
JUN	59.58 1787.5	62.63 1878.9	43.24 1297.3	49.15 1474.4	52.14 1564.3	59.53 1786.0	47.00 1409.9	45.71 1371.4	43.04 1291.2	47.01 1410.4	51.51 1545.2
JUL	102.19 3167.8	178.55 5535.1	158.85 4924.3	108.50 3363.5	111.53 3457.3	104.01 3224.4	119.85 3715.4	102.37 3173.4	133.65 4143.0	68.79 2132.4	109.04 3380.1
AUG	230.27 7138.3	242.39 7514.2	268.39 8320.2	219.09 6791.8	213.92 6631.4	204.47 6338.7	220.91 6848.1	179.90 5576.9	255.83 7930.8	240.99 7470.7	135.92 5763.6
SEP	247.19 7415.7	170.97 5129.1	174.07 5222.1	295.99 8879.7	187.15 5614.5	217.02 6510.6	188.65 5659.6	255.67 7670.2	218.27 6548.6	180.77 5423.1	327.32 9819.5
OCT	152.11 4715.5	114.75 3557.3	124.32 3853.8	157.15 4871.7	119.17 3694.2	128.41 3980.8	128.04 3969.1	156.92 4864.4	140.94 4369.1	108.26 3356.0	132.20 5558.3
NOV	74.73 2241.9	65.40 1961.9	95.45 2863.6	78.64 2359.3	85.17 2555.2	64.07 1922.2	66.15 1984.6	72.44 2173.2	68.74 2062.3	52.91 1587.4	89.91 2697.3
DEC	50.80 1574.7	42.10 1305.0	60.24 1867.5	35.88 1112.2	46.05 1427.5	35.84 1110.9	48.38 1499.7	53.56 1660.5	39.93 1237.7	28.11 871.5	51.35 1591.7
Total											

From: Long Term Rainfall-Runoff Analysis, Proc of JSCE,  
NO.336 Aug 1983, pp 47-53.

Table 4-15 Ordinates of Time Variant Unit Hydrographs The Yuam River  
at Sop Han (R13336)

( CA = 2496 km<sup>2</sup> )

	01	02	03	04	05	06	07	08	09	10	11	12	Diagonal sums	
01	K0101 .06704													
02	K0201 .11686	K0202 .01044												
03	K0301 .01598	K0302 .08747	K0303 .01044											
04	K0401 .01389	K0402 .01044	K0403 .05348	K004 .01044										
05	K0501 .02625	K0502 .01389	K0503 .01044	K004 .01044	K005 .01044									
06	K0601 .02478	K0602 .02625	K0603 .01044	K004 .01044	K005 "	K006 .01044								
07	K0701 .08136	K0702 .01433	K0703 .02625	K004 .01044	K005 "	K006 .01044	K712 .00241							
08	K0801 .20242	K0802 .07054	K0803 .01044	K004 .01044	K005 "	K006 .01044	K712 .00241	" .00241						
09	K0901 .18925	K0902 .04737	K0903 .07054	K004 .01044	K005 "	K006 .01044	K712 .00241	" "	" .00241					
10	K1001 .17303	K1002 .01044	K1003 .04737	K004 .01044	K005 "	K006 .01044	K712 .00241	" "	" "	" .00241				
11	K1101 .01044	K1102 .09643	K1103 .01044	K004 .01044	K005 "	K006 .01044	K712 .00241	" "	" "	" "	" .00241			
12	K1201 .09664	K1202 .01044	K1203 .04051	K004 .01044	K005 "	K006 .01044	K712 .00241	" "	" "	" "	" "	K712 .00241		
13		K0102 .09091	K0103 .01044	K004 .01044	K005 "	K006 .01044	K712 .00241	" "	" "	" "	" "	K712 .00241		.13370
14			K0203 .01044	K004 .01044	K005 "	K006 .01044	K712 .00241	" "	" "	" "	" "	K712 .00241		.30359
15				K004 .01044	K005 "	K006 .01044	K712 .00241	" "	" "	" "	" "	K712 .00241		.08264
16					K005 .01044	K006 .01044	K712 .00241	" "	" "	" "	" "	K712 .00241		.08400
17						K006 .01044	K712 .00241	" "	" "	" "	" "	K712 .00241		.12453
18							K712 .00241	" "	" "	" "	" "	K712 .00241		.09533
19								" .00241	" "	" "	" "	K712 .00241		.26822
20									" .00241	" "	" "	K712 .00241		.34294
21										" .00241	" "	K712 .00241		.25591
22											" .00241	K712 .00241		.35575
23												K712 .00241	.07710	
													.24377	

Table 4-16 Ordinates of Time Variant Unit Hydrographs The Yuam River  
at Ban Tha Rua (R13336)

(CA = 5 770 km<sup>2</sup>)

	01	02	03	04	05	06	07	08	09	10	11	12	Diagonal sums	
01	K0101 .02082													
02	K0201 .14923	K0202 .01921												
03	K0301 .01921	K0302 .08602	K0303 .01921											
04	K0401 .01921	K0402 .01921	K0403 .01921	K004 .01921										
05	K0501 .03427	K0502 .01921	K0503 .01921	K004 .01921	K005 .01921									
06	K0601 .07754	K0602 .03427	K0603 .01921	K004 .01921	K005 "	K006 .01921								
07	K0701 .23488	K0702 .01921	K0703 .01921	K004 .01921	K005 "	K006 .01921	K712 .00444							
08	K0801 .25679	K0802 .17862	K0803 .01921	K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444						
09	K0901 .14704	K0902 .08910	K0903 .17862	K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444	" .00444					
10	K1001 .05758	K1002 .09424	K1003 .08190	K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444	" .00444	" .00444				
11	K1101 .16976	K1102 .05758	K1103 .02629	K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444	" .00444	" .00444	" .00444			
12	K1201 .01921	K1202 .06619	K1203 .04025	K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444	" .00444	" .00444	" .00444	K712 .00444		
13		K0102 .01921	K0103 .04879	K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444	" .00444	" .00444	" .00444	K712 .00444		.14351
14			K0203 .01921	K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444	" .00444	" .00444	" .00444	K712 .00444		.33873
15				K004 .01921	K005 "	K006 .01921	K712 .00444	" .00444	" .00444	" .00444	" .00444	K712 .00444		.14190
16					K005 .01921	K006 .01921	K712 .00444	" .00444	" .00444	" .00444	" .00444	K712 .00444		.14190
17						K006 .01920	K712 .00444	" .00444	" .00444	" .00444	" .00444	K712 .00444		.17202
18							K712 .00444	" .00444	" .00444	" .00444	" .00444	K712 .00444		.20023
19								" .00444	" .00444	" .00444	" .00444	K712 .00444		.67639
20									" .00444	" .00444	" .00444	K712 .00444		.51926
21										" .00444	" .00444	K712 .00444		.35184
22											" .00444	K712 .00444		.23968
23												K712 .00444	.36901	
													.14190	



Table 4-17 Evaporation Extracted Inflow at Mae Rit Dam

Unit: m<sup>3</sup>/s·day

	1960	1961	1962	1963	1964	1965	1966	1967	1968	1969	1970	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
JAN.	172 2	239 2	213 2	198 2	191 2	171 2	180 2	133 2	183 2	168 2	236 2	197 2	187 2	208 2	196 2	211 2	200 3	254 2	196 2	167 2	137 2	183 2	173 2	174 2	135 2
FEB.	130 2	184 2	164 2	174 2	168 2	178 2	147 2	120 2	139 2	128 2	170 2	145 2	144 2	145 2	144 2	144 2	152 2	143 2	144 2	126 2	113 2	125 2	125 2	125 2	101 3
MAR.	128 3	182 3	162 3	176 3	166 3	176 3	145 3	118 3	137 3	126 3	168 3	143 3	142 3	143 3	142 3	142 3	135 3	134 3	142 3	115 3	113 3	119 3	120 3	124 3	98 4
APR.	109 3	161 3	130 3	138 3	142 3	135 3	130 3	107 3	115 3	118 3	154 3	137 3	133 3	140 3	127 3	139 3	132 3	131 3	128 3	111 3	109 3	116 3	117 3	114 3	66 4
MAY	194 3	170 3	189 3	117 3	182 3	154 3	161 3	153 3	158 3	165 3	254 3	181 3	129 3	182 3	180 3	157 3	161 3	142 3	149 3	143 3	191 3	122 3	162 3	109 3	81 4
JUN.	263 2	260 2	283 2	297 2	211 2	276 2	260 2	209 2	282 2	358 2	310 2	355 2	190 2	279 2	305 2	305 2	232 2	170 2	150 2	159 2	254 2	257 2	443 2	154 2	426 2
JUL.	446 1	500 1	541 1	532 1	719 1	399 1	575 1	489 1	503 1	545 1	570 1	1199 1	731 1	554 1	501 1	553 1	457 1	329 1	575 1	291 1	416 1	542 1	655 1	136 1	303 2
AUG.	1228 2	1098 2	848 2	726 2	923 2	818 2	1045 2	1019 2	825 2	2225 2	970 2	1198 2	729 2	553 2	861 2	846 2	828 2	681 2	978 2	900 2	601 2	994 2	1421 2	386 2	807 1
SEP.	840 2	971 2	947 2	811 2	1008 2	636 2	749 2	918 2	719 2	1365 2	992 2	995 2	720 2	1131 2	683 2	1112 2	728 2	1111 2	881 2	485 2	1230 2	596 2	1017 2	446 2	837 2
OCT.	838 2	969 2	945 2	809 2	1006 2	634 2	747 2	916 2	490 2	698 2	610 2	585 2	520 2	723 2	482 2	766 2	634 2	523 2	626 2	469 2	734 2	458 2	713 2	498 2	828 2
NOV.	417 2	287 2	357 2	380 2	289 2	314 2	232 2	293 2	270 2	442 2	339 2	329 2	400 2	367 2	368 2	378 2	357 2	336 2	298 2	231 2	353 2	327 2	332 2	384 2	363 2
DEC.	316 2	253 2	288 2	269 2	232 2	238 2	190 2	224 2	204 2	317 2	274 2	241 2	276 2	260 2	218 2	258 2	250 2	238 2	200 2	168 2	256 2	232 2	226 2	177 2	232 2
Total	314	251	266	267	230	236	188	222	202	214	272	239	274	258	216	255	248	236	198	166	254	230	224	175	230

Note: Upper figure show raw inflow, middle figure show evaporation loss and lower figure show net inflow in each of the monthly cells.

Table 4-18 Evaporation Extracted Inflow at Mae Ngao Dam

Unit: m<sup>3</sup>/s.day

	1960	1961	1962	1963	1964	1965	1966	1967	1968	1969	1970	1971	1972	1973	1974	1975	1976	1977	1978	1979	1980	1981	1982	1983	1984	
JAN.	352 11 341	643 11 632	445 11 434	515 11 504	459 11 448	404 11 393	401 11 382	291 11 287	495 11 484	393 11 382	708 13 695	468 12 456	438 10 428	438 10 428	458 10 448	493 10 483	460 16 454	460 16 454	798 12 786	367 9 358	238 9 227	254 11 243	466 11 454	421 11 410	371 12 359	339 11 328
FEB.	227 12 215	455 12 443	372 11 361	418 12 406	392 12 380	415 12 403	298 12 286	155 11 144	287 12 275	244 11 233	448 11 437	286 11 273	283 11 272	326 11 315	326 11 315	277 11 266	305 11 292	305 11 292	309 12 300	260 12 248	177 12 163	172 12 160	222 12 210	243 12 231	202 12 190	206 12 194
MAR.	146 18 128	370 18 352	237 17 220	273 18 255	287 18 269	240 18 222	240 18 222	124 18 106	173 15 158	169 15 152	341 17 328	233 17 216	233 17 215	297 18 278	297 18 278	192 17 175	219 16 203	219 16 203	244 16 228	197 16 176	138 16 116	139 16 122	182 16 164	147 19 128	164 19 147	164 19 150
APR.	143 20 123	232 20 212	188 19 169	171 20 151	201 20 181	130 20 110	130 20 110	109 20 89	193 16 177	151 16 134	316 19 296	149 20 130	149 20 130	221 19 208	221 19 208	176 18 160	145 18 127	145 18 127	201 18 183	137 18 116	110 21 87	127 21 103	139 21 119	152 21 131	98 21 77	150 21 130
MAY	449 15 434	364 14 350	439 14 425	160 14 146	336 14 321	298 14 284	325 14 311	295 15 280	297 15 282	390 15 378	596 12 581	333 12 314	333 12 314	200 12 188	400 12 388	323 12 310	362 12 346	362 12 346	242 11 225	291 11 275	153 16 135	439 16 423	193 16 178	371 15 352	105 15 90	168 15 154
JUN.	802 9 793	825 9 816	916 9 907	1068 9 1059	993 9 984	914 9 905	824 9 815	530 9 521	530 10 521	911 8 903	1411 8 1403	926 9 917	485 9 476	855 7 846	966 7 959	1109 11 1102	785 7 776	785 7 776	381 10 371	284 11 273	215 9 206	610 9 604	887 6 878	1745 9 1736	337 9 328	1933 9 1924
JUL.	1641 8 1633	1848 8 1830	2115 8 2107	2150 9 2141	3053 9 3044	1456 8 1448	2308 8 2300	2084 8 2056	2084 7 2056	1926 7 1919	2290 6 2284	2319 8 2311	5136 9 5129	3343 9 3334	1890 7 1883	2107 11 2096	2263 7 2256	1921 12 1909	1069 10 1062	1815 7 1805	862 10 856	1381 6 1375	2263 6 2255	3006 8 2994	370 8 362	2159 8 2151
AUG.	4531 9 4522	4095 9 4086	3201 9 3192	2752 9 2743	3636 9 3627	2978 9 2969	3963 9 3954	4438 9 4427	3184 10 3174	10255 11 10244	3555 8 3547	5665 9 5656	4804 9 4795	4804 9 4795	3368 8 3360	3617 10 3607	2676 11 2665	3606 10 3596	2607 8 2599	3454 8 3446	4045 10 4035	2082 5 2077	4104 9 4095	6839 11 6828	1443 8 1437	4210 6 4204
SEP.	3059 12 3047	3333 12 3321	3218 12 3206	2794 12 2782	3654 12 3642	2233 12 2221	2883 12 2871	2788 12 2776	2820 13 2807	5841 12 5829	3676 12 3663	3901 13 3888	3023 13 3011	3023 13 3011	3641 11 3630	2424 12 2412	3157 9 3148	2632 10 2624	3941 11 3930	2390 15 2375	1731 11 1720	4580 12 4568	2146 13 2133	3981 14 3967	1765 11 1754	2685 12 2673
OCT.	2145 15 2130	2300 15 2285	2066 15 2051	1547 15 1532	1758 15 1743	1425 15 1410	1484 15 1469	1902 15 1887	1343 15 1328	2826 15 2811	1977 16 1961	2033 12 2021	1980 15 1965	1980 15 1965	2596 16 2580	1721 16 1706	2334 13 2321	2198 16 2182	1415 14 1401	1691 16 1675	1614 13 1601	2859 13 2846	1674 20 1654	2449 12 2437	1831 14 1817	1614 12 1602
NOV.	1154 12 1142	835 12 823	911 12 899	993 12 981	790 12 778	754 12 742	595 12 583	888 12 876	728 13 715	1596 11 1585	1023 11 1012	1064 10 1054	1316 9 1305	1316 9 1305	1286 13 1276	1040 13 1032	1077 15 1062	1131 14 1117	912 10 902	648 13 635	686 10 674	1237 10 1227	1086 12 1072	1039 14 1027	1049 12 1037	785 12 773
DEC.	882 12 870	580 11 569	727 11 716	696 11 685	627 11 616	571 11 560	669 11 654	669 11 658	536 11 525	1065 11 1049	724 11 713	652 10 642	922 10 912	922 10 912	834 10 823	548 10 538	611 16 595	627 16 617	532 9 523	392 11 381	400 12 388	760 10 750	681 12 669	589 11 578	547 11 536	489 11 478
Total																										

Note: Upper figure show raw inflow, middle figure show evaporation loss and lower figure show net inflow in each of the monthly cells.

Table 4-19 Design Flood of Each Dam Site

Project Name	C. A. (km <sup>2</sup> )	Design Flood (m <sup>3</sup> /s)	Specific Runoff m <sup>3</sup> /s/100 km <sup>2</sup>	Value of Coefficient C
Lower Yuam	5,920	6,200	1.49	40
Nam Mae Ngao	835	3,600	4.95	55
Upper Mae Ngao	490	2,700	-ditto-	-ditto-
Nam Mae Rit	1,268	2,400	0.99	30
Upper Mae Rit 1	686	1,800	-ditto-	-ditto-
Upper Mae Rit 2 (a)	525	1,500	-ditto-	-ditto-
Upper Mae Rit 3	349	1,200	-ditto-	-ditto-
Upper Mae Yuam 1	1,967	2,900	0.92	30
Upper Mae Yuam 2	1,149	2,300	-ditto-	-ditto-
Upper Mae Yuam 3	447	1,400	-ditto-	-ditto-
c.f.				
Khao Laem	3,720	7,100	4.69	56
Nam Chon	4,908	5,900	1.92	42




Fig. 4-1 Gaging and Observatory Stations

LEGEND

□ : Observed data available

▨ : Estimated by regression on observed runoff

▩ : Estimated by Time Variant Unit Hydrograph method from rainfall

▧ : Estimated by regression on estimated runoff




Fig. 4-2 Observed & Estimated Periods of Runoff Data, Nam Yuam River Basin

STATION	Y E A R																			
	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	
Mae La Luang		Feb.																		
Sop Han	May																			
Chom Chaeng																				
Ban Tha Rua																				
Mae Savieng	52																			
Mae Ngao																				May
Mae Suat																		Apr.		
Wang Khan																				May

Fig. 4-3 Available Daily Precipitation

STATION	Y E A R																			
	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	
Sop Han	Only Min.	Apr. Max. and Min.				Sept. May														
Ban Tha Rua						Jul.														Oct.
Mae Ngao																				Oct.
Mae Suat																				
Wang Khan																			May	

Fig. 4-4 Available Daily Temperature

STATION	YEAR																			
	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	
Sop Hon	May					Sept.														
Ban Tha Rua						Jul.					Feb. Apr.									
Mae Ngao																			Aug.	
Mae Suat																	May			
Wang Khan																			Aug.	

Fig. 4-5 Available Daily Relative Humidity

STATION	YEAR																			
	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	
Mae La Luang												Nov.								
Sop Hon								Jul. Aug.												
Ban Tha Rua						Apr. Jul.														
Mae Ngao																			Aug.	
Mae Suat																	May			
Wang Khan																			Aug.	

Fig. 4-6 Available Evaporation

Y : Daily Runoff of The Yuam River at Sop Han, cms, NEA, CA=2496 km<sup>2</sup>  
Jan. 1976 - Dec. 1978 & Jan. 1980 - Dec. 1984

X : Daily Inflow to RID Weir, Mae Sariang, cms, RID, (Spill over  
Weir + Irrigation intake)  
Jan. 1976 - Dec. 1978 & Jan. 1980 - Dec. 1984

Regression model :  $Y = -2.096 + 1.05096X$




Fig. 4-7 Regression Y : X (Sop Han: RID Weir)



Y : Daily Runoff of The Rit River at Ban Mae Suat, CA=1376 km<sup>2</sup> (DRRIT)

X1 : Daily Runoff of The Yuam River at Sop Han, CA=2496 km<sup>2</sup> (DR113H)

Period of Regression : 1 Apr. 1983 - 31 Dec. 1984, # of points=641




Fig. 4-8 Regression Y : X1 (Nam Mae Rit: Sop Han)




Fig. 4-9 Regression Y : X2 (Nam Mae Rit: Ban Tha Rua)




Fig. 4-10 Regression Y : X1 (Nam Mae Ngao: Sop Han)

Y : Daily Runoff of The Ngao River at Ban Mae Ngao, cms, CA=935 km<sup>2</sup>

X2 : Daily Runoff of The Yuam River at Ban Tha Rua, CA=5770 km<sup>2</sup>  
(Irrigation Water-take at RID Weir at Mae Sariang is added to observed values)

Period of regression : May 1984 - Dec. 1984, No. of points=245




Fig. 4-11 Regression Y : X2 (Nam Mae Ngao: Ban Tha Rua)




Fig. 4-12 Regression Y : X (Wang Khon: Soh Han)




Fig. 4-13 Observed & Estimated Runoffs of  
 The Rit River at Ban Mae Suat (CA = 1376 km<sup>2</sup>)




Fig. 4-14 Observed & Estimated Runoffs of  
 The Ngao River at Ban Mae Ngao (CA = 935 km<sup>2</sup>)




Fig. 4-15 Observed & Estimated Runoffs of  
The Yuam River at Wang Khan (CA = 1173 km<sup>2</sup>)






Fig. 4-16 Estimated & Observed Monthly Runoffs of The Rit River at Ban Mae Suat,  
 CA=1376 sq. km, Jan. 1960 - Dec. 1984 (25 years)




Fig. 4-17 Estimated & Observed Monthly Runoffs of The Ngao River at Ban Mae Ngao,  
 CA=935 sq. km, Jan. 1960 — Dec. 1984 (25 years)




Fig. 4-18 Estimated & Observed Monthly Runoffs of The Yuam River at Wang Khan,  
 CA=1173 sq. km, Jan. 1960 - Dec. 1984 (25 years)





Fig. 4-19 Comparison of Runoffs Observed and Estimated for The Yuam River at Ban Tha Rua



**Notes:**

1. Creager's Eq.  
(Unit in cfs-sq Miles)  $q = 45 C A^{0.059} S^{0.045} I$   
(Unit in m<sup>3</sup>-sq km)  $q = 0.503 C (0.385 A)^{0.045} I$
2. Values in [ ] are Creager's coefficients C derived from Design PMF




Fig. 4-20 Comparison of Design Floods in Thailand

## **CHAPTER 5. DEVELOPMENT PLAN**



## CHAPTER 5 DEVELOPMENT PLAN

### CONTENTS

	Page
5.1 Basic Item .....	5 - 1
5.2 Procedure for Study of Development Plan .....	5 - 3
5.3 Individual Development Plan (First Stage Study) .....	5 - 5
5.4 Selected Main Projects (Second Stage Study) .....	5 - 26
5.5 Additional Study .....	5 - 46
5.6 Incremental Benefit of the Lower Yuam Project .....	5 - 53





## Table List

		Page
Table 5-1	Basic Figures of Each Project .....	5-2
Table 5-2	Alternative Thermal Power Plant for Studying Optimum Scale of Development (First and Second Stage) .....	5-13
Table 5-3	1st Stage Planning Study Upper Mae Yuam 1 .....	5-14
Table 5-4	1st Stage Planning Study Upper Mae Yuam 2 .....	5-15
Table 5-5	1st Stage Planning Study Upper Mae Yuam 3 .....	5-16
Table 5-6	1st Stage Planning Study Nam Mae Rit .....	5-17
Table 5-7	1st Stage Planning Study Upper Mae Rit 1 .....	5-18
Table 5-8	1st Stage Planning Study Upper Mae Rit 2 .....	5-19
Table 5-9	1st Stage Planning Study Upper Mae Rit 2a .....	5-20
Table 5-10	1st Stage Planning Study Upper Mae Rit 3 .....	5-21
Table 5-11	1st Stage Planning Study Nam Mae Ngao (Site No. 2) .....	5-22
Table 5-12	1st Stage Planning Study Nam Mae Ngao (Site No. 3) .....	5-23
Table 5-13	1st Stage Planning Study Upper Mae Ngao .....	5-24
Table 5-14-1	Summary of First Stage Study, Mater Plan of Nam Yuam River Basin .....	5-25
Table 5-14-2	Summary of Second Stage Study .....	5-29
Table 5-15	2nd Stage Study Upper Mae Yuam 1 .....	5-30
Table 5-16	2nd Stage Study Upper Mae Rit .....	5-32
Table 5-17	2nd Stage Study Upper Mae Rit 2a .....	5-34
Table 5-18	2nd Stage Study Nam Mae Ngao (No. 2 Site) .....	5-36
Table 5-19	2nd Stage Study Lower Yuam .....	5-39
Table 5-20	Integrated Development including Transmission Line Nam Mae Ngao No. 2 + Lower Yuam .....	5-40
Table 5-21	Incremental Benefit of Lower Yuam due to the Effect of Nam Mae Ngao No. 2 Development (Lower Yuam: Dam & Installed Capacity are Fixed at F/S Levels-Second Stage) ..	5-41
Table 5-22	Incremental Benefit of Lower Yuam due to the Effect of Nam Mae Ngao No. 2 Development (Lower Yuam: Dam is Fixed at F/S Level, Installed Capacity is Optimized-Second Stage) ..	5-42
Table 5-23	Fuel Price Variations for Alternative Thermal Plants .....	5-47
Table 5-24	Reservoir Simulation Nam Mae Ngao .....	5-49
Table 5-25	Reservoir Simulation Lower Yuam .....	5-51

Table 5--26

Incremental Benefit of Lower Yuam due to the Effect of ..... 5--55  
Nam Mae Ngao No. 2 Development  
(Lower Yuam: Dam & Installed Capacity are Fixed at F/S Level  
- Additional Stage)

## Figure List

		Page
Fig. 5-1	Flow Mass Curve Upper Mae Yuam 1 (Case YIB 325.10) .....	5-31
Fig. 5-2	Flow Mass Curve Nam Mae Rit (Case ROB 270.15) .....	5-33
Fig. 5-3	Flow Mass Curve Upper Mae Rit 2a (Case R2a D 585.5) .....	5-35
Fig. 5-4	Flow Mass Curve Nam Mae Ngao (Case NOB 250.20b) .....	5-38
Fig. 5-5	Flow Mass Curve Nam Mae Ngao (Case NO2A 260.25b) .....	5-50
Fig. 5-6	Flow Mass Curve Lower Yuam (Case YOA 170.20b) .....	5-52
Fig. 5-7	Load Duration Curve, Northern Region, 2000 with Nam Mae Ngao Hydro Power Fitted .....	5-43
Fig. 5-8	Load Duration Curve, Northern Region, 2000 with Lower Yuam Hydro Power (Case 0) fitted .....	5-44
Fig. 5-9	Load Duration Curve, Northern Region, 2000 with Nam Mae Ngao and Lower Yuam Integrated Development Projects (Case VI) Fitted .....	5-45
Fig. 5-10	Area-Capacity Curve, Nam Mae Ngao No. 2 .....	5-56
Fig. 5-11	Area-Capacity Curve, Nam Mae Rit .....	5-57
Fig. 5-12	Area-Capacity Curve, Nam Mae Ngao No. 3 .....	5-58
Fig. 5-13	Area-Capacity Curve, Upper Mae Ngao No. 2 .....	5-59
Fig. 5-14	Area-Capacity Curve, Upper Mae Ngao No. 3 .....	5-60
Fig. 5-15	Area-Capacity Curve, Upper Mae Rit 1 .....	5-61
Fig. 5-16	Area-Capacity Curve, Upper Mae Rit 2 .....	5-62
Fig. 5-17	Area-Capacity Curve, Upper Mae Rit 3 .....	5-63
Fig. 5-18	Area-Capacity Curve, Upper Mae Yuam 2 .....	5-64
Fig. 5-19	Area-Capacity Curve, Upper Mae Yuam 3 .....	5-65



## CHAPTER 5. DEVELOPMENT PLAN

### 5.1 Basic Items

#### 1) Location of the Dam Site

The projects to be studied in the Master Plan are nine (9) projects, illustrated on the Fig. 1-1.

The basic figures of the projects are shown on Table 5-1.

#### 2) Catchment Area and Storage Capacity Curve

The three kinds of topographical map listed below can be utilized.

Scale	1:250,000	whole river basin
Scale	1:50,000	- ditto -
Scale	1:5,000	Nam Mae Ngao, Nam Mae Rit and Upper Mae Yuam 1

The measurement of both catchment area and storage capacity curve has been made by EGAT using 1:50,000 scale map and handed over to the JICA survey team during the first field survey.

The team checked the catchment area and the area-capacity curve of each project. The exactitude of the catchment area measured by EGAT has been confirmed and the value was adapted for the inflow calculation as shown on Table 5-1. Regarding to the area-capacity curves, some discrepancies have been found out. So the team checked the area-capacity curve again using 1:25,000 scale map, enlarged from 1:50,000.

However, final volumes were measured by 1:5,000 scale map for the major three planned reservoirs; Nam Mae Ngao, Nam Mae Rit, and Upper Mae Yuam 1 in the second stage.

Table 5-1 Basic Figures of Each Project

NO.	Project name	Coordinates						CA ( km <sup>2</sup> )	Tailrace W.L. ( m )
		Dam site		Power house		E°			
		N°	E°	N°	E°				
1	Upper Mae Yuam 1	18° 23' 52"	97° 54' 48"				1,967	262.0	
2	Upper Mae Yuam 2	18° 33' 20"	97° 54' 41"				1,149	326.5	
3	Upper Mae Yuam 3	18° 45' 27"	97° 51' 21"				447	428.0	
4	Nam Mae Rit	17° 55' 11"	98° 00' 07"				1,268	192.0	
5	Upper Mae Rit 1	17° 59' 55"	98° 04' 10"	17° 57' 04"		98° 04' 00"	686	281.0	
6	Upper Mae Rit 2	18° 04' 35"	98° 05' 55"	18° 03' 28"		98° 05' 55"	525	491.0	
				18° 01' 55"		98° 04' 49"		407.0	
7	Upper Mae Rit 3	17° 56' 24"	98° 08' 17"	17° 57' 07"		98° 04' 18"	349	281.0	
8	Nam Mae Ngao	17° 47' 24"	97° 59' 42"				835	163.0	
		17° 46' 14"	98° 00' 38"					756	171.0
9	Upper Mae Ngao	17° 35' 10"	98° 06' 37"				159	271.1	
	Lower Yuam (NEA)	17° 49'	97° 49'				5,920	73.2	

## 5.2 Procedure for Study of Development Plan

### 1) Study Procedure

The study of the development plan is to be made divided into the three stages described below.

#### a. First Stage

The principal objective of the first stage is to find out the economical feasibility of the planned projects; Nam Mae Ngao, Nam Mae Rit, Upper Mae Yuam 1 and other six projects, at the preliminary study level.

Comparison studies are made for individual projects varying dam heights, effective storage capacities, installed capacities, etc.

The study results are described in Clause 5-3.

#### b. Second Stage

Taking into account the study result in the first stage, the selected projects are examined more in detail.

In the study, Lower Yuam on which the feasibility study was already completed in 1984, is regarded as if it is an existing power station therefore the increment of power and energy of the station is considered to be an additional benefit.

The study results are described in clause 5-4.

#### c. Additional Stage

In the additional stage, following studies have been made, based upon the third minutes of meeting.

- i) Detailed optimization study of Nam Mae Ngao No.2, applying the up-dated fuel prices which were given by EGAT.
- ii) Study of the incremental benefit of Lower Yuam due to the regulation effect of Nam Mae Ngao No.2, applying the same up-dated fuel prices.



The study results are described in the clause 5-5.

## 2) Reservoir operation and energy production

### a) Reservoir Operation

To study operation of a reservoir and an output capacity, the 95% firm discharge will first be obtained. Herein, the mass curve of runoff is drawn, then on the assumption that past runoff is reproduced exactly the same way and that the future discharge is completely foreseeable, the 95% firm discharge is obtained from the probability distribution of the minimum discharge of each year, with operation of reservoir made most effectively.

In the annual inflow calculation to the dam site, evapotranspiration loss has not been considered at the first stage study, since the effect of loss is small in the proposed reservoir simulation. However, the evaporation loss was considered in the second stage.

The various reservoir operations for the planned dam sites have been examined varying the dam height and the effective storage volume to find out the most optimized development scale.

### b) Equivalent Peak Duration Hours

The first assumption to be made for the examination of output capacity is that of the peak duration hours to be supplied by the project. Since peak duration hours are closely related to load duration curves, and the latter is mostly dependent on the character demand, a discussion has been made with EGAT during the first field survey.

EGAT usually adopts a plant factor between 20% and 30% for planning a storage type hydro power plant depending upon the situations and conditions of the proposed hydro power project.

Since a power supply area of the Nam Yuam hydro power projects is most reasonably considered to be the Northern Region, the

plant factor of the Nam Yuam hydro power plants should be determined based upon a daily load duration curve and a daily load factor, etc. of the Northern Region.

After the discussion, the plant factor of 25% has been adopted tentatively, and used for the first stage study of the Master Plan. However, in the second stage, three plant factors; 15, 20 and 25% have been adopted for the comparison study, based on "the Second Minutes of Meeting".

c) Maximum Discharge

The maximum discharge is to be obtained by the firm discharge of 95% probability and the equivalent peak duration hours of 6, 4.8 and 3.6 hours (Plant factor of 25, 20 and 15%) respectively.

d) Calculation of Energy Production

Energy production of each planned power station is calculated based on the monthly inflow for the 25 year period from 1960 to 1984 at each dam site.

e) Firm Capacity

The firm capacity is calculated by the maximum turbine discharge and the lowest reservoir water level.

f) Firm and Secondary Energy

Of the annual energy production, the part corresponding to firm discharge is taken as the firm energy, and any energy production other than the firm energy is taken to be the secondary energy.

### 5.3 Individual Development Plan (First Stage Study)

The projects to be studied in the first stage study of the Master Plan are nine pre-selected projects.

Number of main cases studied in this stage including some alternative cases are as following:

Upper Mae Yuam 1	.....	12 cases
Upper Mae Yuam 2	.....	12 cases
Upper Mae Yuam 3	.....	3 cases
Nam Mae Rit	.....	12 cases
Upper Mae Rit 1	.....	4 cases
Upper Mae Rit 2	.....	9 cases
Upper Mae Rit 2a	.....	3 cases
Upper Mae Rit 3	.....	4 cases
Nam Mae Ngao (Site No.2)	.....	16 cases
Nam Mae Ngao (Site No.3)	.....	8 cases
Upper Mae Ngao	.....	9 cases
Total:		92 cases

Reservoir operation study was performed for each case to maximize the firm capacity, firm energy and secondary energy given the various high water levels and low water levels (i.e., given the various effective heads and various effective reservoir capacities).

The details of the study results were included in the "Interim Report, Master Plan Study on Nam Yuam River Basin Hydroelectric Development Project, Nov. 1985" and the computer output volumes submitted and explained to EGAT in November 1985, so that those details have not been attached here.

The summary of the study results are shown on Table 5-14-1. On this table, only the most economical case among several cases studied is listed for each of the nine projects. (Note that either Upper Mae Rit 2 or Upper Mae Rit 2a constitutes one project, and either Nam Mae Ngao Site No.2 or Nam Mae Ngao Site No.3 will be Nam Mae Ngao Project.)

It is seen also that Nam Mae Ngao Site No.2 is the most promising project (B/C = 1.67, rank 1) followed by Upper Mae Rit 2a (rank 2), Nam Mae Rit (rank 3), Upper Mae Yuam 1 (rank 4), etc. in this order.

The B/C ratios of these four upper ranked projects are nearly equal to or greater than 1.0. Taking into account of these results and other relevant information as described in the following subsections, it is judged that the above four projects were deserved for the objects of the next stage of study. The explanation of the study results for the individual project are as follows.

1) Upper Mae Yuam 1

This project, planned on the upstream of the Yuam river, is located about 2 km upstream from Ban Wan Kang in the Mae La Noi District.

There are no alternative dam axes except the planned dam site according to the topographical condition.

The site location is shown on Table 5-1.

Rockfill type dam is adopted and the power station is planned on the left bank of the down stream considering the topographical condition.

To find out the economic feasibility and the optimized development scale, various comparison studies were made varying HWL, available reservoir capacity and installed capacity for twelve cases in total. The results are shown on Table 5-3.

Judging from the result, the project feasibility of the individual development plan is still uncertain unless the investigation works are carried out more, including the possibility of irrigation scheme. In addition to the above the studied project scale should be re-examined using 1:5,000 scale map of the planned reservoir, mapped out by EGAT.

Tentative design works are made at preliminary study level using 1:50,000 scale map for the next investigation works.

2) Upper Mae Yuam 2

This project is planned on the Yuam river, about 17 km upstream from Upper Mae Yuam 1 project. There are no alternative dam axes except this dam site due to the topographical condition.

The site location is shown on Table 5-1.

Rockfill type dam is adopted and power station is planned on the left bank of the downstream from the dam site.

Various comparison studies were made varying HWL, available reservoir capacity and installed capacity for twelve cases in total.

The results are shown on Table 5-4.

Judging from the results, this project is not so promising so that further study need not be made in the next stage.

3) Upper Mae Yuam 3

This project is planned on the upper most reach of the Yuam river. There are no access roads so that any reconnaissance survey was not carried out during the first field investigation works.

The site location is shown on Table 5-1.

Comparison study was made varying HWL, available reservoir capacity and installed capacity for three cases in total.

The study results are shown on Table 5-5.

This project shows the poorest character in economy among those planned on the main stream of the Yuam river.

4) Nam Mae Rit

This project is located about 6 km upstream from the confluence of the Rit river and the Yuam river. Two alternative dam sites are planned for the project.

The reconnaissance survey to both dam sites was carried out during the first and second field survey. As the results, the downstream site has been selected for the study.

The location of the site is shown on Table 5-1.

This project is planned as a dam and waterway type power station. Rockfill type dam is adopted and power station is planned on the right bank of the down stream from the dam.

The comparison studies to find out the project feasibility were made varying HWL, available reservoir capacity and installed capacity for twelve cases in total.

The results are shown on Table 5-6.

The studied project scale should be re-examined using 1:5,000 scale map for the planned reservoir which will be mapped out by EGAT.

Tentative design works are made at preliminary study level using 1:50,000 scale map for the next investigation works.

5) Upper Mae Rit 1

This project is planned about 6 km upstream from the confluence of the Rit river and the Lap river, one of the tributary of the Rit river coming from the left bank.

There are no access roads to the site so that any reconnaissance survey was not carried out.

The site location is shown on Table 5-1.

Various comparison studies were made and the results are shown on the Table 5-7.

6) Upper Mae Rit 2

Upper Mae Rit 2

This project is planned on the upper most reach of the Rit river. Any reconnaissance survey was not carried out because of no access roads.

This project is planned as dam and waterway type power station. The location of the dam and power station are shown on Table 5-1.

The project consists of rockfill type dam, power tunnel with 2,100 m long and power station.

Comparison studies for the project feasibility were made varying HWL, available reserrior capacity and installed capacity for nine cases in total.

The results are shown on Table 5-8.

Judging from the results, it can be said that the project could be advantageous provided the dam height is reduced.

In other word, run-of-river type power station would be more advantageous.

For making clear this tendency, an alternative plan (2a) was examined.

#### Upper Mae Rit 2a

The alternative 2a consists of intake dam, planned on the same site, power tunnel with 5,900 m long and power station located on the right bank, to utilize the steep gradient of the river.

Comparison study for the project feasibility was made for three cases in total. The results are shown on Table 5-9.

Judging from the results, run-of-river type power station seems to be suitable to the upper reach of the Rit river and the high project economy can be expected.

Therefore tentative design works are made at preliminary study level using 1:50,000 scale map.

#### 7) Upper Mae Rit 3

This project is planned on the Lap river, one of the tributary of the Rit river.

The location of the project is shown on Table 5-1. Any reconnaissance survey was not carried out because of no access roads.

Various comparison studies were made and the results are on Table 5-10.

#### 8) Nam Mae Ngao

This project is planned about 8 - 12 km upstream from the confluence of the Yuam river and the Ngao river.

Three alternative dam sites were studied.

The reconnaissance survey to the sites was carried out during the first and second field survey. As the results, alternative site of No.2 and No.3 were selected for the study.

The locations of two sites are shown on Table 5-1.

#### No. 2 Site

This project was planned as dam type power station. Main structures are rockfill type dam and power station planned on the left bank considering the topography and the geology.

Various comparison studies were made to find out the project feasibility and optimum development scale varying HWL, available reservoir capacity and installed capacity for sixteen cases in total.

The study results are shown in Table 5-11.

Judging from the results, this project is very promising and the results show that the Ngao river has high potential.

In the next stage, the project should be re-examined using 1:5,000 scale map of the planned reservoir, mapped out by EGAT.

Tentative design works are made on preliminary study level for the next investigation works using 1:50,000 scale map.

The case with HWL 260 m is very attractive. However, judging from the topography, the case with HWL 250 m was conservatively adopted for the first stage study.

Therefore, tentative design drawings are based upon the figures described on Table 5-14.

#### No. 3 Site

The higher is HWL, the more is the benefit of the project. However, since the HWL of the No.2 site is restricted due to topographical and geological condition, the No. 3 dam axis is considered as an alternative dam site. The field reconnaissance was also made by the team.

The comparison study results are shown on Table 5-12.

According to the results, No.3 site also be very promising to construct high dam keeping the economy of the project.



Considering the study results of the above two sites, No. 2 site is preferred to No. 3 site.

However, due to the uncertainty of topographical and geological information, the investigation works in the next stage should be made for both No.2 and No.3 site.

9) Upper Mae Ngao

This project is planned upstream of Nam Mae Ngao.

Therefore the site was selected according to the study results of Nam Mae Ngao. The location of the site is shown on Table 5-1.

Comparison study results are shown on Table 5-13 and summarized on Table 5-14.

Table 5-2 Alternative Thermal Power Plant for Studying Optimum Scale of Development (First and Second Stage)

Item	Calculation formula	Hydro power plant	Alternative Thermal Power Plant			
			Gas Turbine	Thermal	Gas Turbine	Thermal
(a) Installed Capacity (MW)			25	600	25	600
(b) Service life (yrs)		50	20	25	20	25
(c) Station-Service Use (%)		0.5	2	7	2	7
(d) Scheduled Outage rate (%)		0.0	12	12	12	12
(e) Forced Outage rate (%)		0.5	4	4	4	4
(f) Adjustment factor (%)	$(1 - C_1/100)(1 - d_1/100)(1 - e_1/100)$ $(1 - C_2/100)(1 - d_2/100)(1 - e_2/100)$		84	79	84	79
(g) O & M cost rate (%)			3	2.5	3	2.5
(h) Unit Construction Cost (US\$/kW)			405	580	405	580
(hz) Cost with IDC (US\$/kW)						
(i) Fuel			Natural Gas	Natural Gas	Diesel Oil	Imported Coal
(i1) Calorific Value (Btu/unit)			1,087.52 Btu/cuft	1,087.52 Btu/cuft		
(i2) Energy Equivalence (Kcal/unit)	$1 \text{ Btu} = 252 \text{ cal}$ $890 \text{ Kcal} / \text{kwh}$		274.06 Kcal/cuft	274.06 Kcal/cuft	9,317.41 Kcal/l	6,717.3 Kcal/kg
(i3) Thermal Efficiency or heat rate			25 %	36 %	25 %	36 %
(i4) Fuel Consumption	$12 / (i_3) \times i_3 \text{ for } i_3 / i_4$		12.55 cuft/kwh	8.72 cuft/kwh	0.37 l/kwh	0.36 kg/kwh
(i5) Unit fuel price			0.095 \$/cuft	0.095 \$/cuft	6.605 \$/l	0.075 US\$/kg
(i6) Fuel cost (¢ / kwh)	$i_4 \times i_5$		1.19 ¢/kwh	0.83 ¢/kwh	2.44 ¢/kwh	0.73 ¢/kwh
(i7) Fuel cost (US\$/kwh)	$i_4 \times i_5$		0.044 US\$/kwh	0.031 US\$/kwh	0.090 US\$/kwh	0.027 US\$/kwh
(j) Installed Capacity (MW)			0.84 G	0.79 T	0.84 G	0.79 T
(k) Effective Capacity (MW)	$(j) \times (f)$		X <sub>6</sub>	X <sub>7</sub>	X <sub>6</sub>	X <sub>7</sub>
(l) Annual Plant Factor (%)			8,760 GX <sub>6</sub>	8,760 TX <sub>7</sub>	8,760 GX <sub>6</sub>	8,760 TX <sub>7</sub>
(m) Annual Energy Production (10 <sup>3</sup> kwh)	$(j) \times 24 \times 365 \times (f)$	0.5	98	93	98	93
(n) Station Service Use (%)	$(1 - r_1/100) / (1 - r_2/100)$		8,584.8 GX <sub>6</sub>	8,146.8 TX <sub>7</sub>	8,584.8 GX <sub>6</sub>	8,146.8 TX <sub>7</sub>
(o) Adjustment Factor (%)	$(m) \times (p)$					
(p) Annual Available Energy (10 <sup>3</sup> kwh)						
(q) Capital Investment Cost (10 <sup>3</sup> US\$)	$(h_1) \times (j)$		405 G	580 T	405 G	580 T
(r) Annual O & M Cost (10 <sup>3</sup> US\$)	$(g) \times (j)$		12.15 G	14.5 T	12.15 G	14.5 T
(s) Annual Fuel Cost (10 <sup>3</sup> US\$)	$(i_4) \times (m)$		385.4 GX <sub>6</sub>	271.6 TX <sub>7</sub>	385.4 GX <sub>6</sub>	271.6 TX <sub>7</sub>
(t) Interest Rate	10 %					
(u) Conversion Rate of Currency	US\$ 1.00 = \$ 2.0					

Table 5-3 1st Stage Planning Study Upper Mae Yuam 1

Description	Unit	325 m			325 m			310 m			310 m		
		H.W.L.	Total Storage Capacity 455 MCM	H.W.L.	Total Storage Capacity 455 MCM	H.W.L.	Total Storage Capacity 194 MCM	H.W.L.	Total Storage Capacity 194 MCM	H.W.L.	Total Storage Capacity 194 MCM		
Case No.		①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫
Project Type		S.G	S.G	S.G	P.G	P.G	P.G	S.G	S.G	S.G	P.G	P.G	P.G
Dam Height	m	75	75	75	75	75	75	60	60	60	60	60	60
Tunnel Length		-	-	-	-	-	-	-	-	-	-	-	-
Available Drawdown	m	10	20	30	10	20	30	10	15	20	10	15	20
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	190	318	395	190	318	395	103	134	158	103	134	158
N.I.W.L.	m	319.7	318.1	316.3	319.7	318.1	316.3	304.5	302.7	301.3	304.5	302.7	301.3
L.W.L.	m	315	305	295	315	305	295	300	295	290	300	295	290
T.W.L.	m	262	262	262	262	262	262	262	262	262	262	262	262
Gross Head	m	63	63	63	63	63	63	48	48	48	48	48	48
Effective Normal Head	m	55.8	54.2	52.4	55.8	54.2	52.4	41.1	39.3	37.8	41.2	39.4	37.9
Firm Discharge (95%)	m <sup>3</sup> /s	12.5	13.9	15.2	12.5	13.9	15.2	11.3	11.7	12.6	11.3	12.3	12.6
Max. Turbine Discharge	m <sup>3</sup> /s	50.1	55.5	63.6	29.9	29.9	29.9	45.1	49.2	50.3	29.9	29.9	29.9
Installed Capacity	MW	24.4	26.2	27.8	14.5	14.1	13.6	16.2	16.9	16.6	10.7	10.3	9.9
Firm Capacity	MW	22.3	19.9	16.5	7.0	6.2	5.2	14.4	13.6	11.7	4.5	4.2	3.6
Associated Capacity	MW	4.2	4.6	5.7	4.0	4.6	5.7	3.5	3.5	4.0	3.2	3.4	3.7
Annual Energy Production	GWH	760	740	730	750	740	730	550	530	520	530	520	500
Firm Energy	GWH	490	440	360	490	440	360	320	300	280	320	300	280
Secondary Energy	GWH	270	300	370	260	300	370	230	230	260	210	220	240
Construction Cost for Generating F.	10 <sup>8</sup>	1,335.9	1,362.1	1,408.3	1,215.5	1,216.4	1,216.2	985.6	1,002.4	1,002.2	903.8	901.9	899.4
Construction Cost for Transmission F.	10 <sup>8</sup>												
Benefit for first kW	10 <sup>8</sup>	14.1	13.5	12.5	10.8	9.7	9.9	9.3	9.2	8.92	7.06	6.94	6.62
Benefit for first kWh	10 <sup>8</sup>	5.66	5.05	4.19	7.8	15.7	13.2	36.6	34.5	29.7	11.4	10.7	9.1
Benefit for Secondary kW	10 <sup>8</sup>	500	449	36.7	500	44.9	36.7	32.6	30.6	26.5	32.6	30.6	28.5
Benefit for Secondary kWh	10 <sup>8</sup>	15.9	17.4	21.5	15.1	17.4	21.5	13.2	13.2	15.1	12.1	12.9	14.0
Annual Cost for Generating F.	10 <sup>8</sup>	149.3	151.2	156.3	134.9	135.0	135.0	109.4	111.3	111.2	100.3	100.1	99.8
Annual Cost for Transmission F.	10 <sup>8</sup>												
B - C	10 <sup>8</sup>	Δ 7.2	Δ 17.7	Δ 30.7	Δ 34.1	Δ 36.3	Δ 38.1	Δ 11.1	Δ 17.1	Δ 22.0	Δ 29.7	Δ 30.7	Δ 33.6
B / C	10 <sup>8</sup>	0.95	0.88	0.80	0.75	0.73	0.72	0.90	0.85	0.80	0.70	0.69	0.65
Annual Energy Cost	\$/kWh	1.95	2.04	2.14	1.80	1.82	1.85	1.99	2.10	2.14	1.89	1.93	2.00
Simulation Case No.		Y18325:10	Y18325:20	Y18325:30	Y18325:10	Y18325:20	Y18325:30	Y18310:10	Y18310:15	Y18310:20	Y18310:10	Y18310:15	Y18310:20

Project Type, SG: Storage Type, RR: Run-of River Type  
PG: Pondage Type.

Table 5-4 1st Stage Planning Study Upper Mae Yuam 2

C. A 1,149 km<sup>2</sup>

Description	Unit	H.W.L. 417 m			H.W.L. 400 m			H.W.L. 380 m						
		Total Storage Capacity 830 MCM			Total Storage Capacity 432 MCM			Total Storage Capacity 178 MCM						
		①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩			
Case No.														
Protect. Type		S.G	S.G	P.G	P.G	P.G	P.G	P.G	P.G	P.G	P.G	P.G	P.G	P.G
Dam Height	m	102	102	102	102	85	85	85	85	65	65	65	65	65
Tunnel Length														
Available Drawdown	m	20	37	20	37	15	30	15	30	10	20	10	20	20
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	447	652	447	652	205	329	205	329	75	124	75	124	124
N.I.W.L	m	410.9	408.4	410.9	408.4	393.9	392.2	393.9	392.2	374.2	371.5	374.3	371.5	371.5
L.W.L		397	360	397	360	385	370	385	370	370	360	370	360	360
T.W.L		326.5	326.5	326.5	326.5	326.5	326.5	326.5	326.5	326.5	326.5	326.5	326.5	326.5
Gross Head		90.5	90.5	90.5	90.5	73.5	73.5	73.5	73.5	53.5	53.5	53.5	53.5	53.5
Effective Normal Head		81.7	79.2	81.7	79.2	65.2	63.5	65.2	63.5	46.1	43.3	46.2	43.4	43.4
Firm Discharge (95%)	m <sup>3</sup> /s	9.7	10.6	9.7	10.6	8.3	9.3	8.3	9.3	7.1	7.1	7.1	7.1	7.4
Max. Turbine Discharge		38.7	42.2	19.4	21.1	33.0	37.0	17.4	18.5	28.4	29.6	17.4	17.4	17.4
Installed Capacity	MW	276	292	138	14.6	188	20.5	9.9	10.2	11.4	11.2	7.0	6.6	6.6
Firm Capacity		229	19.7	11.4	9.3	16.2	13.3	8.1	6.7	10.4	8.2	5.2	4.1	4.1
Associated Capacity		2.8	4.0	2.8	4.0	2.6	3.5	2.6	3.5	2.1	2.6	1.8	2.4	2.4
Annual Energy Production	GWH	68.0	67.0	68.0	67.0	52.0	52.0	52.0	52.0	37.0	35.0	35.0	35.0	34.0
Firm Energy		50.0	41.0	50.0	41.0	35.0	29.0	35.0	29.0	23.0	18.0	23.0	18.0	18.0
Secondary Energy		18.0	26.0	18.0	26.0	17.0	23.0	17.0	23.0	14.0	17.0	12.0	16.0	16.0
Construction Cost for Generating F. for Transmission F.	10 <sup>8</sup>	1,943	1,967	1,805	1,816	1,307	1,337	1,201	1,214	822	827	745	742	742
Benefit for first kW	10 <sup>8</sup>	132.2	122.3	103.0	98.4	98.3	92.5	77.8	75.7	67.5	60.7	51.8	48.9	48.9
for first KWH		58.2	47.5	29.0	23.6	41.1	33.8	20.6	17.0	26.4	20.8	13.2	10.4	10.4
for Secondary kW		10.6	15.1	10.6	15.1	9.8	13.2	9.8	13.2	7.9	9.8	6.8	9.1	9.1
for Secondary KWH		12.4	17.9	12.4	17.9	11.7	15.9	11.7	15.9	9.7	11.7	8.3	11.0	11.0
Annual Cost for Generating F. for Transmission F.	10 <sup>8</sup>	215.7	218.3	200.4	201.6	145.1	149.4	133.3	134.8	91.2	91.8	82.7	82.4	82.4
B - C	10 <sup>8</sup>	Δ 83.5	Δ 96.0	Δ 97.4	Δ 103.2	Δ 46.8	Δ 55.9	Δ 55.5	Δ 59.1	Δ 23.7	Δ 31.1	Δ 30.9	Δ 33.5	Δ 33.5
B / C		0.61	0.56	0.51	0.49	0.68	0.62	0.58	0.56	0.74	0.66	0.63	0.59	0.59
Annual Energy Cost	\$/kWh	3.17	3.26	2.95	3.01	2.79	2.85	2.56	2.59	2.46	2.62	2.36	2.42	2.42
Simulation Case No		Y28417.20	Y28417.37	Y2C417.20	Y2C417.37	Y28400.15	Y28400.30	Y28400.15	Y2C400.30	Y28383.10	Y28380.20	Y20380.10	Y20380.20	Y20380.20

Project Type, SG : Storage Type, RR : Run-of-River Type  
PG : Pondage Type

Table 5-5 1st Stage Planning Study Upper Mae Yuam 3

C. A 447 km<sup>2</sup>  
Annual Inflow 129.5 MCM

Description	Unit	H.W.L. 477 m		
		Total Storage Capacity 67.6 MCM		
Case No.		①	②	③
Project Type		S.G	S.G	S.G
Dam Height	m	62	62	62
Tunnel Length	′	—	—	—
Available Drawdown	m	10	15	20
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	32.3	42.0	49.9
N.I.W.L	m	470.7	469.8	468.7
L.W.L	′	467	462	457
T.W.L	′	428	428	428
Gross Head	′	49	49	49
Effective Normal Head	′	41.3	40.3	39.2
Firm Discharge (95%)	m <sup>3</sup> /s	2.8	2.9	2.9
Max. Turbine Discharge	′	11.3	11.4	11.7
Installed Capacity	MW	4.1	4.0	4.0
Firm Capacity	′	3.7	3.2	2.8
Associated Capacity	′	0.7	0.9	0.9
Annual Energy Production	GWH	13.0	12.7	12.4
Firm Energy	′	8.1	7.1	6.2
Secondary Energy	′	4.9	5.6	6.2
Construction Cost	10 <sup>6</sup> B			
for Generating F.	′	475.0	476.4	477.9
for Transmission F.	′	—	—	—
Benefit	10 <sup>6</sup> B	23.7	22.6	21.1
for first kW	′	9.4	8.1	7.1
for first kWh	′	8.3	7.2	6.3
for Secondary kW	′	2.6	3.4	3.4
for Secondary kWh	′	3.4	3.9	4.3
Annual Cost	10 <sup>6</sup> B			
for Generating F.	′	52.7	52.9	53.0
for Transmission F.	′	—	—	—
B ~ C	10 <sup>6</sup> B	Δ 29.0	Δ 30.3	Δ 31.9
B / C	′	0.45	0.43	0.40
Annual Energy Cost	B/kWh	4.05	4.17	4.27
Simulation Case No		Y3B477.10	Y3B477.15	Y3B477.20

Project Type, SG ; Storage Type, RR ; Run-of River Type  
PG ; Pondage Type,



Table 5-7 1st Stage Planning Study Upper Mae Rit 1

C.A 686 km<sup>2</sup>  
Annual Inflow 214 MCM

H.W.L.	m	445	490		
Total Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	0.3	15.8		
Case No.		①	②	③	④
Project Type		R.R	P.G	P.G	P.G
Dam Height	m	-	66	66	66
Tunnel Length	✓	5,100	5,100	5,100	5,100
Available Drawdown	m	-	10	15	5
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	-	8.1	11.2	4.7
N.I.W.L	m	365	401.8	399.9	403.8
L.W.L	✓	-	397	392	402
T.W.L	✓	281	281	281	281
Gross Head	✓	84	126	126	126
Effective Normal Head	✓	64	90.9	88.9	92.9
Firm Discharge (95%)	m <sup>3</sup> /s	2.01	2.72	2.90	2.46
Max. Turbine Discharge	✓	12.94	12.94	12.94	12.94
Installed Capacity	MW	7.2	10.3	10.0	10.5
Firm Capacity	✓	1.1	8.2	8.2	7.8
Associated Capacity	✓	2.3	3.9	3.7	3.9
Annual Energy Production	GWH	29.8	42.5	41.9	42.7
Firm Energy	✓	9.8	17.9	18.0	17.1
Secondary Energy	✓	20.0	24.6	23.9	25.6
Construction Cost	10 <sup>6</sup> B				
for Generating F.	✓	553.8	837.2	838.6	836.3
for Transmission F.	✓	-	-	-	-
Benefit	10 <sup>6</sup> B	34.0	70.8	69.7	69.6
for first kW	✓	2.8	20.8	20.8	19.8
for first kWh	✓	10.0	18.3	18.4	17.4
for Secondary kW	✓	10.2	14.7	14.0	14.7
for Secondary kWh	✓	11.0	17.0	16.5	17.7
Annual Cost	10 <sup>6</sup> B				
for Generating F.	✓	61.5	92.9	93.1	92.8
for Transmission F.	✓	-	-	-	-
B - C	10 <sup>6</sup> B	Δ 27.5	Δ 22.1	Δ 23.4	Δ 23.2
B / C	✓	0.55	0.76	0.75	0.75
Annual Energy Cost	B/kWh	2.06	2.19	2.22	2.17
Simulation Case No		RIE365.0	RID407.10	RID407.15	RID407.50

Project Type. SG : Storage Type, RR : Run-of River Type  
PG : Pondage Type.

Table 5-8 1st Stage Planning Study Upper Mae Rit 2

Description	Unit	H.W.L. 6.45 m		H.W.L. 6.15 m		H.W.L. 5.85 m		Annual Inflow 163 MCM	525 km <sup>2</sup>
		Total Storage Capacity	134 MCM	Total Storage Capacity	486 MCM	Total Storage Capacity	13.5 MCM		
Case No.		①	②	③	④	⑤	⑥	⑦	⑧
Project Type		SG	SG	SG	SG	SG	SG	SG	SG
Dam Height	m	123	123	123	93	93	93	63	63
Tunnel Length	m	2,015	2,015	2,015	2,055	2,055	2,110	2,110	2,110
Available Drawdown	m	10	20	30	10	15	20	5	10
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	34	63	65	15.7	22.4	27.9	3.2	5.3
N.L.W.L.	m	636.3	634.7	633.5	608.7	606.5	604.4	581.4	579.4
L.W.L.	m	635	625	615	605	600	595	580	575
T.W.L.	m	491	491	491	491	491	491	491	491
Gross Head	m	154	154	154	124	124	124	94	94
Effective Normal Head	m	139.6	136.0	134.8	111.5	109.3	107.2	85.7	83.7
Firm Discharge (95%)	m <sup>3</sup> /s	3.6	4.1	4.1	2.7	3.1	3.3	1.8	2.0
Max. Turbine Discharge	m <sup>3</sup> /s	14.2	16.4	16.4	10.7	12.2	13.3	8.3	8.4
Installed Capacity	MW	173	19.5	19.3	10.4	11.6	12.5	6.2	6.1
Firm Capacity	MW	169	18.1	16.7	10.1	10.9	11.4	5.4	5.6
Associated Capacity	MW	26	20	26	3.1	2.8	2.5	2.4	2.4
Annual Energy Production	GWH	54.0	53.0	53.0	42.0	42.0	41.0	28.0	28.0
Firm Energy	GWH	37.0	40.0	36.0	22.0	22.0	23.0	12.0	12.0
Secondary Energy	GWH	17.0	13.0	17.0	20.0	18.0	16.0	16.0	16.0
Construction Cost	10 <sup>8</sup> B								
for Generating F.		1,666	1,701.5	1,702.5	998.0	1,016.0	1,027.0	561.1	563.0
for Transmission F.									
Bensih	10 <sup>8</sup> B								
for first kW		102.1	103.4	100.6	73.6	75.2	75.0	46.0	46.0
for first kWh		42.9	46.0	42.4	25.7	27.7	29.0	13.7	14.2
for Secondary kW		37.7	40.8	36.7	22.4	24.5	25.5	12.2	12.2
for Secondary kWh		9.8	7.6	9.8	11.7	10.6	9.5	9.1	9.1
Annual Cost	10 <sup>8</sup> B								
for Generating F.		184.9	188.9	189.0	110.8	112.8	114.0	62.3	62.3
for Transmission F.									
B/C	10 <sup>8</sup> B	Δ 82.8	Δ 85.5	Δ 88.4	Δ 37.2	Δ 37.6	Δ 39.0	Δ 16.3	Δ 16.5
B/C		0.55	0.55	0.53	0.66	0.67	0.66	0.74	0.74
Annual Energy Cost	\$/kWh	3.42	3.56	3.57	2.64	2.69	2.78	2.22	2.23
Simulation Case No.		R28645.10	R28645.20	R28645.30	R28615.10	R28615.15	R28615.20	R20385.50	R28585.15

Project Type. SG : Storage Type. RR : Run-of-River Type  
PG : Pondage Type.



Table 5-9 1st Stage Planning Study Upper Mae Rit 2a

C. A 525 km<sup>2</sup>  
Annual Inflow 163 MCM

H.W.L.	m	445	490	535
Total Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	0.3	15.8	—
Case No.		(10)	(11)	(12)
Project Type		PG	PG	RR
Dam Height	m	63	38	13
Tunnel Length	“	5,500	5,845	5,960
Available Drawdown	m	5	5	—
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	3.2	0.8	—
N.I.W.L.	m	581.3	556.9	534.0
L.W.L.	“	575	555	—
T.W.L.	“	407	407	407
Gross Head	“	178	153	128
Effective Normal Head	“	151.4	126.9	104
Firm Discharge (95%)	m <sup>3</sup> /s	1.8	1.6	1.5
Max. Turbine Discharge	“	9.9	9.9	9.9
Installed Capacity	MW	13.1	11.0	9.0
Firm Capacity	“	9.6	6.8	1.4
Associated Capacity	“	4.9	4.4	2.8
Annual Energy Production	GWH	53.0	44.0	37.1
Firm Energy	“	21.0	15.0	12.2
Secondary Energy	“	32.0	29.0	24.9
Construction Cost	10 <sup>6</sup> B			
for Generating F.	“	745.1	599.9	433.7
for Transmission F.	“	—	—	—
Benefit	10 <sup>6</sup> B			
for first kW	“	24.4	17.3	3.6
for first kWh	“	21.4	15.3	12.4
for Secondary kW	“	18.5	16.6	12.4
for Secondary kWh	“	22.1	20.0	13.7
Annual Cost	10 <sup>6</sup> B			
for Generating F.	“	82.7	66.6	48.1
for Transmission F.	“	—	—	—
B - C	10 <sup>6</sup> B	3.70	2.60	Δ 6.0
B / C	“	1.04	1.04	0.88
Annual Energy Cost	B/kWh	1.56	1.51	1.30
Simulation Case No		R2aD 585.5	R2aD 560.5	R2aE 535.0

Project Type. SG : Storage Type, RR : Run-of River Type  
PG ; Pondage Type,

Table 5-10 1st Stage Planning Study Upper Mae Rit 3

C. A 349 km<sup>2</sup>  
Annual Inflow 108.6 MCM

H. W. L.	m	445	490		
Total Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	0.3	15.8		
Case No.		①	②	③	④
Project Type		R.R	P.G	P.G	S.G
Dam Height	m	--	64	64	64
Tunnel Length	m	6,800	6,800	6,800	6,800
Available Drawdown	m	--	5	10	15
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	--	4.1	7.1	9.7
N. I. W. L	m	445	486.3	484.4	482.3
L. W. L	m	--	485	480	475
T. W. L	m	281	281	281	281
Gross Head	m	164	209	209	209
Effective Normal Head	m	138	176.1	174.2	172.0
Firm Discharge (95%)	m <sup>3</sup> /s	0.27	1.38	1.59	1.73
Max. Turbine Discharge	m <sup>3</sup> /s	6.58	6.58	6.58	6.94
Installed Capacity	MW	7.9	10.1	10.0	10.4
Firm Capacity	MW	1.2	8.4	9.4	10.0
Associated Capacity	MW	2.5	3.6	3.3	3.2
Annual Energy Production	GWH	32.7	41.8	42.2	42.7
Firm Energy	GWH	10.7	10.5	20.6	21.8
Secondary Energy	GWH	22.0	23.3	21.6	20.9
Construction Cost	10 <sup>6</sup> B				
for Generating F.	B	447.9	829.7	831.5	838.1
for Transmission F.	B	--	--	--	--
Benefit	10 <sup>6</sup> B				
for first kW	B	3.0	21.3	23.9	25.4
for first kWh	B	10.9	10.7	21.0	22.2
for Secondary kW	B	11.1	13.6	12.5	12.1
for Secondary kWh	B	12.1	16.1	14.9	14.4
Annual Cost	10 <sup>6</sup> B				
for Generating F.	B	49.7	92.1	92.3	93.0
for Transmission F.	B	--	--	--	--
B - C	10 <sup>6</sup> B	Δ 12.6	Δ 304	Δ 200	Δ 18.9
B / C		0.75	0.67	0.78	0.80
Annual Energy Cost	B/kWh	1.52	2.20	2.19	2.18
Simulation Case No		R3E445.0	R30490.5	R30490.10	R38490.15

Project Type. SG : Storage Type, RR: Run-of River Type  
PG : Pondage Type.



Table 5-12 1st Stage Planning Study Nam Mae Ngao (Site No. 3)

C.A 756 km<sup>2</sup>  
Annual Inflow 1,182 MCM

Description	Unit	H.W.L		280 m		260 m		H.W.L		260 m	
		Total Storage Capacity	MCM	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
Case No.											
Project Type											
Dam Height	m	120	120	120	120	120	120	100	100	100	100
Tunnel Length											
Available Drawdown	m	10	15	20	25	10	15	20	25	20	25
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	212	315	409	494	156	218	269	315	269	315
N.I.W.L	m	274.8	272.3	270.3	268.9	255.1	253.0	251.0	248.9	251.0	248.9
L.W.L	m	270	265	260	255	250	245	240	235	240	235
T.W.L	m	171	171	171	171	171	171	171	171	171	171
Gross Head	m	109	109	109	109	89	89	89	89	89	89
Effective Normal Head	m	100.6	98.1	96.0	94.7	81.4	79.3	77.3	75.2	77.3	75.2
Firm Discharge (95%)	m <sup>3</sup> /s	17.9	22.7	25.5	26.5	15.0	18.2	20.5	22.7	20.5	22.7
Max. Turbine Discharge	m <sup>3</sup> /s	79.9	91.0	101.9	106.1	79.9	79.9	82.1	91.0	82.1	91.0
Installed Capacity	MW	700	778	854	87.6	567	552	554	597	554	597
Firm Capacity	MW	59.9	72.0	76.2	74.7	40.1	45.4	47.5	48.7	47.5	48.7
Associated Capacity	MW	21.9	17.5	15.9	16.1	200	17.7	16.5	15.4	16.5	15.4
Annual Energy Production	GWH	269.1	266.8	263.8	253.8	216.0	212.0	208.0	204.0	208.0	204.0
Firm Energy	GWH	131.1	157.7	166.9	163.6	88.0	99.0	104.0	107.0	104.0	107.0
Secondary Energy	GWH	138.0	109.1	96.9	100.2	128.0	113.0	104.0	97.0	104.0	97.0
Construction Cost	10 <sup>6</sup> B										
for Generating F.		2,927	2,998	3,072	3,115	2,140	2,139	2,151	2,201	2,151	2,201
for Transmission F.											
Benefit	10 <sup>6</sup> B	463.8	485.3	492.0	485.6	355.6	361.2	361.7	358.6	361.7	358.6
for first kW		152.1	182.9	193.5	189.7	101.9	115.3	120.7	123.7	120.7	123.7
for first KWH		133.7	160.9	170.2	166.9	89.8	101.0	106.1	109.1	106.1	109.1
for Secondary kW		82.8	66.2	60.1	60.9	75.6	66.9	62.4	58.2	62.4	58.2
for Secondary KWH		95.2	75.3	68.2	69.1	88.3	78.0	72.5	67.6	72.5	67.6
Annual Cost	10 <sup>6</sup> B										
for Generating F.		324.9	332.8	341.0	345.8	237.5	237.4	238.8	244.3	238.8	244.3
for Transmission F.											
B - C	10 <sup>6</sup> B	138.9	152.5	151.0	140.8	118.1	123.8	122.9	114.3	122.9	114.3
B / C		1.43	1.46	1.44	1.41	1.50	1.52	1.51	1.47	1.51	1.47
Annual Energy Cost	B/kwh	1.21	1.25	1.28	1.31	1.10	1.12	1.14	1.20	1.14	1.20
Simulation Case No		N#30280.10	N#38280.15	N#38280.20	N#38280.25	N#30260.10	N#30260.15	N#38260.20	N#38260.25	N#38260.20	N#38260.25

Project Type. SG : Storage Type, RR : Run-of River Type  
PG : Pondage Type

Table 5-13 1st Stage Planning Study Upper Mae Ngao

Description	Unit	420 m		380 m		340 m	
		H.W.L. Total Storage Capacity	4.22 MCM	H.W.L. Total Storage Capacity	1.61 MCM	H.W.L. Total Storage Capacity	43.2 MCM
Case No.		(1)	(2)	(3)	(4)	(5)	(6)
Project Type		S.G	S.G	S.G	S.G	S.G	S.G
Dam Height	m	160	160	160	120	120	80
Tunnel Length	m						
Available Drawdown	m	10	15	20	10	15	20
Effective Storage Capacity	10 <sup>6</sup> m <sup>3</sup>	71	111	152	398	566	713
N.I.W.L	m	414.0	412.1	411.2	374.5	372.3	370.0
L.W.L	m	410	405	400	370	365	360
Gross Head	m	271.1	271.1	271.1	271.1	271.1	271.1
Effective Normal Head	m	148.9	148.9	148.9	108.9	108.9	108.9
Firm Discharge (95%)	m <sup>3</sup> /s	138.4	136.6	135.7	100.2	97.9	95.7
Max. Turbine Discharge	m <sup>3</sup> /s	5.0	5.5	5.9	3.5	4.3	5.0
Installed Capacity	MW	24.0	26.6	27.9	14.7	14.7	16.7
Firm Capacity	MW	23.3	25.2	25.5	11.8	13.6	14.9
Associated Capacity	MW	4.4	3.9	3.9	4.7	4.0	3.5
Annual Energy Production	GWH	79.8	80.3	80.8	56.3	55.9	55.3
Firm Energy	GWH	51.1	55.2	55.9	25.8	29.9	32.7
Secondary Energy	GWH	28.7	25.1	24.9	30.5	26.0	22.6
Construction Cost	10 <sup>8</sup> B	4,940	4,963	4,973	2,402	2,406	2,428
for Generating F.							
for Transmission F.							
Benefit	10 <sup>8</sup> B	147.7	152.3	153.7	95.1	98.0	100.0
for first RW		59.2	64.0	64.9	30.0	34.5	37.8
for first KWH		52.1	56.3	57.0	26.3	30.5	33.4
for Secondary RW		16.6	14.7	14.7	17.8	15.1	13.2
for Secondary KWH		19.9	17.3	17.2	21.0	17.9	15.6
Annual Cost	10 <sup>8</sup> B	548.3	550.9	552.0	266.6	267.1	269.5
for Generating F.							
for Transmission F.							
B - C	10 <sup>8</sup> B	Δ 400.6	Δ 396.6	Δ 398.3	Δ 171.5	Δ 169.1	Δ 169.5
B / C		0.27	0.28	0.28	0.36	0.37	0.37
Annual Energy Cost	\$/kWh	6.97	6.96	6.83	4.74	4.78	4.87
Simulation Case No		N1842010	N1842015	N1842020	N1838010	N1838015	N1838020
					N1834050	N1834010	N1834015

Project Type. SG : Storage Type. RR : Run-of River Type  
PG : Pondage Type.

Table 5-14-1 Summary of First Stage Study, Mater Plan of Nam Yuam River Basin

10 December, 1985

Unit	Upper Mae Yuam 1	Upper Mae Yuam 2	Upper Mae Yuam 3	Nam Mae Rit	Upper Mae Rit 1	Upper Mae Rit 2	Upper Mae Rit 2a	Upper Mae Rit 3	Nam Mae Ngao (Site No.2)	Nam Mae Ngao (Site No.3)	Upper Mae Ngao 1
C.A.	1967	1149	447	1268	686	525	525	525	835	756	159
Annual Inflow	570	333	129.5	395	214	163	163	163	1304	1182	249
Case No.	1	9	1	7	2	8	8	4	15	6	8
Project Type 1)	SG	SG	SG	SG	PG	PG	PG	SG	SG	PG	PG
Dam Height	75	65	62	83	66	63	38	64	95	100	80
Tunnel Length	-	-	-	5100	2110	6800	5845	6800	-	-	-
HWL	325	380	477	270	407	585	560	490	250	260	340
NHWL	319.7	374.2	470.7	265.5	401.8	579.4	556.9	482.3	240.8	253	335
LWL	315	370	467	260	397	575	555	475	230	245	330
TWL	262	326.5	428	192	281	491	407	281	163	171	271.1
Total Storage	455	178	67.6	79	19.4	13.5	3.2	15.8	478	538	43.2
Draw down	10	10	10	10	10	10	5	15	20	15	10
Effective Storage	190	75	32.3	22.5	8.1	5.3	0.8	9.7	251	218	15.2
Gross Head	63	53.5	49	78	126	94	153	209	87	89	68.9
Effective Normal-Head	55.8	46.1	41.3	71.2	90.9	83.7	126.9	172	75.2	79.3	61.8
95% Firm Discharge	12.5	7.1	2.8	5.55	2.72	2.0	1.6	1.73	20.6	18.2	2.2
Max. Turbine Discharge	50.1	28.4	11.3	22.2	12.9	8.3	9.9	6.94	82.6	79.9	16.8
Installed Capacity	24.4	11.4	4.1	13.8	10.3	6.1	11.0	10.4	54.2	55.2	9.1
Firm Capacity	22.3	10.4	3.7	12.7	8.2	5.6	6.8	10.0	46.4	45.4	4.3
Associated Capacity	4.2	2.1	0.7	5.1	3.9	2.4	4.4	3.2	18.7	17.7	3.6
Annual Energy-Production	76.0	37.0	13.0	61.0	42.5	28.0	44.0	42.7	220.7	212.0	33.2
Firm Energy	49.0	23.0	8.1	28.0	17.9	12.0	15.0	21.8	101.5	99.0	9.4
Secondary Energy	27.0	14.0	4.9	33.0	24.6	16.0	29.0	20.9	118.2	113.0	23.8
Capacity Factor 2)	0.36	0.37	0.36	0.50	0.47	0.52	0.46	0.47	0.46	0.44	0.42
Construction Cost	1335.9	822	475	968	837.2	561.1	599.9	838.1	2021	2139	909.1
Annual Benefit	141.1	67.5	23.7	103.6	70.8	46.5	69.2	74.1	374.3	361.2	50.5
for Firm KW	56.6	26.4	9.4	32.3	20.8	14.2	17.3	25.4	117.9	115.3	10.9
for Firm KWH	50.0	23.5	8.3	28.6	18.3	12.2	15.3	22.2	103.5	101.0	9.6
for Associated KW	15.9	7.9	2.6	19.3	14.7	9.1	16.6	12.1	76.7	66.9	13.6
for Secondary KWH	18.6	9.7	3.4	22.8	17.0	11.0	20.0	14.4	82.2	78.0	16.4
Annual Cost	148.3	91.2	52.7	107.4	92.9	62.3	66.6	93.0	224.3	237.4	100.9
B-C	Δ7.2	Δ23.7	Δ29.0	Δ4.4	Δ22.1	Δ15.8	2.6	Δ18.9	150	123.8	Δ50.4
B/C	0.95	0.74	0.45	0.96	0.76	0.75	1.04	0.80	1.67	1.52	0.50
Annual Energy Cost	1.95	2.46	4.05	1.76	2.19	2.24	1.51	2.18	1.02	1.12	3.04
Simulation Case No.	Y1E325.10	Y2B380.10	Y3B477.10	ROB270.10	R1B407.10	R2D585.10	R2AD560.5	R3B490.15	NO2B250.20	MO3D260.15	N1D340.10
Rank of the Project	4	7	9	3	6	5	2	5	1	8	8
Selected Project for the Second Stage-Study	*	*	*	*	*	*	*	*	*	*	*

1) Project Type, SG : Storage Type  
PG : Pondage Type

2) Capacity Factor = Annual Energy Production (MWH) / Installed Capacity (MW) x 8760 (hr)

#### 5.4 Selected Main Projects (Second Stage Study)

In this stage, further detailed studies were performed for the four main projects selected in the first stage study.

Main items studied more in detail are as following:

- 1) 1:5,000 scale map prepared by EGAT was used as against 1:50,000 scale map used for the first stage study.
- 2) Evaporation loss from the proposed reservoir surfaces was estimated and deducted from the inflow so that net inflow were input to the reservoir simulation program. In order to estimate the loss, however, pre-simulation of the reservoir operation was needed to obtain the monthly variation of the reservoir surface area.
- 3) Three daily plant factors, 0.15, 0.20 and 0.25 were adopted for comparison purpose as against only one daily plant factor of 0.25 in the first stage study.
- 4) High water levels and low water levels were varied with narrower intervals than those adopted in the first stage study taking into account the new information collected through the second field survey.
- 5) Runoff regulation effect of Nam Mae Ngao on Lower Yuam was newly studied. The incremental benefit due to this effect will be described in the later section.
- 6) Several transmission line routes were compared for formulating the optimal transmission scheme. The details of the study are contained in Chapter 7.
- 7) Irrigation benefit which would be expected to accrue from the development of Upper Mae Yuam 1 was studied. Although the details of the study are explained in Chapter 10, the result shows up a negligible incremental irrigation benefit.

However, following basic values were unchanged from those adopted in the first stage study.

a) Fuel prices, other relevant costs and coefficients of the alternative thermal power plants which were used for the economic evaluation of the hydro power projects.

b) Discount rate, 10%

Based upon the above new information and additional requests for the variation of basic values, the number of cases studied in the second stage excluding pre-run cases for evaporation loss estimation has come up to:

Upper Mae Yuam 1	.....	3 cases
Nam Mae Rit	.....	12 cases
Upper Mae Rit 2a	.....	8 cases
Nam Mae Ngao	.....	24 cases
Effect on Lower Yuam	.....	8 cases
Total:		55 cases

Among these, only Upper Mae Rit 2a was studied using 1:50,000 scale map and Upper Mae Yuam 1 was studied belatedly to others after the 1:5,000 scale map was availed to the team on September 1986.

The reservoir operation study was performed for each case employing the same procedure as adopted in the first stage study.

The details of the results were included in the "Master Plan Study on Nam Yuam River Basin Hydroelectric Development Project, Study Result (Second Stage), June, 1986", "The Master Plan Study on Nam Yuam River Basin Hydroelectric Development Project, The Second Progress Report, August 1986" and in particular, the computer output volumes submitted and explained to EGAT in June 1986, so that those details have not been attached here except the summary results for all the cases as shown on Table 5-15 through Table 5-20.

From these results it is seen that Nam Mae Ngao (No.2 Site) Case (1) is most economical for individual development scheme (see Table 5-18), but from the view point of integrated development scheme, Nam Mae Ngao plus Lower Yuam, Case VI in Table 5-20 is most superior.

All the other projects, Upper Mae Yuam 1, Nam Mae Rit and Upper Mae Rit 2a resulted in the B/C ratios less than 1.0. Therefore, the key



projects in the Nam Yuam river development planning should be Nam Mae Ngao and Lower Yuam which are to be further studied in the next stage of the study.

Table 5-14-2 Summary of Second Stage Study

	Unit	Mae Ngao (Site No.2)	Mae Rit	Mae Rit 2a	Upper Yuan 1
C.A.	Km <sup>2</sup>	835	1,268	525	1,967
Annual Inflow	MCM	1,292	395	163	567
Case No.		3	2	3	1
Project Type 1)		SG	SG	PG	SG
Dam Height	m	114	87	38	62
Tunnel Length	m	-	-	5,845	-
HWL	m	260	270	560	325
NIWL	m	248.4	262.9	556.9	319.4
LWL	m	235	255.0	555	315
TWL	m	163	192	407	277
Total Storage	MCM	661.2	85.7	3.2	421.4
Draw down	m	25	10	5	10
Effective Storage	MCM	355.2	34.7	0.8	188.1
Gross Head	m	97	78	153	48.0
Effective Normal-Head	m	82.5	68.5	126.9	41.0
95% Firm Discharge	CmS	24.9	6.18	1.56	13.2
Max. Turbine Discharge	CmS	166.2	41.2	10.4	53.0
Installed Capacity	MW	116.9	24.0	11.2	18.5
Firm Capacity	MW	97.9	21.3	11.1	16.5
Annual Energy-Production	GWH	245.2	61.5	43.6	54.46
Firm Energy	GWH	128.6	28.0	14.5	36.17
Secondary Energy	GWH	116.5	33.5	29.1	18.29
Daily Plant Factor	%	15	15	15	25.0
Capacity Factor	%	23.9	29.2	44.5	33.6
Construction Cost	10M฿	3,373	1,273	698	1,791
Annual Benefit	10M฿	488.5	115.8	68.7	100
for Firm KW	10M฿	171.8	37.4	19.5	29
for Firm KWH	10M฿	197.5	43.0	22.3	55.6
for Secondary KWH	10M฿	119.2	35.4	26.9	15.4
Annual Cost	10M฿	374.4	141.3	77.5	198.8
B/C	10M฿	1.305	0.82	0.858	0.503
Simulation Case No.		No2A260.25b	ROA270.15b	R2aA560.5b	Y1V325.10b

1) Project Type, SG: Storage Type

PG: Pondage Type

Table 5--15 2nd Stage Study Upper Mae Yuam 1

C. A 1967km<sup>2</sup>  
Annual flow 567MCM

Available draw down	Unit m	HWL 325m PF=0.25		
		10	15	20
Case No.		①	②	③
Simulation case No.		YIV325-10b	YIV325-15b	YIV325-20b
Project type		SG	SG	SG
Dam height	m			
Tunnel length	m			
Total storage capacity	MCM	421.4	421.4	421.4
Effective storage capacity	MCM	188.1	257.4	311.9
HWL	m	325	325	325
NIWL	m	319.4	318.2	317.1
LWL	m	315	310	305
TWL	m	277	277	277
Gross head	m	48	48	48
Effective head	m	41.0	39.7	38.7
Daily plant factor	%	25	25	25
Capacity factor	%	33.6	32.4	31.8
95 % firm discharge	cms	13.2	13.7	13.9
Max. turbine discharge	cms	53.0	54.9	55.8
Installed capacity	MW	18.5	18.6	18.4
Firm capacity	MW	16.5	14.8	12.6
Annual energy production	GWH	54.5	52.7	51.3
firm energy	GWH	36.2	32.3	27.7
secondary energy	GWH	18.3	20.4	23.6
Construction cost	M฿			
for generating F.	M฿	1791	1791	1791
for transmission F.	M฿	—	—	—
Benefit	M฿	100.0	92.7	84.4
for firm kW	M฿	29.0	26.0	22.1
for firm kWh	M฿	55.6	49.6	42.5
for secondary kWh	M฿	15.4	17.1	19.8
Annual cost	M฿			
for generating F.	M฿	198.8	198.8	198.8
for transmission F.	M฿	—	—	—
B / C		0.503	0.466	0.425




Fig. 5-1 Flow Mass Curve Upper Mae Yuam 1 (Case YIB 325.10)

Table 5-16 2nd Stage Study Upper Mae Rit

C.A  
Annual flow 1268 km<sup>2</sup>  
395 MCM

Available draw down	Unit	HWL 270m		PF=0.15		HWL 265m		PF=0.15		HWL 270m		PF=0.20		HWL 265m		PF=0.25	
		10	15	10	15	10	15	10	15	10	15	10	15	10	15	10	15
Case No.		①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭	⑮	⑯
Simulation case No.		ROA270.0a	ROA270.15b	ROA265.0a	ROA265.15b	ROA270.0b	ROA265.0b	ROA270.15b	ROA265.15b	ROA270.0b	ROA265.0b	ROA270.15b	ROA265.15b	ROA270.0b	ROA265.0b	ROA270.15b	ROA265.15b
Project type		SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG
Dam height	m																
Tunnel length	m																
Total storage capacity	MCM	85.7	85.7	73.5	73.5	85.7	85.7	73.5	73.5	85.7	85.7	73.5	73.5	85.7	85.7	73.5	73.5
Effective storage capacity	MCM	25.4	34.7	22.5	32.9	25.4	34.7	22.5	32.9	25.4	34.7	22.5	32.9	25.4	34.7	22.5	32.9
HWL	m	270	270	265	265	270	270	265	265	270	270	265	265	270	270	265	265
NWL	m	264.9	262.9	260.2	257.9	264.9	262.8	260.2	257.9	264.9	262.8	260.2	257.9	264.9	262.8	260.2	257.9
LWL	m	260	255	255	250	260	255	255	250	260	255	255	250	260	255	255	250
TWL	m	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192
Gross head	m	78	78	73	73	78	78	73	73	78	78	73	73	78	78	73	73
Effective head	m	70.5	68.5	66.0	63.7	70.5	68.5	66.0	63.7	70.5	68.5	66.0	63.7	70.5	68.5	66.0	63.7
Daily plant factor	%	15	15	15	15	20	20	20	20	20	20	20	20	20	20	25	25
Capacity factor	%	31.6	29.2	32.9	29.6	41.4	38.4	42.6	38.9	49.5	46.9	50.3	47.3	50.3	47.3	50.3	47.3
95% firm discharge	cms	5.65	6.18	5.44	6.06	5.65	6.18	5.44	6.06	5.65	6.18	5.44	6.06	5.65	6.18	5.44	6.06
Max. turbine discharge	cms	37.7	41.2	36.3	40.4	28.3	30.9	27.2	30.3	22.6	24.7	21.8	24.2	24.7	21.8	24.2	24.2
Installed capacity	MW	22.7	24.0	20.4	22.0	17.0	18.0	15.3	16.5	13.6	14.4	12.3	13.2	14.4	12.3	13.2	13.2
Firm capacity	MW	21.1	21.3	18.8	19.2	15.8	16.0	14.1	14.4	12.7	12.8	11.3	11.5	12.7	12.8	11.3	11.5
Annual energy production	GWH	62.8	61.5	59.7	57.1	61.6	60.6	57.1	56.2	58.9	59.2	54.3	54.7	58.9	59.2	54.3	54.7
firm energy	GWH	27.7	28.0	24.7	25.2	27.7	28.0	24.7	25.2	27.7	28.0	24.7	25.2	27.7	28.0	24.7	25.2
secondary energy	GWH	35.1	33.5	34.0	31.9	33.9	32.6	32.4	31.0	31.2	31.2	29.6	29.5	31.2	31.2	29.6	29.5
Construction cost	M\$																
for generating F.	M\$	1,297	1,273	1,235	1,305	1,223	1,216	1,142	1,121	1,075	1,151	1,098	1,090	1,075	1,151	1,098	1,090
for transmission F.	M\$																
Benefit	M\$	115.1	115.8	103.1	106.2	97.6	97.3	88.9	89.0	86.3	86.9	76.5	77.4	86.3	86.9	76.5	77.4
for firm kW	M\$	37.0	37.4	33.0	33.7	45.8	46.4	40.9	41.8	36.8	37.1	32.8	33.4	36.8	37.1	32.8	33.4
for firm kWh	M\$	42.5	43.0	37.9	38.7	23.3	23.5	20.8	21.2	23.3	23.5	20.8	21.2	23.3	23.5	20.8	21.2
for secondary kWh	M\$	35.6	35.4	34.2	33.8	28.5	27.4	27.2	26.1	26.2	26.2	23.0	22.9	26.2	26.2	23.0	22.9
Annual cost	M\$																
for generating F.	M\$	144.0	141.3	137.1	144.9	135.8	135.0	126.8	124.4	119.3	127.8	121.9	121.0	119.3	127.8	121.9	121.0
for transmission F.	M\$																
B - C	M\$																
B/C	M\$	0.799	0.620	0.767	0.733	0.719	0.721	0.701	0.715	0.723	0.680	0.628	0.640	0.723	0.680	0.628	0.640
Annual energy cost	¢/kWh																

SG : Storage, PG : Pondage, RR : Run-of-River Capacity factor annual energy / (installed capacity x 8760)




Fig. 5-2 Flow Mass Curve Nam Mae Rit (Case ROB 270.15)

Table 5-17 2nd Stage Study Upper Mae Rit 2a

C.A 525 km<sup>2</sup>  
Annual flow 163MCM

Available draw down	HWL 580m PF=0.15		HWL 560m PF=0.15		HWL 560m PF=0.20		HWL 560m PF=0.20	
	10	15	5	10	10	15	5	10
Case No.	①	②	③	④	⑤	⑥	⑦	⑧
Simulation case No.	R2aA58010a	R2aA58015b	R2aA56015b	R2aA56010b	R2aA56010b	R2aA56015b	R2aA56015b	R2aA56010b
Project type	SG	SG	PG	PG	SG	SG	PG	PG
Dam height	58	58	38	38	58	58	38	38
Tunnel length	5510	5510	5845	5845	5510	5510	5845	5845
Total storage capacity	MCM	10.3	10.3	3.2	3.2	10.3	3.2	3.2
Effective storage capacity	MCM	4.1	5.4	0.8	1.6	4.1	0.8	1.6
HWL	m	580	580	560	560	580	560	560
NLWL	m	574.5	572.3	556.9	555.4	574.6	572.3	556.9
LWL	m	570	565	555	550	570	565	555
TWL	m	407	407	407	407	407	407	407
Gross head	m	173	173	153	153	173	153	153
Effective head	m	144.5	142.3	126.9	125.5	144.5	126.9	125.4
Daily plant factor	%	15.0	15.0	15.0	15.0	20.0	20.0	20.0
Capacity factor	%	38.0	36.6	44.5	42.7	47.4	46.3	53.5
95% firm discharge	cms	1.94	2.03	1.56	1.66	1.94	2.03	1.56
Max. turbine discharge	cms	12.9	13.5	10.4	11.1	9.68	10.1	7.78
Installed capacity	MW	15.9	16.4	11.2	11.8	11.9	12.3	8.4
Firm capacity	MW	15.4	15.6	11.1	11.3	11.3	11.7	8.3
Annual energy production	gWh	52.9	52.6	43.6	44.1	49.4	49.9	39.3
firm energy	gWh	20.2	20.4	14.5	14.9	20.2	20.5	14.5
secondary energy	gWh	32.7	32.2	29.1	29.2	29.2	29.4	24.8
Construction cost	M\$							
for generating F.	M\$	883	895	698	713	806	824	613
for transmission F.	M\$							
Benefit	M\$	89.3	90.0	68.7	70.1	74.9	75.9	57.1
for firm kW	M\$	27.0	27.4	19.5	19.8	33.4	33.9	24.1
for firm kWh	M\$	31.0	31.3	22.3	22.9	17.0	17.2	12.2
for secondary kWh	M\$	31.2	31.3	26.9	27.4	24.5	24.7	20.8
Annual cost	M\$							
for generating F.	M\$	98.0	99.5	77.5	79.1	89.5	91.5	68.0
for transmission F.	M\$							
B/C		0.899	0.899	0.858	0.872	0.803	0.812	0.796

SG: Storage, PG: Pondage, RR: Run-of-Rive. Capacity factor annual energy/(Installed capacity x 8760)




Fig. 5-3 Flow Mass Curve Upper Mae Rit 2a (Case R2a D 585.5)



Table 5-18 2nd Stage Study Nam Mae Ngao (No. 2 Site)

C. A , 935 km<sup>2</sup>  
Annual flow 1292MCM

Available draw down	Unit	HWL 260m					HWL 255m					PF = 0.15					PF = 0.15					PF = 0.20				
		15	20	25	30	35	15	20	25	30	35	25	30	35	25	30	35	25	30	35	25	30	35			
Case No.	m	①	②	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭	⑮	⑯	⑰	⑱	⑲	⑳	㉑	㉒			
Simulation case No.		NO2A26015b	NO2A26020b	NO2A26025b	NO2A26030b	NO2A26035b	NO2A25515b	NO2A25520b	NO2A25525b	NO2A25530b	NO2A25535b	NO2A25515b	NO2A25520b	NO2A25525b	NO2A25530b	NO2A25535b	NO2B26015b	NO2B26020b	NO2B26025b	NO2B26030b	NO2B26035b	NO2B26015b	NO2B26020b			
Project type		SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG	SG			
Dam height	m	105	105	105	105	105	100	100	100	100	100	100	100	100	100	105	105	105	105	105	105	105	105			
Tunnel length	m	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
Total storage capacity	MCM	661.2	661.2	661.2	661.2	661.2	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0	578.0			
Effective storage capacity	MCM	230.2	295.2	355.2	407.3	454.7	212.0	272.0	324.0	371.4	414.2	230.2	295.2	355.2	407.3	230.2	295.2	355.2	407.3	454.7	230.2	295.2	355.2			
HWL	m	260	260	260	260	260	255	255	255	255	255	255	255	255	255	260	260	260	260	260	260	260	260			
NIWL	m	252.8	250.6	248.4	246.4	244.9	247.9	245.7	243.7	241.5	239.5	252.9	250.6	248.3	246.4	252.9	250.6	248.3	246.4	244.9	243.7	241.5	239.5			
LWL	m	245	240	235	230	225	240	235	230	225	220	245	240	235	230	245	240	235	230	225	245	240	235			
TWL	m	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163	163			
Gross head	m	97	97	97	97	97	92	92	92	92	92	92	92	92	92	97	97	97	97	97	97	97	97			
Effective head	m	86.9	84.7	82.5	80.5	79.0	82.1	79.9	77.9	75.9	73.9	86.9	84.6	82.5	80.5	86.9	84.6	82.5	80.5	79.0	77.9	75.9	73.9			
Daily plant factor	%	15	15	15	15	15	15	15	15	15	15	15	15	15	15	20	20	20	20	20	20	20	20			
Capacity factor	%	30.8	26.9	23.9	22.4	21.7	32.2	27.9	26.0	23.4	22.3	30.8	26.9	23.9	22.4	30.8	26.9	23.9	22.4	21.7	20.2	18.2	16.2			
95% firm discharge	cms	19.1	22.2	24.9	26.8	27.8	18.2	21.2	23.0	25.5	27.0	19.1	22.2	24.9	26.8	19.1	22.2	24.9	26.8	27.8	29.8	31.6	33.4			
Max. turbine discharge	cms	127.6	147.7	166.2	178.7	185.0	121.5	141.3	153.2	170.2	180.0	127.6	147.7	166.2	178.7	127.6	147.7	166.2	178.7	185.0	195.7	210.7	224.7			
Installed capacity	MW	94.6	106.7	116.9	122.7	124.5	95.1	96.3	101.8	110.0	113.4	94.6	106.7	116.9	122.7	94.6	106.7	116.9	122.7	124.5	134.4	143.3	151.2			
Firm capacity	MW	86.1	93.3	97.9	97.6	93.2	76.9	83.4	83.9	86.0	83.2	86.1	93.3	97.9	97.6	86.1	93.3	97.9	97.6	93.2	92.0	87.6	83.2			
Annual energy production	GWH	255.4	251.5	245.2	240.8	236.2	240.1	234.7	232.1	225.9	221.3	255.4	251.5	245.2	240.8	255.4	251.5	245.2	240.8	236.2	231.6	227.0	222.4			
firm energy	GWH	113.1	122.6	128.6	128.3	122.5	101.1	109.6	110.3	113.0	109.4	113.1	122.6	128.6	128.3	113.1	122.6	128.6	128.3	122.5	118.6	114.0	109.4			
secondary energy	GWH	142.3	128.9	116.5	112.5	113.7	139.0	125.0	121.9	112.9	111.9	142.3	128.9	116.5	112.5	142.3	128.9	116.5	112.5	113.7	122.6	117.6	113.0			
Construction cost	M\$	314	3286	3373	3438	3472	2897	3035	3094	3190	3236	314	3286	3373	3438	314	3286	3373	3438	3472	3502	3502	3502			
for generating F.	M\$	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
for transmission F.	M\$	460.4	478.9	488.5	484.4	471.3	423.5	439.5	442.6	446.6	437.8	460.4	478.9	488.5	484.4	460.4	478.9	488.5	484.4	471.3	460.4	446.6	437.8			
Benefit	M\$	151.1	163.7	171.8	171.3	163.6	155.0	146.4	147.2	150.9	146.0	151.1	163.7	171.8	171.3	151.1	163.7	171.8	171.3	163.6	155.0	146.6	143.8			
for firm kW	M\$	173.7	188.3	197.5	197.1	188.2	155.3	168.3	169.4	173.6	168.0	173.7	188.3	197.5	197.1	173.7	188.3	197.5	197.1	188.2	155.3	146.6	143.8			
for firm kWh	M\$	135.6	126.9	119.2	116.0	119.6	133.3	124.8	125.9	122.1	123.8	135.6	126.9	119.2	116.0	135.6	126.9	119.2	116.0	119.6	122.1	115.3	110.1			
for secondary kWh	M\$	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
Annual cost	M\$	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
for generating F.	M\$	348.7	364.7	374.4	381.6	385.4	321.6	336.9	343.4	354.1	359.2	348.7	364.7	374.4	381.6	348.7	364.7	374.4	381.6	385.4	390.2	390.2	390.2			
for transmission F.	M\$	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—			
B / C		1.320	1.313	1.305	1.269	1.223	1.317	1.305	1.289	1.261	1.219	1.320	1.313	1.305	1.269	1.320	1.313	1.305	1.269	1.223	1.207	1.207	1.207			






Fig. 5-4 Flow Mass Curve Nam Mae Ngao (Case NOB 250.20b)

Table 5-19 2nd Stage Study Lower Yuam

C.A 5,920km<sup>2</sup>  
Annual flow 2,820MCM

Case No.	Unit	Individual development without upstream projects		Integrated development													
		①	②	Installed capacities are fixed at 152MW 1)		Installed capacities are estimated											
Simulation case No.		Y8V170-206	Y8A170-208	③	④	⑤	⑥	⑦	⑧	⑨	⑩	⑪	⑫	⑬	⑭	⑮	⑯
Upstream Projects																	
Name	None	None	None														
Simulation case No.																	
Lower Nam Yuam after upstream projects																	
Total storage capacity	MCM	444	444	444	444	444	444	444	444	444	444	444	444	444	444	444	444
Effective storage capacity	MCM	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260
HWL	m	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170	170
NLWL	m	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4	161.4
TWL	m	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2	73.2
Gross head	m	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8	96.8
Effective head	m	87.3	85.6	85.6	85.3	85.3	85.3	85.3	85.3	85.3	85.3	85.3	85.3	85.3	85.3	85.3	85.3
Daily plant factor		NA	0.148	0.15	0.239	0.247	0.254	0.254	0.225	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
Annual capacity factor		NA	0.380	0.384	0.389	0.397	0.398	0.388	0.386	0.248	0.239	0.233	0.233	0.233	0.233	0.233	0.261
95% firm discharge	cms	29.5	32.5	32.5	32.5	34.4	34.4	34.4	49.7	52.4	54.4	54.4	54.4	54.4	54.4	54.4	54.4
Max. turbine discharge	cms	21.5	219.5	216.9	219.5	220.2	220.2	220.2	220.2	220.2	220.2	220.2	220.2	220.2	220.2	220.2	220.2
Installed capacity	MW	162 1)	162 1)	160.1	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)	162 1)
Firm capacity	MW	128	139.9	138.2	139.7	140.3	140.3	140.3	140.3	140.3	140.3	140.3	140.3	140.3	140.3	140.3	140.3
Annual energy production	GWH	565	538.9	538.1	550.0	549.8	550.9	547.4	547.4	559.3	559.3	559.3	559.3	559.3	559.3	559.3	559.3
firm energy	GWH	NA	181.6	181.6	292.5	303.8	311.8	277.2	277.2	292.5	292.5	292.5	292.5	292.5	292.5	292.5	292.5
secondary energy	GWH	NA	357.3	356.5	257.5	246.0	239.1	270.2	270.2	266.8	266.8	266.8	266.8	266.8	266.8	266.8	266.8

Table 5-20 Integrated Development including Transmission Line  
 Nam Mae Ngao No. 2 + Lower Yuam

Case No.	Unit	Lower Yuam: Dam & Installed capacity are fixed.						Lower Yuam: Dam fixed. Installed capacity optimized					
		I	II	III	IV	V	VI	VI	VI	VI	VI	VI	
Case No. of Ngao No. 2		②NF2A260-20b	③NF2A260-25b	④NF2A260-30b	⑤NF2A260-35b	⑥NF2A260-20D	⑦NF2A260-25b	⑧NF2A260-30b	⑨NF2A260-35b	⑩NF2A260-20c	⑪NF2A260-25c	⑫NF2A260-30c	⑬NF2A260-35c
Case No. of Lower Nam Yuam		①YAVITO-20a	②YAVITO-20a	③YAVITO-20a	④YAVITO-20a	⑤YAVITO-20a	⑥YAVITO-20a	⑦YAVITO-20a	⑧YAVITO-20a	⑨YAVITO-20a	⑩YAVITO-20a	⑪YAVITO-20a	⑫YAVITO-20a
Installed capacity	MW	268.7	278.4	284.7	286.5	350.3	374.0	389.7	398.5				
Ngao No. 2	MW	106.7	116.9	122.7	124.5	106.7	116.9	122.7	124.5				
Lower Nam Yuam	MW	162.0	161.5	162.0	162.0	243.6	257.1	267.0	274.0				
Firm capacity	MW	233.6	237.6	237.9	233.5	304.2	320.5	328.8	330.5				
Ngao No. 2	MW	93.3	97.9	97.6	93.2	93.3	97.9	97.6	93.2				
Lower Nam Yuam	MW	139.9	140.3	139.7	140.3	210.9	222.6	231.2	237.3				
Annual firm energy	GWH	399.8	421.1	432.1	434.3	399.8	421.1	432.1	434.3				
Ngao No. 2	GWH	122.6	128.6	128.3	122.5	122.6	128.6	128.3	122.5				
Lower Nam Yuam	GWH	277.2	292.5	303.8	311.8	277.2	292.5	303.8	311.8				
Annual secondary energy	GWH	399.1	374.0	358.5	352.8	399.1	383.3	367.2	360.8				
Ngao No. 2	GWH	128.9	116.5	112.5	113.7	128.9	116.5	112.5	113.7				
Lower Nam Yuam	GWH	270.2	257.5	246.0	239.1	270.2	266.8	254.7	247.1				
Construction cost for generating f.	M\$	4,340	7,628	7,712.7	7,780	8,307	8,528.2	8,656.1	8,740.7				
Ngao No. 2	M\$	3,286	3,373	3,438	3,472	3,286	3,373	3,438	3,472				
Lower Nam Yuam	M\$	4,340	4,342	4,342	4,342	5,021	5,155.2	5,216.1	5,268.7				
Construction cost for transmission f.	M\$	400	465.5	465.5	465.5	465.5	465.5	465.5	465.5				
Ngao No. 2	M\$	65.5	65.5	65.5	65.5	65.5	65.5	65.5	65.5				
Lower Nam Yuam	M\$	400	400.0	400.0	400.0	400.0	400.0	400.0	400.0				
Total benefit	M\$	824.7	1,320.6	1,331.2	1,318.9	1,460.8	1,504.4	1,519.7	1,520.3				
unit benefit for firm capacity	M\$/kW	1,755	2,271	2,309	2,356	2,365	2,071	2,077	2,078				
benefit for total firm capacity	M\$	245.5	530.5	548.6	555.8	626.6	663.8	682.8	686.7				
unit benefit for firm energy	M\$/kWh	1,536	1,137	1,113	1,097	1,248	1,231	1,223	1,221				
benefit for total firm energy	M\$	278.9	454.7	468.7	474.1	498.8	518.4	528.3	530.3				
unit cost for secondary energy	M\$/kWh	0.8405	0.8405	0.8405	0.8405	0.8405	0.8405	0.8405	0.8405				
benefit for total secondary energy	M\$	300.3	335.4	314.3	301.3	355.4	322.2	308.6	303.3				
Total annual cost	M\$	543.0	925.2	934.8	942.3	1,034.8	1,060.2	1,074.7	1,084.1				
for generation facilities O:111	M\$	481.7	845.7	856.1	863.6	922.1	946.6	962.8	970.2				
for transmission facilities O:112	M\$	44.8	52.1	52.1	52.1	83.5	83.5	83.5	83.5				
for transmission losses Benefit x2%	M\$	16.5	26.4	26.6	26.6	29.2	30.1	30.4	30.4				
B - C	M\$	281.7	395.4	396.8	388.9	426.0	444.2	445.0	436.2				
B/C		1.519	1.427	1.424	1.413	1.394	1.412	1.414	1.402				
Annual energy cost	M\$/kWh	1.01	1.16	1.18	1.19	1.20	1.32	1.34	1.36				
Case to be adapted			Δ				○						

Table 5-21 Incremental Benefit of Lower Yuam due to the Effect of Nam Mae Ngao No. 2 Development (Lower Yuam: Dam & Installed Capacity are Fixed at F/S Levels-Second Stage)

		Individual Development			Integrated Development Nam Mae Ngao & Lower Yuam Case II	Increase (4)-(3)
		Nam Mae Ngao ③ NØ2A 260-25b	Lower Yuam ① YØV 170-200	Total (1)+(2)		
Case No.	Unit	(1)	(2)	(3)	(4)	(5)
Installed Capacity	MW	116.9	162.0	278.9	278.9	0
Firm Capacity	MW	97.9	139.9	237.8	237.6	-0.2
Annual Energy Production						
Firm Energy	GWH	128.6	181.6	310.2	421.1	110.9
Secondary Energy	GWH	116.5	357.3	473.8	374.0	-99.8
Total	GWH	245.1	538.9	784.0	795.1	11.1
Construction Cost						
Generating F.	MØ	3373.	4340.	7713	7713	0
Transmission F.	MØ	65.5	400.	465.5	465.5	0
Total	MØ	3438.5	4740.	8178.5	8178.5	0
Annual Benefit						
for Firm Capacity	MØ	171.8	245.5	417.3	548.6	131.3
for Firm Energy	MØ	197.5	278.9	476.4	468.7	-7.7
for Secondary Energy	MØ	119.2	300.3	419.5	314.3	-105.2
Total	MØ	488.5	824.7	1313.2	1331.6	18.4
Annual Cost						
for Generating F.	MØ	374.4	481.7	856.1	856.1	0
for Transmission F.	MØ	7.3	44.8	52.1	52.1	0
for Transmission Losses	MØ	9.8	16.5	26.3	26.6	0.3
Total	MØ	391.5	543.0	934.5	934.8	0.3
B - C	MØ	97.0	281.7	378.7	396.8	18.1
B/C		1.248	1.519	—	1.424	—
Energy Cost	B/kwh	1.60	1.01	—	1.18	—
Incremental Benefit	MØ					18.1

Table 5-22 Incremental Benefit of Lower Yuam due to the Effect of Nam Mae Ngao No. 2 Development (Lower Yuam: Dam is Fixed at F/S Level, Installed Capacity is Optimized-Second Stage)

		Individual Development			Integrated Development Nam Mae Ngao & Lower Yuam Case VI	Increase (4)-(3)
		Nam Mae Ngao ③ N#2A26025b	Lower Yuam ① Y#V170 200	Total (1)+(2)		
Case No.	Unit	(1)	(2)	(3)	(4)	(5)
Installed Capacity	MW	116.9	162.0	278.9	374.0	95.1
Firm Capacity	MW	97.9	139.9	237.8	320.5	82.7
Annual Energy Production						
Firm Energy	GWH	128.6	181.6	310.2	421.1	110.9
Secondary Energy	GWH	116.5	357.3	473.8	383.3	- 90.5
Total	GWH	245.1	538.9	784.0	804.4	20.4
Construction Cost						
Generating F.	M\$	3373.	4340.	7713	8528.2	815.2
Transmission F.	M\$	65.5	400.	465.5	745.5	280.0
Total	M\$	3438.5	4740.	8178.5	9273.7	1095.2
Annual Benefit						
for Firm Capacity	M\$	171.8	245.5	417.3	663.8	246.5
for Firm Energy	M\$	197.5	278.9	476.4	518.4	42.0
for Secondary Energy	M\$	119.2	300.3	419.5	322.2	- 97.3
Total	M\$	488.5	824.7	1313.2	1504.4	191.2
Annual Cost						
for Generating F.	M\$	374.4	481.7	856.1	946.6	90.5
for Transmission F.	M\$	7.3	44.8	52.1	83.5	31.4
for Transmission Losses	M\$	9.8	16.5	26.3	30.1	3.8
Total	M\$	391.5	543.0	934.5	1060.2	125.7
B - C	M\$	97.0	281.7	378.7	444.2	65.5
B/C		1.248	1.519	—	1.419	—
Energy Cost	B/kwh	1.60	1.01	—	1.32	—
Incremental Benefit	M\$					65.5




Fig. 5-7 Load Duration Curve, Northern Region, 2000 with Nam Mae Ngao Hydro Power Fitted






Fig. 5-8 Load Duration Curve, Northern Region, 2000 with Lower Yuam Hydro Power (Case 0) Fitted




Fig. 5-9 Load Duration Curve, Northern Region, 2000 with Nam Mae Ngao and Lower Yuam Integrated Development Projects (Case VI) Fitted

## 5.5 Additional Study

When the first stage and the second stage studies were being proceeded in 1985, the world oil price was at its highest level so that the evaluations of the benefit of the hydropower projects were made based upon that highest price level.

However, from the beginning of 1986 to around July 1986 the oil price has come down drastically to the present low price level and remains, it seems, calmly at this price level.

Although there are no assurances the price level would rocket up again, it was requested that the benefits of the hydro power projects selected in the previous stages should be re-evaluated based on the present low price level from a conservative view point.

Discussion was held between EGAT officials and team members at the end of the June 1986 on the fuel costs which would be adopted in the additional stage of study.

The finally concluded fuel costs are shown on Table 5-23 as base case and summarized and compared with those adopted in the previous stages in the same table.

It is seen that the adopted diesel oil price at 3.68  $\text{฿/lit}$  of the base case is only 56% of the one at 6.6  $\text{฿/lit}$  adopted in the previous stage.

Moreover, it is requested also that the fuel prices should be varied on several levels to see the impact of the oil price reduction on the project economy.

Table 5-23 Fuel Price Variations for Alternative Thermal Plants

Fuels	Unit	Case #			Fuel prices adopted in the second stage of study 4)
		No.1 1) Base Case	No.2 2)	No.3 3)	
Natural Gas	฿/MBtu	5) 71.09	75.16	79.24	87.38
Diesel Oil	฿/lit	6) 3.68	4.41	5.14 5)	6.60
Imported Coal	฿/kg	1.484	1.619	1.755	2.025
Lignite	฿/kg	0.5332	0.5332	0.5332	0.5332

1) Given by EGAT on July 3, 1986

2), 3) Assumed by the JICA team

4) Given by EGAT on Oct. 7, 1985 (Letter No. EGAT 32004/51394)

5)  $83 \text{ ฿/MBtu} - \text{Tax } 11.9053 \text{ ฿/MBtu} = 71.0947 \text{ ฿/MBtu}$

6)  $6.17 \text{ ฿/lit} - \text{Tax } 2.525 \text{ ฿/lit} + \text{Transport by ship } 0.035 \text{ ฿/lit} = 3.68 \text{ ฿/lit}$

1 US\$ = 26.5 ฿

Accordingly, in the additional stage, following number of cases were studied

Nam Mae Ngao (Individual Development) .....	6 cases
Lower Yuam (Individual Development) .....	6 cases
Nam Mae Ngao & Lower Yuam (Integrated Development) ....	6 cases
Total:	18 cases

However, the reservoir operations themselves undergo no change from the ones studied in the second stage. Among all the cases of the reservoir operation studied, only the ones of the finally adopted cases of Nam Mae Ngao individual development project and Nam Mae Ngao & Lower Yuam integrated development project are listed in Table 5-24 and Table 5-25 respectively.

The mass curves corresponding to these cases are also shown on Fig. 5-5 and Fig. 5-6 respectively.

Using these results, economic evaluation of the projects were performed for the various fuel cost cases as above described.

The result of the base case calculation shows that the B/C ratio of Nam Mae Ngao individual development project has come down to 1.2 from that of 1.3 attained in the second stage of study.

Also, the B/C ratio of the Nam Mae Ngao and Lower Yuam integrated development scheme reduced from the previous stage value of 1.4 to 1.3.

Even these reduced values, however, are well above the balance point of  $B/C=1$ , especially when the integrated development scheme will be realized.

As for the proposed dam site of Nam Mae Ngao project, further survey and investigation works based on the topographical and geological conditions are needed towards the start of the feasibility study.

Table 5-24 Reservoir Simulation Nam Mae Ngao

Case No.	NO2A260.25b			Project	Nam Mae Ngao 3	
CA at dam				835 Km <sup>2</sup>		
Annual inflow at dam				1292 MCM (40.95 cms)		
Project type				Storage		
NHWL	260 m	LWL	235 m	Draw down	25 m	
MWL	248.38 m	TWL	163 m	Head loss	2.9 m	
Maxhead	97 m	Eff normal head	82.45 m			
Total storage		661.2 MCM	Eff storage		355.2 MCM	
Effective storage / annual inflow				27 %		
Installed capacity				116.9 MW		
Firm capacity				97.9 MW		
Annual energy production (100%)				252.734 GWH		
Annual energy production (97%)				245.152 GWH		
Annual firm energy				128.647 GWH		
Annual secondary energy (100%)				124.087 GWH		
Annual secondary energy (97%)				116.505 GWH		
Daily plant factor		0.15	Machine efficiency		0.87	
Capacity factor = $\frac{\text{annual energy (97\%)}}{\text{installed capacity} \times 8760}$				= 0.239		
Flow utilizability = $(\text{inflow} - \text{spill}) / \text{inflow}$				= 99.5%		
Energy produced by 1m <sup>3</sup> of discharge				0.198 KWH		
Daily firm energy production				352.459 MWH		
Referenced gaging station				CA= 935 km <sup>2</sup> file : MR8		
Annual min discharges obtained by reservoir simulation in cms						
Yr	Min discharge	Yr	Min discharge			
2	32.935	14	34.872			
3	32.935	15	33.690			
4	32.692	16	32.359			
5	32.126	17	32.045			
6	30.996	18	28.539			
7	26.976	19	24.894			
8	26.976	20	24.894			
9	31.120	21	28.109			
10	31.120	22	32.101			
11	33.913	23	25.111			
12	30.651	24	25.111			
13	30.651					
Least minimum discharge				24.894 cms		
95% firm discharge				24.931 cms		
95% firm dis / mean inflow =				60.9%		
Parameters of uniform distribution for min discharges : Y = a + bX,						
a = -2.17806      b = 0.08937						
Maximum discharge				166.205 cms		
Max dis / mean inflow =				4.06		
Dam Ht		Tunnel length				
		Total	Present w	Levelized		
Construction cost						
Transmission line						
Total cost						
KW benefit						
KWH benefit						
Total benefit						
B-C	B/C		EOR			
Power production cost						
Discount rate			Price year			




Fig. 5-5 Flow Mass Curve Nam Mae Ngao (Case NO2A 260.25b)

Table 5-25 Reservoir Simulation Lower Yuam

Case No.	Y0A170.20b			Project	Lower Nam Yuam				
CA at dam				5,920 Km <sup>2</sup>		Referenced gaging station			
Annual inflow at dam				2,816 MCM					
Project type				Storage		CA=            km <sup>2</sup> file :			
NHWL 170 m	LWL 150 m	Draw down 20 m		Annual min discharges obtained by reservoir simulation in cms					
MWL 161.4 m	TWL 73.2 m	Head loss 2.9 m		Yr	Min discharge	Yr	Min discharge		
Maxhead 96.8 m	Eff normal head		85.3 m		2	70.054	14	71.186	
Total storage 444 MCM	Eff storage		260 MCM		3	69.395	15	68.617	
Effective storage / annual inflow				9 %		4	69.395	16	67.221
Installed capacity				267.0 MW		5	64.456	17	66.770
Firm capacity				231.2 MW		6	64.456	18	60.913
Annual energy production (100%)				575.819 GWH		7	56.892	19	56.210
Annual energy production (97%)				558.544 GWH		8	56.892	20	56.210
Annual firm energy				303.839 GWH		9	63.788	21	57.064
Annual secondary energy (100%)				271.980 GWH		10	63.788	22	64.680
Annual secondary energy (97%)				254.705 GWH		11	71.098	23	66.717
Daily plant factor 0.15	Machine efficiency		0.88		12	63.541	24	51.202	
Least minimum discharge				51.202 cms		13	63.541		
Capacity factor = $\frac{\text{annual energy (97\%)}}{\text{installed capacity} \times 8760} = 0.239$						95% firm discharge            54.426 cms			
Flow utilizability = $(\text{inflow} - \text{spill}) / \text{inflow} = 99.8 \%$						95% firm dis / mean inflow = 61.0 %			
Energy produced by 1m <sup>3</sup> of discharge				0.199 KWH		Parameters of uniform distribution for min discharges : Y = a + bX, a = -2.73183            b = 0.051112			
Daily firm energy production				832.437 MWH		Maximum discharge    362.843 cms			
Dam Ht 120 m				Tunnel length 240 m		Max dis / mean inflow = 4.07			
		Total	Present w	Levelized	Effect of upstream project, Ngao No. 2 (Case N02A260.30b) is considered. Installed capacity, etc. are determined based on the estimated plan: factor.				
Construction cost									
Transmission line									
Total cost									
KW benefit									
KWH benefit									
Total benefit									
B-C	B/C	EDR							
Power production cost									
Discount rate		Price year							






Fig. 5-6 Flow Mass Curve Lower Yuam (Case YOA 170.20b)

## 5.6 Incremental Benefit of the Lower Yuam Project

### 1) Combination of the Projects

The situation of Lower Yuam, which has been studied by JICA in response to the request of NEA in 1984, is considered in the Master Plan Study as if it is the existing power station.

The incremental benefit of Lower Yuam, accruing from the effects of the upstream projects, have to be examined systematically in relation with the upstream projects.

As described in the previous clause 5-4 "Selected Main Projects (Second Stage Study)", the selected four projects in the first stage study have also been restudied further by using 1:5,000 scale map except Upper Mae Rit 2a.

According to the study results, Nam Mae Ngao is the most promising project.

Strictly speaking, for the incremental benefit study of Lower Yuam Project, the effects of Nam Mae Rit and Upper Mae Yuam 1 have to be taken into account together with Nam Mae Ngao, because both projects are planned as reservoir type power station.

However, the Nam Mae Ngao project is the most important and superior among the four projects in terms of both the scale and the feasibility. Therefore outline of the basin development plan can be obtained almost definitely in the integrated development plan of Nam Mae Ngao and Lower Yuam.

Accordingly, the following cases were studied.

- . Dam and installed capacity are fixed at Feasibility Study level.
- . Dam is fixed at Feasibility Study level but installed capacity is optimized.

### 2) River Runoff Data

The river runoff data for 11 years at Ban Tha Rua, spanned between 1970 and 1980, have been used in the feasibility study made by JICA in 1984.

However, in the present study, as described in Chapter 4 "Meteorology and Hydrology", the runoff data of Ban Tha Rua have been extended from 11 years to 25 years, spanning between 1960 and 1984, by means of the regression analyses.

Accordingly, the extended runoff data for 25 years were adopted for the reservoir simulation study and the power and energy calculation of Lower Yuam.

### 3) Construction Cost

The construction cost of Lower Yuam has been reviewed applying the same work quantities of the feasibility study and the same unit price of the master plan study.

### 4) Incremental Benefit

As mentioned above, the incremental benefit was studied based upon the combination with Nam Mae Ngao and the reservoir operation using the extended runoff data. The results are shown in Table 5-20, 5-21 and 5-22 in the previous section 5-4 for the second stage of study, and in Table 5-26 for the additional stage of study. (More detailed results corresponding to the additional stage of study are contained in the later chapter 9, in Table 9-10 and 9-11). Note that in the additional stage, only the incremental benefit that accrues from the later case above (i.e. Dam is fixed but installed capacity optimized) was studied because this case is more realistic than the former case (i.e. Dam and installed capacity are fixed).

The leftmost column in Table 5-20, designated by case 0 corresponds to the values of the feasibility study made by JICA in 1984 which is the individual development plan without any effect from the upstream projects.

In this case, the economic feasibility is still dominant in terms of Benefit-Cost ratio (B/C); 1.519.

Table 5-26 Incremental Benefit of Lower Yuam due to the Effect of  
 Nam Mae Ngao No. 2 Development  
 (Lower Yuam: Dam & Installed Capacity are Fixed at F/S Level  
 - Additional Stage)

Case No.	unit	Individual development			Integrated development Nam Mae Ngao & Lower Yuam Case VI	In-crease (4)-(3)
		Nam Mae Ngao (3) NØ2A 260.25b	Lower Yuam (1) YØV170- 170.20o	Total (1)+(2)		
	unit	(1)	(2)	(3)	(4)	(5)
Installed capacity	MW	116.9	162.0	278.9	278.9	0
Firm Capacity	MW	97.9	139.9	237.8	237.6	-0.2
Annual energy production						
Firm energy	GWH	128.6	181.6	310.2	421.1	110.9
Secondary energy	GWH	116.5	357.3	473.8	374.0	-99.8
Total	GWH	245.1	538.9	784.0	795.1	11.1
Construction cost						
Generating f.	MØ	3,373	4,340	7,713	7,713	0
Transmission f.	MØ	65.5	400	465.5	465.5	0
Total		3,438.5	4,740	8,178.5	8,178.5	0
Annual benefit						
for firm capacity	MØ	171.8	245.5	417.3	548.6	131.3
for firm energy	MØ	197.5	278.9	476.4	468.7	-7.7
for secondary energy	MØ	119.2	300.3	419.5	314.3	-105.2
Total	MØ	488.5	824.7	1,313.2	1,331.6	18.4
Annual cost						
for generating f.	MØ	374.4	481.7	856.1	856.1	0
for transmission f.	MØ	7.3	44.8	52.1	52.1	0
for transmission losses	MØ	9.8	16.5	26.3	26.6	0.3
Total	MØ	391.5	543.0	934.5	934.8	0.3
B-C	MØ	97.0	281.7	378.7	396.8	18.1
B/C		1.248	1.519	-	1.424	-
Energy cost	Ø/ KWH	1.60	1.01	-	1.18	-
Incremental benefit	MØ					18.1

Nam Mae NGAO (No.2)




Fig. 5-10 Area-Capacity Curve, Nam Mae NGAO No. 2




Fig. 5-11 Area-Capacity Curve, Nam Mae Rit

NAM MAE NGAO SITE No.3




Fig. 5-12 Area-Capacity Curve, Nam Mae Ngao No. 3

UPPER MAE NGAO  
 (RELATED TO NAM MAE NGAO SITE No.2 )  
 CA = 490 km<sup>2</sup>




Fig. 5-13 Area-Capacity Curve, Upper Mae Ngao No. 2






Fig. 5-14 Area-Capacity Curve, Upper Mae Ngao No. 3

# UPPER MAE RIT 1




Fig. 5-15 Area-Capacity Curve, Upper Mae Rit 1

# UPPER MAE RIT 2




Fig. 5-16 Area-Capacity Curve, Upper Mae Rit 2

UPPER MAE RIT 3




Fig. 5-17 Area-Capacity Curve, Upper Mae Rit 3

UPPER MAE YUAM 2




Fig. 5-18 Area-Capacity Curve, Upper Mae Yuam 2

UPPER MAE YUAM 3




Fig. 5-19 Area-Capacity Curve, Upper Mae Yuam 3



## **CHAPTER 6. PRELIMINARY DESIGN**





## CHAPTER 6 PRELIMINARY DESIGN

### CONTENTS

	Page
6.1 Civil Main Structure .....	6 – 1
6.2 Electrical Equipment .....	6 – 4



## Figure List

	Page
Fig. 6-1 Nam Mae Ngao General Plan .....	6-11
Fig. 6-2 Nam Mae Ngao Dam .....	6-13
Fig. 6-3 Nam Mae Ngao Spillway .....	6-15
Fig. 6-4 Nam Mae Ngao Waterway .....	6-17
Fig. 6-5 Nam Mae Rit General Plan .....	6-19
Fig. 6-6 Nam Mae Rit Dam .....	6-21
Fig. 6-7 Nam Mae Rit Spillway .....	6-23
Fig. 6-8 Nam Mae Rit Waterway .....	6-25
Fig. 6-9 Upper Mae Yuam 1 General Plan .....	6-27
Fig. 6-10 Upper Mae Yuam 1 Dam .....	6-29
Fig. 6-11 Upper Mae Yuam 1 Spillway .....	6-31
Fig. 6-12 Upper Mae Yuam 1 Waterway .....	6-33
Fig. 6-13 Upper Mae Rit 2a .....	6-35
Fig. 6-14 Single Line Diagram. Ngao, Rit, Rit 2a .....	6-37



## CHAPTER 6. PRELIMINARY DESIGN

### 6.1 Civil Main Structure

Preliminary design has been carried out for the selected four projects; Nam Mae Ngao, Nam Mae Rit, Upper Mae Yuam 1 and Upper Mae Rit 2a, based upon the basic figures, studied in the previous Chapter 5 "Development Plan".

Topographic maps used for the preliminary design were 1:5,000 scale map for Nam Mae Ngao, Nam Mae Rit, and Upper Mae Yuam 1 and 1:50,000 scale map for Upper Mae Rit 2a.

Preliminary design drawings are shown on Fig. 6-1 through 6-13. However, those basic figures and preliminary design drawings should be required further review at the next feasibility study stage. Stated hereunder is the preliminary design outline at each project site.

#### 1) Nam Mae Ngao

The project undertakes construction of rockfill dam of 114 m height, 545 m crest length and  $5,360 \times 10^3 \text{m}^3$  volume on the axis along site No. 2.

Upstream and downstream faces are sloped at 1:2.0 and 1:1.8 respectively. The left bank of dam is provided with a spillway, which is capable to release the design flood of  $3,600 \text{m}^3/\text{sec}$ .

Two diversion tunnels are located on the left bank and one of them will be converted to an outlet structure in the future. An intake with the maximum intake quantity of  $166.2 \text{m}^3/\text{sec}$  is provided on the right bank upstream of the dam.

From the intake, a headrace and penstock convey the water intake by 7.0 - 6.5 m inner diameter and the length of 700 m, leading to the powerhouse for power generation of maximum output of 116.9 MW.

#### 2) Nam Mae Rit

The project undertakes construction of rockfill dam of 87 m height, 285 m crest length and  $2,100 \times 10^3 \text{m}^3$  volume on the axis

along the proposed site. Upstream and downstream faces are sloped at 1:2.0 and 1:1.8 respectively.

The left bank of dam is provided with a spillway, which is capable to release the design flood of 2,400 m<sup>3</sup>/sec. Two diversion tunnels are located on the right bank and one of them will be converted to an outlet structure in the future.

An intake with the maximum intake quantity of 41.2 m<sup>3</sup>/sec is provided on the right bank upstream of the dam. From the intake, a headrace and penstock convey the water intake by 4.1 - 3.8 m inner diameter and the length of 417 m, leading to the powerhouse for power generation of maximum output of 24.0 MW.

3) Upper Mae Yuam 1

The project undertakes construction of rockfill dam of 62 m height, 520 m crest length and 2,307 x 10<sup>3</sup>m<sup>3</sup> volume on the axis along the proposed site. Upstream and downstream faces are sloped at 1:2.0 and 1:1.8 respectively.

The left bank of dam is provided with a spillway, which is capable to release the design Flood of 2,900 m<sup>3</sup>/sec. Two diversion tunnels are located on the right bank and one of them will be converted to an outlet structure in the future.

An intake with the maximum intake quantity of 53.0 m<sup>3</sup>/sec is provided on the right bank upstream of the dam axis. From the intake, a headrace and penstock convey the water intake by 4.5 - 4.2 m inner diameter and the length of 259.0 m, leading to the powerhouse for power generation of maximum output of 18.5 MW.

4) Upper Mae Rit 2a

The project undertakes construction of rockfill dam of 38 m height, 105 m crest length and 177 x 10<sup>3</sup>m<sup>3</sup> volume on the axis along the proposed site. Upstream and downstream faces are sloped at 1:2.0 and 1:1.8 respectively.

The left bank of dam is provided with a spillway, which is capable to release the design flood of 1,500 m<sup>3</sup>/sec. Two diversion tun-

nels are located on the right bank and one of them will be converted to an outlet structure in the future.

An intake with the maximum intake quantity of  $10.4 \text{ m}^3/\text{sec}$  is provided on the right bank upstream of the dam axis. From the intake, a headrace and penstock convey the water intake by 2.5 - 1.8 m inner diameter and the length of 6,280 m, leading to the powerhouse for power generation of maximum output of 11.2 MW.