

Report No. 17: Food

REPORT ON THE DIAGNOSIS  
FOR  
ENERGY CONSERVATION

— Star Feed Mill Co., Ltd. —

January, 1984

Japan International Cooperation Agency

## Contents

1.	Outline of the Factory .....	17-1
2.	Manufacturing Process.....	17-2
3.	Major Equipment .....	17-2
4.	State of Energy Management .....	17-3
5.	State of Fuel Consumption .....	17-5
6.	Problems in Heat Control and Potential Solutions .....	17-7
7.	State of Electric Power Consumption .....	17-10
8.	Problems of Power Control and Potential Solutions.....	17-13
9.	Summary .....	17-18

The Diagnosis for Energy Conservation  
— Star Feed Mill Co., Ltd. —

I. Outline of the Factory

Address	29/8 Mue. 3 Lagsong Nongkaen Bangkok 10160	
Capital	4 Million Bt	
Type of industry	Food	
Major products	Livestock feed	
Annual product	55,000 ton	
No. of employees	80	
Annual energy consumption	Electric power	837,000 kWh
	Fuel	H.O. A. 158 kℓ
Interviewees	Mr. Apira : Factory Manager	
Date of diagnosis	July 18 ~ 19, 1983	
Diagnosers	A. Koizumi, S. Honda, Y. Kaneko	

Twelve years ago, this factory was established jointly by Thai capital and RALTON PURINA, USA. However, four years ago, the company came under the control of the C.P. Group (CHAROEN POCKAPHAN), and is now manufacturing various types of animal feed, especially for chicken and pig. Raw materials are mostly corn, soya bean cake, crushed rice, fish meal, rice bran, calcium, sodium, molasses, nutritives such as vitamins. These ingredients are mixed and manufactured into 22 kinds of livestock feed. There are two different forms of the feed: pellets and powder. The former accounts for 92% and is packed in a 30-kg bag.

The factory has a 60,000 t/year production capacity, but now maintains it at the level of 55,000 t/year. The operators are working on a two-shift basis and for 16 h/day. The number of operating days per year is 300 days.

2. Manufacturing Process




Fig. 17-1

3. Major Equipment

3.1 Major Equipment

Table 17-1

Name	No. of units installed	Type, etc.
Boiler	1	Flue tube boiler 0.5 t/h, 6 kg/cm <sup>2</sup>
Pelletizer	1	U.S.A. CPM Made

### 3.2 Layout




Fig. 17-2

## 4. State of Energy Management

### 4.1 Policy for Energy Conservation

The forward-looking attitude of the factory general manager for factory management is laudable. However, we were a little concerned about the lone activities of the general manager, because he himself had to cover an extensive range of works from routine management to future planning. We suggest that he keep his assistant staff, transfer his authority about a part of routine work to them, and limit the scope of his duties to listening to their reports and instructing them, and that in the meantime, he devote himself toward the solution of major problems of long-term and high-level nature such as rationalization of factory operation and planning of future developments.

With regard to energy conservation, the company set in 1981, a target for the achievement of a 10% energy conservation by the end of 1983. The company has put the following into practice:

- Heat Control

- (1) Recovery of condensate
- (2) Preheating of fuel
- (3) Repair and replacement of steam traps
- (4) Periodical checkup of boilers

- Electric Power Control

- (1) Removal of unnecessary lights
- (2) Improvement of switches for electric equipment
- (3) Prevention of motor idling

#### (4) Induction of solar light through ceiling

The investment in the above improvement was 600,000 Bt. The company has reached an energy conservation level of 12% up to now, thus achieving the set target.

#### 4.2 Participation by All Employees

The company, highly interested in employees' education, encourages the employees to participate in seminars by MOI and TPA. However, unfortunately, the staff members are not capable of making the best of knowledge which they have acquired at the seminars. Therefore, actually the general manager himself participated in the seminars and utilizes what he has learned there for improvements.

Through the daily operation, the employees are requested to cooperate in a safety campaign, activities aimed at achieving the target "clean workshop and office". They are also requested to be mindful about energy conservation. For the suggestion system, the company awards incentives to the employees for their broached excellent ideas, but is not actively making the most of the system.

In order to promote participation in the activities by all the employees, it is important to first appoint the staff members who assist in the general manager and encourage "small group activities" at the workshop mainly under the guidance of the staff members. It is observed that the factory has many subjects for study which are suitable to the small group activities, namely, maintenance of insulation, prevention of steam leakage and reduction of a loss in handling the products.

#### 4.3 Control through Data

The general manager makes it a rule to seek data on energy consumption rate from individual work results, prepare a control chart, evaluate fluctuations in the variables, analyze causes for the fluctuations and take necessary actions.

In this way, control through data is carried out satisfactorily. However, we recommend that henceforth, staff members be educated through the preparation of control data, and control through data be promoted on an organizational basis.

Thus it will be possible to arouse all the employees' interest in production control and make the best of the wisdom and knowledge of many people.

It is suggested that the company clarify the relationships between the factors such as raw material mixing, moisture content, grain size, pelletizing temperature and pressure, and the yield and quality of finished product, and energy consumption amount according to accumulated data, and that the company try to improve its technological level.

#### 4.4 Technological Leveling-Up of Employees

As the animal feed factory is one of the "Process industry", and productivity is highly valued. On account of its untiring efforts, the factory enjoys the most favorable level of unit fuel and electric power consumption rate. Nevertheless, the labor productivity is low as shown in Table 17-2.

Table 17-2 Feed Mill Consumption Ratio

	Fuel ℓ/t	Electricity kWh/t	Productivity t/month/1 person
Star feed mill	2.85	16.84	57
(Comparison) Hokkaido, Japan feed mills average	4.02	16.7	23.7

It is considered that in future, the company would face the necessity of further increasing the productivity following its development. In such a case, the company would have to minimize troubles by measures such as rationalization of transportation through improved layout and mechanization, and through perfect equipment maintenance services. At the factory, the general manager is only the person who supports its technological side. However, in future, the company will have to manage the factory by organizing a specialized system or using specialists. The problem which the general manager has to solve is to bring up technical staff and equipment engineers as quickly as possible.

5. State of Fuel Consumption

5.1 Fuel Consumption

Heavy oil A 158 kl/year

Breakdown of use — Pelletized feed 95% (Pelletizer) (150 kl)  
 — Compounded feed 5% (mixer) (8 kl)

Fuel for compounded feed is used for heating when mixing fats and molasses. However, it is not used now.

Fuel consumption rate: 158 kl/55,000 t = 2.8 l/t finished product

5.2 Heat Balance of Boiler

On July 18, 1983, we calculated the heat balance based on the results of boiler diagnosis as shown in Table 17-3.

Table 17-3

Input			Output		
Item	10 <sup>3</sup> kcal/h	%	Item	10 <sup>3</sup> kcal/h	%
Heat of fuel combustion	293.6	99.8	Heat of steam	247.9	84.2
Sensible heat of fuel	0.7	0.2	Heat loss in exhaust gas	31.1	10.6
			Heat loss in blow water	11.1	3.8
			Heat release from boiler body, others	4.8	1.4
Total	294.3	100.0	Total	294.3	100.0

### Elements for Calculation of Heat Balance

Fuel type		Heavy oil A
Fuel consumption	(F)	30.5 kg/h
Heat content of fuel (low value)	(HI)	9,625 kcal/kg
Specific gravity of fuel	(SG)	0.975
Specific heat of fuel	(Cp)	0.45 kcal/kg°C
Temperature of fuel	(Tf)	83°C
Reference temperature	(To)	31°C
Oxygen content in exhaust gas	(O <sub>2</sub> )	1.0%
Temperature of exhaust gas	(Tg)	307°C
Quantity of blow down water	(B)	89 kg/h
Temperature of blow down water	(Tb)	159.1°C
Quantity of feed water	(W)	486 kg/h
Temperature of feed water	(Tw)	34°C
Steam pressure	(P)	5.2 kg/cm <sup>2</sup> G
Quantity of steam (S = W - B)	(S)	397 kg/h
Enthalpy of steam	(Es)	658.4 kcal/kg
Enthalpy of feed water	(Ef)	34 kcal/kg

### Equation for Calculation of Heat Balance

Input		
Heat of fuel combustion	(Qc)	$293.6 \times 10^3$ kcal/h
$Q_c = F \times HI$		
Sensible heat of fuel	(Qs)	$0.7 \times 10^3$ kcal/h
$Q_s = F \times C_p (T_f - T_o)$		
Output		
Heat of steam	(Qv)	$247.9 \times 10^3$ kcal/h
$Q_v = S \times (E_s - E_f)$		
Heat loss in exhaust gas	(Qe)	$31.1 \times 10^3$ kcal/h
$Q_e = F \times G \times 0.33 (T_g - T_o)$		
Theoretical amount of air (Ao)		
$A_o = 0.85 HI / 1,000 + 2.0 = 10.18$ Nm <sup>3</sup> /kg		
Theoretical amount of exhaust gas (Go)		
$G_o = 1.11 HI / 1,000 = 10.68$ Nm <sup>3</sup> /kg		
Air ratio (m)		
$m = 21 / (21 - O_2) = 1.05$		
Actual amount of exhaust gas (G)		
$G = G_o + A_o(m - 1) = 11.19$ Nm <sup>3</sup> /kg		
Heat loss in blow down water	(Qb)	$11.1 \times 10^3$ kcal/h
$Q_b = B \times (T_b - T_w)$		
Heat release from body and others	(Qr)	$4.2 \times 10^3$ kcal/h



## 6. Problems in Heat Control and Potential Solutions

### 6.1 Control of Combustion in Boiler

At present, each boiler is operated for 16 hours a day and 300 days a year. We diagnosed the boiler by analyzing the exhaust gas of boiler three times.

Temperature of exhaust gas	°C	337	238	345
Oxygen content of exhaust gas O <sub>2</sub>	%	0.7	0.8	1.1

The temperature of exhaust gas is high. In the meantime, the air supply for combustion tends to be short. However soot is not blown down and the burners and tips are cleaned only once a month. This frequency is not enough. The sight of a slight rising smoke is suggestive of the fouling of inner tubing with soot. Therefore, it is necessary to increase the frequency of cleaning services to approx. once a week and adjust the quantity of air for combustion so that the oxygen content of exhaust gas may be approx. 4% and subsequently the generation of soot be prevented. At the same time, the temperature of exhaust gas must be lowered by cleaning boiler tubing.

If the temperature of exhaust gas is decreased at 250°C, the fuel consumption will be reduced as follows:

Assuming that the oxygen content of exhaust gas is 4%, we calculated the conserved fuel amount according to the heat balance table.

$$m' = 1.25$$

$$G' = 13.07 \text{ Nm}^3/\text{kg}$$

Assuming that the amount of fuel combustion after adjustment is  $x$  kg/h, the results are represented by the following equation:

$$\frac{294.3}{30.5} \cdot x = (247.9 + 11.1 + 4.2) + \frac{13.07 \times 0.33 (250 - 31)x}{1,000}$$

$$\therefore x = 30.2 \text{ kg/h}$$

Energy conservation rate

$$\frac{30.5 - 30.2}{30.5} \times 100 = 1.0\%$$

Annual amount of conserved heavy oil

$$158 \text{ kg/year} \times 0.01 = 1.6 \text{ kl/year}$$

### 6.2 Decrease in Quantity of Blow Down Water

The quantity of blow down water for boiler is equivalent to approx. 18% of the quantity of feed water. The electric conductivity of boiler water is low at 1,000  $\mu\text{S}/\text{cm}$  and the pH value is also low at 8.9. The tolerable electric conductivity of boiler water is up to approx. 6,000  $\mu\text{S}/\text{cm}$ . Therefore, the quantity of blow down water equivalent to 1/3 of its present quantity may be sufficient. The pH value needs to be maintained at 11 to 11.8, and also the consumption of chemicals may be small, if the quantity of blow down water is decreased.

If the quantity of conserved energy when the quantity of blow water is decreased from the present 89 kg/h to 30 kg/h, is calculated according to the heat balance table, the results will be as follows:

$$\frac{294.3}{30.5}x = (247.9 + 4.2) + \frac{30 \times (159.1 - 34)}{1,000} + \frac{31.1}{30.5}x$$

$$\therefore x = 29.6 \text{ kg/h}$$

Energy conservation rate

$$\frac{30.5 - 29.6}{30.5} = 3.0\%$$

Annual quantity of conserved heavy oil

$$158 \text{ kl} \times 0.03 = 4.7 \text{ kl/year}$$

### 6.3 Insulation of Boiler Body

The back wall of the boiler has a surface temperature of 135°C and the under-mentioned heat release occurs. The dimensions are 1.2 m for diameter, 0.038 m for thickness and 1.27 m<sup>2</sup> for surface area.

- Radiation heat loss

$$Q = 4.88 \epsilon A \left\{ \left( \frac{T_1}{100} \right)^4 - \left( \frac{T_2}{100} \right)^4 \right\} = 4.88 \times 0.8 \times 1.27 \left\{ \left( \frac{273 + 135}{100} \right)^4 - \left( \frac{273 + 31}{100} \right)^4 \right\}$$

$$= 947 \text{ kcal/h}$$

- Convection heat loss

$$Q = ac \times A \times \Delta t = 2.2 \times A \times \Delta t^{1.25} = 2.2 \times 1.27 \times 104^{1.25} = 930 \text{ kcal/h}$$

$$\text{Total} \quad 1,877 \text{ kcal/h}$$

If the said part of the boiler is insulated by 30mm calcium silicate and galvanized iron sheet to lower the surface temperature to 50°C, the heat release amount will be represented by the following equation:

$$\text{Radiation heat loss} = 4.88 \times 0.3 \times 1.27 \left\{ \left( \frac{273 + 50}{100} \right)^4 - \left( \frac{273 + 31}{100} \right)^4 \right\} = 43 \text{ kcal/h}$$

$$\text{Convection heat loss} = 2.2 \times 1.27 \times 19^{1.25} = 111 \text{ kcal/h}$$

$$\text{Total} \quad 154 \text{ kcal/h}$$

Therefore, if the quantity of energy conserved by insulation is converted into equivalent Heavy oil A, the results will be as follows:

$$\frac{(1,877 - 154) \times 16 \times 300}{9,625 \times 0.975 \times 0.842} = 1.0 \text{ kl/year}$$

$$\text{Energy conservation rate} \quad 1.0/158 \times 100 = 0.6\%$$

While the cost of conserved heavy oil is 4,300 Bt/year, that of insulation is approx. 1,300 Bt. The cost of its installation will be recovered in approx. 4 months.

### 6.4 Conversion from Heavy Oil A to Heavy Oil C

At present, heavy oil A is used as boiler fuel after being heated at 83°C. The specifications of heavy oil A are specific gravity 15/15°C 0.975(max.), viscosity - Redwood second (38°C) 500 to 600 and calorific value 9,625 kcal/kg.

If this heavy oil A is converted to heavy oil C, the latter has viscosity of 1,100 to 1,500 and calorific value of 9,514 kcal/kg, it is necessary to raise the temperature by 15°C so that the viscosity for use may be the same as heavy oil A.

The relationship between fuel oil viscosity and price is as follows: (according to Shell Oil data)

- ~ 80 cst 50° C (RWI 600 sec 38° C) 4.32 Bt/l heavy oil A
- ~ 145 cst 50° C (RWI 1,200 sec 38° C) 4.17 Bt/l heavy oil C
- ~ 180 cst 50° C (RWI 1,500 sec 38° C) 4.09 Bt/l
- ~ 230 cst 50° C (RWI 2,000 sec 38° C) 4.04 Bt/l
- ~ 280 cst 50° C (RWI 2,500 sec 38° C) 3.99 Bt/l

If "A" and "C" heavy oils are compared in terms of price per calorific value, they show the following values:

$$\text{Heavy oil A } 4.32 \text{ Bt}/9,625 = 0.449 \text{ Bt}/10^3 \text{ kcal}$$

$$\text{Heavy oil C } 4.17 \text{ Bt}/9,514 = 0.438 \text{ Bt}/10^3 \text{ kcal}$$

An estimated deficiency due to temperature rising of heavy oil C at an assumed efficiency of 50% is:

$$\frac{0.45 \times 15 \times 0.99}{0.5} = 13.3 \text{ kcal/l}$$

If this deficiency is put into consideration, the price per calorific value of heavy oil C will be as follows:

$$4.17 \text{ Bt}/(9,514 - 13) = 0.439 \text{ Bt}/10^3 \text{ kcal}$$

The existing burners are of a low-pressure atomizing type, so that if heavy oil heater is provided with more effective insulation, it is possible to change the fuel from heavy oil A to heavy oil C.

Cost reduction rate

$$\frac{0.449 - 0.438}{0.449} = 2.4\%$$

## 6.5 Recovery of Heat Release from Stack

Combustion exhaust gas from the boiler is discharged from the burner side of the boiler to the stack, and the air intake is near the stack fortunately. The stack, made of iron, releases a large amount of heat, so that the ambient temperature near the stack stands at 34° C or higher. For this reason, it is suggested that the existing air intake be turned to the opposite with a simple enclosure provided and as much high-temperature air around the stack as possible be taken in. Then it is possible to economize the fuel.

## 6.6 Insulation of Steam Piping and Valves

It is observed that valves and piping around the machine has a damaged insulation and some spots are uninsulated. The insulation effect anticipated when the 2 1/2" pipe of equivalent 8 m is more effectively insulated, is as follows:

$$360 \text{ kcal/mh} \times 8 \times 16 \times 300 = 13,824 \times 10^3 \text{ kcal/year}$$

In this case, steam temperature is 140° C

If the above-mentioned part is insulated with 25 mm glass wool, thus preventing the 80% heat release, the quantity of conserved heavy oil A will be as follows:

$$13.824 \times 10^3 \times 0.8 / (9.625 \times 0.975 \times 0.842) = 1.7 \text{ kl/year}$$

$$\text{Energy conservation rate } 1.7 / 158 \times 100 = 1.1\%$$

The estimated cost reduction of heavy oil A will be 7,300 Bt/year at a unit price of 4.32 Bt l. On the other hand, the estimated cost of insulation will be approx. 1,500 Bt and recovered in three months. The fact that the steam pipe is insulated is a good example. However, this pipe is insulated combined with the condensate recovery pipe. As the condensate is reduced to an atmospheric pressure at 100°C, it has an effect of cooling the steam. For this reason, it is recommended that both pipes be insulated separately.

### 6.7 Others

At the factory, a blow out of powder from the bag filter, a spilling and scattering of the finished products during the handling and are almost a routine sight. Therefore, it is effective for energy conservation to prevent this loss. It is desired that the Company put its efforts to maintain the equipment in good condition by cleaning the bag filter, repairing the leakage and tightly closing the openings of the machine. It is also desired to prevent the breakage of bags by quality control of bags. As a result of carrying out the above-mentioned matters, there will be an improvement of the working environments.

## 7. State of Electric Power Consumption

### 7.1 The Principal Data Relating to Power Consumption

Power Company	: MEA
Peak Demand	: 300 kW (January, 1983)
Power Consumption	: $837 \times 10^3$ kWh/year (1982)
Load Factor	: Monthly load factor 47 to 66%
Penalty Fee	: 18,720 Bt/year (1982)
Power Factor	: Monthly power factor 62 to 73%
Transformer	: $3\phi$ 500 kVA $\times$ one unit $3\phi$ 315 kVA $\times$ one unit
Final Power Cost	: Annual average 1.90 Bt/kWh

### 7.2 One Line Diagram




Fig. 17-3

### 7.3 State of Consumption

#### 7.3.1 Monthly Power Consumption

Table 17-4

By MEA Meter

M / Year	Power consumption kWh	Maximum demand power kW	Reactive power kVar	Power factor P.F (%)	Load factor L.F (%)	Average power kW
1 / 83	62,000	300	280	73	51.7	148
2	55,000	290	269.7	73	47.4	145
3	66,000	300	280	73	55.0	157
4	7,000	270	280.1	69	65.7	187
5	58,000	220	279.6	62	65.91	138
Total	312,000					

$$\text{Average power per year} = \frac{837 \times 10^3 \text{ kWh}}{4,800 \text{ h}} = 174 \text{ kW}$$

#### 7.3.2 Monthly Load Curve




Fig. 17-4

7.3.3 Hourly Power Consumption

Table 17-5

By MEA Meter

Time	Active power kWh	Reactive power kVar
8.30		
9.00	200	200
9.30	100	100
10.00	100	100
10.30	100	100
11.00	100	100
11.30	100	100
12.00	100	100
12.30	0	0
13.00	100	100
13.30	100	100
14.00	100	100
14.30	110	300




Fig. 17-5

7.3.4 Hourly Load Curve




Fig. 17-6

8. Problems of Power Control and Potential Solutions

8.1 Measuring Data

Table 17-6 Instantaneous Value

19 July

	Measurement						cos $\phi$ P.F %	
	kW	V	AR	As	AT			
Transformer 3 $\phi$ 500kVA	176.1	419	358	393	341	65		
Use for	Name Plate			Measurement			P.F (%)	L.F (%)
	kW	V	A	kW	V	A		
Grinding No. 1	110	380	195	13.3	412	56.3	33	12.1
Pellet	90	380	168	91.9	411	152	85	102.1
Cooler Fan	18.5	380	37	14.4	415	27.1	74	78
Pellet	7.5	440	133	2.0	411	5.1	56	27.0
Mixer No. 1	15	380		6.3	413	21.9	40	42
Mixer No. 2	15	380		10.2	415	20.4	69	68.3
Use for	Name Plate			Measurement			P.F (%)	L.F (%)
	kW	V	A	kW	V	A		
Crumbear	7.5	400	14	No load	406	3.8	30	10.5
Mixer	7.5	440	13.3	1.8	404	4.73	54	23.6
Bucket elevator	7.5	440		1.8	405	5.6	46	23.7
Whirly feed	15	440		1.3	410	7.8	24	8.5
Bucket elevator	3.7	440		0.5	414	2.4	26	12.9
Boiler blower	1.5	410	3.8	0.8	415	2.3	49	50.7

## 8.2 Power Distribution

### 8.2.1 Transformer

As shown in Fig. 17-3 "One Line Diagram", there are one unit of the 500 kVA transformer and one unit of the 315 kVA transformer. At present, the unit of the 315 kVA transformer is disconnected both on the primary and secondary, hence contributing toward energy conservation.

If necessary, the two transformers are able to be connected easily for parallel operation. However, there are problems as follows:

- (1) Electric power loss due to the cross current between the two transformers in parallel.

The specifications of the transformer are as follows:

500 kVA primary winding	12,000 V	11,700 V	11,400 V	11,100 V	10,800 V
secondary winding	416V/696A	%Z = 3.58%			
315 kVA primary winding	11,550 V	11,275 V	11,000 V	10,725 V	10,450 V
secondary winding	416V/438A	%Z = 3.91%			
	(Estimated)				

There is a difference in the tap voltage on the primary windings between them. Therefore, if the same voltage is applied to the primary, some difference voltage will occur in each secondary winding, resulting in the generation of an electrical power loss between the two transformers due to the traversal current flow. The typical example of this case is shown below.

Note; Assuming that the operating time as 4,800 hours per year, iron loss as 0.3% and copper loss as 1.4%. The transformer's impedance ( $Z(\Omega)$ ) per phase is:

$$Z(\Omega) = \frac{\frac{\%Z}{100} \times [\text{Secondary Voltage kV}]^2}{\text{Transformer kVA}/1,000}$$

Based on the above equation,  $Z_1$  is 0.01239 $\Omega$  for 500 kVA and  $Z_2$  is 0.02148 $\Omega$  for 315 kVA. Then assuming that the working tap voltage is 11,700V/416V for 500 kVA and 11,550V/416V for 315kVA, the difference ratio to be

$$\frac{11,700}{11,550} \doteq 1.0129$$

If the same voltage is applied to the primary winding, the voltage differential of approx. 1.3% will occur on the secondary winding. Accordingly the traversal current flow  $I_c$  will be:

$$I_c = \frac{(416 \times 1.0129)v - 416v}{\sqrt{3}(Z_1\Omega + Z_2\Omega)} = \frac{5.3664v}{0.05866\Omega} \doteq 91.5 \text{ A}$$

On the other hand, the resistances per phase of each transformer  $R_{500}$ ,  $R_{315}$  according to the copper loss =  $3I^2R$ , will be as follows:

$$R_{500} = \frac{500 \times 0.014}{3 \times 696^2} = 0.00482 \Omega$$

For 315 kVA

$$R_{315} = \frac{315 \times 0.014}{3 \times 438^2} = 0.00766 \Omega$$



That is, the loss (equivalent to 3 phases) of transformer due to  $I_c$  will be:

$$P = 3 \times 91.5^2 \times (0.00482 + 0.00766) = 0.3135 \text{ kW}$$

The annual loss will be:

$$0.3135 \text{ kW} \times 8,760 \text{ h/year} \doteq 2.7 \times 10^3 \text{ kWh/year.}$$

Consequently, the parallel operation of transformers should be refrained except for the emergency case.

- (2) The power loss when one unit of transformer to be operated or two units to be operated respectively (not parallel operation) is calculated as follows:

Assuming that 4,800 h/year for operating time, 174 kW for average electric power, 70% for power factor and 249 kVA for apparent electric power, the result is as shown in Table 17-7.

Table 17-7

	Transformers kVA	Load	Iron loss $10^3$ kWh/year	Copper loss $10^3$ kWh/year	Total $10^3$ kWh/year
Case No. 1	500	159	13	3.4	16.4
	315	90	8	1.7	9.7
					$= 26 \times 10^3$ kWh/year
Case No. 2	500	249	13	8.3	21.3
					$= 21 \times 10^3$ kWh/year
Difference					$5 \times 10^3$ kWh/year

That is, the difference power loss between two ways will be  $5 \times 10^3$  kWh/year  $\times$  1.45 Bt/kWh = 7.250 Bt/year. The present single unit operation of the 500 kVA transformer is the best way of operation.

### 8.2.2 Power Factor

Based on the value of Table 17-4 the effect of power factor improvement when a 100 kVar condenser being equipped is shown in Fig. 17-6 and Table 17-8.

Table 17-8

Average power kW	Condenser kVar	Apparent power kVA	Reactive power kVar	Power factor %
174	0	268	204	65
	100	203	104	86

That is, if the 100 kVar condenser is installed, the power factor will be improved to 86% and no penalty instead of the present 18,720 Bt/year.

In the meantime, the expected advantage due to the reduction of copper loss in the 500 kVA transformer will be as follows:

If the given data of 4,800 h/year for operating time, 174 kW for average electric power, 65%

for power factor, 268 kVA for apparent electric power, 86% for improved power factor and 203 kVA for apparent electric power after improvement are as preconditions.

$$500 \text{ kVA} \times 0.014 \left\{ \left( \frac{268}{500} \right)^2 - \left( \frac{203}{500} \right)^2 \right\} \times 4,800 \text{ h/year} \doteq 4.1 \times 10^3 \text{ kWh/year}$$

$$4.1 \times 10^3 \text{ kWh/year} \times 1.45 \text{ Bt/kWh} = 5,950 \text{ Bt/year}$$

$$\text{Energy conservation rate } 4.1 \times 10^3 / (837 \times 10^3) \times 100 = 0.5\%$$

The estimated installation cost of one unit of 100 kVar condenser is approx. 50,000 Bt.

Therefore, the time required for the recovery of the said cost will be:

$$\frac{50,000}{18,720 + 5,950} \doteq 2.0 \text{ years}$$

### 8.3 Application of Electric Power

#### 8.3.1 Voltage

The total capacity of all the motors are approx. 400 kW. However, as shown in Table 17-6, the motors are composed of old and new units including 17 units at a rated voltage of 400V or higher amounting to approx. 60 kW. For this reason, we explain two problems concerning the voltage of electric motors as follows:

- (1) If a 380V of voltage is supplied to the motors rated at 400V or higher, the torque will be reduced by approx. 10 to 20%, and the full-loaded speed reduced by 1 % or more. Despite this slight disadvantage, the efficiency will be increased by 2 % or more and the power factor improved by 4% or more because the load factor of the electric motor is approx. 50% or less. It is concluded, therefore, that the above-mentioned voltage supply will be advantageous as a whole.

Table 17-9

	Iron loss	Copper loss	Total
15 kW	$15 \times 0.016 \times \frac{380^2}{440^2} = 0.18 \text{ kW}$	$15 \times 0.05 \times \left( \frac{8}{15} \right)^2 = 0.21 \text{ kW}$	0.39 kW
11 kW	$11 \times 0.016 = 0.18 \text{ kW}$	$11 \times 0.05 \times \left( \frac{8}{11} \right)^2 = 0.29 \text{ kW}$	0.47 kW

No merit in exchanging motor

- (2) If the electric motor rated at 440 V, 15 kW is replaced by the electric motor rated at 380V, 11 kW, the change of power loss is as Table 17-9, and no merit is expected. In this calculation, each electric motor are 1.6% for core loss, 5% for copper loss, 380V for voltage, 8 kW for actual load and 4,800 h/year for operating time as preconditions.

The rated voltage of the electric motors amounting to 361 kW or approx. 85% of the entire motors of the factory is 380V, so that the voltage should be reduced according to the said rated voltage. At present, as each electric motor has a low load, the power loss for transformer, distribution line and electric motor will be reduced by approx. 2 to 3% by decreasing the voltage during a low-loaded operation.

Assuming the advantage as 2%, the annual electric power consumption  $837 \times 10^3$  kWh/year and the unit cost as 1.45 Bt/kWh, the energy conservation amount due to

the reduction of voltage will be as follows:

$$837 \times 10^3 \text{ kWh/year} \times 0.02 = 16.7 \times 10^3 \text{ kWh/year}$$

$$16.7 \times 10^3 \text{ kWh/year} \times 1.45 \text{ Bt/kWh} = 24,200 \text{ Bt/year}$$

Judging these points, generally, it will be the best way to set the service voltage at approx. 380V. But it is desired to confirm the power consumption and motor temperature rising after reducing voltage.

### 8.3.2 Power Consumption Rate

The monthly load curve as shown in Fig. 17-4 indicates the following trend:

During the period of April and May, the power consumption unit was ameliorated in accordance with the increase of the load factor to 65% or higher. In addition, despite the high load, the peak demand was held at low level. We suggest that the company study how to improve the power consumption rate and to restrain the peak demand, comparing the operating method for the period of February and March with that of April and May.

## 8.4 Others

### 8.4.1 Management of Operation and Maintenance

We were unable to confirm data on faults and accidents, but we would point out the common problems applicable to the factories handling powder.

- (1) Accidents due to the deterioration of insulation caused by the moistening of powder depositing in the power board and the control board.
- (2) Burning due to the deterioration of the cooling effect caused by the clogging of powder in the electric motor.

Because of the above, periodical cleaning and repair are necessary. Especially, the burning accident due to the insufficient cleaning of the motor are sometimes mistaken for an accident caused by an overload. Therefore, it is desired to pay attention to this point. In addition, a small spark in the powder by a deteriorated insulation or the burning of the electric motor may lead to a serious fire accident. For this reason, you are requested to be careful about the maintenance and control of operation.

9. Summary

The above-mentioned improving measures, if actually taken, will bring about energy conservation effects as shown below:

	(Oil equivalent) kl/year	%
Control of combustion in boiler	1.6	1.0
Reduction of quantity of blow down water	4.7	3.0
Insulation of boiler body	1.0	0.6
Insulation of steam piping and valves	1.7	1.1
<hr/>		
Subtotal	9.0	5.7
	10 <sup>3</sup> kWh/year	%
Improvement of power factor	4.1	0.5
Reduction of service voltage to electric motor	16.7	2.0
<hr/>		
Subtotal	20.8	2.5

Report No. 18: Food

REPORT ON THE DIAGNOSIS  
FOR  
ENERGY CONSERVATION

— Central Food Products Co., Ltd. —

January, 1984

Japan International Cooperation Agency

## Contents

1.	Outline of the Factory .....	18-1
2.	Manufacturing Process.....	18-2
3.	Major Equipment .....	18-2
4.	State of Energy Management .....	18-3
5.	State of Fuel Consumption .....	18-4
6.	Problems in Heat Control and Potential Solutions .....	18-6
7.	State of Electric Power Consumption .....	18-9
8.	Problems of Power Control and Potential Solutions.....	18-12
9.	Summary .....	18-15

The Diagnosis for Energy Conservation  
— Central Food Products Co., Ltd. —

I. Outline of the Factory

Address	7/3 Pahol Yothin Rd. KM 33 Rangsit Pathumthani	
Capital	200 Million Bt	
Type of industry	Food	
Major products	Livestock feed	
Annual product	250,000 ton	
No. of employees	160	
Annual energy consumption	Electric power	6,000,000 kWh
	Fuel	H.O. (A) 850 kℓ
Interviewees	Mr. Johnny Chang : Plant Manager Mr. Pai Boon : Deputy Plan-Manager	
Date of diagnosis	July 26 ~ 27, 1983	
Diagnosers	A. Koizumi, S. Honda, Y. Kaneko	

This factory belongs to the Centaco Group and is the largest animal feed manufacturer of 250,000 tons per year in Thailand. Some of their production is exported. The major ingredient of the feed is corn blended with soya beans, crushed rice, fish meal, bone powder, plant seeds, vitamins and other. The feeds are shipped in the form of pellets or powder in paper bags. The company maintains silos capable of storing 34,000 tons of raw materials with conveyors which carry them. The hammer mill and pelletizer use steam which is generated by four units of boiler. In addition, the factory is provided with two units of dryer for drying corn containing a high percentage of moisture delivered during the humid season.

The factory goes in full operation during the period from July through December; that is, it continuously produces 24,000 tons per month for 24 hours a day on a 3-shift basis. However, during the period from January through June, the factory turns out the product at a rate of 18,000 tons per month for 16 hours a day on a 2-shift basis. Of the above-mentioned tonnage, approx. 80% is put into pellets.

The factory is manned with 40 employees assigned to the office and 120 to production, totaling 160.

2. Manufacturing Process




Fig. 18-1

3. Major Equipment

3.1 Major Equipment

Table 18-1

Name	No. of units installed	Type, etc.	
Boiler	2	Fire tube	20 HP
	2		100 HP
Hammer mill	2	270 HP	Electrical heating
	2	150 HP	Steam heating
Pelletizer	2	220 HP	Electrical heating
	2	150 HP	Steam heating
Dryer	2	50 t/day	Hot air dryer



### 3.2 Layout




Fig. 18-2

## 4. State of Energy Management

### 4.1 Policy for Energy Conservation

The company, reflecting a general policy of management for the entire Centaco group, is seen strictly pursuing its essential target of improved profitability. In order to further reduce cost, it will be necessary to present concrete target for cost reduction and time of its achievement in future.

As an example of the recent energy conservation investment, in transfer equipment a bucket elevator system is now being used instead of the old pneumatic conveyor system. Although 250,000 Bt was spent, approx. 800,000 Bt has been saved in terms of electric power and repairs. This fact supports the adequacy of the project.

It is also observed that the entire organization is under good management: that is, employees are well disciplined and the application of system rule satisfactory.

### 4.2 Participation by All Employees

The Safety Committee and Quality Committee are established in each department. Even the employees at the lower echelon are encouraged to participate in the activities of the committees. Occasionally the factory general manager provides instructions to the members on given subjects, thus making a direct appeal to the employees for better factory

management.

Although the improvement suggestion system is in force, active utilization is not observed. Nevertheless, the employees are sufficiently trained and as such, are considered well qualified for participation in the internal activities such as QC circle henceforth.

#### 4.3 Control through Data

Data on factors involved in each process and facility are logged on an hourly basis. It is considered that the whole factory is accustomed to control through data collected through the determination of consumption rate and analysis of variation factors.

Only the regret is that a feed water meter is not yet installed and the actual state can not be grasped, although it is indispensable for the monitoring of boiler operating efficiency.

#### 4.4 Education and Training, Technical Leveling-Up of Employees

The company is highly interested in employees' education and as a matter of fact, it sent employees to the external seminars fifteen times and the study visits to other industrial facilities two times last year.

The company is the largest manufacturer in the Thai animal feed industry and is proud of its high-level technology. Therefore, it is desired that the company be a leader in promoting technical information exchanges and thus raising the technical level of the whole industry. This will lead to the acceleration of each manufacturer's energy conservation and a subsequent stabilization of the entire industry.

### 5. State of Fuel Consumption

#### 5.1 State and Breakdown of Fuel Consumption

Heavy oil A : 850 kl/year

Breakdown of Consumption : Pelletization 53% (boiler) 450 kl  
Dryig of raw maize 47% (dryer) 400 kl

Two boilers(100 HP) are normally operated on a two-shift basis, burning 35 kl of heavy oil A per month. During the busy season, they are operated on a three-shift basis, burning 40 kl of heavy oil A per month.

The dryer is usually used from September through December when corn containing a high percentage of moisture is delivered. It is dried with hot air prior to being stored in the silos.

Table 18-2 Energy Consumption Rate

Season	Jan. ~ Jun.	Jul. ~ Dec.	Hokkaido Japan
Working time / day	16 h (2 shift)	24 h (3 shift)	24 h (3 shift)
Production	18,000 t/month	24,000 t/month	—
Fuel oil for boiler	35 kl/month	40 kl/month	—
Boiler oil (ℓ)/Production (t)	1.94	1.67	4.0
* kWh/Production (t)	27.32	22.68	16.7
Productivity ton/month/person	112.5	150	237

\* Dryer running power are included in the golden age electric power.

Fuel consumption rate (estimated on the actual production for the last fiscal year).

For pelletization  $450 \text{ kl}/153,000 \text{ t} = 2.94 \text{ l/t}$

For drying raw corn  $400 \text{ kl}/12,750 \text{ t} \times 4 = 7.84 \text{ l/t}$

## 5.2 Heat Balance of Boiler

We calculated the heat balance of No.1 boiler based on its diagnostic results on July 27, 1983. The heat balance is partially based on an estimated value because there was not equipped flow meter for the feed water.

Table 18-3

Input			Output		
Item	$10^3 \text{ kcal/h}$	%	Item	$10^3 \text{ kcal/h}$	%
Heat of fuel combustion	402.1	99.8	Heat of steam	352.5	87.5
Sensible heat of fuel	0.9	0.2	Heat loss in exhaust gas	21.5	5.3
			Heat loss in blow water	8.8	2.2
			Heat release from boiler body, others	20.2	5.0
Total	403.0	100.0	Total	403.0	100.0

### Data Given for Calculation of the Heat Balance

Fuel type		Heavy oil A
Fuel consumption	(F)	$41.8^{*1} \text{ kg/h}$
Heat content of fuel (low value)	(kl)	$9,619 \text{ kcal/kg}$
Specific gravity of fuel	(SG)	0.955
Specific heat of fuel	(Cp)	$0.45 \text{ kcal/kg}^\circ\text{C}$
Temperature of fuel	(Tf)	$80^\circ\text{C}$
Reference temperature	(To)	$30^\circ\text{C}$
Oxygen content of exhaust gas	(O <sub>2</sub> )	5.3%
Temperature of exhaust gas	(Tg)	$140^\circ\text{C}$
Quantity of blow down water	(B)	$60^{*2} \text{ kg/h}$
Temperature of blow down water	(Tb)	$175.9^\circ\text{C}$
Quantity of feed water	(W)	$617.8 \text{ kg/h}$
Temperature of feed water	(Tw)	$30^\circ\text{C}$
Steam pressure	(P)	$8.3 \text{ kg/cm}^2\text{G}$
Quantity of steam ( $S = W - B$ )	(S)	$557.8 \text{ kg/h}$
Enthalpy of steam	(Es)	$662.0 \text{ kcal/kg}$
Enthalpy of feed water	(Ef)	$30 \text{ kcal/kg}$

\*1 Quantity of fuel: estimated at 35 kl/month (2 boilers), 16h/day and 25 days/month.

\*2 Refer to Item 6.2.

## Equation for Calculation of the Heat Balance

### Input

Heat of fuel consumption (Qc)  $402.1 \times 10^3 \text{ kcal/h}$

$$Q_c = F \times HI$$

Sensible heat of fuel (Qs)  $0.9 \times 10^3 \text{ kcal/h}$

$$Q_s = F \times C_p(T_f - T_o)$$

### Output

Heat of steam (Qv)  $352.5 \times 10^3 \text{ kcal/h}$

$$Q_v = S \times (E_s - E_f)$$

$$352.5 = S \times (662 - 30), \quad S = 557.8 \text{ kg/h}$$

Heat loss in exhaust gas (Qe)  $21.5 \times 10^3 \text{ kcal/h}$

$$Q_e = F \times G \times 0.33(T_g - T_o)$$

Theoretical amount of air (Ao)

$$A_o = 0.85 HI / 1.000 + 2.0 = 10.18 \text{ Nm}^3 / \text{kg}$$

Theoretical amount of exhaust gas (Go)

$$G_o = 1.11 HI / 1.000 = 10.68 \text{ Nm}^3 / \text{kg}$$

Air ratio (m)

$$m = 21 / (21 - O_2) = 1.34$$

Actual amount of exhaust gas (G)

$$G = G_o + A_o(m - 1) = 14.14 \text{ Nm}^3 / \text{kg}$$

Heat loss in blow down water (Qb)  $8.8 \times 10^3 \text{ kcal/h}$

$$Q_b = B \times (T_b - T_w)$$

Heat release from body and others (Qr)  $20.2 \times 10^3 \text{ kcal/h}$

(estimated as 5% of input)

## 6. Problems in Heat Control and Potential Solutions

### 6.1 Control of Combustion at the Boiler

There are now installed four units (100 HP  $\times$  2, 30HP  $\times$  2) of boiler, out of which 2 units of 100 HP are in operation. If 1 HP is regarded as equivalent to 15.65 kg/h, a 100 HP boiler means 1,565 kg/h of steam generating capacity. However, as shown in the heat balance table, the boilers are actually operated at an extremely low load.

At present, the oil flow meter is faulty, so only the way to determine a heavy oil consumption is by a change in the tank content using a bob. In addition, through lack of flow meter of the feed water, it is impossible to calculate an evaporation multiple which indicates a combustion efficiency of boiler. Therefore, the factory cannot control the boiler combustion sufficiently everyday. It is desired that the flow meter of the fuel oil be repaired and a flow meter of the feed water also be installed so the data are collected from the meters and evaporation multiple may be logged for boiler control.

$$\text{Evaporation multiple} = \frac{\text{Amount of feed water} - \text{Amount of blow down water}}{\text{Fuel consumption}}$$

The boiler room is not cleaned up thoroughly and the pressure gauges around the boilers are not well maintained.

The oxygen content of boiler exhaust gas is rather high, so it is suggested that the air damper be adjusted to maintain the oxygen content at the level of 4% or less. In this case,

$$m' = 1.24$$

$$G' = 13.12$$

Assuming that the fuel amount after adjustment is  $x$  kg/h, the following equation is established according to the boiler heat balance:

$$\frac{403.0}{41.8} \cdot x = (352.5 + 8.8 + 20.2) + \frac{13.12 \times 0.33 \times (140 - 30)}{1,000} \cdot x$$

$$\therefore x = 41.6 \text{ kg/h}$$

Energy conservation rate

$$\frac{41.8 - 41.6}{41.8} \times 100 = 0.5\%$$

If the same is true about a 3-shift operation, an annual heavy oil A conservation will be:  $450 \text{ kl} \times 0.005 = 2.3 \text{ kl/year}$ .

### 6.2 Reduction in Quantity of Blow Down Water for Boiler

At present, boiler water is blown down twice a day, each time lasting two minutes.

Although the quantity of blown-down water is unavailable through lack of flow meter, the estimated quantity will be  $3.6 \text{ m}^3/\text{h} \times 4 = 14.4 \text{ m}^3/\text{h}$ , if the liquid flow velocity through a 1 1/4" blow pipe is assumed to be 4 m/s.

It is estimated that the total quantity of blow down water in a day is 960 l based on a blow down frequency of 2 times, each time lasting two minutes during 16 hours, and therefore, the hourly blow down quantity is 60 l/h on the average. The pH and electric conductivity of boiler feed water are 7.15 and 897  $\mu\text{S}/\text{cm}$  respectively. On the other hand, the pH and electric conductivity of boiler water are 11.17 and 1,000  $\mu\text{S}/\text{cm}$  respectively. Judging from these values, the quality of water used is comparatively higher. Since the electric conductivity of boiler water is tolerable up to approx. 6,000  $\mu\text{S}/\text{cm}$ , it will almost not affect the boiler body adversely, even if water is blown down once a day.

### 6.3 Insulation of Steam Line

Uninsulated parts of the steam piping and valves are seen through the factory. If these parts are insulated with 25-mm glass wool, the heat loss will be reduced as shown in Table 18-4.

If a reduction in the heat loss is converted to equivalent fuel oil, the following equation will be established:

$$\frac{(11,300 - 2,065) \times (16 + 24) \times 150}{9,619 \times 0.955 \times 0.875} = 6.9 \text{ kl/year}$$

$$6.9 \text{ kl/year} \times 4.3 = 29,700 \text{ Bt/year}$$

Against the above, necessary cost for insulation is estimated at approx. 7,100 Bt. This cost will be recovered in approx. 3 months.

Table 18-4

Piping	Actual heat loss kcal/h	Heat loss after insulation kcal/h
Pelleter room header		
Glove valve 2" x 1	400	74
4" x 3	2,400	438
6" x 1	1,300	210
(Skin temperature 156°C)		
Steam piping		
Glove valve 2" x 10	4,000	740
Piping 9 m	3,200	603
Total	11,300	2,065

#### 6.4 Recovery of Condensate and Reduction of Steam Pressure

Condensate generated in a total length of 100 m of four 4" pipes from the four boilers to the pelletizers is discharged straight into the pit through a blow pipe. And rising steam is conspicuous due to the faulty traps.

Assuming that heat loss in the 25-mm insulated 4" pipe is 115 kcal/mh, the following equation is established:  $115 \text{ kcal/mh} \times 100\text{m} \times (16 + 24) \times 150 = 69,000 \times 10^3 \text{ kcal/year}$

As a steam of 8.3 kg/cm<sup>2</sup>G is fed, the latent heat of steam is 484.4 kcal/kg. Consequently, the quantity of generated condensate is represented by the following equation:

$$\frac{69,000 \times 10^3}{484.4} = 142 \times 10^3 \text{ kg/year}$$

If this condensate amount is released at an atmospheric pressure, approx. 14% will be evaporated as flash steam, losing 52% of its heat quantity. The heat quantity of the remaining condensate is represented by the following equation:

$$142 \times 10^3 \times 177.8 \times 0.42 = 10,604 \times 10^3 \text{ kcal/year}$$

If this heat quantity is recovered and utilized for boiler feed water, the energy of equivalent fuel oil to  $10,604 \times 10^3 / (9,619 \times 0.955 \times 0.875) = 1.3 \text{ kl/year}$  will be conserved.

$$\text{Energy conservation rate} = \frac{1.3 \times 100}{850} = 0.2\%$$

The higher the steam pressure, the more heat of condensate is lost into the flash steam as above-mentioned. For this reason, it is advantageous to use steam at as low pressure as possible. If the steam pressure of 8.3 kg/cm<sup>2</sup>G is reduced to 3 kg/cm<sup>2</sup>G, the heat effectively used for heating, that is, the latent heat of steam will be increased from 484.4 kcal/kg to 510 kcal/kg. Therefore, the estimated required steam quantity will be

$$\frac{484.4}{510} = 0.95$$

This means that the required steam quantity can be 5% less than when the steam pressure is high.

$$\text{Heavy oil conservation } 450 \text{ kl/year} \times 0.05 = 22.5 \text{ kl/year}$$

## 6.5 Study on Production Method

Generally, continuous operation is advantageous for the process industry which utilizes heat. At this factory, the heavy oil consumption rate is 1.67 l/ton on a 3-shift operation base and 1.94 l/ton on a 2-shift operation base. Accordingly, it is recommended that a 3-shift continuous operation be adopted and after that, the operation be suspended, as far as issues such as delivery condition, inventory capacity, change of inventory quality and labor cost allow. The suspension period can be applied to equipment maintenance and employee education/training.

The expected effects will be :  $18,000 \text{ tons/months} \times (1.94 - 1.67) \text{ l/t} \times 6 \text{ months} = 29.2 \text{ kl/year.}$

## 7. State of Electric Power Consumption

### 7.1 The Principal Data Relating to Power Consumption

Power Company	: MEA
Peak Demand	: 1,360 kw (March, 1982)
Power Consumption	: $6,000 \times 10^3 \text{ kWh/year}$ (estimated from data for March)
Load Factor	: Monthly load factor 60 ~ 68% (estimated)
Penalty Fee	: 36,000 Bt/year (estimated from data for March)
Power Factor	: Monthly power factor 75 ~ 85% (estimated)
Transformer	: $3\phi 1,250 \text{ kVA} \times 2 \text{ units...for factory}$ $3\phi 500 \text{ kVA} \times 1 \text{ units..for general office}$
Power Cost	: 1.72 Bt/kWh (March, 1982)

7.2 One Line Diagram




Fig. 18-3 One Line Diagram



7.3

7.3.1 State of Hourly Power Consumption

Table 18-5 Hourly Power Consumption

By MEA Meter		July 26		
Time	Effective power kWh	Reactive power kVar	Power factor %	
11:00 ~ 12:00	1,173	891	80	
12:00 ~ 13:00	1,200	800	83	
13:00 ~ 14:00	880	800	74	
14:00 ~ 15:00	1,120	920	77	
15:00 ~ 16:00	1,040	880	76	

July 27			
Time	Effective power kWh	Reactive power kVar	Power factor %
9:00	—	—	—
9:00 ~ 10:00	800	720	74
10:00 ~ 11:00	800	680	76
11:00 ~ 12:00	720	600	77
12:00 ~ 12:30	280	440	53
12:30 ~ 13:00	320	520	53
13:00 ~ 13:30	320	160	90
13:30 ~ 14:00	320	160	90
14:00 ~ 15:00	—	—	—

7.3.2 Hourly Load Curve




Fig. 18-4 Hourly Load Curve

8. Problems of Power Control and Potential Solutions

8.1 Measuring Data

Table 18-6 Instantaneous Value

July 27

	Name plate			Measurement					
	kVA	V <sub>1</sub>	V <sub>2</sub>	kW	V	AR	AS	AT	P.F %
TR 1	1,250	22,800	400	506	393	940	957	1,005	76.8
TR 2	1,250	22,800	400	519	394	900	918	884	84.5

Use for	Name plate			Measurement			P.F (%)	L.F (%)
	kW	V	A	kW	V	AR		
Grinder IV	200	380	370	138	393	252	84	69
Grinder V	200	380	370	152.8	392	234	91	76.4
Pellet III	120	380		112.5	392	192.1	83	93.7
Pellet IV	120	380						
Pellet I	110	380	204	59.1	394	104.2	82	537.3
Grinder I	110	380	185	30.8	395	70.7	75	28
Blower I	55	380	104	18.87	387	56.7	50	34.3
Blower II	55	380	104	32.9	393	62.8	75	59.8
Fan I	45	386	82	35.4	387	57.5	89	78.7
Fan II	45	380	82	36.8	388	66.1	78	81.8
Fan III	45	380	82	39.5	386	66.1	78	81.8
Air compressor	30	380	61	26.2	389	46.7	83	87.3

8.2 Power Distribution

8.2.1 Transformers

Two 1,250 kVA transformers are provided for the factory and one 500 kVA transformer is installed for the general office.

(1) 1,250 kVA × 2 units

We calculated an expected advantage of the case where the number of transformers shown in Table 18-6 is reduced by one transformer on the following preconditions:

Operating time — 6,000 h/year

Annual power consumption — {6,000 × 10<sup>3</sup> — 1,000 × 10<sup>3</sup>(for office)} = 5,000 × 10<sup>3</sup> kWh/year

Average electric power

$$\text{Average electric power} = \frac{5,000 \times 10^3 \text{ kWh}}{6,000 \text{ h}} = 840 \text{ kW}$$

Assuming that the power factor as 78.9%, the apparent power as 1,065 kVA, the iron loss as 0.3 kW and the copper loss as 1.1 kW based on the case of March, 1982, the following equation is established:

	Iron Loss	Copper Loss	Total
2,500 kVA (1,250 × 2)	65.7 × 10 <sup>3</sup> kWh/year	29.9 × 10 <sup>3</sup> kWh/year	95.6 × 10 <sup>3</sup> kWh/year



The total cost saving including penalty will be approx. 50,000 Bt/year. On the other hand, cost involved in the installation of a 200 kVar condenser is estimated at approx. 80,000 Bt. This cost will be recovered in 1.6 years.

### 8.3 Power Application

#### 8.3.1 Voltage

According to Table 18-6, the service voltage to motors is generally rather high such as approx. 390 V excepting some. On the other hand, the load factor varies from 28 to 94%, so it is difficult to determine it. Therefore, we cite an expected advantage when the tap of the transformer is switched to reduce the service voltage to approx. 370 V or 5% drop as a referential case. That is, it is generally said that reduction of loss in the transformer, distribution line and electric motor attributed to a drop of voltage during a light load operation, is approx. 2 ~ 3%. Then assuming that the expected advantage is 2% and the annual power consumption of the factory is  $5,000 \times 10^3$  kWh/year, the following equation is established:

$$5,000 \times 10^3 \text{ kWh/year} \times 0.02 = 100 \times 10^3 \text{ kWh/year}$$

$$100 \times 10^3 \text{ kWh/year} \times 1.45 \text{ Bt/kWh} = 145,000 \text{ Bt/year}$$

It is desired that the company confirm the power consumption and the temperature fluctuation of the electric motors after 5% drop of service voltage.

### 8.4 Others

#### 8.4.1 Power Consumption Rate

Making the power consumption rate for 1979 four years ago 100%, it is increased approx. 50% to 150% as of July, 1983. The conceivable major causes are as follows:

- (1) Increase in the load due to newly built silos.
- (2) Increase in the load due to a new general office.

As to the general office, the load should be treated as outside the framework for power consumption rate of the factory. It is suggested that after installing a recording meter for enabling the determination of a power consumption in detail at the office, a power consumption rate be newly established and be controlled toward a set target.

#### 8.4.2 Operation and Safety Control

We were not able to confirm data on troubles or accidents. However, common troubles which tend to occur at the powder-handling factories are as follows:

- (1) Troubles attributable to the deterioration of insulation by moisture in the power board and the control board.
- (2) Burning caused by the diminishing of cooling effect resulting from the clogging of an electric motor with powder.

It is important to clean the above-mentioned parts regularly. Specially a burning trouble with the electric motor is sometimes mistaken for an overloaded operation, so it is necessary to determine the cause with care. In addition, a small spark caused by the deterioration of insulation or a burning of the electric motor in powder is likely to lead to a

large fire. We invite the employees' attention to operating safety and secure maintenance.

9. Summary

The above-mentioned improving measures, if actually taken, will bring about energy conservation effects as shown below:

	(Heavy oil equivalent) kl/year	%
Improvement of Burning in Boiler	2.3	0.5
Insulation of Steam Line	6.9	0.8
Recovery of Condensate	1.3	0.2
Drop of Steam Pressure	22.5	2.6
Continuous Operation	29.2	3.4
<hr/>		
Total	62.2	7.3
	10 <sup>3</sup> kWh/year	%
Improvement of Power Factor	9.9	0.1
Reduction of Service Voltage of Electric Motor	10.0	1.7
<hr/>		
Total	109.9	1.8



ATTACHED DATA





## Study Team Members

Part	Name	Present Post
Team Leader	Mitsuo Iguchi	Managing Director, ECC
Chemical Group		
Heat	Hiroo Igarashi	General Manager, International Cooperation Department, ECC
”	Hiroshi Murata	Registered Diagnoser, ECC
Power	Kenichi Kurita	” ”
Food Group		
Heat	Akira Koizumi	General Manager, Hokkaido Branch, ECC
”	Shiroo Honda	Registered Diagnoser, ECC
Power	Yuuji Kaneko	” ”

## Counterparts Names

Part		Name	Organization
Chemical	Heat	Danai Egkamol	NEA
		Pinyo Tonthumas	”
		Pichai Nitinon	”
		Boonyong Juengthanawiwat	”
		Nattavut Suanin	”
		Derake Wuthichok	MOI
	Power	Thumasak Suwanadhep	NEA
		Wicha Thongsuk	”
		Somkid Aoluknua	”
Food	Heat	Supachok Kusolsong	NEA
		Supon Khwankongrai	”
		Somjet Junsawang	”
		Sakon Bhutachart	”
		Tawatchai Titivudtiwong	MOI
		Surapong Bhiraleus	”
		Sirichai Savangmongkol	”
	Power	Banphot Diskul	NEA
		Umporn Koonchonrat	”
		Buranachai Cutchon	”

## Itinerary of Study

1983	June	26	Departed Narita, arrived Bangkok
		27	Visits to the JICA Bangkok Office, NEA and TPA
		28	Meeting with NEA Director General and Deputy Director General Report on summary of outcome of the secondary study
		29	Arrangements for diagnosis (Preparation of instruments and explanation of plans)
		30	
		1	Factory diagnosis and data sorting
	July,	27	
		27	Visit to JICA Office, Japanese Embassy Report on summary of outcome of the third study
		28	Meeting with NEA Director General, Report on summary of outcome of third study Delivery of instruments to NEA
		29	Visit to JICA Office, TPA, NEA
		30	Departed Bangkok, arrived Narita

## Energy Conservation Survey 省エネルギー調査表

1 Name of Factory  
工場名

---

2 Location  
所在地

---

Tel.

---

3 Name of Company Officials  
会社役員名

---

President  
社長

---

Factory Manager  
工場長

---

Energy Manager  
エネルギー担当者

---

4 Segment of Industry  
業種

---

5 Capital  
資本金 bahts

---

6 Annual Turnover  
年間売上高 bahts

---

7 Number of Employees  
従業員数

---

8 Number of Engineers  
技術者数

---

Electricity  
電気

---

Heat  
熱

---

9 Major Products  
主要生産物

---

10 Production Capacity of Major Products  
主要生産物の生産能力

---

Nominal  
公稱

---

Present Condition  
現状

---

## 11 Fuel Consumption 燃料消費高

<input type="checkbox"/>	Fuel oil 重油	kl/y	bahts/y
<input type="checkbox"/>	Diesel oil 軽油	kl/y	bahts/y
<input type="checkbox"/>	Kerosene 灯油	kl/y	bahts/y
<input type="checkbox"/>	Gasoline ガソリン	kl/y	bahts/y
<input type="checkbox"/>	LPG 液化石油ガス	t/y	bahts/y
<input type="checkbox"/>	Natural gas 天然ガス	m <sup>3</sup> /y	bahts/y
<input type="checkbox"/>	Lignite or Brown Coal 亜炭又は褐炭	t/y	bahts/y
<input type="checkbox"/>	Bagasse バガス	t(m <sup>3</sup> )/y	bahts/y
<input type="checkbox"/>	Charcoal 木炭	t/y	bahts/y
<input type="checkbox"/>	Firewood 薪	t(m <sup>3</sup> )/y	bahts/y
<input type="checkbox"/>	Others ( ) その他 ( )	/y	bahts/y

## 12 Electric Power, 電力

Electricity Consumption 電力消費高		KWh/y	bahts/y
Contract Demand 契約電力	KW.	Receiving Voltage 受電電圧	V
Power Factor 力率	%		
Power Plant 発電設備	Have or Not.	Capacity 能力	KW or KVA.

## 13 Water Consumption, 水消費量

Sea Water 海水	m <sup>3</sup> or t/y	River Water 河水	m <sup>3</sup> or t/y
Underground Water 地下水	m <sup>3</sup> or t/y	City Water 水道水	m <sup>3</sup> or t/y


14 Boiler, ボイラ

Built(A.D.) 設置(西暦)	Type 型式	Nominal Capacity 公称能力		Kind of Fuel 燃料の種類	Operating period 運転時間	
		Steam Press. kg/cm <sup>2</sup> G	Evaporating Volume t/h		hrs/day	days/y.


15 Major Facilities Using Energy, エネルギー使用の主要設備

Built(A.D.) 設置(西暦)	Name of Facility 設備名	Products 生産物	Output 生産高		Kind of Energy used 使用エネルギー の種類	Operating period 運転時間	
			Nominal 公称	Present Condition 現状		hrs/day	days/y


16 Flow-chart of Producing Process of Major Products, 主要生産物の生産工程図



17 Energy Flow-chart, エネルギー流れ図




18 Skeleton Diagram, 单線結線図





19 Plant Layout, 工場配置図



20 In case you have any problem(s) in your course of promotion of energy conservation, please circle the no(s). of applicable item(s) among the following: (Maximum 5 items)

省エネルギー推進上の問題点があれば、下記の該当する項目に丸印を付して下さい。(但し、最高5項目まで)

- (1) Prospect of energy price is not clear.  
エネルギー価格の見通しが不明。
- (2) The proportion of energy cost in the whole cost of enterprise is small.  
企業におけるエネルギー費用の割合が小さい。
- (3) Increase of energy cost can be covered by raising the prices of products.  
エネルギー費用の上昇は製品値上げでカバーできる。
- (4) Instability of energy supply. (power stoppage, etc.)  
エネルギー供給が不安定(停電など)。
- (5) Shortage of engineers.  
技術者が不足。
- (6) Difficulty in obtaining good energy conservation equipments.  
省エネルギー機器のよいものが手に入り難い。
- (7) Information such as active cases is not easy to obtain.  
実施例のような情報が入りにくい。
- (8) System of research and development is not sufficient.  
研究開発体制が不十分。
- (9) Shortage of fund for facility improvement.  
設備改善の資金が不足。
- (10) The facilities are superannuated.  
設備が老朽化している。
- (11) Employees' consciousness is low.  
従業員の意識が低い。
- (12) No personnel is available who can educate the employees.  
従業員教育をできる人がいない。
- (13) Shortage of measuring equipments.  
計量設備が不足している。
- (14) No time to analyze energy consumption rate.  
原単位解析を行う時間がない。
- (15) Shortage of information on government's measures.  
政府施策の情報が不足。
- (16) Shortage of government's subsidiary measures.  
政府の助成策が不足。
- (17) Others  
その他。

1 Energy Management



3	<p>Organization Planning and Promotion Committee Frequency of Holding Committee Chairman Project Team Consultant Contract</p>	<p>組 織 企画・推進 委員会 開催頻度 委員長 プロジェクトチーム コンサルタント契約</p>	<p>Section held _____ Times/y _____ made _____ made</p> <p>Person in Charge not held not made not made</p>
4	<p>System Improvement Proposition System Achievement Commendation System Inspection, Audit</p>	<p>制 度 改善提案制度 実績表彰制度 視察, 診断</p>	<p>is isn't is isn't done not done</p>
5	<p>Education of Employees Seminar Observation Meeting</p>	<p>従業員教育 研究会 見学会</p>	<p>held Times/y not held held Times/y not held</p>
6	<p>Campaign to Employees Appeal from Factory Manager Poster, etc.</p>	<p>従業員への呼びかけ 工場長の呼びかけ ポスター 等</p>	<p>done not done done not done</p>
7	<p>Activities in the Business Circles</p>	<p>業界の活動</p>	<p>Practised not practised</p>

2 Heat

2-1 Furnace, Kiln, Dryer

2-2 Steam Consuming Equipment

2-3 Boiler

2-4 Steam Piping, Condensate Recovery

2-1 Furnace, Kiln, Dryer

1	Part	工 程				
2	Name of Equipment	設 備 名				
3	Use	用 途				
4	Charge	被加熱物				
5	No. of Furnace	番 号				
6	Type	型 式				
7	Maker	メーカ-				
8	Time built	設置時期				
9	Outer Dimension Length or Dia. Width Height	外法寸法 長さ・径 巾 高				
10	Design Capacity	設備能力				
11	Usage Continuous Batch h/Day h/month	使用状況 連 続 非 連 続				
12	Induced Draft Fan. Forced Draft Fan	吸込み送風機 押し込み送風機			___ m <sup>3</sup> /h ___ mmAq ___ kW	
13	Improvement done	改造実績				

(15)

Diagnoser

Date

Factory

14	Fuel Name Lower Heating Value Specific Gravity Moisture	燃料名 發熱量 (低位) 比重 水分	Kcal/kg. l.m <sup>3</sup> N			
15	Average Consumption	燃料使用量 (平均)	/h			
16	Oil Storage Tank Contents Volume Temp. Insulation	油貯蔵タンク 種類 容量 温度 保温	m <sup>3</sup>	°C	mm	
17	Fuel Receiving Measuring Volume Temp. Sp.grav. Analysis	受入れ 計量 温度測定 比重 分析	done	not done	done	not done
18	Oil Leak	油洩れ	good	not good		
19	Steam Pressure Temp.	スチーム 圧力 温度	kg/cm <sup>2</sup> G	°C		
20	Electricity Elect. Heater Infra Red Lamp	電力 電熱 赤外線ランプ	_____ kW	_____ V	_____ kW	_____ V



No. of Equipment	設備名	
21	Combustion	Pressure jet, Low pr.air Rotary, Intermixing, Interior Semi atomizing, mixing
Burner	バーナー	atomizing, atomizing, atomizing, atomizing, atomizing, atomizing
Burner Tile	バーナータイル	Good
Cleaning of Burner tip	バーナー手入	not good
Flame Color	火焰色	times/y
Length	長さ	good
Sparks	火花	good
Blow off	吹きとび	good
Color of Smoke	煙の色	good
Air/fuel ratio	空気比	good
Automatic Controller	制御装置	Factory Data
Fuel Consumption	燃料量	exist
Fuel Temp.	油温	not exist
Air Temp.	燃燒空気温度	kg.l.m <sup>3</sup> /h
Primary Air flow	一次空気量	°C (at Burner, after Heater)
Secondary Air flow	二次空気量	m = $\frac{0.21}{0.21 - (O_2)}$
Atomizing press.	噴霧圧	

No. of Equipment	設備番号																	
22	炉 圧 炉 圧 制 御 タンパー作動 空 気 吸 込 炉 壁 バナーまわり 出 入 口 台車シール State of Stack, Gas duct 煙突、煙道の状態 冷 却 空 気	_____ mmHg (Measuring Point _____ mmHg) done not done good not good good not good good not good good not good good not good good not good _____ m <sup>3</sup> /min.																
23	加 熱 炉 温 装 入 温 度 抽 出 温 度 温 度 測 定 温 度 制 御 装 置 バナー取付 装 入 方 法 Seal	<table border="1" data-bbox="774 190 917 1108"> <tr> <td></td> <td>Preheating Zone</td> <td>Heating Zone</td> <td>Soaking Zone</td> </tr> <tr> <td>_____ °C</td> <td>_____ °C</td> <td>_____ °C</td> <td>_____ °C</td> </tr> <tr> <td>_____ °C</td> <td>Set</td> <td></td> <td></td> </tr> <tr> <td>_____ °C</td> <td>Actual</td> <td></td> <td></td> </tr> </table> Thermocouple( _____ ), Resistance Thermometer, Optical Pyrometer, Radiation thermometer, Seger cone exist not exist good not good good not good, Truck Speed _____		Preheating Zone	Heating Zone	Soaking Zone	_____ °C	_____ °C	_____ °C	_____ °C	_____ °C	Set			_____ °C	Actual		
	Preheating Zone	Heating Zone	Soaking Zone															
_____ °C	_____ °C	_____ °C	_____ °C															
_____ °C	Set																	
_____ °C	Actual																	
24	材 料 寸 法 ホットチャージ	done not done																

No. of Equipment	設備番号										
25	乾燥風温量 風量 装入物水分 Inlet Outlet	_____ °C _____ m <sup>3</sup> /h _____ % _____ %									
26	断熱 壁面構成 耐火材 断熱材 外壁 壁の色 壁面温度 側面 上面 Heat Flux	<table border="1"> <thead> <tr> <th data-bbox="534 750 758 1064">Preheating Zone</th> <th data-bbox="534 1064 758 1377">Heating Zone</th> <th data-bbox="534 1377 758 1892">Soaking Zone</th> </tr> </thead> <tbody> <tr> <td data-bbox="758 750 981 1064"></td> <td data-bbox="758 1064 981 1377">           °C            °C         </td> <td data-bbox="758 1377 981 1892">           °C            °C         </td> </tr> <tr> <td data-bbox="981 750 1348 1064">kcal/m<sup>2</sup>h</td> <td data-bbox="981 1064 1348 1377"></td> <td data-bbox="981 1377 1348 1892"></td> </tr> </tbody> </table> スキッド断熱 台車・コンベア等の 軽量化	Preheating Zone	Heating Zone	Soaking Zone		°C °C	°C °C	kcal/m <sup>2</sup> h		
Preheating Zone	Heating Zone	Soaking Zone									
	°C °C	°C °C									
kcal/m <sup>2</sup> h											
		good      not good done      not done									



No. of Equipment	設備番号	
28	設備管理 作業標準 昇温曲線 記録 安全整備 周期 記録	made not made exist not exist good not good good not good _____ly good not good
29	実績 処理量 燃料量 熱効 率 排ガス損失 冷却水損失 放熱損失	t/h _____ kg.m <sup>3</sup> /h _____ % _____ Kcal/h _____ % Kcal/h _____ % Kcal/h _____ %

2-2 Steam Consuming Equipment (蒸氣使用設備)

1	Part	工 程	
2	Use	用 途	
3	Name of Equipment	設 備 名 稱	
4	No. of Equip.	番 号	
5	Type	型 式	
6	Maker	メ ー カ ー	
7	Time built	設 置 時 期	
8	Dimension	寸 法	ℓ mm x w mm x h mm, d mm x h mm
9	Heating surface area	伝 熱 面 積	m <sup>2</sup>
10	Volume	容 量	
11	Capacity	能 力	
12	Subject of heating	被 加 熱 体	
13	Heat source	熱 源	Steam: kg/cm <sup>2</sup> G, °C t/h, Hot water °C, t/h
14	Quantity of Treatment	処 理 量	
15	Operating condition	操 業 条 件	
	Temp.	温 度	°C
	Press.	圧 力	kg/cm <sup>2</sup> G
16	Insulation	断 熱	mm good, not good
	Surface Temp.	表 面 温 度	°C heat flux Kcal/m <sup>2</sup> h

Diagnoser

Date Factory

17	Cleaning for heating surface	伝熱面の掃除	done	not done		
18	Instruments	計	Temp.	Press.	Flow.	Other:
19	Auxiliary Equip. Heat Recovery High Temp. Fluid Low Temp. Fluid Temp. rising (falling) Flow Condensate recovery Rate of Recovery	附 属 設 備 熱 回 収 高温流体 低温流体 温度上昇 (降下) 流 量 ドレン回収 回 収 率	exist	not exist	type	specific heat specific heat
			done	not done,	open system,	closed system
				m <sup>3</sup> /h		%

2-3 Boiler (ボイラ)

1	Part	工 程	
2	Use	用 途	
3	No. of Boiler	番 号	
4	Type	型 式	Water tube boiler (水管) Flue tube boiler (炉筒) Once-through boiler (貫流) Hot-water boiler (温水) Other (その他)
5	Rated evaporation	定 格 蒸 気 量	t/h
6	Manufacture date	製 造 年 月 日	
7	Steam pressure	圧 力	Rated (定格) kg/cm <sup>2</sup> G, Normal (常用) kg/cm <sup>2</sup> G
8	Heating surface area	伝 熱 面 積	m <sup>2</sup>
9	Auxiliary Equip.	附 属 設 備	Superheater (過熱器) m <sup>2</sup> , Reheater (再熱器) m <sup>2</sup> Economizer (節炭器) m <sup>2</sup> , Air heater (空氣予熱器) m <sup>2</sup>
10	Fuel Name Lower Calorific Value Specific gravity	燃 料 名 前 發 熱 量 (低位) 比 重	Kcal/kg, l, m <sup>3</sup> N
11	Usage Continuous Batch	使 用 状 況 連 統 非 連 統	h/d, d/m, h/y,

Diagnoser

Date

Factory



Item	項目	Unit 単位	Nominal 定 格	Actual 実 績	Remarks 備 考
12	Oil Tank Volume Temp. Insulation Leak	— m <sup>3</sup> °C mm —			good, not good
13	Boiler Steam Pressure Steam Temp. Feed water flow rate " Temp. " Meter Blow off flow rate Boiler water pH Conductivity	— kg/cm <sup>2</sup> G °C m <sup>3</sup> /h °C — m <sup>3</sup> /d — — μS/cm			Type Continuous, Intermittance, Heat recovery
14	Feed Water pH Conductivity Preparation method Testing time Cl' content	— — μS/cm — — — ppm			

Item	項目	Unit 單位	Nominal 定 格	Actual 実 績	Remarks 備 考
15	Combustion Fuel Consumption Temp. Meter Burner Type	— — kg.m <sup>3</sup> /h °C — —			exist, not exist <u>Oil burner</u> Low press, air atomizing (低圧噴霧式) Steam or air atomizing (高圧噴霧式) Press. jet type (袖圧式) Rotary (回転式) <u>Gas burner</u> Intermixing type (内部混合式) Injector atomizer (外部混合式) Semi-mixing (半混合式)
	Capacity Burner tile Clinker Air ratio Insulation Sucking air	— — — — mm —			good, not good found, not found Measuring point (場処) good, not good good, not good good, not good
16	Color of smoke	—			good, not good
17	Air heater Air temp. Inlet Outlet	— — °C °C			exist, not exist

Item	項目	Unit 単位	Nominal 定 格	Actual 実 績	Remarks 備 考
O <sub>2</sub> % Inlet Outlet Waste gas temp. Inlet Outlet	入口 出口 排ガス温度 入口 出口	% % — °C °C			
18 Economizer Waste gas temp. Inlet Outlet Feed water temp. Inlet Outlet	エコマイザー 排ガス温度 入口 出口 給水温度 入口 出口	— — °C °C — °C °C			exist, not exist
19 Automatic Controller Subject System Operation	自動制御 対象 方式 作動	— — — —			exist, not exist Steam press. air ratio good, not good
20 Steam accumulator Capacity Pressure	スチームキュームレーター 容量 圧力	— m <sup>3</sup> kg/cm <sup>2</sup> G			exist, not exist
22 Evaporation ratio Boiler efficiency Loss with waste gas	蒸発倍数 ボイラ効率 排ガス損失	Kg/kg, l % Kcal/h			Hh base, Hl base

Item	項目	Unit 項目	Nominal 定 格	Actual 実 績	Remarks 備 考
23	Soot blow Service a burner Removal of scale Air heater Economizer Gas duct Stack Cleaning burner tip	/d /m — /y " " " /m			

2-4 Steam Piping, Condensate Recovery (蒸気管, ドレン回収)

Steam Piping Insulation Leakage	蒸気配管 保温 漏洩				
Recovery of Flashed Steam Cylinder Hood	フラッシュ蒸気 の利用 シリンダー上 のフード	exist, 有	not exist 無		
Condensate Recovery	ドレン回収				
Flow Rate System	発生量 回収率 回収方式		m <sup>3</sup> /h %	open, closed	
Steam Trap Type No. of Unit Present Condition	スチームトラップ 形式 数 作動状況			good, not good	
Flow Sheet Steam Condensate	フローシート 蒸気 ドレン				

Diagnoser	
-----------	--

Date		Factory
------	--	---------

- 3 Electric Power
  - 3-1 Electric Power Management
  - 3-2 Transformer
  - 3-3 Motor Driven Machine-Except Air Compressor
  - 3-4 Operation of Motors
  - 3-5 Air Compressor
  - 3-6 House Power Plant
  - 3-7 Air Conditioner
  - 3-8 Lighting Fittings

3-1 Electric Power Management (電力管理)

1	General (1) Record of used power for every month (2) Examination the cause for variance for used power (3) Stability of voltage and frequency of source	一般 毎月の使用電力値 (KWH) の記録	done	not done (理由)			
		使用電力値が変化した理由の検討	done	not done			
		受電電圧、周波数の安定状況	stable	not stable			
		電力原単位	Yes	No			
2	(1) Calculation for major product's EPSU monthly (2) Preparation table on the right for every process and use	毎月の主要製品の電力原単位の算出	Output (A)	Used power (B)	EPSU (B/A)	ratio of electric power fee per total cost	
		用途別・工程別に右表があるか	生産額(A)	電力使用量(B)	原単位(B/A)	生産費に占める電力割合	
		電力原単位の目標値	決めている	determined (value)	決めている	決めている	not determined
3	Load Factor (1) Record of hourly consumption of power (2) Daily load curve graph (3) Improvement of load curve	負荷率					
		毎時間の消費電力の記録	記録している	done	(max. kWh) (min. kWh)	記録していない	not done
		日負荷曲線	グラフ化している	done		していない	not done
4	Value of power factor contracted (1) Supplier (2) Penalty fee	日負荷の最大値を抑える対策	行なっている	done		行なっていない	not done
		電力料金算定上の力率					
		電力会社					
		ペナルティ					

Diagnoser

Date

Factory

5	Substation	受変電設備 受電盤の計器の有無とその 指針の良否	受変電設備																	
			Meter 計器	Voltage 電圧	Ampere 電流	kW 電力	kWh 電力量	Power Factor 力率	kVr 無効電力	kVrh 無効電力量	Primary 一次側	Secondary 二次側	Note 備考							
	(1) Meters at receiving panel and adequacy of indication		Good																	
	(2) Measurement of transformer load	変圧器の負荷測定	Yes																	No
	(3) Transformer exclusively for lighting	電灯用専用変圧器	Yes																	No
	(4) Turning off transformer when off load	不要時の変圧器遮断	Yes																	No
	(5) Improvement of power factor by static condenser	コンデンサーによる力率改善	Yes																	No
	(6) One-line diagram	配線系統図の有無	Have																	No
6	Distribution system	配線設備																		
	(1) Measurement of main circuit load	主回路別の負荷測定	Yes																	No
	(2) Rate of voltage drop of main circuit	主回路別の電圧降下率																		
	(3) Balance in three phases	相間のバランス																		
7	Motor	電動機																		
	(1) Measurement of load of motors over 15 kW	15kW以上の電動機の負荷測定	Yes																	No
	(2) Periodically lubrication of gear and motor	ギヤや電動機の定期的な給油	Yes																	No
	(3) Turning off motor when off load	無負荷時の電動機の停止	Yes																	No



8	Motor driven machine	電動機応用設備						
	(1) Flow control of blower and pump	ブロワーやポンプの流量制御	電動機速度制御 Control of numbers of operating motor 台数制御 Damper or valve control ダンパー、バルブの開閉 Others その他					
	(2) Checking leakage of compressed air or water	圧縮空気や水のもれのチェック	Yes	No				
	(3) Keeping adequate working pressure of compressed air	圧縮機の使用圧力は適正か	Yes	No				
	(4) Keeping adequate discharge pressure of pump	ポンプの吐出圧は適正か	Yes	No				
9	Lighting fittings	照明設備						
	(1) Cleaning lighting fittings	照明器具の清掃	Yes	No				
	(2) Turning off unnecessary light	不要な照明の消灯	Yes	No				
10	Electric welder	電気溶接機						
	(1) Static condenser exclusively for welder	専用の力率改善用コンデンサー	Yes	No				
	(2) Transformer exclusively for welder	専用の変圧器	Yes	No				
	(3) Keeping circuit balance of three phases	電源の各相のバランス	Yes	No				
	(4) Cable length from welder to holder	溶接機の手元までの配線長さ	Yes	No				
	(5) Primary cutout type voltage reducing device	一次切入式電撃防止器の有無	Yes	No				
11	Classification of load 負荷の配分							
		Machines 主機のモーター	Air Compressors コンプレッサ	Pumps ポンプ	Heaters ヒーター	Lighting 照明	Air Conditioner 空調	Total 合計
		kW	kW	kW	kW	kW	kW	kW
		%	%	%	%	%	%	%
								100.0
								%

3-2 Transformer for

( 変圧器 )

1	Type of Transformer	型 式	<input type="checkbox"/> Oil Immersed Self Cooling ( 油入自冷式 ) <input type="checkbox"/> Dry Type ( 乾 式 ) <input type="checkbox"/> Air cooling Forced Oil ( 送油風冷式 ) <input type="checkbox"/> Others ( その他 )
2	Number of Phase	相 数	<input type="checkbox"/> 3 Phase ( 三相 ) <input type="checkbox"/> Single Phase ( 单相 )
3	Connection (Single Phase)	結 線 方 法 ( 单相Tr )	<input type="checkbox"/> Δ - Δ <input type="checkbox"/> Δ - Y <input type="checkbox"/> Y - Δ <input type="checkbox"/> V - V
4	Rated Output	定 格 出 力	_____ kVA, Number of Bank (バンク数) _____
5	Rated Voltage Rated Current	定 格 電 圧 定 格 電 流	Primary V, A        Secondary V, A
6	Rated Frequency	定 格 周 波 数	_____ Hz.        7        % Impedance    パーセントインピーダンス        % At        kVA Base
8	Maker, Year Made	メーカと製造年	_____
9	Loss	損 失	Iron Loss (鉄損) _____ kW,        Copper Loss At Full Load (全負荷銅損) _____ kW,

Measurement Record

( 1 )

Time 時 間	Voltage 電 圧	Current 電 流	Apparent Power 皮相電力	Power Factor 力 率	Power 電 力	Oil temp. 油 温	積算電力計 Watt hour meter		Remarks
							読み Reading	常数 Coefficient	
	V	A	kVA	%	kW	°C		kWh	

Diagnoser	Date	Factory
-----------	------	---------



3-3 Motor Driven Machine except Air Compressor ~ Over 1.5 kW (電動力応用設備コンプレッサを除く〜1.5kW以上)

1	Name of Equipment	設備名	Number of Similar Equipment 同種設備の数
2	Kind of Motor	電動機の種類	<input type="checkbox"/> D.C. (直流) <input type="checkbox"/> Inductor (誘導機) <input type="checkbox"/> Wound Rotor <input type="checkbox"/> Others <input type="checkbox"/> A.C. (交流) <input type="checkbox"/> Synchronous (同期機) <input type="checkbox"/> Squirrel Cage
3	Rating of Motor	電動機の定格	Output (出力) _____ kW, Voltage (電圧) _____ V, Current (電流) _____ A Frequency (周波数) _____ Hz, RPM (回転数) _____ rpm, Magnetic Pole (極数) _____
4	Starting Method	起動方法	<input type="checkbox"/> Full-Voltage (直入) <input type="checkbox"/> Star-delta (A-Δ) <input type="checkbox"/> Rotor-resistance (二次抵抗) <input type="checkbox"/> Others
5	Coupling Apparatus	伝導装置	<input type="checkbox"/> Direct(直結) <input type="checkbox"/> Belt(ベルト) <input type="checkbox"/> Gear (歯車) <input type="checkbox"/> Others <input type="checkbox"/> Natural(自然物) <input type="checkbox"/> Synthetic(人工物) <input type="checkbox"/> Number(本数)
6	Equipment	設備機械	<input type="checkbox"/> Pump (ポンプ) <input type="checkbox"/> Blower (ブロワー) <input type="checkbox"/> Others
7	Kind of Flow and Density	流体名と密度	<input type="checkbox"/> Air (空気) <input type="checkbox"/> Water (水) <input type="checkbox"/> Others, <input type="checkbox"/> Density (or Specific Gravity) (密度又は比重) _____ kg/m <sup>3</sup> (lb/m <sup>3</sup> )
8	Flow Control	流量制御	<input type="checkbox"/> Automatic (自動) <input type="checkbox"/> Valve (バルブ) <input type="checkbox"/> Speed Control (速度制御) <input type="checkbox"/> Manual (手動) <input type="checkbox"/> Damper (ダンパー) <input type="checkbox"/> Others
9	Speed Control	速度制御	<input type="checkbox"/> Motor (モーター) <input type="checkbox"/> Pole Change (極数) <input type="checkbox"/> Voltage (電圧) <input type="checkbox"/> Mechanical (機械式) <input type="checkbox"/> Frequency (周波数) <input type="checkbox"/> Others
10	Automatic Cutting-off (When Off-Load)	空転時の自動停止装置	<input type="checkbox"/> Yes (有) <input type="checkbox"/> No (無)
11	Frequency of Lubrication	給油頻度	Frequency of filter cleaning 取入フィルター清掃 _____ times/year (回/年)    12 _____ times/Month

Diagnoser	Date	Factory
-----------	------	---------

Motor driven machine (電動機応用設備)

Name of machine \_\_\_\_\_

Date	Used power 使用電力			Temp. of fluid °C 流体温度	Flow Q m <sup>3</sup> /min 流量 Q' t/h	Fluid 液体		Valve Position バルブ開度 管径cm	Velocity of fluid m/s 流速	Estimated Load kW 推定負荷	Efficiency % 総合効率	Remarks Sound Vibration Leakage Others 備考
	Voltage V 電圧	Current A 電流	Power factor % 力率			Electric power kW 電力	Pressure H'kg/cm <sup>2</sup> Hm 圧力					
					Rated 定格 Actual 測定値 max. 最大 min. 最小							

1) Required electric power of blower 送風機所要電力  
 $P = \frac{A \cdot Q \cdot P_T}{1,000 \cdot \eta \cdot 6.12}$  (kW)  
 PT: Total pressure (mmAq), A: Allowance, η: efficiency of blower (0.72-0.78%)  
 (1.1-1.3) 余裕率 送風機効率

2) Required electric power of pump  
 $P = \frac{A \cdot \gamma \cdot Q \cdot H}{\eta \cdot 6.12}$  or  $P = \frac{Q' \cdot H'}{\gamma \cdot \eta \cdot 36.7}$  (kW)  
 A: allowance (1.05~1.2) 余裕率  
 η: efficiency of pump (0.8~0.85%) ポンプ効率

3) Velocity of fluid 配管内流速  
 $U = \frac{Q}{A}$  (m/sec)  
 Q: flow (m<sup>3</sup>/sec) 流量  
 A: sectional area of pipe (m<sup>2</sup>) 管内断面積

velocity (m/sec)	pressure (Kg/cm <sup>2</sup> )	
City water 水道水	0.6 ~ 1.5	1.8 ~ 3.0
River water 一般水	1.5 ~ 3.0	3.0 ~ 10
Air 空気	8 ~ 15	1 ~ 2

3-4 Operation of Motors

Process 工程	Used for 用途	Maker メーカー	Year built 製造年	Output 容量		Voltage 電圧		Current			Revolutions 回転数	Speed control 速度制御	Power factor 力率	Note 備考
				Rated kW HP	Actual kW HP	Rated V	Actual V	Rated 定格 A	Actual 实际 A	$\text{③} / \text{④}$ %				

Diagnoser

Date

Factory



3-6 House Power Plant (家用発電設備)

1	Kind of Engine	エンジンの種類	<input type="checkbox"/> Diesel Engine	<input type="checkbox"/> Steam Turbine		
			<input type="checkbox"/> Gas Turbine	<input type="checkbox"/> Condensing turbine		
				<input type="checkbox"/> Back Pressure Turbine		
				<input type="checkbox"/> Extraction and Back Pressure Turbine		
2	Output of Engine	エンジン出力	PS(kW)	3	Fuel Consumption	燃料消費量 _____ ℓ(Kg)/h
4	Kind of Fuel	燃料種別	<input type="checkbox"/> Coal	<input type="checkbox"/> Heavy Oil	<input type="checkbox"/> Diesel Oil	<input type="checkbox"/> Others
5	Caloric Value of Fuel	同上の発熱量	Kcal/ℓ(Kg)			
6	Rated Output of Generator	発電機出力	kVA (kW)	7	Rated Power Factor	定格力率 _____ %
8	Rated Voltage, Rated Current	定格電圧	V		定格電流	A
9	Daily Record	運転日誌	<input type="checkbox"/> Yes (有)	<input type="checkbox"/> No (無)		

Measurement Record (測定記録)

Time 時間	Generated Energy 発電量 kWh	Fuel Consumption 燃料消費量 Kg	Steam Temp. 蒸気温度 °C	Steam Pressure 蒸気圧力 kg/	Voltage 電圧 V	Current 電流 A	Power Factor 力率 %	Remarks 備考
			In. Out	In. Out				

Diagnoser	Date	Factory
-----------	------	---------



3-7 Air Conditioner (空調設備)

1	Type of System	空調方式	<input type="checkbox"/> Air Duct Conditioning (集中方式) <input type="checkbox"/> Fan Coil Unit (ファンコイル方式) <input type="checkbox"/> Unit Air Conditioning (パッケージ方式)
2	Room Air Conditioned (1) Room Size	室の状況 室の大きさ	Floor Space (床面積) <u>        </u> m <sup>2</sup> , Room Volume (室容積) <u>        </u> m <sup>3</sup>
	(2) Number of person in the Room	室内人数	<u>        </u> 人
	(3) Usage	用途	<input type="checkbox"/> Office (事務室) <input type="checkbox"/> Works (工場) <input type="checkbox"/> Others
	(4) Room Temp.	室温	Actual Temp. (実測温度) <u>        </u> °C Set Temp. (設定温度) <u>        </u> °C Measurement Method (測温方式) <input type="checkbox"/> Manual <input type="checkbox"/> Automatic Control Method (制御方式) <input type="checkbox"/> Manual <input type="checkbox"/> Automatic
	(5) Humidity	湿度	Actual (実測湿度) <u>        </u> (設定湿度) Measurement Method (測定方式) <input type="checkbox"/> Manual <input type="checkbox"/> Automatic Control Method (制御方式) <input type="checkbox"/> Manual <input type="checkbox"/> Automatic
	(6) Air Flow	風量	Fresh Air Flow Induced (外気取入風量) <u>        </u> m <sup>3</sup> /min, Circulating Air Flow (室内循環風量) <u>        </u> m <sup>3</sup> /min.
3	Water Cooling Tower	クーリングタワー	Actual Temp. (実測温度) <u>        </u> °C, (湿球温度) <u>        </u> °C, (水露) <u>        </u> l/min., (吐出圧) <u>        </u> kg/cm <sup>2</sup> G Wet Bulb Temp. (湿球温度) <u>        </u> °C, (吐出圧) <u>        </u> kg/cm <sup>2</sup> G Flow (流量) <u>        </u> Delivery Press. (吐出圧)
4	Type of Refrigerating Machine	冷凍機の種類	<input type="checkbox"/> Compression Type (圧縮式) <input type="checkbox"/> Absorption Type (吸収式)
5	Refrigerant	冷媒	<input type="checkbox"/> Ammonia (アンモニア) <input type="checkbox"/> Freon (フロン) <input type="checkbox"/> High Pressure (高圧) <input type="checkbox"/> Low Pressure (低圧)

Diagnoser	Date	Factory
-----------	------	---------

6	Cleanness of Air (1) Method for removal of flying cotton	清 淨 度 風綿除去方式	<input type="checkbox"/> Nozzle absorbing (ノズル吸込) <input type="checkbox"/> Traveling absorber (巡回吸込) <input type="checkbox"/> Floor duct (床面吸込) <input type="checkbox"/> Air conditioner (空調機) <input type="checkbox"/> Wiper (ワイパー式) <input type="checkbox"/> Blowoff (ブローオフ式)
	(2) Method for electrostatic shielding	静電防止方式	Humidifier (給湿機) Electric (電気方式)
7	Insulation of roof and wall	屋根, 壁の断熱	good not good
8	Insulation of duct and pipe	ダクト, 配管の断熱	good not good
9	Tightness of window and door	窓, ドアの気密	good not good
10	Separation heat generating equipment	発熱機器の分離	yes no
11	Partial air conditioning in large room	大空間の中の空調を要する部分の隔離	yes no
12	Heat recovery by total enthalpy heat exchanger	全熱交換器による熱回収	yes no (Type )
13	Water spray on roof	屋根 散 水	done not done
14	Starting and stopping time of air conditioner	装置の起動停止時刻	Starting time _____ Stopping time _____
15	Stopping water pump when refrigerating machine stops	冷凍機停止時に冷却水ポンプの停止	stop not stop (auto, manual)
16	Prevention over cooling and stopping when unnecessary	過冷防止, 不要時の運転停止	yes no

17	Setting most suitable temperature by climate	季節による設定温度の変更	yes	no
18	Control of induced fresh air	必要外気量の管理	yes	no
19	Checking temperatures of evaporation, condensation and pressure of refrigerating machine	冷凍機の蒸発温度、凝縮温度の管理、制御の管理	yes	no
20	Cleaning (Condenser)	清掃(冷凍用コンデンサー)	done (times/month)	not done
21	Cleaning (Air Conditioner Coil)	清掃(空調用コイル)	done (times/month)	not done
22	Cleaning (Air Filter)	清掃(エアフィルター)	done (times/month)	not done
23	Cleaning (Cooling Tower)	清掃(クーリングタワー)	done (times/year)	not done

Air Conditioner Measurement Record No.1 (空調測定記録 その1.)

	Inlet Fan (外気取入ファン)	Circulating Fan (室内循環用ファン)	Cooling Tower		Refrigerating Machine (冷凍機)	
			Pump (ポンプ)	Fan (ファン)	Compression Type (圧縮式)	Absorption Type (吸収式)
Rated (定格)	kW	kW	kW	kW	kW	Kcal/h
Actual (実測)	kW	kW	kW	kW	kW	Kcal/h





**List of Information Material Collected**

1. Energy Production and Consumption Restructuring Program
2. Electrical Rate (MEA, PEA)
3. Price list of oil product



JICA