

APPENDIX 6.6.1 EXISTING WELL INVENTORY IN PAMPANGA PROVINCE

Well No	JICA Original	Depth Well (m)	Tested Yield (l/min)	Drawdown (m)	Specific Capacity (l/min/m)	Transmissivity (m ² /day)	Location Barangay / Municipality
	CL-34	244	3,705	19.5	190	400	Magalang
	CL-35	237	2,543	25.4	100	190	Porac
	CL-38	240	4,201	13.5	311	610	Sta. Ana
	CL-41	253	6,052	14.7	412	900	Bacolor
	Ex-20	204	1,694	29.5	57	110	St. Rosario Magalang
1	PS- 1	153	1,892	18.3	90	-	Mabini st Angeles
2	PS- 2	243	921	19.3	42	-	Mabini st Angeles
3	PS- 3	123	394	18.3	22	-	Mabini st Angeles
4	PS- 4	80	394	15.0	17.5	-	Kulliat st Angeles
5	PS- 5	110	935	14.6	67	-	Balagtas Angeles
6	PS- 6	120	985	8.4	154	-	Pandan Angeles
7	PS- 7	214	921	13.7	60	-	San Joaquin Angeles
8	PS- 8	104	755	13.7	55	-	Pampang Angeles
9	PS- 9	110	181	15.3	12	-	St. Cristo Angeles
10	PS-10	92	657	18.3	36	-	McArthur Angeles
11	PS-11	98	493	15.3	32	-	Mirasol Angeles
14	PS-14	143	602	3.7	163	370	Eje school Angeles
16	17991	27	64	1.3	49	-	Mining Angeles
19	17992	34	76	0.6	127	-	Pandan Angeles
20	17993	49	26	1.5	17	-	Sapalibutad Angeles
22	426025	14	22	1.2	18	-	Pulung Cacutud Angeles
24	BWS- 6	183	1,970	14.6	141	-	Lakandula Angeles
27	43673	57	227	3.1	73	-	Balibago Angeles
29	BWS- 4	183	1,325	25.6	52	-	Balibago Angeles
30	BWS- 2	85	1,473	20.4	72	-	Josefa Subd Angeles
31	17994	25	23	2.7	8	-	Pampang Angeles
32	17993	25	133	0.9	144	-	Pampang Angeles
34	TW	152	395	80.3	4.8	-	Cutcut Angeles
39	13159	16	57	1.5	35	-	Calzadang Porac
40	43672	32	33	1.1	35	-	Senora Porac
41	13155	19	30	1.6	19	-	Macantian Porac
42	13155	15	140	0.6	229	-	Macantian Porac
43	13155	13	30	0.9	34	-	Macantian Porac
44	13153	12	49	0.3	164	-	Mhibaug Porac
46	19352	43	76	0.9	84	-	St. Cruz Angeles
46	19353	44	38	2.7	14	-	St. Cruz Angeles
46	22091	20	33	1.5	25	-	Pulung Mababa Porac
52	426253	49	33	1.2	32	-	Pasbulbulu Porac
53	426522	49	26	3.1	8.4	-	Margot Angeles
54	426039	40	30	2.1	14	-	Margot Angeles
55	426032	62	19	8.0	2.4	-	Margot Angeles
57	3224	64	33	1.5	25	-	Saparbato Angeles
59	6652	60	23	5.4	4.2	-	Saparbato Angeles
61	20241	106	530	4.6	116	-	Clark A.B. Angeles
62	20771	26	33	0.3	126	-	Baluga VIII Angeles
63	17969	25	66	0.6	105	-	Malabanas Angeles
65	C- 5	203	-	-	-	160	Calzadang Porac
66	BWS- 7	92	1,306	3.5	212	-	Dau Angeles
67	BWS- 8	92	2,496	15.9	157	-	Henson VIII Angeles
68	EPZA	92	369	3.3	104	150	Export Proc Angeles
70	426111	63	56	1.3	31	-	Balibago Angeles
71	13162	21	33	0.3	126	-	Secungbulaon Porac
72	17040	24	56	1.5	37	-	Secungbulaon Porac
73	14734	21	26	4.9	5.4	-	Pulong Santol Porac
74	18059	37	45	1.5	30	-	Planas Porac
75	5957	32	26	1.5	17	-	Planas Porac
76	17133	28	26	3.7	7	-	Palat Porac
77	13161	22	33	0.6	63	-	Mitla Porac
78	42601	40	26	0.6	43	-	Mitla Porac
79	13159	12	56	1.5	37	-	Calzadang Porac
80	43671	24	33	0.3	41	-	Balubad Porac
81	426017	30	33	2.5	15	-	Cangatta Porac

NO. 40

NO. 44

NO 52

WELL NO	LOCATION	DEPTH (m)	CASING DEPTH (m)	CASING DIAMETER (mm)	STATIC WATER LEVEL (m)	PUMP TEST DATA	LOG
LWUA well no. 43672 (BPW)	BO. SENORA PORAC, PAMPANGA	30.0 M					SAND BLUE CLAY SAND & GRAVEL ADOBE SANDSTONE
LWUA well no. 22091 (BPW)	BO. PULUNG MABA PORAC, PAMPANGA	30.11 M			14.63 M		SANDSTONE SAND W/ STONE SAND COARSE SAND W/ GRAVEL
LWUA well no. 13158 (BPW)	BO. MANI BAOG PORAC, PAMPANGA	11.9 M			5.18 M		SANDY CLAY W/ BOULDER SAND & GRAVEL

WELL NO	LOCATION	DEPTH (m)	CASING DEPTH (m)	CASING DIAMETER (mm)	STATIC WATER LEVEL (m)	PUMP TEST DATA	LOG
WELL NO BPW 531715	MARGOT, ANGELES	161.6 m			24.39m		SAND ADOBE BOULDER SANDSTONE ADOBE SANDY CLAY SAND & GRAVEL SANDY CLAY W/ GRAVEL LOOSE ROCK ADOBE (TUFF) SAND & GRAVEL SANDY CLAY LOOSE ROCK SANDY CLAY
WELL NO BPW 426253	PASBUL, PORAC	48.8 m		100	26.2m		SAND, F SAND, C ADOBE, SOFT SAND & GRAVEL, T COMPACT SAND, C SANDY CLAY ADOBE SAND, F SAND, F+C

NO. 55

LOG	DEPTH	LOG	DEPTH	LOG	DEPTH
<p>LWUA well no. BPW-426032 LOCATION: BO. MARGOT, ANGELES CITY, PAMP DEPTH: 62.30 M CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 27.44 PUMP TEST DATA DISCHARGE: 0.32 LPS DRAWDOWN:</p>		<p>LWUA well no. BPW-436622 LOCATION: MARGOT, ANGELES CITY, PAMPANGA DEPTH: 48.78 M CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 27.44 PUMP TEST DATA DISCHARGE: 0.44 LPS DRAWDOWN:</p>		<p>LWUA well no. BPW-10857 LOCATION: BO. LOURDES, ANGELES CITY, PAMP DEPTH: 106.10 M CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 4.26 PUMP TEST DATA DISCHARGE: 18.83 LPS DRAWDOWN:</p>	

NO. 61

LOG	DEPTH	LOG	DEPTH	LOG	DEPTH
<p>LWUA well no. BPW 6286 LOCATION: KULIAT, BO. LOURDES, ANGELES CITY, PAMP DEPTH: 103.65 M CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 2.44 PUMP TEST DATA DISCHARGE: 7.57 LPS DRAWDOWN:</p>		<p>LWUA well no. BPW 20241 LOCATION: CLARK FIELD, ANGELES CITY, PAMP DEPTH: 106.10 M CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 25.91 PUMP TEST DATA DISCHARGE: 8.83 LPS DRAWDOWN:</p>		<p>LWUA well no. BPW 20771 LOCATION: DEPTH: CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:</p>	

NO. 62

NO 69

NO 65

NO 66

NO. 70

NO. 70

WELL NO	WELL NO	WELL NO	WELL NO
C-4	C-5	(Cont.)	BWS 8
LOCATION: STA. MARIA, MABALACAT DEPTH: 143.3m CASING DEPTH: 135.6m CASING DIAMETER: 400/300mm STATIC WATER LEVEL: 1.22 PUMP TEST DISCHARGE: DRAWDOWN:	LOCATION: CALSADONG BAYO PORAC DEPTH: 208.9m CASING DEPTH: 208.9m CASING DIAMETER: 400/300mm STATIC WATER LEVEL: 6.67 DISCHARGE: DRAWDOWN:	LOCATION: DEPTH: CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: DISCHARGE: DRAWDOWN:	LOCATION: Balibago, Angolo DEPTH: 67.5m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 2.74m PUMP TEST DATA DISCHARGE: 0.94 LPS DRAWDOWN:
LOG SAND, LOAM SAND W/ GRANULE FINE - VERY COARSE CLAY W/ GRANULE SAND, COARSE W/ GRANULE CLAY, SANDY CLAYEY SAND CLAY, SANDY W/ PEBBLES SAND, FINE - VERY COARSE W/ GRANULE CLAYEY SAND SAND, FINE - MEDIUM SAND, VERY FINE SAND, FINE SAND W/ GRAVEL SAND, FINE	LOG SAND W/ CLAY SAND, COARSE SAND, CLAYEY SAND W/ PEBBLE - GRAVEL SAND, COARSE, CLAYEY SILT SILT W/ SAND, FINE CLAY, SILTY - SANDY SAND & GRAVEL SAND, F - C SAND & GRAVEL W/ CLAY SAND & GRAVEL SAND, F - C SAND & GRAVEL SAND, F - C	LOG SAND, FINE SILT W/ SAND SAND, C. GRAVEL SILT W/ SAND	LOG Sand & gravel loose boulders Sand, F Sand, C CLAY, FINE Sand, C Coral Sand, C
DEPTH (m) 143.3 100 80	DEPTH (m) 170 200 50 100 150 170	DEPTH (m) 170 200	DEPTH 50 100

NO. 68



NO. 81

NO. 17

WELL NO. EPZA	WELL NO C-20A	WELL NO CAPAYA II
LOCATION : EXPORT PROCESSING ZONE DEPTH : 91.5 m CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : PUMP TEST DISCHARGE : 14.49 lps DRAWDOWN : 8.33 m	LOCATION : PULONG BOLO, ANGELES DEPTH : CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : DISCHARGE : DRAWDOWN :	LOCATION : CAPAYA II DEPTH : 122 m CASING DEPTH : 122 m CASING DIAMETER : STATIC WATER LEVEL : DISCHARGE : DRAWDOWN :
SAND, MEDIUM GRAINED WHITE SILICA W/Q ₅ SAND, VERY FINE GRAINED SILICATE, INTERCALATED W/ BOULDER SAND, FINE GRAINED W/ Q ₅ W/ RESISTIVITY LOG	CLAY VOLCANIC TUFF CLAYEY TUFF GRAVEL CLAYEY SAND W/ FRAGMENT S.S & BASALT SAND STONE GRAVEL TUFFACEOUS GRAVEL	SANDY CLAY FINE SAND GRAVEL & SAND SANDY CLAY FINE SAND YELLOW STICKY CLAY SAND ROCK W/ COARSE SAND YELLOW STICKY CLAY GRAVEL & SAND SAND ROCK CLAY SAND ROCK YELLOW STICKY CLAY ADOBE YELLOW STICKY CLAY
DEPTH (m) : 0, 50, 100	DEPTH (m) : 0, 50, 100	DEPTH (m) : 0, 50, 100, 122

LITHOLOG LOG MODIFIED BY RESISTIVITY LOG

LWUA Well No. BPW-4901	LWUA Well No. BPW-4901 (CONT.)	LWUA Well No.
LOCATION : HERANDA ST. ANGELES CITY, PAMPANGA DEPTH : 271.34 M CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : 7.32 M PUMP TEST DATA : DISCHARGE : 4.73 LPS DRAWDOWN :	LOCATION : DEPTH : CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : PUMP TEST DATA : DISCHARGE : DRAWDOWN :	LOCATION : DEPTH : CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : PUMP TEST DATA : DISCHARGE : DRAWDOWN :
SANDY CLAY FINE SAND GRAVEL & SAND SANDY CLAY FINE SAND YELLOW STICKY CLAY SAND ROCK W/ COARSE SAND YELLOW STICKY CLAY GRAVEL & SAND SAND ROCK CLAY SAND ROCK YELLOW STICKY CLAY ADOBE YELLOW STICKY CLAY	YELLOW STICKY CLAY FINE SAND BLUE STICKY CLAY CLAY SAND ROCK BLUE CLAY	LOG LOG LOG
DEPTH : 0, 50, 100	DEPTH : 0, 50, 100, 271.34	DEPTH :



LWUA well no. C-20 (NWRC) NO. 14 (W.W.) LOCATION: PULONG BULU, ANGELES CITY DEPTH: 145.7 M	LWUA well no. BPW 13159 LOCATION: BO. CALZABANGSAY FORAC, PAMPANGA DEPTH: 16.2 M	LWUA well no. BPW 436617 LOCATION: BO. SAN JOSE, ANGELES CITY, PAMP. DEPTH: 123.47 M	LWUA well no. BPW 4901 LOCATION: HERANDA ST. ANGELES CITY, PAMP. DEPTH: 142.86 M	LWUA well no. LOCATION: DEPTH: CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:
CASING DEPTH: CASING DIAMETER: 10.10 cm STATIC WATER LEVEL: 5.6 M PUMP TEST DATA DISCHARGE: 11.57 LPS DRAWDOWN: 3.66 M	CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 2.43 M PUMP TEST DATA DISCHARGE: 0.94 LPS DRAWDOWN:	CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 3.04 PUMP TEST DATA DISCHARGE: 0.94 LPS DRAWDOWN:	CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 7.32 PUMP TEST DATA DISCHARGE: 4.73 LPS DRAWDOWN:	
DEPTH	DEPTH	DEPTH	DEPTH	DEPTH
LOG	LOG	LOG	LOG	LOG
SANDY CLAY COARSE SAND W/ SOME GRAVEL FINE SAND, GRAY COARSE SAND TO FINE GRAVEL COARSE SAND GRAVEL W/ FINE SAND FINE SAND W/ GRAVEL SANDY CLAY W/ FINE GRAVEL FINE SAND TO FINE GRAVEL FINE GRAVEL W/ FINE SAND SANDY CLAY GRAVEL SANDY CLAY GRAVEL SANDY CLAY GRAVEL SAND & GRAVEL	SANDY CLAY SANDY CLAY W/ GRAVEL YELLOW CLAY BLUE CLAY SAND & GRAVEL	FINE SAND COARSE SAND BOULDER W/ SAND SAND SAND, STONE SAND & GRAVEL SAND BLUE STICKY CLAY CLAY SAND & GRAVEL	SANDY CLAY FINE SAND SAND & GRAVEL SANDY CLAY FINE SAND YELLOW STICKY CLAY SAND ROCK W/ COARSE SAND YELLOW STICKY CLAY GRAVEL & SAND SAND ROCK CLAY SAND ROCK YELLOW STICKY CLAY ADDOBE	
50	50	100	100	

LWUA well no. C-20 (NWRC) NO. 14 (W.W.) LOCATION: PULONG BULU, ANGELES CITY DEPTH: 145.7 M	LWUA well no. BPW 13159 LOCATION: BO. CALZABANGSAY FORAC, PAMPANGA DEPTH: 16.2 M	LWUA well no. BPW 436617 LOCATION: BO. SAN JOSE, ANGELES CITY, PAMP. DEPTH: 123.47 M	LWUA well no. BPW 4901 LOCATION: HERANDA ST. ANGELES CITY, PAMP. DEPTH: 142.86 M	LWUA well no. LOCATION: DEPTH: CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:
CASING DEPTH: CASING DIAMETER: 10.10 cm STATIC WATER LEVEL: 5.6 M PUMP TEST DATA DISCHARGE: 11.57 LPS DRAWDOWN: 3.66 M	CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 2.43 M PUMP TEST DATA DISCHARGE: 0.94 LPS DRAWDOWN:	CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 3.04 PUMP TEST DATA DISCHARGE: 0.94 LPS DRAWDOWN:	CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 7.32 PUMP TEST DATA DISCHARGE: 4.73 LPS DRAWDOWN:	
DEPTH	DEPTH	DEPTH	DEPTH	DEPTH
LOG	LOG	LOG	LOG	LOG
SANDY CLAY COARSE SAND W/ SOME GRAVEL FINE SAND, GRAY COARSE SAND TO FINE GRAVEL COARSE SAND GRAVEL W/ FINE SAND FINE SAND W/ GRAVEL SANDY CLAY W/ FINE GRAVEL FINE SAND TO FINE GRAVEL FINE GRAVEL W/ FINE SAND SANDY CLAY GRAVEL SANDY CLAY GRAVEL SANDY CLAY GRAVEL SAND & GRAVEL	SANDY CLAY SANDY CLAY W/ GRAVEL YELLOW CLAY BLUE CLAY SAND & GRAVEL	FINE SAND COARSE SAND BOULDER W/ SAND SAND SAND, STONE SAND & GRAVEL SAND BLUE STICKY CLAY CLAY SAND & GRAVEL	SANDY CLAY FINE SAND SAND & GRAVEL SANDY CLAY FINE SAND YELLOW STICKY CLAY SAND ROCK W/ COARSE SAND YELLOW STICKY CLAY GRAVEL & SAND SAND ROCK CLAY SAND ROCK YELLOW STICKY CLAY ADDOBE	
50	50	100	100	

LWUA Well No. BPW-43578	LWUA Well No. BPW-10864	LWUA Well No. (CONT.)
LOCATION: BALIBAGO ANGELES CITY, PAMPANGA DEPTH: 56.70 M CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 2.49 M PUMP TEST DATE: DISCHARGE: 3.78 LPS DRAWDOWN:	LOCATION: SAN ANGELO SUBD. ANGELES CITY, PAMP. DEPTH: 213.41 M CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: 3.65 M PUMP TEST DATE: DISCHARGE: 15.78 LPS DRAWDOWN:	LOCATION: DEPTH: CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATE: DISCHARGE: DRAWDOWN:
FINE SAND LOOSE ROCK COARSE SAND SAND STONE COARSE SAND SAND B GRAVEL	COARSE SAND SAND BLUE SANDY CLAY LIGHT BROWN SANDY CLAY SAND BROWN SANDY CLAY YELLOW CLAY SAND STONE BROWN SANDY CLAY SAND LIGHT BROWN SANDY CLAY BLUE SANDY CLAY	BLUE SANDY CLAY
0 20 40 60 80 100	0 50 100 150 200 250	0 50 100 150 200 250
DEPTH LOG	DEPTH LOG	DEPTH LOG

APPENDIX 6.7.1 Selection of Water Quality Examination Points

Selection of these source were done in consideration of the following favors.

- The points are located strategically i.e. possibly covering the whole municipality whereby the results would be representative of the overall condition in the area.
- Samples were collected from areas where water quality is reported to be undesirable.
- Accessibility and easy facilitation for sampling

Over selection of these points was done comprising of:

- Eleven (11) deep wells int he city water supply system (ACWS)
- Five (5) deep wells in the private/public system
- Five (5) shallow wells
- One (1) river
- Four (4) water taps on the service pipe for bacteriological analysis the location of these points is shown in FIGURE 6.7.1.1.

APPENDIX 6.7.2 WATER QUALITY ANALYSIS - ANGELES CITY

Sample No.	Well No.	Location	Group	Turb. (FTU)	TDS (mg/l)	pH (-)	EC (μ S/cm)	Alk. (mg/l)	Hard. (mg/l)	Acid. (mg/l)	Na (mg/l)	K (mg/l)	Ca (mg/l)	Mg (mg/l)	CO ₃ (mg/l)	HCO ₃ (mg/l)	Cl (mg/l)	SO ₄ (mg/l)	Fe (mg/l)	Mn (mg/l)	E.Coli. (ppm)	NO ₂ -N (mg/l)	NO ₃ -N (mg/l)
1	ACMS 1	Mabini	A	0.82	128	6.45	147	75	75	84	12.5	2.0	16.4	8.3	0	91.5	18.6	3	0.03	nil	-	3.15	nil
2	ACMS 2	Mabini	A	0.61	136	6.89	255	133	127	22	13	2.1	30.0	12.6	0	162.3	18.6	4	0.03	0.05	-	1.63	nil
3	ACMS 3	Rizal	A	0.40	147	6.45	140	85	97	42	10	2.0	30.0	5.3	0	103.7	18.6	1	0.08	nil	-	2.46	nil
4	ACMS 4	Kaliot	A	0.33	154	6.45	190	55	97	53	13	2.0	26.8	7.3	0	115.9	18.6	2.5	0.05	nil	-	3.95	nil
5	ACMS 5	Balagtas	A	0.48	154	6.45	130	105	97	37	12.5	2.1	20.8	10.9	0	128.1	13.9	1.5	0.03	nil	-	3.95	nil
6	ACMS 6	Pandan	A	0.43	179	6.08	185	110	90	26	22.5	2.0	24.0	7.3	0	134.2	18.6	3.0	0.05	nil	-	6.15	nil
7	ACMS 7	San Joaquin	A	0.43	192	6.85	288	122	112	15	20.0	1.7	24.0	12.6	0	148.8	18.6	5.0	0.05	nil	-	1.14	nil
8	ACMS 8	Pampang Road	A	2.03	147	6.32	150	95	90	33	17.5	1.7	12.0	14.6	0	115.9	13.9	1.5	0.10	nil	-	3.91	nil
9	ACMS 10	McArthur	A	0.41	154	6.15	149	95	82	24	20.0	2.0	20.8	7.3	0	115.9	13.9	1.5	0.15	0.10	-	4.18	nil
10	ACMS 12	Lourdes N.E.	A	0.50	128	6.09	160	85	75	22	13	2.1	20.8	5.6	0	103.7	13.9	1	0.10	0.10	-	4.58	nil
11	ACMS 14	Ang Elementary School	A	0.52	125	6.52	155	75	75	29	10	2	24	3.6	0	91.5	11.6	3	0.10	0.10	-	2.46	nil
12	ACMS 12	Ateron River (Bafibago Bldg.)	D	332	122	7.88	130	63	75	11	8	4.2	20.8	5.6	0	80.5	18.6	7	0.80	0.30	-	6.47	0.97
13	ACMS 50	Timos Park Subd., Cutcut	B	0.53	154	7.09	180	104	97	9	10.5	2	24	8.9	0	126.88	18.6	3	0.12	0.10	-	2.38	nil
14	ACMS 31	Pampang (BPW #17904)	C	0.81	115	6.25	140	70	75	11	6.5	2.3	24	3.6	0	85.4	13.9	3	0.08	nil	-	7.43	nil
15	ACMS 34A	Nepo Subd., Cutcut	C	18.15	160	6.84	260	66	97	15	8.0	2.6	20.8	10.9	0	80.5	18.6	32	0.56	0.10	-	0.80	nil
16	ACMS 36	Villa Teresa Subd.	B	0.62	122	6.58	153	75	75	22	10.5	2.3	15.0	9.1	0	91.5	23.2	4.0	0.12	nil	-	4.65	nil
17	ACMS 37	L & S Subd., Domingo	B	0.42	179	6.41	210	104	112	15	15.5	2.1	18.0	16.3	0	126.9	27.9	14.0	0.10	0.10	-	1.32	nil
18	ACMS 64	Villa Angelina Subd.	C	1.83	102	6.70	142	70	67	15	8	2.2	14.8	7.3	0	85.4	9.3	6.5	0.25	0.10	-	2.95	nil
19	ACMS 16	Miming (BPW #17901)	C	90.0	266	6.65	419	123	127	24	20	5.3	44.8	3.6	0	150.1	41.8	11.0	0.65	0.50	-	3.19	nil
20	ACMS 19A	Pandan (near BPW #17902)	C	5.99	173	5.76	237	85	97	33	10.5	5.2	26.8	7.3	0	103.7	27.9	16.0	0.35	0.10	-	8.17	nil
21	ACMS 25	Bafibago (BJS #1)	B	10.55	160	7.61	220	84	90	20	10	3.1	18	10.9	0	102.5	13.9	11.5	0.30	0.30	-	3.02	nil
22	ACMS 29	Bafibago (BJS #4)	B	0.35	144	7.68	210	104	90	20	8	2.2	24	7.3	0	126.9	13.9	3	0.11	0.10	-	2.34	nil
23	ACMS 1	Mabini St.	E	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	+	-	-
24	ACMS 7	San Joaquin	E	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	-	-
25	ACMS 6	Pandan	E	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	-	-
26	Faucet	City Engineer's Office	E	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0	-	-

*: Category; A - Deep wells in the city water supply system
 B - Deep wells in private/public systems
 C - Shallow wells
 D - River
 E - Water taps on the service pipe

Philippine National Standards for Drinking Water

Water Quality: Physical, Chemical and Radiological Requirements

Bacteriological Quality Standards

Parameter	Maximum Permissible level*
Turbidity	5 units
Color	5 units (s) **
Odor	Unobjectionable
Threshold odor number	Not more than 3
Taste	Unobjectionable
Total Solids	500 (s)
pH	6.5 - 8.5
Phenolic substances	0.001
Radioactive Subs.	
Gross Alpha	3 pCi/l
Gross Beta	30pCi/l
Trace Elements	
Arsenic	0.05
Barium	1.0
Cadmium	0.01
Chromium	0.05
Copper	1.0
Cyanide	0.05
Fluoride	0.6
Iron	1.0
Lead	0.05
Manganese	0.5 (s)
Mercury	0.002
Selenium	0.01
Zinc	5.0 (s)
Organic Chemicals	
Synthetic Detergents (MBAS)	0.5
Oil & Grease	Nil
Persistent Pesticides	
Aldrin	0.001
DDT	0.05
Dieldrin	0.001
Chlordane	0.003
Endrin	0.0002
Heptachlor	0.0001
Lindane	0.004
Toxaphane	0.005
Methoxychlor	0.1
2,4 --E	0.1
2, 4, 5 -- T	0.01
PCB	Nil
Other Chemicals	
Calcium	75
Chloride	200 (s)
Magnesium	50 (s)
Nitrate (NO ₃)	30
Sulfate	200 (s)
Hydrogen sulfide	0.05 (s)

Minimum Requirements on Bacteriological Quality

a) Chlorinated or Otherwise Disinfected Supplies

Efficient treatment culminating in chlorination or some other form of disinfection should yield a water free of any coliform organism however polluted the original raw water may have been. In practice it should not be possible to demonstrate the presence of coliform organisms in any sample of 100ml. The efficacy of the purification process and method of sampling should be looked into when a sample of the water entering the distribution system does not conform to this standard. In testing chlorinated water, presumptive positive tubes should always be subjected to appropriate confirmatory tests.

b) Non-disinfected Supplies

Where supplies of this sort exist, no water entering the distribution system should be considered satisfactory if it yields E coli in 100ml. If E. coli is absent, the presence of not more than 3 coliform organisms per 100ml may be tolerated in occasional samples from established non-disinfected pipes supplies, provided that they have been regularly and frequently tested and that the catchment area and storage conditions are found to be satisfactory. If repeated samples show the presence of coliform organisms, steps should then be taken to discover and, if possible, remove the source of pollution. If the number of coliform organisms increases to more than 3 per 100ml, the supply should be considered unsuitable for use without disinfection.

c) Individual or Small Community Supplies

Where supply of waters are individual wells, bores and springs everything possible should be done to prevent pollution of the water. It should be possible to reduce the coliform count of water from even a shallow well to less than 10 per 100ml. Persistent failure to achieve this, particularly if E. coli is repeatedly found, should, as a general rule lead to chlorination or boiling of the water for domestic consumption.

* All units are in mg/l unless otherwise stated.

** (s) - Secondary standards; compliance with the standard and analysis are not obligatory.

APPENDIX 7.2.1 Data on the Unit Cost for Estimation of Project Cost

(1) Deep Well Construction : Peso

Depth (m)	Casing size (m/m)	Cost
200	250	940,000
200	300	1,160,000
250	150	640,000

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	17	-	-	-	20	37
Civil Works	33	8	5	-	17	63
Total	50	8	5	-	37	100

(2) Deep Well Pump Station (Electric Motor Drive) : Thousand Peso

KW	Cost
7	450
15	560
22	640
29	720
37	790
44	840
51	890
59	960
66	1,020
74	1,080

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	9	-	-	42	5	56
Civil Works	21	9	5	-	9	44
Total	30	9	5	42	14	100

(3) Booster Pump Station

$$C = (72.16 - 13.68 \log Q) \times Q^{(0.42 + 0.1 \log Q)} \\ \times H^{0.305(\log Q - 0.7)} \quad (6/H - 0.25)$$

where,

C = cost for electric motor drive (thousand peso)

Q = design capacity (l/sec)

H = total dynamic head (m)

BREAKDOWN OF COSTS IN %

Material	Local Component		F E C		Total	
	Labor		Direct	Indirect		
	Skilled	Unskilled				
Equipment	11	-	53	2	66	
Civil Works	17	9	6	-	34	
Total	28	9	6	53	4	100

(4) Pipeline Cost

Following pipe materials are presently available in the Philippines:

- GI (galvanized iron),
- PE (poly-ethylene),
- PB (poly-butylene),
- PVC (poly-vinyl-chloride),
- SP (steep pipe),
- CI (cast iron), and
- AC (asbestos cement).

Among these materials, the use of CI pipe is limited due to its high cost and AC pipe is also rare by safety reason.

Followings are comparison of unit cost at the 1985 price level.

Diameter	(Unit: ₱/m)				
	GI	PE	PB	PVC	SP
13	20.8	13.8	9.1	-	-
19	24.7	19.9	13.6	-	-
25	32.3	25.3	22.0	-	-
38	59.2	41.5	44.7	-	-
50	87.5	61.4	76.4	33.9	-
63	117.7	-	-	48.0	-
75	180.3	-	-	81.3	-
100	230.8	-	-	122.4	235.0
150	-	-	-	256.9	250.0
200	-	-	-	506.5	290.0
250	-	-	-	-	315.0
300	-	-	-	-	425.0
400	-	-	-	-	520.0
500	-	-	-	-	700.0
600	-	-	-	-	890.0

Based on the above comparison, SP is advantageous for the diameter of 200 mm and above than PVC. Thus, for the cost estimates of major transmission and distribution pipes, SP is considered for diameter of 200 mm and above, while PVC for diameter of less than 150 mm taking into account the transportation cost and easy installation.

Diameter (mm)	Unit Cost (₱/m)
150 (PVC)	410
200 (SP)	520
250 (")	630
300 (")	760
350 (")	900
400 (")	970
450 (")	1,160
500 (")	1,330
600 (")	1,600
700 (")	1,910

Source : LWUA Design Depart

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	23	-	-	4	27	54
Civil Works	17	7	4	-	18	46
Total	40	7	4	4	45	100

(5) Valve In-place Cost

Diameter (mm)	Gate Valve (₹)	Butterfly Valve (₹)
50	1,700	-
75	2,900	-
100	3,900	-
150	5,300	-
200	6,700	-
250	11,200	-
300	-	34,800
350	-	74,400
400	-	95,200
450	-	125,900
500	-	174,000
600	-	243,600
700	-	313,200

Source : LWUA Design Depart

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	9	-	-	63	5	77
Civil Works	12	3	6	-	2	23
Total	21	3	6	63	7	100

(6) Internal Network

Population Density (Person/ha)	Total Length of Pipeline (m/ha)	Unit Cost (₱/ha)	
		Diameter (100/150)	Diameter (75/100)
50	64	18,300	14,900
60	67	19,300	15,700
75	72	20,900	16,800
100	80	23,100	18,700
150	90	25,700	21,000
200	100	28,300	-
250	108	30,400	-
300	116	32,500	-

BREAKDOWN OF COSTS IN %

	Material	Local Component		F E C		Total
		Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	22	-	-	7	27	56
Civil Works	17	7	4	-	16	44
Total	39	7	4	7	43	100

(7) In-place of Service Connections

Diameter (inch)	Without Meter ₱/unit	With Meter ₱/unit	Meters ₱/unit
1/2	450	810	400
5/8 - 3/4	520	1,280	880

SERVICE CONNECTION WITHOUT METER

BREAKDOWN OF COSTS IN %

	Material	Local Component		F E C		Total
		Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	9	-	-	60	2.5	71.5
Civil Works	17	3	6	-	2.5	28.5
Total	26	3	6	60	5	100

SERVICE CONNECTION WITHOUT METER
BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	4	-	-	83	2	89
Civil Works	6	1	3	-	1	11
Total	10	1	3	83	3	100

(8) Fire Hydrant In-place Cost

<u>Type</u>	<u>Size (mm)</u>	<u>Unit Cost (₱)</u>
Commercial	150	16,800
Residential	100	9,400

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	8	-	-	57	5	70
Civil Works	10	8	10	-	2	30
Total	18	8	10	57	7	100

(9) Elevated Tank/Ground Reservoir

Elevated Tank: $C = 0.615 H^{1.144} V^{0.749}$

Ground Reservoir: $C = 20.05 V^{0.639}$

where, C = cost (thousand peso)

H = overflow elevation above ground level

V = storage volume (cu.m)

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	4	-	-	3	2	9
Civil Works	53	5	7	-	26	91
Total	57	5	7	3	28	100

(10) Gas Chlorinator In-place Cost

Type	Water Flow Condition	Maximum Chlorine Feed (kg/day)	Unit cost ^{1/} (₹)
I-A	constant	22	98,100
I-B	constant	45	119,100
II-A	Variable	22	147,700
II-B	Variable	45	169,300

^{1/} Empty gas cylinders and automatic switchover include

TYPE I-A, I-B
BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	15	-	-	41	5	61
Civil Works	25	6	3	-	5	39
Total	40	6	3	41	10	100

TYPE II-A, II-B
BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	21	-	-	53	2	76
Civil Works	12	6	2	-	4	24
Total	33	6	2	53	6	100

(11) Administration & Operation Building

Future Service Population	Administration Bldg. (Thousand Peso)	Operation Center (Thousand Peso)
30,000	1,000	810
40,000	1,110	890
50,000	1,220	990
60,000	1,320	1,090
70,000	1,410	1,180
80,000	1,500	1,280
100,000	1,610	1,380
110,000	1,820	1,590

ADMINISTRATION BUILDING
BREAKDOWN OF COSTS IN %

	Material	Local Component		F E C		Total
		Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	20	-	-	-	16	36
Civil Works	42	7	5	-	10	64
Total	62	7	5	-	26	100

OPERATION CENTER
BREAKDOWN OF COSTS IN %

	Material	Local Component		F E C		Total
		Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	14	-	-	30	6	50
Civil Works	26	10	5	-	9	50
Total	40	10	5	30	15	100

(12) Energy Cost

$$C = N_p (h) (P_u) (E_m)^{-1}$$

where,

- C = cost (thousand peso)
- N_p = pump power demand (kw)
- h = hours of operation
- P_u = unit power cost (₱/kWh)
- E_m = motor efficiency (0.85)

(13) Chemical Cost

$$C = (\text{Annual Water Demand}) \cdot D \cdot U_{CL} \times 10^{-3}$$

where,

C = annual cost for chlorine (₱)

D = chlorine dosage (mg/l)

U_{CL} = unit cost of chlorine gas (₱/kg)

(14) Minimum Cost Diameter

Following cost function is applied to determine the most economical diameter of pipelines that are not simulated by the network analysis.

$$D_{min.} = 187.7 Q^{0.486} C^{-0.315} (E_c/O_e)^{0.17}$$

where,

$D_{min.}$ = minimum cost diameter

Q = water flow (l/sec)

C = "C" value (Hazen William Formula)

E_c = energy cost (₱/kwh)

O_e = overall efficiency

F. COST COMPARISON

General

Analysis and evaluation of alternative are based largely on present-worth cost studies, taking into consideration the salvage value after the design period. Cost comparison is based on present worth of net disbursement during the period of 1980-2010 without any escalation factor applied to the 1980 unit prices.

If the differences between net PW cost of an alternative and that of the least-cost alternative is within the limit of cost estimating accuracy (10-15%) further cost comparison shall be made applying escalation factor to 1980 unit prices. For escalation rates, refer to Chapter VII-C: Escalation Rates. Moreover, non-economic parameters may also be influence the selection of the recommended plan.

Construction Cost

Construction cost estimates of the proposed improvements are based on the projected July 1980 unit prices. All estimates on imported materials are based on an exchange rate of ₱7.40 per 1 US dollar. Further, it is assumed that no custom duty will be charged on items imported for the public water supply project. The cost of any facility to be replaced during the design period (1980-2010) is included under the capital cost for the particular year.

Annual Cost

Annual costs are all costs associated with the maintenance, operation, and management of the project. These include labor, power, chemical and maintenance costs. These estimates are carried out for the period 1980-2010. The present-worth cost of annual expenditure is based on uniform and gradient series at a given interest.

Personnel and maintenance costs may abruptly increase as additional facilities are put into operation - e.g., the power cost at a pump station increases in relation to the daily pumpage of water.

Salvage Value

The salvage values of facilities at the end of the design period 2010 are important in calculating net present worth of the total expenditures. It is assumed that the value of a facility depreciates linearly throughout its service life therefore, a facility with longer service life depreciates less than a facility with shorter service life (Refer to Table VI-1 for service life of different facilities). Moreover, a facility constructed at a later stage has higher salvage value than one constructed at an earlier stage.

TABLE VI-1

SERVICE LIFE CATEGORIES OF FACILITIES

Civil Works	Economic Life	Equipment	Economic Life
Wells	30 years	Wells (pumping engine or motors)	15 years
Springs	50	Springs (vales, pipes)	50
Transmission Mains	50	Transmission (pipes, valves)	50
Storage Facilities	50	Storage (valves, pipes, level gauge, etc.)	50
Disinfection Facilities	50	Disinfection facilities (chlorinators, mech-	
Distribution Mains	50	anical equipment and filter equipment,	
Internal Network	50	pipes, valves)	15
Service Connections	50	Distribution mains (pipes, valves)	50
Fire Hydrants	50	Internal networks (pipes, valves)	50
Operational Buildings	50	Service connections (meters, pipes)	50
		Operational buildings (workshop, etc.)	15
		Fire hydrants	30
		Vehicles	7

Net Present Worth

The net present worth cost of an alternative scheme is the difference between the total present worth of capital cost and annual cost minus the present worth of salvage values.

For Construction Cost:

$$C_n = C_c - C_s$$

$$C_c = C \times \frac{1}{(1+i)^n}$$

$$C_c = C \times \frac{1}{(1+i)^{nx}} \times \left(1 - \frac{nx - n}{SL}\right)$$

For Annual Cost:

$$C_c = A_c \times \frac{1}{(1+i)^n}$$

where,

C_n = net present worth comparable cost

C_c = present worth of construction cost

C_s = present worth of salvage value (design year)

C = construction cost

SL = service life

i = discount rate

nx = number of years between design year and base year

n = number of years between year of construction and base year

A_c = annual cost

APPENDIX 7.3.1 Cost Estimates of Water Source Alternatives

(Unit : ₪1,000)


Required Facilities	Unit Cost (₪)		Alternative S-1		Alternative S-2		Alternative S-3	
	Q'ty	Cost	Q'ty	Cost	Q'ty	Cost	Q'ty	Cost
Water Sources								
Deep Well	18	940,000	11	16,920	11	10,340	-	-
Deep Well Pump	18	640,000	11	11,520	11	7,040	-	-
River Water Intake	-	-	1	-	1	3,694	-	-
Booster Pump (226 l/s, H=25m)	-	-	-	-	-	-	1	8,414
Booster Pump (600 l/s, H=40m)	-	-	-	-	-	-	1	8,414
Sub Total				<u>28,440</u>		<u>21,074</u>		
Transmission Line								
ø200 mm	4,700 m	520	2,700 m	2,444	2,700 m	1,404	-	-
ø250 mm	2,300 m	630	2,300 m	1,449	2,300 m	1,449	-	-
ø300 mm	500 m	760	-	380	-	-	-	-
ø400 mm	500 m	970	-	485	-	-	-	-
ø450 mm	2,800 m	1,160	10,000 m	3,248	10,000 m	16,000	10,000	19,100
ø600 mm	-	1,600	-	-	-	-	-	-
ø700 mm	-	1,910	-	-	-	-	-	-
Sub Total				<u>8,006</u>		<u>18,853</u>		<u>19,100</u>
Treatment Facility								
Slow Sand Filter	-	-	3,900 sq.m	8,190	10,280 sq.m	18,504	-	-
TOTAL CONSTRUCTION COST				<u>36,846</u>		<u>48,117</u>		<u>46,018</u>
Operation & Maintenance (15 years)								
Energy	52,003 MWH	0.30/kWH	44,320 MWH	13,296	52,000 MWH	15,600	-	-
Maintenance	-	-	-	-	-	-	-	-
(10% of Construction Cost)	-	-	-	-	-	-	-	-
TOTAL				<u>3,685</u>		<u>4,812</u>		<u>4,602</u>
GRAND TOTAL				<u>19,295</u>		<u>18,108</u>		<u>20,202</u>
				<u>56,141</u>		<u>66,225</u>		<u>66,220</u>

o List of Computed Cases

Alternative	D-1	(2010)	
	D-2	(2010)	
	D-3	(2010)	Southwest Area
	D-3/D-4	(2010)	Northeast Area
	D-4-A	(1995, 2010)	Southwest Area
	D-4-B	(1995, 2010)	Southwest Area

o Note

This appendix shows the results of Hydraulic Analysis aided by the computer. The distribution network is shown in the figure of following page. The nodes, however, with no flow and 20.00 m in Dynamic Head was treated as a dummy node. Those nodes can be ignored and have no relation to the computation results.



ALTERNATIVE D-1
 Supply System w/2 Reservoirs, Year2010
 << NODES >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
1	1	600	100	130	-26224	-1.07	-0.17
2	2	600	100	130	-26224	-1.07	-0.17
3	3	450	730	120	17698	1.29	3.90
4	4	500	500	120	29591	1.75	6.09
5	5	450	500	120	13518	0.98	2.97
6	6	450	450	120	11428	0.83	1.42
7	7	400	150	120	10020	0.92	0.36
8	8	200	190	110	367	0.14	0.14
9	9	150	180	110	1400	-0.92	-1.59
10	10	350	410	120	10380	1.25	2.03
11	11	150	1020	110	1510	1.05	11.64
12	12	250	1110	120	3850	0.91	4.52
13	13	300	1120	120	5552	0.91	3.99
14	14	250	700	120	3406	0.80	2.26
15	15	350	540	120	9488	-1.14	-2.26
16	16	150	990	110	1050	0.71	5.39
17	17	200	320	110	1243	0.45	0.56
18	18	150	860	110	669	0.44	1.93
19	19	250	350	120	3167	-0.75	-0.99
20	20	200	370	110	1567	-0.59	-0.99
21	21	150	200	110	1500	-1.05	-0.23
22	22	250	490	120	1111	0.26	0.20
23	23	350	430	120	5172	-0.62	-0.58
24	24	150	880	110	941	0.62	3.71
25	25	250	460	120	2270	-0.54	-0.70
26	26	250	150	120	1379	-0.33	-0.09
27	27	200	420	110	2840	1.08	3.50
28	28	170	410	120	220	0.05	0.01
29	29	150	200	110	1600	-1.05	-0.23
30	30	350	260	120	3951	-1.20	-1.19
31	31	150	140	120	9906	-1.19	-0.63
32	32	250	250	120	3665	-0.91	-1.02
33	33	350	500	120	12146	-1.46	-3.31
34	34	200	60	110	5700	-0.99	-0.44
35	35	250	510	120	4030	-0.95	-2.69
36	36	350	660	120	7285	-0.68	-1.69
37	37	150	300	110	3900	-1.90	-10.18
38	38	350	370	120	13378	-1.61	-2.93
39	39	400	360	120	13848	-1.28	-1.58
40	40	450	460	120	15301	-1.29	-1.54
41	41	250	510	120	12340	1.14	2.17
42	42	350	310	120	6050	0.73	0.56
43	43	250	330	120	2420	0.57	0.57
44	44	300	820	120	2420	0.49	0.58
45	45	250	750	120	1210	0.29	0.36
46	46	350	500	120	16397	-1.97	-5.75
47	47	250	300	120	4322	-1.51	-1.53
48	48	350	380	120	5622	-1.33	-1.51
49	49	150	20	110	1300	-0.93	-0.15
50	50	200	480	110	1584	-0.98	-1.31
51	51	350	560	110	6404	-2.36	-20.30
52	52	420	600	120	16687	-2.01	-7.14
53	53	350	1410	120	1210	-0.39	-0.57
54	54	250	500	120	1210	-0.39	-0.57
55	55	250	470	120	580	0.14	0.06

Iteration Times : 20

ALTERNATIVE D-1
 Supply System w/2 Reservoirs, Year2010
 << PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
1	1	600	100	130	-26224	-1.07	-0.17
2	2	600	100	130	-26224	-1.07	-0.17
3	3	450	730	120	17698	1.29	3.90
4	4	500	500	120	29591	1.75	6.09
5	5	450	500	120	13518	0.98	2.97
6	6	450	450	120	11428	0.83	1.42
7	7	400	150	120	10020	0.92	0.36
8	8	200	190	110	367	0.14	0.14
9	9	150	180	110	1400	-0.92	-1.59
10	10	350	410	120	10380	1.25	2.03
11	11	150	1020	110	1510	1.05	11.64
12	12	250	1110	120	3850	0.91	4.52
13	13	300	1120	120	5552	0.91	3.99
14	14	250	700	120	3406	0.80	2.26
15	15	350	540	120	9488	-1.14	-2.26
16	16	150	990	110	1050	0.71	5.39
17	17	200	320	110	1243	0.45	0.56
18	18	150	860	110	669	0.44	1.93
19	19	250	350	120	3167	-0.75	-0.99
20	20	200	370	110	1567	-0.59	-0.99
21	21	150	200	110	1500	-1.05	-0.23
22	22	250	490	120	1111	0.26	0.20
23	23	350	430	120	5172	-0.62	-0.58
24	24	150	880	110	941	0.62	3.71
25	25	250	460	120	2270	-0.54	-0.70
26	26	250	150	120	1379	-0.33	-0.09
27	27	200	420	110	2840	1.08	3.50
28	28	170	410	120	220	0.05	0.01
29	29	150	200	110	1600	-1.05	-0.23
30	30	350	260	120	3951	-1.20	-1.19
31	31	150	140	120	9906	-1.19	-0.63
32	32	250	250	120	3665	-0.91	-1.02
33	33	350	500	120	12146	-1.46	-3.31
34	34	200	60	110	5700	-0.99	-0.44
35	35	250	510	120	4030	-0.95	-2.69
36	36	350	660	120	7285	-0.68	-1.69
37	37	150	300	110	3900	-1.90	-10.18
38	38	350	370	120	13378	-1.61	-2.93
39	39	400	360	120	13848	-1.28	-1.58
40	40	450	460	120	15301	-1.29	-1.54
41	41	250	510	120	12340	1.14	2.17
42	42	350	310	120	6050	0.73	0.56
43	43	250	330	120	2420	0.57	0.57
44	44	300	820	120	2420	0.49	0.58
45	45	250	750	120	1210	0.29	0.36
46	46	350	500	120	16397	-1.97	-5.75
47	47	250	300	120	4322	-1.51	-1.53
48	48	350	380	120	5622	-1.33	-1.51
49	49	150	20	110	1300	-0.93	-0.15
50	50	200	480	110	1584	-0.98	-1.31
51	51	350	560	110	6404	-2.36	-20.30
52	52	420	600	120	16687	-2.01	-7.14
53	53	350	1410	120	1210	-0.39	-0.57
54	54	250	500	120	1210	-0.39	-0.57
55	55	250	470	120	580	0.14	0.06

ALTERNATIVE D-1
 1 Supply System w/2 Reservoirs, Year 2010

<< PIPELINE >>

PIPE No.	NOE No. From	NOE No. to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
56	42	44	300	900	120	1790	0.29	0.35
57	42	50	400	500	120	-19347	-1.78	-4.09
58	43	45	200	1150	110	290	0.11	0.14
59	44	46	200	800	110	290	0.11	0.09

<< NODES >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
1	2	700	100	130	-37550	-1.13	-0.16
2	3	700	100	130	-37650	-1.13	-0.16
3	4	400	730	120	-13324	1.23	2.99
4	5	700	500	130	56916	1.71	2.04
5	6	350	600	120	9144	1.10	3.91
6	7	350	450	120	7054	0.85	2.42
7	8	350	150	120	9195	1.11	3.95
8	9	350	790	120	-3183	0.75	-2.55
9	10	350	180	110	-1400	-0.92	-2.81
10	11	350	410	120	9595	1.05	4.24
11	12	350	1020	110	1510	1.15	11.74
12	13	350	1110	120	3036	0.72	2.90
13	14	350	1120	120	5073	1.20	7.57
14	15	350	700	120	8799	1.05	6.54
15	16	350	540	120	-15225	-1.40	-2.55
16	17	350	990	110	1050	0.71	5.39
17	18	350	320	110	793	0.29	0.70
18	19	350	860	110	435	0.28	0.87
19	20	350	350	110	-3412	-1.25	-3.95
20	21	200	370	110	-1512	-0.57	-1.29
21	22	200	20	110	-1600	-1.05	-1.23
22	23	150	490	120	1841	0.43	0.51
23	24	150	430	110	-254	-0.49	-2.80
24	25	150	890	110	1175	0.77	5.37
25	26	200	450	110	-1175	-0.55	-3.37
26	27	200	150	110	-1355	-0.50	-2.04
27	28	200	420	110	-2470	-0.91	-2.61
28	29	150	410	110	245	0.16	0.14
29	30	150	20	110	-1600	-1.05	-1.23
30	31	350	260	120	-5509	-0.66	-0.40
31	32	350	140	120	-8558	-0.66	-0.40
32	33	350	250	110	-751	-0.50	-0.71
33	34	350	500	120	-10695	-1.30	-2.55
34	35	350	60	110	-2700	-0.98	-3.32
35	36	450	610	120	-21969	-1.60	-3.55
36	37	450	660	120	11991	0.87	1.25
37	38	150	300	110	-2900	-1.90	-10.18
38	39	150	370	120	-19115	-1.75	-2.96
39	40	350	460	120	-19585	-1.43	-2.70
40	41	350	460	120	-25597	-1.51	-4.53
41	42	350	510	120	30219	1.78	3.65
42	43	350	310	120	6950	0.73	3.56
43	44	350	330	110	2420	0.89	1.97
44	45	350	820	120	2420	0.57	1.72
45	46	350	750	110	1210	0.45	1.24
46	47	350	500	120	6001	0.72	0.90
47	48	350	300	110	2501	0.44	0.99
48	49	350	380	120	-2501	-0.59	-1.62
49	50	350	20	110	-1300	-0.85	-1.58
50	51	350	480	110	-1601	-0.59	-1.33
51	52	350	560	120	-571	-2.19	-7.72
52	53	350	600	120	571	0.59	31.53
53	54	300	1410	110	-1210	-0.45	-1.56
54	55	300	500	110	-580	-0.21	-0.20

Iteration Times : 18

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
1	2	700	100	130	-37550	-1.13	-0.16
2	3	700	100	130	-37650	-1.13	-0.16
3	4	400	730	120	-13324	1.23	2.99
4	5	700	500	130	56916	1.71	2.04
5	6	350	600	120	9144	1.10	3.91
6	7	350	450	120	7054	0.85	2.42
7	8	350	150	120	9195	1.11	3.95
8	9	350	790	120	-3183	0.75	-2.55
9	10	350	180	110	-1400	-0.92	-2.81
10	11	350	410	120	9595	1.05	4.24
11	12	350	1020	110	1510	1.15	11.74
12	13	350	1110	120	3036	0.72	2.90
13	14	350	1120	120	5073	1.20	7.57
14	15	350	700	120	8799	1.05	6.54
15	16	350	540	120	-15225	-1.40	-2.55
16	17	350	990	110	1050	0.71	5.39
17	18	350	320	110	793	0.29	0.70
18	19	350	860	110	435	0.28	0.87
19	20	350	350	110	-3412	-1.25	-3.95
20	21	200	370	110	-1512	-0.57	-1.29
21	22	200	20	110	-1600	-1.05	-1.23
22	23	150	490	120	1841	0.43	0.51
23	24	150	430	110	-254	-0.49	-2.80
24	25	150	890	110	1175	0.77	5.37
25	26	200	450	110	-1175	-0.55	-3.37
26	27	200	150	110	-1355	-0.50	-2.04
27	28	200	420	110	-2470	-0.91	-2.61
28	29	150	410	110	245	0.16	0.14
29	30	150	20	110	-1600	-1.05	-1.23
30	31	350	260	120	-5509	-0.66	-0.40
31	32	350	140	120	-8558	-0.66	-0.40
32	33	350	250	110	-751	-0.50	-0.71
33	34	350	500	120	-10695	-1.30	-2.55
34	35	350	60	110	-2700	-0.98	-3.32
35	36	450	610	120	-21969	-1.60	-3.55
36	37	450	660	120	11991	0.87	1.25
37	38	150	300	110	-2900	-1.90	-10.18
38	39	150	370	120	-19115	-1.75	-2.96
39	40	350	460	120	-19585	-1.43	-2.70
40	41	350	460	120	-25597	-1.51	-4.53
41	42	350	510	120	30219	1.78	3.65
42	43	350	310	120	6950	0.73	3.56
43	44	350	330	110	2420	0.89	1.97
44	45	350	820	120	2420	0.57	1.72
45	46	350	750	110	1210	0.45	1.24
46	47	350	500	120	6001	0.72	0.90
47	48	350	300	110	2501	0.44	0.99
48	49	350	380	120	-2501	-0.59	-1.62
49	50	350	20	110	-1300	-0.85	-1.58
50	51	350	480	110	-1601	-0.59	-1.33
51	52	350	560	120	-571	-2.19	-7.72
52	53	350	600	120	571	0.59	31.53
53	54	300	1410	110	-1210	-0.45	-1.56
54	55	300	500	110	-580	-0.21	-0.20

ALTERNATIVE D-2
 1 Supply System w/1 Reservoir, Year2010

<< PIPELINE >>

PIPE No.	NODE from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
56	42 44	200	900	120	1790	0.66	2.62
57	42 50	350	500	120	3051	0.37	0.26
58	42 51	350	600	120	-5711	-0.69	-0.98
59	43 45	150	1150	110	290	0.19	0.55
60	44 46	150	600	110	290	0.19	0.38

ALTERNATIVE D-3
 2 Supply Systems w/3 Reservoirs, Southwest Area, Year2010
 << NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	120.00	0.00	120.00	0.00	10.00
2	85.00	5050.00	119.84	34.84	45.00
3	78.00	4180.00	117.05	38.05	52.00
4	77.00	2090.00	115.58	38.58	53.00
5	81.00	1040.00	114.56	33.56	49.00
6	81.00	1040.00	116.15	36.15	50.00
7	80.00	4910.00	112.53	30.53	48.00
8	82.00	4390.00	108.01	25.01	47.00
9	83.00	3230.00	104.29	27.29	53.00
10	77.00	3740.00	103.71	23.71	50.00
11	80.00	0.00	104.69	21.68	47.00
12	83.00	5900.00	105.64	17.64	42.00
13	88.00	2440.00	105.43	14.43	39.00
14	91.00	2050.00	106.12	12.12	36.00
15	94.00	0.00	106.21	12.21	36.00
16	94.00	5000.00	106.20	14.20	38.00
17	92.00	3820.00	107.37	14.37	37.00
18	93.00	2240.00	108.00	16.00	38.00
19	92.00	1870.00	111.31	18.31	37.00
20	93.00	6790.00	110.32	23.32	43.00
21	85.00	2900.00	120.50	35.50	45.00
22	87.00	410.00	113.29	26.29	43.00
23	87.00	2820.00	114.59	27.59	43.00
24	87.00	1050.00	116.50	28.50	42.00
25	93.00	2700.00	117.75	18.75	37.00
26	94.00	2260.00	114.67	20.67	36.00
27	94.00	1210.00	114.55	20.65	36.00
28	95.00	1210.00	114.89	19.89	35.00
29	92.00	1210.00	113.73	11.73	28.00
30	97.00	4790.00	112.74	15.74	33.00
31	93.00	0.00	111.31	18.31	37.00
32	94.00	3340.00	108.34	14.34	36.00
33	98.00	1880.00	109.68	11.68	32.00
34	98.00	290.00	118.91	17.91	28.00
35	101.00	1610.00	101.75	17.75	46.00
36	84.00	1080.00	98.90	28.90	60.00
37	70.00	1610.00	100.90	30.90	60.00
38	88.00	0.00	108.00	20.00	42.00
39	88.00	0.00	122.00	20.00	28.00
40	102.00	0.00	131.00	20.00	15.00
41	111.00	0.00	121.00	20.00	23.00
42	107.00	0.00	121.00	20.00	20.00
43	110.00	0.00	130.00	20.00	20.00
44	115.00	0.00	135.00	20.00	15.00
45	118.00	0.00	138.00	20.00	12.00
46	117.00	0.00	137.00	20.00	12.00
47	94.00	-1600.00	106.44	12.44	36.00
48	83.00	-1500.00	104.90	21.90	47.00
49	93.00	-1300.00	111.47	18.47	37.00
50	130.00	0.00	130.00	0.00	0.00

Iteration Times : 19

ALTERNATIVE D-3
 2 Supply Systems w/3 Reservoirs, Southwest Area, Year2010
 << PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
1	1 2	600	100	130	-25400	-1.04	-0.16
2	1 3	600	100	130	-25400	-1.04	-0.16
3	2 3	450	730	120	17473	1.27	2.78
4	2 4	500	600	120	25261	1.67	3.81
5	3 4	450	600	120	13293	0.97	1.38
6	4 5	450	450	120	11203	0.82	0.75
7	5 6	400	150	120	10022	0.92	0.36
8	6 7	200	790	110	141	0.05	0.02
9	7 8	150	180	110	-1400	-0.92	-1.59
10	8 9	350	410	120	10382	1.25	2.03
11	8 10	150	1020	110	1610	1.05	11.64
12	9 10	250	1110	120	3862	0.91	4.53
13	9 11	300	1120	120	5583	0.91	3.72
14	10 11	250	700	120	3492	0.82	2.37
15	10 12	350	540	120	-9603	-1.16	-2.31
16	11 12	150	990	110	1080	0.71	5.35
17	11 13	200	320	110	1273	0.47	0.58
18	11 14	150	860	110	674	0.44	1.95
19	12 13	250	350	120	-3141	-0.74	-0.97
20	12 14	200	370	110	-4541	-0.57	-2.59
21	12 15	150	20	110	-1500	-1.05	-0.23
22	13 14	250	490	120	1129	0.27	0.42
23	13 15	350	430	120	-5077	-0.51	-1.31
24	14 15	150	936	110	936	0.91	3.68
25	14 16	250	450	120	-2248	-0.53	-0.69
26	15 16	250	150	120	-1375	-0.32	-0.60
27	15 17	340	420	110	-2922	-1.08	-3.56
28	16 17	250	410	120	224	0.01	0.02
29	16 18	150	20	110	-1600	-1.05	-0.23
30	17 18	350	260	120	-9652	-1.19	-4.49
31	18 19	350	140	120	-9913	-1.19	-4.54
32	18 20	250	250	120	-3759	-0.89	-0.97
33	19 20	350	500	120	-12153	-1.45	-6.62
34	20 21	200	60	110	-2700	-0.95	-0.44
35	20 22	250	610	120	-4555	-1.10	-5.83
36	20 23	350	550	120	-6638	-0.80	-1.43
37	21 22	150	300	110	-2500	-1.90	-10.78
38	21 23	350	370	120	-13493	-1.62	-8.03
39	23 24	400	350	120	-13953	-1.29	-4.47
40	24 25	450	450	120	-16642	-1.21	-1.60
41	25 26	300	300	120	10575	0.97	1.63
42	27 28	350	310	120	3550	0.44	0.22
43	28 29	350	330	120	2420	0.57	0.57
44	29 30	350	750	120	1210	0.29	0.36
45	31 32	350	500	120	-15622	-1.86	-5.27
46	31 33	350	300	120	4193	0.99	1.42
47	32 33	350	380	120	5493	1.20	2.98
48	32 34	150	20	110	-1300	-0.85	-0.15
49	33 34	200	480	110	-1605	-0.59	-1.34
50	34 35	200	560	110	-6408	-0.36	-2.60
51	35 50	350	1100	120	-15912	-1.91	-11.99

ALTERNATIVE D-3, D-4(Recommended Plan):-A(Single P.):-B(Parallel P.)
 2 Supply Systems w/2 or 3 Reservoirs, Northeast Area, Year2010

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	120.00	0.00	140.00	20.00	10.00
2	85.00	0.00	105.00	20.00	45.00
3	78.00	0.00	98.00	20.00	52.00
4	77.00	0.00	97.00	20.00	53.00
5	81.00	0.00	101.00	20.00	49.00
6	80.00	0.00	100.00	20.00	50.00
7	82.00	0.00	102.00	20.00	48.00
8	83.00	0.00	103.00	20.00	47.00
9	77.00	0.00	97.00	20.00	53.00
10	80.00	0.00	100.00	20.00	50.00
11	83.00	0.00	103.00	20.00	47.00
12	86.00	0.00	106.00	20.00	44.00
13	96.00	0.00	116.00	20.00	34.00
14	91.00	0.00	111.00	20.00	39.00
15	94.00	0.00	114.00	20.00	36.00
16	94.00	0.00	114.00	20.00	36.00
17	92.00	0.00	112.00	20.00	38.00
18	93.00	0.00	113.00	20.00	37.00
19	92.00	0.00	112.00	20.00	38.00
20	93.00	0.00	113.00	20.00	37.00
21	97.00	0.00	117.00	20.00	33.00
22	85.00	0.00	105.00	20.00	45.00
23	87.00	0.00	107.00	20.00	43.00
24	87.00	0.00	107.00	20.00	43.00
25	88.00	0.00	108.00	20.00	42.00
26	92.00	0.00	112.00	20.00	38.00
27	94.00	0.00	114.00	20.00	36.00
28	94.00	0.00	114.00	20.00	36.00
29	95.00	0.00	115.00	20.00	35.00
30	102.00	0.00	122.00	20.00	28.00
31	97.00	0.00	117.00	20.00	33.00
32	93.00	0.00	113.00	20.00	37.00
33	94.00	0.00	114.00	20.00	36.00
34	98.00	0.00	118.00	20.00	32.00
35	101.00	0.00	121.00	20.00	29.00
36	84.00	0.00	104.00	20.00	46.00
37	70.00	0.00	90.00	20.00	60.00
38	70.00	0.00	90.00	20.00	60.00
39	88.00	1210.00	111.25	23.25	42.00
40	102.00	1210.00	120.73	18.73	28.00
41	111.00	1210.00	120.80	9.80	18.00
42	107.00	290.00	120.94	13.94	23.00
43	110.00	290.00	121.71	11.41	20.00
44	115.00	290.00	124.25	9.25	15.00
45	116.00	290.00	125.93	11.93	12.00
46	117.00	290.00	125.93	9.63	13.00
47	94.00	0.00	114.00	20.00	36.00
48	83.00	0.00	103.00	20.00	47.00
49	93.00	0.00	113.00	20.00	37.00
50	130.00	0.00	150.00	20.00	0.00
51	130.00	0.00	150.00	20.00	0.00

Iteration Times : 21

ALTERNATIVE D-3, D-4(Recommended Plan):-A(Single P.):-B(Parallel P.)
 2 Supply Systems w/2 or 3 Reservoirs, Northeast Area, Year2010

<< PIPELINE >>

PIPE No.	NODE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
1	39 40	150.	1410.	110.	-1210.	-0.79	-9.48
2	40 46	200.	1000.	110.	-2402.	-0.88	-5.90
3	40 41	75.	800.	110.	-18.	-0.05	-0.06
4	41 44	150.	500.	110.	-1228.	-0.80	-3.45
5	42 43	100.	470.	110.	-149.	-0.22	-0.47
6	42 44	75.	900.	110.	-141.	-0.37	-3.67
7	43 45	100.	1150.	110.	-439.	-0.65	-8.52
8	44 46	200.	800.	110.	-1659.	-0.61	-2.39
9	45 51	250.	10.	120.	-5080.	-1.20	-6.77
10	45 46	250.	650.	120.	4351.	1.03	3.31

ALTERNATIVE D-4-A (Recommended Plan, Single Pipeline Alignment)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year1995

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	120.00	0.00	120.00	0.00	0.00
2	85.00	1850.00	119.86	34.86	35.00
3	78.00	2900.00	119.36	41.36	42.00
4	77.00	1300.00	119.19	42.19	43.00
5	81.00	1050.00	119.16	38.16	39.00
6	81.00	650.00	119.15	38.15	39.00
7	80.00	-1400.00	120.75	40.75	40.00
8	82.00	650.00	119.15	37.15	38.00
9	83.00	2250.00	116.94	33.94	37.00
10	80.00	1080.00	109.63	32.63	43.00
11	80.00	2080.00	111.38	31.38	40.00
12	83.00	0.00	114.81	31.81	37.00
13	86.00	4180.00	115.79	27.79	32.00
14	91.00	1580.00	105.50	14.60	29.00
15	94.00	1040.00	108.88	14.88	26.00
16	94.00	0.00	109.59	15.59	26.00
17	92.00	3340.00	114.05	22.05	28.00
18	93.00	2120.00	114.25	21.25	27.00
19	92.00	1750.00	114.57	22.57	28.00
20	92.00	1580.00	115.27	23.27	27.00
21	87.00	3600.00	117.60	30.60	33.00
22	85.00	-2900.00	127.98	42.98	35.00
23	87.00	250.00	118.49	31.49	33.00
24	85.00	1850.00	118.88	31.88	32.00
25	85.00	850.00	119.31	31.31	32.00
26	93.00	-2700.00	116.71	23.71	27.00
27	94.00	1800.00	117.25	23.25	26.00
28	94.00	2000.00	116.14	22.14	26.00
29	95.00	1200.00	114.20	19.20	25.00
30	102.00	1300.00	112.98	10.98	18.00
31	97.00	3380.00	116.14	19.14	23.00
32	93.00	0.00	109.83	16.83	27.00
33	94.00	2020.00	109.63	16.63	26.00
34	98.00	1340.00	109.59	11.99	22.00
35	101.00	0.00	121.00	20.00	19.00
36	84.00	1080.00	100.81	16.81	36.00
37	70.00	0.00	90.00	20.00	50.00
38	70.00	0.00	108.00	20.00	50.00
39	88.00	0.00	108.00	20.00	32.00
40	102.00	0.00	122.00	20.00	18.00
41	111.00	0.00	131.00	20.00	9.00
42	107.00	0.00	127.00	20.00	13.00
43	110.00	0.00	130.00	20.00	10.00
44	115.00	0.00	135.00	20.00	5.00
45	118.00	0.00	138.00	20.00	2.00
46	117.00	0.00	137.00	20.00	3.00
47	94.00	-1800.00	109.82	15.82	26.00
48	83.00	-1600.00	115.03	32.03	37.00
49	83.00	-1300.00	109.99	16.99	27.00
50	105.00	-2900.00	114.67	9.67	15.00

Iteration Times : 36

ALTERNATIVE D-4-A (Recommended Plan, Single Pipeline Alignment)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year1995

<< PIPELINE >>

PIPE No.	NODE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
1	2	700	100	130	-34958	-1.05	-0.14
2	3	400	730	120	5108	0.47	0.51
3	25	700	500	130	28000	0.84	0.92
4	3	350	500	120	2287	0.27	0.28
5	4	350	450	120	907	0.11	0.02
6	5	350	150	120	-99	-0.01	0.00
7	6	150	160	110	-1400	-0.92	-8.81
8	6	350	410	120	650	0.08	0.03
9	13	350	700	120	5740	0.69	1.55
10	9	400	540	120	-7980	-0.74	-0.66
11	10	150	320	110	-1080	-0.71	-1.74
12	11	200	350	110	-3160	-1.16	-3.43
13	12	200	370	110	-1560	-0.57	-2.65
14	12	48	150	20	-1600	-1.05	-0.23
15	14	35	80	110	1080	0.71	1.28
16	15	150	480	110	-2650	-0.93	-3.28
17	15	200	150	110	-2140	-0.79	-4.78
18	15	200	150	110	-1560	-0.57	-4.78
19	15	17	410	110	-540	-0.80	-10.87
20	17	150	260	120	-1600	-1.05	-0.23
21	17	18	140	120	-3880	-0.47	-1.28
22	18	19	250	120	-6720	-0.81	-2.21
23	18	33	100	120	720	1.05	4.63
24	19	20	350	120	-8700	-1.02	-3.41
25	19	20	200	110	-2100	-0.59	-0.44
26	20	27	450	120	-10960	-0.80	-1.61
27	20	31	450	120	-3580	-0.26	0.13
28	21	22	150	300	-2300	-1.90	-10.18
29	21	22	400	120	-5690	-0.60	-33.93
30	21	23	370	120	-5690	-0.60	-1.10
31	23	24	450	120	-10790	-0.65	-0.40
32	24	25	500	120	-1790	-0.54	-0.43
33	25	27	450	120	-16360	-1.19	-2.05
34	27	28	250	120	-3800	-0.85	1.11
35	28	29	200	110	-2400	-0.88	1.94
36	29	30	200	110	1200	0.44	1.22
37	30	32	250	120	1300	0.31	0.21
38	32	33	150	110	-1300	-0.85	-0.15
39	32	34	200	110	-2300	-1.07	-4.68

ALTERNATIVE D-4-A (Recommended Plan, Single Pipeline Alignment)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year2010

<< NODES >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0.00)
1	1	700	100	130	-35107	-1.06	-0.14
2	2	700	100	130	-35107	-1.06	-0.14
3	3	400	730	120	13251	1.22	2.96
4	2	700	600	130	51894	1.56	4.06
5	3	350	600	120	9081	1.09	1.72
6	4	350	450	120	6991	0.84	2.31
7	5	350	150	120	9260	1.11	3.86
8	6	250	790	120	-3309	-0.78	1.07
9	5	150	180	110	-1400	-0.92	2.38
10	7	350	410	120	9620	1.16	4.00
11	8	350	1020	110	1610	1.05	3.06
12	9	250	1110	120	3100	0.73	1.75
13	10	250	1120	120	5026	1.19	4.29
14	9	350	700	120	9296	1.12	3.01
15	13	400	540	120	-15612	-1.44	7.44
16	10	150	990	110	1090	0.71	6.64
17	11	150	320	110	716	0.71	2.87
18	11	150	350	110	442	0.71	5.39
19	12	200	350	110	-3465	-1.28	5.45
20	12	200	370	110	-1865	-0.99	2.04
21	13	150	20	110	-1500	-1.37	11.62
22	13	150	430	120	227	0.55	3.66
23	14	150	250	110	766	0.72	1.28
24	14	150	880	110	1168	0.71	1.60
25	15	200	460	110	-1281	-0.47	3.30
26	15	200	150	110	-1806	-0.57	5.55
27	16	200	420	110	-1525	-0.56	1.84
28	16	150	410	110	-205	-0.30	3.48
29	17	150	20	110	-1500	-1.05	1.07
30	17	150	260	120	-6001	-0.72	2.54
31	18	100	140	120	-9656	-1.19	0.75
32	18	100	250	110	46	0.07	1.38
33	19	250	500	120	-12106	-1.46	4.47
34	20	200	60	110	-2700	-0.99	1.50
35	20	200	610	120	-18854	-1.37	6.57
36	21	150	660	120	7579	0.55	4.33
37	21	150	300	110	-2900	-1.90	2.68
38	21	150	370	120	-19502	-1.90	0.54
39	22	450	360	120	-19972	-1.00	0.16
40	23	500	460	120	-26101	-1.45	3.93
41	23	450	610	120	24744	1.54	6.29
42	27	450	310	120	3630	1.80	4.88
43	28	200	750	110	1210	0.85	1.21
44	29	200	300	110	220	0.45	4.43
45	31	150	300	110	290	0.45	3.54
46	31	150	300	110	290	0.45	5.93
47	32	250	350	120	2459	0.75	1.44
48	32	250	350	120	3800	0.92	1.56
49	33	150	20	110	-1300	-0.86	0.34
50	33	150	480	110	505	0.33	1.90
51	34	200	560	110	-2900	-1.07	3.95
52	34	200	560	110	-2900	-1.07	1.68
53	34	200	560	110	-2900	-1.07	4.68
54	34	200	560	110	-2900	-1.07	6

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0.00)
1	1	700	100	130	-35107	-1.06	-0.14
2	2	700	100	130	-35107	-1.06	-0.14
3	3	400	730	120	13251	1.22	2.96
4	2	700	600	130	51894	1.56	4.06
5	3	350	600	120	9081	1.09	1.72
6	4	350	450	120	6991	0.84	2.31
7	5	350	150	120	9260	1.11	3.86
8	6	250	790	120	-3309	-0.78	1.07
9	5	150	180	110	-1400	-0.92	2.38
10	7	350	410	120	9620	1.16	4.00
11	8	350	1020	110	1610	1.05	3.06
12	9	250	1110	120	3100	0.73	1.75
13	10	250	1120	120	5026	1.19	4.29
14	9	350	700	120	9296	1.12	3.01
15	13	400	540	120	-15612	-1.44	7.44
16	10	150	990	110	1090	0.71	6.64
17	11	150	320	110	716	0.71	2.87
18	11	150	350	110	442	0.71	5.39
19	12	200	350	110	-3465	-1.28	5.45
20	12	200	370	110	-1865	-0.99	2.04
21	13	150	20	110	-1500	-1.37	11.62
22	13	150	430	120	227	0.55	3.66
23	14	150	250	110	766	0.72	1.28
24	14	150	880	110	1168	0.71	1.60
25	15	200	460	110	-1281	-0.47	3.30
26	15	200	150	110	-1806	-0.57	5.55
27	16	200	420	110	-1525	-0.56	1.84
28	16	150	410	110	-205	-0.30	3.48
29	17	150	20	110	-1500	-1.05	1.07
30	17	150	260	120	-6001	-0.72	2.54
31	18	100	140	120	-9656	-1.19	0.75
32	18	100	250	110	46	0.07	1.38
33	19	250	500	120	-12106	-1.46	4.47
34	20	200	60	110	-2700	-0.99	1.50
35	20	200	610	120	-18854	-1.37	6.57
36	21	150	660	120	7579	0.55	4.33
37	21	150	300	110	-2900	-1.90	2.68
38	21	150	370	120	-19502	-1.90	0.54
39	22	450	360	120	-19972	-1.00	0.16
40	23	500	460	120	-26101	-1.45	3.93
41	23	450	610	120	24744	1.54	6.29
42	27	450	310	120	3630	1.80	4.88
43	28	200	750	110	1210	0.85	1.21
44	29	200	300	110	220	0.45	4.43
45	31	150	300	110	290	0.45	3.54
46	31	150	300	110	290	0.45	5.93
47	32	250	350	120	2459	0.75	1.44
48	32	250	350	120	3800	0.92	1.56
49	33	150	20	110	-1300	-0.86	0.34
50	33	150	480	110	505	0.33	1.90
51	34	200	560	110	-2900	-1.07	3.95
52	34	200	560	110	-2900	-1.07	1.68
53	34	200	560	110	-2900	-1.07	4.68
54	34	200	560	110	-2900	-1.07	6

Iteration Times : 19

ALTERNATIVE D-4-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year 1995

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu.m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	120.00	0.00	120.00	0.00	0.00
2	85.00	1850.00	119.86	34.86	35.00
3	78.00	2900.00	114.76	36.76	42.00
4	77.00	1300.00	111.58	34.58	43.00
5	81.00	1000.00	111.09	30.09	39.00
6	81.00	650.00	111.03	30.03	39.00
7	86.00	-1400.00	112.62	32.62	49.00
8	82.00	550.00	110.86	28.86	38.00
9	83.00	2250.00	109.10	26.10	37.00
10	77.00	1080.00	108.56	9.56	43.00
11	80.00	2080.00	88.30	8.30	40.00
12	83.00	0.00	102.23	18.23	37.00
13	88.00	4180.00	105.21	18.21	32.00
14	91.00	1580.00	105.53	14.53	29.00
15	94.00	1040.00	110.47	16.47	26.00
16	94.00	0.00	111.82	17.82	25.00
17	92.00	3340.00	111.22	19.22	27.00
18	93.00	2120.00	111.63	18.63	27.00
19	93.00	1780.00	112.14	20.14	28.00
20	93.00	1580.00	113.53	20.53	27.00
21	85.00	3900.00	112.08	25.08	33.00
22	87.00	-2900.00	122.25	37.25	33.00
23	87.00	250.00	114.49	27.49	33.00
24	87.00	1950.00	115.67	26.67	33.00
25	88.00	850.00	117.05	29.05	32.00
26	93.00	-2700.00	113.97	20.97	27.00
27	94.00	1800.00	115.11	21.11	26.00
28	94.00	1200.00	114.00	20.00	26.00
29	85.00	1200.00	112.06	17.06	25.00
30	102.00	1200.00	110.84	6.84	18.00
31	97.00	3880.00	112.99	15.99	23.00
32	93.00	0.00	111.59	18.59	27.00
33	94.00	2020.00	110.48	16.48	26.00
34	98.00	1340.00	113.18	15.18	22.00
35	101.00	0.00	121.00	20.00	19.00
36	84.00	1080.00	100.73	16.73	36.00
37	70.00	0.00	90.00	20.00	50.00
38	70.00	0.00	90.00	20.00	50.00
39	86.00	0.00	108.00	20.00	32.00
40	102.00	0.00	122.00	20.00	16.00
41	111.00	0.00	131.00	20.00	9.00
42	107.00	0.00	127.00	20.00	13.00
43	110.00	0.00	130.00	20.00	10.00
44	118.00	0.00	135.00	20.00	5.00
45	117.00	0.00	138.00	20.00	2.00
46	117.00	0.00	137.00	20.00	3.00
47	94.00	-1600.00	112.05	18.05	26.00
48	83.00	-1800.00	102.45	18.45	37.00
49	93.00	-1300.00	111.75	18.75	27.00
50	105.00	-2900.00	117.86	12.86	15.00

Iteration Times : 18

ALTERNATIVE D-4-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year 1995

<< PIPELINE >>

PIPE No.	NODE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0.700)
1	1-2	700	100	130	-34946	-1.05	-1.38
2	2-3	250	730	120	5156	1.22	5.14
3	3-4	500	600	130	27931	1.65	6.99
4	4-5	200	600	110	2656	0.83	3.18
5	5-6	200	450	110	986	0.39	0.49
6	6-7	250	150	120	1082	0.25	0.39
7	7-8	150	190	110	-1116	-0.73	-4.58
8	8-9	150	180	110	-1400	-0.92	-6.81
9	9-10	300	410	120	1834	0.30	0.17
10	10-11	200	110	110	1184	0.44	1.76
11	11-12	300	700	120	6279	1.03	2.89
12	12-13	300	540	110	-7345	-1.20	-2.96
13	13-14	150	320	120	-1050	-0.71	-1.74
14	14-15	150	350	110	-3160	-2.01	-13.92
15	15-16	150	370	110	-1860	-1.02	-3.98
16	16-17	150	20	110	-1600	-1.05	-0.23
17	17-18	200	490	110	1100	0.41	1.39
18	18-19	100	430	110	-561	-0.83	-5.02
19	19-20	150	880	110	1080	0.71	4.79
20	20-21	150	460	110	-1550	-1.02	-4.95
21	21-22	150	150	110	-147	-0.92	-3.01
22	22-23	150	420	110	-1182	-0.77	-2.70
23	23-24	150	410	110	183	0.21	0.69
24	24-25	150	20	110	-1600	-1.05	-0.23
25	25-26	300	260	120	-3718	-0.61	-1.56
26	26-27	300	140	120	-5638	-0.96	-0.40
27	27-28	350	500	120	-7618	-0.92	-1.39
28	28-29	200	50	110	-2700	-0.99	-0.44
29	29-30	400	570	120	-10419	-0.95	-1.44
30	30-31	350	860	120	3922	0.47	0.84
31	31-32	150	300	110	-2900	-1.90	-10.19
32	32-33	300	370	120	-8046	-1.32	-2.42
33	33-34	350	360	120	-8295	-1.00	-1.77
34	34-35	400	450	120	-11262	-1.04	-1.96
35	35-36	450	610	120	15819	1.15	1.67
36	36-37	250	310	120	3600	0.65	1.11
37	37-38	200	390	110	2400	0.88	1.54
38	38-39	200	150	110	1200	0.44	0.58
39	39-40	200	300	110	342	0.50	1.40
40	40-41	320	380	110	1642	0.61	1.11
41	41-42	150	20	110	-1300	-0.85	-0.16
42	42-43	100	480	110	-378	-0.56	-1.63
43	43-44	200	560	110	-2900	-1.07	-4.68

ALTERNATIVE D-4-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year2010

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	120.00	0.00	120.00	0.00	0.00
2	85.00	5060.00	112.86	34.86	35.00
3	78.00	4180.00	116.94	38.94	42.00
4	77.00	2090.00	114.11	37.11	43.00
5	81.00	1040.00	112.81	31.81	39.00
6	81.00	1040.00	112.07	31.07	39.00
7	86.00	-1400.00	113.65	33.65	40.00
8	82.00	4910.00	110.19	28.19	38.00
9	83.00	4390.00	106.99	23.99	37.00
10	77.00	3230.00	99.61	22.48	43.00
11	80.00	3740.00	98.61	18.61	40.00
12	83.00	0.00	103.15	20.15	37.00
13	88.00	5900.00	104.66	16.66	32.00
14	91.00	2440.00	103.14	12.14	26.00
15	94.00	2050.00	104.64	10.64	26.00
16	94.00	0.00	105.25	11.25	26.00
17	92.00	5000.00	109.35	14.35	28.00
18	93.00	3820.00	107.03	14.03	27.00
19	92.00	2240.00	107.89	15.89	28.00
20	93.00	1870.00	111.38	18.38	27.00
21	81.00	6790.00	110.51	33.51	33.00
22	85.00	-2900.00	120.69	37.69	33.00
23	87.00	470.00	114.91	27.91	33.00
24	87.00	280.00	115.84	28.84	33.00
25	85.00	1050.00	118.27	30.27	32.00
26	93.00	-2700.00	111.82	18.82	27.00
27	94.00	2260.00	113.76	19.76	26.00
28	94.00	1210.00	112.63	18.63	26.00
29	95.00	1210.00	110.86	15.86	25.00
30	102.00	1210.00	109.42	7.42	18.00
31	97.00	4790.00	110.70	13.70	23.00
32	93.00	0.00	109.42	16.42	27.00
33	94.00	3340.00	107.04	13.04	26.00
34	95.00	1860.00	105.53	7.53	22.00
35	101.00	290.00	110.46	9.46	19.00
36	84.00	1510.00	97.68	12.68	35.00
37	70.00	1050.00	94.09	24.09	50.00
38	70.00	1510.00	98.56	28.56	50.00
39	88.00	1210.00	108.00	20.00	32.00
40	102.00	1210.00	122.00	20.00	18.00
41	111.00	1210.00	131.00	20.00	19.00
42	107.00	280.00	127.00	20.00	19.00
43	115.00	290.00	130.00	20.00	13.00
44	115.00	290.00	135.00	20.00	5.00
45	118.00	290.00	138.00	20.00	2.00
46	117.00	-290.00	137.00	20.00	2.00
47	94.00	1560.00	105.68	11.68	26.00
48	83.00	-1500.00	103.38	20.38	37.00
49	93.00	-1300.00	109.57	16.57	27.00
50	105.00	-2900.00	110.21	5.21	15.00

Iteration Times : 17

ALTERNATIVE D-4-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year2010

<< PIPELINE >>

PIPE No.	NODE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
1	2	700	100	130	-35109	-1.06	-0.14
2	2	250	730	120	3819	0.90	2.92
3	2	500	600	120	18941	1.12	2.65
4	2	700	100	130	-35109	-1.06	-0.14
5	2	350	730	120	9253	1.11	2.92
6	2	500	600	130	33144	1.36	2.55
7	2	200	600	170	2133	0.79	2.84
8	2	300	600	120	6759	1.11	2.68
9	2	400	450	110	1632	0.60	2.68
10	2	300	450	120	5171	0.85	2.88
11	2	250	450	120	4260	1.01	2.93
12	2	150	790	110	-884	-0.59	-3.84
13	2	250	150	120	4260	1.01	3.84
14	2	150	790	110	-1905	-0.70	-3.03
15	2	150	180	110	-1400	-0.92	-6.81
16	2	300	410	120	6636	1.09	4.57
17	2	200	410	120	2285	1.84	4.57
18	2	200	410	110	1634	0.60	2.89
19	2	150	1020	110	1970	1.05	11.64
20	2	150	110	110	167	0.30	2.69
21	2	300	700	120	5860	0.91	2.32
22	2	300	540	120	-8037	-1.32	-6.52
23	2	350	1120	120	5051	1.19	7.51
24	2	350	700	120	3455	0.81	3.32
25	2	300	540	120	-8037	-1.32	-6.52
26	2	150	320	110	741	0.49	2.71
27	2	150	930	110	1060	0.71	5.45
28	2	150	230	110	-1125	-1.13	-4.54
29	2	150	850	110	491	0.30	1.09
30	2	150	350	110	-1725	-1.13	-4.54
31	2	150	370	110	-625	-0.61	-1.51
32	2	150	20	110	-1600	-1.05	-1.28
33	2	150	370	110	-925	-0.61	-1.51
34	2	200	400	110	1701	0.63	3.11
35	2	170	430	110	-311	-0.46	-1.68
36	2	150	490	110	798	0.52	3.11
37	2	150	430	110	-903	-0.59	-1.68
38	2	150	830	110	1159	0.76	5.45
39	2	150	460	110	-818	-0.54	-1.50
40	2	150	460	110	822	0.42	3.26
41	2	150	150	110	-327	-0.42	-1.50
42	2	150	420	110	-328	-0.42	-1.50
43	2	150	150	110	-327	-0.42	-1.50
44	2	150	420	110	-327	-0.42	-1.50
45	2	150	410	110	-353	-0.37	-1.09
46	2	150	20	110	-1600	-1.05	-1.28
47	2	300	260	120	-4915	-0.80	-2.62
48	2	300	260	110	-1551	-0.57	-2.62
49	2	300	140	120	-7788	-1.28	-6.17
50	2	150	140	110	-2461	-0.91	-3.04
51	2	150	250	110	-27	-0.04	-0.01
52	2	200	500	120	-12499	-1.50	-3.49
53	2	200	60	110	-2700	-0.99	-1.32
54	2	200	610	120	-12994	-1.20	-2.39
55	2	350	650	120	-4454	-0.54	-1.03

ALTERNATIVE D-4-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Supply Systems w/2 Reservoirs, Southwest Area, Year 2010

<< PIPELINE >>

PIPE No.	NODE No.	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
56	20	27	300.	120.	-6098.	-1.00	-2.39
57	20	31	300.	120.	-2959.	0.49	0.68
58	21	22	150.	300.	-2900.	-1.90	10.18
59	21	23	300.	120.	-992.	-1.63	3.60
60	21	23	300.	120.	-992.	-1.63	3.60
61	23	24	350.	120.	-10217.	-1.23	-1.73
62	23	24	350.	120.	-10217.	-1.23	-1.73
63	24	25	400.	120.	-15291.	-1.41	-2.43
64	24	25	350.	120.	-10762.	-1.29	-2.43
65	25	27	450.	120.	24982.	1.62	4.51
66	27	28	250.	120.	3650.	0.86	1.13
67	28	29	200.	110.	2420.	0.89	1.97
68	29	30	200.	750.	1210.	0.45	1.24
69	31	32	100.	110.	326.	0.48	1.28
70	31	35	150.	500.	290.	0.19	0.24
71	32	33	200.	110.	2018.	0.74	1.28
72	32	33	200.	110.	2480.	0.91	2.38
73	32	33	150.	110.	-1300.	-0.85	-0.15
74	32	33	150.	110.	1164.	0.76	2.38
75	33	34	100.	480.	277.	0.41	1.51
76	34	50	200.	110.	-2900.	-1.07	-4.68

APPENDIX 7.3.3 Cost Estimates of Alternative Water Supply Systems

(1) Water Sources (Common Facilities)

o	Replacement of Pumps at existing wells 5 pumps x 320,000 ₱/pump	= ₱ 1,600,000
o	Reconstruction of one existing well 940,000 ₱/well + 640,000 ₱/ump	= ₱ 1,580,000
o	Pump installation at test well	₱ 640,000
o	16 new well construction 16 wells x (940,000 ₱/well + 640,000 ₱/well)	= ₱25,280,000
	<u>TOTAL</u>	<u>₱29,100,000</u>

(2) Transmission Line

(Unit : ₱x1,000)

Pipe	Unit Alternative D-1		Alternative D-2		Alternative D-3		Alternative D-4		
	Cost	Q'ty	Cost	Q'ty	Cost	Q'ty	Cost	Q'ty	
ϕ200 mm	520	4,500 m	2,340	3,500 m	1,820	5,500 m	2,860	4,500 m	2,340
ϕ250 mm	630	500 m	315	1,000 m	630	500 m	315	1,000 m	630
ϕ350 mm	900	500 m	450	1,000 m	900	500 m	450	1,000 m	900
ϕ400 mm	970	1,000 m	970	1,500 m	1,455	500 m	485	500 m	485
ϕ500 mm	1,330	500 m	665	500 m	665	500 m	665	500 m	665
TOTAL		7,000 m	4,740	7,500 m	5,470	7,500 m	4,775	7,500 m	5,020

(3) Reservoir

Costs were estimated based on the cost functions adopted in the LWUA Methodology Manual.

Alternative D-1

Ground Reservoir :	Q = 3,525 cu.m	₱ 3,705,000
	Q = 9,531 cu.m	₱ 6,996,000
	<u>TOTAL</u>	<u>₱10,701,000</u>

Alternative D-2

Deep Well Pump : Same as Alternative D-1 ₱19,947,000
Booster Pump : 2,904.6 MWH/year x 15 years x 0.3 ₱/KWH = ₱13,071,000
TOTAL = ₱33,018,000

Alternative D-3

Deep Well Pump : Same as Alternative D-1 ₱19,947,000
Booster Pump : 2,937.7 MWH/year x 15 years x 0.3 ₱/KWH = ₱13,220,000
TOTAL = ₱33,167,000

Alternative D-4

Deep Well Pump : Same as Alternative D-1 ₱19,947,000
Booster Pump : 2,892.9 MWH/year x 15 years x 0.3 ₱/KWH = ₱13,018,000
TOTAL = ₱32,965,000

(6) Labor

Unit Cost : ₱ 2,000/MM

Alternative D-1 and D-2

₱ 2,000/MM x 2 persons x 15 years = ₱ 720,000

Alternative D-3 and D-4

₱ 2,000/MM x 3 persons x 15 years = ₱ 1,080,000

APPENDIX 8.2.1.A BREAKDOWN OF COST ESTIMATES

(Unit: thousand Pesos)

Angeles	ITEM	UNIT COST	Phase I (Stage 1)		Phase I (Stage 2)		Phase I Total		Phase II Cost	
			NUMBER	COST	NUMBER	COST	NUMBER	COST	NUMBER	COST
1 SOURCE FACILITY										
	(1) DEEP WELL CONSTRUCTION	940000	1	940	6	5640	7	6580	10	9400
	(2) DEEP WELL PUMP w/HOUSE	640000	2	1280	6	3840	8	5120	10	6400
	Well Pump	320000	5	1600	0	0	5	1600	0	0
	Flow Meter D=150	62000	7	434	6	372	13	806	10	620
	SUB-TOTAL			4254		9852		14106		16420
2 TRANSMISSION FACILITIES										
	Main Pipes									
	D=200 (Steel Pipe)	520	0	0	1500	780	1500	780	3500	1820
	D=350 (Steel Pipe)	900	0	0	500	450	500	450	500	450
	D=400 (Steel Pipe)	970	0	0	500	485	500	485	500	485
	D=500 (Steel Pipe)	1330	0	0	0	0	0	0	2800	3724
	SUB-TOTAL		0	0	0	1715	0	1715		6479
3 DISTRIBUTION FACILITIES										
	(1) Reservoir			4202	0	0		4202		6210
	(2) Pump Facility (Equip.)			1301		3765		5066		4246
	-do- (Civil)			2228		0		2228		2187
	(3) Chlfrtn Facility 22kg/d	98100	7	687	1	98	8	785	3	294
	(4) Elevated Tank	1330000	0	0	0	0	0	0	2	2678
	(5) Electric Sub-station		1	2757						5131
	(6) Distribution pipes									
	1) Main Pipes									
	D=150 (PVC Pipe)	410	1440	590	300	123	1740	713	6190	2538
	D=200 (Steel Pipe)	520	2370	1233	1080	562	3450	1795	2100	1092
	D=250 (Steel Pipe)	630	380	239	310	195	690	434	4170	2627
	D=350 (Steel Pipe)	900	2800	2520	410	369	3210	2889	0	0
	D=400 (Steel Pipe)	970	1640	1591	0	0	1640	1591	0	0
	D=450 (Steel Pipe)	1160	2240	2599	0	0	2240	2599	0	0
	D=500 (Steel Pipe)	1330	460	612	0	0	460	612	0	0
	D=700 (Steel Pipe)	1910	700	1337	0	0	700	1337	100	191
	2) Valves									
	D=150 (Gate Valve)	5300	5	26	1	5	6	31	21	111
	D=200 (Gate Valve)	6700	8	54	4	27	12	81	7	47
	D=250 (Gate Valve)	11200	1	11	1	11	2	22	14	157
	D=350 (Butterfly Valve)	74400	9	870	1	74	10	744	0	0
	D=400 (Butterfly Valve)	95200	5	476	0	0	5	476	0	0
	D=450 (Butterfly Valve)	125900	7	882	0	0	7	882	0	0
	D=500 (Butterfly Valve)	174000	1	174	0	0	1	174	0	0
	D=700 (Butterfly Valve)	313200	2	626	0	0	2	626	0	0
	3) Internal Network									
	Commercial 100pop/ha	23100	0	0	0	0	0	0	75	1733
	Commercial 150pop/ha	25700	0	0	46	1181	46	1181	0	0
	Residential 100pop/ha	18700	140	2618	0	0	140	2618	672	12566
	Residential 150pop/ha	21000	0	0	403	8463	403	8463	0	0
	4) Service Connections									
	D=1/2	810	3940	3192	14370	11640	18310	14832	17540	14207
	D=3/4	1280	20	26	30	40	50	66	30	38
	5) Rehabilitation									
	Water Meter 1/2"	400	2878	1151	0	0	2878	1151		
	Old Laterals			857				857		
	Service Connect.w/Meter	480	1440	690	0	0	1440	690		
	Service Connect.w/Meter	880	625	550	0	0	625	550		
	6) Flow Meter D=400	215000	1	215	0	0	1	215	1	215
	7) Fire Protection									
	D=150	16800	0	0	0	0	0	0	95	1596
	D=100	9400	0	0	0	0	0	0	430	4042
	SUB-TOTAL			34114		26553		60667		61906
4 Administration Bldg.										
	(1) Administration Bldg.		1	1590			1	1590	1	1820
(2) Operation Center										
	(2) Operation Center		1	1590			1	1590	1	1090
	SUB-TOTAL		1	1590	0	0	1	1590	2	2910
5 Land Acquisition										
	Land Acquisition	120	2900	348	2000	240	4900	588	9300	1116
	Vehicle	300000	2	600	4	1200	6	1800	4	1200
	Stored Material & Equip.			438		519		957		964
	SUB-TOTAL			1386		1959		3345		3280
6 Replacement of Equipment										
	Replacement of Equipment			0		0		0		26093
	TOTAL			41344		40079		81423		117088
7 Leak Detection										
	Leak Detection	240	4128	990	0	0	4128	990		0
	GRAND TOTAL			42334		40079		82413		117088

(Unit: thousand Pesos)

Angeles		1988		1989		1990		1991	
ITEM	UNIT COST	NO	COST	NO	COST	NO	COST	NO	COST
1 SOURCE FACILITY									
(1) DEEP WELL CONSTRUCTION	940000		0	1	940		0	2	1880
(2) DEEP WELL PUMP w/HOUSE	640000		0	2	1280		0	2	1280
Well Pump	320000		0			5	1600	0	0
Flow Meter D=150	62000		0	2	124	5	310	2	124
SUB-TOTAL			0		2344		1910		3284
2 TRANSMISSION FACILITIES									
Main Pipes					0		0		0
D=200 (Steel Pipe)	520		0		0		0		0
D=350 (Steel Pipe)	900		0		0		0	500	450
D=400 (Steel Pipe)	970		0		0		0	500	485
D=500 (Steel Pipe)	1330		0		0		0		0
SUB-TOTAL			0		0		0		935
3 DISTRIBUTION FACILITIES									
(1) Reservoir					4292		4202		
(2) Pump Facility (Equip.)							651		753
-do- (Civil)							2228		
(3) Chlrtn Facility 22kg/d	98100			2	196	5	491	1	98
(4) Elevated Tank	1339000				0	0	0	0	0
(5) Electric Sub-station				1	2757				
(6) Distribution pipes		1988		1989		1990		1991	
1) Main Pipes									
D=150 (PVC Pipe)	410		0	240	98	1200	492	300	123
D=200 (Steel Pipe)	520		0	1490	775	880	458	1080	562
D=250 (Steel Pipe)	630		0	380	239	0	0	310	195
D=350 (Steel Pipe)	900		0	1500	1350	1300	1170	410	369
D=400 (Steel Pipe)	970		0	910	883	730	708	0	0
D=450 (Steel Pipe)	1160		0	1580	1833	660	766	0	0
D=500 (Steel Pipe)	1330		0	460	612		0	0	0
D=700 (Steel Pipe)	1910		0	700	1337		0		0
2) Valves									
D=150 (Gate Valve)	5300		0	1	5	4	21	1	5
D=200 (Gate Valve)	6700		0	5	34	3	20	4	27
D=250 (Gate Valve)	11200		0	1	11	0	0	1	11
D=350 (Butterfly Valve)	74400		0	5	372	4	298	1	74
D=400 (Butterfly Valve)	95200		0	3	286	2	190	0	0
D=450 (Butterfly Valve)	125900		0	5	630	2	252	0	0
D=500 (Butterfly Valve)	174000		0	1	174		0	0	0
D=700 (Butterfly Valve)	313200		0	2	626		0	0	0
3) Internal Network									
Commercial 100pop/ha	23100		0		0		0		0
Commercial 150pop/ha	25700		0		0		0	10	257
Residential 100pop/ha	18700		0	70	1309	70	1309		0
Residential 150pop/ha	21000		0		0		0	81	1701
4) Service Connections									
D=1/2	810		0	1970	1596	1970	1596	2874	2328
D=3/4	1280		0	10	13	10	13	6	8
5) Rehabilitation									
Water Meter 1/2"	400	2878	1151	0	0	0	0		
Old Laterals					429		428		
Service Connect. w/Meter	480	480	230	480	230	480	230		
Service Connect. w/Meter	880	209	184	208	183	208	183		
6) Flow Meter D=400	215000		0		215		0		0
7) Fire Protection									
D=150	16800								
D=100	9400								
SUB-TOTAL			1565		23274		9275		6511
4 Administration Bldg.									
(2) Operation Center				1	1590				
SUB-TOTAL			0	1	1590		0		0
5 Land Acquisition									
Vehicle	300000	2	600		0		0	1	300
Stored Material & Equip.			30		246		162		136
SUB-TOTAL			978		246		162		676
6 Replacement of Equipment									
TOTAL			2543		27454		11347		11406
7 Leak Detection	240	1376	330	1376	330	1376	330		0
GRAND TOTAL			2873		27784		11677		11406

(Unit: thousand Pesos)

Angeles		1992		1993		1994		1995	
ITEM	UNIT COST	NO	COST	NO	COST	NO	COST	NO	COST
1 SOURCE FACILITY									
(1)DEEP WELL CONSTRUCTION	940000	1	940	1	940	1	940	1	940
(2)DEEP WELL PUMP w/HOUSE	610000	1	610	1	640	1	640	1	640
Well Pump	320000	0	0	0	0	0	0	0	0
Flow Meter D=150	62000	1	62	1	62	1	62	1	62
SUB-TOTAL			1642	3	1642	3	1642	3	1642
2 TRANSMISSION FACILITIES									
Main Pipes			0		0		0		0
D=200 (Steel Pipe)	520	500	260	500	260	500	260		0
D=350 (Steel Pipe)	900		0		0		0		0
D=400 (Steel Pipe)	970		0		0		0		0
D=500 (Steel Pipe)	1330		0		0		0		0
SUB-TOTAL			260		260		260		0
3 DISTRIBUTION FACILITIES									
(1)Reservoir									
(2)Pump Facility (Equip.)			753		753		753		753
-do- (Civil)									
(3)Chlrtn Facility 22kg/d	98100		0		0		0		0
(4)Elevated Tank	1330000	0	0	0	0	0	0	0	0
(5)Electric Sub-station									
(6)Distribution pipes		1992		1993		1994		1995	
1)Main Pipes			0		0		0		0
D=150 (PVC Pipe)	410		0		0		0		0
D=200 (Steel Pipe)	520		0		0		0		0
D=250 (Steel Pipe)	630		0		0		0		0
D=350 (Steel Pipe)	900		0		0		0		0
D=400 (Steel Pipe)	970		0		0		0		0
D=450 (Steel Pipe)	1160		0		0		0		0
D=500 (Steel Pipe)	1330		0		0		0		0
D=700 (Steel Pipe)	1910		0		0		0		0
2)Valves			0		0		0		0
D=150 (Gate Valve)	5300		0		0		0		0
D=200 (Gate Valve)	6700		0		0		0		0
D=250 (Gate Valve)	11200		0		0		0		0
D=350 (Butterfly Valve)	74400		0		0		0		0
D=400 (Butterfly Valve)	95200		0		0		0		0
D=450 (Butterfly Valve)	125000		0		0		0		0
D=500 (Butterfly Valve)	174000		0		0		0		0
D=700 (Butterfly Valve)	313200		0		0		0		0
3)Internal Network			0		0		0		0
Commercial 100pop/ha	23100		0		0		0		0
Commercial 150pop/ha	25700	9	231	9	231	9	231	9	231
Residential 100pop/ha	18700		0		0		0		0
Residential 150pop/ha	21000	81	1701	81	1701	80	1680	80	1680
4)Service Connections									
D=1/2	810	2874	2328	2874	2328	2874	2328	2874	2328
D=3/4	1280	6	8	6	8	6	8	6	8
5)Rehabilitation									
Water Meter 1/2"	400								
Old Laterals									
Service Connect.w/Meter	480								
Service Connect.w/Meter	880								
6)Flow Meter D=400	215000	0	0	0	0	0	0	0	0
7)Fire Protection									
D=150	16800								
D=100	9400								
SUB-TOTAL			5021		5021		5000		5000
4 Administration Bldg.									
(2)Operation Center			0		0		0		0
SUB-TOTAL			0		0		0		0
5 Land Acquisition									
Vehicle	300000	1	300	1	300	1	300		0
Stored Material & Equip.			97		97		96		93
SUB-TOTAL			397		397		396		93
6 Replacement of Equipment									
T O T A L			7320		7320		7298		6735
7 Leak Detection									
	240								
GRAND TOTAL			7320		7320		7298		6735

APPENDIX 8.2.1.B PROJECT COST WITH FOREIGN AND LOCAL CURRENCY
 BREAKDOWN (1986 Price Level, Angeles City)

SUMMARY

Phase I, Stage 1

	(Unit: thousand ₱)		
	<u>F.E.C</u>	<u>Local</u>	<u>Total</u>
Direct Construction Cost	23,052	18,292	41,344
Physical Cont. (8% of D.C.C.)	1,844	1,464	3,308
Sub Total	24,896	19,756	44,652
Leakage Detection	-	990	990
Detailed Design (10% of S.T. in Stage 1 & Stage 2)	4,397	4,397	8,794
Construction Supervision (4% of S.T.)	893	893	1,786
Total	30,186	26,036	56,222

Phase I, Stage 2

	(Unit: thousand ₱)		
	<u>F.E.C</u>	<u>Local</u>	<u>Total</u>
Direct Construction Cost	25,221	14,858	40,079
Physical Cont. (8% of D.C.C.)	2,018	1,188	3,206
Sub Total	27,239	16,046	43,285
Construction Supervision (4% of S.T.)	228	1,503	1,731
Total	27,467	17,549	45,016

Phase II

	(Unit: thousand ₱)		
	<u>F.E.C</u>	<u>Local</u>	<u>Total</u>
Direct Construction Cost	71,592	45,496	117,088
Physical Cont. (8% of D.C.C.)	5,727	3,640	9,367
Sub Total	77,319	49,136	126,455
Detailed Design (10% of S.T.)	6,323	6,323	12,646
Construction Supervision (4% of S.T.)	-	5,058	5,058
Total	83,642	60,517	144,159

The following tables show the breakdown of the project cost in each design year. The unit of all figures is thousand pesos. Project cost is further broken down into the Foreign Exchange Component and the Local Currency Component. Abbreviations in the tables are as follows:

COST	---	Construction Cost
C.FEC	---	Cost for Civil Work in the Foreign Exchange Component
C.DOM	---	Cost for Civil Work in the Local Currency Component
C.D.UNSKL	---	Cost for Unskilled Laborer of Civil Works in the Local Currency Component.
E.FEC	---	Cost for Equipments in the Foreign Exchange Component
E.DOM	---	Cost for Equipments in the Local Currency Component

$$\text{COST} = \text{C.FEC} + \text{C.DOM} + \text{E.FEC} + \text{E.DOM}$$

The exchange rates used in the cost estimates are as follows:

$$\text{₱20} = \$1$$

$$\$1 = \text{₱155}$$

No.	Articles	ITEM	1988			1989			1990					
			COST	C.FEC	C.DON	C.D. UNSKI	E.FEC	E.DON	COST	C.FEC	C.DON	C.D. UNSKI	E.FEC	E.DON
1.0	SOURCE FACILITY													
	(1) DEEP WELL		0.0	0.0	0.0	0.0	47.0	188.0	159.8	0.0	0.0	0.0	0.0	0.0
	(2) PUMPING FACILITY		0.0	0.0	0.0	0.0	64.0	601.6	115.2	0.0	0.0	0.0	0.0	0.0
	1) Pumping Station		0.0	0.0	0.0	0.0	0.0	124.0	0.0	0.0	0.0	0.0	0.0	0.0
	2) Flow Meter		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	(3) PUMP REPLACEMENT		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	SUB-TOTAL		0.0	0.0	0.0	0.0	111.0	913.6	275.0	0.0	0.0	0.0	0.0	256.0
2.0	TRANSMISSION FACILITIES													
	(1) Pipelines		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	SUB-TOTAL		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3.0	DISTRIBUTION FACILITIES													
	(1) Reservoir		0.0	0.0	0.0	0.0	294.1	210.1	168.1	0.0	0.0	0.0	0.0	0.0
	(2) Pump Facility (Equip)		0.0	0.0	0.0	0.0	0.0	54.0	10.7	0.0	0.0	0.0	0.0	0.0
	Pump Facility (Civil)		0.0	0.0	0.0	0.0	2091.3	401.0	10.7	0.0	0.0	0.0	0.0	110.3
	(3) Chlorination Facility		0.0	0.0	0.0	0.0	16.1	39.2	0.0	0.0	0.0	0.0	0.0	0.0
	(4) Electric Sub-station		0.0	0.0	0.0	0.0	55.1	1447.5	29.4	0.0	0.0	0.0	0.0	0.0
	(5) Distribution Pipes		0.0	0.0	0.0	0.0	603.5	0.0	275.1	0.0	0.0	0.0	0.0	0.0
	1) Main Pipes		0.0	0.0	0.0	0.0	1995.6	2209.3	1630.2	0.0	0.0	0.0	0.0	826.8
	2) Valves		0.0	0.0	0.0	0.0	449.0	128.3	449.0	15.6	0.0	0.0	0.0	70.3
	3) Internal Network		0.0	0.0	0.0	0.0	366.5	52.4	288.0	209.4	0.0	0.0	0.0	288.0
	4) Service Connections		0.0	0.0	0.0	0.0	160.9	1387.6	64.4	160.9	0.0	0.0	0.0	64.4
	5) Water Meter		1151.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	6) Svc Cnctn Rhltn w/H		230.0	5.8	59.8	20.7	13.8	143.7	20.7	230.0	5.8	59.8	13.8	20.7
	7) Svc Cnctn Rhltn w/H		184.0	1.8	18.4	7.4	18.3	155.0	7.3	183.0	1.8	18.3	5.5	7.3
	8) Lateral Rehabilitation		0.0	0.0	0.0	0.0	120.1	17.2	94.4	428.0	77.0	119.8	17.1	132.8
	9) Flow Meter		0.0	0.0	0.0	0.0	0.0	215.0	0.0	0.0	0.0	0.0	0.0	0.0
	10) Fire Protection		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	SUB-TOTAL		1565.0	7.6	78.2	19.3	1451.1	8724.1	2890.3	9275.0	997.2	2062.5	342.5	1559.9
4.0	ADMINISTRATION BLDG		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	1) Administration Bldg		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	2) Operation Center		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	SUB-TOTAL		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	TOTAL		1565.0	7.6	78.2	19.3	1451.1	8724.1	2890.3	9275.0	997.2	2062.5	342.5	1559.9
5.0	LAND ACQUISITION													
	Vehicle		348.0	0.0	348.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	Stored Material & Equip.		30.0	0.0	30.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	SUB-TOTAL		378.0	0.0	378.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6.0	REPLACEMENT OF EQUIPMENT													
	1) Deep Well Pump		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	2) Booster Pump		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	3) Flow Meter		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	4) Chlorinator		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	5) Water Meter		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	6) Operation Center		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	7) Vehicle		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	8) Stored Material & Equip.		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	SUB-TOTAL		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	7.0 Leakage Detection		330.0	0.0	330.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	GRAND TOTAL		2873.0	7.6	756.2	19.3	1776.3	10116.7	3127.3	11677.0	907.2	2392.5	342.5	1841.8

No.	Articles	ITEM	1988			1989			1990					
			COST	C.FEC	C.DON	C.D. UNSKI	E.FEC	E.DON	COST	C.FEC	C.DON	C.D. UNSKI	E.FEC	E.DON
1	Deep Well Facilities		0.0	0.0	0.0	0.0	111.0	913.6	275.0	0.0	0.0	0.0	0.0	256.0
2	Transmission Facilities		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3	Purification Plant		0.0	0.0	0.0	0.0	294.1	210.1	168.1	0.0	0.0	0.0	0.0	0.0
4	Reservoir		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5	Disinfection Facilities		0.0	0.0	0.0	0.0	5.9	90.2	29.4	0.0	0.0	0.0	0.0	0.0
6	Electric Sub-Station		0.0	0.0	0.0	0.0	55.1	1417.5	275.7	0.0	0.0	0.0	0.0	0.0
7	Distribution Facilities		0.0	0.0	0.0	0.0	684.0	5009.4	2324.7	6762.0	948.0	1656.0	260.2	1293.8
8	Service Connection		1565.0	7.6	78.2	19.3	1451.1	8724.1	2890.3	9275.0	997.2	2062.5	342.5	1559.9
9	Admin. Bldg. & Oper. Ctr.		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10	Land Acquisition		348.0	0.0	348.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11	Vehicle & Stored Material		330.0	0.0	330.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12	Replacement of Equip.		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13	Leakage Detection		330.0	0.0	330.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	TOTAL		2873.0	7.6	756.2	19.3	1776.3	10116.7	3127.3	11677.0	907.2	2392.5	342.5	1841.8

No.	Angieles	ITEM	Phase I (Stage 1)					1991					1992				
			COST	C.FEC	C.DUM	E.FEC	E.DUM	COST	C.FEC	C.DUM	E.FEC	E.DUM	COST	C.FEC	C.DUM	E.FEC	E.DUM
1.0	SOURCE FACILITY	(1) DEEP WELL	940.0	158.8	432.4	188.0	159.8	864.8	319.6	376.0	319.6	940.0	159.8	432.4	188.0	159.8	
		(2) PUMPING FACILITY	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(3) Pumping Station	1280.0	115.2	448.0	601.0	115.2	448.0	601.0	115.2	1280.0	115.2	448.0	601.0	115.2		
		2) Flow Meter	434.0	0.0	0.0	1347.0	256.0	0.0	0.0	0.0	0.0	62.0	0.0	0.0	0.0		
		(3) PUMP REPLACEMENT	1800.0	0.0	0.0	1347.0	531.0	312.8	101.0	434.8	1812.0	217.4	656.4	79.0	559.8		
		SUB-TOTAL	4234.0	275.0	880.4	3567.0	351.0	770.4	215.1	72.8	260.0	46.8	10.4	80.6	59.8		
		CIP-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
2.0	TRANSMISSION FACILITIES	(1) Pipelines	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		CIP-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
3.0	DISTRIBUTION FACILITIES	(1) Reservoir	4202.0	1082.5	213.3	210.1	168.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(2) Pump Facility (Equip)	1301.0	0.0	0.0	1079.8	221.2	753.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(3) Pump Facility (Civil)	2228.0	133.7	2034.3	316.0	103.1	33.3	45.1	14.7	0.0	0.0	0.0	0.0	0.0		
		(4) Electric Sub-station	2757.0	427.3	606.5	1447.5	275.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(5) Distribution pipes	10721.0	1929.8	3001.9	3323.5	2405.6	349.7	50.0	387.2	0.0	0.0	0.0	0.0	0.0		
		2) Valves	2919.0	58.4	613.0	1984.9	262.7	24.6	7.0	79.6	0.0	0.0	0.0	0.0	0.0		
		3) Internal Network	2618.0	418.8	733.0	890.2	576.0	548.2	78.3	605.7	1932.0	309.1	541.0	77.3	656.9		
		4) Service Connections	3218.0	32.2	321.8	2735.2	128.8	233.6	93.4	1985.6	2336.0	23.4	233.6	70.1	1985.6		
		5) Water Meter	1151.0	0.0	0.0	1151.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		6) Srvc Concntr Rbbln w/Al	690.0	17.4	178.4	431.1	62.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		7) Srvc Concntr Rbbln w/Al	550.0	5.4	55.0	467.6	22.0	278.7	192.8	0.0	0.0	0.0	0.0	0.0	0.0		
		8) Lateral Rehabilitation	857.0	145.6	239.0	34.3	278.7	192.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		9) Flow Meter	215.0	0.0	0.0	215.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		10) Fire Protection	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		SUB-TOTAL	30114.0	4205.5	6809.6	14500.6	4179.3	1189.4	208.3	3708.2	5021.0	332.5	774.6	117.4	3267.5		
4.0	OPERATION CENTER	(1) Administration Bldg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(2) Operation Center	1590.0	143.1	651.9	572.4	222.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		SUB-TOTAL	1590.0	143.1	651.9	572.4	222.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		TOTAL	30958.0	4713.6	12341.9	16070.6	5231.0	2769.0	403.7	5179.0	6922.0	596.7	1503.8	236.8	3938.9		
5.0	LAND ACQUISITION	Vehicle	348.0	0.0	0.0	348.0	0.0	240.0	0.0	150.0	300.0	0.0	0.0	150.0	0.0		
		Stored Material & Equip.	438.0	0.0	0.0	367.9	70.1	135.0	0.0	114.2	97.0	0.0	0.0	81.5	0.0		
		SUB-TOTAL	386.0	0.0	318.0	667.9	310.1	676.0	0.0	264.2	397.0	0.0	0.0	231.5	0.0		
6.0	REPLACEMENT OF EQUIPMENT	(1) Deep Well Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(2) Booster Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(3) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(4) Chlorinator	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(5) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(6) Operation Center	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(7) Vehicle	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		(8) Stored Material & Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		GRAND TOTAL	42334.0	4713.6	13079.9	18338.5	5602.0	11406.0	403.7	5443.8	7320.0	596.7	1503.8	236.8	4130.4		

No.	Angieles	ITEM	Phase I (Stage 1)					1991					1992				
			COST	C.FEC	C.DUM	E.FEC	E.DUM	COST	C.FEC	C.DUM	E.FEC	E.DUM	COST	C.FEC	C.DUM	E.FEC	E.DUM
1	Deep Well Facilities		4254.0	275.0	880.4	3567.0	351.0	770.4	215.1	72.8	260.0	46.8	10.4	80.6	59.8		
2	Transmission Facilities		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
3	Purification Plant		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
4	Reservoir		4202.0	1082.5	213.3	210.1	168.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
5	Disinfection Facilities		687.0	34.4	606.5	1417.5	275.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
6	Electric Sub-station		2757.0	427.3	606.5	1447.5	275.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
7	Distribution Facilities		20830.0	2686.3	6882.1	1144.2	3748.5	4077.0	540.4	922.5	2685.0	368.1	511.0	77.3	1281.9		
8	Service Connection		5609.0	35.0	556.2	184.5	4784.9	212.9	2336.0	93.4	1985.6	23.4	233.6	70.1	1985.6		
9	Admini. Bldg. & Opr. Ctr.		1590.0	143.1	651.9	572.4	222.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
10	Land Acquisition		348.0	0.0	318.0	667.9	310.1	676.0	0.0	264.2	397.0	0.0	0.0	0.0	0.0		
11	Vehicle & Stored Material		1038.0	0.0	0.0	867.9	370.1	436.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
12	Replacement of Equip.		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		SUB-TOTAL	41344.0	4713.6	12899.9	18338.5	5602.0	11406.0	403.7	5443.8	7320.0	596.7	1503.8	236.8	4130.4		
13	Leakage Detection		800.0	0.0	800.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
		TOTAL	42334.0	4713.6	13079.9	18338.5	5602.0	11406.0	403.7	5443.8	7320.0	596.7	1503.8	236.8	4130.4		

No.	Angels	ITEM	Phase 1 (Stage 2)					Phase 1 Total					Phase 2				
			CUST	C.FEC	C.DUM	C.D. UNSKI	E.DUM	CUST	C.FEC	C.DUM	C.D. UNSKI	E.DUM	CUST	C.FEC	C.DUM	C.D. UNSKI	E.DUM
1.0	SOURCE FACILITY																
	(1) DEEP WELL	8610.0	958.8	2594.4	282.0	1128.0	1304.8	3026.8	329.0	1316.0	1118.6	3026.8	329.0	1316.0	1118.6	1118.6	
	(2) PUMPING FACILITY	3940.0	345.0	1344.0	192.0	1804.8	1792.0	460.8	256.0	2406.4	460.8	1792.0	256.0	2406.4	460.8	460.8	
	(3) Flow Meter	372.0	0.0	0.0	0.0	372.0	0.0	0.0	0.0	808.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(4) PUMP REPLACEMENT	8652.0	1304.4	3938.4	474.0	3304.8	4818.8	585.0	585.0	5872.4	1620.0	6504.0	790.0	5508.0	2174.0	2174.0	
	SUB-TOTAL	1715.0	308.7	480.2	68.6	531.6	480.2	308.7	68.6	531.6	308.7	480.2	68.6	531.6	308.7	308.7	
2.0	TRANSMISSION FACILITIES																
	(1) Pipelines	1715.0	308.7	480.2	68.6	531.6	480.2	308.7	68.6	531.6	308.7	480.2	68.6	531.6	308.7	308.7	
	SUB-TOTAL	1715.0	308.7	480.2	68.6	531.6	480.2	308.7	68.6	531.6	308.7	480.2	68.6	531.6	308.7	308.7	
3.0	DISTRIBUTION FACILITIES																
	(1) Reservoir	0.0	0.0	0.0	0.0	0.0	2731.3	294.1	294.1	210.1	8888.0	5777.2	622.2	444.4	355.5	355.5	
	(2) Pump Facility (Group)	3765.0	0.0	0.0	0.0	3765.0	0.0	0.0	0.0	4204.8	0.0	0.0	0.0	3524.2	721.8	721.8	
	(3) Pump Facility (Civil)	0.0	0.0	0.0	0.0	0.0	2034.3	401.0	0.0	2187.0	0.0	2055.8	393.7	2055.8	0.0	0.0	
	(4) Chlorination Facility	98.0	4.9	35.3	2.9	45.1	246.8	23.5	23.5	361.1	117.8	100.0	8.8	135.2	44.1	44.1	
	(5) Electric Substation	0.0	0.0	0.0	0.0	0.0	606.5	551.1	551.1	1147.5	5121.0	1128.8	102.9	2093.8	513.1	513.1	
	(6) Distribution Pipes	1248.0	224.8	348.4	50.0	387.2	3351.6	478.9	478.9	3710.7	2753.7	1895.4	257.9	1998.5	1483.5	1483.5	
	(7) Valves	117.0	2.5	24.6	7.0	79.5	637.6	182.2	182.2	2064.5	273.2	65.2	18.9	214.2	28.4	28.4	
	(8) Internal Network	9844.0	1543.1	2700.4	385.7	3278.9	3433.4	490.5	490.5	4189.1	2687.6	4003.7	572.0	4861.7	3145.8	3145.8	
	(9) Service Connections	11680.0	117.0	1168.0	350.5	9928.0	1489.2	447.1	12863.2	395.8	14245.0	142.5	427.4	12108.2	569.8	569.8	
	(10) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1151.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(11) 5/8" Conc'n Rhtln w/M	0.0	0.0	0.0	0.0	0.0	179.4	41.4	41.4	431.1	62.1	0.0	0.0	0.0	0.0	0.0	
	(12) 3/4" Conc'n Rhtln w/M	0.0	0.0	0.0	0.0	0.0	55.0	16.5	16.5	467.6	22.0	0.0	0.0	0.0	0.0	0.0	
	(13) Lateral Rehabilitation	0.0	0.0	0.0	0.0	0.0	239.9	34.3	278.7	192.8	0.0	0.0	0.0	0.0	0.0	0.0	
	(14) Flow Meter	0.0	0.0	0.0	0.0	0.0	215.0	0.0	215.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(15) Fire Protection	26553.0	1892.1	4276.0	796.1	16843.8	6187.0	2451.5	3174.4	8019.4	5698.0	112.8	563.8	3495.6	451.0	451.0	
	SUB-TOTAL	40079.0	3595.2	8934.6	1338.7	21716.1	3197.7	40054.0	11525.1	117098.0	10582.4	4162.0	61009.2	16632.4	16632.4	16632.4	
4.0	ADMINISTRATIVE BLDG	240.0	0.0	240.0	0.0	0.0	0.0	0.0	0.0	900.0	0.0	1116.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	240.0	0.0	240.0	0.0	0.0	0.0	0.0	0.0	900.0	0.0	1116.0	0.0	0.0	0.0	0.0	
5.0	LAND ACQUISITION	1200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	900.0	0.0	0.0	0.0	0.0	0.0	0.0	
	Levelling & Equip.	519.0	0.0	0.0	0.0	435.9	0.0	0.0	0.0	900.0	0.0	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	1959.0	0.0	240.0	0.0	1035.9	0.0	0.0	0.0	1703.8	0.0	0.0	0.0	1409.8	754.2	754.2	
6.0	REPLACEMENT OF EQUIPMENT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(1) Deep Well Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(2) Booster Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(3) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(4) Chlorinator	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(5) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(6) Operation Center	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(7) Vehicle	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(8) Stored Material & Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
7.0	LEAKAGE DETECTION	40079.0	3595.2	8934.6	1338.7	21716.1	3197.7	40054.0	11525.1	117098.0	10582.4	4162.0	61009.2	16632.4	16632.4	16632.4	
	GRAND TOTAL	40079.0	3595.2	8934.6	1338.7	21716.1	3197.7	40054.0	11525.1	117098.0	10582.4	4162.0	61009.2	16632.4	16632.4	16632.4	

No.	Angels	ITEM	Phase 1 (Stage 2)					Phase 1 Total					Phase 2				
			CUST	C.FEC	C.DUM	C.D. UNSKI	E.DUM	CUST	C.FEC	C.DUM	C.D. UNSKI	E.DUM	CUST	C.FEC	C.DUM	C.D. UNSKI	E.DUM
1.0	DEEP WELL FACILITIES																
	(1) Deep Well	8652.0	1304.4	3938.4	474.0	3304.8	4818.8	585.0	585.0	5872.4	1620.0	6504.0	790.0	5508.0	2174.0	2174.0	
	(2) Pumping Facilities	3940.0	345.0	1344.0	192.0	1804.8	1792.0	460.8	256.0	2406.4	460.8	1792.0	256.0	2406.4	460.8	460.8	
	(3) Purification Plant	372.0	0.0	0.0	0.0	372.0	0.0	0.0	0.0	808.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(4) Reservoir	8652.0	1304.4	3938.4	474.0	3304.8	4818.8	585.0	585.0	5872.4	1620.0	6504.0	790.0	5508.0	2174.0	2174.0	
	SUB-TOTAL	1715.0	308.7	480.2	68.6	531.6	480.2	308.7	68.6	531.6	308.7	480.2	68.6	531.6	308.7	308.7	
2.0	TRANSMISSION FACILITIES																
	(1) Pipelines	1715.0	308.7	480.2	68.6	531.6	480.2	308.7	68.6	531.6	308.7	480.2	68.6	531.6	308.7	308.7	
	SUB-TOTAL	1715.0	308.7	480.2	68.6	531.6	480.2	308.7	68.6	531.6	308.7	480.2	68.6	531.6	308.7	308.7	
3.0	DISTRIBUTION FACILITIES																
	(1) Reservoir	0.0	0.0	0.0	0.0	0.0	2731.3	294.1	294.1	210.1	8888.0	5777.2	622.2	444.4	355.5	355.5	
	(2) Pump Facility (Group)	3765.0	0.0	0.0	0.0	3765.0	0.0	0.0	0.0	4204.8	0.0	0.0	0.0	3524.2	721.8	721.8	
	(3) Pump Facility (Civil)	0.0	0.0	0.0	0.0	0.0	2034.3	401.0	0.0	2187.0	0.0	2055.8	393.7	2055.8	0.0	0.0	
	(4) Chlorination Facility	98.0	4.9	35.3	2.9	45.1	246.8	23.5	23.5	361.1	117.8	100.0	8.8	135.2	44.1	44.1	
	(5) Electric Substation	0.0	0.0	0.0	0.0	0.0	606.5	551.1	551.1	1147.5	5121.0	1128.8	102.9	2093.8	513.1	513.1	
	(6) Distribution Pipes	1248.0	224.8	348.4	50.0	387.2	3351.6	478.9	478.9	3710.7	2753.7	1895.4	257.9	1998.5	1483.5	1483.5	
	(7) Valves	117.0	2.5	24.6	7.0	79.5	637.6	182.2	182.2	2064.5	273.2	65.2	18.9	214.2	28.4	28.4	
	(8) Internal Network	9844.0	1543.1	2700.4	385.7	3278.9	3433.4	490.5	490.5	4189.1	2687.6	4003.7	572.0	4861.7	3145.8	3145.8	
	(9) Service Connections	11680.0	117.0	1168.0	350.5	9928.0	1489.2	447.1	12863.2	395.8	14245.0	142.5	427.4	12108.2	569.8	569.8	
	(10) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1151.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(11) 5/8" Conc'n Rhtln w/M	0.0	0.0	0.0	0.0	0.0	179.4	41.4	41.4	431.1	62.1	0.0	0.0	0.0	0.0	0.0	
	(12) 3/4" Conc'n Rhtln w/M	0.0	0.0	0.0	0.0	0.0	55.0	16.5	16.5	467.6	22.0	0.0	0.0	0.0	0.0	0.0	
	(13) Lateral Rehabilitation	0.0	0.0	0.0	0.0	0.0	239.9	34.3	278.7	192.8	0.0	0.0	0.0	0.0	0.0	0.0	
	(14) Flow Meter	0.0	0.0	0.0	0.0	0.0	215.0	0.0	215.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(15) Fire Protection	26553.0	1892.1	4276.0	796.1	16843.8	6187.0	2451.5	3174.4	8019.4	5698.0	112.8	563.8	3495.6	451.0	451.0	
	SUB-TOTAL	40079.0	3595.2	8934.6	1338.7	21716.1	3197.7	40054.0	11525.1	117098.0	10582.4	4162.0	61009.2	16632.4	166		

APPENDIX 8.2.1.C OPERATION AND MAINTENANCE COST (Angeles City)

(cost: thousand peso)

Item	Stage 1		Stage 2		Phase II	
		Cost		Cost		Cost
Operation & Maintenance Cost						
Salary	2,000 p/M.M	1,104		1,752		2,688
Power	0.3 P/kWh	323		986		2,016
Chemical	27 P/kg	95		246		471
Miscellaneous		838		2,207		3,877
Maintenance		629		1,725		3,063
Total		2,989		6,916		12,115

APPENDIX 9.3.1 MARKET SURVEY

The market survey was conducted by interviews to the residents in the study area using the LWUA's interview sheet as per attached in the end of this section.

The total number of respondents and its estimated coverage ratio to the total number of households in the study area are as follows:

<u>Total Number of Respondents</u>	<u>Estimated Total Household</u>	<u>Coverage Ratio to Total Household</u>
6,556	24,025	27%

The results of the market survey are obtained as shown in TABLE 9.3.1.

From the market survey, the income distribution of the respondents are shown as follows:

<u>Income Bracket^{1/}</u>	<u>Ave. Pesos</u>	<u>Number</u>
P900 and below	722	903
P901 to P1500	1,292	1,754
P1,501 to P2,500	2,132	1,339
P2,501 to P4,500	3,486	1,358
P4,501 and above	8,256	945

The existing sources of water for the respondents and their willingness to connect to each source are indicated as follows:

^{1/} Residential, excluding no-income and no-answer

TABLE 9.3.1 MARKET SURVEY SUMMARY

Total Number of Respondents: 6556

1. Distribution According to Building Type					
		No.	%		
a. Residential	:	6359	97.00		
b. Commercial	:	171	2.61		
c. Industrial	:	26	0.40		
2. Distribution According to Source of Water					
		No.	%		
a. Connected to System	:	1653	25.21		
b. Neighbor's Connection	:	850	12.97		
c. Public Faucet	:	239	3.65		
d. Private System	:	3786	57.75		
e. Water Vendor	:	3	0.05		
f. Others	:	25	0.38		
3. Average Persons Per Household					
a. Residential / Number of Sample	:	6.55 /	6355		
b. Commercial / Number of Sample	:	6.83 /	171		
c. Industrial / Number of Sample	:	9.27 /	26		
4. Willingness To Connect (%)					
		Residential	Commercial	Industrial	Total
a. Yes	:	59.43	49.12	46.15	59.11
b. No	:	15.16	19.30	19.23	15.28
c. Undecided	:	0.39	0.00	3.85	0.40
d. W/ Own Conn.:		25.02	31.58	30.77	25.21
5. Average Monthly Water Needs					
Type / Number of Sample :	Residential	Commercial	Industrial		
a. Kerosene Can / 1032 :	13.39	23.90	7.75		
b. Drum / 5302 :	5.99	4.14	5.17		
c. Gallon / 185 :	97.76	45.21	2.00		
d. Others / 29 :	63.66	0.10	0.00		
6. Ave. Monthly Electric Bills for Residential Users (PESO):148.18					
Number of Effective Respondents				: 6163	
7. Income Distribution					
(Residential, Excluding No-Income and No-Answer)					
		AVE.PESO	NUMBER		
a. P900 and Below :		722	903		
b. P901 to P1500 :		1292	1754		
c. P1501 to P2500 :		2132	1339		
d. P2501 to P4500 :		3486	1358		
e. P4501 and Above :		8256	945		

Sources of Water	Distribution	Willingness to Connect	
		Yes	No
Connected to System	25 %	- %	- %
Neighbor's Connection	13	79	21
Public Faucet	4	76	24
Private System	58	79	20

The private system is the major source of water for the respondents, followed by the system, neighbor's connection and public faucets.

In addition, only 0.4% of the respondents depend on water vendors and others for its water sources. The above table shows that majority of the respondents are willing to connect to the waterworks system.

The following are the distribution of water sources and the respondents' willingness to connect according to income bracket as obtained from the market survey.

TABLE 9.3.2 DISTRIBUTION OF WILLINGNESS TO CONNECT BY INCOME BRACKET

Sources of Water	Income Bracket				
	P900 & below	P901- P1,500	P1,501- P2,500	P2,501- P4,500	P4,501- & above
Connected to System	12 %	20 %	27 %	31 %	37 %
Neighbor's Connection	29	19	11	5	2
Public Faucet	8	5	3	1	0
Private System	50	55	58	62	60
Willingness to Connect					
Yes	63	63	60	58	50
No	25	16	13	11	13
Undecided	1	1	0	0	0
With Own Connection	11	20	27	31	36

As the result of the market survey, the respondents' willingness to connect and the user's types are shown as follows :

<u>Answer</u>	<u>Residential</u>	<u>Commercial</u>	<u>Industrial</u>	<u>Total</u>
Yes	: 59.4 %	49.1 %	46.1 %	59.1 %
No	: 15.2	19.3	19.2	15.3
Undecided	: 0.4	0.0	3.3	0.4
With Own Conn.	: 25.0	31.6	30.8	25.2

Residential users account for 97% of the total respondents, so respondents' willingness to connect is approximately 60% of the total, while unwillingness to connect is 15%. It was observed from the results of the survey that the majority of the respondents in all income brackets are willing to connect to the waterworks system.

Judging from the above, it is safe to conclude that the majority of the residents in the study area are willing to connect to the new system when the water supply system is expanded.

AAPENDIX 9.7.1 FINANCIAL INTERNAL RATE OF RETURN (FIRR)

In the calculation of Financial Internal Rate of Return (FIRR), the following two indicators are normally used to evaluate financial profitability of a project.

(1) Internal Rate of Return on Investment (IRROI)

The term IRROI indicates the internal rate of return on total capital investment, and assesses the profitability of the Project as a whole and the ability to recover funds invested in the Project.

The IRROI is calculated based on the assumption that the total capital investment is covered by its own capital. Therefore, the financial conditions such as the loan conditions on borrowed capital, changes on the ratio of equity to total capital requirement and others have no effect on the IRROI. Accordingly, the IRROI indicates the profitability of the Project itself.

(2) Internal Rate of Return on Equity (IRROE)

The term IRROE indicates the internal rate of return on equity, and assesses the profitability only with respect to equity and the ability to recover funds invested in the Project as equity. Here, the IRROE is calculated on the basis of such financial conditions proper to the Project as the loan conditions on borrowed capital and amount of capital owned.

In this study, the FIRR was calculated using the same method applied in the study report of the BACOLOD CITY WATER DISTRICT PHASE II WATER SUPPLY FEASIBILITY STUDY, DRAFT REPORT VOLUME 3 by LWUA.

APPENDIX 9.8.1 PROPOSED WATER RATE

The proposed water rates for 1/2 inch connections of commercial users, and 3/4 inch connections of domestic and commercial users to achieve financial self-sufficiency are as follows :

(1) Water rate for 1/2 inch connections of commercial users

Period	Rate/ Unit	First 10cu.m	11-20cu.m	21-35cu.m	Above 35cu.m
1988	P1.0	P 50.0	P 6.2	P 8.0	P 10.6
1989	1.2	60.0	7.6	9.6	12.6
1990	1.2	60.0	7.6	9.6	12.6
1991	1.8	90.0	11.2	14.4	19.0
1992	2.7	135.0	16.8	21.6	28.4
1993	2.9	145.0	18.2	23.2	30.4
1994	3.1	155.0	19.4	24.8	32.6
1995	3.1	155.0	19.4	24.8	32.6
1996	3.3	165.0	20.6	26.4	34.6
1997	3.3	165.0	20.6	26.4	34.6

(2) Water rate for 3/4 inch connection of domestic users

Period	Rate/ Unit	First 10cu.m	11-20cu.m	21-35cu.m	Above 35cu.m
1988	P1.0	P 40.0	P 5.0	P 6.4	P 8.5
1989	1.2	48.0	6.1	7.7	10.1
1990	1.2	48.0	6.1	7.7	10.1
1991	1.8	72.0	9.0	11.5	15.2
1992	2.7	108.0	13.4	17.3	22.7
1993	2.9	116.0	14.6	18.6	24.3
1994	3.1	124.0	15.5	19.8	26.1
1995	3.1	124.0	15.5	19.8	26.1
1996	3.3	132.0	16.5	21.1	27.7
1997	3.3	132.0	16.5	21.1	27.7

(3) Water rate for 3/4 inch connection of commercial users

<u>Period</u>	<u>Rate/ Unit</u>	<u>First 10cu.m</u>	<u>11-20cu.m</u>	<u>21-35cu.m</u>	<u>Above 35cu.m</u>
1988	P1.0	P 80.0	P10.0	P12.8	P17.0
1989	1.2	96.0	12.2	15.4	20.2
1990	1.2	96.0	12.2	15.4	20.2
1991	1.8	144.0	18.0	23.0	30.4
1992	2.7	216.0	26.8	34.6	45.4
1993	2.9	232.0	29.2	37.2	48.6
1994	3.1	248.0	31.0	39.6	52.2
1995	3.1	248.0	31.0	39.6	52.2
1996	3.3	264.0	33.0	42.2	55.4
1997	3.3	264.0	33.0	42.2	55.4

LIST OF PERSONS CONCERNED

LIST OF PERSONS CONCERNED

ADVISORY COMMITTEE MEMBERS

- | | |
|--|---|
| Dr. Kiyoshi Yamada | - Chairman of Committee,
Professor, Ritsumeikan University |
| Mr. Hisashi Watanabe | - Member, for Water Supply System Planning,
Nagoya City |
| Mr. Masahiro Takai | - Member, for Water Source Planning,
Kobe City |
| Mr. Tsutomu Sakagawa
(Predecessor:
Mr. Yoshiro Kaburagi) | - Member, for Water Supply System Planning,
Ministry of Health and Welfare |
| Mr. Shozo Matsuura
(Predecessor:
Mr. Yoichi Seki) | - Coordinator,
Japan International Cooperation
Agency (JICA) |

LWUA OFFICIALS

- | | |
|----------------------------|---|
| Mr. Porthos P. Alma Jose | - Administrator |
| Col. Carlos C. Leño, Jr. | - Ex-General Manager |
| Mr. Salvador J. Rivera | - Sr. Deputy Administrator |
| Mr. Ibarra J. Olgado | - Deputy Administrator for Regulatory |
| Mr. Daniel I. Castillo | - Deputy Administrator for Finance |
| Mr. Vitaliano J. dela Vega | - Deputy Administrator for Engineering |
| Mr. Alfredo B. Espino | - Manager, Planning Department |
| Mr. Isidoro A. Yee | - Asst. Manager, Planning Department |
| Mr. Roberto B. Binag | - Manager, Water Systems Development
Division |
| Mr. Eriberto R. Calubaquib | - Manager, Water Resources Division |
| Mr. Antonio R. de Vera | - Project Manager IV |
| Mr. Armando T. Fernandes | - Manager, Construction Department |
| Mr. Arador R. Sambo | - Manager, Water District Formation/
Review Department |
| Mr. Francis C. Joven | - Manager, Formation of Water
District Division |

LWUA OFFICIALS (CONT'D)

Mr. Hector A. Dayrit - Manager, Rates Division
Mr. Teofilo R. Palaganas - Area Manager, Advisory Services Div.
Mr. Henry I. Pacis - Water District Development Officer

Mrs. Jean C. Leoncio - Manager, Loan Evaluation Division

OTHER AGENCIES

NIA CONSULTANTS INC.

Mr. Isidro Digal - Manager, Planning Division
Mr. Lorenzo N. Macaspac - Professional Mechanical Engineer

NWRC

Atty. Elena Luz J. Alojipan - Hearing Officer, IV

MWSS

Mr. Antonio E. Kaimo - Acting Department Manager, Planning and Design Department

ANGELES CITY

Mr. Francisco G. Nepomuceno - City Mayor
Atty. Filomeno Espiritu - City Treasurer
Mr. Filomeno M. Bonifacio, Jr. - City Engineer
Mr. Romeo P. Calara - Sr. Mechanical Engineer

DAGUPAN CITY

Mr. Liberato L. Reyna, Sr. - City Mayor
Mr. Cipriano M. Manaois - Ex-Mayor
Mr. Juanito A. Pajaro - City Treasurer
Mr. Silverio C. Coquia - Waterworks Superintendent
Mr. Manuel B. Ravanzo - City Development Coordinator

CABUYAO, STA. ROSA AND BINAN

Atty. Felicismo T. San Luis	- Governor, Province of Laguna
Mr. Romeo G. Ballesteros	- Provincial Civil Security Officer
Mr. Dante T. Reyes	- Executive Assistant/Development Coordinator
Mr. Catalino Caparas	- Waterworks Supervisor, Province of Laguna
Mr. Isidro T. Hildawa	- Mayor, Municipality of Cabuyao
Mr. Cesar E. Nepomuceno	- Mayor, Municipality of Sts. Rosa
Mr. Noe C. Zarate	- Mayor, Municipality of Biñan
Mrs. Josefa L. Pradel	- Municipal Development Coordinator, Cabuyao
Mr. Felizardo P. Manto	- Municipal Planning and Development Coordinator, Sta. Rosa
Mr. Carito P. Torres	- Municipal Census Officer, Sta. Rosa

BAYOMBONG AND SOLANO

Mrs. Belen F. Calderon	- Governor, Province of Nueva Vizcaya
Mrs. Natalia F. Dumlao	- Ex-Governor
Mr. Clamente G. Bacani	- Provincial Secretary
Mr. Artemio P. Bahia	- Provincial Attorney
Mr. Jesus M. Calata	- Provincial Engineer
Mr. Tomas C. Garra	- Supervising Project Analyst Provincial Planning & Develop't Office
Mr. Geoffrey B. Magday	- Concurrent Provincial Waterworks Officer
Capt. Federico M. Bolusan	- Provincial Waterworks Supervisor
Mr. John Bagasao	- Mayor, Municipality of Bayombong
Mr. Lunbert Galima	- Mayor, Municipality of Solano

STUDY TEAM MEMBERS

- | | |
|----------------------|---|
| Mr. Toru Hayashi | - Team Leader
Legistration/Organization
Nippon Jogesuido Sekkei Co., Ltd. (NJS) |
| Mr. Masatoshi Momose | - Water Supply System Planning, NJS |
| Mr. Chikara Amitani | - Water Supply System Planning, NJS |
| Mr. Masuomi Hiroyama | - Transmission/Distribution System Planning,
NJS |
| Mr. Hideaki Fukui | - Transmission/Distribution System Planning,
NJS |
| Mr. Takafumi Kiguchi | - Facility Design, NJS |
| Mr. Yukio Maejima | - Water Source Planning, NJS |
| Mr. Fumiaki Ichino | - Water Source Planning,
Richo Soil Investigation Co., Ltd. |
| Mr. Mitsuo Tsutsumi | - Well Development, NJS |
| Mr. Masaaki Awamoto | - Financial and Economic Analysis,
Techno Consultants, Inc. |

MINUTES OF THE MEETINGS

MINUTES OF THE MEETING
MUNICIPAL WATER SUPPLY
PROJECT STUDY

Manila, March 25, 1986

Toru Hayashi

Toru Hayashi
Study Team Leader
Japan International
Cooperation Agency

[Signature]
Atty. Ibarra Oligado
Officer in charge
LWUA

[Signature]

T.H.

[Signature]

MINUTES OF THE MEETING

A series of meetings between JICA survey team and LWUA personnel regarding the Inception Report were held during March 18 to March 24, 1986 to confirm the objectives, scope of work and schedule for implementation of the study. Also discussed during the meetings were undertakings by both parties and approaches to the project.

The following are the items agreed upon:

1. Objective of the Study.

The objective of the study is to prepare Basic Development Plan and Short Term Development Plan for the water supply projects in the following four project areas.

1. Angeles City, Pampanga
2. Dagupan City, Pangasinan
3. Cabuyao, Sta. Rosa and Binan, Laguna
4. Bayombong and Solano, Nueva Vizcaya

2. Scope of the Study

The study will be conducted in four (4) phases including works both in the Philippines and in Japan. The following are the outline of each phase:

2.1 Phase I: Formulation of Basic Development Plan

- a) Collection and review of data and information available
- b) Implementation of field survey
- c) Outline of Basic Development Plan
- d) Preparation of framework for the Feasibility Study
- e) Preparatory work for implementation of Phase II study

2.2 Phase II: Field Investigation for Preparation of Feasibility Study

- a) Field Investigation
 - o Geoelectric prospecting
 - o Test well drilling and pumping test
 - o Inventory of wells and pumping tests of selected existing wells
 - o Measurement of yield at springs

- o Testing of existing pumps
 - o Measurement of unaccounted-for-water and hydraulic survey
 - o Investigation of existing water supply facilities
- b) Study of availability of materials and equipment for construction and improvement of water supply facilities and capability of local contractors
 - c) Review of design criteria for design of proposed water supply facilities
 - d) Study of the alternative water supply schemes

2.3 Phase III: Preparation of Feasibility Study (Draft Final Report)

- a) Preliminary design of the recommended water supply systems among alternatives
- b) Recommendation on organization/management of the system and establishment of water districts
- c) Implementation schedule
- d) Cost estimation for construction, operation, and maintenance of the system
- e) Financial study

2.4 Phase IV: Preparation of Final Report

3. Approach to the Project

3.1 Development of Master Plan

a) Study Area

Study of fundamentals for the development of Master Plan will be made covering the entire city/municipality. However, the plan for the water supply system should be limited to those areas to be covered by level II/III systems.

b) Target Year

The base year for planning is 1986 in principle and target year is 2010. In addition, the years, 1990, 1995 and 2000 shall be considered although detailed study, such as breakdown of population by sub-area shall be only made for the present, 1990 and 2010.

J.H.

[Signature]

c) Plan of Water Supply System

Layout of the existing and proposed pipelines and other major facilities will be shown on the map

d) Rough Cost Estimates

Rough cost estimates will be made using cost data prepared by the LWUA for feasibility studies.

e) Water Sources

Based on the data on water resources collected during Phase I, applicable water sources will be recommended to meet the water demands and other conditions including socio-economic needs.

f) Establishment of the Water District

Information on the willingness by the cities and municipalities as well as present problem areas in management of the existing water supply systems will be collected and evaluated to make recommendations for implementation of the water supply project.

3.2 Preparation of Framework for the Short Term Development Plan

a) Previous reports, if any, prepared by the city/municipality will be reviewed. The subject area will be recommended in consideration of existing service area, potential water resources, needs and willingness of the inhabitants, and financial viability. Marketing surveys will be conducted by the LWUA financial specialists to support the study.

b) Target Year

The base year is 1986 in principle and target year is 1990 for the four project areas.

c) Water Sources

Existing water sources including springs and deep wells will be evaluated to their maximum safe capacities. Improvement of existing source facilities and new development requirements will also be studied.

J.H.

- d) Preparatory work for the field survey during Phase II.

Most of the measurements in the field will be conducted during the Phase II. Since the work for test well drilling is critical, timely arrangement/procurement of equipment and material at the initial stage of the Phase II is indispensable. Detailed discussion to reach an agreement for the purpose between two parties will be made during the last two weeks of Phase I period reflecting the result of field survey and collected information. Responsibilities by each party for implementation of the field examination will be accomplished in accordance with the minutes exchanged on October 23, 1985.

4. Schedule for Implementation of the Study

4.1 Phase I

JICA team started field work from March 17 and is scheduled to finish its Phase I work on April 27. Discussions on the methodologies and required arrangements as well as collection and review of data will be conducted in Manila during first half of the study period. Field trip to the subject cities/municipalities will be done within two weeks during latter half of the study period. The outline of the basic development plan and framework of the short term plan will be prepared by the end of this Phase. Detailed schedule is attached herewith.

4.2 Phase II to Phase IV

Phase II field work is tentatively scheduled to start from the beginning of June 1986 and Final Report will be submitted at the end of February 1987 in Phase IV period.

5. Undertakings by JICA and LWUA

In accordance with the agreement between JICA and LWUA signed on October 23, 1985, each party will accomplish its responsibilities.

JICA

SCHEDULE FOR IMPLEMENTATION OF THE STUDY

<u>Date</u>	<u>Activities</u>
March 17 Mon	1st Group: Tokyo-Manila, visit to Japan Embassy & JICA.
18 Tue	A.M.: Courtesy call on LWUA, P.M.: Explanation of and discussions on Inception Report.
19 Wed	Discussions on Inception Report, data collection and required arrangements.
20 Thur	Preparation of minutes and data collection.
21 Fri	Exchange of minutes.
22 Sat	Inner meeting of Survey Team.
②③ Sun	- do -
24 Mon	Collection and review of data and information.
25 Tue	2nd Group: Tokyo-Manila, review of data and information.
26 Wed	. Analysis of data and information collected. . Preparatory work for the field survey
△ 27 Thur)	
△ 28 Fri)	
△ 29 Sat)	Analysis of data and information collected.
③⑩ Sun)	B Group: Manila-Dagupan/ C Group: Manila-Dagupan
31 Mon	A Group: Cabuyao, etc / Dagupan City Dagupan City
April 1 Tue	. Data collection . Data collection
2 Wed	. Field Survey . Field Survey
	. Discussions with officers . Discussions with officers
3 Thur	
4 Fri	
5 Sat	Preparation of Field/ Report Preparation of Field Report C Group: Dagupan
⑥ Sun	- do - - do - Dagupan-Manila
7 Mon	A Group: Angeles City / B Group: Bayombong & Solano Cabuyao, etc.
8 Tue	. Data collection . Data collection
9 Wed	. Field Survey . Field Survey
Thu	. Discussions with officers . Discussions with officers
11 Fri	

April 12	Sat	Preparation of Field Report	Preparation of Field Report
(13)	Sun	- do -	B Group: Dagupan-Manila
14	Mon	Review of data and information	
15	Tue	Preparation of Basic Development Plan and Framework of short term plan	
16	Wed	- do -	
17	Thur	- do -	
18	Fri	- do -	
19	Sat	- do -	
(20)	Sun	Preparation of Report	
21	Mon	Preparation of Report	
22	Tue	- do -	
23	Wed	- do -	
24	Thur	Meeting with LWUA	
25	Fri	Meeting with LWUA and visit to JICA and Embassy	
26	Sat	Inner meeting	
(27)	Sun	Manila - Tokyo	