

APPENDIX 8.2.1.B PROJECT COST WITH FOREIGN AND LOCAL CURRENCY
 BREAKDOWN (1986 Price Level, Dagupan City)

SUMMARY

Phase I, Stage 1

	(Unit: thousand ₱)		
	<u>Local</u>	<u>F.E.C</u>	<u>Total</u>
Direct Construction Cost	21,868	26,532	48,400
Physical Cont. (8% of D.C.C.)	1,749	2,123	3,872
Sub Total	23,617	28,655	52,272
Leakage Detection	1,020	-	1,020
Detailed Design (10% of S.T. in Stage 1 & Stage 2)	3,778	3,779	7,557
Construction Supervision (4% of S.T.)	1,045	1,046	2,091
Total	29,460	33,480	62,940

Phase I, Stage 2

	(Unit: thousand ₱)		
	<u>Local</u>	<u>F.E.C</u>	<u>Total</u>
Direct Construction Cost	9,604	11,965	21,569
Physical Cont. (8% of D.C.C.)	769	957	1,726
Sub Total	10,373	12,922	23,295
Construction Supervision (4% of S.T.)	609	223	932
Total	10,982	13,145	24,227

Phase II

	(Unit: thousand ₱)		
	<u>Local</u>	<u>F.E.C</u>	<u>Total</u>
Direct Construction Cost	53,133	67,267	120,400
Physical Cont. (8% of D.C.C.)	4,251	5,381	9,632
Sub Total	57,384	72,648	130,032
Detailed Design (10% of S.T.)	6,501	6,502	13,003
Construction Supervision (4% of S.T.)	5,201	-	5,201
Total	69,086	79,150	148,236

The following tables show the breakdown of the project cost in each design year. The unit of all figures is thousand pesos. Project cost is further broken down into the Foreign Exchange Component and the Local Currency Component. Abbreviations in the tables are as follows:

COST	---	Construction Cost
C.FEC	---	Cost for Civil Work in the Foreign Exchange Component
C.DOM	---	Cost for Civil Work in the Local Currency Component
C.D.UNSKL	----	Cost for Unskilled Laborer of Civil Works in the Local Currency Component.
E.FEC	---	Cost for Equipments in the Foreign Exchange Component
E.DOM	---	Cost for Equipments in the Local Currency Component

$$\text{COST} = \text{C.FEC} + \text{C.DOM} + \text{E.FEC} + \text{E.DOM}$$

The exchange rates used in the cost estimates are as follows:

$$\text{₱20} = \$1$$

$$\$1 = \text{₱155}$$

ITEM	1988				1989				1990				
	COST	C.FEC	C.DUH	E.FEC	E.DUH	C.FEC	C.DUH	E.FEC	E.DUH	C.FEC	C.DUH	E.FEC	E.DUH
1.0 SOURCE FACILITY	0.0	0.0	0.0	0.0	0.0	435.2	1177.6	512.0	435.2	2580.0	435.2	1177.6	512.0
(1) DEEP WELL	0.0	0.0	0.0	0.0	0.0	182.0	630.0	846.0	162.0	1800.0	162.0	630.0	846.0
(2) PUMPING FACILITY	0.0	0.0	0.0	0.0	0.0	350.0	0.0	350.0	0.0	0.0	0.0	0.0	
(3) PUMPING STATION	0.0	0.0	0.0	0.0	0.0	2520.0	0.0	2116.8	403.2	160.0	0.0	0.0	0.0
(4) REPAIR & IMPROVEMENT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
(5) RADIAL WELL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
(6) PUMP HOUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
(7) SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	7290.0	1807.6	3821.8	1000.4	4460.0	547.2	1807.6	218.0
2.0 TRANSMISSION FACILITIES	0.0	0.0	0.0	0.0	0.0	5419.0	1517.3	1679.5	1246.4	2375.0	477.5	645.0	546.3
(1) Pipelines	0.0	0.0	0.0	0.0	0.0	5419.0	1517.3	1679.5	1246.4	2375.0	477.5	645.0	546.3
(2) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3) WATER PURIFICATION PLANT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(4) Slow Sand Filtration	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5) SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	5419.0	1517.3	1679.5	1246.4	2375.0	477.5	645.0	546.3
3.0 DISTRIBUTION FACILITIES	0.0	0.0	0.0	0.0	0.0	2845.0	798.6	881.9	654.4	1685.0	303.3	471.8	387.6
(1) Reservoir	0.0	0.0	0.0	0.0	0.0	2845.0	798.6	881.9	654.4	1685.0	303.3	471.8	387.6
(2) Pump Facility	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3) Chlorination Facility	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(4) Electric Sub-station	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5) Distribution Pipes	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6) Main Pipes	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7) Driver Crossing Material	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8) Valves	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(9) Internal Network	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(10) Service Connections	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(11) Water Meter	571.0	0.0	0.0	0.0	0.0	571.0	0.0	571.0	0.0	0.0	0.0	0.0	0.0
(12) Svc Concn Rbltn w/Hr	110.0	2.0	30.2	7.0	10.4	116.0	2.9	72.5	10.4	116.0	2.9	72.5	10.4
(13) Svc Concn Rbltn w/Hr	411.0	4.1	41.1	12.3	349.4	411.0	4.1	349.4	16.4	411.0	4.1	349.4	16.4
(14) Lateral Rehabilitation	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(15) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(16) Fire Protection	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(17) SUB-TOTAL	1088.0	7.0	71.3	19.3	982.9	2845.0	798.6	881.9	654.4	1685.0	303.3	471.8	387.6
4.0 ADMINISTRATION BLDG	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(1) Administration Bldg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2) Operation Center	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3) SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5.0 LAND ACQUISITION	132.0	7.0	71.3	19.3	982.9	132.0	0.0	150.0	150.0	300.0	0.0	0.0	0.0
(1) Land Acquisition	132.0	7.0	71.3	19.3	982.9	132.0	0.0	150.0	150.0	300.0	0.0	0.0	0.0
(2) Stored Material & Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3) SUB-TOTAL	132.0	7.0	71.3	19.3	982.9	132.0	0.0	150.0	150.0	300.0	0.0	0.0	0.0
6.0 REPLACEMENT OF EQUIP.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(1) Well Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2) Chlorinator	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(4) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5) Booster Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6) Operation Center	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7) Vehicle	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8) Stored Material & Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(9) SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7.0 LEAKAGE DETECTION	1891.0	7.0	544.3	19.3	1154.7	1891.0	0.0	150.0	150.0	341.0	0.0	0.0	0.0
(1) Leakage Detection	1891.0	7.0	544.3	19.3	1154.7	1891.0	0.0	150.0	150.0	341.0	0.0	0.0	0.0
(2) SUB-TOTAL	1891.0	7.0	544.3	19.3	1154.7	1891.0	0.0	150.0	150.0	341.0	0.0	0.0	0.0
GRAND TOTAL	1891.0	7.0	544.3	19.3	1154.7	1891.0	10374.5	14006.4	4969.4	14166.0	1897.4	4476.0	2343.6

ITEM	1988				1989				1990				
	COST	C.FEC	C.DUH	E.FEC	E.DUH	C.FEC	C.DUH	E.FEC	E.DUH	C.FEC	C.DUH	E.FEC	E.DUH
1 Deep Well Facilities	0.0	0.0	0.0	0.0	0.0	587.2	1847.6	3624.8	1090.4	4660.0	587.2	1847.6	3624.8
2 Transmission Facilities	0.0	0.0	0.0	0.0	0.0	975.4	1517.3	1679.5	1246.4	2375.0	427.5	665.0	546.3
3 Purification Plant	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
4 Reservoir	0.0	0.0	0.0	0.0	0.0	753.9	1883.7	141.9	115.9	0.0	0.0	0.0	0.0
5 Disinfection Facilities	0.0	0.0	0.0	0.0	0.0	51.0	366.9	486.2	161.0	0.0	0.0	0.0	0.0
6 Electric Sub-station	0.0	0.0	0.0	0.0	0.0	401.1	576.4	1375.5	262.0	0.0	0.0	0.0	0.0
7 Distribution Facilities	0.0	0.0	0.0	0.0	0.0	1080.0	3151.2	567.3	4342.7	5382.0	856.3	1500.6	1096.1
8 Service Connection	1098.0	7.0	71.3	19.3	982.9	163.0	163.0	1215.0	64.1	1462.0	16.4	164.8	64.2
9 Admin. Bldg & Bns. Ctr.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10 Land Acquisition	132.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11 Vehicle & Stored Material	320.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12 Replacement of Equip.	1584.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13 Leakage Detection	1891.0	7.0	544.3	19.3	1154.7	1891.0	0.0	150.0	150.0	341.0	0.0	0.0	0.0
TOTAL	1891.0	7.0	544.3	19.3	1154.7	1891.0	10374.5	14006.4	4969.4	14166.0	1897.4	4476.0	2343.6

ITEM	1992			1994			1995			E. DMN			
	COST	C. FE.C.	C. DMN	E. FE.C.	E. DMN	C. FE.C.	C. DMN	E. FE.C.	E. DMN				
1.0 SOURCE FACILITY	640.0	108.8	284.4	128.0	108.8	1280.0	217.6	588.8	64.0	256.0	217.6	108.8	108.8
(1) DEEP WELL													
(2) PUMPING FACILITY	450.0	40.5	157.5	211.5	40.5	900.0	81.0	315.0	45.0	423.0	81.0	40.5	40.5
2) Flow Meter	25.0	0.0	0.0	25.0	0.0	50.0	0.0	0.0	0.0	50.0	0.0	0.0	0.0
(3) REPAIR & IMPROVEMENT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(4) RADIAL WELL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5) PUMP HOUSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUB-TOTAL	1115.0	149.3	451.9	361.5	149.3	2230.0	248.6	903.8	103.0	722.0	248.6	149.3	149.3
2.0 TRANSMISSION FACILITIES													
(1) Pipelines	511.0	92.0	143.1	188.4	92.0	918.0	165.2	257.0	36.7	284.7	165.2	92.0	92.0
(2) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUB-TOTAL	511.0	92.0	143.1	188.4	92.0	918.0	165.2	257.0	36.7	284.7	165.2	92.0	92.0
3.0 WATER PURIFICATION PLANT													
(1) Slow Sand Filtration	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4.0 DISTRIBUTION FACILITIES													
(1) Reservoir	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2) Pump Facility	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3) Distribution Facility	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(4) Electric Sub-station	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5) Distribution pipes	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1) Main Pipes	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
2) River Crossing	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3) River Crossing Material	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4) Valves	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5) Internal Network	180.0	28.8	50.4	61.2	28.8	179.0	29.4	50.1	7.2	60.9	29.4	28.8	28.8
6) Service Connections	618.0	6.2	61.8	525.3	6.2	620.0	6.2	62.0	18.6	527.0	6.2	6.2	6.2
7) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8) Srvc Concn Khln In v/A	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9) Srvc Concn Khln w/H	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10) Lateral Rehabilitation	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUB-TOTAL	798.0	35.0	112.2	586.5	35.0	789.0	34.8	112.1	25.8	587.3	34.8	35.0	35.0
5.0 ADMINISTRATION BLDG													
(1) Administration Bldg	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2) Operation Center	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6.0 LAND ACQUISITION													
(1) Vehicle	2124.0	276.3	707.2	1109.4	276.3	3947.0	489.6	1272.9	171.5	1601.6	489.6	276.3	276.3
(2) Stored Material & Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUB-TOTAL	2124.0	276.3	707.2	1109.4	276.3	3947.0	489.6	1272.9	171.5	1601.6	489.6	276.3	276.3
7.0 REPLACEMENT OF EQUIP.													
(1) Well Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(2) Chlorinator	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(3) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(4) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(5) Booster Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(6) Infiltration Tank	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(7) Vehicle	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
(8) Stored Material & Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8.0 LEAKAGE DETECTION													
(1) Leakage Detection	2453.0	276.3	707.2	1133.8	276.3	3951.0	494.6	1272.9	171.5	1638.6	494.6	276.3	276.3
GRAND TOTAL	2453.0	276.3	707.2	1133.8	276.3	3951.0	494.6	1272.9	171.5	1638.6	494.6	276.3	276.3

ITEM	1993			1994			1995			E. DMN			
	COST	C. FE.C.	C. DMN	E. FE.C.	E. DMN	C. FE.C.	C. DMN	E. FE.C.	E. DMN				
1 Deep Well Facilities	1115.0	149.3	451.9	149.3	149.3	2230.0	248.6	903.8	103.0	729.0	248.6	149.3	149.3
2 Transmission Facilities	511.0	92.0	143.1	188.4	92.0	918.0	165.2	257.0	36.7	284.7	165.2	92.0	92.0
3 Purification Plant	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4 Reservoir	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5 Disinfection Facilities	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6 Electric Sub-station	180.0	28.8	50.4	61.2	28.8	179.0	29.4	50.1	7.2	60.9	29.4	28.8	28.8
7 Distribution Facilities	618.0	6.2	61.8	525.3	6.2	620.0	6.2	62.0	18.6	527.0	6.2	6.2	6.2
8 Service Connection	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9 Admin. Bldg. & Op. Ctr.	29.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10 Land Acquisition	29.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11 Vehicle & Stored Material	2453.0	276.3	707.2	1133.8	276.3	3947.0	494.6	1272.9	171.5	1638.6	494.6	276.3	276.3
12 Replacement of Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
13 Leakage Detection	2453.0	276.3	707.2	1133.8	276.3	3951.0	494.6	1272.9	171.5	1638.6	494.6	276.3	276.3
TOTAL	2453.0	276.3	707.2	1133.8	276.3	3951.0	494.6	1272.9	171.5	1638.6	494.6	276.3	276.3

No.	ITEM	Phase 1 (Stage 2)		Phase 1 (Stage 1)		Phase 1 (Stage 2)		Phase 1 (Stage 1)		Phase 1 (Stage 2)		Phase 1 (Stage 1)		Phase 1 (Stage 2)		Phase 1 (Stage 1)		Phase 1 (Stage 2)		Phase 1 (Stage 1)		Phase 1 (Stage 2)	
		C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH	C.F.F.C.	E. DMH
1.0	SOURCE FACILITY	4180.0	761.6	2000.8	761.6	9800.0	1632.0	4416.0	480.0	1820.0	1822.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	(1) DEEP WELL																						
	(2) PUMPING FACILITY	3150.0	283.5	1102.5	283.5	6756.0	607.5	2962.5	337.5	3172.5	807.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	1) Pumping Station	175.0	0.0	0.0	0.0	2620.0	0.0	0.0	0.0	2200.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	2) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(3) REPAIR & IMPROVEMENT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(4) RADIAL WELL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(5) PUMP HOUSE	7805.0	1045.1	3165.3	361.5	12985.0	2229.5	6778.5	817.5	7819.3	2659.7	13203.0	3142.0	5125.4	597.3	4384.3	650.7	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	3835.0	606.3	1073.8	153.3	11629.0	2093.2	3256.1	465.1	3605.0	2674.7	43624.0	7816.3	12158.7	1737.0	13461.5	9987.5	0.0	0.0	0.0	0.0	0.0	
	(2) Pipeline	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(2) Pipeline	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	3835.0	606.3	1073.8	153.3	11629.0	2093.2	3256.1	465.1	3605.0	2674.7	43624.0	7816.3	12158.7	1737.0	13461.5	9987.5	0.0	0.0	0.0	0.0	0.0	
2.0	WATER PURIFICATION PLANT	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(1) Slow Sand Filtration	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
3.0	DISTRIBUTION FACILITIES	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(1) Reservoir	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(2) Pumping Facility	800.0	0.0	0.0	0.0	3815.0	85.6	1246.0	202.4	417.5	115.9	4462.0	1134.1	2635.3	385.3	218.1	174.5	0.0	0.0	0.0	0.0	0.0	
	(3) Chlorination Facility	0.0	0.0	0.0	0.0	1079.0	54.0	306.5	32.4	496.2	161.9	5142.0	102.8	1845.4	308.5	282.8	565.6	0.0	0.0	0.0	0.0	0.0	
	(4) Electric Sub-station	0.0	0.0	0.0	0.0	2520.0	406.1	576.4	52.4	1375.5	262.0	1020.0	158.1	224.4	20.4	535.5	102.0	0.0	0.0	0.0	0.0	0.0	
	(5) Distribution Pipes	4073.0	733.1	1140.4	162.9	8603.0	1549.5	2408.8	341.1	2065.8	1979.8	6117.0	1101.1	1712.8	244.7	1806.2	1406.0	0.0	0.0	0.0	0.0	0.0	
	1) Main Pipes	0.0	0.0	0.0	0.0	199.0	85.6	113.4	15.9	42.7	32.3	487.0	213.7	283.3	38.8	58.1	43.3	0.0	0.0	0.0	0.0	0.0	
	2) River Crossing Material	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	3) Valves	516.0	10.3	108.4	31.0	2661.0	53.2	558.8	158.7	1809.5	231.5	390.0	6.8	71.4	20.4	231.2	30.6	0.0	0.0	0.0	0.0	0.0	
	5) Internal Network	808.0	143.6	251.4	36.0	5977.0	95.4	1665.1	238.0	2022.1	1308.4	6981.0	973.0	1702.7	243.2	2067.5	1337.8	0.0	0.0	0.0	0.0	0.0	
	6) Service Connections	3095.0	31.0	309.5	92.8	4963.0	49.7	496.3	198.9	4218.5	198.5	7261.0	72.6	726.1	217.8	6171.9	290.4	0.0	0.0	0.0	0.0	0.0	
	7) Water Meter	0.0	0.0	0.0	0.0	571.0	0.0	0.0	0.0	571.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	8) Svc Concn Rbltn w/4	0.0	0.0	0.0	0.0	318.0	8.7	86.6	21.0	217.5	31.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	9) Svc Concn Rbltn w/4	0.0	0.0	0.0	0.0	123.0	12.3	159.3	22.8	185.5	128.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	10) Labors? Rehabilitation	0.0	0.0	0.0	0.0	571.0	0.0	0.0	0.0	571.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(1) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(2) Fire Protection	0.0	0.0	0.0	0.0	35683.0	4113.6	9088.0	1521.2	16926.5	4953.7	34939.0	3811.9	10273.1	1772.0	16559.8	4264.2	0.0	0.0	0.0	0.0	0.0	0.0
	SUB-TOTAL	3582.0	918.0	1894.2	322.7	13915.6	35683.0	9088.0	1521.2	16926.5	4953.7	34939.0	3811.9	10273.1	1772.0	16559.8	4264.2	0.0	0.0	0.0	0.0	0.0	
5.0	ADMINISTRATION BLDG	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(1) Administration Bldg	0.0	0.0	0.0	0.0	1389.0	124.2	565.8	69.0	496.8	133.2	1610.0	161.0	869.4	80.5	257.6	322.0	0.0	0.0	0.0	0.0	0.0	0.0
	(2) Operation Center	0.0	0.0	0.0	0.0	4380.0	624.2	565.8	69.0	496.8	133.2	1610.0	161.0	869.4	80.5	257.6	322.0	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	2102.0	2453.4	6044.8	857.5	6817.0	857.5	20284.6	2873.8	28884.6	10380.5	10720.0	13093.1	33292.1	4769.4	35045.0	15310.8	0.0	0.0	0.0	0.0	0.0	0.0
6.0	LAND ACQUISITION	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	Vehicle	300.0	0.0	0.0	0.0	300.0	0.0	0.0	0.0	300.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	Stored Material & Equip.	247.0	0.0	0.0	0.0	750.0	0.0	0.0	0.0	503.1	119.9	898.0	0.0	1320.0	0.0	450.0	450.0	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	547.0	0.0	0.0	0.0	1050.0	0.0	0.0	0.0	803.1	119.9	898.0	0.0	1320.0	0.0	450.0	450.0	0.0	0.0	0.0	0.0	0.0	
7.0	REPLACEMENT OF EQUIP.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(1) Well Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(2) Chlorinator	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(3) Flow Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(4) Water Meter	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(5) Booster Pump	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(6) Operation Center	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(7) Vehicle	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	(8) Stored Material & Equip.	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	SUB-TOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
8.0	LEAKAGE DETECTION	21569.0	2653.4	6616.8	857.5	70989.0	8570.5	21441.6	2873.8	28826.7	11650.2	120169.0	19093.1	34582.1	4759.4	48174.0	18550.8	0.0	0.0	0.0	0.0	0.0	
	GRAND TOTAL	21569.0	2653.4	6616.8	857.5	70989.0	8570.5	21441.6	2873.8	28826.7	11650.2	120169.0	19093.1	3									

APPENDIX 8.2.1.C OPERATION AND MAINTENANCE COST (Dagupan City)

(cost; thousand peso)

Item		Stage 1	Stage 2	Phase II
		Cost	Cost	Cost
Operation & Maintenance Cost				
Salary	1,730 ₱/M.M	1,080	1,495	1,806
Power	0.50 ₱/kWh	484	746	1597
Chemical	27 ₱/kg	90	122	241
Miscellaneous		690	1,051	1,902
Maintenance		511	800	1,482
Total		2,855	4,214	7,028

APPENDIX 9.3.1 MARKET SURVEY

The market survey was conducted by interviews to the residents in the study area using the LWUA's interview sheet as per attached in the end of this section.

The total number of respondents and its estimated coverage ratio to the total number of households in the study area are as follows:

<u>Total Number of Respondents</u>	<u>Estimated Total Household</u>	<u>Coverage Ratio to Total Household</u>
4,050	11,616	35%

The results of the market survey are obtained as shown in TABLE 9.3.1.1.

From the market survey, the income distribution of the respondents are shown as follows:

<u>Income Bracket^{1/}</u>	<u>Ave. Pesos</u>	<u>Number</u>
₱900 and below	650	1,027
₱901 to ₱1500	1,224	1,227
₱1,501 to ₱2,500	2,121	674
₱2,501 to ₱4,500	3,501	458
₱4,501 and above	8,406	314

^{1/} Residential, excluding no-income and no-answer

TABLE 9.3.1.1 MARKET SURVEY SUMMARY

Total Number of Respondents: 4050

1. Distribution According to Building Type					
		No.	%		
a.	Residential	: 3727	92.02		
b.	Commercial	: 269	6.64		
c.	Industrial	: 54	1.33		
2. Distribution According to Source of Water					
		No.	%		
a.	Connected to System	: 1310	32.35		
b.	Neighbor's Connection	: 567	14.00		
c.	Public Faucet	: 1467	36.22		
d.	Private System	: 665	16.42		
e.	Water Vendor	: 26	0.64		
f.	Others	: 15	0.37		
3. Average Persons Per Household					
a.	Residential / Number of Sample	: 6.69 /	3711		
b.	Commercial / Number of Sample	: 6.78 /	267		
c.	Industrial / Number of Sample	: 8.76 /	54		
4. Willingness To Connect (%)					
		Residential	Commercial	Industrial	Total
a.	Yes	: 31.26	21.56	20.37	30.47
b.	No	: 36.84	29.00	44.44	36.42
c.	Undecided	: 0.78	0.74	0.00	0.77
d.	W/ Own Conn.:	31.12	48.70	35.19	32.35
5. Average Monthly Water Needs					
	Type / Number of Sample	Residential	Commercial	Industrial	
a.	Kerosene Can / 1006	: 10.23	8.71	5.50	
b.	Drum / 1705	: 2.33	3.98	5.02	
c.	Gallon / 194	: 62.65	10.71	10.00	
d.	Others / 1122	: 55.52	60.20	118.19	
6. Ave. Monthly Electric Bills for Residential Users (PESO):121.20					
Number of Effective Respondents				: 3122	
7. Income Distribution					
(Residential, Excluding No-Income and No-Answer)					
		AVE. PESO	NUMBER		
a.	P900 and Below	: 650	1027		
b.	P901 to P1500	: 1224	1227		
c.	P1501 to P2500	: 2121	674		
d.	P2501 to P4500	: 3501	458		
e.	P4501 and Above	: 8406	314		

Existing major sources of water for the respondents and willingness to connect by each source of water are :

<u>Sources of Water</u>	<u>Distribution</u>	<u>Willingness to Connect</u>	
		<u>Yes</u>	<u>No</u>
Connected to System	32%	- %	- %
Neighbor's Connection	14	64	34
Public Faucet	36	41	58
Private System	16	37	62

Public faucet and connections to the system are the major sources of water for the respondents. The rest draw their water needs from private systems and neighbor's connections. In addition, only 1% of the respondents depends on water vendors and others for its water sources. From the above table, the majority of the respondents using neighbor's connections are willing to connect to the waterworks system, while the majority of respondents using public faucet and private system are unwilling to connect to the waterworks system.

The following results on the distribution of water sources and willingness to connect according to income bracket of the respondents are also obtained from the market survey.

TABLE 9.3.1.2 DISTRIBUTION OF WILLINGNESS TO CONNECT BY INCOME BRACKET

<u>Sources of Water</u>	<u>Income Bracket</u>				
	<u>₱900 & below</u>	<u>₱901- ₱1,500</u>	<u>₱1,501- ₱2,500</u>	<u>₱2,501- ₱4,500</u>	<u>₱4,501- & above</u>
Connected to System	13 %	27 %	45 %	49 %	61 %
Neighbor's Connection	19	15	13	11	4
Public Faucet	53	42	27	18	10
Private System	14	15	15	21	25
<u>Willingness to Connect</u>					
Yes	33	33	29	29	20
No	54	39	26	21	19
Undecided	1	1	1	1	1
With Own Connection	12	27	44	49	60

As shown above, around 50% of the respondents belonging to the high income group is already connected to the existing waterworks system. However, the extension of waterworks is rather limited in the low income group, being dependent mainly on public faucet for their water sources.

As the result of market survey, the respondents' willingness to connect and the user's types are shown as follows :

<u>Answer</u>	<u>Residential</u>	<u>Commercial</u>	<u>Industrial</u>	<u>Total</u>
Yes :	31.3 %	21.6 %	20.4 %	30.5 %
No :	36.8	29.0	44.4	36.4
Undecided :	0.8	0.7	0.0	0.8
With Own Conn. :	31.1	48.7	35.2	32.3

Residential users account for 92% of the total respondents and willingness to connect on the part of the respondents is only 30% of the total, while unwillingness to connect is 36%. It is observed from the result of the market survey that one third of respondents, especially in the low income group, are not willing to connect to the waterworks system in Dagupan city.

In the calculation of Financial Internal Rate of Return (FIRR), the following two indicators are normally used to evaluate financial profitability of a project.

(1) Internal Rate of Return on Investment (IRROI)

The term IRROI indicates the internal rate of return on total capital investment, and assesses the profitability of the Project as a whole and the ability to recover funds invested in the Project.

The IRROI is calculated based on the assumption that the total capital investment is covered by its own capital. Therefore, the financial conditions such as the loan conditions on borrowed capital, changes on the ratio of equity to total capital requirement and others have no effect on the IRROI. Accordingly, the IRROI indicates the profitability of the Project itself.

(2) Internal Rate of Return on Equity (IRROE)

The term IRROE indicates the internal rate of return on equity, and assesses the profitability only with respect to equity and the ability to recover funds invested in the Project as equity. Here, the IRROE is calculated on the basis of such financial conditions proper to the Project as the loan conditions on borrowed capital and amount of capital owned.

In this study, the FIRR was calculated using the same method applied in the study report of the BACOLOD CITY WATER DISTRICT PHASE II WATER SUPPLY FEASIBILITY STUDY, DRAFT REPORT VOLUME 3 by LWUA.

APPENDIX 9.8.1 PROPOSED WATER RATE

The proposed water rates for 1/2 inch connections of commercial users, and 3/4 inch connections of domestic and commercial users to achieve financial self-sufficiency are as follows :

(1) Water rate for 1/2 inch connections of commercial users

<u>Period</u>	<u>Rate/ Unit</u>	<u>First 10cu.m</u>	<u>11-20cu.m</u>	<u>21-35cu.m</u>	<u>Above 35cu.m</u>
1988	₱1.0	₱ 50.0	₱ 6.8	₱ 9.2	₱13.0
1989	1.5	75.0	10.2	13.8	19.6
1990	1.5	75.0	10.2	13.8	19.6
1991	2.0	100.0	13.6	18.6	26.0
1992	2.6	130.0	17.6	24.0	33.8
1993	3.0	150.0	20.2	27.8	39.0
1994	3.2	160.0	21.6	29.6	41.6
1995	3.2	160.0	21.6	29.6	41.6
1996	3.9	195.0	26.4	36.0	50.8
1997	4.5	225.0	30.4	41.6	58.6

(2) Water rate for 3/4 inch connection of domestic users

<u>Period</u>	<u>Rate/ Unit</u>	<u>First 10cu.m</u>	<u>11-20cu.m</u>	<u>21-35cu.m</u>	<u>Above 35cu.m</u>
1988	₱1.0	₱ 40.0	₱ 5.4	₱ 7.4	₱10.4
1989	1.5	60.0	8.2	11.0	15.7
1990	1.5	60.0	8.2	11.0	15.7
1991	2.0	80.0	10.9	14.9	20.8
1992	2.6	104.0	14.1	19.2	27.0
1993	3.0	120.0	16.2	22.2	31.2
1994	3.2	128.0	17.3	23.7	33.3
1995	3.2	128.0	17.3	23.7	33.3
1996	3.9	156.0	21.1	28.8	40.6
1997	4.5	180.0	24.3	33.3	46.9

(3) Water rate for 3/4 inch connection of commercial users

<u>Period</u>	<u>Rate/ Unit</u>	<u>First 10cu.m</u>	<u>11-20cu.m</u>	<u>21-35cu.m</u>	<u>Above 35cu.m</u>
1988	₱1.0	₱80.0	₱10.8	₱14.8	₱20.8
1989	1.5	120.0	16.4	22.0	31.4
1990	1.5	120.0	16.4	22.0	31.4
1991	2.0	160.0	21.8	29.8	41.6
1992	2.6	208.0	28.2	38.4	54.0
1993	3.0	240.0	32.4	44.4	62.4
1994	3.2	256.0	34.6	47.4	66.6
1995	3.2	256.0	34.6	47.4	66.6
1996	3.9	312.0	42.2	57.6	81.2
1997	4.5	360.0	48.6	66.6	93.8

カブヤオ-サンタ・ロサ-ビニヤン, ラグナ県

APPENDIX 3.4.1 ELECTRIC CHARGES ADOPTED BY THE MERALCO

Residential

First 14 kwh	₱2.00 (Minimum Charge)
Next 36 kwh	0.125 per kwh
Next 50 kwh	0.15 per kwh
Next 100 kwh	0.20 per kwh
Excess kwh	0.365 per kwh

General Service

Classification

X-1 (Conn. Load : 1-500c Natis)

First 14 kwh	₱3.00 (Minimum Charge)
Next 76 kwh	0.21 per kwh
Excess kwh	0.365 per kwh

X-MD (Conn. Load : over 5,000 Natis)

Demand Charge	₱12.60 per kw
Plus Energy Charge	
First 100 hrs.	₱ 0.33 per kwh
Next 100 hrs.	0.28 per kwh
Next 100 hrs.	0.25 per kwh
Excess kwh	0.23 per kwh

APPENDIX 4.1.1 POPULATION AND NUMBER OF HOUSEHOLDS BY WATER SERVICE
MUNICIPALITY OF CABUYAO (1980)

Barangay	Population No. of HH	Level III System	Level I System (Point Source)			Total
			Well	Spring	Others	
	2298	1638	660	-	-	660
1. Bgy. I	383	273	110	-	-	110
	1590	1308	282	-	-	282
2. Bgy. II	265	218	47	-	-	47
	1698	1014	684	-	-	684
3. Bgy. III	283	169	114	-	-	114
	1320	-	1320	-	-	1320
4. Baclaran	220	-	220	-	-	220
5. Banay- banay	2946	-	2946	-	-	2946
	491	-	491	-	-	491
	3246	-	3222	36	-	3246
6. Banlic	541	-	537	6	-	541
	3954	972	2982	-	-	2982
7. Bigaa	659	162	497	-	-	497
	1632	-	1626	6	-	1632
8. Butong	272	-	271	1	-	272
	648	-	252	144	252	648
9. Casile	108	-	42	24	42	108
	588	-	576	12	-	588
10. Diezmo	98	-	96	2	-	98
	5112	-	5112	-	-	5112
11. Gulod	852	-	852	-	-	852
	4794	-	4794	-	-	4794
12. Mamatid	799	-	799	-	-	799
	5376	-	5376	-	-	5376
13. Marinig	896	-	896	-	-	896
	3588	-	3588	-	-	3588
14. Niugan	598	-	598	-	-	598
	450	-	390	-	60	450
15. Pittland	75	-	65	-	10	75
	2892	-	2892	-	-	2892
16. Pulo	482	-	482	-	-	482
	3042	582	2424	36	-	2460
17. Sala	507	97	404	6	-	410
	1998	-	1998	-	-	1998
18. San Isidro	333	-	333	-	-	333
Total	47172	5514	41112	234	312	41658
	7862	919	6852	39	52	6943

Note: Above : Population
Below : No. of Households

Source: Comprehensive Development Plan

APPENDIX 4.1.2 POPULATION AND NUMBER OF HOUSEHOLDS SERVED BY WATER
SOURCE MUNICIPALITY OF STA. ROSA (1980)

Barangay	Population No. of HH	Level III System	Level I System(Point Source)		Total
			Well/Spring	Others	
1. Kan- luran	4794 799 3198	1038 173 942	1722 287 606	2034 339 1650	3756 626 2256
2. Malusok	533 2142	157 228	101 1404	275 510	376 1914
3. Market - Area	357 7134	38 246	234 6444	85 444	319 6888
4. Aplaya	1189 5736	41 1350	1074 1788	74 2598	1148 4386
5. Balibago	956 4716	225	298 4716	433	731 4716
6. Caingin	786 2376	- 132	786 1146	- 1098	786 2244
7. Dila	396 5172	22 546	191 3558	183 1068	374 4626
8. Dita	862 1416	91	593 1416	178	771 1416
9. Don Jose	236 1626	- 366	236 492	- 768	236 1260
10. Ibaba	271 3120	61 288	82 2310	128 522	210 2832
11. Labas	520	48	385	87	472
12. Maka- biling	3312 552	-	3108 518	204 34	3312 552
13. Malit- lit	2964 494 4836	-	2898 483 4824	66 11 16	2964 494 4836
14. Pook	806	-	804	2	806
15. Pulong Sta.Cruz	3156 526	-	2634 439	522 87	3156 526
16. Sto, Domingo	714 119 6588	-	714 119 6372	- - 216	714 119 6588
17. Sinalahan	1098 6900	- 840	1062 4386	36 1674	1098 6060
18. Tagapo	1150	140	731	279	1010
TOTAL	69900 11650	5976 996	50502 8417	13422 2237	63924 10654

Note: Above : Population
Below : No. of Households

Source: Comprehensive Development Plan

APPENDIX 4.1.3 POPULATION AND NUMBER OF HOUSEHOLDS SERVED BY WATER
SOURCE MUNICIPALITY OF BINAN (1980)

Barangay	Population No. of HH	Level III	Point Source with Pitcher Pump			Point Source
			Public Well	Private Well	Total	
	8238	150	156	3216	3372	4716
1. Canlalay	1373	25	26	536	562	786
	600		24	264	288	312
2. Casile	100	-	4	44	48	52
	14766	276	282	5736	6018	8472
3. dela Paz	2461	46	47	956	1003	1412
	15174	264	264	5388	5652	9258
4. Malaban	2529	44	44	898	942	1543
	4044	858	66	1350	1416	1770
5. Poblacion	674	143	11	225	236	295
6. San Antonio	14100	2088	282	5682	5964	6048
	2350	348	47	947	994	1008
	4062	366	78	1602	1680	2016
7. San Jose	677	61	13	267	280	336
8. San Vicente	7650	222	144	2970	3114	4314
	1275	37	24	495	519	719
9. Sto. Domingo	2856	138	60	1230	1290	1428
	476	23	10	205	215	238
	228	60	12		72	156
10. Biñan	38	10	2		12	26
	222		12	48	60	162
11. Bungahan	37		2	8	10	27
	1320		36	408	456	864
12. Calabuso	220	-	6	68	76	144
	366		12	36	48	318
13. Ganado	61	-	2	6	8	53
	1608		36	456	492	1116
14. Halang	268	-	6	76	82	186
	828		24		144	660
15. Langkiwa	138	-	4	24	28	110
	762		24	180	204	558
16. Loma	127	-	4	30	34	93
	90		6	12	18	72
17. Malamig	15	-	1	2	3	12
18. Mamp-lasan	1056		30	306	336	720
	176	-	5	51	56	120
	4026	216	72	1476	1548	2262
19. Platero	671	36	12	246	258	377
	1086		36	138	174	912
20. San Anton	181	-	6	23	29	152
21. Soro-Soro	996	-	36	168	204	792
	166	-	6	28	34	132
	624		18	126	144	480
22. Timbao	104	-	3	21	24	80
	2292		60	168	228	2064
23. Tubigan	382	-	10	28	38	344
	276		12	60	72	204
24. Zapote	46	-	2	10	12	34
	87270	4578	1782	31236	33018	49674
TOTAL	14545	763	297	5206	5503	8279

Note: Above : Population
Below : No. of Households
Source: Municipal Development Plan

APPENDIX 4.2.1 SURVEY FOR ESTIMATION OF C-VALUE

A section of the transmission pipeline was selected for the purpose of this survey. Measurements of water pressure and flow rate were conducted at the two points throughout the day. The selection criteria for the section of the pipeline are:

- 1) There is no distribution of water in the section.
- 2) There is easy access to the points. Also electricity is available.
- 3) Water pressure can be measured using existing devices.

The section between the reservoir area to Cabuyao (diameter of pipes, 250 mm; length, approximately 7 km) was selected in the light of the above conditions.

The test at the selected points was implemented during the unaccounted-for-water/not utilized water survey. Although the two points were measured on different dates, both points were measured for about 7 hours. The flow rates in the selected section fluctuated at a certain range daily, but it was expected that the range would be negligible during week days. However, the supplementary measurements mentioned above were still taken into account. FIGURE 4.2.1.1 shows the location of measuring points.




FIGURE 4.2.1.1 LOCATION OF MEASURING POINTS


The flow rate in the Cabuyao-Sta. Rosa line is directly affected by the operation of the valve at the reservoir. The time period for analysis was determined to be for four hours, from 1:00 P.M. to 5:00 P.M. thus avoiding the valve operation time.

The average flow velocity is about 1.4 m/s, thus the time log is estimated at one hour between the two points. TABLE 4.2.1.2 shows the measurement result on the requirements.

TABLE 4.2.1.2 MEASUREMENT RESULTS

Time	Item	Reservoir			Cabuyao Inlet		
		Flow Rate cu.m/hr.	Velocity m/s	Pressure (m)	Flow Rate cu.m/hr.	Velocity m/s	Pressure (m)
13:00		270	1.33	0.4	-	-	-
14:00		274	1.35	0.4	274	1.35	13.3
15:00		289	1.42	0.4	281	1.38	16.9
16:00		293	1.44	0.4	289	1.42	19.0
17:00		-	-	-	295	1.45	19.8
Average		282	1.39	0.4	285	1.40	17.3

FIGURE 4.2.1.2 - presents the profiles of hydraulic grade-line and computation result of "C" value.



UPSTREAM (Reservoir area)

$Q = 282 \text{ m}^3/\text{hr} = 0.0783 \text{ m}^3/\text{sec}$

ELEVATION = 76.2 m

PRESSURE HEAD = 0.4 m

PIPE DIAMETER = 250 mm

COMPUTATION ;

$C = 3.59028 \cdot Q_{ave} \cdot D^{-2.63} \cdot H^{-0.54} \cdot L^{0.54}$

Thus;

$C = 3.5902 \times 0.0787 \times (0.25)^{-2.63}$

$\times (49.2)^{-0.54} \times (5680)^{0.54} = 141$

DOWNSTREAM (Entrance of Cabuyao)

$Q = 285 \text{ m}^3/\text{hr} = 0.0792 \text{ m}^3/\text{sec}$

ELEVATION = 10.1 m

PRESSURE HEAD = 17.3

PIPE DIAMETER = 250 mm

Where ;

$Q_{ave} = 1/2 (0.078 + 0.0792) = 0.0787$

$D = 0.250 \text{ m}$

$L = 5.680 \text{ m}$

$H = (76.2 + 0.4) - (10.1 + 17.3) = 49.2$

FIGURE 4.2.1.2 PROFILE OF HYDRAULIC GRADE LINE

APPENDIX 4.2.2 WATER PRESSURE IN THE SERVICE AREA

The preliminary survey revealed that many of the houses possess additional faucets. The water pressure measurements were done outside the houses covering 36 points; 7 in Cabuyao, 17 in Sta. Rosa and 12 in Biñan. (10 points: Automatic Pressure Recorder). The survey was conducted for three days to cover the three areas, one day for each area. Two shifts had been adopted due to the measuring requirement throughout the day.

TABLE 4.2.2.1 and FIGURE 4.2.2.1. show the selected points for this test. FIGURE 4.2.2.2 shows contour line covering the 3 municipalities.

The measurement records for every hour at the 36 points throughout the day are shown in TABLE 4.2.2.2. The contour lines are prepared for the total water head and water pressure based on the records at 7:00 A.M. and 1:00 P.M. which may represent the hours in maximum and minimum water consumption throughout the day, respectively. FIGURE 4.2.2.3.A to FIGURE 4.2.2.3.L present the contour lines by municipality. The total water head at the measurement point is calculated using the topographical contour prepared by each municipality.

TABLE 4.2.2.1 LOCATION OF SELECTED POINTS FOR PRESSURE TEST

No.	Elevation (GL m)	Address of the Selected Point	R.M.
1	13	Sala, Cabuyao	APR
2	11	144, Sala, Cabuyao	
3	8	8, P. Burgos St. Cabuyao	
4	7	156, Bigaa, Cabuyao	
5	9	M.H. Del Pilar St., Cabuyao	
6	10	59, AM. Roxas St., Cabuyao	
7	9	176, Malvar St., Cabuyao	
8	9	Max. Pueblo, Sta. Rosa	APR
9	16	1816, Dita, Sta. Rosa	
10	13	1586, Dila, Sta. Rosa	
11	12	1211, Balibago, Sta. Rosa	
12	13	13th, F. Reyes St. Balibago, Sta. Rosa	
13	9	890, Rizal St. Labas, Sta. Rosa	
14	7	1176, Lucero St. Malusok, Sta. Rosa	
15	8	J.P. Riza, Sta. Rosa	APR
16	6	180, Ibaba, Sta. Rosa	
17	4	Aplaya, Sta. Rosa	APR
18	9	1072, Lucero St., Sta. Rosa	
19	9	686, P. Gomez St., Sta. Rosa	
20	7	Tatlong Hari, Sta. Rosa	APR
21	7	Tatlong Hari, Sta. Rosa	APR
22	9	7, Tagapo, Sta. Rosa	
23	9	Hi-way, Tagapo, Sta. Rosa	
24	13	Balibago, Hi-way, Sta. Rosa	
25	9	Platero, Biñan	
26	8	Monalat, Biñan	
27	8	780, Balintawak St., Biñan	
28	7	Manabat, Biñan	APR
29	4	497, Dalampasigan St., Malabon, Biñan	
30	6	828, Dela Paz, Biñan	
31	8	Capinpin St., Biñan	APR
32	8	55, Dr. A. Gonzales St., San Jose, Biñan	
33	9	67, A. Bonifacio St. Canlacay, Biñan	
34	9	San Vicente, Biñan	
35	9	San Vicente, Biñan	APR
36	8	Bonifacio St., Biñan	APR

Note: APR ---- Automatic Pressure Recorder



FIGURE 4.2.2.2
CONTOUR MAP

DATE	PROJECT	SCALE	PAGE NO.
	STUDY OF MUNICIPAL WASTE DISPOSAL PROJECT		
PREPARED BY			
CHECKED BY			
DATE			


(Unit: kg/cm²)

TABLE - 4.2.2.2 PRESSURE TEST

Hour No.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
1	1.3	1.3	1.7	1.7	1.7	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	0.9	0.9	0.9	0.9	1.2	1.3	1.3	1.3
2	1.7	1.7	1.7	1.5	1.5	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.3	0.7	0.7	0.8	0.8	0.8	0.5	1.0	1.3	1.6	1.7
3	1.9	1.9	1.8	1.8	0.9	0.4	0.3	0.3	0.5	0.5	0.5	0.5	0.5	0.7	0.4	0.4	0.4	0.4	0.4	1.4	1.4	1.7	1.9	1.9
4	2.0	2.0	2.0	2.0	1.5	0.9	0.5	0.5	0.5	0.5	0.5	0.5	0.7	0.8	0.9	1.0	1.0	1.0	1.0	1.4	1.4	1.8	2.0	2.0
5	1.7	1.7	1.7	1.2	1.0	0.3	0.1	0.3	0.2	0.2	0.2	0.1	0.3	0.5	0.7	0.7	0.7	0.7	0.7	1.2	1.2	1.5	1.6	1.6
6	1.9	1.9	1.9	1.9	1.6	0.7	0.5	0.6	0.6	0.5	0.5	0.6	0.6	0.7	0.8	0.9	0.9	0.9	0.9	1.2	1.5	1.5	1.9	1.9
7	2.0	2.2	2.5	2.5	2.4	0.5	0.6	0.6	0.6	0.5	0.6	0.6	0.8	0.8	0.8	0.8	0.9	0.9	0.8	1.2	1.5	1.6	1.8	1.8
8	1.7	1.7	1.7	1.7	1.3	0.6	0.4	0.5	0.6	0.5	0.5	0.6	0.6	0.6	0.7	0.7	0.7	0.7	0.7	1.2	1.5	1.6	1.8	1.8
9	1.0	1.0	1.0	1.0	0.4	0	0	0	0	0	0	0	0	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
10	1.0	1.0	1.1	1.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
11	0.8	0.8	0.8	0.7	0.4	0	0	0	0	0	0	0	0	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
12	0.6	0.6	0.7	0.6	0.5	0.3	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	1.1	1.3	1.5	1.6	1.6
13	0.9	1.0	1.0	1.0	0.8	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
14	0.6	0.6	0.6	0.5	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
15	0.6	0.6	0.6	0.5	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
16	0.9	1.0	1.0	1.0	0.8	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
17	1.1	1.1	1.1	1.1	1.0	0.5	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	1.1	1.3	1.5	1.6	1.6
18	1.1	1.1	1.1	1.1	1.0	0.5	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	1.1	1.3	1.5	1.6	1.6
19	1.0	1.1	1.1	1.0	0.9	0.3	0.1	0.1	0.2	0.1	0.1	0.1	0.3	0.4	0.4	0.4	0.4	0.5	0.5	1.1	1.3	1.5	1.6	1.6
20	1.3	1.3	1.3	1.2	1.1	0.6	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.7	0.7	0.7	0.8	0.8	1.1	1.3	1.5	1.6	1.6
21	0.8	0.8	0.8	0.8	0.7	0.4	0.3	0.3	0.2	0.3	0.4	0.5	0.4	0.4	0.4	0.5	0.5	0.5	0.5	1.1	1.3	1.5	1.6	1.6
22	0.8	0.8	0.8	0.8	0.8	0.5	0.3	0.3	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
23	0.9	1.1	0.9	0.8	0.7	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
24	1.3	1.4	1.3	1.3	1.1	0.4	0.2	0.2	0.5	0.3	0.4	0.4	0.5	0.5	0.6	0.7	0.7	0.7	0.7	1.1	1.3	1.5	1.6	1.6
25	1.7	1.7	1.7	1.9	1.5	0.8	0.5	0.3	0.3	0.2	0.2	0.2	0.3	0.4	0.4	0.4	0.5	0.5	0.5	1.1	1.3	1.5	1.6	1.6
26	0.9	0.8	0.8	0.8	0.7	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
27	0.4	0.4	0.4	0.3	0.1	0.1	0.1	0.1	0	0	0	0	0	0	0	0	0	0	0	1.1	1.3	1.5	1.6	1.6
28	0.4	0.4	0.4	0.4	0.3	0.1	0.5	0.5	0.5	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
29	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
30	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
31	0	0	0	0	0	0.3	0.4	0.4	0.3	0.3	0.2	0.4	0.2	0.3	0.4	0.2	0.1	0.3	0.3	1.1	1.3	1.5	1.6	1.6
32	0.1	0.1	0.1	0.1	0	0	0.1	0.1	0.1	0	0	0	0	0	0	0	0	0	0	1.1	1.3	1.5	1.6	1.6
33	0.5	0.5	0.5	0.3	0.2	0.1	0.7	0.7	0.5	0.1	0.7	0.1	0	0	0	0	0	0	0	1.1	1.3	1.5	1.6	1.6
34	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0	0	0	0	0	0	0	0	1.1	1.3	1.5	1.6	1.6
35	0.5	0.5	0.5	0.5	0.4	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.1	1.3	1.5	1.6	1.6
36	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0	0	0	0	0	0	0	0	1.1	1.3	1.5	1.6	1.6


Note: Φ.1 : less than 0.1 kg/cm²

MUNICIPALITY OF CABUYAO



- MUNICIPAL BOUNDARY
- BARANGAY BOUNDARY
- 12- TOTAL WATER HEAD (m)

FIGURE 4.2.2.3.A
CONTOUR OF TOTAL WATER
HEAD IN CABUYAO (7:00 AM)




MUNICIPALITY OF CABUYAO



- MUNICIPAL BOUNDARY
- BARANGAY BOUNDARY
- 0.5 — WATER PRESSURE (kg/cm²)

FIGURE 4.2.2.3.B
CONTOUR LINE OF WATER
PRESSURE IN CABUYAO (7:00 AM)






FIGURE 4.2.2.3.C
CONTOUR LINE OF TOTAL
WATER HEAD IN STA. ROSA (7:00 AM)




FIGURE 4.2.2.3.F
CONTOUR LINE OF
WATER PRESSURE IN
BINAN (7:00 AM)


MUNICIPALITY OF BINAN

MUNICIPALITY OF CABUYAO



- MUNICIPAL BOUNDARY
- BARANGAY BOUNDARY
- 1.5 — WATER PRESSURE (kg/cm²)

FIGURE 4.2.2.3.H
CONTOUR LINE OF WATER
PRESSURE IN CABUYAO (1:00 AM)






FIGURE 4.2.2.3.1
 LINE OF TOTAL WATER
 HEAD IN STA. ROSA (1:00 AM)





FIGURE 4.2.2.3.K
CONTOUR LINE OF
TOTAL WATER HEAD IN
BIÑAN (1:00 AM)

MUNICIPALITY OF BIÑAN



APPENDIX 4.2.3 COLLECTED CHARGES FOR THE MONTH OF JUNE, 1986 BY
CONSUMER TYPE

Unit: Peso

Municipality	Barangay	Metered										Flat Rate					Total
		Domestic					Commercial					Without Meter					
		Domestic	Commercial	Institutional	Industrial	Sub-Total	Domestic	Commercial	Nonfunctioning	Insti.	Sub-Total	Domestic	Commer.	Insti.	Sub-Total		
Cabayao	1 Barangay I	6295.75	-	-	-	6295.75	750.00	10.00	30.00	790.00	44.00	14.00	30.00	88.00	7173.75		
	2 " II	5565.00	68.50	36.75	-	5702.25	402.00	-	-	402.00	-	-	-	-	6072.25		
	3 " III	3900.25	-	-	-	3900.25	287.75	-	-	287.75	-	-	-	-	4248.00		
	4 Bigaa	2937.75	-	-	-	2937.75	312.75	-	-	312.75	-	-	-	-	3250.50		
	5 Sala	3095.25	10.00	50.00	-	3155.25	137.75	-	10.00	147.75	14.00	-	-	14.00	3317.00		
	Sub-Total	21854.00	78.50	86.75	-	22019.25	1890.25	10.00	40.00	1940.25	58.00	14.00	30.00	102.00	24061.50		
Sta. Rosa	1 Aplaya	887.75	-	-	-	887.75	127.75	-	-	127.75	-	-	-	-	1015.50		
	2 Balibago	10155.00	14.50	-	4219.00	14388.50	897.25	66.25	-	963.50	14.00	-	-	14.00	15366.00		
	3 Barangay I	3523.00	10.00	-	-	3533.00	354.50	-	-	354.50	57.20	-	-	57.20	3944.70		
	4 " II	5874.25	10.00	-	-	5884.25	359.00	-	-	359.00	43.80	-	-	43.80	6287.05		
	5 " III	1009.00	-	-	-	1009.00	116.50	-	-	116.50	-	15.20	-	15.20	1140.70		
	6 Dila	416.75	-	-	1109.00	1525.75	30.00	-	-	30.00	-	-	-	-	1555.75		
	7 Dita	5990.50	2203.00	-	260.50	8454.00	260.25	-	13.00	273.25	14.00	-	-	14.00	8741.25		
	8 Ibaba	1812.75	-	-	-	1812.75	10.00	-	-	10.00	14.00	-	-	14.00	1836.75		
	9 Labas	1900.00	-	-	-	1900.00	139.50	-	-	139.50	-	-	-	-	2039.50		
	10 Macablang	347.50	-	-	147.00	494.50	42.00	-	-	42.00	-	-	-	-	536.50		
	11 Tagapo	4955.00	-	160.00	-	5115.00	69.25	-	-	69.25	28.60	-	-	28.60	5212.85		
Sub-Total	36871.50	2237.50	160.00	5735.50	45004.50	2406.00	66.25	13.00	2485.75	171.60	15.20	-	186.80	47676.55			
Binaan	1 Dela Paz	313.25	-	-	-	313.25	20.00	-	-	20.00	143.60	-	-	143.60	476.85		
	2 Malaban	176.50	-	-	-	176.50	34.00	-	-	34.00	340.80	-	15.20	356.00	566.50		
	3 Platero	1691.00	-	-	-	1691.00	219.75	-	-	219.75	-	-	-	1910.75			
	4 Poblacion	1472.25	189.50	-	-	1661.75	133.00	-	45.00	178.00	925.40	58.40	14.60	998.40	2838.15		
	5 San Antonio	7342.50	34.25	-	-	7376.75	716.25	-	-	716.25	1008.20	-	-	1008.20	9102.20		
	6 San Jose	607.50	-	-	-	607.50	22.00	-	-	22.00	403.40	-	-	403.40	1032.90		
	7 San Vicente	803.50	-	-	-	803.50	-	-	-	-	57.20	-	-	57.20	860.70		
	8 Sto. Domingo	175.25	-	-	-	175.25	-	-	-	-	199.60	-	-	199.60	374.85		
Sub-Total	12581.75	223.75	-	-	12805.50	1145.00	-	45.00	1190.00	3078.20	58.40	29.80	3166.70	17161.90			
Total	71307.25	2539.75	246.75	5735.50	79829.25	5441.25	76.25	98.00	5675.50	3307.80	87.60	59.80	3455.20	86899.95			

APPENDIX 4.3.1 SPRING DISCHARGE RATE

The discharge rate from the existing spring is 115.8 l/s or 10,008 cu.m/day. The total discharge volume from the four springs in the vicinity of the existing spring box, which may be tapped as additional sources of water, is approximately 40 l/s.

TABLE 4.3.1.1 DISCHARGE RATE FROM SPRINGS

Existing/ Potential	Point	l/s	Measurement Records
Existing spring box	ø 300	82.5	AM. 298 cu.m/hr. Ave. 297 cu.m/hr. PM. 295
	ø 200	33.3	AM. 120 Ave. 120 PM. 120
	Sub-Total	115.8	AM. 418 AVE. 417 PM. 415
Potential Source	No. 1	5.6	Required time to fill a drum-can 245 l : 43.8 sec
	No. 2	21.5	245 l : 11.4 sec
	No. 3	9.6	245 l : 25.4 sec
	No. 4	1.6	18 l : 11.0 sec
	Sub-Total	38.3	
TOTAL		154.1	

The discharge amount from the existing spring box is almost constant through the year (approximately 8 percent increase in rainy season compared to the amount during dry season). The amount from the four potential water sources (springs) is also constant through the year. TABLE 4.3.1.2 shows the figures measured in dry and rainy season.

TABLE 4.3.1.2 SPRING WATER MEASUREMENT RECORDS

Kind	Detail	Daily Discharge Rate		R. M.
		Dry	Rainy	
Existing spring box	ø 300	6,826 cu.m/d.	7,128	Difference between two seasons is less than 8%
	ø 200	2,462	2,880	
Sub-Total			9,288	10,008
Potential sources	4 springs	3,283	3,309	

APPENDIX 4.4.1 WATER CONSUMPTION (METERED CONNECTIONS) BY CONSUMER TYPE

Unit: cu.m/month or cu.m/day

Municipality	Barangay	Domestic		Commercial		Institutional		Industrial		Total	
		Monthly	Daily	Monthly	Daily	Monthly	Daily	Monthly	Daily	Monthly	Daily
Cabuyao	1 Barangay I	7,573	252.4	-	-	-	-	-	-	7,573	252.4
	2 Barangay II	6,643	221.4	99	3.3	45	1.5	-	-	6,787	226.2
	3 Barangay III	4,960	165.3	-	-	-	-	-	-	4,960	165.3
	4 Bigaa	3,742	124.7	-	-	-	-	-	-	3,742	124.7
	5 Sala	4,049	135.0	1	0.0	65	2.2	-	-	4,115	137.2
	Sub-Total	26,967	898.8	100	3.3	110	3.7	-	-	27,177	905.8
Sta. Rosa	1 Aplaya	1,155	38.5	-	-	-	-	-	-	1,155	38.5
	2 Balibago	11,760	392.0	19	0.6	-	-	2,851	95.0	14,630	487.6
	3 Barangay I	4,474	149.1	10	0.3	-	-	-	-	4,484	149.4
	4 Barangay II	7,290	243.0	-	-	4	0.1	-	-	7,294	243.1
	5 " III	1,212	40.4	-	-	-	-	-	-	1,212	40.4
	6 Dila	536	17.9	-	-	-	-	816	27.2	1,352	45.1
	7 Dita	7,611	253.7	1,507	50.2	-	-	212	7.1	9,330	311.0
	8 Ibaba	2,283	76.1	-	-	-	-	-	-	2,283	76.1
	9 Labas	2,249	75.0	-	-	-	-	-	-	2,249	75.0
	10 Macablang	401	13.4	-	-	-	-	-	-	401	13.4
	11 Tagapo	6,437	214.6	-	-	171	5.7	147	4.9	6,608	220.3
	Sub-Total	45,408	1,513.7	1,536	51.1	175	5.8	4,026	134.2	51,145	1,704.8
Biñan	1 Dela Paz	397	13.2	-	-	-	-	-	-	397	13.2
	2 Malaban	236	7.9	-	-	-	-	-	-	236	7.9
	3 Platero	2,100	70.0	-	-	-	-	-	-	2,100	70.0
	4 Poblacion	1,870	62.3	260	8.7	-	-	-	-	2,130	71.0
	5 San Antonio	9,283	309.4	49	1.6	-	-	-	-	9,332	311.0
	6 San Jose	761	25.4	-	-	-	-	-	-	761	25.4
	7 San Vicente	997	33.2	-	-	-	-	-	-	997	33.2
	8 Sto. Domingo	234	7.8	-	-	-	-	-	-	234	7.8
	Sub-Total	15,878	529.2	309	10.3	-	-	-	-	16,187	539.5
	Total	88,253	2,941.7	1,945	64.7	285	9.5	4,026	134.2	94,509	3,150.1

APPENDIX 4.5.1 UNACCOUNTED-FOR WATER/NOT-UTILIZED WATER

This survey comprises two major elements; one for the transmission lines and another for distribution networks in the selected model areas. The two study section of the transmission lines and the four areas are shown in FIGURE 4.5.1.1 and given below.

- Transmission Line : Cabuyao - Sta. Rosa Line ; one from the spring to reservoir area and another from the reservoir area to the entrance of Cabuyao

- Distribution network :
 - a) The core area of Cabuyao.
 - b) The Sta. Rosa area including the core area of the municipality and the area along Cabuyao - Sta. Rosa line in Sta. Rosa.
 - c) The area along Biñan line in Sta. Rosa.
 - d) The Biñan area.

A flow chart for this investigation and analysis is given in FIGURE 4.5.1.2.

(1) Background Information on the Study Sections of the Transmission Pipeline and the Study Areas

There are no residents along the transmission line from the spring to the entrance of Cabuyao. However, there are large houses approximately 300 m from the transmission pipeline upstream of the reservoir as shown in FIGURE 4.5.1.1. The aforementioned four areas are high population density areas. The following are some information on the study areas based on the field survey.

1) The core area of Cabuyao

The area consists of barangays Bigaa, Sala and Poblacion. The area is predominantly a residential area except for the area along J.P. Rizal St. near the public market which is used both for commercial and institutional purposes in barangay Sala.





FIGURE 4.5.1.1
STUDY AREA AND PIPELINE
SECTION

FIGURE 4.5.1.2 Flow Chart for estimation of unaccounted for water/
not utilized water



Commercial establishments are mainly eateries, grocery stores and a wet market that caters to the local constituents of the municipality.

- 2) The Sta. Rosa area; the core area of Sta. Rosa and the area along Cabuyao - Sta. Rosa line.

The subject area comprises barangays Aplaya, Balibago, Barangay I, II & III, Pila, Pita, Ibaba, Labas and Tagapo. Although there are many industrial establishments in Sta. Rosa, the area served by the water system is predominantly a residential area except for the municipal building, market and the school areas at the poblacion. Commercial establishments in the poblacion mainly caters to the local constituents.

- 3) The area along Biñan line in Sta. Rosa

The study area comprises barangays Balibago and Macabling in Sta. Rosa, and Platero in Biñan. The area is also residential.

- 4) Biñan area

The area includes barangays Dela Paz, Malaban, Platero, Poblacion, San Antonio, San Jose, San Vicente and Sto. Domingo. The area is predominantly a residential area. Commercial establishments include supermarkets, groceries, theaters and the supermarket where food products from other municipalities are regularly delivered.

Existing Water Supply

There are 726 metered domestic connections in Cabuyao, 719 of which are domestic, 4 commercial and 3 institutional connections.

A total of 49 domestic concessionaires or about 7% of the total number of concessionaires was interviewed.

Based on the 49 concessionaires interviewed, except for those at the fringes at barangays Bigaa and Sala, water supply including water pressure was said to be relatively adequate in the service area.

About 316 persons are served by the 49 interviewed domestic connections; 272 persons are primary users while 44 or about 16% of the primary users are secondary users or borrowers. The 49 connections registered a combined consumption of 61.257 cu.m for one day, or an average per capita consumption for the 316 served population of about 194 liters/day.

As of June 1986, there are 1,188 domestic connections, 3 commercial, 4 institutional and 5 industrial connections or a total of 1,200 service connections in the Sta. Rosa service area. One of these connections is the Nissin Monde Biscuits factory which draws about 2,850 cu.m of water monthly. Based on the 37 interviewed domestic concessionaires in the core area of Sta. Rosa, water supply and pressure are relatively adequate in the distribution system except for the area near the Balibago market which draws water from the Cabuyao - Sta. Rosa line. According to the 66 domestic concessionaires interviewed along the transmission lines, the same situation as in the market area is also experienced during the day, especially in the morning, along the Biñan transmission line in barangay Pulong St. Cruz, and the Cabuyao - Sta. Rosa transmission line along barangays Dita, Dila and Balibago. These areas get only enough water and pressure during the nighttime. Concessionaires often resort to storing water during the night for use the next day.

Along the distribution line, about 276 persons are served by the 37 interviewed domestic concessionaires; 197 persons are primary users while 79 or about 40% of the primary users are secondary users or borrowers. The 37 connections registered a combined consumption of 48.265 cu.m for one day, or an average per capita consumption for the 276 served population of about 175 liters/day.

Along the transmission line, about 572 persons are served by the 66 interviewed domestic concessionaires; 376 persons are primary users while 196 or about 52% of the primary users are secondary users or borrowers. The 37 connections registered a combined consumption of 80.100 cu.m for one day, or an average per capita consumption for the 572 served population of about 140 liters/day.

As of June 1986, there are 483 domestic and 7 commercial connections, or a total of 490 service connections in the Biñan service area.

According to the interviewed 37 domestic connections, the Biñan area has a scheduled supply of water; corresponding to the operation of the pump at the public market and at the subdivision in barangay Platero. The only area wherein water supply is available anytime is at barangays San Antonio and Platero which draw water from the Cabuyao-Sta. Rosa line. Water supply and pressure are so inadequate in the area that affluent concessionaires often install individual booster pumps. Especially in the poblacion area, interviewed concessionaires contend that they could not draw water anytime without a booster pump.

About 298 persons are served by the 35 domestic connections: 197 are primary users while 101 or 51% of the primary users are secondary users. The 35 domestic connections registered a combined consumption of 55.248 or an average per capita consumption of about 185 liters/day.

TABLE 4.5.1.1 summarizes the results of the interviews on the served population and daily consumption.

TABLE 4.5.1.1 SUMMARY OF INTERVIEWED DOMESTIC CONCESSIONAIRES

Area	Primary User		Secondary User		Secondary Primary	Total User		Daily Consumpt.	Per Capita Consumption liters/day
	H.H.	Pop.	H.H.	Pop.	%	H.H.	Pop.		
Cabuyao	49	272	7	44	16%	56	316	61.257	194
Sta. Rosa	37	197	20	79	40%	57	276	48.265	175
Biñan	35	197	23	101	51%	58	298	55.248	185
Area along Biñan line (Sta. Rosa)	66	376	49	196	52%	115	572	80.100	140

(2) Unit Water Consumption and Total Water Consumption

Unit water consumption by consumer type was estimated using reported water consumption (metered) for the month of June, 1986 including the secondary users/borrowers as based on the interview results. A summary of average unit water consumption by municipality both from recorded data for the month of June and results of meter reading during the interview is given in TABLE 4.5.1.2.

TABLE 4.5.1.2 UNIT WATER CONSUMPTION BY WATER CONSUMER TYPE (METERED)

Municipality	Domestic					
	Data in June l/cap.d	Data in June cu.m/con.d	Inter- view l/cap.d	Commer- cial cu.m/con.d	Institu- tional cu.m/con.d	Indus- trial cu.m/con.d
Cabuyao	173.6	1.250	194	1.100	1.223	-
Sta. Rosa	151.7	1.274	*175 140	17.033	1.450	26.840
Biñan	121.7	1.096	185	1.471	-	-
Total	150.8	1.231	174	4.621	1.357	26.840

Note: * Average in the core area. Average in the area along Biñan line.

With regard to the unit domestic consumption, the figures from meter reading are larger than those from the data for the month of June. The figures from the meter readings seem to correspond to the daily maximum as was gathered from the concessionaires during the interview. The average consumption figure by municipality corresponds to the water supply status in relation to the location of the spring water source with service

area. However the figures are comparatively larger than those of similar municipalities. It was concluded through interview with concessionaires and officials concerned that the figures may include the water caused by wastage and leakage in the section of service connection between the water meter and faucets.

The number of metered connections for commercial, institutional and industrial use is limited in the subject area. Therefore estimated average unit water consumption for these uses is not a reliable bases for future demand projection. The average figure by consumer type may however be used to estimate present water consumption by unmetered connections.

The total water consumption by study area as estimated is shown in TABLE 4.5.1.3. The following are the bases of calculation:

Metered connections:	Reported figures for the month of June by consumer type
Unmetered connections:	Estimated figures using municipal average per connection consumption and number of connections (Data on June 1986)

TABLE 4.5.1.4 summarizes the total water consumption in round figures by study area.

TABLE 4.5.1.3 (cont'd)

MAIN PIPELINE	INSTITUTIONAL				INDUSTRIAL				TOTAL
	MUNICIPALITY/ BARANGAY	FUNCTIONAL METERED	NON-FUNCTIONAL METERED w/out METER	TOTAL	FUNCTIONAL METERED	NON-FUNCTIONAL METERED w/out METER	TOTAL		
		CONNECTIONS H3/d	CONNECTION H3/d	CONN. H3/d	CONNECTIONS H3/d	CONNECTIONS H3/d	CONN. H3/d		
<u>CABUYAO</u>									
	1. BARANGAY I	-	3	4	3	4	-	-	-
	2. BARANGAY II	2	-	2	-	-	-	-	-
	3. BARANGAY III	-	-	-	-	-	-	-	-
	4. BIGAA	-	-	-	-	-	-	-	-
	5. SALA	1	1	41*	2	4	-	-	-
	<u>SUB-TOTAL</u>	3	4	45	7	4	-	-	-
<u>CABUYAO</u>									
<u>STA. ROSA</u>									
	1. APLAYA	-	-	-	-	-	-	-	-
	2. BALIBAGO	-	-	-	-	-	-	-	-
	3. BARANGAY I	-	-	-	-	-	-	-	-
	4. BARANGAY II	1	0	1	0	-	-	-	-
	5. BARANGAY III	-	-	-	-	-	-	-	-
	6. DILA	-	-	-	-	-	27	-	27
	7. DIYA	-	1	2	1	2	7	-	17
	8. IBABA	-	-	-	-	-	-	-	-
	9. LABAS	-	-	-	-	-	-	-	-
	10. TAGAPO	3	6	-	3	6	-	-	-
	<u>SUB-TOTAL</u>	7	6	1	2	5	8	34	34
	<u>TOTAL</u>	7	10	5	47	12	57	34	34
<u>BINANAN</u>									
	1. BALIBAGO	-	-	-	-	-	-	95	1
	2. MACABLING	-	-	-	-	-	-	5	1
	<u>SUB-TOTAL</u>	-	-	-	-	-	-	100	2
<u>BINANAN</u>									
	1. PLATERO	-	-	-	-	-	-	100	2
	<u>TOTAL</u>	-	-	-	-	-	-	100	2

TABLE 4.5.1.3 (cont'd)

MAIN PIPELINE	MUNICIPALITY/ BARANGAY	GRAND TOTAL						REMARKS
		FUNCTIONAL METERED		NON-FUNCTIONAL METERED		TOTAL		
		CONNECTIONS	H 3/d	CONNECTIONS	H 3/d	CONNECTIONS	M 3/d	
<u>CABUYAO</u>								
	1. BARANGAY I	203	252	36	45	239	297	
	2. BARANGAY II	183	226	28	35	211	261	
	3. BARANGAY III	130	165	14	18	144	183	
	4. BICAA	99	125	8	10	107	135	
	5. SALA	111	137	9	51	120	188	
	SUB-TOTAL	726	905	95	159	821	1064	
<u>STA. ROSA</u>								
	1. APLAYA	32	39	5	6	37	45	
	2. BALIBAGO	59	83	3	4	62	87	
	3. BARANGAY I	127	150	19	24	146	174	
	4. BARANGAY II	191	243	16	20	207	263	
	5. BARANGAY III	32	40	5	6	37	46	
	6. DILA	21	45	3	4	24	49	
	7. DITA	203	341	13	17	216	328	
	8. IBABA	64	76	2	3	66	79	
	9. LABAS	52	75	5	6	57	81	
	10. TAGAFO	182	221	6	8	188	229	
	SUB-TOTAL	963	1283	77	98	1040	1381	
	TOTAL	1689	2188	172	257	1861	2445	
<u>BIRAN</u>								
	1. BALIBAGO	221	405	23	29	244	434	
	2. MACABLING	14	18	1	1	15	19	
	SUB-TOTAL	235	423	24	30	259	453	
<u>PLATERO</u>								
	28	32	2	2	30	34		
	TOTAL	263	455	26	32	289	487	

*Municipal building consumption = 40 m³/day

TABLE 4.5.1.3 (cont'd)

DOMESTIC

COMMERCIAL

MAIN PIPELINE	BARANGAY	FUNCTIONAL METERED		NON-FUNCTIONAL METERED w/out METER		TOTAL		FUNCTIONAL METERED		NON-FUNCTIONAL METERED w/out METER		TOTAL	
		CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONN. H 3/4	CONN. H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONN. H 3/4	CONN. H 3/4	CONN. H 3/4	CONN. H 3/4
	<u>BIRAN</u>												
COMBINED CABUYAO AND BIRAN LINE	1. DE LA PAZ	14	13	12	13	23	26	-	-	-	-	-	-
	2. MALABAN	8	8	27	30	35	38	-	-	-	-	-	-
	3. PLATERO	29	38	5	6	34	44	-	-	-	-	-	-
	4. POBLACION	64	62	72	79	136	141	6	9	5	7	11	16
	5. SAN ANTONIO	263	309	120	132	383	441	1	2	-	-	1	2
	6. SAN JOSE	31	25	30	33	61	58	-	-	-	-	-	-
	7. SAN VICENTE	38	33	4	5	42	38	-	-	-	-	-	-
	8. STO. DOMINGO	8	8	14	15	22	23	-	-	-	-	-	-
	SUB-TOTAL	455	496	284	313	739	809	7	11	5	7	12	18

WATER SOURCE	BARANGAY	FUNCTIONAL METERED		NON-FUNCTIONAL METERED w/out METER		TOTAL		FUNCTIONAL METERED		NON-FUNCTIONAL METERED w/out METER		TOTAL	
		CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONN. H 3/4	CONN. H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONN. H 3/4	CONN. H 3/4	CONN. H 3/4	CONN. H 3/4
	<u>BIRAN</u>												
COMBINED CABUYAO AND BIRAN LINE	1. DE LA PAZ	-	-	-	-	-	-	-	-	-	-	-	-
	2. MALABAN	-	-	1	2	1	2	-	-	-	-	-	-
	3. PLATERO	-	-	-	-	-	-	-	-	-	-	-	-
	4. POBLACION	-	-	3	4	3	4	-	-	-	-	-	-
	5. SAN ANTONIO	-	-	-	-	-	-	-	-	-	-	-	-
	6. SAN JOSE	-	-	-	-	-	-	-	-	-	-	-	-
	7. SAN VICENTE	-	-	-	-	-	-	-	-	-	-	-	-
	8. STO. DOMINGO	-	-	-	-	-	-	-	-	-	-	-	-
	SUB-TOTAL	-	-	4	6	4	6	-	-	-	-	-	-

INDUSTRIAL

WATER SOURCE	BARANGAY	FUNCTIONAL METERED		NON-FUNCTIONAL METERED w/out METER		TOTAL		FUNCTIONAL METERED		NON-FUNCTIONAL METERED w/out METER		TOTAL	
		CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONN. H 3/4	CONN. H 3/4	CONNECTIONS H 3/4	CONNECTIONS H 3/4	CONN. H 3/4	CONN. H 3/4	CONN. H 3/4	CONN. H 3/4
	<u>BIRAN</u>												
COMBINED CABUYAO AND BIRAN LINE	1. DE LA PAZ	14	13	12	13	26	26	26	26	26	26	26	26
	2. MALABAN	8	8	28	32	36	40	36	40	36	40	36	40
	3. PLATERO	29	38	5	6	34	44	34	44	34	44	34	44
	4. POBLACION	70	141	80	90	150	231	150	231	150	231	150	231
	5. SAN ANTONIO	264	311	120	132	384	443	384	443	384	443	384	443
	6. SAN JOSE	31	25	30	33	61	58	61	58	61	58	61	58
	7. SAN VICENTE	38	33	4	5	42	38	42	38	42	38	42	38
	8. STO. DOMINGO	8	8	14	15	22	23	22	23	22	23	22	23
	SUB-TOTAL	462	577	293	326	755	903	755	903	755	903	755	903

REMARKS

TABLE 4.5.1.4 SUMMARY OF WATER CONSUMPTION BY STUDY AREA

Study Area	Unit: cu.m/day	
	Water Consumption	Percentage
a. Core area of Cabuyao	1,050	27.6
b. Core area and area along Cabuyao-Sta. Rosa line in Sta. Rosa	1,350	48.7
c. Area along Biñan line in Sta. Rosa	500	
d. Biñan area	900	23.7
T o t a l	3,800	100

(3) Flow Rate Measurement Results

The measurement results are summarized (rounded off) by section of pipeline in TABLE 4.5.1.5. Continuous measurement for one day was conducted at 6 points and a short time measurement at the spring and another point. Detailed records are given in TABLE 4.5.1.6.

TABLE 4.5.1.5 MEASUREMENT RESULTS

Section of Pipe Line	Measuring Point	Daily flow	R. M.
Transmission line: Spring - Reservoir area	Total of 2 outlets from existing spring	10,000	Details are given in "Discharge rate of Spring"
	Approx. 3 km from spring	11,000	reference point
Cabuyao-Sta. Rosa Line: Reservoir - exit of Sta. Rosa	Manhole in the premise of Reservoir	5,600	24 hours
	Entrance of core area of Cabuyao	5,600	"
	Outlet of Cabuyao	3,400	"
	Outlet of Sta. Rosa	50	" 53 cu.m/day = flow into Biñan line
Biñan Line: Reservoir area - Biñan area	Reservoir premise	4,050	24 hours
	Entrance of Biñan	1,550	"

TABLE 4.5.1.6 FLOW RATE MESUREMENT (24 HOURS)

CABUYAO TIME	CABUYAO STA. ROSA LINE	BIRAN LINE	RESERVOIR WATER LEVEL	STORAGE VOLUME	CABUYAO STA. ROSA LINE	C. S. ROSA LINE	SUPPLIED AMOUNT TO CABUYAO	OUTLET OF S. R. Inflow / Outflow		SUPPLIED AMOUNT TO STA. ROSA	ENTRANCE OF BIRAN
	1	2			4	5		6	6		7
0 - 1	135	167	1.42	994	191	133	58	0	5	128	88
1 - 2	100	166	1.57	1,112	197	137	60	0	6	131	88
2 - 3	122	166	1.76	1,266	201	141	60	0	6	135	88
3 - 4	100	166	1.92	1,398	206	143	63	0	5	138	88
4 - 5	244	162	2.10	1,552	211	140	71	0	2	138	85
5 - 6	254	169	2.06	1,500	219	129	90	8	0	137	78
6 - 7	272	173	1.94	1,415	223	113	110	31	0	144	56
7 - 8	282	174	1.83	1,323	219	108	111	49	0	157	37
8 - 9	293	174	1.77	1,274	219	111	108	55	0	166	32
9 - 10	299	170	1.61	1,144	222	111	111	49	0	160	41
10 - 11	302	166	1.49	1,049	218	108	110	43	0	151	45
11 - 12	293	169	1.40	978	236	128	108	48	0	176	38
12 - 13	273	173	1.31	909	267	155	112	42	0	197	46
13 - 14	262	165	1.10	750	274	168	106	28	0	196	64
14 - 15	263	(168)	1.08	736	281	175	106	25	0	200	67
15 - 16	275	(168)	1.03	714	289	182	107	20	0	202	71
16 - 17	290	(168)	0.98	662	295	186	109	32	0	218	57
17 - 18	296	(168)	0.90	604	298	183	115	39	0	222	48
18 - 19	316	(168)	0.85	569	293	182	111	39	0	221	47
19 - 20	300	(168)	0.85	569	297	182	115	20	0	202	36
20 - 21	187	161	0.85	569	224	141	83	17	0	158	74
21 - 22	135	169	0.95	641	169	112	57	6	0	118	82
22 - 23	140	168	1.11	758	176	120	56	1	0	121	88
23 - 24	131	167	1.26	870	185	129	56	0	5	124	89
TOTAL	3,564	4,033	-	983	5,610	3,417	2,193	552	29	3,940	1,533




FIGURE 4.5.1.3 LOCATION OF MEASUREMENT POINT

FIGURE 4.5.1.4 shows the flow rates along the main pipeline from the spring to the service areas together with the amount of water calculated to be to major service areas.

Because of no flow/quite low pressure at the junction area of Biñan and Cabuyao-Sta. Rosa lines, approximately 550 cu.m/day is transmitted by the Biñan line to supply part of Sta. Rosa through the Cabuyao-Sta. Rosa line. Approximately 1,000 cu.m/day is discharged from the reservoir into Cabuyao - Sta. Rosa line between 4:00 A.M. and 6:00 P.M.

(4) Discussions and Conclusions on not utilized water/unaccounted-for water

1) Transmission lines

The two sections of the transmission line from the spring to the entrance of Cabuyao area were studied using flow rate measurement results.

a) Transmission line from the spring to the reservoir area

Discharge rate from the spring box : 10,000 cu.m/day

Transmitted amount at the reservoir area :

9,650 cu.m/day

Supply to the high class residents, leakage and other

losses : 350 cu.m/day

Although approximately 3,000 cu.m/day were suspected to be leaked in the study section during the Phase I survey, the measurement result revealed that the amount of water transmitted from the intake of the spring box was substantial. The "C" value may be more than the expected figure taking into consideration the existing pipe alignment and the year of its construction. It is concluded that the pipeline installed is in straight alignment with the field and that the water does not contain unfavorable materials associated with "C" value and the joint portions are not damaged.




FIGURE 4.5.1.4

FLOW RATE ALONG MAIN PIPE LINES

- b) Transmission line from the reservoir area to the entrance of Cabuyao.

Transmitted rate at the reservoir area : 5,600 cu.m/day
(Cabuyao - Sta. Rosa line)

Transmitted rate at the entrance of
Cabuyao : 5,600 cu.m/day

There is no difference between the above measurement results in rounded off figures. Additional flow rate measurement between the two points were conducted thereby confirming that the figure is almost the same as the one mentioned.

2) Distribution networks

The relationship between distributed water amount and water consumption is summarized in TABLE 4.5.1.7 and FIGURE 4.5.1.5 by study area.

TABLE 4.5.1.7 RELATIONSHIP BETWEEN DISTRIBUTED AND CONSUMED WATER

Study Area	Distributed Water (cu.m/d.)	Water Consumption (cu.m/d.)	Percentage of utilized water	R.M.
a. Core area of Cabuyao	2,200	1,050	48%	
b. Core area and area along Cabuyao - Sta. Rosa line	3,900	1,350	35	
c. Area along Bifian line in Sta. Rosa	2,000	500	25	
d. Bifian area	*2,000	900	45	
T o t a l	10,100 (8,100)	3,800 (3,300)	38 (41)	() means excluding C. area

Note : * Distributed amount includes that from the existing pumping station (reported supply amount)




FIGURE 4.5.1.5

RELATIONSHIP BETWEEN DISTRIBUTED CONSUMED AND NOT UTILIZED WATER IN THE FOUR (4) AREAS

The percentage of utilized water for the four service areas shows low levels with a maximum of less than 50 percent. The water consumption is estimated using the monthly average figure (June, 1986), however, the result of the meter reading for the domestic consumption as revealed during interview was higher than the average (10% to 50%). Assuming that about 20% is added to the average water consumption, the average percentage of utilized water in the system excluding the area along Biñan line is calculated at approximately 50 percent. Accordingly almost half of distributed water is counted as unutilized water.

As to the causes of not utilized water, further detailed investigations will be required with a special emphasis on service connections with leakage, and non-metered and illegal connections as the culprits.

Unaccounted-for water

An accounted-for water was estimated by municipality based on the following:

- a) Metered connections : water consumption reported for the month of June
- b) Non-metered connections : 18 cu.m/connection-month for the concessionaires with one faucet. (₱14/connect.) and 1 cu.m/additional faucet-month (₱0.6/connect.)
- c) Metered but not functioning : Average charges per connection are calculated and water consumption per connection is estimated according to the metered rate.

TABLE 4.5.1.8 shows the accounted-for water by municipality.

TABLE 4.5.1.8 ACCOUNTED-FOR WATER

MUNICIPALITY	M E T E R E D		N O N - M E T E R E D		N O T F U N C T I O N I N G M E T E R E D		T O T A L C O N S U M P T I O N		
	NO. OF CONNECT	CHARGE ₱	CONSUMPTION m ³ /m	NO. OF CONNECT	CHARGE ₱	CONSUMP. m ³ /m	CHARGE ₱	CONSUMP. m ³ /m	MONTHLY DAILY m ³ /m m ³ /d
CABUYAO	726	₱ 22,019.25	27,177	5	₱ 102.00	143	₱ 1,940.25	2,880	30,200 1,007
STA. ROSA	1,200	45,004.50	51,145	13	186.80	241	2,485.75	3,608	54,994 1,833
BINAN	490	12,805.50	16,187	221	3,166.40	4,132	1,190.00	1,628	21,947 732
TOTAL	2,416	₱79,829.25	94,509	239	₱3,455.20	4,516	₱ 5,615.50	8,116	107,141 3,572

Approximately 3,600 cu.m/day corresponds to the accounted-for-water, while 6,500 cu.m/day or about 65 percent of production amount is unaccounted-for water.

It may be worthwhile to notice that there are a number of additional faucets in the category of non-metered connections. The water consumption in the whole system was estimated at 3,800 cu.m/day without considering the consumption at the additional faucets because there was no data available on the per faucet consumption. Additional faucets are for the primary consumer or for other families (secondary users/borrowers). Depending on who uses the faucets, per faucet consumption could differ.

If the average per faucet consumption is assumed to be 1.231 cu.m/day which is the overall average of the domestic metered connection, about 260 cu.m/day would be the additional consumption. The following is the percentage of utilized water in the total system, except the area along Bifian line, using the above assumption.

Distributed water	:	8,100 cu.m/day
Water consumption (1)	:	3,600 (= 3,300 + 300)
Water consumption (2)	:	
(20% additional)	:	4,300
<hr/>		
Percentage of utilized water	:	55%

APPENDIX 6.7.1 WELL LITHOLOGIC LOGS

Well No.	Location	Depth (m)	Casing Depth (m)	Casing Diameter (mm)	Static Water Level (m)	Pump Test Data	Discharge (m³/h)	Drawdown (m)	LOG
LWUA Well No. P-10	P. Sta. Cruz, Sta. Rosa	250							<p>LOG</p> <p>DEPTH</p> <p>V-V TUFF CLAY</p> <p>V-V CLAY, TUFF</p> <p>V-V CLAY, TUFF</p> <p>V-V TUFF CLAY</p> <p>V-V CLAY</p> <p>TUFF, SOME CLAY</p> <p>CLAY</p> <p>TUFF, CLAYEY</p> <p>TUFF, SOME CLAY</p>
LWUA Well No. P-13	Mangera, Sta. Rosa	200							<p>LOG</p> <p>DEPTH</p> <p>V-V RESIDUAL CLAY</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V TUFF</p> <p>V-V VOL. ASH, TUFFACEOUS</p> <p>V-V TUFF, PUMICEOUS</p>
LWUA Well No. P-14	P. Sta. Cruz, Sta. Rosa	200							<p>LOG</p> <p>DEPTH</p> <p>V-V RESIDUAL CLAY</p> <p>V-V TUFF, WEATHERED CLAY</p> <p>V-V VOL. ASH, CLAYEY</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH, SILTY</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V PUMICE</p> <p>V-V TUFF, CLAYEY</p>
LWUA Well No. P-16	P. Sta. Cruz, Sta. Rosa	200							<p>LOG</p> <p>DEPTH</p> <p>V-V RESIDUAL CLAY</p> <p>V-V VOL. ASH</p> <p>V-V TUFF, PUMICEOUS</p> <p>V-V VOL. ASH, TUFFACEOUS</p> <p>V-V PUMICES</p> <p>V-V TUFF, SANDY</p> <p>V-V VOL. ASH, TUFFACEOUS</p> <p>V-V TUFF</p> <p>V-V VOL. ASH, TUFFACEOUS</p> <p>V-V TUFF</p> <p>V-V VOL. ASH, TUFFACEOUS</p> <p>V-V TUFF</p> <p>V-V TUFF, WELDED</p> <p>V-V VOL. ASH, CALCAREOUS</p>
LWUA Well No. P-17	Bo. Dito, Sta. Rosa	235							<p>LOG</p> <p>DEPTH</p> <p>V-V VOL. ASH</p> <p>V-V PUMICE</p> <p>V-V TUFF, CLAY, PUMICEOUS</p> <p>V-V VOL. ASH, CLAYEY</p> <p>V-V TUFF, CLAYEY, PUMICEOUS</p> <p>V-V VOL. ASH</p> <p>V-V TUFF, CLAYEY</p> <p>V-V VOL. ASH, SILTY</p> <p>V-V TUFF, CLAYEY</p>

LWUA Well No. P-26		LWUA Well No. P-24		LWUA Well No. P-23		LWUA Well No. P-40		LWUA Well No. m-3		LWUA Well No.	
LOCATION: Macabbing, Sta. Rosa DEPTH: 204 m. CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:		LOCATION: Alasason, Sta. Rosa DEPTH: 200 m. CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:		LOCATION: Kawad, Sta. Domingo, Sta. Rosa DEPTH: 186 m. CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:		LOCATION: Langkiwa, Bifitan DEPTH: 161 m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:		LOCATION: Macabbing, Sta. Rosa DEPTH: 240 m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:		LOCATION: DEPTH: CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATA DISCHARGE: DRAWDOWN:	
DEPTH	LOG	DEPTH	LOG	DEPTH	LOG	DEPTH	LOG	DEPTH	LOG	DEPTH	LOG
100-110	VOL. ASH, TUFFACEOUS	RESIDUAL CLAY	RESIDUAL CLAY	RESIDUAL CLAY	RESIDUAL CLAY	VOL. ASH & TUFF	VOL. ASH & TUFF	CLAY SAND, TUFFACEOUS	CLAY SAND, TUFFACEOUS		
110-120	VOL. ASH, TUFFACEOUS	VOL. ASH	VOL. ASH	VOL. ASH	VOL. ASH	CLAY	CLAY	CLAY W/ TUFF	CLAY W/ TUFF		
120-130	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF	VOL. TUFF	BASALTIC & TUFFA-CEOUS SAND	BASALTIC & TUFFA-CEOUS SAND		
130-140	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY	CLAY	TUFF AND PUMICE SAND	TUFF AND PUMICE SAND		
140-150	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. ASH	VOL. ASH	PUMICE	PUMICE		
150-160	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. ASH, CLAYEY	VOL. ASH, CLAYEY	PUMICE SAND W/ LITTLE PEBBLE	PUMICE SAND W/ LITTLE PEBBLE		
160-170	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	SAND, BASALTIC & PUMICEOUS	SAND, BASALTIC & PUMICEOUS		
170-180	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	PUMICE SAND WITH TUFF	PUMICE SAND WITH TUFF		
180-190	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	CLAYS W/ SAND	CLAYS W/ SAND		
190-200	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	PUMICE SAND WITH TUFF LAYER	PUMICE SAND WITH TUFF LAYER		
200-210	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	COARSE SAND W/ PUMICE	COARSE SAND W/ PUMICE		
210-220	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	CLAYEY, STICKY	CLAYEY, STICKY		
220-230	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
230-240	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	PUMICE	PUMICE		
240-250	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
250-260	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
260-270	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
270-280	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
280-290	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
290-300	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
300-310	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
310-320	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
320-330	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
330-340	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
340-350	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
350-360	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
360-370	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
370-380	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
380-390	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
390-400	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
400-410	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
410-420	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
420-430	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
430-440	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
440-450	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
450-460	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
460-470	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
470-480	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
480-490	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		
490-500	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	VOL. TUFF, CLAYEY	CLAY, SANDY	CLAY, SANDY	TUFF	TUFF		

LWUA Well No. (B) LOCATION: San Vicente, Biñan DEPTH: 161 m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATE: DISCHARGE: DRAWDOWN:	LWUA Well No. C-41 LOCATION: Elem. Sch. Biñan DEPTH: 152 m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATE: DISCHARGE: DRAWDOWN:	LWUA Well No. LOCATION: DEPTH: CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATE: DISCHARGE: DRAWDOWN:	LWUA Well No. P-45 LOCATION: San Isidro, Cabuyao DEPTH: 172 m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATE: DISCHARGE: DRAWDOWN:	LWUA Well No. (1) LOCATION: Bantaybany, Cabuyao DEPTH: 91 m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATE: DISCHARGE: DRAWDOWN:	LWUA Well No. (2) LOCATION: Bantaybany, Cabuyao DEPTH: 91 m CASING DEPTH: CASING DIAMETER: STATIC WATER LEVEL: PUMP TEST DATE: DISCHARGE: DRAWDOWN:
DEPTH	DEPTH	DEPTH	DEPTH	DEPTH	DEPTH
LOG	LOG	LOG	LOG	LOG	LOG
SAND	CLAY W/ FINE SAND SAND SILTY SAND SAND SAND . CLAYEY SILTY SAND SAND SAND SILTY	RESIDUAL CLAY TUFF TUFF CLAY TUFF TUFF TUFF TUFF CLAY TUFF CLAY TUFF	SAND & GRAVEL SANDY CLAY SILTY SANDY SANDY CLAY	SAND SANDY CLAY CLAY SILTY SAND CLAYEY SAND CLAY CLAYEY SAND	
161	152	172	91	91	

LWUA Well No. P - 58	LWUA Well No. P - 43	LWUA Well No. (A)
LOCATION : Calabuso, Binan DEPTH : 170 m CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : PUMP TEST DATE : DISCHARGE : DRAWDOWN :	LOCATION : SoroSoro, Binan DEPTH : 169 m CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : PUMP TEST DATE : DISCHARGE : DRAWDOWN :	LOCATION : Binon, Laguna DEPTH : 183 m CASING DEPTH : CASING DIAMETER : STATIC WATER LEVEL : PUMP TEST DATE : DISCHARGE : DRAWDOWN :
LOG TUFF VOL. ASH VOL. TUFF CLAY TUFFACEOUS CLAY TUFFACEOUS VOL. TUFF CLAY TUFFACEOUS VOL. ASH CLAY STICKY VOL. ASH VOL. TUFF CLAY TUFFACEOUS VOL. ASH VOL. TUFF CLAY TUFFACEOUS VOL. TUFF VOL. TUFF	LOG RESIDUAL CLAY VOL. ASH CLAY TUFFACEOUS VOL. TUFF CLAY VOL. TUFF CLAY TUFF CLAY	LOG ADOBE HARD ADOBE BROWN CLAY W/ SAND OLIVE GRAY CLAY W/ SAND GRAYISH SAND WITH CLAY GRAYISH SAND & CLAY
50	68	83
100	72	200

APPENDIX 6.8.1 SELECTION OF SAMPLING POINT

Sampling points in the project area took into account the following:

- Existing sources, i.e., spring and deep well, to evaluate the qualitative characteristics of the present water system;
- The other deep well sources at representative locations, thus, a general impression on the areas overall water quality could be established;
- Important well sources, e.g. the free-flowing wells in Sta. Rosa. By comparing test results of each, relative analysis on the continuity of the aquifer i.e. similar valves would probably describe some water source, could be done; and
- Large well source (NIA wells) and the Laguna de Bay as they pose to be alternative sources for the system.

To summarize:

- Two (2) existing deep wells in the city water supply system
- One (1) existing spring in the city water supply system
- Seven (7) deep wells
- Four (4) shallow wells
- One (1) potential spring
- One (1) surface water source (Laguna de Bay)
- Three (3) faucets and one (1) shallow well for bacteriological analysis

FIGURE 6.8.1.1 shows location of the selected points.

APPENDIX 6.8.2 WATER QUALITY ANALYSIS - CABUYAO-STA. ROSA-BIÑAN

Sample No.	Well No.	Location	Group	Turb. (FTU)	TDS (mg/l)	pH (-)	EC (µS/cm)	Alk. (mg/l)	Hard. (mg/l)	Acid. (mg/l)	Na (mg/l)	K (mg/l)	Ca (mg/l)	Mg (mg/l)	CO ₃ (mg/l)	HCO ₃ (mg/l)	Cl (mg/l)	SO ₄ (mg/l)	Fe (mg/l)	Mn (mg/l)	E.Coli. (MPN)	NO ₂ -N (mg/l)	NH ₄ -N (mg/l)	
1	NIA P-58	Calaboso, Biñan	C	0.67	320	7.43	470	233	146	22	49	9.7	31.6	16.3	0	284.3	13.9	5	0.15	0.2	-	-	1.24	0.01
2	WW-1	Biñan Market, Biñan	A	0.61	384	7.21	530	235	199	12	59	9.4	42.0	22.8	0	344.7	18.6	7.5	0.13	nil	-	-	0.78	0.02
3	Faucet	San Antonio, Biñan	G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(+)	-	-	-
4	B-2	Malaban, Biñan	D	1.25	640	7.63	800	328	356	9	80	15	76.5	40.1	0	400.2	83.6	90	0.10	nil	-	-	9.67	0.06
5	B-1	San Antonio, Biñan	D	1.31	352	7.56	560	256	172	28	50	8.7	32.8	21.9	0	312.3	18.6	5	0.15	0.10	-	-	0.87	0.04
6	B-1	San Antonio, Biñan	G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(+)	-	-	-
7	WW-2	Tulay Bato, Biñan	A	-	-	6.95	400	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	NIA M-3	Macabiling, Sta. Rosa	C	1.45	314	7.41	455	237	176	32	39.5	7.4	32.8	22.8	0	238.1	13.9	3.5	0.13	nil	-	-	1.09	0.01
9	NIA P-56	Mampalasan, Biñan	C	0.45	288	6.92	415	218	176	36	33	6.4	32.8	22.8	0	236	11.6	3	0.06	nil	-	-	1.46	nil
10	NIA P-18	Paguayo, Sta. Rosa	C	0.58	314	7.26	470	228	191	14	30	7.2	40.4	21.9	0	278.2	11.6	3.5	0.06	0.10	-	-	1.58	0.01
11	SR-1	Labas, Sta. Rosa	D	2.45	374	7.73	520	275	206	9	47	6.7	36	23.2	0	335.5	18.6	2	0.10	0.05	-	-	0.87	0.01
12	Faucet	Aplayo, Sta. Rosa	G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(+)	-	-	-
13	NIA P-57	Aplayo, Sta. Rosa	C	0.43	355	7.84	595	236	139	6	72.5	8.5	26.8	17.5	0	312.3	18.6	10.0	0.20	nil	-	-	0.44	0.01
14	NIA P-57	Laguna de Bay, Sta. Rosa	F	25.8	576	7.47	910	142	184	12	120	7.1	44.8	17.5	0	173.2	190.4	34.5	0.20	0.20	-	-	5.04	0.08
15	Faucet	Waterworks Office, Cabuyao	G	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(-)	-	-	-
16	C-1	Waterworks Office, Cabuyao	D	2.75	526	7.73	495	247	191	14	36	7.5	38.8	22.8	0	301.3	13.9	3	0.06	0.05	-	-	0.50	0.02
17	APP-NBA1	Cabuyao	C	0.75	352	7.73	515	266	221	16	27.5	6.8	43.6	27.2	0	324.5	11.6	3	0.10	nil	-	-	0.39	0.01
18	NIA P-45	San Isidoro, Cabuyao	C	-	-	6.87	400	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19	Spring 1	Katan Tubig	B	0.41	250	7.01	330	176	157	33	17.5	5	38.8	14.6	0	214.7	11.6	5	0.13	nil	-	-	4.50	0.01
20	Spring 2	Katan Tubig	E	0.43	237	6.96	340	171	165	28	15	4.8	36.0	18.2	0	208.6	9.3	4	0.13	nil	-	-	4.48	nil

*: Category:
 A - Deep wells in the city water supply system
 B - Spring in the city water supply system
 C - Deep well
 D - Shallow well
 E - Potential spring for the city water supply system
 F - Surface water source
 G - For bacteriological analysis

Philippine National Standard for Drinking Water

Water Quality: Physical, Chemical and Radiological Requirements

Bacteriological Quality Standards

Parameter		Maximum Permissible level*
Turbidity		5 units
Color		5 units (s) **
Odor		Unobjectionable
Threshold odor number		Note more than 3
Taste		Unobjectionable
Total Solids		500 (s)
pH		6.5 - 8.5
Phenolic substances		0.001
Radioactive Subs.	Gross Alpha	3 pCi/l
	Gross Beta	30pCi/l
Trace Elements	Arsenic	0.05
	Barium	1.0
	Cadmium	0.01
	Chromium	0.05
	Copper	1.0
	Cyanide	0.05
	Fluoride	0.6
	Iron	1.0
	Lead	0.05
	Manganese	0.5 (s)
	Mercury	0.002
	Selenium	0.01
	Zinc	5.0 (s)
Organic Chemicals	: Synthetic Detergents (MBAS)	0.5
	Oil & Grease	Nil
Persistent Pesticides	: Aldrin	0.001
	DDT	0.05
	Dieldrin	0.001
	Chlordane	0.003
	Endrin	0.0002
	Heptachlor	0.0001
	Lindane	0.004
	Toxaphene	0.005
	Methoxychlor	0.1
	2,4 -- E	0.1
	2, 4, 5 -- T	0.01
PCB		Nil
Other Chemicals	: Calcium	75
	Chloride	200 (s)
	Magnesium	50 (s)
	Nitrate (NO ₃)	30
	Sulfate	200 (s)
	Hydrogen sulfide	0.05 (s)

Minimum Requirements on Bacteriological Quality

a) Chlorinated or Otherwise Disinfected Supplies

Efficient treatment culminating in chlorination or some other form of disinfection should yield a water free of any coliform organism however polluted the original raw water may have been. In practice it should not be possible to demonstrate the presence of coliform organisms in any sample of 100ml. The efficacy of the purification process and method of sampling should be looked into when a sample of the water entering the distribution system does not conform to this standard. In testing chlorinated water, presumptive positive tubes should always be subjected to appropriate confirmatory tests.

b) Non-disinfected Supplies

Where supplies of this sort exist, no water entering the distribution system should be considered satisfactory if it yields E coli in 100ml. If E. coli is absent, the presence of not more than 3 coliform organisms per 100ml may be tolerated in occasional samples from established non-disinfected pipes supplies, provided that they have been regularly and frequently tested and that the catchment area and storage conditions are found to be satisfactory. If repeated samples show the presence of coliform organisms, steps should then be taken to discover and, if possible, remove the source of pollution. If the number of coliform organisms increases to more than 3 per 100ml, the supply should be considered unsuitable for use without disinfection.

c) Individual or Small Community Supplies

Where supply of waters are individual wells, bores and springs everything possible should be done to prevent pollution of the water. It should be possible to reduce the coliform count of water from even a shallow well to less than 10 per 100ml. Persistent failure to achieve this, particularly if E. coli is repeatedly found, should, as a general rule lead to chlorination or boiling of the water for domestic consumption.

* All units are in mg/l unless, otherwise stated.

** (s) - Secondary standards; compliance with the standard and analysis are not obligatory.

APPENDIX 7.2.1 WATER RIGHT IN THE SPRING AREA

User Name	Water Volume		Purpose	Remarks
	l/sec	cu.m/day		
1) Canlubang Sugar Estate	461	39,830	industry	the water after power plant
2) Yulo	96	8,294	irrigation	
3) Canlubang Pulp Manufacturing	457	39,485	electric power	
Total	1,014	87,609		

Source; NWRG

The total of 48,124 cu.m/day comprising item 1) and 2) in the above table may be water amount available including river water and spring water. The amount was also field confirmed as follows:

- a) Existing spring for the CSBWS waterworks and potential springs : 12,600 cu.m/day
 - b) Transmitted amount to Canlubang Sugar estate : 15,000 cu.m/day
 - c) Flow rate at the upstream of nearby river : 15,500 cu.m/day
- Total : 43,100 cu.m/day

The water utilized for the Canlubang Sugar Estate at present might be used for the CSBWS waterworks in the future when its business activities would be discontinued as related to the survey term. It is advantageous to consider spring water sources for the water supply, however, a total of 12,600 cu.m/day may be the maximum available volume at this stage. Negotiations with the private sector to acquire additional spring water should be done in the future.

APPENDIX 7.2.2 DATA ON THE UNIT COST FOR ESTIMATION OF PROJECT COST

(1) Deep Well Construction : Peso

<u>Depth (m)</u>	<u>Casing size (m/m)</u>	<u>Cost</u>
200	250	940,000
200	300	1,160,000
250	150	640,000

BREAKDOWN OF COSTS IN %

	<u>Local Component</u>			<u>F E C</u>		<u>Total</u>
	<u>Material</u>	<u>Labor</u>		<u>Direct</u>	<u>Indirect</u>	
		<u>Skilled</u>	<u>Unskilled</u>			
Equipment	17	-	-	-	20	37
Civil Works	33	8	5	-	17	63
Total	50	8	5	-	37	100

(2) Deep Well Pump Station (Electric Motor Drive) : Thousand Peso

<u>KW</u>	<u>Cost</u>
7	450
15	560
22	640
29	720
37	790
44	840
51	890
59	960
66	1,020
74	1,080

BREAKDOWN OF COSTS IN %

	<u>Local Component</u>			<u>F E C</u>		<u>Total</u>
	<u>Material</u>	<u>Labor</u>		<u>Direct</u>	<u>Indirect</u>	
		<u>Skilled</u>	<u>Unskilled</u>			
Equipment	9	-	-	42	5	56
Civil Works	21	9	5	-	9	44
Total	30	9	5	42	14	100

(3) Booster Pump Station

$$C = (72.16 - 13.68 \log Q) \times Q^{(0.42 + 0.1 \log Q)} \\ \times H^{0.305(\log Q - 0.7)} (6/H - 0.25)$$

where,

C = cost for electric motor drive (thousand peso)

Q = design capacity (l/sec)

H = total dynamic head (m)

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	11	-	-	53	2	66
Civil Works	17	9	6	-	2	34
Total	28	9	6	53	4	100

(4) Pipeline Cost

Following pipe materials are presently available in the Philippines:

- GI (galvanized iron),
- PE (poly-ethylene),
- PB (poly-butylene),
- PVC (poly-vinyl-chloride),
- SP (steep pipe),
- CI (cast iron), and
- AC (asbestos cement).

Among these materials, the use of CI pipe is limited due to its high cost and AC pipe is also rare by safety reason.

Followings are comparison of unit cost at the 1985 price level.

Diameter	(Unit: ₱/m)				
	GI	PE	PB	PVC	SP
13	20.8	13.8	9.1	-	-
19	24.7	19.9	13.6	-	-
25	32.3	25.3	22.0	-	-
38	59.2	41.5	44.7	-	-
50	87.5	61.4	76.4	33.9	-
63	117.7	-	-	48.0	-
75	180.3	-	-	81.3	-
100	230.8	-	-	122.4	235.0
150	-	-	-	256.9	250.0
200	-	-	-	506.5	290.0
250	-	-	-	-	315.0
300	-	-	-	-	425.0
400	-	-	-	-	520.0
500	-	-	-	-	700.0
600	-	-	-	-	890.0

Based on the above comparison, SP is advantageous for the diameter of 200 mm and above than PVC. Thus, for the cost estimates of major transmission and distribution pipes, SP is considered for diameter of 200 mm and above, while PVC for diameter of less than 150 mm taking into account the transportation cost and easy installation.

Diameter (mm)	Unit Cost (₱/m)
150 (PVC)	410
200(SP)	520
250(")	630
300(")	760
350(")	900
400(")	970
450(")	1,160
500(")	1,330
600(")	1,600
700(")	1,910

Source : LWUA Design Depart

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	23	-	-	4	27	54
Civil Works	17	7	4	-	18	46
Total	40	7	4	4	45	100

(5) Valve In-place Cost

Diameter (mm)	Gate Valve (₱)	Butterfly Valve (₱)
50	1,700	-
75	2,900	-
100	3,900	-
150	5,300	-
200	6,700	-
250	11,200	-
300	-	34,800
350	-	74,400
400	-	95,200
450	-	125,900
500	-	174,000
600	-	243,600
700	-	313,200

Source : LWUA Design Depart

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	9	-	-	63	5	77
Civil Works	12	3	6	-	2	23
Total	21	3	6	63	7	100

(6) Internal Network

Population Density (Person/ha)	Total Length of Pipeline (m/ha)	Unit Cost (₱/ha)	
		Diameter (100/150)	Diameter (75/100)
50	64	18,300	14,900
60	67	19,300	15,700
75	72	20,900	16,800
100	80	23,100	18,700
150	90	25,700	21,000
200	100	28,300	-
250	108	30,400	-
300	116	32,500	-

BREAKDOWN OF COSTS IN %

	Material	Local Component		F E C		Total
		Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	22	-	-	7	27	56
Civil Works	17	7	4	-	16	44
Total	39	7	4	7	43	100

(7) In-place of Service Connections

Diameter (inch)	Without Meter ₱/unit	With Meter ₱/unit	Meters ₱/unit
1/2	450	810	400
5/8 - 3/4	520	1,280	880

SERVICE CONNECTION WITHOUT METER

BREAKDOWN OF COSTS IN %

	Material	Local Component		F E C		Total
		Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	9	-	-	60	2.5	71.5
Civil Works	17	3	6	-	2.5	28.5
Total	26	3	6	60	5	100

SERVICE CONNECTION WITHOUT METER
BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	4	-	-	83	2	89
Civil Works	6	1	3	-	1	11
Total	10	1	3	83	3	100

(8) Fire Hydrant In-place Cost

<u>Type</u>	<u>Size (mm)</u>	<u>Unit Cost (₱)</u>
Commercial	150	16,800
Residential	100	9,400

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	8	-	-	57	5	70
Civil Works	10	8	10	-	2	30
Total	18	8	10	57	7	100

(9) Elevated Tank/Ground Reservoir

Elevated Tank: $C = 0.615 H^{1.144} V^{0.749}$

Ground Reservoir: $C = 20.05 V^{0.639}$

where, C = cost (thousand peso)

H = overflow elevation above ground level

V = storage volume (cu.m)

BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	4	-	-	3	2	9
Civil Works	53	5	7	-	26	91
Total	57	5	7	3	28	100

(10) Gas Chlorinator In-place Cost

Type	Water Flow Condition	Maximum Chlorine Feed (kg/day)	Unit cost ^{1/} (₹)
I-A	constant	22	98,100
I-B	constant	45	119,100
II-A	Variable	22	147,700
II-B	Variable	45	169,300

^{1/} Empty gas cylinders and automatic switchover include

TYPE I-A, I-B
BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	15	-	-	41	5	61
Civil Works	25	6	3	-	5	39
Total	40	6	3	41	10	100

TYPE II-A, II-B
BREAKDOWN OF COSTS IN %

	Local Component			F E C		Total
	Material	Labor		Direct	Indirect	
		Skilled	Unskilled			
Equipment	21	-	-	53	2	76
Civil Works	12	6	2	-	4	24
Total	33	6	2	53	6	100

(11) Administration & Operation Building

Future Service Population	Administration Bldg. (Thousand Peso)	Operation Center (Thousand Peso)
30,000	1,000	810
40,000	1,110	890
50,000	1,220	990
60,000	1,320	1,090
70,000	1,410	1,180
80,000	1,500	1,280
100,000	1,610	1,380
110,000	1,820	1,590

ADMINISTRATION BUILDING
BREAKDOWN OF COSTS IN %

	Material	Local Component		Direct	F E C		Total
		Labor			Indirect		
		Skilled	Unskilled				
Equipment	20	-	-	-	16		36
Civil Works	42	7	5	-	10		64
Total	62	7	5	-	26		100

OPERATION CENTER
BREAKDOWN OF COSTS IN %

	Material	Local Component		Direct	F E C		Total
		Labor			Indirect		
		Skilled	Unskilled				
Equipment	14	-	-	30	6		50
Civil Works	26	10	5	-	9		50
Total	40	10	5	30	15		100

(12) Energy Cost

$$C = N_p (h) (P_u) (E_m)^{-1}$$

where,

- C = cost (thousand peso)
- N_p = pump power demand (kw)
- h = hours of operation
- P_u = unit power cost (₱/kWh)
- E_m = motor efficiency (0.85)

(13) Chemical Cost

$$C = (\text{Annual Water Demand}) \cdot D \cdot U_{CL} \times 10^{-3}$$

where,

C = annual cost for chlorine (₹)

D = chlorine dosage (mg/l)

U_{CL} = unit cost of chlorine gas (₹/kg)

(14) Minimum Cost Diameter

Following cost function is applied to determine the most economical diameter of pipelines that are not simulated by the network analysis.

$$D_{min.} = 187.7 Q^{0.486} C^{-0.315} (E_c/O_e)^{0.17}$$

where,

$D_{min.}$ = minimum cost diameter

Q = water flow (l/sec)

C = "C" value (Hazen William Formula)

E_c = energy cost (₹/kwh)

O_e = overall efficiency

APPENDIX 7.3.1 ALTERNATIVE STUDY OF WATER SOURCE AND TRANSMISSION

(1) Cost Estimates of Water Source and Transmission Alternatives

Required Facilities	Unit Cost (₱)	Alternative S-1		Alternative S-2	
		Q'ty	Cost (₱1,000 peso)	Q'ty	Cost (₱1,000 peso)
<u>Construction Cost</u>					
1. Water Sources					
Deep Well	1,160,000	16 units	18,560	4 units	4,640
Deep Well Pump	790,000	16 units	12,640	4 units	3,160
Intake Pump Station	8,366,000	-	-	1 unit	8,366
<u>Sub Total</u>			<u>31,200</u>		<u>16,166</u>
2. Transmission Line					
ϕ 250 mm	630 /m	10,000 m	6,300	2,400 m	1,512
ϕ 350 mm	900 /m	700 m	630	-	-
ϕ 400 mm	970 /m	1,800 m	1,746	1,100 m	1,067
ϕ 450 mm	1,160 /m	-	-	1,300 m	1,508
ϕ 500 mm	1,330 /m	500 m	665	-	-
ϕ 700 mm	1,910 /m	4,400 m	8,404	1,000 m	1,910
<u>Sub Total</u>			<u>17,745</u>		<u>5,997</u>
3. Water Treatment					
Rapid Sand Filter	61,204,000	-	-	1 unit	<u>61,204</u>
<u>TOTAL</u>			<u>48,945</u>		<u>83,367</u>
<hr/>					
<u>Operation & Maintenance Cost (15 years)</u>					
1. Energy	₱ 0.3 /KWH	77,790	23,337	48,360 MWH	14,508
2. Laborer	₱ 1,200 /MM	16 persons	3,456	5 persons	1,080
3. Maintenance (10% of Construction Cost)		-	4,895	-	8,337
<u>TOTAL</u>			<u>31,688</u>		<u>23,925</u>
<hr/>					
<u>GRAND TOTAL</u>			<u>80,633</u>		<u>107,292</u>

(2) Cost Estimates of Transmission Alternatives

Pipe Size	Pipe Length (m)			Unit Cost (₱/m)	Cost (₱ x 1,000)		
	Phase I	Phase II	Total		Phase I	Phase II	Total
<u>Alternative T-1</u>							
ϕ 250 mm	1,400	4,800	6,200	630	882	3,024	3,906
ϕ 350 mm	-	700	700	900	-	630	630
ϕ 400 mm	-	1,800	1,800	970	-	1,746	1,746
ϕ 500 mm	-	500	500	1,330	-	665	665
ϕ 700 mm	3,200	1,200	4,400	1,910	6,112	2,292	8,404
<u>TOTAL</u>	4,600	9,000	13,600		6,994	8,357	15,351

<u>Alternative T-2</u>							
ϕ 250 mm	2,200	4,800	7,000	630	1,386	3,024	4,410
ϕ 350 mm	-	700	700	900	-	630	630
ϕ 400 mm	1,100	1,800	2,900	970	1,067	1,746	2,813
ϕ 450 mm	1,300	-	1,300	1,160	1,508	-	1,508
ϕ 500 mm	-	500	500	1,330	-	665	665
ϕ 600 mm	-	3,200	3,200	1,600	-	5,120	5,120
ϕ 700 mm	-	1,200	1,200	1,910	-	2,292	2,292
<u>TOTAL</u>	4,600	12,200	16,800		3,961	13,477	17,438

APPENDIX 7.3.2 COST COMPARISON OF THE TWO CASES

Case 1 Construction of transmission line from the spring to the existing reservoir area, enabling use of the additional springs.

Case 2 Development of an additional well in Bifian with a production of approx. 5,200 cu.m/day, as an alternative, to utilize new spring water sources.

A new well site for Case 2 is tentatively scheduled for development in Sta. Rosa, with a minimum transmission pipeline length of 1 km. The cost requirement for Case 1 is bigger than that of Case 2.

Case 1

Item	Unit	Quantity	Unit Cost	Cost	R.M.
Pipeline ø350	m	4,100	970	3,977,000	
Total				3,977,000	3,300cu.m/day

Case 2

Item	Unit	Quantity	Unit Cost	Cost	R.M.
Well Construction ø250 x 200m	unit	1	940,000	940,000	Q=5,200 cu.m/d
Pipe line ø200	m	1,000	410	410,000	
Pump Station	unit	1		790,000	3.7 cu.m/min x 40m x 37kw
Sub-Total				2,140,000	
Operation & Maintenance Cost					15 years
Electricity	kwh	5,208,000	0.3₱/kwh	1,562,400	
Labor	unit	1		216,000	
Maintenance				214,000	Const. Cost x 0.1
Sub-Total				1,992,400	
Total				4,132,400	for 5,200 cmd
				(2,622,500	for 3,300 cmd)

FIGURE 7.3.2.1 SCHEMATIC LAYOUT OF CABUYAO




TABLE 7.3.2.1 COST COMPARISON ON CABUYAO SYSTEM

Case 1

Phase	Item	Unit	Unit Cost	Cost	Remarks
I	Transmission Lain				
	φ400	6,500 m	970 ₱/m	6,305,000	
	Sub Total			6,305,000	
	Distribution Lain				
	φ400	3,300	970 ₱/m	3,201,000	
	φ350	1,800	900 ₱/m	1,620,000	
	φ300	3,200	760 ₱/m	2,432,000	
	Reservoir V = 1,800 cu.m	1 unit		2,411,000	
II	Pump Station	1 unit		20,449,000	φ250x7.0 cu.m/min x 35m x 59kw x 4sets
	Sub Total			30,113,000	
I & II	Operation & Maintenance				
	Electricity	69,532,000 kwh	0.3 ₱/kwh	20,859,600	
	Labor	1 unit		1,944,000	Mechanical Engineer 1 Pump Operator 4 Labor 4
	Maintenance			3,641,800	Construction Cost x 0.1
	Sub Total			26,445,400	
II	Land Acquisition	900 sq.m	120 ₱/m	108,000	
	Total			62,971,400	

TABLE 7.3.2.1 COST COMPARISON ON CABUYAO SYSTEM (CONT'D)

Case 2


Phase	Item	Unit	Unit Cost	Cost	Remarks
I	Pipe Line				
	φ600	5,400m	1,600 ₱/m	8,640,000	
	φ500	2,400m	1,330 ₱/m	3,192,000	
	φ350	1,000m	900 ₱/m	900,000	
	φ300	2,300m	760 ₱/m	1,748,000	
	Sub Total			14,480,000	
II	Distribution				
	Pipe Line				
	φ500	3,000m	1,330 ₱/m	3,990,000	
	φ450	500m	1,160 ₱/m	580,000	
	φ400	1,800m	970 ₱/m	1,746,000	
	φ300	1,200m	760 ₱/m	912,000	
	Reservoir V = 1,800 cu.m	1 unit		2,411,000	
	Sub Total			9,639,000	
I & II	Operation & Maintenance				
	Maintenance			2,412,000	Construction Cost x 0.1
II	Land Acquisition	900 sq.m	120 ₱/m	108,000	
	Ground Total			26,639,000	

o List of Computed Cases

Alternative	D-1-A	(1995, 2010)
	D-1-B	(1995, 2010)
	D-2	(2010)

o Note

This appendix show the results of Hydraulic Analysis aided by the computer. The distribution network is shown in the figure of following page. The nodes, however, with no flow and 20.00 m in Dynamic Head was treated as a dummy node. Those nodes can be ignored and have no relation to the computation results.



SCHEMATIC PLAN OF DISTRIBUTION SYSTEM FOR HYDRAULIC ANALYSIS (Cabuyao-Sta. Rosa-Binan)

LEGEND:
 (Node Number)
 Q=1980 Outflow at the Node in 2010
 Q=1200 Outflow at the Node in 1995
 GL+14.0 Ground Elevation at the Node

ALTERNATIVE D-1-A (Recommended Plan, Single Pipeline Alignment)
2 Reservoir System, Year 1995

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu.m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	24.00	0.00	44.00	20.00	51.00
2	22.00	0.00	42.00	20.00	53.00
3	25.00	0.00	45.00	20.00	50.00
4	28.00	0.00	48.00	20.00	47.00
5	10.00	0.00	30.00	20.00	65.00
6	5.00	0.00	25.00	20.00	70.00
7	5.00	0.00	25.00	20.00	70.00
8	5.00	0.00	25.00	20.00	70.00
9	21.00	0.00	41.00	20.00	54.00
10	18.00	0.00	38.00	20.00	57.00
11	14.00	1400.00	24.45	10.45	61.00
12	10.00	730.00	24.65	14.65	65.00
13	10.00	740.00	24.68	14.68	65.00
14	10.00	730.00	23.72	13.72	65.00
15	5.00	0.00	25.00	20.00	70.00
16	9.00	900.00	23.43	14.43	65.00
17	10.00	1100.00	23.64	13.64	65.00
18	5.00	900.00	25.00	20.00	70.00
19	23.00	0.00	43.00	20.00	50.00
20	16.00	1100.00	52.75	36.75	59.00
21	14.00	1200.00	53.05	39.05	61.00
22	12.00	1000.00	54.45	42.45	63.00
23	5.00	0.00	25.00	20.00	70.00
24	10.00	2000.00	45.40	36.40	65.00
25	10.00	1600.00	52.50	42.50	65.00
26	9.00	1500.00	42.39	33.39	66.00
27	9.00	800.00	39.77	30.77	65.00
28	10.00	600.00	39.28	29.28	65.00
29	10.00	700.00	37.83	27.83	65.00
30	5.00	0.00	37.05	32.05	70.00
31	5.00	2100.00	32.91	27.91	70.00
32	10.00	800.00	39.74	29.74	65.00
33	5.00	1700.00	41.52	31.52	65.00
34	5.00	0.00	25.00	20.00	70.00
35	5.00	0.00	25.00	20.00	70.00
36	9.00	1700.00	47.38	38.38	65.00
37	9.00	1800.00	45.74	37.74	65.00
38	8.00	0.00	45.03	37.03	65.00
39	8.00	2100.00	48.03	38.03	67.00
40	8.00	1800.00	38.21	30.21	67.00
41	8.00	1800.00	42.91	34.91	67.00
42	8.00	1000.00	38.24	30.24	67.00
43	8.00	1600.00	28.00	20.00	67.00
44	8.00	0.00	28.00	20.00	67.00
45	5.00	1400.00	20.99	15.99	70.00
46	8.00	0.00	36.91	28.91	67.00
47	8.00	1800.00	39.37	31.37	67.00
48	8.00	1800.00	38.29	30.29	67.00
49	8.00	900.00	36.79	28.79	67.00
50	5.00	3300.00	36.47	31.47	70.00
51	8.00	0.00	30.00	20.00	65.00
52	8.00	0.00	30.00	20.00	65.00
53	8.00	0.00	29.00	20.00	65.00
54	25.00	0.00	37.67	12.67	50.00

ALTERNATIVE D-1-A (Recommended Plan, Single Pipeline Alignment)
2 Reservoir System, Year 1995

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu.m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
56	5.00	5600.00	34.64	29.64	70.00
57	15.00	0.00	35.00	20.00	60.00
58	70.00	0.00	75.00	5.00	5.00
59	75.00	0.00	75.00	0.00	0.00
60	55.00	0.00	55.00	0.00	20.00

ALTERNATIVE D-1-A (Recommended Plan, Single Pipeline Alignment)
2 Reservoir System, Year 1995

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (D/100)
1	12	14	300.	120.	-1400.	-0.23	-0.22
2	13	14	300.	120.	-730.	-0.12	-0.03
3	14	15	250.	120.	2730.	0.64	2.15
4	14	55	250.	120.	-5600.	-1.32	-8.12
5	15	17	250.	120.	900.	0.21	0.27
6	15	18	250.	120.	1100.	0.26	0.40
7	21	22	250.	120.	-1100.	-0.26	-0.40
8	22	23	250.	120.	-2300.	-0.54	-1.56
9	23	60	700.	120.	-44700.	-1.34	-8.40
10	23	25	250.	120.	7039.	1.66	12.40
11	23	26	600.	130.	32817.	1.34	1.95
12	23	26	200.	750.	15444.	0.57	2.60
13	25	27	250.	120.	5039.	1.19	4.00
14	25	37	600.	130.	31289.	1.28	2.38
15	26	37	200.	2150.	1472.	0.54	5.12
16	27	28	250.	650.	3839.	0.91	2.62
17	28	29	300.	250.	4200.	0.69	1.96
18	29	34	250.	120.	-2761.	-0.65	-1.75
19	29	33	350.	750.	800.	0.10	0.03
20	29	30	250.	450.	3400.	0.80	3.22
21	30	31	250.	120.	2600.	0.69	2.25
22	31	32	200.	900.	2100.	0.77	4.14
23	34	37	250.	1100.	1750.	1.05	5.33
24	37	38	600.	400.	25405.	1.04	1.62
25	37	38	200.	110.	1195.	0.44	0.65
26	38	39	600.	500.	23685.	0.97	1.42
27	38	39	200.	500.	1115.	0.41	0.71
28	39	40	500.	400.	-8.	0.00	0.00
29	39	42	500.	950.	21250.	1.25	3.12
30	39	42	200.	950.	1750.	0.64	3.28
31	41	43	450.	500.	-2100.	-0.15	-0.04
32	42	48	450.	650.	2100.	0.54	3.55
33	43	49	450.	300.	-1400.	-0.23	-0.81
34	45	55	150.	1550.	-7000.	-1.65	-12.27
35	47	48	250.	200.	7000.	1.15	2.27
36	47	56	300.	450.	12400.	1.14	1.08
37	48	49	400.	300.	900.	0.08	0.01
38	49	50	400.	120.	6600.	0.19	1.50
39	49	51	350.	700.	3300.	0.40	0.33
40	51	52	350.	550.	-5600.	-1.22	-37.33
41	55	58	250.	4600.	130.	-0.23	-0.12
42	58	59	600.	10.	-5600.	0.00	0.00

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	24.00	1430.00	64.60	40.60	51.00
2	22.00	2300.00	61.47	39.47	53.00
3	25.00	1080.00	57.68	32.68	50.00
4	28.00	2880.00	48.79	18.79	47.00
5	10.00	3060.00	35.52	25.52	65.00
6	5.00	1080.00	25.33	20.33	70.00
7	5.00	3960.00	13.12	8.12	70.00
8	5.00	2970.00	15.97	10.97	70.00
9	5.00	990.00	19.92	14.92	70.00
10	21.00	2030.00	61.73	40.73	54.00
11	18.00	3240.00	45.42	27.42	57.00
12	14.00	1920.00	35.98	21.98	61.00
13	10.00	900.00	27.31	17.31	65.00
14	10.00	1260.00	29.43	19.43	65.00
15	10.00	1080.00	27.34	17.34	65.00
16	5.00	1080.00	16.58	11.58	70.00
17	9.00	3240.00	20.39	11.39	66.00
18	10.00	1980.00	27.58	17.58	65.00
19	5.00	1510.00	17.18	12.18	70.00
20	25.00	2520.00	33.48	8.48	50.00
21	16.00	1980.00	31.81	15.81	59.00
22	14.00	1980.00	38.56	24.56	61.00
23	12.00	1310.00	52.38	40.38	63.00
24	5.00	2270.00	17.18	12.18	70.00
25	10.00	6160.00	42.95	32.95	65.00
26	10.00	2880.00	46.71	36.71	65.00
27	9.00	4590.00	36.93	27.93	66.00
28	9.00	1080.00	32.26	23.26	66.00
29	10.00	1980.00	30.40	20.40	65.00
30	10.00	900.00	25.39	15.39	65.00
31	5.00	1170.00	22.41	17.41	70.00
32	5.00	3510.00	17.41	12.41	70.00
33	10.00	1080.00	21.74	17.74	65.00
34	10.00	3900.00	31.26	21.26	65.00
35	5.00	1190.00	23.22	18.22	70.00
36	5.00	3370.00	11.19	12.19	70.00
37	9.00	3300.00	31.83	22.83	66.00
38	9.00	3240.00	29.45	20.45	66.00
39	9.00	2880.00	26.80	17.80	66.00
40	8.00	900.00	24.98	15.98	67.00
41	8.00	2700.00	23.27	15.27	67.00
42	8.00	2880.00	23.96	15.96	67.00
43	8.00	1620.00	22.05	14.05	67.00
44	8.00	2700.00	22.06	14.06	67.00
45	10.00	1980.00	20.39	10.39	65.00
46	5.00	5180.00	13.82	8.82	70.00
47	8.00	260.00	18.15	10.15	67.00
48	8.00	2880.00	21.69	13.69	67.00
49	8.00	2160.00	21.46	13.46	67.00
50	8.00	2880.00	21.37	13.37	67.00
51	8.00	5940.00	17.02	9.02	67.00
52	5.00	5940.00	16.06	11.06	70.00
53	10.00	3060.00	20.23	10.23	65.00
54	9.00	3060.00	17.58	8.58	66.00
55	25.00	0.00	34.41	9.41	50.00

Iteration Times : 42

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
56	5.00	7780.00	15.12	10.12	70.00
57	15.00	360.00	26.09	11.09	60.00
58	70.00	0.00	74.97	4.97	5.00
59	75.00	0.00	75.00	0.00	0.00
60	55.00	0.00	55.00	0.00	20.00

ALTERNATIVE D-1-A (Recommended Plan, Single Pipeline Alignment)
 2 Reservoir System, Year 2010

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
1	1	58	4500	130	-30730	-1.26	-10.37
2	2	50	13312	120	13312	1.60	3.87
3	3	350	500	120	15967	1.47	5.74
4	4	300	650	120	11012	1.32	3.98
5	5	300	1150	120	9952	1.63	11.10
6	6	300	2200	120	7052	1.15	11.26
7	7	200	2350	120	3992	0.94	10.19
8	8	200	1450	110	2912	1.07	12.21
9	9	200	2250	110	-1048	-0.39	-2.65
10	10	200	900	120	-4018	-0.95	-3.95
11	11	300	2050	120	-5837	-0.96	-7.39
12	12	150	1000	110	830	0.54	3.34
13	13	300	900	120	13957	2.29	16.31
14	14	300	850	120	10717	1.75	9.44
15	15	300	850	120	8797	1.44	6.55
16	16	300	450	120	-5737	-1.10	-2.12
17	17	55	1500	120	-3337	-0.79	-4.98
18	18	250	450	120	4019	0.98	2.06
19	19	250	1050	120	5019	1.18	6.63
20	20	15	200	120	-1962	-0.46	-0.23
21	21	15	1650	110	-250	-0.16	-0.60
22	22	19	950	110	1779	0.66	3.21
23	23	21	1000	120	-3942	-0.93	-4.24
24	24	24	1250	110	17	0.01	0.00
25	25	250	900	120	-2520	-0.59	-0.92
26	26	250	750	120	-5922	-1.40	-6.75
27	27	250	900	120	-7902	-1.86	-13.82
28	28	250	250	130	-104413	-3.14	-2.62
29	29	250	650	120	26382	2.43	9.43
30	30	250	650	120	7654	1.81	5.43
31	31	260	750	130	58407	2.39	5.67
32	32	260	1000	110	2748	1.01	5.67
33	33	24	1000	110	-2252	-0.83	-5.23
34	34	27	600	120	21508	1.99	6.02
35	35	27	600	120	6278	1.48	6.02
36	36	37	2150	130	55657	2.28	14.88
37	37	25	2150	110	2512	0.96	14.88
38	38	27	650	120	5244	1.24	4.67
39	39	27	650	120	18052	1.66	4.67
40	40	28	250	120	8627	1.41	1.86
41	41	28	800	120	2037	0.48	1.00
42	42	33	750	120	11551	1.39	4.52
43	43	30	450	120	5647	1.57	5.02
44	44	31	350	120	5747	1.36	2.98
45	45	32	900	110	2320	0.86	5.00
46	46	32	900	110	-1184	-0.78	-5.81
47	47	35	900	120	10471	1.26	4.52
48	48	34	1100	120	-1263	-0.30	-0.57
49	49	35	909	120	8157	1.34	6.03
50	50	35	1350	120	4787	0.78	3.37
51	51	37	400	130	51299	2.10	2.38
52	52	38	400	110	2414	0.89	2.38
53	53	38	500	130	46200	1.97	2.65
54	54	38	500	110	2268	0.84	2.65
55	55	39	400	120	25377	1.50	1.82

ALTERNATIVE D-1-A (Recommended Plan, Single Pipeline Alignment)
 2 Reservoir System, Year 2010

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
56	39	42	500	120	20194	1.19	2.83
57	39	42	950	110	1663	0.61	2.83
58	39	57	1000	170	360	0.24	0.71
59	40	41	500	120	24477	1.44	1.70
60	41	42	250	120	-2280	-0.54	-0.69
61	41	43	450	120	13762	1.00	1.23
62	41	44	350	120	10295	1.24	4.87
63	42	48	450	120	16696	1.22	2.58
64	43	49	300	120	12142	0.89	1.94
65	44	45	450	120	1980	0.68	1.82
66	44	53	350	1150	5615	0.26	1.80
67	46	56	150	1150	-393	-2.01	-3.54
68	47	48	200	120	-8533	-2.34	3.03
69	47	56	300	120	8173	1.34	6.73
70	48	49	400	120	5253	0.49	0.22
71	49	50	400	120	3385	0.31	0.10
72	49	51	350	700	11880	1.43	4.44
73	50	53	850	110	505	0.33	1.13
74	51	52	350	550	5940	0.71	0.97
75	53	54	250	1000	3060	0.72	2.65
76	55	58	250	4800	-5857	-1.38	-6.82
77	58	59	600	130	-36587	-1.50	-0.03

ALTERNATIVE D-1-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Reservoir System, Year 1995

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	24.00	0.00	44.00	20.00	51.00
2	22.00	0.00	42.00	20.00	53.00
3	25.00	0.00	45.00	20.00	50.00
4	28.00	0.00	48.00	20.00	47.00
5	10.00	0.00	30.00	20.00	65.00
6	5.00	0.00	25.00	20.00	70.00
7	3.00	0.00	25.00	20.00	70.00
8	5.00	0.00	25.00	20.00	70.00
9	21.00	0.00	41.00	20.00	70.00
10	18.00	0.00	38.00	20.00	54.00
11	14.00	0.00	33.00	20.00	57.00
12	14.00	1400.00	44.43	30.43	61.00
13	10.00	730.00	43.77	33.77	65.00
14	10.00	740.00	44.96	34.96	65.00
15	10.00	730.00	44.69	34.69	65.00
16	5.00	0.00	25.00	20.00	70.00
17	9.00	900.00	29.96	20.96	66.00
18	10.00	1100.00	44.78	34.78	65.00
19	5.00	900.00	26.27	21.27	70.00
20	25.00	0.00	45.00	20.00	50.00
21	15.00	1100.00	46.29	30.29	59.00
22	14.00	1200.00	48.66	34.66	61.00
23	12.00	1000.00	48.66	34.66	63.00
24	5.00	0.00	25.00	20.00	70.00
25	10.00	2000.00	42.36	32.36	65.00
26	10.00	1600.00	48.43	38.43	65.00
27	9.00	1200.00	36.03	27.03	66.00
28	10.00	1600.00	21.35	22.35	66.00
29	10.00	800.00	21.20	17.20	65.00
30	10.00	600.00	22.15	12.15	65.00
31	5.00	700.00	19.41	14.41	70.00
32	5.00	2100.00	15.27	10.27	70.00
33	10.00	800.00	29.01	19.01	65.00
34	10.00	1700.00	31.81	21.81	65.00
35	5.00	0.00	25.00	20.00	70.00
36	5.00	0.00	25.00	20.00	70.00
37	9.00	1700.00	34.71	25.71	66.00
38	9.00	1800.00	32.80	23.80	66.00
39	9.00	1800.00	30.69	21.69	66.00
40	8.00	0.00	27.85	19.85	67.00
41	8.00	2100.00	25.01	17.01	67.00
42	8.00	1800.00	26.38	18.38	67.00
43	8.00	1000.00	21.06	13.06	67.00
44	8.00	1600.00	22.19	14.19	67.00
45	10.00	0.00	30.00	20.00	65.00
46	5.00	1400.00	13.16	8.16	70.00
47	8.00	1800.00	18.79	10.79	67.00
48	8.00	1800.00	19.60	11.60	67.00
49	8.00	1800.00	19.16	11.16	67.00
50	8.00	900.00	19.08	11.08	67.00
51	8.00	3300.00	15.99	7.99	67.00
52	5.00	3300.00	14.32	9.32	70.00
53	10.00	0.00	30.00	20.00	65.00
54	9.00	0.00	29.00	20.00	65.00
55	25.00	0.00	52.71	27.71	50.00

ALTERNATIVE D-1-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Reservoir System, Year 1995

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0/100)
1	12	250	850	120	-1400	-0.33	-0.53
2	13	14	150	450	-730	-0.48	-2.64
3	14	55	250	1600	-4238	-1.00	-7.75
4	14	15	250	450	1368	0.32	0.60
5	15	17	180	1050	1800	1.16	14.03
6	15	18	250	200	-1162	-0.27	-0.09
7	17	19	150	1000	900	0.59	3.89
8	18	21	250	1000	-2262	-0.53	-1.51
9	21	22	250	750	-3352	-0.78	-3.15
10	21	23	250	900	-4562	-1.08	-5.55
11	23	60	800	250	-48562	-1.99	-1.34
12	23	25	250	650	8450	1.99	11.30
13	23	26	200	750	2629	0.97	6.97
14	23	26	500	750	31922	1.88	5.22
15	25	27	250	600	6450	1.52	10.54
16	26	37	200	2150	2507	0.92	13.72
17	26	37	500	2150	30443	1.79	6.38
18	27	28	250	650	5250	1.24	4.68
19	28	29	200	250	4200	1.55	4.15
20	28	34	250	800	-1350	-0.32	-0.58
21	28	33	150	750	800	0.52	3.12
22	29	30	200	450	3400	1.25	5.05
23	30	31	200	350	2800	1.03	2.74
24	31	32	200	900	2100	0.77	4.14
25	34	37	250	1100	-3098	-0.72	-2.90
26	37	38	200	400	2149	0.79	4.78
27	37	38	500	400	26055	1.54	1.91
28	38	39	200	500	2008	0.74	2.12
29	38	39	500	500	24392	1.44	2.12
30	39	40	350	400	12612	1.52	2.84
31	39	42	250	950	9904	1.19	4.30
32	39	42	250	950	2084	0.77	4.53
33	40	41	350	400	12612	1.52	2.84
34	41	43	300	500	8912	1.46	3.95
35	41	44	150	250	1600	1.05	11.28
36	42	48	300	650	10188	1.67	6.57
37	43	48	300	300	7912	1.30	11.11
38	45	56	200	1550	-1400	-0.52	-3.36
39	47	48	300	200	-7000	-1.15	-2.17
40	47	56	300	450	7000	1.15	5.05
41	48	49	200	300	1388	0.51	2.13
42	48	50	250	300	900	0.21	0.68
43	49	51	300	700	6500	1.08	0.27
44	51	52	250	550	3300	0.78	3.17
45	55	58	250	4600	-4238	-1.00	-22.28
46	58	59	350	10	-4237	-0.51	-0.94

ALTERNATIVE D-1-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Reservoir System, Year 2010

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	24.00	1430.00	64.33	40.33	51.00
2	22.00	2300.00	61.19	39.19	53.00
3	25.00	1080.00	57.60	32.60	50.00
4	28.00	2880.00	46.50	18.50	47.00
5	10.00	3050.00	35.22	25.22	65.00
6	5.00	1080.00	25.01	20.01	70.00
7	5.00	3960.00	12.76	7.76	70.00
8	5.00	2970.00	15.59	10.59	70.00
9	5.00	990.00	19.53	14.53	70.00
10	21.00	2030.00	61.30	40.30	54.00
11	18.00	3240.00	53.14	35.14	57.00
12	14.00	1920.00	42.95	28.95	61.00
13	10.00	900.00	27.51	17.51	65.00
14	10.00	1260.00	31.21	21.21	65.00
15	10.00	1080.00	29.04	19.04	65.00
16	5.00	1080.00	14.09	9.09	70.00
17	9.00	3240.00	18.73	9.73	65.00
18	10.00	1980.00	20.18	10.18	65.00
19	5.00	1570.00	15.38	11.38	70.00
20	25.00	2520.00	34.95	9.95	30.00
21	16.00	1980.00	32.55	16.55	59.00
22	14.00	1980.00	38.37	24.37	61.00
23	12.00	1370.00	50.74	38.74	63.00
24	5.00	2770.00	16.46	11.46	70.00
25	10.00	6160.00	42.13	32.13	65.00
26	10.00	2880.00	45.02	35.02	65.00
27	9.00	4590.00	36.74	21.74	66.00
28	9.00	1080.00	32.66	23.66	66.00
29	10.00	1980.00	30.45	20.45	65.00
30	10.00	900.00	25.30	15.30	65.00
31	5.00	1170.00	22.21	17.21	70.00
32	5.00	3570.00	16.78	11.78	70.00
33	10.00	1080.00	25.50	19.50	65.00
34	10.00	3900.00	32.25	22.25	65.00
35	5.00	1130.00	21.67	16.67	70.00
36	5.00	3370.00	16.90	11.90	70.00
37	9.00	3300.00	33.62	24.62	65.00
38	9.00	3240.00	31.18	22.18	66.00
39	8.00	2880.00	28.45	19.45	66.00
40	8.00	900.00	26.92	18.92	67.00
41	8.00	2700.00	24.86	16.86	67.00
42	8.00	2880.00	25.41	17.41	67.00
43	8.00	1620.00	23.64	15.64	67.00
44	8.00	2700.00	22.91	14.91	67.00
45	5.00	1980.00	21.49	11.49	65.00
46	5.00	5180.00	14.69	9.69	70.00
47	8.00	360.00	21.64	13.64	67.00
48	8.00	2980.00	23.42	15.42	67.00
49	8.00	2160.00	23.04	15.04	67.00
50	8.00	2880.00	22.87	14.87	67.00
51	8.00	5940.00	19.19	11.19	67.00
52	5.00	5940.00	17.81	12.81	70.00
53	10.00	3060.00	21.16	11.16	65.00
54	9.00	3060.00	18.51	9.51	66.00
55	25.00	0.00	35.87	10.87	50.00

Iteration Times : 32

ALTERNATIVE D-1-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Reservoir System, Year 2010

<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
56	5.00	7780.00	17.91	12.91	70.00
57	15.00	360.00	27.74	12.74	60.00
58	70.00	0.00	74.98	4.98	5.00
59	75.00	0.00	75.00	0.00	0.00
60	55.00	0.00	55.00	0.00	20.00

ALTERNATIVE D-1-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Reservoir System, Year 2010

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL (m/sec)	HEADLOSS (m) (0/00)
1	1 58	600	4500	130	-31184	-1.28	-10.65
2	1 2	350	400	120	13317	1.60	3.14
3	1 10	400	500	120	16438	1.51	3.02
4	2 3	350	650	120	11017	1.33	6.04
5	4 3	300	1150	120	9937	1.63	3.59
6	4 5	300	1150	120	9937	1.63	11.11
7	5 6	350	2200	120	7057	1.16	9.66
8	6 7	250	2350	120	3997	0.94	11.27
9	7 8	200	1450	110	2917	0.94	5.12
10	8 9	250	2250	110	-1043	-0.38	4.35
11	9 16	250	900	120	-4013	-0.95	8.45
12	9 13	300	1000	120	1060	-0.94	-1.26
13	10 11	350	2050	120	-6083	-1.00	-3.94
14	11 12	350	900	120	14408	1.73	5.45
15	12 14	150	850	120	11168	1.83	3.89
16	12 14	250	850	120	1785	1.17	9.07
17	13 14	250	650	120	7463	1.75	11.74
18	13 14	250	450	120	-5635	-1.33	13.81
19	14 55	150	450	120	-1348	-0.88	-3.69
20	14 15	250	1600	120	-3222	-0.76	-8.21
21	15 17	200	450	120	4226	1.00	-2.92
22	15 18	250	1050	120	3165	1.17	4.82
23	15 18	250	1050	120	-1503	-0.35	9.82
24	17 19	150	950	120	703	0.46	0.14
25	17 19	150	950	120	705	0.46	-0.71
26	18 21	250	1000	120	-3483	-0.82	2.47
27	19 24	150	1250	120	-100	-0.07	2.37
28	20 55	250	750	120	-2520	-0.59	-0.07
29	21 22	250	750	120	-5463	-1.29	-0.82
30	22 31	250	900	120	-7443	-1.76	-5.81
31	23 60	300	250	120	-13505	-2.21	-1.75
32	23 25	400	650	120	25118	2.31	-12.37
33	23 26	500	750	120	30209	1.78	-13.75
34	23 26	500	750	120	30209	1.78	13.25
35	23 26	500	750	120	-90568	-3.71	5.29
36	23 26	500	750	120	7287	1.72	-17.05
37	23 26	500	750	120	2387	0.92	8.61
38	24 31	200	750	120	30209	1.76	4.72
39	25 27	400	1000	120	-2370	-0.87	6.29
40	25 27	400	600	120	20345	1.87	4.72
41	26 37	500	2150	120	5910	1.39	-5.75
42	26 37	500	2150	120	28826	1.70	5.38
43	25 27	500	2150	120	28826	0.87	8.97
44	27 28	400	650	120	28826	1.70	5.77
45	27 28	400	650	120	16788	1.70	12.40
46	28 29	250	750	120	4877	1.35	5.77
47	28 33	350	750	120	5664	1.15	4.08
48	28 33	350	750	120	9529	1.38	6.28
49	28 33	350	750	120	2469	1.10	8.84
50	28 33	350	750	120	1263	0.30	4.22
51	29 30	200	450	110	941	0.92	6.64
52	29 30	200	450	110	3436	1.27	0.41
53	30 31	200	350	110	2986	1.10	3.16
54	30 31	200	350	110	2986	1.10	5.15
55	31 32	200	900	110	2432	0.90	11.44
							3.09
							8.82
							6.03

ALTERNATIVE D-1-B (Parallel Pipeline Alignment of Recommended Plan)
 2 Reservoir System, Year 2010

<< PIPELINE >>

PIPE No.	PIPE No. from-to	DIA (mm)	LENGTH (m)	H-W C	FLOW (cu.m/day)	VEL (m/sec)	HEADLOSS (m) (0/00)
56	32 35	150	900	110	-1078	-0.71	-4.88
57	33 34	300	900	120	9390	1.54	7.83
58	35 36	300	1100	120	-2037	-0.48	8.70
59	35 36	300	900	120	7162	1.18	-1.37
60	35 36	300	1350	120	3812	0.62	4.77
61	37 38	500	400	120	29716	1.75	2.21
62	37 38	200	400	110	2447	0.90	2.44
63	37 38	450	400	120	22524	1.64	2.44
64	38 39	500	500	120	27956	1.65	2.72
65	38 39	200	500	110	2302	0.85	5.45
66	38 39	450	500	120	21190	1.54	2.72
67	39 40	150	1000	110	360	0.24	5.45
68	39 40	450	400	120	17534	1.28	0.71
69	39 40	400	950	120	11674	1.08	1.53
70	39 40	350	400	120	9054	1.09	3.05
71	39 40	350	400	120	8217	0.99	3.21
72	39 40	200	950	110	1729	0.64	3.05
73	40 41	400	400	120	15076	1.39	3.05
74	40 41	250	400	120	10612	1.28	5.15
75	41 42	350	450	120	-2011	-0.47	2.06
76	41 43	400	500	120	10093	0.93	0.55
77	41 44	300	250	120	8858	1.45	1.22
78	41 43	300	500	120	4736	0.78	7.81
79	41 44	150	250	110	1312	0.86	1.22
80	42 48	400	650	120	11386	1.05	1.99
81	42 48	300	650	120	5343	0.87	3.06
82	43 49	400	300	120	8991	0.83	0.59
83	43 49	300	300	120	4719	0.69	1.98
84	44 45	250	1200	120	1580	0.47	0.59
85	44 45	350	1150	120	5490	0.66	1.42
86	45 56	200	1550	120	-1368	-0.50	1.75
87	47 48	300	200	120	9508	-1.56	-3.22
88	47 48	300	450	120	9148	1.50	-1.78
89	48 49	300	300	120	3299	0.54	8.29
90	48 49	200	300	110	1041	0.38	1.25
91	49 50	300	300	120	2168	0.36	0.38
92	49 50	250	700	120	4543	1.07	0.17
93	49 50	250	300	120	1342	0.32	3.66
94	51 51	300	700	120	7337	1.20	0.17
95	50 53	150	850	110	630	0.41	5.51
96	51 52	250	550	120	2970	0.70	1.71
97	51 52	250	550	120	2970	0.70	1.38
98	51 54	250	1000	120	3060	0.72	2.51
99	55 58	250	4600	120	-5742	-1.35	2.65
100	58 59	600	10	130	-30174	-1.24	-39.10
101	58 59	350	10	120	-6749	-0.81	-0.02

ALTERNATIVE D-2
3 Reservoir System, Year 2010
<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
1	24.00	1430.00	63.45	39.45	51.00
2	22.00	2300.00	61.81	39.81	53.00
3	25.00	1080.00	58.19	33.19	50.00
4	28.00	2880.00	48.98	18.98	47.00
5	10.00	3050.00	35.57	25.57	65.00
6	5.00	1080.00	25.12	20.12	70.00
7	5.00	3950.00	12.50	7.50	70.00
8	5.00	2970.00	15.09	10.09	70.00
9	5.00	990.00	18.94	13.94	70.00
10	21.00	2030.00	59.98	38.98	54.00
11	18.00	3240.00	50.42	32.42	57.00
12	14.00	1920.00	37.95	23.95	61.00
13	10.00	900.00	26.62	16.62	65.00
14	10.00	1250.00	28.81	18.81	65.00
15	10.00	1080.00	24.92	14.92	65.00
16	5.00	1080.00	14.20	9.20	70.00
17	9.00	3240.00	17.75	8.75	66.00
18	10.00	1980.00	24.93	14.93	65.00
19	5.00	1510.00	14.27	9.27	70.00
20	25.00	2520.00	32.97	7.97	50.00
21	16.00	1980.00	26.58	10.58	59.00
22	14.00	1980.00	30.39	15.39	61.00
23	12.00	1310.00	39.54	27.54	63.00
24	5.00	2270.00	14.14	9.14	70.00
25	10.00	6150.00	32.42	22.42	65.00
26	10.00	2880.00	29.53	19.53	65.00
27	9.00	4590.00	28.18	18.18	66.00
28	9.00	1080.00	25.13	15.13	66.00
29	10.00	1980.00	23.30	13.30	65.00
30	10.00	900.00	21.25	11.25	65.00
31	5.00	1170.00	18.33	13.33	70.00
32	5.00	3510.00	16.66	11.66	70.00
33	10.00	1080.00	22.62	12.62	65.00
34	10.00	3300.00	25.08	15.08	65.00
35	5.00	1130.00	17.68	12.68	70.00
36	5.00	3370.00	15.05	10.05	70.00
37	9.00	3300.00	27.55	18.55	66.00
38	9.00	3240.00	37.89	28.89	66.00
39	9.00	2880.00	34.94	25.94	66.00
40	8.00	900.00	31.12	23.12	67.00
41	8.00	2700.00	27.51	19.51	67.00
42	8.00	2880.00	27.67	19.67	67.00
43	8.00	1620.00	24.41	15.41	67.00
44	8.00	2700.00	25.50	17.50	67.00
45	10.00	1980.00	20.55	10.55	65.00
46	5.00	5180.00	14.47	9.47	70.00
47	8.00	360.00	21.80	13.80	67.00
48	8.00	2880.00	22.99	14.99	67.00
49	8.00	2160.00	22.88	14.88	67.00
50	8.00	2880.00	22.70	14.70	67.00
51	8.00	5940.00	18.44	10.44	67.00
52	5.00	5940.00	16.39	11.39	70.00
53	10.00	3050.00	19.74	9.74	65.00
54	9.00	3050.00	17.09	8.09	66.00
55	25.00	0.	33.89	8.89	50.00

Iteration Times : 29

ALTERNATIVE D-2
3 Reservoir System, Year 2010
<< NODES >>

NODE No.	GROUND ELEV. (m)	FLOW (cu. m/day)	H.G.L. ELEV. (m)	DYNAMIC HEAD (m)	STATIC HEAD (m)
56	5.00	7780.00	16.45	11.45	70.00
57	15.00	360.00	29.81	14.81	60.00
58	70.00	0.00	74.97	4.97	5.00
59	75.00	0.00	73.00	0.00	0.00
60	40.00	0.00	40.00	0.00	35.00
61	40.00	0.00	40.00	0.00	35.00

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
56	39 57	100.	1000.	110.	360.	0.53	5.13
57	40 41	450.	400.	120.	27821.	2.02	3.61
58	41 42	200.	450.	110.	-522.	-0.19	-0.16
59	41 43	400.	500.	120.	16650.	1.53	3.09
60	41 44	300.	250.	120.	8994.	1.47	2.01
61	42 48	400.	650.	120.	18053.	1.66	4.67
62	43 49	400.	300.	120.	15030.	1.38	1.54
63	44 45	200.	1200.	110.	1960.	0.73	4.95
64	44 53	250.	1150.	120.	4314.	1.02	5.76
65	46 56	300.	1550.	120.	-3336.	-0.55	-1.98
66	47 48	350.	200.	120.	-11476.	-1.38	-1.19
67	47 56	300.	450.	120.	11116.	1.62	5.35
68	48 49	400.	300.	120.	3697.	0.34	0.11
69	49 50	400.	300.	120.	4686.	0.43	0.18
70	49 51	350.	700.	120.	11880.	1.43	4.44
71	50 53	200.	850.	110.	1806.	0.67	2.95
72	51 52	300.	550.	120.	5940.	0.97	2.05
73	53 54	250.	1000.	120.	3660.	0.72	2.65
74	55 58	250.	4600.	120.	-5895.	-1.35	-41.07
75	58 59	600.	10.	130.	-38414.	-1.57	-0.03

PIPE No.	PIPE No. from-to	DIA. (mm)	LENGTH (m)	H-W C	FLOW (cu. m/day)	VEL. (m/sec)	HEADLOSS (m) (0/00)
1	58 600.	130.	4500.	130.	-32518.	-1.33	-11.51
2	1 2	400.	13365.	120.	17723.	1.63	3.47
3	1 3	400.	500.	120.	11065.	1.33	3.62
4	2 3	350.	650.	120.	9985.	1.63	11.21
5	3 4	300.	1150.	120.	7105.	1.16	11.42
6	4 5	300.	2200.	120.	4045.	0.95	10.44
7	5 6	250.	2350.	120.	2965.	1.09	12.63
8	6 7	200.	1450.	110.	-995.	-0.37	-2.59
9	7 8	200.	2950.	110.	-3685.	-0.93	-3.85
10	8 9	250.	600.	120.	-5957.	-0.98	-7.68
11	9 13	300.	2050.	120.	1002.	0.66	4.74
12	10 11	350.	1000.	110.	15693.	1.89	9.56
13	11 12	300.	850.	120.	12453.	2.04	12.47
14	12 14	300.	850.	120.	10533.	1.72	9.14
15	13 14	200.	450.	120.	-6857.	-1.12	-2.19
16	14 55	250.	1600.	120.	-3316.	-0.80	-5.09
17	15 17	250.	450.	120.	5792.	1.37	3.89
18	16 18	250.	1050.	120.	5099.	1.20	7.16
19	17 20	250.	1050.	120.	-387.	-0.09	-0.01
20	18 20	150.	1650.	110.	-78.	-0.05	-0.07
21	19 19	200.	950.	110.	1859.	0.68	3.49
22	17 19	200.	950.	110.	-2367.	-0.56	-1.65
23	18 21	250.	1000.	120.	211.	0.10	0.13
24	19 24	200.	1250.	110.	-2520.	-0.59	-0.92
25	20 55	250.	500.	120.	-4347.	-1.03	-3.81
26	21 22	250.	750.	120.	-6371.	-1.49	-6.16
27	22 23	250.	900.	120.	-40623.	-1.22	-0.46
28	23 60	700.	250.	130.	22663.	2.09	7.12
29	23 25	250.	650.	120.	6585.	1.55	7.12
30	25 250.	250.	650.	120.	3736.	1.38	10.02
31	23 26	200.	750.	110.	-1999.	-0.74	-4.19
32	24 31	200.	1000.	110.	17892.	1.65	4.24
33	25 27	400.	600.	120.	5168.	1.23	4.24
34	25 27	250.	600.	120.	656.	0.32	1.87
35	26 37	200.	2150.	110.	4169.	0.98	3.05
36	27 28	250.	650.	120.	14395.	1.32	3.05
37	27 28	400.	650.	120.	8574.	1.40	1.84
38	29 300.	250.	120.	120.	437.	0.10	0.06
39	28 34	250.	800.	120.	8408.	1.01	2.51
40	28 33	350.	750.	120.	5594.	1.08	2.03
41	29 30	300.	450.	120.	5694.	1.34	2.93
42	30 31	250.	350.	120.	2526.	0.60	1.67
43	31 32	250.	900.	110.	-984.	-0.35	-1.02
44	32 35	300.	900.	120.	7328.	1.20	4.95
45	33 35	300.	1100.	120.	-2863.	-0.67	-2.34
46	34 37	250.	900.	120.	5214.	0.85	2.63
47	35 36	300.	900.	120.	1844.	0.30	0.93
48	36 46	300.	1350.	120.	-5307.	-1.36	-10.24
49	37 38	200.	400.	110.	51016.	2.09	2.94
50	38 39	600.	500.	130.	2401.	0.88	2.94
51	38 39	200.	500.	110.	61963.	-2.54	-8.44
52	38 61	600.	250.	130.	28721.	2.09	3.83
53	39 40	450.	950.	120.	18688.	1.72	7.28
54	39 42	400.	950.	120.	2767.	1.02	7.28
55	39 42	200.	950.	110.			

F. COST COMPARISON

General

Analysis and evaluation of alternative are based largely on present-worth cost studies, taking into consideration the salvage value after the design period. Cost comparison is based on present worth of net disbursement during the period of 1980-2010 without any escalation factor applied to the 1980 unit prices.

If the differences between net PW cost of an alternative and that of the least-cost alternative is within the limit of cost estimating accuracy (10-15%) further cost comparison shall be made applying escalation factor to 1980 unit prices. For escalation rates, refer to Chapter VII-C: Escalation Rates. Moreover, non-economic parameters may also be influence the selection of the recommended plan.

Construction Cost

Construction cost estimates of the proposed improvements are based on the projected July 1980 unit prices. All estimates on imported materials are based on an exchange rate of ₱7.40 per 1 US dollar. Further, it is assumed that no custom duty will be charged on items imported for the public water supply project. The cost of any facility to be replaced during the design period (1980-2010) is included under the capital cost for the particular year.

Annual Cost

Annual costs are all costs associated with the maintenance, operation, and management of the project. These include labor, power, chemical and maintenance costs. These estimates are carried out for the period 1980-2010. The present-worth cost of annual expenditure is based on uniform and gradient series at a given interest.

Personnel and maintenance costs may abruptly increase as additional facilities are put into operation - e.g., the power cost at a pump station increases in relation to the daily pumpage of water.

Salvage Value

The salvage values of facilities at the end of the design period 2010 are important in calculating net present worth of the total expenditures. It is assumed that the value of a facility depreciates linearly throughout its service life therefore, a facility with longer service life depreciates less than a facility with shorter service life (Refer to Table VI-1 for service life of different facilities). Moreover, a facility constructed at a later stage has higher salvage value than one constructed at an earlier stage.

TABLE VI-1

SERVICE LIFE CATEGORIES OF FACILITIES

Civil Works	Economic Life	Equipment	Economic Life
Wells	30 years	Wells (pumping engine or motors)	15 years
Springs	50	Springs (vales, pipes)	50
Transmission Mains	50	Transmission (pipes, valves)	50
Storage Facilities	50	Storage (valves, pipes, level gauge, etc.)	50
Disinfection Facilities	50	Disinfection facilities (chlorinators, mech-	
Distribution Mains	50	anical equipment and filter equipment,	
Internal Network	50	pipes, valves)	15
Service Connections	50	Distribution mains (pipes, valves)	50
Fire Hydrants	50	Internal networks (pipes, valves)	50
Operational Buildings	50	Service connections (meters, pipes)	50
		Operational buildings (workshop, etc.)	15
		Fire hydrants	30
		Vehicles	7

Net Present Worth

The net present worth cost of an alternative scheme is the difference between the total present worth of capital cost and annual cost minus the present worth of salvage values.

For Construction Cost:

$$C_n = C_c - C_s$$

$$C_c = C \times \frac{1}{(1+i)^n}$$

$$C_c = C \times \frac{1}{(1+i)^{nx}} \times \left(1 - \frac{nx - n}{SL}\right)$$

For Annual Cost:

$$C_c = A_c \times \frac{1}{(1+i)^n}$$

where,

C_n = net present worth comparable cost

C_c = present worth of construction cost

C_s = present worth of salvage value (design year)

C = construction cost

SL = service life

i = discount rate

nx = number of years between design year and base year

n = number of years between year of construction and base year

A_c = annual cost

Cabuyao-Sta. Rosa-Binan ITEM	UNIT COST	Phase I (Stage 1)		Phase I (Stage 2)		Phase I		Phase II		
		NUMBER	COST	NUMBER	COST	NUMBER	COST	NUMBER	COST	
1 SOURCE FACILITY										
(1) DEEP WELL CONSTRUCTION	1180000	0	0	4	4640	4	4640	11	12760	
(2) DEEP WELL PUMP w/HOUSE Flow Meter D=150	790000 82000	1 1	790 82	4 4	3160 248	5 5	3950 310	11 11	8890 882	
SUB-TOTAL			852		8048		8900		22132	
2 TRANSMISSION FACILITIES										
(1) Pipe Protection										
D=200	251	400	100	0	0	400	100	0	0	
D=300	337	400	135	0	0	400	135	0	0	
(2) Main Pipes										
D=250 (Steel Pipe)	630	1100	693	1300	819	2400	1512	4800	3024	
D=350 (Steel Pipe)	900	0	0	0	0	0	0	700	830	
D=400 (Steel Pipe)	970	1100	1067	0	0	1100	1067	1800	1746	
D=450 (Steel Pipe)	1160	1300	1508	0	0	1300	1508	0	0	
D=500 (Steel Pipe)	1330	0	0	0	0	0	0	500	665	
D=600 (Steel Pipe)	1600	0	0	0	0	0	0	3200	5120	
D=700 (Steel Pipe)	1910	0	0	0	0	0	0	1200	2292	
SUB-TOTAL			3503		819		4322		13477	
3 DISTRIBUTION FACILITIES										
(1) Reservoir			3417	0	0		3417		11291	
(2) Pump Facility (Equip.)			2090		3084		5174		6437	
-do- (Civil)			2668		0		2668		3216	
(3) Chlorin Facility 22kg/d	98100	2	196	1	98	3	294	1	98	
-do- 45kg/d	119000	0	0	0	0	0	0	1	119	
(4) Electric Sub-station			3643						4858	
(5) Distribution pipes										
1) Main Pipes										
D=150 (PVC Pipe)	410	0	0	2950	1210	2950	1210	4000	1640	
D=200 (Steel Pipe)	520	0	0	1850	962	1850	962	5950	3094	
D=250 (Steel Pipe)	630	2050	1292	0	0	2050	1292	8000	5040	
D=300 (Steel Pipe)	760	2000	1520	2300	1748	4300	3268	7100	5396	
D=350 (Steel Pipe)	900	1450	1305	1400	1260	2850	2565	2500	2250	
D=400 (Steel Pipe)	970	600	582	0	0	600	582	2400	2328	
D=450 (Steel Pipe)	1160	1450	1682	0	0	1450	1682	0	0	
D=500 (Steel Pipe)	1330	950	1264	800	1064	1750	2328	0	0	
D=600 (Steel Pipe)	1600	3800	6080	0	0	3800	6080	4500	7200	
D=700 (Steel Pipe)	1910	250	478	0	0	250	478	0	0	
2) Valves										
D=150 (Gate Valve)	5300	0	0	15	80	15	80	18	95	
D=200 (Gate Valve)	6700	0	0	6	40	6	40	20	134	
D=250 (Gate Valve)	11200	7	79	0	0	7	79	27	302	
D=300 (Butterfly Valve)	34800	7	243	8	278	15	521	24	835	
D=350 (Butterfly Valve)	74400	5	372	5	372	10	744	8	595	
D=400 (Butterfly Valve)	95200	2	190	3	286	5	476	0	0	
D=450 (Butterfly Valve)	125900	5	630	0	0	5	630	0	0	
D=500 (Butterfly Valve)	174000	3	522	3	522	6	1044	0	0	
D=600 (Butterfly Valve)	243600	13	3167	0	0	13	3167	15	3654	
D=700 (Butterfly Valve)	313200	1	313	0	0	1	313	0	0	
3) Internal Network										
Commercial 150pop/ha	25700	0	0	18	463	18	463	0	0	
Commercial 250pop/ha	30400	0	0	0	0	0	0	62	1885	
Residential 100pop/ha	18700	52	972	0	0	52	972	0	0	
Residential 150pop/ha	21000	0	0	394	8274	394	8274	0	0	
Residential 250pop/ha	30400	0	0	0	0	0	0	561	17054	
4) Service Connections										
D=1/2	810	4901	3970	15464	12525	20365	16495	42879	34732	
D=3/4	1280	66	84	12	17	78	101	74	95	
5) Rehabilitation										
Water Meter 1/2"	400	491	196	0	0	491	196	0	0	
Water Meter 3/4"	880	0	0	0	0	0	0	0	0	
Old Laterals			860	0	0	0	860	0	0	
Service Cnctn.w/Meter	480	246	117	0	0	246	117	0	0	
Service Cnctn.w/Meter	880	1208	1064	0	0	1208	1064	0	0	
6) Flow Meter D=150	62000	1	62	0	0	1	62	0	0	
-do- D=350	164000	1	164	0	0	1	164	2	328	
7) Pipe Protection										
D=150	16800	0	0	0	0	0	0	75	1260	
D=100	9400	0	0	0	0	0	0	335	3140	
SUB-TOTAL			39220		32283		71503		117185	
4 Administration Bldg.										
(2) Operation Center			1583				1583		1820	
SUB-TOTAL			1583		0		1583		1820	
5 Land Acquisition										
Vehicle	300000	2	600	4	1200	6	1800	13	3900	
Stored Material & Equip.			501		561		1062		1841	
SUB-TOTAL			1281		1961		3242		7151	
6 Replacement of Equipment										
TOTAL			46439		43111		89550		182613	
7 Leak Detection										
	240	2907	899	0	0	2907	899	0	0	
GRAND TOTAL			47138		43111		90249		182613	

(Unit: thousand Pesos)

Cabuyao-Sta.Rosa-Binan	UNIT COST	1988		1989		1990		1991	
		NO	COST	NO	COST	NO	COST	NO	COST
1 SOURCE FACILITY									
(1) DEEP WELL CONSTRUCTION	1160000	0	0	0	0	0	0	1	1160
(2) DEEP WELL PUMP w/HOUSE Flow Meter D=150	790000	0	0	1	790	0	0	1	790
	62000	0	0	1	62	0	0	1	62
SUB-TOTAL			0	2	852		0		2012
2 TRANSMISSION FACILITIES									
(1) Pipe Protection									
D=200	251		0	400	100		0		0
D=300	337		0	400	135		0		0
(2) Main Pipes								800	504
D=250 (Steel Pipe)	630		0	1100	693		0		0
D=350 (Steel Pipe)	900		0	0	0		0		0
D=400 (Steel Pipe)	970		0	1100	1067		0		0
D=450 (Steel Pipe)	1160		0	1300	1508		0		0
D=500 (Steel Pipe)	1330		0	0	0		0		0
D=600 (Steel Pipe)	1600		0	0	0		0		0
D=700 (Steel Pipe)	1910		0	0	0		0		0
SUB-TOTAL			0		3503		0		504
3 DISTRIBUTION FACILITIES									
(1) Reservoir				1	3417				
(2) Pump Facility (Equip.)					2090				3084
-do- (Civil)					2666				
(3) Chlrtn Facility 22kg/d	98100			2	196		0	1	98
-do- 45kg/d	119000				0		0	0	0
(4) Electric Sub-station				1	3643				
(5) Distribution pipes		1988		1989		1990		1991	
1) Main Pipes									
D=150 (PVC Pipe)	410		0		0		0	2950	1210
D=200 (Steel Pipe)	520		0		0		0	1850	962
D=250 (Steel Pipe)	630		0	1050	662	1000	630	0	0
D=300 (Steel Pipe)	760		0	700	532	1300	988	2300	1748
D=350 (Steel Pipe)	900		0	750	675	700	630	1400	1260
D=400 (Steel Pipe)	970		0	300	291	300	291	0	0
D=450 (Steel Pipe)	1160		0	650	754	800	928	0	0
D=500 (Steel Pipe)	1330		0	950	1264		0	800	1064
D=600 (Steel Pipe)	1600		0	3800	6080		0		0
D=700 (Steel Pipe)	1910		0	250	478		0		0
2) Valves								15	80
D=200 (Gate Valve)	6700		0		0		0	6	40
D=250 (Gate Valve)	11200		0	4	45	3	34	0	0
D=300 (Butterfly Valve)	34800		0	3	104	4	139	8	278
D=350 (Butterfly Valve)	74400		0	3	223	2	149	5	372
D=400 (Butterfly Valve)	95200		0	1	95	1	95	3	286
D=450 (Butterfly Valve)	125900		0	2	252	3	378	0	0
D=500 (Butterfly Valve)	174000		0	3	522		0	3	522
D=600 (Butterfly Valve)	243600		0	13	3167		0	0	0
D=700 (Butterfly Valve)	313200		0	1	313		0	0	0
3) Internal Network								4	103
Commercial 150pop/ha	25700		0		0		0		0
Commercial 250pop/ha	30400		0		0		0		0
Residential 100pop/ha	18700		0	26	486	26	486		0
Residential 150pop/ha	21000		0		0		0	79	1650
Residential 250pop/ha	30400		0		0		0		0
4) Service Connections								3093	2505
D=1/2	810		0	2451	1985	2450	1985		
D=3/4	1280		0	33	42	33	42	3	4
5) Rehabilitation									
Water Meter 1/2"	400	191	196	0	0	0	0		0
Water Meter 3/4"	880	0	0	0	0	0	0		0
-Old Laterals			0		430		-430		0
Service Cnctn. w/Meter	480	82	39	82	39	82	39		0
Service Cnctn. w/Meter	880	403	355	403	355	402	354		0
6) Flow Meter D=150	62000		0	1	62		0		0
-do- D=150	164000		0	1	164		0		0
7) Fire Protection									
D=150	16800		0		0		0		0
D=100	9400		0		0		0		0
SUB-TOTAL			590		31032		7598		15275
4									
(1) Administration Bldg.					1583				
(2) Operation Center									
SUB-TOTAL			0		1583		0		0
5 Land Acquisition									
Vehicle	100	1800	180		0		0	2000	200
Stored Material & Equip.	300000	2	600		0		0		300
SUB-TOTAL			791		387		103		243
6 Replacement of Equipment									
			0		0		0		0
T O T A L			1381		37357		7701		18531
7 Leak Detection									
	240	980	233	989	233	969	233		0
GRAND TOTAL			1661		37590		7934		18531

(Unit: thousand Pesos)

Cabuyao-Sta.Rosa-Binan		UNIT COST		1992		1993		1994		1995	
ITEM		NO	COST	NO	COST	NO	COST	NO	COST	NO	COST
1 SOURCE FACILITY											
(1) DEEP WELL CONSTRUCTION	1160000	1	1160	1	1160	1	1160	0	0	0	0
(2) DEEP WELL PUMP w/HOUSE	790000	1	790	1	790	1	790	0	0	0	0
Flow Meter D=150	62000	1	62	1	62	1	62	0	0	0	0
SUB-TOTAL		3	2012	3	2012	3	2012	0	0	0	0
2 TRANSMISSION FACILITIES											
(1) Pipe Protection											
D=200	251	0	0	0	0	0	0	0	0	0	0
D=300	337	0	0	0	0	0	0	0	0	0	0
(2) Main Pipes											
D=250 (Steel Pipe)	630	200	126	200	126	100	63				0
D=350 (Steel Pipe)	900		0		0		0				0
D=400 (Steel Pipe)	970		0		0		0				0
D=450 (Steel Pipe)	1160		0		0		0				0
D=500 (Steel Pipe)	1330		0		0		0				0
D=600 (Steel Pipe)	1600		0		0		0				0
D=700 (Steel Pipe)	1910		0		0		0				0
SUB-TOTAL			126		126		63				0
3 DISTRIBUTION FACILITIES											
(1) Reservoir											
(2) Pump Facility (Equip.)											
-do- (Civil)											
(3) Chlorntrn Facility 22kg/d	98100	0	0	0	0	0	0	0	0	0	0
-do- 45kg/d	119000	0	0	0	0	0	0	0	0	0	0
(4) Electric Sub-station											
(5) Distribution pipes											
1) Main Pipes											
D=150 (PVC Pipe)	410		0		0		0		0		0
D=200 (Steel Pipe)	520		0		0		0		0		0
D=250 (Steel Pipe)	630		0		0		0		0		0
D=300 (Steel Pipe)	760		0		0		0		0		0
D=350 (Steel Pipe)	900		0		0		0		0		0
D=400 (Steel Pipe)	970		0		0		0		0		0
D=450 (Steel Pipe)	1160		0		0		0		0		0
D=500 (Steel Pipe)	1330		0		0		0		0		0
D=600 (Steel Pipe)	1600		0		0		0		0		0
D=700 (Steel Pipe)	1910		0		0		0		0		0
2) Valves											
D=150 (Gate Valve)	5300		0		0		0		0		0
D=200 (Gate Valve)	6700		0		0		0		0		0
D=250 (Gate Valve)	11200		0		0		0		0		0
D=300 (Butterfly Valve)	34800		0		0		0		0		0
D=350 (Butterfly Valve)	74400		0		0		0		0		0
D=400 (Butterfly Valve)	95200		0		0		0		0		0
D=450 (Butterfly Valve)	125900		0		0		0		0		0
D=500 (Butterfly Valve)	174000		0		0		0		0		0
D=600 (Butterfly Valve)	243600		0		0		0		0		0
D=700 (Butterfly Valve)	313200		0		0		0		0		0
3) Internal Network											
Commercial 150pop/ha	25700	4	103	4	103	3	77	3	77		
Commercial 250pop/ha	30400		0		0		0		0		0
Residential 100pop/ha	18700		0		0		0		0		0
Residential 150pop/ha	21000	79	1659	79	1659	79	1659	76	1638		
Residential 250pop/ha	30400		0		0		0		0		0
4) Service Connections											
D=1/2	810	3093	2505	3093	2505	3093	2505	3093	2505		
D=3/4	1280	3	1	2	3	2	3	2	3		
5) Rehabilitation											
Water Meter 1/2"	400		0		0		0		0		0
Water Meter 3/4"	380		0		0		0		0		0
-Old Laterals			0		0		0		0		0
Service Cnctn.w/Meter	480		0		0		0		0		0
Service Cnctn.w/Meter	880		0		0		0		0		0
6) Flow Meter D=150	62000		0		0		0		0		0
-do- D=350	164000		0		0		0		0		0
7) Fire Protection											
D=150	16800		0		0		0		0		0
D=100	9400		0		0		0		0		0
SUB-TOTAL			1271		1270		1211		1223		
4 Administration Bldg.											
(2) Operation Center											
SUB-TOTAL			0		0		0		0		0
5 Land Acquisition											
Vehicle	300000	1	300	1	300	1	300				0
Stored Material & Equip.			85		85		81		81		64
SUB-TOTAL			385		385		381		381		64
6 Replacement of Equipment											
T O T A L			6791		6793		6703		6703		1287
7 Leak Detection											
	240		0		0		0		0		0
GRAND TOTAL			6791		6793		6703		6703		1287