

8. Cost Estimates

8.1 Project Cost Estimates

The project cost estimates for the Immediate Project are presented on Table 7 broken down into foreign exchange and local currency components. The costs are estimated on the basis of the unit costs as of August 1983 which are prepared taking into account current tender prices of plant equipment, pipes and appurtenances and civil works. Total costs including land acquisition cost and contingencies amount to :

Foreign Exchange Component	Rp. 17,000 million	(US\$ 17.0 million)
Local Currency Component	Rp. 15,300 "	(US\$ 15.45 ")
T o t a l	Rp. 32,130 "	(US\$ 33.45 ")

The foreign exchange component includes costs of imported equipment and materials (CIF Jakarta) and expatriate services for installation of equipment to be paid in foreign currency. The local currency component includes costs of labor and materials to be paid in the local currency; namely, it comprises the costs for local labour and materials locally manufactures or produced, including local handling and transportation charges for imported materials, for expatriate's local expenditure, and for imported materials which are locally available.

8.2 Operation and Maintenance Cost Estimates

1) Composition of staff in the new treatment plant :

Chief of the plant	1
Chief of electrical facilities	1
Chief of mechanical facilities	1
Administration	3
Laboratory	3
Four shifts of staff for control room,	4 x 8
Handling chemicals, inspecting	
machinery and patrol	
Miscellaneous worker	5
	<hr/>
Total staff	46

2) Operation and Maintenance Costs :

Personnel cost

46 @ Rp. 109,000/month x 12 months = Rp. 60.2×10^6

Power Cost

12,901,000 kWh/year x (1+0.01) x Rp. 26.5/KWH = Rp. 345.3×10^6

Chemical Cost ;

Chlorine gas 520.1 t/year @ Rp. 1,115,000 = Rp. 579.9×10^6

Alum 2,081 t/year @ Rp. 162,000 = Rp. 579×10^6

Polymer 2.1 t/year @ Rp. 162,000 = Rp. 337.1×10^6

Lime 1,248.3 t/year @ Rp. 41,000 = Rp. 51.2×10^6

Rp. 970×10^6


Maintenance cost (amounting 3 % of machinery costs)

US\$ 1,759,000 x 3 % @ Rp. 980 = Rp. 51.7×10^6

Total O/M costs Rp. $1,427.2 \times 10^6$

FIGURES AND TABLES

Fig. 1 WATER QUALITY ALONG THE WEST TARUM CANAL




NOTE :

- ① CROSSING POINT WITH THE CIPINANG RIVER
- ② JUST BEFORE CROSSING POINT WITH THE SUNTER RIVER
- ③ CROSSING POINT WITH THE BUARAN RIVER
- ④ CROSSING POINT WITH THE CARUNG RIVER
- ⑤ JUST AFTER CROSSING POINT WITH THE BEKASI RIVER
- ⑥ JUST BEFORE CROSSING POINT WITH THE BEKASI RIVER
- ⑦ BEKASI RIVER JUST BEFORE JOINT POINT
- ⑧ BEKASI RIVER 4Km UPSTREAM FROM JOINT POINT

SOURCE : SURVEY BY JICA TEAM

Fig.2 WATER QUALITY ALONG THE WEST TARUM CANAL



NOTE :


- ① CROSSING POINT WITH THE CIPINANG RIVER
- ② JUST BEFORE CROSSING POINT WITH THE SUNTER RIVER
- ③ CROSSING POINT WITH THE BUARAN RIVER
- ④ CROSSING POINT WITH THE CAPUNG RIVER
- ⑤ JUST AFTER CROSSING POINT WITH THE BEKASI RIVER
- ⑥ JUST BEFORE CROSSING POINT WITH THE BEKASI RIVER
- ⑦ BEKASI RIVER JUST BEFORE JOINT POINT
- ⑧ BEKASI RIVER 4Km UPSTREAM FROM JOINT POINT

DATE OF SAMPLING
NUMBER OF SAMPLES

25 AUGUST 1983
8.

SOURCE : SURVEY BY JICA TEAM

Fig. 3 WEST TARUM CANAL
6 OCT 83
(DPMA)



SOURCE : WATER QUALITY SURVEY BY NEDCO CONSULTANTS





Fig. 5 SAMPLING POINT FOR WATER QUALITY ANALYSIS
OF WEST TARUM CANAL



● ① Sampling Points by JICA Team (Jul. 12 and Aug. 25, 1983)

○ ① Sampling Points by NEDCO Consultants (Oct. 6 and 7, 1983)

Fig. 7 ALTERNATIVE I FOR IMMEDIATE PROJECT






Fig 8 PLAN OF TREATMENT PLANT FOR ALTERNATIVE I



SCALE 1 : 2000

Fig. 9 ALTERNATIVE II FOR IMMEDIATE PROJECT







Fig.11 ALTERNATIVE III FOR IMMEDIATE PROJECT







Fig.12 PLAN OF TREATMENT PLANT FOR ALTERNATIVE II






FIG 14 EXISTING AND PROPOSED DISTRIBUTION MAINS
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA




FIG 4.13 GENERAL MAP OF PROPOSED TREATMENT PLANT
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA




Fig. 16 PROPOSED TREATMENT PLANT FOR IMMEDIATE PROJECT




Fig. 17 HYDRAULIC PROFILE OF TREATMENT PLANT

Table 2 Quality of Water in West Tarum Canal and in Sources

Water	Unit	Sources							
		Curug - Cibeet	Cibeet Cikarang	Cikarang Bekasi	Bekasi Jakarta	Jatiluhur Reservoir	Cibeet	Cikarang	Kali Bekasi
Temperatur	°C	30	30	30	30	30	29	29	29
Colour	Unit PtCo	17	24	28	19	12	23	20	17
Turbidity	mg/l SiO ₂	78	176	142	103	14	86	126	65
Dissolved Solids	mg/l	105	119	112	104	107	128	116	112
Suspended Solids	mg/l	118	459	326	160	26	285	188	94
Total Solids	mg/l	196	635	468	264	123	371	414	159
Conductivity	umho/cm	155	168	152	153	145	187	169	156
pH	mg/l	7.8	7.6	7.6	7.6	8.3	7.6	7.7	7.6
Calcium Ca	mg/l	16.0	19.7	20.3	19.9	16.1	21.6	21.1	19.4
Magnesium Mg	mg/l	5.5	5.5	4.6	3.6	4.6	5.6	5.3	4.6
Sodium Ng	mg/l	6.8	7.1	5.4	7.6	6.8	7.2	5.5	4.5
Potassium K	mg/l	2.4	2.4	1.9	4.4	2.3	2.3	1.7	1.8
Iron Fe	mg/l	1.1	2.5	1.7	1.3	0.3	1.4	1.5	0.9
Manganese Mn	mg/l	0.07	0.20	0.13	0.11	0.03	0.19	0.14	0.06
Amonium NH	mg/l	0.20	0.16	0.15	0.29	0.32	0.26	0.23	0.27
Bicarbonate HCO ₃	mg/l	72.2	79.7	77.8	72.9	73.6	87.9	85.1	71.3
Chloride Cl	mg/l	7.5	7.3	7.1	5.4	6.2	6.1	6.0	7.5
Sulphate SO ₄	mg/l	8.3	11.8	8.1	8.7	5.3	10.8	8.0	9.5
Nitrate NO ₃	mg/l	0.033	0.17	0.25	0.18	0.26	0.19	0.28	0.21
Nitrite NO ₂	mg/l	0.004	0.004	0.002	0.008	0.002	0.003	0.004	0.006
Fluoride F	mg/l	0.06	0.04	0.01	0.012	0.04	0.02	0.016	0.07
Carbondioxide CO ₂	mg/l	3.6	3.9	4.5	3.4	2.5	4.8	4.3	3.5
Arsenic As	mg/l	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003
Cadmium Cd	mg/l	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003	< 0.003
Chrom (VI) Cr	mg/l	< 0.017	< 0.017	< 0.017	< 0.017	< 0.017	< 0.017	< 0.017	< 0.017
Copper Co	mg/l	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004	< 0.004
Mercury Hg	mg/l	< 0.0006	< 0.0006	< 0.0006	< 0.0006	< 0.0006	< 0.0006	< 0.0006	< 0.0006
Nickel Ni	mg/l	< 0.024	< 0.024	< 0.024	< 0.024	< 0.024	< 0.024	< 0.024	< 0.024
Lead Pb	mg/l	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02	< 0.02
Tine Zn	mg/l	0.13	0.12	0.10	0.14	0.08	0.09	0.09	0.05
Organic Matter	mg/l KMnO ₄	8.2	12.8	11.9	11.5	4.7	11.4	9.4	8.3
BOD (20°C-5d)	mg/l	1.1	1.2	1.6	1.6	0.8	1.6	1.4	1.2
Dissolved Oxygen	mg/l	6.4	6.5	6.9	6.1	7.5	6.7	6.9	6.9
Faecal Coli (44.5°C) MPN/100 ml		1.7x10 ⁴	1.1x10 ⁵	6.7x10 ⁴	1.6x10 ⁶	135	1.5x10 ⁴	5.8x10 ⁴	6.0x10 ⁴

Source : " Study of Cibeet Irrigation Flood Control and Water Supply,
Vol. 6 March 1983" by NEDECO

Table 3 Water Quality Analysis of West Tarum Canal Water

Analyzed by Institute of Hydraulic Engineering (DPA)

No.	PARAMETER	Unit	Result of Analysis										Result of Analysis									
			1	2	3	4	5	6	7	8	9	10	1	2	3	4	5	6	7	8	9	10
			6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83	6 Oct 83	7 Oct 83
1.	Temperature	°C	31	31	32	31.5	30	31	30	31.5	29	30	29	31	29	31	29	31	29	31	29	32
2.	Dissolved Oxygen	mg/l	6.2	6.4	7.2	6.7	7.2	6.9	7.1	6.8	6.4	6.6	6.3	5.9	5.7	6.8	6.8	6.8	6.8	6.8	6.0	6.0
3.	pH	-	7.3	7.8	8.0	8.0	8.2	7.95	7.7	8.0	7.7	7.8	7.6	7.5	7.8	7.8	8.0	8.0	8.1	8.1	7.9	7.9
4.	Conductivity	Umho/cm	199	190	305	186	195	188	200	189	197	190	198	191	198	185	199	173	173	182	182	182
5.	Turbidity	mg/l @102	24	26	24	23	21	24	21	21	21	22	20	23	23	20	20	20	21	21	21	21
6.	Colour	PCU	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
7.	Organic matter (MnO ₂)	mg/l @2000	21	11.4	16.7	7.4	9.3	7.6	6.7	9.7	8.2	7.3	8.6	7.8	6.6	6.3	7.8	8.3	9.1	9.1	9.1	
8.	T.O.C	mg/l	4.2	3.8	4.6	3.3	4.1	4.6	4.2	4.1	5.1	4.2	4.5	5.8	5.7	4.2	6.3	4.7	4.1	4.1	4.1	
9.	Ammonia - N	mg/l	0.34	0.15	0.28	0.090	0.45	0.045	0.030	0.066	0.095	0.057	0.046	0.37	0.36	0.16	0.18	0.38	0.47	0.47	0.47	
10.	Nitrate - N	mg/l	0.90	0.61	0.27	0.51	0.32	0.44	0.39	0.43	0.43	0.48	0.024	0.073	0.062	0.012	0.007	0.030	0.030	0.030	0.030	
11.	Nitrite - N	mg/l	0.031	0.020	0.029	0.013	0.029	0.021	0.031	0.022	0.028	0.039	0.040	0.024	0.024	0.024	0.024	0.024	0.024	0.024	0.024	
12.	Z. Coil	MPM/100ml	1.1x10 ⁶	4.6x10 ⁶	4.6x10 ⁶	1.1x10 ⁵	1.3x10 ⁵	1.3x10 ⁵	2.6x10 ⁶	4.3x10 ⁶	2.6x10 ⁶	9.3x10 ⁶	4.6x10 ⁶	2.4x10 ⁶	4.6x10 ⁶	1.5x10 ⁶	7.5x10 ⁶	2.4x10 ⁶	2.4x10 ⁶	2.4x10 ⁶	9.3x10 ⁶	
13.	Total Coil	MPM/100ml	1.1x10 ⁶	4.6x10 ⁶	4.6x10 ⁶	1.1x10 ⁵	1.3x10 ⁵	1.3x10 ⁵	2.6x10 ⁶	4.3x10 ⁶	2.6x10 ⁶	9.3x10 ⁶	4.6x10 ⁶	2.4x10 ⁶	4.6x10 ⁶	1.5x10 ⁶	7.5x10 ⁶	2.4x10 ⁶	2.4x10 ⁶	2.4x10 ⁶	9.3x10 ⁶	

Number location of sampling:

1. West Tarum Canal outlet to Cilbung
2. West Tarum Canal inlet to Cilbung (BTS 52)
3. West Tarum Canal near Sunter river (BTS 51 a)
4. West Tarum Canal (BTS 49), middle of the Sunter and Buaran Rivers.
5. West Tarum Canal (BTS 48), near the Buaran river
6. West Tarum Canal (BTS 47), near DKI boundary
7. West Tarum Canal at slit trap
8. West Tarum Canal (BTS 45), out let to the Bekasi River
9. Sunter river at down stream

Source: Water Quality Survey by NHECO Consultants

Table 6 Water Supply Facilities for Immediate Project

Items	Description
Max Daily Demand	2.0 m ³ /sec (Average daily demand)
Intake/ Treatment Flow Rate	2.14 m ³ /sec
A. Land Acquisition	
1. Intake/ Treatment Plant Site	290 m x 180 m = 52,200 m ² (including land for raw water pumping station on 2nd stage)
2. Distribution Main Site	
B. Intake	
1. Intake Bay	B ₁ 20.0 m x B ₂ 6.0 m x L 7.0 m x 1 Bay (for common use of the First Phase of Stage II)
2. Raw water channel	B 0.0 m x H 2.5 m x L 20 m x 1 channel (for common use with the First Phase of Stage II)
C. Treatment Plant	
1. Receiving well	4 7.0 m x D 5.2 m V = 200 m ³ 1 well RT = 1.5 min with overflow weir
2. Mixing well	3 3.0 m x L 5.0 m x D 5.3 m V = 133 m ³ 2 well RT = 2.0 min with overflow weir
3. Flocculation Basin	L 24.1 x W 3.0 x D 3.0 m x 3 stage V = 660 m ³ 4 units RT = 20 min with mechanical flocculator
4. Sedimentation Basin	Horizontal flow type W = 24.5 m x L 70 m x D 3.5 V = 6,000 m ³ 4 units RT = 3 hrs mean velocity = 0.38 m/min with sludge scraper
5. Rapid Sand Filter	Conventional type Area of bed 91.2 m ² 18 units (including 1 standby). flow rate = 5.0 m ³ /m ² /hr surface wash pump 18.5 m ³ /min x 20 m x 90 kW x 2 secs
6. Clear water reservoirs	L 50 m x W 36 m x D 4.0 m V = 720 m ³ 2 units RT = 2 hrs W 3.0 m x D 4.5 m with influent channel
7. Clear water pump well	Office space for monitoring of treatment process, chemical feeders and chemical storage space and laboratory area = 1,280 m ² . Backwash tank, reinforced concrete with a capacity of 757 m ³ . Backwash pump 18.9 m ³ /min x 17 m x 70 kW x 2 secs.
8. Operation and Chemical Building	W 10.0 m x L 35.0 m x D 3.0 m V = 1,050 m ³ 2 units with drain pump 37 kW x 6 secs Alum, lime and chlorine
9. Waste water disposal facility	12 m x 15 m = 180 m ² , 4500 KVA
10. Chemical feeding system	
11. Power Substation	
D. Distribution	
1. Pumping Station	BY 1 Pump house 1 P = Electric equipment A = 1,200 m ²
2. Distribution pump	60 m ³ /min x 54 m x 720 kv x 3 sets including 1 standby
3. Distribution main	DIP 4 1,100 L = 7,600 m DIP 4 1,000 L = 5,800 m DIP 4 900 L = 3,400 m

Table 7 Cost Estimate for Immediate Project

ITEMS	DESCRIPTION	F/C	L/C
A. Land Acquisition			
1) Treatment Plant	4.5 ha for Immediate Project	-	270.0
B. Civil Works			
B-1 Intake Facilities			
1) Intake Bay 1/	W 20m x 6m x L7m	-	10.0
2) Intake channel 1/	B 6m x H 2.5m x L 70m	-	61.1
Sub-total			71.1
B-2 Treatment facilities			
1) Receiving well	ø 7m x 5.2m = 200m ³	-	56.8
2) Mixing, flocculation and Sedimentation basins	Mixing well 133m ³ x 2, Flocculation basin 660 m ³ x 4, sedimentation basin 6,000 m ³ x 4	-	1,815.6
3) Rapid sand filter	93.2 m ² x 18 units	-	1,593.9
4) Clear water reservoir	50m x 36m x 4m x 2 units (14,400 m ³)	-	892.8
5) Operation/chemical blidges	40m x 16m x 2 stories, backwash tank 757 m ³	-	769.4
6) Wastewater pond	10m x 35m x 3.0 m x 2 units	-	188.5
7) Yard piping	ø1,200 x 160m, ø1,100 x 80m, ø1,000 x 20m, ø600 x 110m	-	71.9
Sub-total			5,388.9
B-3 Distribution facilities			
1) Distribution pump house	pump house 1,200 m ³ , power receiving house 180 m ²	-	936.0
2) Distribution mains	ø1,100 x 7.6 km, ø1,000 x 5.8km, ø900 x 3.4km	-	2,119.4
Sub-total			3,055.4

Immediate Project

ITEMS	DESCRIPTION	F/C	L/C
C. Installation of Equipment			
1) Chemical feeders		-	24.0
2) Electric facilities		-	324.0
3) Transmission pumps		-	20.7
4) Backwash, surface wash pumps		-	3.8
Sub-total		-	<u>372.5</u>
D. Administration Cost			
1) Administration cost	10 % for total costs of (B+C)	-	<u>889.1</u>
E. Equipment and Materials			
1) Intake bay and channel	gates, coarse and fine screens	143	-
2) Receiving well	gates	17	-
3) Flocculation/sedimentation basins	floculators, sludge scrapers, valves/pipes	801	-
4) Rapid sand filter	valves/pipes, surface water pump	1,618	-
5) Chemical feeders	alum, polymer, lime and chlorine	458	-
6) Clear water reservoir	valves and pipes	125	-
7) Yard pipes	pipes, gate for wastewater pond	271	-
8) Pumps,	Distribution pump, backwash pump, header pipe and drain pumps	546	-
9) Electrical equipment	power receiving, instrumentation etc.	1,682	-
10) Distribution Mains	ø1,100 x 7.6km, ø1,000 x 5.8km, ø 900 x 3.4 km	6,529	-
Sub-total		<u>12,190</u>	-
F. Engineering Cost			
1) Consultancy services	for detailed design and supervision service	<u>1,341</u>	<u>622</u>
Total (A to F)		<u>13,531</u>	<u>10,669</u>

Immediate Project

ITEMS	DESCRIPTION	F/C	L/C
G. Contingency			
1) Physical contingency	10 % for F/C and 12% for L/C for total costs of (B to F)	1,353	1,280
2) Price Contingency	7 % to 6 % for F/C and 11 % to 7 % for L/C of total costs of (A to G-1)	2,116	3,351
Sub-total		3,469	4,631
Total costs		17,000	15,300

Total Project Costs Equivalent to Rupiah Rp. 32,130 million


Conversion rate : US\$ 1.0 = Rp. 990 = Y 230 (as of November, 1983)

Note : F/C, Foreign exchange to be paid in foreign currency for imported materials and equipment (CIF), and foreign currency portion for expatriate service fees
 L/C, Local currency to be paid in local currency for land acquisition, local labors and materials for civil works and materials locally manufactured
 1/ Facilities are constructed as conjoint structure with the raw water intake facilities for the existing Pejomongan Plant, and cost is amounted as allocation cost by ratio of raw water flow rate.

Table 8
Hydraulic Calculation of Distribution Main

i - j	Q l/sec	D mm	IL km	I o/oo	hf m	hf ₁₀₀ m	Hw + m	GH + m	Heff m	Remarks
0							+ 59.2			Treatment plant
0 - 5	2,000	∅ 1,100	7.6	2.97	22.6	22.6	+ 36.6			C = 130
5 - 6	920	∅ 1,000	3.9	1.30	5.1	21.7	+ 31.5	+ 15.5	16.0	
6 - 7	380	∅ 1,000	1.9	0.25	0.5	28.2	+ 31.0			
5 - 1	780	∅ 900	3.4	1.60	5.4	28.0	+ 31.2			
1 - 2	780	(∅ 800)	1.5	2.84	4.3	32.3	+ 26.9			Existing pipe
2 - 3	540	(∅ 800)	3.8	1.44	5.5	37.8	+ 21.4			do
3 - 4	290	(∅ 800)	3.6	0.46	1.5	39.3	+ 19.9	+ 3.0	16.9	do

Hazen-Williams Formula Velocity Coefficient C = 130



Note: () shows the existing main.
Refer to Fig.14 on the location of discharge points.

Table 9 shows distribution quantities in service area to be supplied by each treatment plant.

Table 9

Water Demand Distribution and Supplied Quantity in 1988

Supply Zone	Kecamatan	Water Demand		Supplied* Quantity 1/s	Remarks	
		Day Ave. 1/s	Day Max. 1/s			
<u>Pejompongan</u>						
I -	1	630	730	600	consists of Pejompongan Plant I and II, Muarakarang, Cenkareng, Cilandak and Tarogong.	
	2 (80%)	460	530	450		
	6	440	500	420		
	7	690	790	660		
II -	2	650	750	620	total capacity: Pejompongan 5,600 1/s Muarakarang 100 Cenkareng 50 Cilandak 450 Tarogong 100 <hr/> 6,300 1/s	
III -	1	60	70	50		
	2	890	1,020	850		
	3	450	520	430		
	4	480	550	460		
	5	20	20	20		
IV -	2 (30%)	120	140	110		
	3 (60%)	200	230	190		
	4	100	110	100		
	5	630	720	600		
	6	500	580	480		
	7	240	280	230		
Total		6,560	7,540	6,270		
<u>Pulogadung</u>						
I -	2 (20%)	120	130	100	consists of Pulogadung, and Sunter	
	3	550	620	520		
	4 (35%)	180	210	170		
	5	540	620	520		
II -	3	1,080	1,240	1,040	total capacity: Pulogadung 4,800 1/s Sunter 50 <hr/> 4,850 1/s	
	4	500	570	480		
	5	300	350	290		
V -	1 (70%)	320	370	300	(Pulogadung Plant will be operated at 20 % increased rate)	
	2	860	990	830		
	3 (40%)	250	280	240		
	6	340	390	330		
Total		5,040	5,770	4,830		
<u>Buarang</u>						
I -	4 (65%)	330	380	320	consists of Buarang, Condet and Ciburial Spring.	
IV -	1	560	640	540		
	2 (70%)	280	320	270	total capacity: Buarang 2,000 1/s Condet 100 Spring 200 <hr/> 2,300 1/s	
	3 (40%)	130	150	130		
V -	1 (30%)	130	150	130		
	3 (60%)	360	420	350		
	4	480	550	460		
	5	150	170	140		
Total		2,270	2,610	2,340		

Note: * Proposed capacity to be supplied by each treatment plant

ATTACHMENTS

1. Cost Estimates for Alternatives I to III M8-36
2. Operation Cost Estimates for Alternative I to III M8-45
3. Drawings M8-48

Attachment 1. Cost Estimates for Alternatives I to III

Table 5-a Cost Estimate of Each Alternative For Immediate Project
(Alternative - I)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
<u>Intake Facilities</u>			
1) Intake Bay	Q = 2,200 l/sec	83 <u>1/</u>	10.0
2) Intake Pipe	ø1,200 x 2 lines x 50 m	43	11.0
3) Raw Water Pump	ø 700 x 300 KW x 3 sets	306	9.0 <u>4/</u>
4) Pump Well/House	Well 24m x 8m x 3m = 576 m3 House 24m x 12m = 288 m2	15 <u>1/</u>	276.5
5) Electric Fac Facilities	Total 900 KW	403	449.0
Sub-total		850	755.5
<u>Raw Water Transmission Mains</u>			
6) Raw water main	ø 1,200 x 9.4 km DIP	4,794	1,252.0
sub-total		4,794	1,252.0
<u>Treatment Facilities</u>			
7) Receiving Well	V = 130 m3	17 <u>1/</u>	36.9
8) Mixing Well/ Flocculation & Sedimentation Basins	V = 24,100 m3	723 <u>2/</u>	1,638.8
9) Rapid Sand Filters	A = 1,440 m2 Backwash pump 185 KW x 3	1,485 <u>3/</u>	1,370.7
10) Chemical Feeders	Q = 2,200 l/sec	202	10.7 <u>4/</u>
11) Electric Facilities	Q = 2,200 l/sec	556	238.4 <u>5/</u>

(Alternative - I)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
12) Clear Water Reservoir	V = 14,400 m ³	125 ^{1/}	892.8
13) Yard Piping Plant	∅ 1,200 x 750m	319	99.9
14) Chemical Building	30m x 15m x 2stories = 900 m ²	-	315.0
Sub-total		3,427	4,603.2
<u>Distribution Facilities</u>			
15) Distribution Pumps	∅700 x 710kW x3sets	426	63.9 ^{4/}
16) Operation Building	60m x18m x2stories = 2,160 m ² including header-pipe	58	1,684.8
17) Distribution Mains	∅1,200x4.8km, ∅1,100x3.4km ∅1,000x5.8km including pipe bridges & road crossings	6,081	1,872.0
Sub-total		6,565	3,621.1
<u>Administration Cost</u>			
18) Administratio Cost	10 % for 1) to 17)	-	1,023.2
Sub-total		-	1,023.2
<u>Land Acquisition Cost</u>			
19) Land Cost	4 ha @ Rp 40,000/m ²	-	1,600.0
Sub-total		-	1,600.0
<u>Total of Construction Cost</u>		<u>15,636</u>	<u>12,855.0</u>
<u>Engineering Cost</u>			
20) Engineering Cost for Design Engineering & Supervision Services	8% for F/C 5 % for L/c	1,251	643.0
Sub-total		1,251	643.0

(Alternative - I)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
<u>Contingency</u>			
21) Physical Contingency	10 % for total costs from 1) to 20)	1,689	1,350.0
22) Price Contingency	5 % per annum for F/C 10 % per annum for L/C	2,424	4,452.0
Sub-total		4,113	5,802.0
<u>Total Project Costs</u>		<u>21,000</u>	<u>19,300.0</u>

- Note:
- 1/ includes gates/valves
 - 2/ includes flocculator, sludge scrapers, drain valves and pipes
 - 3/ includes pipes and valves in gallery and backwash pumps
 - 4/ includes installation of equipment
 - 5/ includes installation of equipments and power receiving cost to be paid to PLN

Table 5-b Cost Estimate of Each Alternative For Immediate Project
(Alternative - II)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
<u>Intake Facilities</u>			
1) Intake Bay	Q = 2,200 l/sec	83 <u>1/</u>	10.0
2) Intake Channel	2.0m x 90m x 1.7m	60 <u>6/</u>	61.3
3) Raw Water Pump	-	-	-
4) Pump Well/House	-	-	-
5) Electric Facilities	-	-	-
Sub-total		143	71.3
<u>Raw Water Transmission Mains</u>			
6) Raw Water Main		-	-
Sub-total		-	-
<u>Treatment Facilities</u>			
7) Receiving Well	V - 200 m3	17 <u>1/</u>	56.8
8) Mixing Well/ Flocculation & Sedimentation Basin	V = 26,400	801 <u>2/</u>	1,815.6
9) Rapid Sand Filters	A = 1,680 m2 surface wash pump /400 x 90kW x 2sets	1,618 <u>3/</u>	1,595.7
10) Chemical Feeders	Q = 2,200 l/sec	458	24.0 <u>4/</u>
11) Electric Facilities	Q = 2,200 l/sec	1,682	324.0 <u>5/</u>

(Alternative - II)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
12) clear Water Reservoir	V = 14,400 m ³	125 ^{1/}	892.8
13) Backwash Tank	V = 760 m ³ Pumps ø400 x 65 KW x 3 sets	86 154	141.4
14) Yard Piping in Plant	ø1,200x160m, ø1,100x80m ø1,000x20m, ø600x110m	137 137	71.9
15) Wastewater Basin	V = 2,070m ³ , Drain pumps and pipes/gates	137	188.5
16) Operation Building	A=40m x 15m x 3stories = 1,800 m ²	-	630.0
Sub-total		5,058	5,740.7
<u>Distribution Facilities</u>			
17) Distribution Pumps	ø700 x 690 KW x 3sets	414	20.7 ^{4/}
18) Pump house	40m x 15m x 2stories = 1,200m ² , including header pipe	46	936.0
19) Distribution Mains	ø1,100x7.6km, ø1,000x5.8km ø900x3.4km including pipe bridges & road crossings	6,529	2,119.4
Sub-total		6,989	3,076.1
<u>Administration Cost</u>			
20) Administration Cost	10% of 1) to 19)	-	889.1
Sub-total		-	889.1
<u>Land Acquisition Cost</u>			
21) Land Cost	4.5 ha @Rp.6,000/m ²	-	270.0
Sub-total		-	270.0
<u>Total of Construction Cost</u>		<u>12,190</u>	<u>10,047.0</u>

(Alternative - II)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
<u>Engineering Cost</u>			
22) Engineering Cost for Design Engineering & Supervision Services	11 % for F/C 7 % for L/C	1,341	622.0
Sub-total		1,341	622.0
<u>Contingency</u>			
23) Physical Contingency	10 % for total costs from 1) to 22)	1,353	1,067.0
24) Price Contingency	5 % per annum for F/C 10 % per annum for L/C	2,116	3,564.0
Sub-total		3,469	4,641.0
<u>Total Project Costs</u>		<u>17,000</u>	<u>15,300</u>

- Note:
- 1/ includes gates/valves
 - 2/ includes flocculators, sludge scrapers, and drain valves/pipes
 - 3/ includes pipes and valves in gallery and surface wash pumps
 - 4/ includes installation of equipment
 - 5/ includes installation of equipment and power receiving cost to be paid to PLN
 - 6/ includes fine screen and gates

Table 5-c Cost Estimate of Each Alternative for Immediate Project
(Alternative - III)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
<u>Intake Facilities</u>			
1) Intake Bay	Q = 2,200 l/sec	83 ^{1/}	10.0
2) Intake Pipe	ø1,200 x 2 lines x 50m	43	11.0
3) Raw Water Pump	ø800 x 75kW x 3sets	94	2.3 ^{4/}
4) Pump Well	15m x 11m x 4m = 660 m ²	15 ^{1/}	59.4
5) Electric Facilities		-	-
Sub-total		43	11.1
<u>Raw Water Transmission Mains</u>			
6) Raw Water Main	ø 1,200 x 10 m	43	11.1
Sub-total		43	11.1
<u>Treatment Facilities</u>			
7) Receiving Well	V = 1,400 m ³	150 ^{1/}	397,6
8) Mixing Well/ Flocculation & Sedimentation Basins	V = 26,400 m ³	801 ^{2/}	1,815,6
9) Rapid Sand Filters	A = 1,717 m ² surface wash pump ø 400 x 125 kW x 2 sets	1,733 ^{3/}	1,632.2
10) Chemical Feeders	Q = 2,200 l/sec	458	24.0 ^{4/}
11) Electric Facilities	Q = 2,000 l/sec	1,682	324.0 ^{5/}

(Alternative - III)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
12) Clear Water Reservoir	V = 14,400 m ³	125 ^{1/}	892.8
13) Backwash Tank	V = 1,320 m ³ pumps ϕ 600x150kWx2sets	109 404	240.6 123.6
14) Yard Piping in Plant	ϕ 2,000x160m, ϕ 1,500x140m, ϕ 1,200x100m, ϕ 1,000x170m ϕ 800x200m		
15) Operation Building	100mx20m = 2,000m ²	-	350.0
16) Wastewater Basin	V = 3,600 m ³ , Drain pumps and pipes gates	165	348.1
Sub-total		5,627	6,149.5
<u>Distribution Facilities</u>			
17) Distribution Pumps	ϕ 700 x 920 kW x 3 sets	938	27.6 ^{4/}
18) Pump House	40m x 15 m x 2 stories = 1,200 m ² , including header-pipe	39	1,056.0
19) Distribution Mains	ϕ 1,100 x 12.9km, ϕ 1,000 x 5.8km ϕ 900 x 3.4km, including Pipe bridges & road crossings	8,531	2,827.7
Sub-total		9,508	3,911.3
<u>Administration Cost</u>			
20) Administration Cost	10% of 1) to 19)	-	1,015.4
Sub-total		-	1,015.4
<u>Local Acquisition Cost</u>			
Land Cost	10ha @ Rp3,000	-	300.0
Sub-total		-	300.0
<u>Total of Construction Cost</u>		<u>15,143</u>	<u>11,470.0</u>

(Alternative - III)

Items	Description	F/C	L/C
		US\$ 1,000	Rp. million
<u>Engineering Cost</u>			
20) Engineering Cost for Design Engineering & Supervision Services	9 % of for F/C 6 % for L/C	1,387	688.0
Sub-total		<u>1,387</u>	<u>688.0</u>
<u>Contingency</u>			
21) Physical Contingency	10% for total costs from 1) to 20)	1,680	1,216.0
22) Price Contingency	5 % per annum for F/C 10 % per annum for L/C	<u>2,520</u>	<u>4,026.0</u>
Sub-total		<u>4,200</u>	<u>5,242.0</u>
<u>Total Project Costs</u>		<u>21,000</u>	<u>17,400</u>

- Note :
- 1/ includes gates/valves
 - 2/ includes flocculators, sludge scrapers, drain valves and pipes
 - 3/ includes pipes and valves in gallery and surface wash pump
 - 4/ includes installation of equipment
 - 5/ includes installation of equipment and power receiving cost to be paid to PLN

Attachment 2.

Operation Cost Estimates for each Alternative

1. Personnel Cost

a. Alternative I

Composition of the staff in the plant is as follows :

Four shifts of staff for control room, handling chemicals, inspection of machinary and patrol	4 x 8
Miscellaneous worker	2
Total	34

Annual personnel cost : 34 @ Rp. 109,000/month x 12 months
= Rp. 44,472,000

b. Alternative II and III

Composition of staff in the new treatment plant is as follows:

Chief of the Plant	1
Chief of electrical facilities	1
Chief of mechanical facilities	1
Administration	3
Laboratory	3
Four shifts of staff for control room, handling chemicals, inspection of machinary and patrol	4 x 8
Miscellaneous worker	5
Total	46

Annual personnel cost : 46 @ Rp. 109,000/month x 12 months
= Rp. 60,168,000

2. Power and Fuel Costs

a. Alternative I

raw water pump	300 kW x 2 x 24h x 365 =	5,256,000 kWh
Flocculator	22 kW x 2 x 24h x 365 =	385,440 kWh
Distribution pump	710 kW x 2 x 24h x 365 =	12,439,200 kWh
Backwash pump	185 kWhx2x10/60x10x365 =	225,083 kWh

Other miscellaneous powers = 366,114 kWh
(2 % of total powers) 18,671,837 kWh

Fuel : Power costs x 1 %
Power costs : 18,672,000 kWh x Rp. 26.5/kWh x (1 + 0.01)
= Rp. 499,756,000

b. Alternative II

Flocculator	42 kW x 24h x 365	=	367,920 kWh
Surface wash pump	90 kW x 10/60 x 9 x 365	=	49,275 kWh
Backwash pump	65 kW x 40/60 x 9 x 365	=	142,350 kWh
Distribution pump	690 kW x 2 x 24h x 365	=	12,088,800 kWh
Other miscellaneous power (2% of total powers)		=	<u>252,967 kWh</u>
Total		=	12,901,312 kWh

Power cost : 12,901,000 kWh x Rp. 26.5 kWh x (1 + 0.01)
= Rp. 345,295,000

c. Alternative II

Raw water pump	75 kW x 2 x 24h x 365	=	1,314,000
Flocculator	42 kWh x 24h x 365	=	367,920
Surface wash pump	125 kW x 10/60 x 7 x 365	=	53,229
Backwash pump	150 kW x 40/60 x 7 x 365	=	225,500
Distribution pump	920 kW x 2 x 24h x 365	=	16,118,400
Other miscellaneous power (2% of total powers)		=	<u>365,181</u>
Total			18,471,230

Power costs : 18,471,000 kWh x Rp. 26.5/kWh (1 + 0.01)
= Rp. 494,276,000

3. Chemical Costs for Alternative I to III

Prechlorine, intermediate chlorine and postchlorine : average 7.5 ppm x 0.19 t/ppm x 365 x @ Rp. 1,115,000	=	579,939,000
Alum : aver. 30 ppm x 0.19 x 365 x @ Rp. 162,000	=	337,041,000
Polymer: aver. 0.03 ppm x 0.19 x 365 x @ Rp. 882,000	=	1,835,000
Postlime : aver. 18 ppm x 0.19 x 365 x @ Rp. 4,100	=	<u>51,180,000</u>
Total Chemical costs		Rp. 969,995,000

4. Maintenance Cost

a. Alternative I US\$ 1,795 x 10,000 x 3 % @ Rp. 980		Rp. 52,800,000
b. Alternative II US\$ 1,759 x 10,000 x 3 % @ Rp. 980		Rp. 51,700,000
c. Alternative III US\$ 2,400 x 10,000 x 3 % @ Rp. 980		Rp. 70,600,000

5. Summary of Operation Costs

Unit : Rp. 1,000


	<u>Alternative I</u>	<u>Alternative II</u>	<u>Alternative III</u>
1. Personnel costs	44,472	60,168	60,168 *
2. Power cost	499,756	345,295	494,376
3. Chemical cost	969,995	969,995	969,995
4. Maintenance cost	52,800	51,700	70,600
Total	1,567,023	1,427,158	1,595,139


Note : * Personnel will be joined with the new treatment plant for Second Stage Extension.

ATTACHMENT


(DRAWINGS)

DWG- 1	General Layout of Buaran (Immediate) Treatment Plant
DWG- 2	Intake Weir & Bay
DWG- 3	Floccuration & Sedimentation Basin
DWG- 4	Filter
DWG- 5	Clear Water Reservoir
DWG- 6	Pump House
DWG- 7	Alum Tank & Feed Pump
DWG- 8	Chemical Building
DWG- 9	Polymer Feeding System
DWG-10	Alum Feeding System
DWG-11	Lime Feeding System
DWG-12	Chlorination System
DWG-13	Neutralization Diagram
DWG-14	Single Line Diagram-1
DWG-15	Single Line Diagram-2
DWG-16	Single Line Diagram-3
DWG-17	Single Line Diagram-4
DWG-18	Instrumentation Diagram-1
DWG-19	Instrumentation Diagram-2






P L A N




S E C T I O N

DWG-2 INTAKE WEIR AND BAY
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA




PLAN




SECTION

DWG-3 FLOCCURATION AND SEDIMENTATION BASIN
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA




PLAN




SECTION

DWG-4 FILTER
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA





PLAN




SECTION


DWG-5 CLEAR WATER RESERVOIR
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA



DWG-6 PUMP HOUSE
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA




DWG-7 ALUM TANK & FEED PUMP
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA




DWG-8 CHEMICAL BUILDING


JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA




DHG-9 POLYMER FEEDING SYSTEM

JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA







DWG-11 LIME FEEDING SYSTEM
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA



DWG-12 CHLORINATION SYSTEM

JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA







POWER SUBSTATION

DWG-14 SINGLE LINE DIAGRAM-1

JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA




DWG-15 SINGLE LINE DIAGRAM-2
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA



DWG-16 SINGLE LINE DIAGRAM-3


JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA

PUMP HOUSE



DWG-17 SINGLE LINE DIAGRAM-4

JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA



MASTER PLAN FOR
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT

M9. APPENDIX MIV-3

DIVISION OF THE SERVICE AREA
(SUPPLY ZONES)

DIVISION OF THE SERVICE AREA
(SUPPLY ZONES)

C o n t e n t s

Introduction	M9-1
1. Distribution of Water Demand to Kecamatan	M9-2
2. Study by Modules to Select and Optimal Supply Zone	M9-14
1) Assumptions	M9-14
2) Cost Comparion	M9-17
3. Conclusions	M9-19
1) Considerations for Application of Modules	M9-19
2) Proposed Supply Zones	M9-20
3) Supply Zones and Administrative Divisions	M9-20

Introduction

The existing water supply system of Jakarta is large in service area and complicated in network of pipelines with many supply sources. As a result of this magnitude and complication, the operation of the water supply system is not necessarily easy, and it is difficult in an emergency case to deliver water to places where water is wanted. Considering the above condition of the water supply system, a basic improvement of the system is considered to be of primary importance in the planning of the water supply system to be constructed in the future.

A new concept of the water supply system is, therefore, introduced here, which is to divide the whole supply area into plural number of supply areas. This area is termed in the present report as "supply zone". Each zone will be operated as if it is an independent service area, each having a supply source of its own, such as a treatment plant or a distribution center.

The major advantages of the above system will be as follows:

1. Rational operation and maintenance will be possible grasping areawise tendencies of water demand increase and characteristic of water consumption pattern.
2. It will be easier to make more precise planning for future extension and arrangement of the distribution system in accordance with the above.
3. More uniform water pressure of the service area as a whole can be maintained; as the result it becomes possible to reduce leakage by reducing excessive water pressure of the distribution pipelines.
4. It becomes possible to prevent the wide area's suspension of water supply in case of unforeseeable emergency in the major facilities such as intake, treatment plant, transmission mains and distribution trunk mains.

Considering the above merits, the smaller size of zone will have more advantage only from the technical point of view, while size of zone is to be decided from the view points of physical conditions of the service area and economical advantage.

To find out such supply zones, the following approach will be employed, namely, 1) to identify a most feasible size of supply zone by using module, and 2) to divide the service area applying the result of the above module study.

1. Distribution of Water Demand to Kecamatan

To fulfil the purpose of dividing the served area, the magnitude of a supply zone must be appropriate in terms of both its area and supply capacity. For convenience of analysis, water demand that is the basis to determine the supply capacity will be firstly distributed to Kecamatan in the processes as described below.

(1) Domestic Demand

Firstly, population in the service area of each Kecamatan is estimated based on population distribution of each transport zone prepared in the Master Plan of Jakarta City in this report and service area map prepared in section 4.1.

Secondly, population served of each Kecamatan which is classified into three categories by income level, income groups I & II, income groups III & IV and income group V, is estimated based on the service ratio of each income group in the physical zone defined by the Master Plan of Jakarta City.

Finally, domestic demand of each Kecamatan is estimated as the product of unit demand (per capita consumption) defined in Section 4.2 and population served estimated in the above.

(2) Public Use

Public use is further classified into five categories such as governmental use, educational use, religious institutional use, hospital use and armed forces use.

Governmental Use

Firstly, present government employees are distributed to each Kecamatan based on the land use map in 1980.

Secondly, government employees of each SDP zone in the Master Plan of Jakarta City are redistributed to each Kecamatan applying the present proportion of employees to each Kecamatan involved in SDP zone concerned.

Finally, water demand of Governmental use of every five years is distributed to each Kecamatan according to the proportion of employees obtained in the above.

Educational and Religious Institutional Use

Water demand of educational and religious institutional uses are distributed applying the proportion of population in the service area.

Hospital Use

Water demand of hospital is divided into two categories, general hospital (large scale hospital) and small hospital (such as maternity hospital).

Present water demand of the general hospitals is distributed to each Walikota based on the number of connections of each Walikota and unit demand which is further distributed to each Kecamatan. Water demand of each Kecamatan in 2005 is distributed applying the proportion of population in the service area. Demand distribution of every five years is made using proportions of water demand of each Kecamatan in 1980 and 2005 estimated in the above. Water demand distribution of small hospital is made according to the proportion of population in the service area.

Armed Forces Use

Water demand for Armed Forces of each Walikota is distributed according to the ratio of the present consumption and it is further distributed to each Kecamatan equally.

(3) Industrial Demand

Water demand of Industrial Use is further classified into two categories, Large & Medium and Small industries.

Large & Medium Industries

Water demand for Large & Medium Industries is distributed based on proportion of the industrial area in each Kecamatan as shown on Land use map at present and Land use plan in 2005 prepared in the Master Plan of Jakarta City.

Small Industries

Water demand for Small Industries is distributed by the proportion of population in the service area considering Small Industries scattered in the whole area of Jakarta which is defined as home industry.

(4) Water Demand of Trade and Services

Water demand of Trade and Services is further classified into two categories which are demands for hotels and trade & services.

Water Demand of Hotel

Present water demand of Hotels is distributed based on the number of rooms in each Kecamatan and unit consumption per room. Future water demand is distributed based on such consideration that water demand of hotel will increase in proportion to the water demand increase of trade & services then water demand in 2005 is distributed in proportion to the water demand of trade & services. From the above two figures, water demand distribution of every five years is estimated.

Water Demand of Trade & Services

Water demand of trade & services is distributed based on the proportion of area in present land use map and distribution of employees of trade & service sector of each SDP zone estimated in the Master Plan of Jakarta City which is further distributed to each Kecamatan.

Distribution of water demand of each kecamatan in every five years is estimated according to the above approach and the result is summarized in Table 1 and shown on Fig. 1 for the year of 1990, 1995 and 2005.




Fig 1A WATER DEMAND DISTRIBUTION (IN 1990)
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA




FIG 1B WATER DEMAND DISTRIBUTION (IN 1995)
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA




FIG 1C WATER DEMAND DISTRIBUTION (IN 2005)

JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA

Table 1A Water Demand Distribution by Each Kecamatan, 1980

KECAMATAN	AREA DOMESTIC (ha) (* 000m ³ /d)	Public Industry	NON-DOMESTIC T & G	Total (* 000m ³ /d) (* 000m ³ /s)	CONSUMPTION (%)	UNACCOUNT	DEMAND (DAY AVG) (m ³ /d)	DAY MAX (l/s)	DENSITY
I-1	757.6	7.0	0.1	2.7	9.8	24.9	46.1	530	0.01
I-2	583.2	5.4	0.3	1.7	7.4	21.2	40.4	470	0.93
I-3	704.0	3.2	0.2	0.7	4.1	18.6	40.7	540	0.77
I-4	461.0	6.0	0.1	2.3	8.4	22.0	39.8	530	1.15
I-5	717.6	4.8	0.2	0.6	5.6	24.2	46.8	600	0.84
I-6	613.6	9.3	0.1	1.5	9.6	17.5	32.4	440	0.72
I-7	1016.8	4.9	0.4	2.1	9.4	26.2	48.5	640	0.63
I-TOTAL	4853.8	37.3	1.4	11.6	50.3	158.0	292.6	3390	0.80
II-2	2509.5	2.4	1.0	0.6	4.0	21.0	45.7	610	0.24
II-3	2423.0	15.8	1.1	0.1	17.0	30.9	67.2	900	0.37
II-4	1571.7	1.5	0.7	0.3	2.5	17.2	37.4	490	0.31
II-5	1190.5	0.8	0.4	0	1.2	7.1	15.4	210	0.18
II-TOTAL	7694.7	20.5	3.2	1.0	24.7	89.5	165.7	2210	0.29
III-1	607.5	0.2	0	0.2	0.4	1.8	3.9	50	0.10
III-2	1518.0	5.0	0.5	2.3	7.8	37.1	68.7	920	0.61
III-3	430.0	1.5	0.1	3.1	4.7	15.8	34.3	460	1.07
III-4	570.2	0.6	0.4	0.6	1.6	17.1	37.2	490	0.86
III-5	94.2	0.2	0	0.1	0.3	0.6	1.3	20	0.21
III-TOTAL	3219.9	7.5	1.0	6.3	14.8	78.5	145.4	1930	0.60
IV-1	958.0	1.8	0.3	0.5	2.6	16.3	35.4	470	0.49
IV-2	792.4	3.3	0.2	0.3	3.8	12.4	27.0	310	0.45
IV-3	836.1	2.7	0.2	0.8	3.7	9.7	21.1	240	0.33
IV-4	439.4	1.0	0	0.2	1.2	2.4	5.2	70	0.16
IV-5	1258.4	5.1	0.2	1.3	6.6	18.4	40.0	530	0.42
IV-6	1475.4	1.7	0.1	1.6	3.6	12.3	26.7	310	0.24
IV-7	766.9	1.5	0.3	0.7	2.3	6.1	13.3	170	0.22
IV-TOTAL	6526.6	17.1	1.3	5.4	23.8	77.6	168.7	2240	0.34
V-1	480.0	3.7	0.2	0.6	4.5	17.3	37.6	510	1.06
V-2	1476.2	6.4	0.6	0.7	7.7	29.3	63.7	740	0.58
V-3	1002.5	4.7	0.2	2.1	7.0	17.3	37.6	510	0.51
V-4	1722.6	7.5	0.2	1.1	7.0	14.5	31.5	410	0.24
V-5	479.7	3.0	0.3	1.0	4.1	5.9	10.9	150	0.31
V-6	878.2	3.0	1.3	0.6	4.9	7.4	16.1	220	0.25
V-TOTAL	6039.2	27.3	2.8	5.1	35.2	90.8	197.4	2280	0.43
TOTAL	28334.2	109.7	9.7	29.4	148.8	446.1	969.0	12900	0.46

Table 1B Water Demand Distribution by Each Kecamatan, 1985

KECAMATAN	AREA	DOMESTIC (ha) (*000m ³ /d)	NON-DOMESTIC T & C		CONSUMPTION (*000m ³ /d) (*000m ³ /s)	UNACCOUNTED (%)	DEMAND (DAY AVG) (m ³ /d)	DAY MAX (l/s)	DENSITY		
			Public	Industry						Total	
I-1	I-1	737.6	7.1	0.2	3.6	10.9	24.1	49.2	660	0.87	
	I-2	583.2	5.7	0.3	2.3	8.3	21.6	44.1	590	1.01	
	I-3	704.0	10.0	0.4	0.9	4.8	22.5	44.7	600	0.85	
	I-4	461.0	12.1	0.2	3.1	9.5	21.6	42.4	560	1.21	
	I-5	717.6	18.4	0.6	0.8	6.3	23.7	48.4	640	0.89	
	I-6	613.6	11.9	0.1	1.8	6.2	18.1	35.5	470	0.77	
	I-7	1016.8	16.7	0.5	2.8	10.4	27.1	53.1	700	0.69	
I-TOTAL	4353.8	105.5	2.1	15.3	76.4	151.9	317.5	4220	0.87		
II-2	II-2	2509.5	3.1	3.1	0.8	7.0	29.6	670	770	0.31	
	II-3	2423.0	19.1	3.7	0.1	21.5	60.3	79.0	1050	0.43	
	II-4	1571.7	1.9	1.7	0.4	4.0	22.9	44.9	600	0.38	
	II-5	1190.5	1.4	1.9	0.1	3.4	11.3	22.2	260	0.25	
	II-TOTAL	7694.7	24.5	10.0	1.4	35.9	104.1	204.1	2360	0.35	
	III-1	III-1	607.5	1.9	0.2	0.3	0.5	2.4	4.7	60	0.10
		III-2	1518.0	31.8	0.8	3.4	9.3	41.1	80.6	950	0.70
III-3		430.0	13.5	0.3	4.2	6.3	19.8	38.8	520	1.21	
III-4		570.2	19.0	0.6	0.9	2.0	21.8	42.7	560	0.98	
III-5		94.2	0.5	0.0	0.2	0.5	1.0	2.0	20	0.21	
III-TOTAL		3219.9	66.7	1.7	9.0	19.4	86.1	168.8	2240	0.70	
IV-1		IV-1	958.0	19.1	0.4	0.8	3.3	22.4	43.9	570	0.62
	IV-2	792.4	12.0	0.3	0.5	4.3	16.3	32.0	430	0.54	
	IV-3	836.1	9.4	0.3	1.1	4.2	13.6	26.7	360	0.43	
	IV-4	439.4	2.0	0.0	0.3	1.6	3.6	7.1	90	0.20	
	IV-5	1250.4	17.3	0.3	1.9	7.4	24.7	48.4	640	0.51	
	IV-6	1475.4	13.7	0.5	2.6	5.5	19.2	37.6	440	0.35	
	IV-7	766.9	6.4	0.1	1.1	3.0	9.4	18.4	240	0.31	
IV-TOTAL	6526.6	79.9	1.9	8.3	29.3	109.2	214.1	2850	0.44		
V-1	V-1	480.0	16.0	0.2	1.0	5.7	21.7	42.5	560	1.17	
	V-2	1476.2	29.2	1.1	1.0	9.2	38.4	75.3	1000	0.68	
	V-3	1002.5	14.6	0.3	3.2	9.1	23.7	46.5	620	0.62	
	V-4	1722.6	11.1	0.4	1.8	8.7	19.8	38.8	520	0.30	
	V-5	479.7	1.4	0.5	0.0	4.7	6.1	12.0	160	0.33	
	V-6	878.2	4.2	2.9	1.2	7.8	12.0	23.5	310	0.35	
	V-TOTAL	6039.2	76.5	5.4	8.2	45.2	121.7	238.6	3170	0.52	
TOTAL	28334.2	396.0	112.9	42.2	176.2	573.0	1123.5	13000	14950	0.53	

Table IC Water Demand Distribution by Each Kecamatan, 1990

KECAMATAN	AREA DOMESTIC (ha) (*000m ³ /d)	NON-DOMESTIC			Total (*000m ³ /d) (*000m ³ /s)	CONSUMPTION (m ³ /s)	UNACCOUNT (%)	DEMAND (DAY AVG) (m ³ /d)	DAY MAX (l/s)	DENSITY
		Public	Industry	T & C						
I-1	757.6	17.0	0.4	5.9	12.3	29.3	19.5	48.8	560	0.84
I-2	583.2	17.3	0.6	3.3	9.1	26.4	17.6	44.0	510	1.01
I-3	704.0	21.6	0.7	1.4	6.2	27.8	18.5	46.3	540	0.88
I-4	461.0	14.4	0.2	4.4	10.1	24.5	16.3	40.8	470	1.17
I-5	717.6	22.2	0.7	1.0	6.8	29.0	19.3	48.3	560	0.89
I-6	613.6	14.7	0.2	2.6	6.9	21.6	14.4	36.0	420	0.72
I-7	1016.8	20.8	0.8	4.5	11.9	32.7	21.8	54.5	630	0.71
I-TOTAL	4853.8	128.0	3.6	23.1	63.3	191.3	127.5	310.8	3690	0.87
II-2	3315.7	30.3	8.6	1.4	13.7	44.0	29.3	73.3	850	0.30
II-3	2423.0	25.7	7.6	0.2	28.6	54.3	36.2	90.5	1050	0.50
II-4	2004.4	25.4	4.7	0.8	8.3	33.7	22.5	56.2	650	0.37
II-5	1190.5	10.6	5.2	0.1	6.9	17.3	11.7	29.2	340	0.33
II-TOTAL	8933.6	92.0	26.1	2.5	57.5	149.5	99.7	249.2	2880	0.37
III-1	1160.6	4.9	1.8	0.8	3.3	0.2	5.5	13.7	160	0.16
III-2	1763.1	46.4	1.6	5.5	12.6	59.0	39.3	98.3	1140	0.74
III-3	430.0	16.1	0.5	6.2	8.4	24.5	16.3	40.8	470	1.26
III-4	570.2	22.4	1.0	1.2	3.9	26.3	17.3	43.8	510	1.03
III-5	1686.3	18.2	0.5	1.6	4.3	22.5	15.0	37.5	430	0.29
III-TOTAL	5610.2	108.0	5.4	13.5	32.5	140.5	93.7	234.2	2710	0.56
IV-1	958.0	25.7	0.5	1.3	4.6	30.3	20.2	50.5	580	0.70
IV-2	792.4	15.9	0.4	0.8	4.9	20.8	13.9	34.7	400	0.58
IV-3	1292.8	19.7	0.6	1.9	5.8	23.5	17.0	42.5	480	0.43
IV-4	530.8	4.3	0.1	0.6	2.5	6.8	4.5	11.3	130	0.28
IV-5	1258.4	23.9	0.4	3.2	8.3	32.2	21.5	53.7	620	0.56
IV-6	1886.4	25.9	1.0	4.4	9.2	35.1	23.4	58.5	680	0.41
IV-7	766.9	10.0	0.2	2.0	4.2	14.2	9.5	23.7	270	0.40
IV-TOTAL	7485.7	125.4	3.2	14.2	39.5	164.9	109.9	274.8	3180	0.49
V-1	480.0	19.4	0.3	1.6	7.1	26.5	17.7	44.2	510	1.23
V-2	1476.2	38.2	2.1	1.6	11.4	49.6	33.1	82.7	960	0.75
V-3	1598.4	27.5	0.7	5.2	12.8	40.3	26.9	67.2	780	0.56
V-4	2042.2	18.1	0.6	2.9	10.5	28.6	19.1	47.7	550	0.31
V-5	479.7	2.0	0.8	0.1	5.7	7.7	5.1	12.8	150	0.32
V-6	878.2	6.7	7.0	2.6	14.7	21.6	14.4	36.0	420	0.35
V-TOTAL	6955.7	111.9	11.5	14.0	62.4	174.3	116.2	290.5	3360	0.35
TOTAL	33839.0	565.3	136.1	49.8	69.3	253.2	820.5	1367.5	15830	0.54

Table 10 Water Demand Distribution by Each Kecamatan, 1995

KECAMATAN	AREA (ha)	DOMESTIC (¹⁰⁰⁰ m ³ /d)	NON-DOMESTIC T & C			CONSUMPTION (¹⁰⁰⁰ m ³ /d)	UNACCOUNT (%)	DEMAND (DAY AVG) (m ³ /d)	DAY MAX (l/s)	DENSITY
			Public	Industry	Total					
I-1	757.6	19.9	6.1	0.5	9.3	15.9	17.6	53.4	710	0.94
I-2	583.2	20.8	5.9	0.9	4.8	11.6	16.0	48.4	640	1.10
I-3	704.0	25.4	5.1	1.1	7.0	8.2	16.5	50.1	580	0.95
I-4	481.0	16.6	5.8	0.3	6.3	12.4	14.3	43.3	580	1.26
I-5	717.6	26.2	5.7	0.9	1.5	8.1	18.9	51.2	680	0.95
I-6	613.6	17.5	4.5	0.2	4.0	8.7	12.9	39.1	450	0.85
I-7	1016.8	25.1	7.0	1.0	7.0	15.0	19.8	59.9	790	0.78
I-TOTAL	4853.8	151.5	40.1	4.9	34.9	79.9	114.0	345.4	4600	0.95
II-2	3315.7	39.0	5.6	17.0	2.6	27.2	32.6	98.8	1310	0.40
II-3	2423.0	32.2	24.4	14.2	0.5	39.1	35.1	106.4	1410	0.58
II-4	2004.4	31.7	4.1	9.4	1.4	14.9	23.0	69.6	930	0.46
II-5	1190.5	14.1	2.4	9.2	0.3	12.6	13.2	46.0	530	0.65
II-TOTAL	8933.6	117.0	36.5	52.5	4.8	93.0	103.8	314.6	4190	0.47
III-1	1573.4	9.0	1.3	4.6	1.3	7.2	8.0	24.2	320	0.20
III-2	1763.1	59.2	7.1	2.5	8.5	18.1	39.1	115.4	1540	0.87
III-3	430.0	18.8	2.2	0.6	8.6	11.4	14.9	45.1	600	1.40
III-4	570.2	26.0	2.9	1.7	1.9	6.5	16.0	48.5	640	1.12
III-5	2533.7	40.0	4.7	1.2	4.1	10.0	24.6	74.6	990	0.39
III-TOTAL	6870.4	153.0	18.2	10.6	24.4	53.2	101.6	307.8	4090	0.60
IV-1	958.0	32.0	3.9	0.7	2.3	6.9	12.2	58.1	770	0.80
IV-2	792.4	19.7	4.5	0.5	1.4	6.4	12.9	39.0	520	0.66
IV-3	1860.4	37.7	5.7	0.9	3.2	9.8	24.4	73.9	990	0.33
IV-4	795.9	11.0	2.7	0.3	1.4	4.4	7.6	23.0	310	0.39
IV-5	1258.4	30.4	3.3	0.5	3.4	11.2	20.5	62.1	830	0.66
IV-6	2931.1	56.3	8.1	1.9	7.0	17.0	36.1	109.4	1460	0.50
IV-7	766.9	15.2	2.6	0.3	3.4	6.3	10.6	32.1	430	0.56
IV-TOTAL	9363.1	204.3	32.8	5.1	24.1	62.0	131.2	397.5	5290	0.56
V-1	480.0	22.9	6.3	0.4	2.6	9.3	15.9	48.1	640	1.33
V-2	1476.2	47.5	9.2	2.8	2.5	14.5	32.2	92.5	1230	0.83
V-3	2333.5	51.0	10.7	1.4	8.2	20.3	35.1	106.4	1410	0.61
V-4	2117.4	25.4	8.6	0.8	4.6	14.0	19.4	58.8	780	0.37
V-5	479.7	2.8	5.3	1.5	0.1	6.9	4.8	14.5	200	0.42
V-6	1322.7	15.4	6.6	10.3	5.1	22.0	18.4	55.8	750	0.54
V-TOTAL	8276.5	165.0	46.7	17.2	23.1	87.0	124.1	376.1	5000	0.60
TOTAL	38297.4	790.8	174.5	90.3	111.3	375.9	574.6	1741.3	23170	0.61

Table 1E. Water Demand Distribution by Each Kecamatan, 2000

KECAMATAN	AREA DOMESTIC (ha) (*000m ³ /d)	Public	NON-DOMESTIC Industry	T & C Total	CONSUMPTION (*000m ³ /s)	UNACCOUNT (2%)	DEMAND (DAY AVG) (m ³ /d)	DAY MAX (l/s)	DENSITY
I-1	757.6	6.5	0.7	15.2	22.4	18.5	63.9	74.0	1.12
I-2	503.2	6.4	1.3	6.8	14.5	15.7	54.2	63.0	1.23
I-3	704.0	5.6	1.5	2.9	10.0	15.9	54.8	72.0	1.02
I-4	461.0	6.4	0.3	9.1	15.0	14.3	47.2	66.0	1.43
I-5	717.6	6.3	1.3	2.2	9.8	16.3	56.3	75.0	1.05
I-6	613.6	4.8	0.3	5.6	10.7	12.9	44.4	59.0	0.96
I-7	1016.8	7.5	1.3	10.9	19.7	20.2	67.6	93.0	0.91
I-TOTAL	4833.8	43.5	6.7	52.7	102.9	113.8	392.4	454.0	1.08
II-2	3315.7	6.3	31.3	4.5	42.1	36.7	126.5	168.0	0.51
II-3	2423.0	28.4	21.2	1.1	50.7	36.4	125.5	167.0	0.69
II-4	2004.4	4.8	14.4	2.7	21.9	24.2	83.4	112.0	0.56
II-5	1190.5	3.0	14.8	0.5	18.3	14.5	49.9	67.0	0.56
II-TOTAL	8933.6	42.5	81.7	8.8	133.0	111.7	385.2	513.0	0.57
III-1	2240.7	2.5	9.9	3.6	16.0	13.6	46.8	62.0	0.28
III-2	1763.1	7.8	3.5	13.2	24.5	38.8	133.8	178.0	1.01
III-3	430.0	2.3	1.0	12.5	15.8	15.2	52.3	70.0	1.63
III-4	370.2	3.0	2.7	2.6	8.3	15.4	53.1	70.0	1.23
III-5	3442.7	7.3	2.1	10.1	19.5	36.5	125.8	168.0	0.49
III-TOTAL	8446.7	22.9	19.2	42.0	84.1	119.4	411.7	549.0	0.65
IV-1	958.0	4.4	0.9	4.0	9.3	19.9	68.6	91.0	0.95
IV-2	792.4	4.8	0.6	2.5	7.9	12.9	44.4	59.0	0.74
IV-3	1860.4	6.6	1.4	5.2	13.2	27.0	93.2	124.0	0.67
IV-4	1133.3	3.9	0.5	3.3	7.7	11.1	44.0	51.0	0.45
IV-5	1258.4	5.9	0.7	8.8	15.4	21.8	75.1	100.0	0.79
IV-6	3169.1	10.7	2.9	11.3	24.9	43.8	151.0	201.0	0.63
IV-7	766.9	3.0	0.3	5.9	9.2	11.5	39.7	53.0	0.69
IV-TOTAL	9933.5	39.3	7.3	41.0	87.6	147.9	510.1	679.0	0.68
V-1	480.0	7.0	0.5	4.1	11.6	15.4	53.0	70.0	1.46
V-2	1476.2	10.4	3.7	3.9	18.0	30.3	104.4	121.0	0.94
V-3	2669.5	12.5	2.1	13.2	27.8	40.3	139.0	185.0	0.69
V-4	2423.1	9.8	1.4	7.3	18.5	21.8	75.1	100.0	0.41
V-5	479.7	5.9	2.2	0.2	8.3	4.9	16.8	22.0	0.66
V-6	1603.8	8.2	19.6	11.0	39.0	25.9	89.3	118.0	0.70
V-TOTAL	9222.3	53.8	29.7	39.7	123.2	130.5	477.5	636.0	0.69
TOTAL	41394.9	202.0	144.6	184.2	530.8	631.3	2176.9	2898.0	0.70

Table 1F Water Demand Distribution by Each Kecamatan, 2005

KECAMATAN	AREA DOMESTIC (ha) (*000m ³ /d)	Public	Industry	NON-DOMESTIC r & e		Total	CONSUMPTION (*000m ³ /d)	UNACCOUNT (25%)	DEMAND (DAY AVG) (m ³ /d)	DAY MAX (l/s)	DENSITY	
				Public	Industry							
I-1	757.6	7.3	0.9	22.9	31.1	57.2	19.1	76.3	880	1010	1.33	
I-2	583.2	7.7	1.8	9.1	18.1	45.4	15.1	60.5	700	810	1.39	
I-3	704.0	6.1	2.0	3.8	11.2	44.5	14.8	59.3	690	790	1.12	
I-4	461.0	6.8	0.4	12.1	17.3	40.6	13.5	54.1	630	720	1.56	
I-5	717.6	6.9	3.0	3.0	11.6	45.8	15.3	61.1	710	820	1.14	
I-6	613.6	5.3	0.4	8.0	13.7	37.8	12.6	50.4	500	670	1.09	
I-7	1016.8	8.3	1.7	16.7	26.7	60.7	20.2	80.9	940	1080	1.06	
I-TOTAL	4853.8	47.9	8.9	75.6	132.4	332.0	110.7	442.7	5120	5890	1.21	
II-2	3315.7	7.6	45.7	5.9	59.2	116.6	38.9	155.5	1800	2070	0.62	
II-3	2623.0	33.1	28.2	1.9	63.2	109.4	36.1	144.5	1670	1920	0.79	
II-4	2004.4	5.6	19.7	5.5	30.8	74.5	24.8	99.3	1150	1320	0.66	
II-5	1190.5	3.4	19.7	0.9	24.0	44.6	14.9	59.5	690	790	0.66	
II-TOTAL	8233.6	49.7	113.3	14.2	177.2	344.1	114.7	450.8	5310	6110	0.68	
III-1	3233.1	4.2	26.5	9.0	39.7	72.5	24.2	96.7	1120	1290	0.40	
III-2	1763.1	9.0	4.9	19.1	33.0	116.8	30.9	155.7	1800	2070	1.17	
III-3	430.0	2.7	1.3	10.6	20.6	44.8	14.9	59.7	690	790	1.04	
III-4	570.2	3.2	3.7	3.6	10.5	43.6	14.5	58.1	670	770	1.35	
III-5	4375.6	12.4	4.1	19.6	36.1	159.2	53.1	212.3	2460	2850	0.65	
III-TOTAL	10372.0	31.5	40.5	67.9	159.9	436.9	145.6	582.5	6740	7750	0.75	
IV-1	930.0	5.0	1.1	6.4	12.5	59.0	19.7	78.7	910	1050	1.10	
IV-2	792.4	5.3	0.7	3.8	10.0	37.5	12.5	50.0	580	670	0.85	
IV-3	1860.4	7.6	1.8	8.1	17.5	82.7	27.6	110.3	1280	1470	0.79	
IV-4	1467.3	5.0	0.8	6.6	12.4	41.6	13.9	55.5	640	740	0.50	
IV-5	1258.4	6.6	0.2	13.8	21.3	66.2	22.1	88.3	1020	1170	0.93	
IV-6	3169.1	13.0	4.2	16.5	33.7	135.1	45.0	180.1	2080	2390	0.75	
IV-7	766.9	3.4	0.5	9.3	13.2	36.5	12.2	48.7	560	640	0.83	
IV-TOTAL	10277.5	45.9	10.2	64.5	120.6	450.6	152.9	611.5	7080	8140	0.79	
V-1	480.0	7.0	0.6	6.2	14.6	44.0	14.7	58.7	680	780	1.63	
V-2	1476.2	64.7	4.8	5.7	22.1	86.8	28.9	115.7	1340	1540	1.04	
V-3	3180.0	100.2	3.3	19.2	30.0	130.2	46.1	186.3	2130	2450	0.77	
V-4	2720.7	46.2	2.1	10.9	24.4	70.6	23.5	94.1	1090	1250	0.46	
V-5	663.4	7.0	3.3	0.3	10.2	17.2	5.7	22.9	270	310	0.47	
V-6	2472.1	46.3	11.1	21.7	59.9	106.2	35.4	141.6	1640	1890	0.76	
V-TOTAL	11015.4	293.8	64.0	64.0	169.2	463.0	154.3	617.3	7140	8210	0.75	
TOTAL	45447.3	1295.3	239.0	214.1	286.2	739.3	2034.6	678.2	2712.8	31400	36110	0.79

2. Study by Module to Select Optimal Supply Zones

To select optimal supply zones, various-sized supply blocks and their combination will be compared in respect to costs, considering at the same time convenience of operation. For this comparative study, some assumptions will first be made, and then based on them, costs be estimated, as briefed in the following.

1) Assumptions

(1) Topographical Condition

- a. Flat: To be applied to the northern part of the served area as shown on Fig. 2.
- b. Sloping, with gradient of 3% :

To be applied to the southern part of the served area as shown on Fig. 2.

This gradient will be considered in calculating pipe size.

(2) Unit Water Demand per Hectare

The following three cases, which are taken from Table 1 as representative unit water demands, will be applied for calculation of necessary pipes.

- a. 1.0 l/sec
- b. 0.75 l/sec
- c. 0.50 l/sec

(3) Size of Supply Zone

To obtain roughly an appropriate magnitude of supply zone, the following assumptions will be employed for module study, although a square-shaped zone cannot be applied to the served area.

- a. 5 x 5 km = 25 km²
- b. 7.5 x 7.5 km = 56 km²
- c. 10 x 10 km = 100 km²

(4) Modules for Comparison

Based on the above assumptions, 18 modules are made as shown on Fig. 3.






Fig 2 TOPOGRAPHICAL FEATURE OF SERVICE AREA
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA

- Scale of Supply Zone**
- ① $4 \times 25 \text{ km}^2 = 100 \text{ km}^2$
 - ② $2 \times 56 \text{ km}^2 = 112 \text{ km}^2$
 - ③ $1 \times 100 \text{ km}^2 = 100 \text{ km}^2$



LAYOUT OF TRUNK MAIN OF EACH CASE



CASE II

a : unit water demand 1.0 l/s/ha (day maximum) l : unit length of main grid
 b : unit water demand 0.75 l/s/ha (day maximum) g : discharge rate of node (hourly maximum)
 c : unit water demand 0.50 l/s/ha (day maximum)

CASE I : flat area CASE II : area with gradient, 3%

FIG 3 MODULE FOR COST COMPARISON
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA

2) Cost Comparison

Applying the assumptions in the foregoing para, construction and O & M costs, and present worth of the costs will be calculated on the following conditions.

- i. Total construction period is assumed as 6 years, where construction of transmission facilities in two years, and distribution facilities in six years.
- ii. Operation period is assumed as 20 years after completion of construction.
- iii. Mechanical and electrical equipment are considered to be replaced at every 15 years after starting operation.

The results of calculation are shown on Table 2. From the Table, the following conclusions will be made, that is:

a. Northern Area with Flat Topography

In all supply capacities, Sub-case 2 with an area of 7.5 km x 7.5 km has least cost.

b. Southern Area with Gradient 3%

Sub-case 3 with 10 km x 10 km area shows least cost, but it is not significantly different from Sub-case 2. Considering that the operation of Sub-case with a smaller area is more convenient and also the supply capacity of this size area is appropriate, Sub-case 2 is considered preferable.

Table 2 Cost Comparison for Scale of Supply Zone

Unit: Million Yen

SUPPLY CAP.	CASE/ SUB-CASE	INITIAL COST UNIT COST	O & M COST		REPLACE- MENT COST	8%		10%		12%		
			UNIT COST	COST		PRESENT WORTH	UNIT COST	PRESENT WORTH	UNIT COST	PRESENT WORTH		
1/sec												
2,500	a - 1	4,849	1.94	134.4	0.054	556	5,375	2.15	5,047	2.02	4,722	1.89
5,630	2	10,577	1.88	302.3	0.054	1,283	11,811	2.10	11,008	1.96	10,355	1.84
10,000	3	18,531	1.85	558.6	0.056	2,422	20,955	2.10	19,494	1.95	18,212	1.83
1,880	b - 1	4,230	2.25	102.1	0.054	433	4,561	2.43	4,272	2.27	4,036	2.15
4,240	2	8,217	1.94	246.2	0.058	1,038	9,272	2.19	8,629	2.04	8,108	1.91
7,090	3	14,051	1.98	387.5	0.055	1,691	15,660	2.20	14,534	2.05	13,684	1.93
1,250	c - 1	2,880	2.30	64.4	0.052	297	3,062	2.45	2,874	2.30	2,720	2.18
2,830	2	5,874	2.08	157.3	0.056	673	6,469	2.29	6,041	2.13	5,692	2.01
5,000	3	10,813	2.16	280.2	0.056	1,222	11,834	2.37	11,060	2.21	10,429	2.09
	Case II											
2,500	a - 1	4,713	1.99	114.7	0.046	472	5,087	2.03	4,764	1.91	4,500	1.80
5,630	2	10,147	1.80	208.0	0.037	874	10,062	1.89	9,993	1.77	9,473	1.68
10,000	3	17,502	1.75	324.2	0.032	1,417	18,036	1.80	17,007	1.70	16,154	1.62
1,880	b - 1	4,131	2.20	80.7	0.043	341	4,290	2.28	4,041	2.15	3,835	20.4
4,240	2	7,941	1.87	182.0	0.043	762	8,477	2.00	7,952	1.88	7,521	1.77
7,090	3	13,256	1.87	227.2	0.032	994	13,502	1.90	12,755	1.80	12,132	1.71
1,250	c - 1	2,833	2.27	53.3	0.043	230	2,926	2.34	2,758	2.21	2,619	2.10
2,830	2	5,689	2.01	114.5	0.040	488	5,938	2.10	5,589	1.97	5,300	1.87
5,000	3	10,294	2.06	164.7	0.033	724	10,384	2.08	9,824	1.96	9,355	1.87

Note: In the table, Case I shows the case where topography is flat

Case II shows the case where gradient is 3%

a shows the case where unit demand is 1.0 l/s/h

b " " " 0.75 "

c " " " 0.50 "

1 shows the case where the areas is 5 x 5 Km²

2 " " " 7.5 x 7.5 "

3 " " " 10 x 10 "

3. Conclusion

1) Considerations for Application of Modules

Selected modules will be applied to the dividing of the existing served area, based on the following basic considerations.

- (1) Taking advantage of the locations of the existing two major treatment plants, i.e., Pejompongan and Pulogadung, and also the natural topographical boundary of the Ciliwung River, the served area will be divided roughly into two main zones, namely, east and west.
- (2) In addition to the above (1), the served area will be roughly divided into two main zones because of the topographical gradient, namely, northern flat zone and southern sloping zone.
- (3) Considering the difficulty of expanding the existing water system located in the highly built up area, new additional systems will be located on the periphery of the city to strengthen the water supply in the peripheral areas.
- (4) The capacity of a supply zone will be targeted at +5 m³/sec, so as to avoid too expensive trunk mains construction works.

2) Proposed Supply Zones

Supply zones selected under the considerations in 1) are proposed as shown on Fig. 4 for 1995 and Fig. 5 for 2005. Water demand of each supply zone is estimated based on area wise (Kecamatan) demand as shown in Tables 3 and 4.

There are some modifications in boundaries of zones for transition from 1995 to 2005, because there are natural growths of water demand. Regarding these modifications, all layout of trunk mains is planned to minimize the construction cost thereof.

3) Supply Zones and Administrative Divisions

The proposed supply zones are determined on technical basis, and do not necessarily correspond with the administrative divisions, the existing Districts. When data sorted by District is required for statistic and other purposes, that is possible by computerized processing.

Table 3 Water Demand Distribution by Supply Zone in 1995 (Day Max in l/s)


Zone	KECAMATAN	TOTAL DEMAND	1995		
			l	Demand	
Z-1	I-1	710	100	710	
	I-2	640	-	-	
	I-6	520	100	520	
	I-7	290	100	790	
	II-2	1,310	40	520	
	III-2	1,540	85	1,310	
	III-3	600	100	600	
	III-4	640	100	640	
	IV-1	770	-	-	
	IV-2	520	40	210	
	IV-5	830	10	80	
	IV-6	1,450	15	220	
		TOTAL			5,600
	Z-2	I-3	670	20	130
I-4		580	65	380	
I-5		680	100	680	
II-4		930	20	190	
V-1		640	100	640	
V-2		1,230	100	1,230	
V-6		750	100	750	
	TOTAL			4,000	
Z-3	I-2	640	100	640	
	I-3	670	80	540	
	I-4	580	35	200	
	II-2	1,310	30	390	
	II-3	1,020	100	1,020	
	II-4	930	80	740	
	II-5	530	100	530	
	Tanjung Priok	390	100	390	
		TOTAL			4,450
Z-4	II-2	1,310	30	400	
	III-1	320	100	320	
	III-2	1,540	15	230	
	III-5	980	100	990	
		TOTAL			1,940

Zone	KECAMATAN	1995		
		TOTAL DEMAND	Demand	
Z-5	IV-1	770	100	770
	IV-2	520	60	310
	IV-3	990	100	990
	IV-4	310	100	310
	IV-5	830	90	750
	IV-6	1,460	85	1,240
	IV-7	430	100	430
	TOTAL			4,800
Z-6	IV-1	-	-	-
	IV-2	-	-	-
	V-3	1,410	100	1,410
	V-4	780	100	780
	V-5	200	100	200
	TOTAL			2,390
TOTAL			23,200	

Table 4 Water Demand Distribution by Supply Zone
in 2005 (Day Max in l/s)

Zone	KECAMATAN	2005		
		TOTAL DEMAND	%	Demand
Z-1	I-1	1,010	100	1,010
	I-6	670	100	670
	I-7	1,080	100	1,080
	III-2	2,070	88	1,820
	III-3	790	65	510
	III-4	770	60	460
	TOTAL			5,550
Z-2	I-4	720	100	720
	I-5	820	100	840
	V-1	780	100	780
	V-2	1,540	100	1,540
	II-4	1,320	10	130
	TOTAL			3,990
Z-3	I-2	810	100	800
	I-3	790	100	790
	II-2	2,070	30	620
	II-3	1,920	100	1,930
	II-4	1,320	90	1,190
	II-5	790	100	790
	TOTAL			6,120
Z-4	II-2	2,070	70	1,450
	III-1	1,290	20	260
	III-2	2,070	5	100
	III-3	790	35	280
	III-4	770	40	310
	TOTAL			2,400
Z-5	III-1	1,290	80	1,030
	III-2	2,070	7	150
	III-5	2,830	100	2,830
	IV-6	2,390	10	240
	TOTAL			4,250
Z-6	V-3	2,450	65	1,590
	V-6	1,890	100	1,890
	TOTAL			3,480
Z-7	IV-5	1,170	100	1,170
	IV-6	2,390	90	2,150
	IV-7	640	100	640
	TOTAL			3,960

Zone	KECAMATAN	2005	
		TOTAL DEMAND	Demand
Z-8	IV-1	1,050	100
	IV-2	670	100
	IV-3	1,470	100
	IV-4	740	100
	TOTAL		3,930
Z -9	V-3	2,450	35
	V-4	1,250	100
	V-5	310	100
	TOTAL		2,420
TOTAL			36,100






Fig 5 | SUPPLY ZONE IN 2005
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA

MASTER PLAN FOR
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT

M10. APPENDIX MIV-4

ALTERNATIVE STUDY ON FUTURE WATER SUPPLY SYSTEM
(RAW WATER SOURCE AND TRANSMISSION)

ALTERNATIVE STUDY ON FUTURE WATER SUPPLY SYSTEM
(RAW WATER SOURCE AND TRANSMISSION)

C o n t e n t s

1.	Introduction	M10-1
2.	Water Demand of Supply Zones	M10-1
3.	Location of Treatment Plant and Distribution Center	M10-4
3.1	Plant Location	M10-4
3.2	Location of the Distribution Center	M10-5
4.	The Supply System for the Second Stage Project	M10-5
5.	Alternatives of Transmission System	M10-8
6.	Conclusion	M10-13

Attachment

CONSIDERATION ON RAW WATER SOURCES FOR JAKARTA WATER SUPPLY SYSTEM IN 1995	M10-26
---	--------

FACILITIES AND CONSTRUCTION COST IN CASE OF THE THIRD STAGE RAW WATER SUPPLY ONLY FROM WATER RESOURCES IN THE EAST	M10-33
--	--------

1. Introduction

Whole service area is planned to be divided into plural supply zones considering the present complicated distribution network and rapid expansion of future water supply system of Jakarta. Details are explained in Appendix MIV-3 "DIVISION OF THE SERVICE AREA ... SUPPLY ZONES".

As to the development of raw water source, two possible source are considered for the future expansion program. They are the Citarum river and the Cisadane river basins located at the east and the west of Jakarta respectively. The feasibility study on the Citarum river basin recommended the Canal 1 as the advantageous raw water conveyance system for water supply to Jakarta. While the feasibility of the development of the Cisadane river basin is in the initial study stage.

It is obvious that balanced raw water supply in quantity from both east and west directions of the City is desirable from the view point of safety water supply. But economical advantage of the system is also vital zoning and availability of raw water, the alternative study was made to find out most advantageous system with required raw water from each source.

During the interim stage of the Master Plan, possible utilization of raw water sources for Jakarta water supply system in the Second Stage was studied comparing feasibility from the economic point of view (refer to Attachment). According to the study, it was found more advantageous to take raw water from the Cisadane river to meet water demand, about 7 m³/sec, of western part of the City. About 3 m³/sec of raw water from the Cisadane river was confirmed by DGWRD for the near future and the rest is still subject to the study on water resources development of the Cisadane basin.

It should be noted that the cost comparison of the study does not include the costs for water resources development and raw water conveyance systems.

2. Water Demand of Supply Zones

Based on water demand distribution to each Kecamatan, water demand of each supply zone for the Second and the Third Stage Project is estimated and shown in Figs 1-1 and 1-2.




Fig 1-1 WATER DEMAND IN 1995

JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA




Fig 1-2 WATER DEMAND IN 2005
 JAKARTA WATER SUPPLY DEVELOPMENT PROJECT | JICA

3. Location of Treatment Plant and Distribution Center

As described in the preceding section, the service area is divided into plural zones. The congested central area is supplied from the existing treatment plant, Pejompongan and Pulogadung plants, and its surroundings, now developing rapidly, are to be supplied from new sources. It will be rather difficult to expand the existing plants due to land availability and congested surroundings to lay large trunk mains.

On the other hand, two raw water sources stand for the future water supply system of Jakarta, east and west directions of the City, as mentioned in the preceding section.

It will be advantageous to place the future water treatment plant at both eastward and westward of the service area.

3.1 Plant Location

1) Eastward Treatment Plant

The location of the treatment plant for the Immediate and First Phase of the Second Stage Projects is proposed at Buaran, along the south bank of WTC taking into consideration the raw water quality, availability of land and nearer locations from the service area. Details are explained in Appendices MIV-2 and MIV-5. As for the future plant location, there are substantially two alternatives, i.e.,

(1) At the Canal end, Bekasi

(2) At Cakung, about 2 km downstream of the Bekasi river along WTC. The site was selected considering land availability and convenient location for layout of treated water transmission pipe along the major road now under construction.

In the former case, longer treated water transmission pipeline and pump facilities are required. In the latter case, raw water is to be transmitted from the Canal 1 end either by transmission pipe or open canal. It will be obvious that the case, placing the treatment plant at Cakung and transmitting raw water by canal, has an advantage among others if hydraulically feasible and land is available for the canal construction. According to the hydraulic analysis, raw water is able to be transmitted by gravity. And land is available along WTC according to the site investigation. Therefore, the location of the treatment plant is proposed at Cakung.

2) Westward Treatment Plant

The site of the plant for the First Phase of the Second Stage Project was proposed at Pondok Pinang, namely Lebakbulus treatment plant, as described in Appendix MIV-6.

The future plant location is planned based on the following conditions:

(1) The intake dam will be constructed at Cilangkap of the Cisadane river for raw water supply to Jakarta.

- (2) Intake water level of dam is at + 50 m or around.
- (3) The raw water transmission system will be constructed up to the treatment plant site.

To utilize the advantage of high potential of water level at the dam, the plant is to be placed at higher location near to the service area. The location of the future plant is proposed somewhere adjacent to the Lebakbulus plant considering convenient operation and maintenance of the plant and easiness to arrange transmission pipeline to each supply zone along the outer link road.

Ground elevation of the area is + 35 m or around, therefore the proposed water receiving level at the plant is + 40 m or around. It will be possible to transmit raw water from the dam to the plant site by gravity considering the difference of elevations as about 10 m and about 20 km distance.

3.2 Location of the Distribution Center

From the advantage of higher location, the distribution centers for supply zones in southern area are placed at south edges along the outer link road. The layout of transmission pipeline will be easier and maintenance of them will be more convenient.

For other distribution centers, located in eastern and western areas, they are also placed at the edges of each supply zone along the outer link road taking into account the tendency of water demand increase to eastern and western directions, availability of land and convenience for layout of transmission pipelines and maintenance of them.

4. The Supply System for the Second Stage Project

It will be advantageous for the First Phase of the Second Stage Project to utilize raw water, 3 m³/sec as described in the above, from the Cisaeane river to supply water for the western zones rather than to transmit water from the east through long transmission pipeline. Earlier completion of the Canal 1 is required if raw water from the Cisadane river is not available.

As for the Second Stage Project, the Canal 1 is the only source for the additional requirement of raw water. Therefore, it is obvious that additional water requirement in the western supply zones is to be transmitted from the east. As the result, the supply system as shown in Fig. 2 is proposed.

Dimension of the transmission facilities are selected as the most advantageous combination of pipe size and pump facilities based on the present worth analysis and taking into consideration of initial cost. The summary of the facilities is presented in Table 1.

Table 1 Summary of Transmission Facilities
for the Second Stage Project

1) Buaran - R1	
a. Transmission Pipe	∅1,500mm x L3.4km, ∅1,650mm x L12.9km
b. Junction Well	D 13 m x H 6.0 m (RC made)
c. Transmission Pump	Q45m ³ /min x H24m x 250kW x 6 units
2) Cakung - R 1	
a. Transmission Pipe	∅ 1,000 mm x L 1.8 km (up to J.Well)
b. Transmission Pump	Q23m ³ /min x H19m x 100kW x 6 units
3) Cakung - R 2	
a. Transmission Pipe	∅ 1,500 mm x L 13.5 km
b. Transmission Pump	Q52m ³ /min x H42m x 480kW x 6 units
4) R 2 - R 3	
a. Transmission Pipe	∅ 1,500 mm x L 6.8 km
b. Transmission Pump	Q47m ³ /min x H30m x 310kW x 6 units
5) R 3 - Lebakbulus	
a. Transmission Pipe	∅ 1,000 mm x L 7.5 km
b. Transmission Pump	(by gravity)
6) Lebakbulus - R 4	
a. Transmission Pipe	∅ 1,200 mm x L 9.1 km
b. Transmission Pump	(by gravity)

5. Alternatives of Transmission System

Four alternatives are proposed as described in the below and they are illustrated in Fig. 3.

Alternative 1

Raw water from the Canal 1 will be increased to meet water demand of the Supply zones 3 and 6: 3.1 m³/s (Zone 3:1.6 m³/s, Zone 6:1.5 m³/s). Raw water from Canal 3 covers water demand of other supply zones except the supply zones 1 and 2 which are supplied from the Pejompogan and Pulogadung plants. As the result, additional transmission systems are required from Lebakbulus plant to DC.R3, DC.R4, and DC.R5 and from the Cakung plant to DC.R1.

Alternative 2

Raw water from the Canal 1 will be increased to meet water demand for all supply zones without increment of any raw water supply from the Cisadane basin. As the result, additional transmission facilities from Cakung plant to every distribution centers are required.

Alternative 3

Raw water from the Canal 1 will be increased to meet water demand of the supply zones 3 and 6: 3.1 m³/s. Increment of water demand for other supply zones except the supply zones 1 and 2 is transmitted from the Canal 2. As the result, additional transmission facilities from new water treatment plant for DC.R3, Lebakbulus plant, DC. R4, DC.R5 and the Cakung plant to DC.R1 are required. New water treatment plant will be located adjacent to DC.R2.

Alternative 4

No increase of raw water from the Canal 1 is planned while all required increment of raw water for service area comes from the Cisadane river basin through the Canal 3. As the result, additional transmission facilities from the Lebakbulus plant to DC.R3, DC.R4 and DC.R5 and from the Cakung plant to DC.R1 are required.




Fig 3-1 ALTERNATIVE 1
JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA





FIG 3-3 ALTERNATIVE 3

JAKARTA WATER SUPPLY DEVELOPMENT PROJECT JICA



6. Conclusion

The result of the cost comparison shows the system, which receives more water from the Cisadane river basin through the Canal 1, has an advantage as shown in Table 2. Although two alternatives, 1 and 4, indicate the minor difference of present worth, the Alternative 1 is recommended since the cost for the initial investment is about 10 per cent lower than the alternative 4 and the former system will use facilities fully to be constructed in the Second Stage.

Raw water requirement of the proposed system, therefore, is as follows:

- | | |
|-----------------------|--|
| (1) West Tarun Canal: | 6 m ³ /sec (5.6 x 1.07) for the Pejompongan Plants |
| (2) Canal 1: | 18 m ³ /sec (17 x 1.07) for the Pulogadung, Buaran and Cakung Plants |
| (3) Cisadane River: | 3.2 m ³ /sec (3 x 1.07) for the Lebakbulus Plant (the First Phase of the Second Stage) |
| (4) Canal 3: | 6 m ³ /sec (5.1 x 1.07) and 11 m ³ /sec (9.8 x 1.07) for the Lebakbulus Plant (the First Phase and the Second Phase of the Third Stage respectively) |

Table 2 Summary of Cost Comparison (unit: million Rp.)

	<u>Alternative 1</u>	<u>Alternative 2</u>	<u>Alternative 3</u>	<u>Alternative 4</u>
Initial Cost				
1st Phase	30,369	84,335	51,288	3,516
2nd Phase	4,475	6,658	5,177	5,151
Total	34,844	90,993	56,465	40,667
O & M Cost				
1st Phase	2,761	4,709	3,439	2,671
2nd Phase	3,551	7,547	5,057	3,019
Present Worth				
8 % of D.R.	63,584	148,968	96,079	65,571
10 % of D.R.	57,054	135,572	86,986	59,800
12 % of D.R.	52,159	125,590	80,197	55,439

Calculation of the present worth for each alternative is indicated in Table 3 based on the cost estimate as shown in Table 4 and following assumptions:

- (1) Period for construction is two years
- (2) Procurement of materials and equipment is one year ahead of construction
- (3) Total O & M Cost is calculated for 27 years after completion of construction of the First Phase

Breakdown of the cost estimate for each alternative shows in Table 4 and its facilities required is presented in Table 5. Unit costs of materials, equipment and construction works which are used as the basis of the cost estimate are shown in Table 6.

Table 3

Present Worth Analysis

unit : million Rp.

Alternative	Route	Initial Cost	O & M Cost	Present Worth		
				(8%)	(10%)	(12%)
			(Second:1st:2nd)			
Alternative 1	P3/P4-R1	-	797	7551	6130	5073
	P4 - R1	8707	241	9613	9147	8791
	P4 - R2	-	1095	10375	8422	6970
	R2 - R3	186	379:197	2615	2200	1882
	R3 - P5	5987	490:647	11327	10166	9299
	P5 - R4	9158	287	10196	9634	9209
	R4 - R5	10806	287	11907	11355	10935
	TOTAL	34844	-	63584	57054	52159
Alternative 2	P3/P4-R1	-	797	7551	6130	5073
	P4 - R1	8707	241	9613	9147	8791
	P4 - R2	34528	1095:1270:2490	63264	57008	52363
	R2 - R3	16739	714:833:1636	35554	31454	28413
	R3 - P5	11055	-	10883	10844	10806
	P5 - R4	9158	287	10196	9634	9209
	R4 - R5	10806	287	11907	11355	10935
	TOTAL	90993	-	148968	135572	125590
Alternative 3	P3/P4-R1	-	797	7551	6130	5073
	P4 - R1	8707	241	9613	9147	8791
	P4 - R2	-	1095	10375	8422	6970
	R2 - R3	16739	714:833:1636	35554	31454	28413
	R3 - P5	11055	-	10883	10844	10806
	P5 - R4	9158	287	10196	9634	9209
	R4 - R5	10806	287	11907	11355	10935
	TOTAL	56465	-	96079	86986	80197
Alternative 4	P3/P4-R1	-	797	7551	6130	5073
	P4 - R1	8707	241	9613	9147	8791
	P4 - R2	88	113:64	3572	3206	2897
	R2 - R3	-	278: -	952	871	799
	R3 - P5	11908	683:1343	21780	19457	17735
	P5 - R4	9158	287	10196	9634	9209
	R4 - R5	10806	287	11907	11355	10935
	TOTAL	40667	-	65571	59800	55439

Table 4-1 Summary of Cost Estimate (Alternative 1)

Route	Transmission Pipe		Pump Well		House		Power Receiving		Transmission Pump		Power Substation		Switch Gear		Initial Cost		O & M Cost			
	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	EL	P	M	Cost
P3/P4-R1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(735)	(314)	(28)	(797)
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797
P4 - R1	5463	2125	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	115	-	513	-	70	169	19	91	10	119	13	-	5463	2125	216	17	8	241
P4 - R2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1038	17	40	1095
P4 - R3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1038	17	40	1095
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	336	17	26	379
P4 - R4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	173	17	7	197
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
P4 - R5	2788	1084	-	-	542	-	196	355	40	191	21	250	28	-	3584	2109	455	17	18	490
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	606	17	24	647
P5 - R4	5752	1817	-	-	523	-	85	203	23	110	12	142	16	-	5752	1817	260	17	10	287
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	475	-	523	-	85	203	23	110	12	142	16	-	455	1134	260	17	10	287
P5 - R5	7044	2475	-	-	523	-	85	203	23	110	12	142	16	-	7044	2475	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	173	-	523	-	85	203	23	110	12	142	16	-	455	832	260	17	10	287
TOTAL	21047	7501	-	-	1559	-	240	828	93	389	43	504	56	-	1721	2754	3288	136	127	3551
1st Phase	-	-	198	-	542	-	196	355	40	191	21	250	28	-	21843	8526	2564	85	112	2761
2nd Phase	-	-	763	-	1559	-	240	828	93	389	43	504	56	-	1721	2754	3288	136	127	3551

Note : () in figure is the cost of Second Stage Project.

Table 4-2 Summary of Cost Estimate (Alternative 2)

Route	Transmission Pipe		Pump Well		Pump House		Power Receiving		Transmission Pump		Power Substation		Switch Gear		Initial Cost		O & M Cost				
	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	P	M	Cost		
P3/P4-R1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(735)	(314)	(28)	(797)	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797	
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797	
P4 - R1	5463	2125	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2nd Phase	-	-	115	-	513	-	70	169	19	91	10	119	13	379	740	2125	-	-	-	8	241
P4 - R2	22476	5272	-	-	675	-	770	1265	141	679	75	889	99	29309	7738	1190	(1038)	(17)	(40)	(1095)	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2nd Phase	-	-	706	-	-	-	-	596	66	319	36	418	46	1333	148	2380	17	63	1270		
P4 - R3	9619	2405	-	-	617	-	905	744	82	399	45	521	58	11283	4274	779	(671)	(17)	(26)	(714)	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2nd Phase	-	-	562	-	-	-	-	475	53	255	28	334	37	1064	118	1558	17	37	833		
P3 - P5	8733	2322	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
P5 - R4	5752	1817	-	-	523	-	85	203	23	110	12	142	16	455	1134	1817	-	-	-	-	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2nd Phase	-	-	475	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
P4 - R5	7044	2475	-	-	523	-	85	203	23	110	12	142	16	455	832	2475	-	-	-	-	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2nd Phase	-	-	173	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
TOTAL	59087	16416	-	-	1292	-	1275	2009	223	1078	120	1410	157	63584	20751	4413	102	194	6709		
1st Phase	-	-	-	-	1559	-	240	1646	184	885	98	1155	128	3686	2972	7118	153	276	7547		
2nd Phase	-	-	763	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		

Note: () in figure is the cost of Second Stage Project.

Table 4-3 Summary of Cost Estimate (Alternative 3)

Route	Transmission Pipe		Pump Well		Pump House		Power Receiving		Transmission Pump		Power Substation		Switch Gear		Initial Cost		EL	P	M	O & M Cost	
	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C					
P3/P4-R1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(735)	(314)	(28)	(797)	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797	
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797	
P4 - R1	5463	2125	-	-	-	-	-	-	-	-	-	-	-	-	-	5463	2125	-	-	-	
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	379	740	216	17	8	241
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
P4 - R2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
R2 - R3	9619	2405	-	-	-	-	-	-	-	-	-	-	-	-	-	11283	4274	(671)	(17)	(26)	(714)
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	11283	4274	779	17	37	833
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1064	118	1598	17	61	1636
R3 - P5	8733	2322	-	-	-	-	-	-	-	-	-	-	-	-	-	8733	2322	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
P5 - R4	5752	1817	-	-	-	-	-	-	-	-	-	-	-	-	-	5752	1817	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	5752	1817	260	17	10	287
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	455	1134	260	17	10	287
R4 - R5	7044	2475	-	-	-	-	-	-	-	-	-	-	-	-	-	7044	2475	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	7044	2475	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	455	832	260	17	10	287
TOTAL	36611	11144	-	-	-	-	-	-	-	-	-	-	-	-	-	38275	13013	3223	85	131	3439
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	38275	13013	3223	85	131	3439
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	2353	2824	4738	136	183	5057

Note: () in figure is the cost of Second Stage Project.

Table 4-4 Summary of Cost Estimate (Alternative 4)

Route	Transmission Pipe		Pump Well		House		Power Receiving		Transmission Pump		Substation		Switch Gear		Initial Cost		P	M	O & M Cost	
	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C	F/C	L/C				
P3/P4-R1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	(735)	(314)	(28)	(797)
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	735	34	28	797
P4 - R1	5463	2125	-	-	513	-	-	-	-	-	-	-	-	-	-	5463	2125	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	5463	2125	-	-	-
2nd Phase	-	-	115	-	-	513	-	70	169	19	91	10	119	13	-	379	740	-	-	-
P4 - R2	-	-	-	-	-	-	-	-	-	35	4	19	2	25	3	-	9	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	9	-	-	856
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	9	-	-	45
P4 - R3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
P5 - R3	6240	1760	-	421	-	589	-	414	569	63	306	34	400	44	7515	5325	638	17	28	683
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	429	48	231	25	301	34	961	107	1276	17	50	1343
P5 - R4	5752	1817	-	475	-	523	-	85	203	23	110	12	142	16	5752	1817	260	17	10	287
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
P5 - R5	7044	2475	-	173	-	523	-	85	203	23	110	12	142	16	7044	2475	260	17	10	287
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TOTAL	24499	8177	-	421	-	589	-	414	569	63	306	34	400	44	25774	9742	2464	85	122	2671
1st Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Note: () in figure is the cost of Second Stage Project.

Table 5-1

Summary of Facilities (Alternative 1)

Route	Transmission Pipe (D x km)	Pump Well (m ³)	Pump House (m ²)	Power Receiving (kVA)	Transmission Pump (QxHxkWxNos)	Power Substation (kVA)	Switch Gear (kW)
P3/P4-R1 (2nd Stage)	1,500x 3.4	1,800	570	1,400	45x24x250x6	2,100	1,500
	1,000x 1.8	900	530	560	23x19x100x6	840	600
	1,650x12.9	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
P4 - R1 (2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,100x14.7	-	-	-	-	-	-
2nd Phase	-	960	540	560	24x18x100x6	560	600
P4 - R2 (2nd Stage)	1,500x13.5	2,070	620	2,690	52x42x480x6	2,690	2,880
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-
R2 - R3 (2nd Stage)	1,500x 6.8	1,890	580	1,740	47x30x310x6	1,740	1,860
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	18x21x82x6	-	-
R3 - P5 (2nd Stage)	1,000x 7.5	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,100x 7.5	1,650	570	1,570	42x30x280x4	1,570	1,120
2nd Phase	-	-	-	-	42x30x280x2	-	560
P5 - R4 (2nd Stage)	1,200x 9.1	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,500x 9.1	-	-	-	-	-	-
2nd Phase	-	3,960	550	680	71x8x120x6	680	720
R4 - R5 (2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,350x13.6	-	-	-	-	-	-
2nd Phase	-	1,440	550	680	36x15x120x6	680	720

Table 5-2

Summary of Facilities (Alternative 2)

Route	Transmission Pipe	Pump Well	Pump House	Power Receiving	Transmission Pump	Power Substation	Switch Gear
	(D x km)	(m ³)	(m ²)	(kVA)	(QxHxkWxNos)	(kVA)	(kW)
P3/P4-R1							
(2nd Stage)	1,500x 3.4	1,800	570	1,400	45x24x250x6	2,100	1,500
	1,000x 1.8	900	530	560	23x19x100x6	840	600
	1,650x12.9	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
P4 - R1							
(2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,100x14.7	-	-	-	-	-	-
2nd Phase	-	960	540	560	24x18x100x6	560	600
P4 - R2							
(2nd Stage)	1,500x13.5	2,070	620	2,690	52x42x480x6	2,690	2,880
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	2,400x13.5	5,880	710	6,160	147x34x1100x3	6,160	3,300
2nd Phase	-	-	-	-	147x34x1100x3	-	3,300
R2 - R3							
(2nd Stage)	1,500x 6.8	1,890	580	1,740	47x30x310x6	1,740	1,860
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	2,200x 6.8	4,680	650	4,040	117x28x720x3	4,040	2,160
2nd Phase	-	-	-	-	117x28x720x3	-	2,160
R3 - P5							
(2nd Stage)	1,000x 7.5	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	2,000x 7.5	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-
P5 - R4							
(2nd Stage)	1,200x 9.1	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,500x 9.1	-	-	-	-	-	-
2nd Phase	-	3,960	550	680	71x8x120x6	680	720
R4 - R5							
(2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,350x13.6	-	-	-	-	-	-
2nd Phase	-	1,440	550	680	36x15x120x6	680	720

Table 5-3 Summary of Facilities (Alternative 3)

Route	Transmission Pipe (D x km)	Pump Well (m3)	Pump House (m2)	Power Receiving (kVA)	Transmission Pump (QxHxkWxNos)	Power Substation (kVA)	Switch Gear (kW)
P3/P4-R1 (2nd Stage)	1,500x 3.4	1,800	570	1,400	45x24x250x6	2,100	1,500
	1,000x 1.8	900	530	560	23x19x100x6	840	600
	1,650x12.9	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
P4 - R1 (2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,100x14.7	-	-	-	-	-	-
2nd Phase	-	960	540	560	24x18x100x6	560	600
P4 - R2 (2nd Stage)	1,500x13.5	2,070	620	2,690	52x42x480x6	2,690	2,880
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-
R2 - R3 (2nd Stage)	1,500x 6.8	1,890	580	1,740	47x30x310x6	1,740	1,860
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	2,200x 6.8	4,680	650	4,040	117x28x720x3	4,040	2,160
2nd Phase	-	-	-	-	117x28x720x3	-	2,160
R3 - P5 (2nd Stage)	1,000x 7.5	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	2,000x 7.5	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-
P5 - R4 (2nd Stage)	1,200x 9.1	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,500x 9.1	-	-	-	-	-	-
2nd Phase	-	3,960	550	680	71x8x120x6	680	720
R4 - R5 (2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,350x13.6	-	-	-	-	-	-
2nd Phase	-	1,440	550	680	36x15x120x6	680	720

Table 5-4

Summary of Facilities (Alternative 4)

Route	Transmission Pipe (D x km)	Pump Well (m ³)	Pump House (m ²)	Power Receiving (kVA)	Transmission Pump (QxHxkWxNos)	Power Substation (kVA)	Switch Gear (kW)
P3/P4-R1 (2nd Stage)	1,500x 3.4	1,800	570	1,400	45x24x250x6	2,100	1,500
	1,000x 1.8	900	530	560	23x19x100x6	840	600
(3rd Stage)	1,650x12.9	-	-	-	-	-	-
P4 - R1 (2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,100x14.7	-	-	-	-	-	-
2nd Phase	-	960	540	560	24x18x100x6	560	600
P4 - R2 (2nd Stage)	1,500x13.5	2,070	620	2,690	52x42x480x6	2,690	2,880
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-
2nd Phase	-	-	-	120	5.3x18x21x6	120	130
R2 - R3 (2nd Stage)	1,500x 6.8	1,890	580	1,740	47x30x310x6	1,740	1,860
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	-	-	-	-	-	-	-
2nd Phase	-	-	-	-	-	-	-
R3 - P5 (2nd Stage)	1,000x 7.5	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,650x 7.5	3,720	620	3,310	88x30x590x3	3,310	1,770
2nd Phase	-	-	-	-	88x30x590x3	-	1,770
P5 - R4 (2nd Stage)	1,200x 9.1	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,500x 9.1	-	-	-	-	-	-
2nd Phase	-	3,960	550	680	71x8x120x6	680	720
R4 - R5 (2nd Stage)	-	-	-	-	-	-	-
(3rd Stage)	-	-	-	-	-	-	-
1st Phase	1,350x13.6	-	-	-	-	-	-
2nd Phase	-	1,440	550	680	36x15x120x6	680	720

Table 6 Unit Cost Used for Cost Estimated

			Unit: 1,000 Rupiah
Item	Unit	Unit Cost	
<u>Initial Cost</u>			
Transmission Pipe			
Ø 700	m	264.4	
Ø 800	m	314.8	
Ø 900	m	375.5	
Ø 1,000	m	446.4	
Ø 1,100	m	516.2	
Ø 1,200	m	576.7	
Ø 1,350	m	699.6	
Ø 1,500	m	831.8	
Ø 1,650	m	1,066.7	
Ø 1,800	m	1,234.1	
Ø 2,000	m	1,474.0	
Ø 2,200	m	1,768.3	
Ø 2,400	m	2,055.4	
Pump Well	m ³	120.0	
Pump House	m ²	950.0	
Power Receiving	kVA	125.0	
Transmission Pump	kW	313.0	
Power Substation	kVA	180.0	
Switch Gear and Instrumentation	kW	220.0	
<u>Operation and Maintenance Cost</u>			
Electricity	kWH	71.0	
Personal	L.S	17,000.0	
Maintenance 1)	%	2.0	

1) For mechanical and electrical equipment