

Annex 3-1 (i) Break-up of Population Growth in W. Sumatra Province

Name of Kodya./Kab	Year	1983 Dec.		Total	Growth Rate by Natural Growth (%)	Total Growth Rate (%)
	1971 Sep.	Nos. of Population by Natural Growth	Nos. of Population by Transmigration			
Kodya. Padang	196,339	509,670	-	509,670	8.27	8.27
Kodya. Bukittinggi	63,132	71,947	-	71,947	1.10	1.10
Kodya. Padang Panjang	30,711	34,660	-	34,660	1.01	1.01
Kodya. Sawahlunto	12,427	14,553	-	14,553	1.32	1.32
Kodya. Payakumbuh	63,388	83,557	-	83,557	2.33	2.33
Kodya. Solok	24,771	33,274	-	33,274	2.49	2.49
Kab. Pasir Selatan	253,606	332,547	9,000	341,547	2.28	2.51
Kab. Solok	295,398	372,351	-	372,351	1.95	1.95
Kab. Sawahlunto/Sijunjung	161,227	219,388	40,000	259,388	2.60	4.04
Kab. Tanan Datar	291,591	338,476	-	338,476	1.25	1.25
Kab. Padang Pariaman	442,649	498,392	-	498,392	0.99	0.99
Kab. Agaz	347,044	401,302	-	401,302	1.22	1.22
Kab. 50 Kota	224,056	288,926	-	288,926	2.14	2.14
Kab. Pasaman	274,256	389,370	2,250	391,620	2.96	3.01
Total	2,793,196	3,588,413	51,250	3,639,663	2.11	2.23

Source: Biro Pusat Statistik (1980) and Dalam Angka (1983)

Annex 3-1 (2) Break-up of Population Growth in Riau Province

Name of Kodya./Kab.	Year	1983 Dec.		Total	Growth Rate by Natural Growth (%)	Total Growth Rate (%)
	1971 Sep.	Nos. of Population by Natural Growth	Nos. of Population by Transmigration			
Kodya. Pekanbaru	145,030	195,068	-	195,068	2.50	2.50
Kab. Kampar	258,692	374,728	81,333	456,061	2.89	4.84
Kab. Indragiri Hulu	197,156	240,099	32,728	272,827	1.53	2.74
Kab. Indragiri Hilir	286,028	402,345	15,030	417,375	2.66	3.20
Kab. Bengkalis	423,503	604,090	36,286	640,376	2.77	3.51
Kab. Kep. Riau	331,136	-	-	446,201	-	2.52
Total	1,641,545	-	-	2,427,908	-	3.32
	(1,310,409)	(1,816,330)	(165,377)	(1,981,707)	(2.64)	(3.51)

() figure does not include island.

Source: Biro Pusat Statistik (1980) and Dalam Angka (1984)

Annex 3-2 (1) Test of Significant Difference of Load Characteristics between
Holidays and Week Days in July 1984 in Padang

(Unit: MW, MWh)

Time	July 1984									
	15 (Sun.) x_1	18 (Wed.) y_1	x_1^2	y_1^2	$x_1 y_1$	${}_3\bar{x}_1$	${}_3\bar{y}_1$	${}_3\bar{x}_1^2$	${}_3\bar{y}_1^2$	${}_3\bar{x}_1 {}_3\bar{y}_1$
1	22.1	29.6	488.4	876.2	654.2					
2	18.8	29.3	353.4	858.5	550.8	17.1	29.5	292.4	870.3	504.5
3	10.5	29.5	110.3	870.3	309.8					
4	14.8	29.4	219.0	864.4	435.1					
5	20.0	26.0	400.0	676.0	520.0	19.6	29.5	384.2	870.3	578.2
6	24.1	33.1	580.8	1095.6	797.7					
7	22.2	25.8	492.8	665.6	572.8					
8	20.3	15.9	412.1	252.8	322.8	21.3	18.7	453.7	349.7	398.3
9	21.3	14.5	453.7	210.3	308.9					
10	21.2	17.5	449.4	306.3	371.0					
11	21.0	15.2	441.0	231.0	319.2	20.7	16.7	428.5	278.9	345.7
12	20.0	17.3	400.0	299.3	346.0					
13	19.4	16.9	376.4	285.6	327.9					
14	19.1	17.3	364.8	299.3	330.4	18.8	17.1	353.4	292.4	321.5
15	18.0	17.2	324.0	295.8	309.6					
16	22.0	16.0	484.0	256.0	352.0					
17	28.0	19.2	784.0	368.6	691.6	26.5	20.0	702.3	400.0	530.0
18	29.5	24.7	870.3	610.1	728.7					
19	32.8	28.7	1075.8	823.7	941.4					
20	35.8	31.7	1281.6	1004.9	1134.9	36.2	31.9	1310.4	1017.6	1154.8
21	40.0	35.4	1600.0	1253.2	1416.0					
22	31.4	32.5	986.0	1056.3	1020.5					
23	27.6	29.2	761.8	852.6	805.9	28.5	29.5	812.3	870.3	840.8
24	26.4	26.8	697.0	718.2	707.5					
Σ	566.3	578.7	14406.6	15030.6	14274.7	188.7	192.9	4737.1	4949.4	4673.7
\bar{X}	23.6	24.1	600.3	626.3	594.8	23.6	24.1	592.1	618.7	584.2

Note: ${}_3\bar{x}_1$ and ${}_3\bar{y}_1$ refer respectively to means per every three hours of x_1 and y_1 .

- 1) Unbiased estimate of variances between Sunday and week days

$$V_1 = \frac{14406.6 - 566.3^2/24}{24 - 1} = 45.40, \quad V_2 = \frac{15030.6 - 578.7^2/24}{24 - 1} = 46.81$$

$$F = \frac{V_2}{V_1} = 1.03 \quad F_{23}^{23} (0.05) = 2.00 > F$$

Therefore, there is no difference in the variances.

- 2) Unbiased estimate of variances on combined data of Sunday and week days

$$V = \frac{14406.6 - 24 (23.6)^2 + 15030.6 - 24 (24.1)^2}{23 + 23}$$

$$= \frac{1039.6 + 1091.2}{46} = 46.32$$

$$\sigma_e = \sqrt{46.32} = 6.81$$

$$t = \frac{24.1 - 23.6}{6.81 \sqrt{\frac{1}{24} + \frac{1}{24}}} = 0.254 \quad t_{0.05} (\phi = 46) = 2.021 > t$$

Therefore, there is no difference in the means.

- 3) Correlation in fluctuation on Sunday and week days

$$r = \frac{8 \times 4673.7 - 188.7 \times 192.9}{\sqrt{8 \times 4737.1 - 188.7^2} \sqrt{8 \times 4949.4 - 192.9^2}} = \frac{989.4}{47.84 \times 48.83} = 0.424$$

$$t = \frac{0.424}{\sqrt{1 - 0.424^2}} \sqrt{8 - 2} = 0.468 \times 2.45 = 1.146$$

$$t_{0.05} (\phi = 6) = 2.447 > t$$

$$t_{0.01} (\phi = 6) = 3.707 > t$$

Therefore, there cannot be said to be any correlation.

Annex 3-2 (2) Test of Significant Difference in Load Characteristics on Holidays
and Week Days in Dec. 1984 in Padang

(Unit: MW, MWh)

Time	Dec. 1984									
	16 (Sun.)	19 (Wed.)	x_2^2	y_2^2	x_2y_2	${}_3\bar{x}_2$	${}_3\bar{y}_2$	${}_3\bar{x}_2^2$	${}_3\bar{y}_2^2$	${}_3\bar{x}_2 {}_3\bar{y}_2$
	x_2	y_2								
1	31.1	31.2	967.2	973.4	970.3					
2	25.7	30.5	660.5	930.3	783.9	27.7	30.6	767.3	936.4	847.6
3	26.2	30.2	686.4	912.0	791.2					
4	26.2	29.9	686.4	894.0	783.4					
5	27.0	30.6	729.0	936.4	826.2	27.4	31.0	750.8	961.0	849.0
6	29.0	32.6	841.0	1062.8	945.4					
7	26.5	29.6	702.3	876.2	784.4					
8	26.0	27.4	676.0	750.8	712.4	27.1	25.7	734.4	660.5	696.5
9	28.8	20.0	829.4	400.0	576.0					
10	23.0	19.8	529.0	392.0	455.4					
11	20.0	19.5	400.0	380.3	390.0	22.9	18.7	524.4	349.7	428.2
12	25.7	16.7	660.5	278.9	429.2					
13	24.3	23.0	590.5	529.0	558.9					
14	26.5	23.5	702.3	552.3	622.8	24.6	22.5	605.2	506.3	553.5
15	23.0	21.1	529.0	445.2	485.3					
16	22.4	23.3	501.8	542.9	521.9					
17	30.2	25.8	912.0	665.6	779.2	29.1	27.2	846.8	739.8	791.5
18	34.7	32.4	1204.1	1049.8	1124.3					
19	41.7	38.3	1738.9	1466.9	1597.1					
20	41.8	33.8	1747.2	1142.4	1412.8	41.3	36.0	1705.7	1296.0	1486.8
21	40.4	35.8	1632.2	1281.6	1446.3					
22	33.2	33.3	1102.2	1108.9	1105.6					
23	29.1	29.0	846.8	841.0	843.9	30.6	29.9	936.4	894.0	914.9
24	-29.5	27.5	870.3	756.3	811.3					
Σ	692.0	664.8	20700.2	19168.8	19757.1	230.7	221.6	6870.9	6343.6	6568.5
$\bar{\Sigma}$	28.8	27.7	862.5	798.7	823.2	28.8	27.7	858.9	793.0	821.1

- 1) Unbiased estimate of variances between Sunday and week days

$$V_1 = \frac{20700.2 - 692.0^2/24}{24 - 1} = 32.50, \quad V_2 = \frac{19168.8 - 664.8^2/24}{24 - 1} = 32.78$$

$$F = V_2/V_1 = 1.01 \quad F_{23}^{23} (0.05) = 2.00 > F$$

Therefore, there is no difference in the variances.

- 2) Unbiased estimate of variances on combined data of Sunday and week days

$$V = \frac{20700.2 - 24(28.8)^2 + 19168.8 - 24(27.7)^2}{46}$$

$$= \frac{793.6 + 753.8}{46} = 33.64$$

$$\sigma_e = \sqrt{33.64} = 5.8$$

$$t = \frac{28.8 - 27.7}{5.8 \sqrt{\frac{1}{24} + \frac{1}{24}}} = 0.657 \quad t_{0.05} (\phi = 46) = 2.021 > t$$

Therefore, there is no difference in the means.

- 3) Correlation in fluctuation on Sunday and week days

$$r = \frac{8 \times 6568.5 - 230.7 \times 221.6}{\sqrt{8 \times 6870.9 - 230.7^2} \sqrt{8 \times 6343.6 - 221.6^2}} = \frac{1424.9}{41.77 \times 40.52} = 0.842$$

$$t = \frac{0.842}{\sqrt{1 - 0.842^2}} \sqrt{8 - 2} = 1.56 \times 2.45 = 3.82$$

$$t_{0.05} (\phi = 6) = 2.447 < t$$

Therefore, there is a correlation.

Annex 3-2 (3) Test of Significant Difference in Load Characteristics on Holiday
and Week Day in March 1985 in Padang

(Unit: MW, MWh)

Time	March 1985									
	17 (Sun.)	20 (Wed.)								
	\bar{x}_3	\bar{y}_3	\bar{x}_3^2	\bar{y}_3^2	$\bar{x}_3\bar{y}_3$	$\bar{3x}_3$	$\bar{3y}_3$	$2\bar{x}_3^2$	$\bar{3y}_3^2$	$\bar{3x}_3 \bar{3y}_3$
1	32.0	31.0	1024.0	961.0	992.0					
2	31.0	31.5	961.0	992.3	976.5	31.3	31.2	979.7	973.4	976.6
3	31.0	31.2	961.0	973.4	967.2					
4	31.5	31.2	992.3	973.4	982.8					
5	31.5	32.0	992.3	1024.0	1008.0	32.3	32.5	1043.3	1056.3	1049.8
6	34.0	34.2	1156.0	1069.6	1162.8					
7	30.3	31.7	918.1	1004.9	960.5					
8	24.5	25.5	600.3	650.3	624.8	28.5	27.3	812.3	745.3	778.1
9	30.7	24.8	942.5	615.0	761.4					
10	29.0	24.9	841.0	620.0	722.1					
11	26.0	24.7	676.0	610.1	642.2	27.8	26.4	772.8	697.0	733.9
12	28.3	29.5	800.9	870.3	834.9					
13	31.5	29.2	992.3	852.6	919.8					
14	27.0	29.5	729.0	870.3	796.5	27.4	28.9	750.8	835.2	791.9
15	23.6	28.0	557.0	784.0	660.8					
16	30.8	28.7	948.6	823.7	884.0					
17	32.5	24.6	1056.3	605.2	799.5	33.3	26.9	1108.9	723.6	895.8
18	36.5	27.5	1332.3	756.3	1003.8					
19	39.7	38.1	1576.1	1451.6	1512.6					
20	40.9	38.8	1672.8	1505.4	1586.9	42.3	38.1	1789.3	1451.6	1611.6
21	46.3	37.5	2143.7	1406.3	1736.3					
22	35.1	34.7	1232.0	1204.1	1218.0					
23	33.2	31.3	1102.2	979.7	1039.2	32.4	31.6	1049.8	998.6	1023.8
24	28.8	28.7	829.4	823.7	826.6					
Σ	765.7	728.8	25036.9	22527.1	23618.8	255.3	242.9	8306.8	7480.9	7861.4
$\bar{\Sigma}$	31.9	30.4	1043.2	938.6	984.1	31.9	30.4	1038.3	935.1	982.7

1) Unbiased estimate of variances between Sunday and week days

$$v_1 = \frac{25036.9 - 765.7^2/24}{24 - 1} = 26.43, \quad v_2 = \frac{22527.1 - 728.8^2/24}{24 - 1} = 17.21$$

$$F = v_1/v_2 = 1.536 \quad F_{23}^{23}(0.05) = 2.00 > F$$

Therefore, there is no difference in the variances.

2) Unbiased estimate of variances on combined data of Sunday and week days

$$v = \frac{25036.9 - 24(31.9)^2 + 22527.1 - 24(30.4)^2}{23 + 23}$$

$$= \frac{614.3 + 347.3}{46} = 20.90$$

$$\sigma_e = \sqrt{20.90} = 4.57$$

$$t = \frac{31.9 - 30.4}{4.57\sqrt{\frac{1}{24} + \frac{1}{24}}} = 1.137 \quad t_{0.05}(\phi = 46) = 2.021 > t$$

Therefore, there is no difference in the means.

3) Correlation in fluctuation on Sunday and week days

$$r = \frac{3^x 3^y}{3^x 3^y} = \frac{8 \times 7861.4 - 255.3 \times 242.9}{\sqrt{8 \times 8306.8 - 255.3^2} \sqrt{8 \times 7480.9 - 242.9^2}} = \frac{878.8}{35.73 \times 29.10} = 0.845$$

$$t = \frac{0.845}{\sqrt{1 - 0.845^2}} = \sqrt{8-2} = 3.871$$

$$t_{0.05}(\phi = 6) = 2.447 < t$$

Therefore, there is a correlation.

Annex 3-3 Test of Significant Difference of Load Characteristics in Dec. 1982
and April 1985 in Pekanbaru

(Unit: MW, MWh)

Time	April 17 (Wed.) 1985		Dec. 20 (Sun.) 1982		x_1^2	x_2^2	${}_3\bar{x}_1^2$	${}_3\bar{x}_2^2$	${}_3\bar{x}_1 {}_3\bar{x}_2$
	x_1	${}_3\bar{x}_1$	x_2	${}_3\bar{x}_2$					
1	5.8		4.5		33.6	20.3			
2	5.7	5.7	4.2	4.3	32.5	17.6	32.5	18.5	24.5
3	5.6		4.1		31.4	16.8			
4	5.6		4.2		31.4	17.6			
5	6.1	6.1	4.5	4.6	37.2	20.3	37.2	21.2	28.1
6	6.7		5.0		44.9	25.0			
7	6.0		4.7		36.0	22.1			
8	5.0	5.2	4.0	4.3	25.0	16.0	27.0	18.5	22.4
9	4.6		4.2		21.2	17.6			
10	5.2		4.3		27.0	18.5			
11	5.9	5.1	4.2	4.3	24.0	19.6	26.0	18.5	21.9
12	5.3		4.3		28.1	18.5			
13	5.2		4.4		27.0	19.4			
14	5.4	5.3	5.0	4.8	29.2	25.0	28.1	23.0	25.4
15	5.4		5.1		29.2	26.0			
16	5.2		4.5		27.0	20.3			
17	4.8	5.2	3.8	4.5	23.0	14.4	27.0	20.3	23.4
18	5.7		5.3		32.5	28.1			
19	8.5		6.5		72.3	42.3			
20	10.1	9.5	7.9	7.4	102.0	62.4	90.3	54.8	70.3
21	9.8		7.9		96.0	62.4			
22	9.5		7.5		90.3	56.3			
23	9.0	9.0	6.6	6.6	81.0	43.6	81.0	43.6	59.4
24	8.5		5.6		72.3	31.4			
Σ		51.1		40.8	1054.1	659.5	349.1	218.4	275.4
$\bar{\Sigma}$		6.4		5.1	43.9	27.5	43.6	27.3	34.4

- 1) Unbiased estimate of variances when the data in 1985 and 1982 are combined

$$v = \frac{1054.1 - 24(6.4)^2 + 659.5 - 24(5.1)^2}{46} = 2.31$$

$$\sigma_e = \sqrt{2.31} = 1.52$$

$$t = \frac{6.4 - 5.1}{1.52 \sqrt{\frac{1}{24} + \frac{1}{24}}} = 2.963$$

$$t_{0.05}(\phi = 46) = 2.021 < t$$

Therefore, there cannot be said to be no difference in the means. In this case, the means in 1985 is larger.

- 2) Correlation of fluctuation between \bar{x}_1 and \bar{x}_2

$$r_{\bar{x}_1 \bar{x}_2} = \frac{8 \times 275.4 - 51.1 \times 40.8}{\sqrt{8 \times 349.1 - 51.1^2} \sqrt{8 \times 218.4 - 40.8^2}} = \frac{118.32}{13.48 \times 9.09}$$

$$= 0.966$$

$$t = \frac{0.966}{\sqrt{1 - 0.966^2}} \sqrt{8 - 2} = 3.736 \times 2.45 = 9.15$$

$$t_{0.05}(\phi = 6) = 2.447 < t$$

$$t_{0.01}(\phi = 6) = 3.707 < t$$

Therefore there is a substantial correlation.

Annex 3-4 Test of the Difference of Daily Energy Consumption between July and December 1984 and March 1985 in Padang

	Daily energy consumption (MWh)							
	1984		1985					
	July	Dec.	March					
	a_1	a_2	a_3		a_1^2	a_2^2	a_3^2	
Sunday Σx	566.3	692.0	765.7		320695.7	478864.0	586296.5	
Week day Σy	578.7	664.8	728.8	Total ₁	334893.7	441959.0	531149.4	Total ₂
Total Σ	1145.0	1356.8	1494.5	3996.3	655589.4	920823.0	1117445.9	2693858
n	2	2	2	6				
\bar{x}	572.5	678.4	747.3	\bar{N}				

$$\text{Total variance } \square = \sum \sum xy_{ij}^2 - \frac{(\text{Total}_1)^2}{N} = 2693858 - \frac{15970414}{6} = 32122$$

$$\begin{aligned} \text{Among-class variance } \Delta &= \frac{(\Sigma a_1)^2}{n} + \frac{(\Sigma a_2)^2}{n} + \frac{(\Sigma a_3)^2}{n} - \frac{(\text{Total}_1)^2}{N} \\ &= 655513 + 920453 + 1116765 - 2661736 = 30995 \end{aligned}$$

$$\text{Interclass variance } \otimes = \square - \Delta = 32122 - 30995 = 1127$$

Variance Matrix

Factors		Fluctuation	Freedom	Unbiased variance	Variance ratio, F_0
Among-class	Δ	30,995	3-1=2	15,498	41.2
Interclass	\otimes	1,127	6-3=3	376	
Total	\square	32,122	6-1=5		

$$F_3^2(0.01) = 30.81 < F_0$$

Since the daily energy consumption varies extensively in each month, the values cannot be recognized as those in the same population. Therefore the energy demand in each month should be handled individually. Here, the value is assumed to increase successively toward the end of fiscal year.

Annex 3-5 Estimation of Daily Average Power Consumption in April 1984 according to Linear Regression


$$y = \bar{\alpha} x + \bar{\beta}$$

$$\bar{\alpha} = \left(\frac{\sum_{i=1}^n x_i y_i - n \bar{x}_i \bar{y}_i}{\sum_{i=1}^n x_i^2 - n \bar{x}_i^2} \right)$$

$$\bar{\beta} = \left(\frac{\sum_{i=1}^n y_i - \bar{y}_i \sum_{i=1}^n x_i}{\sum_{i=1}^n x_i^2 - n \bar{x}_i^2} \right)$$

Unit: MWh

Calendar month	Coordinate month x	Daily average (Sun. + Wed.)/2, y	x ²	y ²	xy
7	4	572.5	16	327956.3	2270.0
12	9	678.4	81	460226.6	6105.6
3	12	747.3	144	558457.3	8967.6
Σ	25	1998.2	241	1346440.1	17363.2
$\bar{\Sigma}$	8.33	666.07	80.33	448813.4	5787.7



$$\bar{\alpha} = (17363.2 - 3 \times 8.33^2 \times 666.07) / (241 - 3 \times 8.33^2)$$

$$= 712.2 / 32.7 = 21.79$$

$$\bar{\beta} = (666.1 \times 241 - 8.33 \times 17363.2) / 32.83$$

$$= 15894.6 / 32.83 = 484.1$$

$$y = 21.79x + 484.1$$

$$\text{at } x = 1 : y = 506.0 \text{ MWh}$$

Annex 3-6 Regression Analysis

Unit : MWh				
	x	y	x ²	y ²
	4	572.5	16	327,756.3
	9	678.4	81	460,226.6
	12	747.3	144	558,457.3
Σ	25	1,998.2	24	1,346,440.1
Σ	8.33	666.07	80.33	448,813.4

o Total variance $\square = 32,122$ (From Annex 3-4)

o Among class variance $\Delta = 30,995$ (Same as above)

o Interclass variance $\otimes = \square - \Delta = 1,127$ (Same as above)

o Variance based on regression $S_R = b^2 (\sum x_i^2 - nx_i^2)$
 $= (21.79)^2 (241 - 3 \times 8.33^2) = 15,589$

o Variance from regression $S_E = \Delta - S_R = 15,406$

Variance Matrix

Factors		Fluctuation	Freedom	Unbiased variance	Variance ratio, Fo	F ₁ ¹ (0.05) F ₁ ² (0.01)
Based on regression	S _R	15,589	1	15,589		10.13
Around regression	S _E	15,406	3 - 2 = 1	15,406	15,406/376 = 41	34.12
Among-class	Δ	30,995	3 - 1 = 2	15,498		
Interclass	⊗	1,127	6 - 3 = 3	376		
Total	□	32,122	6 - 3 = 3			

$$F_o > F_{\frac{1}{3}} (0.01)$$

The difference is highly significant. This fact proves that the data are small in dispersion, and y, namely, the demand grows linearly followed by the change of x along with elapse of months.

Annex 3-7 (1) Example of Preparing Totalized Load Curves: Demand Forecast and Load Curves in Fiscal Year 19xx

Consumer type	Sold energy (GWh)	Daily sales energy (MWh)		Sending and energy (MWh)		Loss ratio, %
		Week day	Holiday	Week day	Holiday	
Residential	178.1	487.9	487.9	587.8	587.8	17
Commercial	46.6	B 130.2	A 117.2	156.9	141.2	17
Public	43.5	B 121.6	A 109.4	146.5	131.8	17
Small Ind.	164.8	D ₁ 479.9	C ₁ 335.9	578.2	404.7	17
Medium Ind.	70.6	D ₂ 205.6	C ₂ 143.9	247.7	173.4	17
(Industry total)	(235.4)					
Cement	179.0	490.4	490.4	505.6	505.6	3
PERTAMINA	-	-	-	-	-	-
Sub total		1915.6	1684.7	2222.7	1924.5	
Yearly total	682.6	682.6 GWh		π 791.3 GWh		

Note: π is explained later. (Annex 3-13)

- Conditions 1. Out of 365 days in one year, 293 and 72 days are assumed to be week days and holidays, respectively.
2. The ratio of sold energy on holidays (A) to that on week days (B) for commercial and public consumers is assumed at 0.9: 1.0.
- Therefore,

$$\frac{\text{Commercial: } 46.5}{\text{Public: } 43.5} \text{ GWh} = 72 A + 293 B$$

$$\frac{A}{B} = 0.9$$

$$\therefore B = \frac{\text{Commercial or Public}}{357.8} = \frac{130.2}{121.6} \text{ MWh}$$

$$A = \text{Above} \times 0.9 = 109.4 \text{ MWh}$$

3. The industrial demand is a total of small and medium industry demand with the ratio being:

$$\frac{m}{0.7} : \frac{n}{0.3}$$

a. Small industry = 164.8 GWh, Medium industry = 70.6 GWh

b. Holiday : Week day for industrial = 0.7: 1.0

$$\frac{C}{D}$$

$$\text{Small or medium industry demand, GWh} = 72 C + 293 D$$

$$\frac{C}{D} = 0.7$$

$$\therefore D_1 = \frac{\text{Small ind.}}{343.4} = 479.9 \text{ MWh} \quad D_2 = \frac{\text{Medium ind.}}{343.4} = 205.6 \text{ MWh}$$

$$C_1 = 0.7 \times D_1 = 335.9$$

$$C_2 = 0.7 \times D_2 = 143.9$$

Annex 3-7 (2) Calculation Chart for Load Curves

(Unit: MW)

Allocation ratio		430	600	560	590	600	690	690	Total
Type	Time zone	Residen- tial	Commer- cial	Public	Small Ind.	Medium Ind.	Cement	PERTAMINA	
Week day	1	22.8	4.4	6.1	16.3	6.7	22.0	-	78.3
	2	27.3	4.4	6.1	16.3	6.7	22.0	-	82.8
	3	18.2	7.0	5.2	26.1	12.0	19.5	-	88.0
	4	13.7	8.7	5.2	32.7	13.3	19.5	-	93.1
	5	13.7	7.8	4.4	31.0	12.7	19.5	-	89.1
	6	18.2	8.7	7.0	32.7	13.3	19.5	-	99.4
	7	45.6	7.0	8.7	21.2	11.3	24.4	-	118.2
	8	36.5	4.4	6.1	16.3	6.7	22.0	-	92.0
x 3 =		196.0	52.4	48.8	192.6	82.7	168.4	-	740.9
		588.0	157.2	146.4	577.8	248.1	505.2	-	2222.7 ← For check
Holiday	1	22.8	3.9	5.5	11.4	4.7	22.0	-	70.3
	2	27.3	3.9	5.5	11.4	4.7	22.0	-	74.8
	3	18.2	6.3	4.7	18.3	8.4	19.5	-	75.4
	4	13.7	7.8	4.7	22.9	9.3	19.5	-	77.9
	5	13.7	7.1	3.9	21.7	8.9	19.5	-	74.8
	6	18.2	7.8	6.3	22.9	9.3	19.5	-	84.0
	7	45.6	6.3	7.8	14.9	7.9	24.4	-	106.9
	8	36.5	3.9	5.5	11.4	4.7	22.0	-	84.0
x 3		196.0	47.0	43.9	134.9	57.9	168.4	-	648.1
		588.0	141.0	131.7	404.7	173.7	505.2	-	1944.5 ← For check

Calculation formula: $\frac{\text{Sending end daily energy}}{\text{Allocation ratio} \times 3} \times \text{Time zone allocation ratio}$

(Refer to Table 3.7-1)

Annex 3-8 (1) Estimation of Load Curves and Test of Goodness of Fit in Padang in 1984

Consumer type	Sold energy (GWh)	Daily sold energy (MWh)		Sending and energy (MWh)		Loss ratio, %
		Week day	Holiday	Week day	Holiday	
Residential	33.32	91.29	91.29	121.7	121.7	25
Commercial	5.15	B 14.39	A 12.95	19.2	17.3	"
Public	14.27	B 39.88	A 35.89	53.2	47.9	"
Small Ind.	11.29	D ₁ 32.88	C ₁ 23.01	43.8	30.7	"
Medium Ind.	1.25	D ₂ 3.64	C ₂ 2.55	4.9	3.4	"
(Industry total)	(12.54)					
Cement	87.16	238.8	238.8	280.9	280.9	15
PERTAMINA	-	-	-	-	-	-
Sub total		420.88	404.49	523.7	501.9	
Yearly total	152.44	152.44 GWh		189.58 GWh		

- Conditions 1. Out of 365 days in one year, 293 and 72 days are assumed to be week days and holidays, respectively.
2. The ratio of sold energy on holidays (A) to that on week days (B) for commercial and public consumers is assumed at 0.9: 1.0.
- Therefore,

$$\frac{\text{Commercial: } 5.15}{\text{Public: } 14.27} \text{ GWh} = 72 A + 293 B$$

$$\frac{B}{A} = 0.9$$

$$B = \frac{\text{Commercial or public}}{357.8} = \frac{14.39}{39.88} \text{ MWh}$$

$$A = \text{Above} \times 0.9 = \frac{12.95}{35.89} \text{ MWh}$$

3. The industrial demand is a total of small and medium industry demand, with the composition being $\frac{m}{n}$ 0.9: 0.1
- a. Holidays : Week days for industrial = 0.7: 1.0
- $$\frac{C}{D}$$
- b. Small or medium Industry demand GWh = 72 C + 293 D

$$\frac{C}{D} = 0.7$$

$$\therefore D_1 = \frac{\text{Small ind.}}{343.4} = 32.84 \text{ MWh}$$

$$D_2 = \frac{\text{Medium ind.}}{343.4} = 3.64 \text{ MWh}$$

$$C_1 = 0.7 \times D_1 = 23.01$$

$$C_2 = 0.7 \times D_2 = 2.55$$

Annex 3-8 (2) Calculation Chart for Load Curves

(Unit: MW)

Allocation ratio		430	600	560	590	600	690	690	Total
Type	Time zone	Residen- tial	Commer- cial	Public	Small Ind.	Medium Ind.	Cement	PERTAMINA	
Week day	1	4.7	0.5	2.2	1.2	0.1	12.2	-	20.9
	2	5.7	0.5	2.2	1.2	0.1	12.2	-	21.9
	3	3.8	0.9	1.9	2.0	0.2	10.9	-	19.7
	4	2.8	1.1	1.9	2.5	0.3	10.9	-	19.5
	5	2.8	1.0	1.6	2.4	0.3	10.9	-	19.0
	6	3.8	1.1	2.5	2.5	0.3	10.9	-	21.1
	7	9.4	0.9	3.2	1.6	0.2	13.6	-	28.9
	8	7.5	0.5	2.2	1.2	0.1	12.2	-	23.8
Σ		40.5	6.5	17.7	14.6	1.6	93.8	-	174.8
$\Sigma \times 3 =$		121.5	19.5	53.1	43.8	4.8	281.4	-	524.1 + For check
Holiday	1	4.7	0.5	2.0	0.9	0.1	12.2	-	20.4
	2	5.7	0.5	2.0	0.9	0.1	12.2	-	21.4
	3	3.8	0.8	1.7	1.4	0.2	10.9	-	18.8
	4	2.8	1.0	1.7	1.7	0.2	10.9	-	18.3
	5	2.8	0.9	1.4	1.6	0.2	10.9	-	17.8
	6	3.8	1.0	2.3	1.7	0.2	10.9	-	19.9
	7	9.4	0.8	2.9	1.1	0.2	13.6	-	28.0
	8	7.5	0.5	2.0	0.9	0.1	12.2	-	23.2
Σ		40.5	6.0	16.0	10.2	1.3	93.8	-	167.8
$\Sigma \times 3 =$		121.5	18.0	48.0	30.6	3.9	281.4	-	503.4 + For check

Annex 3-8 (3)

Test of Goodness of Fit in Padang

(Unit: MW)

	July 18, 1984		$\frac{(y_1 - z_1)^2}{z_1}$	Dec. 19, 1984		$\frac{(y_2 - z_2)^2}{z_2}$	Mar. 20, 1985		$\frac{(y_3 - z_3)^2}{z_3}$
	y_1	z_1 , estimated		y_2	z_2 , estimated		y_3	z_3 , estimated	
1	29.5	23.1	1.773	30.6	27.6	0.326	31.2	29.0	0.167
2	29.5	24.2	1.161	31.0	28.9	0.153	32.5	30.4	0.145
3	18.7	21.7	0.415	25.7	26.0	0.003	27.3	27.4	0.000
4	16.7	21.5	1.072	18.7	25.7	1.907	26.4	27.1	0.018
5	17.1	21.0	0.724	22.5	25.1	0.269	28.9	26.4	0.237
6	20.0	23.3	0.467	27.2	27.8	0.013	26.9	29.3	0.197
7	31.9	31.9	0	36.0	38.1	0.116	38.1	40.2	0.110
8	29.5	26.3	0.389	29.0	31.4	0.183	31.6	33.1	0.068
Σ	192.9	192.9	6.001	230.7	230.7	2.865	242.9	242.9	0.942
			χ^2_1			χ^2_2			χ^2_3

The estimated values were compared with actual energy consumption in the respective time zones so that the daily energy consumption in the load curves obtained in the previous table would match the actual daily energy consumption. Since only the total consumption is affected by the actual values, χ^2 -test of $n - 1 = 8 - 1 = 7$ was carried out with respect to the freedom.

Regarding the week day in July 1984,

$$\chi^2_1 < \chi^2_{\phi=7}(0.50) = 6.346$$

Therefore, the estimated values have a goodness of fit with the actual values.

Similarly regarding the week day in Dec. 1984,

$$\chi^2_2 < \chi^2_{\phi=7}(0.80) = 3.822$$

Also, the estimated values comply nearly perfectly with the actual values.

Regarding the week days in March 1985, moreover,

$$\chi^2_3 < \chi^2_{\phi=7}(0.99) = 1.239$$

Therefore, the estimated values also comply entirely with the actual values.

Annex 3-9 (1) Estimation of Load Curves and Check of their Applicability in Pekanbaru in 1984

Consumer type	Sold energy (GWh)	Daily sold energy (MWh)		Sending end energy (MWh)		Loss ratio, %
		Week day	Holiday	Week day	Holiday	
Residential	22.70	62.19	62.19	82.9	82.9	25
Commercial	5.66	B 15.82	A 14.24	21.1	19.0	"
Public	6.19	B 17.30	A 15.57	23.1	20.8	"
Small Ind.	5.52	D ₁ 16.07	C ₁ 11.25	21.4	15.0	"
Medium Ind.	0.61	D ₂ 1.78	C ₂ 1.24	2.4	1.7	"
(Industry total)	(6.13)					
Cement	-	-	-	-	-	
PERTAMINA	-	-	-	-	-	
Sub total		113.16	104.49	150.9	139.4	
Yearly total	40.68	40.68 GWh		54.25 GWh		

- Conditions
1. Out of 365 days in one year, 293 and 72 days are assumed to be week days and holidays, respectively.
 2. The ratio of sold energy on holidays (A) to that on week days (B) for commercial and public consumers is assumed at 0.9: 1.0.

Therefore,

$$\frac{\text{Commercial: } 5.66}{\text{Public: } 6.19} \text{ GWh} = 72 A + 293 B$$

$$\frac{A}{B} = 0.9$$

$$B = \frac{\text{Commercial or public}}{357.8} = \frac{15.82}{17.30} \text{ MWh}$$

$$A = \text{Above} \times 0.9 = \frac{14.24}{15.57} \text{ MWh}$$

3. The industrial demand is a total of small and medium industry demand, with the composition being $\frac{m}{m} 0.9 : 0.1$

a. Small ind. = 5.52 GWh, Medium ind. = 0.61 GWh

b. Holiday : Week day for industry = $\frac{C}{D} 0.7 : 1.0$

$$\text{Small or medium ind., GWh} = 72 C + 293 D$$

$$\frac{C}{D} = 0.7$$

$$D_1 = \frac{\text{Small ind.}}{343.4} = 16.07 \text{ MWh}$$

$$D_2 = \frac{\text{Medium ind.}}{343.4} = 1.98 \text{ MWh}$$

$$C_1 = 0.7 \times D_1 = 11.25$$

$$C_2 = 0.7 \times D_2 = 1.24$$

Annex 3-9 (2) Calculation Chart for Load Curves in 1984

(Unit: MW)

Allocation ratio		430	600	560	590	600	690	690	
Type		Residen- tial	Commer- cial	Public	Small Ind.	Medium Ind.	Cement	PERTAMINA	Total
Time zone									
Week day	1	3.2	0.6	1.0	0.6	0.1	-	-	5.5
	2	3.9	0.6	1.0	0.6	0.1	-	-	6.2
	3	2.6	0.9	0.8	1.0	0.1	-	-	5.4
	4	1.9	1.2	0.8	1.2	0.1	-	-	5.4
	5	1.9	1.1	0.7	1.1	0.1	-	-	4.9
	6	2.6	1.2	1.1	1.2	0.1	-	-	6.2
	7	6.4	0.9	1.4	0.8	0.1	-	-	9.6
	8	5.1	0.6	1.0	0.6	0.1	-	-	7.4
Σ		27.6	7.1	7.8	7.1	0.8	-	-	50.6
$\Sigma \times 3 =$		82.8	21.3	23.4	21.3	2.4	-	-	151.8 + For check
Holiday	1	3.2	0.5	0.9	0.4	0.0	-	-	5.0
	2	3.9	0.5	0.9	0.4	0.0	-	-	5.7
	3	2.6	0.8	0.7	0.7	0.1	-	-	4.9
	4	1.9	1.1	0.7	0.8	0.1	-	-	4.6
	5	1.9	0.9	0.6	0.8	0.1	-	-	4.3
	6	2.6	1.1	1.0	0.8	0.1	-	-	5.6
	7	6.4	0.8	1.2	0.6	0.1	-	-	9.1
	8	5.1	0.5	0.9	0.4	0.0	-	-	6.9
Σ		27.6	6.2	6.9	4.9	0.5	-	-	46.1
$\Sigma \times 3 =$		82.8	18.6	20.7	14.7	1.5	-	-	138.3 + For check

Annex 3-9 (3)

Test of Goodness of Fit in Pekanbaru

(Unit: 10^2 kW)

	April 17, 1984		$\frac{(x_1 - z_1)^2}{z}$	Dec. 20, 1982		$\frac{(x_2 - z_2)^2}{z}$
	x_1	z_1 , estimated	z	x_2	z_2 , estimated	z
1	57	56	0.018	43	44	0.023
2	61	63	0.063	46	50	0.320
3	52	55	0.164	43	44	0.023
4	51	55	0.291	43	44	0.023
5	53	49	0.327	48	40	1.600
6	52	63	1.921	45	50	0.500
7	95	97	0.041	74	77	0.117
8	90	75	3.000	66	60	0.600
Σ	511	511	5.825	408	408	3.206
			\parallel χ_1^2			\parallel χ_2^2

The test of goodness of fit for load curves in Pekanbaru was checked with respect to each one day in 1985 and 1982. Since the estimated values have been corrected to match actually daily energy consumption, the freedom for performing χ^2 -test is $\phi = n - 1 = 7$.

$$\chi_1^2 < \chi_{\phi=7}^2 (0.5) = 6.35$$

$$\chi_2^2 < \chi_{\phi=7}^2 (0.75) = 4.25$$

In both cases, the estimated load curves match very well with the actual values.

Annex 3-10 Analysis for Estimating the Maximum Power Demand per Hour from the Model Load Curve

Unit: MW

Time	July 1984				Dec. 1984				March 1985			
	15 (Sun.)	18 (Wed.)			16 (Sun.)	19 (Wed.)			17 (Sun.)	20 (Wed.)		
	x_1	y_1	x_1^2	y_1^2	x_2	y_2	x_2^2	y_2^2	x_3	y_3	x_3^2	y_3^2
1	22.1	x29.6	488.4		31.1	x31.2	967.2		x32.0	x31.0		
2	18.8	29.3	353.4	858.5	x25.7	30.5		930.3	31.0	31.5	961.0	992.3
3	x10.5	29.5		870.3	26.2	30.2	686.4	912.0	31.0	31.2	961.0	973.4
Σ		99.7		2570.6		118.0		3495.9		124.7		3887.7
\bar{x}		24.9		642.7		29.5		874.0		31.175		971.9
σ_1		4.76 (19.1%)				1.94 (6.6%)				0.21 (0.7%)		
4	x14.8	29.4		864.4	x26.2	29.9		894.0	31.5	x31.2		992.3
5	20.0	26.0	400.0	676.0	27.0	30.6	729.0	936.4	31.5	32.0	992.3	1024.0
6	24.1	x33.1	580.8		29.0	x32.6	841.0		34.0	x34.2		1156.0
Σ		99.5		2521.2		116.5		3400.4		129.0		4164.6
\bar{x}		24.9		630.3		29.1		850.1		32.25		1041.2
σ_2		3.21 (12.9%)				1.81 (6.2%)				1.04 (3.2%)		
7	22.2	x25.8	492.8		26.5	x29.6	702.3		30.3	x31.7		918.1
8	20.3	15.9	412.1	252.8	26.0	27.4	676.0	750.8	x24.5	25.5		650.3
9	21.3	x14.5	453.7		28.8	x20.0	829.4		30.7	24.8	942.5	615.0
Σ		79.7		1611.4		108.7		2958.5		111.3		3125.9
\bar{x}		19.9		402.9		27.18		739.6		27.83		781.5
σ_3		2.62 (13.2%)				0.92 (3.4%)				2.64 (9.5%)		
19	32.8	x28.7	1075.8		41.7	38.3	1738.9	1466.9	39.7	38.1	1576.1	1451.6
20	35.8	31.7	1281.6	1004.9	x41.8	x33.8			40.9	38.8	1672.8	1505.4
21	x40.0	35.4		1253.2	40.4	35.8	1632.2	1281.6	x46.3	x37.5		
Σ		135.7		4615.5		156.2		6119.6		157.5		6205.9
\bar{x}		33.93		1153.9		39.05		1529.9		39.38		1551.5
σ_7		1.62 (4.8%)				2.24 (5.7%)				0.83 (2.1%)		
22	31.4	x32.5	986.0		33.2	x33.3	1102.2		x35.1	34.7		1204.1
23	27.6	29.2	761.8	852.6	29.1	29.0	846.8	841.0	33.2	31.3	1102.2	979.7
24	x26.4	26.8		718.2	29.5	x27.5	870.3		28.8	x28.7		829.4
Σ		115.0		3318.6		120.8		3660.3		128.0		4115.4
\bar{x}		28.75		829.7		30.2		915.1		32.0		1028.9
σ_8		1.76 (6.1%)				1.74 (5.8%)				2.20 (6.9%)		

Note: The values denoted by x refer to the values calculated from those in statistics excluding the maximum and minimum values from groups x_j and y_j .

The values in parenthesis refer to the ratio to average values.

Annex 3-11 Example of Obtaining Daily Maximum and Minimum Power Demand

The daily maximum and minimum power demand is obtained by calculation from the values in Annex 3-7 (1), (2).

(Unit: MW, MWh)

Week day	Minimum	$78.3 - 2 \times 0.07 \times 78.3 \approx 67.3$	Daily L.F. 68.7%
	Maximum	$118.2 + 2 \times 0.07 \times 118.2 \approx 134.8$	
	Daily	2,222.7	
Holiday	Minimum	$70.3 - 2 \times 0.07 \times 70.3 \approx 60.5$	Daily L.F. 66.5%
	Maximum	$106.9 + 2 \times 0.07 \times 106.9 \approx 121.9$	
	Daily	1,944.5	

Annex 3-12 Example of Obtaining Yearly Maximum and Minimum Power Demand

The yearly maximum and minimum power demand is obtained as follows from the calculation chart in Annex 3-7 (1), (2).

			Unit: MW, GWh
Yearly	Minimum	Holiday minimum $70.3 \div 1.059 - (14\% \text{ portion})$ = 57.1	Yearly L.F 63.3%
	Maximum	Week day maximum $118.2 \times 1.059 + (14\% \text{ portion})$ = 142.7	
	Yearly	791.3	

Note: Coefficient of increase/6 months $\frac{\text{Sold energy in the next year}}{\text{Sold energy in this year}} \div 2 = 1.059$

Annex 3-13 Example of Obtaining Monthly Sending End Energy Demand

Average power $P_A = \frac{\pi}{8,760 \text{ hr.}} = 0.09033 \text{ GWh}$
 : from Annex 3-7 (1), (2).

When an increase rate per six months is taken into account, the power demand in one month is,

6 m increase rate

$$P_{\text{Mar.}} = P_A \times 1.059 \quad \times 730 \text{ hr.} = 69.83 \text{ GWh}$$

$$P_{\text{Apr.}} = P_A \div 1.059 \quad \times 730 \text{ hr.} = 62.27 \text{ GWh}$$

$$\text{where } \Delta = \frac{P_{\text{Mar.}} - P_{\text{Apr.}}}{11} = 0.687 \text{ GWh}$$

$$P_{\text{Feb.}} = P_{\text{Mar.}} - \Delta$$

$$P_{\text{Jan.}} = P_{\text{Feb.}} - \Delta$$

Months	Monthly allocation (GWh)
4	62.3
5	63.0
6	63.7
7	64.3
8	65.0
9	65.7
10	66.4
11	67.1
12	67.8
1	68.4
2	69.1
3	69.8

Annex 4-1. Effect of Transmission Loss upon the Respective
Alternative Plans for Trunk Power System

1. Comparison between Basic 150 kV Plan and Alternative Plans

Year	(A) Basic Plan		(B) Alternative 150 kV Plan		(C) Alternative 150 kV Plan In case no investment is made in 2005	
	T/L loss (MW)	Capacity of converter (MVA)	T/L loss (MW)	Capacity of converter (MVA)	T/L loss (MW)	Capacity of converter (MVA)
1993	2.3	0	2.0	0	2.0	0
1995	5.8	31	8.7	31	8.7	31
2000	9.6	48	10.4	7	10.4	7
2005	18.7	171	23.1	156	23.1	156
2005*	16.0	152	16.0	152	-	

* In case of loop operation


The Plans (B) and (C) are apparently disadvantageous over the basic plan (A) since these plans require higher construction cost and are larger in transmission loss than the basic plan (A).

In case a loop configuration is not adopted for the basic plan (A), the capacity of condensers required to be installed is by 15 MVA larger in 2005 than that for the Plans (B) and (C), and a resultant additional cost is about ¥10 million per year. Even in this case, the effect of increase in power loss (4.4 MW, namely, $4.4 \text{ MW} \times 8,760 \text{ h} \times 0.432 = 16,650 \text{ MWh/year}$) of Plans (B) and (C) is still greater than in the case of the basic plan (A).


0.432: Loss factor

2. Power Flow of Alternative 150kV Plan

Upper figure shows Power Flow in 2000
Lower figure shows Power Flow in 2005



3. Power Flow in Case of Loop System in 2005



4. Comparison between 150 kV Plan and 275 kV Introduction Plan

The amount of power loss in the basic plan and alternative 275 kV introduction plan is roughly calculated and compared as listed below.

Transmission loss in 2005

	(Unit: MW)			
	Ombilin - Kuantan	Kuantan - Pekanbaru	Other sections	Total
Power loss in 150 kV line	7.4	5.2	10.4	23.0
Power loss in 275 kV line *1	1.5	1.1	10.4	13.0
Power loss in 150 kV loop line (Basic Plan)				16.0

*1. This power loss is approximately calculated by taking into account the difference of voltage and resistance between conductors.


In the case of the 275 kV plan, transmission loss is reduced by about 3 MW. This amount is equivalent to about ¥116 million in terms of annual expenditures*2, about ¥935 million in terms of the amount of investment or ¥240 million in terms of present value. The results of economic comparison taking into consideration transmission loss as shown in Table 4.2-3 become as follows:

	Unit: 10 ⁶ Yen		
	A: Basic 150 kV plan	B: 275 kV plan	C: Initial 150 kV & later 275 kV plan
Present value of construction cost	6,041	11,634	8,321
Reduction of power loss		-240	-240
Total	6,041	11,394	8,081

As listed above, the basic 150 kV plan (A) is apparently advantageous over the other alternative plans even though the amount of power loss is considered.

*2. Regarding conversion of power loss in terms of monetary value, refer to 4.4(d).

Annex 5-1 Electric Power System Development Project
in Central Sumatra
Location Map - I




Project


Payakumbuh (S/S)

Batusangkar (S/S)

Ombilin (P/s)

Salak (P/s)






**ELEVATIONS IN METRES
DEPTHS IN FATHOMS**

OPERATIONS GRAPHIC-GROUND

Scale 1:250,000



INTERVAL 100 METRES WITH SUPPLEMENTARY CONTOUR AT 50 METRES


TRANSVERSE MERCATOR PROJECTION

10-70 PRINTED BY THE U. S. ARMY TOPOGRAPHIC COMMAND Printed by Mapping and Charting Establishment RE 4 70 61 MCE RE

GLOSSARY

- Air. A. river
- Batang. B. hill, mountain
- Bukit lake
- Denau bank, reef, shoal
- Gosong mountain
- Guguk mountain
- Gunung mountain
- Kabupaten regency
- Karang reef
- Kotapradja municipality
- Muara estuary
- Padang open grass area
- Propinsi province
- Pulau island
- Rawang marsh, swamp
- Rimba patch of trees
- Sungai, S. river
- Ujung cape, point

LOCATION DIAGRAM FOR SA 47-3




the Director of Military
COPYRIGHT 1970
SPC.RE in 1969

STOCK NO. 1501XSA4703

SERIES 1501
SHEET SA 47-3
EDITION I-GSGS





Legend:

- 150 KV Transmission Line (Existing)
- 150 KV Transmission Line (Plan)


100°30' MUARA 10 KM MUARA 12 KM ALAM PANJANG 9 KM 101°00' 15' 100'

the Director of Military Survey, Ministry of Defence, United Kingdom 1970
 COPYRIGHT 1970
 SPC.RE in 1989

ELEVATIONS IN METRES
DEPTHS IN FATHOMS

JOINT OPERATIONS GRAPHIC-GROUND

Scale 1:250 000



CONTOUR INTERVAL 100 METRES WITH SUPPLEMENTARY CONTOUR AT 50 METRES

Contour Supplementary contour

TRANSVERSE MERCATOR PROJECTION

MAGNETIC DECLINATION FOR 1969 VARIES FROM 2° 15' WEST FOR THE SW CORNER TO 0° 34' WEST FOR THE NE CORNER
 (Magnetic declination changes with date)

REFER CORRECTIONS TO THIS GRAPHIC TO
 DIRECTOR OF MILITARY SURVEY, MINISTRY OF DEFENCE, LONDON

PROGRAM FOR SA 47-3
 SHOWN IN RED/BROWN 103'30"

NA 47-11	NA 47-12	NA 48-9
NA 47-15	NA 47-16	NA 48-12
SUMATERA		M-10
SA 47-3	SA 47-4	SA 48-1
SA 47-7	SA 47-8	SA 48-5
INDONESIA		
SA 47-11	SA 47-12	SA 48-9




01XSA4703
 SERIES 1501
 SHEET SA 47-3
 EDITION I-GSGS

Brown lines along roads denote approximate distances in kilometres between markers

THIS GRAPHIC SUPERSEDES SERIES T503 SHEET SA 47-4


THIS GRAPHIC IS NOT AN AUTHORITY ON INTERNATIONAL BOUNDARIES

SERIES 1501
SHEET NA 47-16
EDITION I-GSGS



Annex 5-2 Electric Power System Development Project
in Central Sumatra
Location Map - 2

- LEGEND**
- POPULATED PLACES:**
- 1st important: PALEMBANG
 - 2nd important: DJAMBI
 - 3rd important: SEKAJU
 - 4th important: Sungsang
 - 5th important: Sugihwaras
- ROADS:**
- A weather, hard surface: Two or more lanes wide: Principal route, Secondary route
 - A weather, loose or light surface: Two or more lanes wide: Principal route, Secondary route
 - Less than two lanes wide: Principal route, Secondary route
 - Fair or dry weather: loose surface dirt road: Principal route, Secondary route
 - Carriacoo
 - Track/footpath
- RAILROADS:**
- Normal gauge: 3'6" (1.067m)
 - Narrow gauge
- BOUNDARIES:**
- Administrations
 - Provinces
 - Kabupaten
- RELIEF:**
- Contour interval: normal 300' elevation: critical
 - Following elevation value indicates accuracy is not within 30 metres
 - Horizontal control point trig astro
- Woodland Rice paddy**
- Unsurveyed stream
 - Tree cultivation
 - Swamp or marsh
 - Near: Tropical grass
 - Reef: Limit of danger
 - Rocks: sunken, awash
 - Foreshore flat
- Power transmission line**
- CAUTION:** Power line information has been extracted from the most reliable source available. However, there is no assurance that all power lines are shown.
- AERODROMES (Military or Civilian):**
- EDNA
 - Field with runway pattern
 - Field with runway pattern
 - Field with runway pattern
 - Field with runway pattern
 - Field with runway pattern
- SEAPLANE BASE**
- SEAPLANE EMERGENCY**
- OBSTRUCTIONS:**
- Obstruction to air navigation: 333' Elevation of obstruction to: above sea level
 - Obstruction to air navigation: 79' Elevation of obstruction to: above ground level
 - Group obstruction
 - Obstruction to air navigation
- RELIABILITY OF VERTICAL OBSTRUCTION DATA:**



ALLY FOREST COVERED

GENERALLY FOREST COVERED

GENERALLY FOREST COVERED


GENERALLY FOREST COVERED

GENERALLY FOREST COVERED

GENERALLY FOREST COVERED

PAKANBARU

Pekanbaru (S/S)





DIPTER REVISI
KEMENTERIAN
PERTANAHAN

Vertical Obstruction
 30' Elevation of obstruction to
 1000 sea level
 24' Elevation of obstruction to
 at sea ground level

RELIABILITY OF VERTICAL OBSTRUCTION
 DATA: NO INFORMATION ON OBSTRUCTIONS
 IS AVAILABLE WITHIN THE AREA OF THE
 GRAPHIC

GEOMETRIC
 BASIC IS QUADRANGLE




Published by the Director of Military Survey, Ministry of Defence, United Kingdom 1970
 © CROWN COPYRIGHT 1970
 Compiled by Ordnance Survey in 1969

ELEVATIONS IN METRES

JOINT OPERATIONS GRAPHIC-GR

Scale 1:250,000



CONTOUR INTERVAL 100 METRES WITH SUPPLEMENTARY CONTOUR AT 50 METRES

Contour 100 Supplementary contour 50

TRANSVERSE MERCATOR PROJECTION

MAGNETIC DECLINATION FOR 1965 VARIES FROM 0°13'14" MILS E FOR THE SW CORNER TO 0°32'10" MILS E FOR THE NE CORNER

SCALE 1:250,000
 PAKANBARU
 INDONESIA




SERIES 1501
 SHEET NA 47-16
 EDITION I-GSGS

Figures in red/brown along roads denote approximate distances in kilometres between markers
 THIS GRAPHIC SUPERSEDES SERIES T503 SHEET NA 47-16

NOTE: THIS GRAPHIC IS NOT AN AUTHORITY ON INTERNATIONAL BOUNDARIES

REFER CORRECTIONS TO THIS GRAPHIC TO
 DIRECTOR OF MILITARY SURVEY, MINISTRY OF DEFENCE, LONDON




Legend:
 — 150KV Transmission Line (Plan)

ELEVATIONS IN METRES

Printed for the Director of Military Survey, Ministry of Defence, United Kingdom by Ordnance Survey
 9-70 PRINTED BY THE U. S. ARMY TOPOGRAPHIC COMMAND

OPERATIONS GRAPHIC-GROUND

Scale 1:250,000



CONTOUR INTERVAL 100 METRES WITH SUPPLEMENTARY CONTOUR AT 50 METRES

Contour 100 Supplementary contour 50

TRANSVERSE MERCATOR PROJECTION

DISTRIBUTION LIMITED—DESTROY WHEN NO LONGER NEEDED

LOCATION DIAGRAM FOR NA 47-16

ONC INDEX SHOWN IN RED/BROWN				
NA 47-6	NA 47-7	NA 47-8	NA 47-9	NA 47-10
MALAYSIA			SINGAPORE	
WEST MALAYSIA			SINGAPORE	
NA 47-10	NA 47-11	NA 47-12	NA 47-13	NA 47-14
SUMATERA		M-10		
NA 47-14	NA 47-15	NA 47-16	NA 47-17	NA 47-18
INDONESIA				
SA 47-1	SA 47-2	SA 47-3	SA 47-4	SA 47-5
SA 47-6	SA 47-7	SA 47-8	SA 47-9	SA 47-10

GLOSSARY

- Air stream
- Bantjah, Bantjah marsh
- Batang river
- Bukit hill
- Danau lake
- Gunung mountain
- Kabupaten regency
- Pematang hillock
- Propinsi province
- Rawang, Rawang marsh, swamp
- Sungai S. river
- Tasik lake
- Tengah-tengah central

STOCK NO. 1501XNA4716

A-42

SERIES 1501
 SHEET NA 47-16
 EDITION I-GSGS

DECLINATION FOR 1969 VARIES FROM 0°13'14" N FOR THE SW CORNER TO 0°32'10" N FOR THE SE CORNER

REFER CORRECTIONS TO THIS GRAPHIC TO DIRECTOR OF MILITARY SURVEY, MINISTRY OF DEFENCE, LONDON