

III. RIO TUBA MINE

CHAPTER III: RIO TUBA MINE

3.1 History and Future Prospects

The Rio Tuba Mine was developed comparatively recently by the Rio Tuba Nickel Mining Corporation which was set-up as a joint venture by an American company, UOP Co., and Philippine capital in 1969. The Rio Tuba Corp. subsequently began exploration and prospecting for nickel deposits.

In 1971 a feasibility study on the potential for extraction of 2 million DMT/year conducted by a group of Japanese companies (Pacific Metals Corp., Ltd. Nippon Mining Co., Ltd., and Sumitomo Metal Mining Corp., Ltd.) was completed and the report for the same was finalized in the following year, 1972. As a result, application for 285 new mine lots for the Rio Tuba Corp. was conducted in addition to the 110 mine lots already settled.

In 1973 Pacific Metals Corp. acquired all stocks held by UOP Co., (40% of total stocks) becoming chief stock holder in the Rio Tuba Corp. At the same time, the Japanese Government was requested to conduct a basic design feasibility study for a development plan. Although the original objective of the plan was 1 million DMT of nickel production, this objective was reduced to 500,000 DMT, all destined for export to Japan, by the Technical Committee in response to economic conditions resulting from the Oil Crisis in 1974. In March, 1975, Nippon Steel Corp., Nisshin Steel Co., Ltd., and Nissho Iwai Corp., decided to invest in the Rio Tuba Corp., acquiring 13%, 10% and 10% of shares respectively (Pacific Metals Corp., held the remaining 67%) and promoting further development.

In 1975, with capital investment by the Export-Import Bank of Japan, construction was begun and main mining facilities were completed by December, 1976. At the same time capital for related mine facilities was provided under the JICA grant aid program with which hospital, school and gymnasium facilities for the Rio Tuba Mine employee town site were established. Mine operation commenced from January 1977 and 22,000 WMT of ore were exported to the Pacific Metals factory in Japan by April of the same year.

Operation continued smoothly for several years; however, the effects of world-wide recession caused by the second oil crisis resulted

in reduced demand for nickel. Even with the subsequent drop in international nickel prices demand failed to increase (TABLE 3-1). Accordingly, in 1979 the Rio Tuba Corp., recognizing that decreased production was unavoidable (TABLE 3-2), halted use of its diesel powered ore-drier in favor of sunlight drying and export of wet unprocessed ore in order to reduce production costs.

Shipment of wet, unprocessed ore however, entails additional shipping costs (nickel content of shipped ore is only 5%) and electric fees for processing in Japan. This has led the Rio Tuba Corp. and Pacific Metal Corp. to consider establishing a new smelting system at the mine itself with the added objective of increasing local benefits within the Philippines.

Although establishment of smelting facilities is still under study and exact power demands of the same are not yet clear, it is obvious that a large amount of power will be required for operation of the same (total peak load for the mine: about 7,500kW). Accordingly, it is desirable that as much of this power as possible be supplied by less expensive hydropower as part of the Rio Tuba Corp. cost reduction scheme.

The Rio Tuba Mine nickel reserve for potential development as of 1983 amounted to 23 million WMT at the high-quality Guintalungan ore vein alone and with the revival of the international nickel market and continued nickel scarcity, it is likely that the number of mine lots at Rio Tuba will increase and mine operation will continue for several decades hence.

3.2 Electrical Facilities and Power Demand

3.2.1 Electrical Facilities

The Rio Tuba Mine is equipped with three 700kW diesel generators at the plant site, and one 160kW and one 50kW diesel generator at the pier site. The power plant facilities at the plant site were jointly manufactured by Japanese companies in 1976 and are functioning efficiently. There are also about 6.5km of 4.16kV and 230V distribution line strung.


Operation and maintenance of the above facilities is performed by a total of 32 workers (not including managerial staff) in 3 shifts.

Overhaul of the generators takes place once in every 3,000 operation hours, and the most recent overhaul was conducted from Sept. to Oct. 1983 which makes the total operating hours to date 27,000. In general, maintenance and equipment condition is good and repairs are performed with adequate technical skill. A single line diagram for the plant and pier site is presented in FIG. 3-1. The electrical systems of the 2 sites however, are as yet unconnected.


3.2.2 Power Supply Conditions

Since Rio Tuba Mine commenced operation in 1977, efforts have been made to reduce production costs. Energy-saving sunlight drying was adopted in 1979 for example in place of the drier facility and the heat source for the latter was converted from electricity to heavy crude oil in 1982. As a result, peak load was drastically reduced from approximately 1,100kW to about 310kW, and generator operation was limited to the use of only 1 unit among the 3 existing units. In addition diesel fuel was changed from light to heavy crude oil further reducing power supply costs. Power supply conditions at the Rio Tuba Mine are presented in FIG. 3-2, while a recent example of the daily load curve is as shown in FIG. 3-3.

PLANT SITE SINGLE LINE DIAGRAM



PIER SITE SINGLE LINE DIAGRAM



RJO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
SINGLE LINE DIAGRAM FOR PLANT AND PIER SITE	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF

FIG. 3-2 ENERGY SUPPLY CONDITIONS AT RIO TUBA MINE




FIG. 3-3

DAILY LOAD CURVE (JAN 30, 1984)




TABLE 3-1 INTERNATIONAL NICKEL PRICE FLUCTUATIONS

Year	INCO (¢/1b) (a)	Canadian Producer Price (\$/MT) (b)	Commerical Market Price (\$/MT) (c)
1975	207.3	4,570	4,155
1976	225.3	4,970	4,573
1977	241.0	5,200	4,579
1978	-	4,610	4,254
1979	280.5	5,990	5,642
1980	342.9	7,530	6,783
1981	345.0	7,560	6,736
1982	320.0	7,055	5,132
1983	320.0	7,053	4,802
1984*	-	7,273	5,510
1985*	-	7,494	6,171
1990*	-	11,708	-
1995*	-	17,965	-

Source: (a) Mining Manual 1983
 (b), (c) Commodity Price, World Bank, 1984 Jan.

TABLE 3-2 CHANGES IN PRODUCTION, SALES AND
 FINANCIAL CONDITIONS OF RIO TUBA MINING CORP.

Item	Year	1977	1978	1979	1980	1981	1982	1983
Amount Produced		472,198	644,443	759,839	675,223	542,737	474,506	421,004
Amount Sold		375,735	661,997	729,367	601,449	631,421	431,112	437,036
Turnover		8,130	9,843	13,543	17,958	16,251	9,897	6,340
Net Profit before Taxes		128	2,330	1,924	3,297	114	950	278

IV. POWER AND ENERGY
DEMAND FORECAST

CHAPTER IV POWER AND ENERGY DEMAND FORECAST

4.1 Objectives of Load Forecast

The 3,800kW maximum capacity hydropower plant to be constructed on the Tamlang River will supply the Rio Tuba Mine through a 34.5kV transmission line 44km in length. A certain portion of the same will also be used to supply electricity to rural communities along the transmission line route which are not presently electrified, thus contributing to the rural electrification program and improvement of rural life.

In consideration of the above overall objectives, load forecast was focused on the following:

- a) power demand forecast in communities to be newly electrified and determination of power distribution to PALECO and the Rio Tuba Mine;
- b) use of a few case studies regarding Rio Tuba Mine energy demand for formulation of the smelting process presently under study.

4.2 Study of Domestic Power Supply

4.2.1 Present Conditions

Brookes Point town is located about 15km northeast of the hydropower project site in Brookes Point Municipality. The population of the same is about 6,000, one of the largest population centers in the Project area. PALECO commenced supply of electricity in the area in March 1982 and a total of 11 rural communities are presently served by the same. Electrification conditions in Brookes Point Municipality are as presented in 2.4.4 above.

PALECO has 2 diesel generators supplying electricity to the above; a 300kW generator manufactured in 1945 and a 150kW generator made in 1969. In addition, connection of the PALECO power systems between Brookes Point, Naraa, Aborlan, and Quezon, is expected to be completed by 1988, the year in which the proposed Tamlang River Hydropower Project is scheduled to begin operation. All communities south of Brookes Point town to the Rio Tuba Mine are presently without electrical power supply.

4.2.2 Residential Power Demand

An interview survey was conducted in 12 rural communities (barangays) in Bataraza Municipality to determine the relationship between such factors as power demand, income, and fuel consumption among low, middle, and high income households. Survey results revealed that 1.6-18% of kerosine are consumed, and 14-158 pesos are expended monthly for lighting with an average monthly consumption of 3% at 26.4 pesos. In addition approximately 60% of households spend 15 pesos/month on dry-cell batteries for radios. The majority of people expressed the desire to become recipients of any future power supply scheme and further, as the lowest PALECO electricity rate is presently 31.1 pesos for up to 12kWh, capability of payment was deemed generally sufficient. At present, PALECO bears the cost of both wattmeter installation and line extension up to 45m from the distribution line (45m x number of household applicants). This policy greatly facilitates electrification for rural residents.

4.2.3 Load Forecast for Residential Power Supply

Load forecast for residential power demand was made for each rural community in the area according to the following conditions.

- (1) Communities eligible for power supply are:

<u>Brookes Point Municipality</u> (South of Brookes Point Town)	<u>Bataraza Municipality</u>	
Tubtub	Inogbong	Colandanum
Oringoring	Bataraza	Rio Tuba
Tagperara	Bonobono	Ocayan
Saraza	Malihod	Iwahig
Samariniana	Bulalacao	Igangigang
Salogon	Tarusan	Sarong
Malis	Sandoval	

- (2) Load forecast was made for a period of 20 years commencing with envisaged power plant start-up in April 1988.

- (3) Household power demand forecasts were made on the following premises:

- a) Population increase was estimated for each community in consideration of past population increase rate,

infrastructure development by PIADP, and migration trends resulting from electrification, etc.;

- b) Household number was calculated as population divided by average number of persons per household. According to the census conducted in 1980, the average number of persons per household was 5.2 and 4.7 in Brookes Point and Bataraza municipalities respectively;
- c) Date for available of electric service in each barangay was estimated by distance from transmission lines, size of community, etc.;
- d) Initial electrification rate was estimated for each community with a 10% growth rate in the first 2 years and uniform growth thereafter. The above figures were determined in consideration of the difficulties involved in supplying individual households and small, isolated mountain communities.
- e) The number of electrified households was obtained by the multiplication of the electrification rate and the number of households;
- f) Electrical appliances were estimated for each income level, and initial average peak load of 80W per household with a 4% growth rate was assumed; and,
- g) A load factor of 30% was determined by estimation of residential power supply usage.

(4) Demand for commercial use, public buildings, street lights, and small scale industry was estimated from number of users and peak load per user.

- a) Number of users was assumed as 5% of number of residential user households.
- b) Peak load per user was estimated at 170W and peak load growth rate at 5%.
- c) Load factor was estimated as 35% based on usage conditions.

(5) Demand for north of and including Brookes Point town will be about 800kW by the time of hydropower plant start-up according to the PALECO program, while, at the same time, the equivalent of 450kW of power output from the existing PALECO diesel generator at Brookes Point town will be supplemented by the hydropower plant to be installed by the Project. Load factor was estimated at 32% and annual output at 1,261MWH.

Demand estimate of power output for rural electrification is presented in TABLE 4-1, estimate of power demand for south of

Brookes Point town in TABLE 4-2 and percentage of energized households for town and rural communities in TABLE 4-3.

4.3 Study of Rio Tuba Mine Power Supply

4.3.1 Present Conditions

Ore drying operations consume the largest percentage of electrical energy and costs in mine operation at Rio Tuba Mine. The Rio Tuba Mine which opened in 1977, originally used an electrical drier. In 1979 however, sunlight drying was adopted and the heat source for the drier was converted from electricity to crude oil in mid 1982 in an effort to reduce production costs. At the same time, restrictions were imposed upon electric consumption in residential use by employees. The combination of the above resulted in drastic decrease in electricity consumption, peak load dropping from about 1,100kW to 310kW while the number of generators required to fulfill demand was limited to the use of only 1 unit among the 3 existing units.

Present conditions of power supply at the Rio Tuba Mine are as illustrated in FIG. 4-1.

4.3.2 Demand Forecast of Power Supply for Mine Use

The Rio Tuba Mine is presently conducting a study to develop a plan to strengthen smelting facilities, etc. and thereby to increase values added to nickel ore production. As the above is still under study, accurate estimate of energy demand for smelting facilities at this stage is difficult to determine and accordingly energy demand forecasts were made for 3 possible cases, namely:

- Case-1 resumption of ordinary drier facility used before the present sunlight method;
- Case-2 establishment of new facilities within the maximum utilization of available energy from the hydropower plant; and,
- Case-3 installation of a new smelting system.

These cases are further detailed on the following page.

(1) Case 1

The case was assumed with the following conditions.

- 1) Demand forecast was for a 24-year period from 1984 to 2007;
- 2) Energy consumption of the drier until commencement of hydropower plant operation will be 200MWH. After start-up in 1988, the drier will be used in rainy season and sunlight drying in dry season. Energy demand for the same was designated at 3,793MWH, the 1980 standard, while the operation factor for the drier was 50%; and,
- 3) Energy consumption, excluding the drier, was estimated to have a growth rate of 4% until 1987, 8% from 1988 to 1997 and 4% thereafter. Peak load growth rate has been the same as the above.

The results of the study are presented in TABLE 4-4.

(2) Case 2

The case was assumed according to the following conditions:

- 1) Demand forecast period covered 20 years from 1988 to 2007;
- 2) Peak load for all facilities including employees' houses was estimated at 3,450kW, taking into account transmission line loss, and power supply of communities; and,
- 3) With a load factor of 65%, consumption of electricity was determined at 19,645MWH.

(3) Case 3

Conditions of the case were as follows:

- 1) Demand forecast period was 20 years from 1988 to 2007;
- 2) Peak load was estimated at 8,500kW with a similar approach as Case 2 above; and,
- 3) Energy consumption was determined at 59,568MWH with a load factor of 80%.

4.4 Power Distribution for Domestic and Mine Use

Residential and mine use demand forecasts to the year 2007 discussed in 4.2.3 and 4.3.2, respectively, are summarized in TABLE 4-5.

Peak demand for rural electrification 10 years after start-up of the Tamlang River Hydropower Plant is estimated at 999kW, representing 26.3% of the plant's maximum output (3,800kW) and power consumption will be 2,844MWH. As this also represents 14.9% of the annual available energy (19,087MWH), the power distribution is considered appropriate from the perspective of Project objectives. Thus, priority for use of forecast energy until 1997, and supply of 1,000kW peak demand with annual energy demand of 2,844MWH thereafter, will be given to PALECO.

4.5 Balance of Supply and Demand for Mine Use

Supply and demand balance estimation was conducted according to the following conditions:

- a) Start-up of the Tamlang River Hydropower Project was designated as April 1988;
- b) Forecast demand for rural electrification will be supplied up to 1997, while only 1,000kW of peak energy and 2,844MWH/year will be supplied for the same thereafter;
- c) Transmission line and transformer losses were considered;
- d) The Rio-Tuba Mine diesel generator installed at the pier site was not considered as a source of power supply;
- e) The existing Rio Tuba Mine diesel generators which are in good condition will be used until 1997; and,
- f) Regular inspection, overhaul etc. of diesel generators will be undertaken during the rainy season.

Estimated available hydropower energy for the Rio Tuba Mine is presented in TABLE 4-6.

4.5.1 Case Analysis

To determine the optimum development plan in light of power and energy demand several case studies were carried out; namely, Case-1, 2 and 3. A summary of the findings are presented hereinafter on the following page.

(1) Case-1

Supply and demand balance for Case-1 is provided in TABLE 4-7. In this case, a surplus of 2,173kW - 1,755kW occurs at peak, and 11,458MWH - 5,727MWH in electric energy from 1988-2007. In addition to developing further power demand at Rio Tuba Mine or planning new facilities, etc. for the same, a plan should also be developed to increase power supply for PALECO and create new sources of power demand.

(2) Case 2

The supply-demand balance for Case-2 is provided in TABLE 4-8. Although the hydropower plant is equipped with weekly regulation capacity via a regulating pond, it is possible that power supply to the Mine would occasionally be insufficient during the dry season as the supply to rural electrification is given priority. Simple calculations indicate that a lack of 1,350kW will occur in peak load, and accordingly, study of a coordinated operation system to compensate the peak shortage through operation of both the diesel and hydropower plants at the Rio Tuba Mine is required.

(3) Case-3

The supply-demand balance for Case-3 is shown in TABLE 4-9. In this case an insufficiency of 6,400kW in power output and 33,014MWH -34,127MWH in electric energy will occur from 1988-2007. As in Case-2, insufficiencies will be compensated, use of other power sources will be minimized and balance will be maintained by coordination of diesel generator operation with hydropower plant operation.

FIG. 4-1

ENERGY DEMAND OF RIO TUBA MINING CORPORATION




TABLE 4-1

DEMAND FORECAST FOR RURAL ELECTRIFICATION

Year	North of Brookes Point Including Brookes Point Town		South of Brookes Point Town		Total	
	Peak Demand (kW)	Energy Demand (MWH)	Peak Demand (kW)	Energy Demand (MWH)	Peak Demand (kW)	Energy Demand (MWH)
1988	450	1,261	164	470	614	1,731
1989	450	1,261	227	652	677	1,931
1990	450	1,261	291	833	741	2,094
1991	450	1,261	332	951	782	2,212
1992	450	1,261	369	1,058	819	2,319
1993	450	1,261	401	1,152	851	2,413
1994	450	1,261	434	1,248	884	2,509
1995	450	1,261	469	1,349	919	2,610
1996	450	1,261	506	1,457	959	2,718
1997	450	1,261	549	1,583	999	2,844
1998	450	1,261	590	1,703	1,040	2,964
1999	450	1,261	639	1,854	1,089	3,106
2000	450	1,261	690	1,992	1,140	3,253
2001	450	1,261	745	2,157	1,195	3,418
2002	450	1,261	808	2,338	1,258	3,599
2003	450	1,261	870	2,521	1,320	3,782
2004	450	1,261	942	2,729	1,329	3,990
2005	450	1,261	1,017	2,949	1,467	4,210
2006	450	1,261	1,097	3,186	1,547	4,447
2007	450	1,261	1,189	3,457	1,639	4,718

TABLE 4-2

**ESTIMATED MAXIMUM POWER DEMAND AND
ENERGY DEMAND FOR SOUTH OF BROOKES POINT TOWN**

RESIDENTIAL

INCREASE RATE OF DEMAND 4%

LOAD FACTOR 30%

COMMERCIAL, PUBLIC BUILDINGS AND STREET LIGHTS

INCREASE RATE OF DEMAND 5%

LOAD FACTOR 35%

YEAR	RESIDENTIAL						
	POPULATION	HOUSEHOLD	ENERGIZED HOUSEHOLD	AVERAGE DEMAND	PEAK DEMAND	ENERGY DEMAND	
1	1988	24,802	5,047	1,984	89W	159KW	418MWH
2	1989	25,738	5,238	2,652	83W	220KW	578MWH
3	1990	26,706	5,430	3,244	87W	282KW	741MWH
4	1991	27,718	5,632	3,562	90W	321KW	844MWH
5	1992	28,770	5,848	3,795	94W	357KW	938MWH
6	1993	29,862	6,067	3,995	97W	388KW	1,020MWH
7	1994	30,996	6,297	4,160	101W	420KW	1,104MWH
8	1995	32,179	6,536	4,319	105W	453KW	1,190MWH
9	1996	33,405	6,783	4,482	109W	489KW	1,285MWH
10	1997	34,680	7,040	4,652	114W	530KW	1,393MWH
11	1998	36,010	7,307	4,828	118W	570KW	1,498MWH
12	1999	37,387	7,586	5,014	123W	617KW	1,621MWH
13	2000	38,822	7,875	5,205	128W	666KW	1,750MWH
14	2001	40,315	8,175	5,405	133W	719KW	1,890MWH
15	2002	41,868	8,485	5,609	139W	780KW	2,050MWH
16	2003	43,483	8,814	5,827	144W	839KW	2,205MWH
17	2004	45,159	9,149	6,050	150W	908KW	2,386MWH
18	2005	46,906	9,503	6,285	156W	980KW	2,575MWH
19	2006	48,723	9,866	6,525	162W	1,057KW	2,778MWH
20	2007	50,612	10,247	6,775	169W	1,145KW	3,009MWH

YEAR	COMMERCIAL			TOTAL			
	NUMBER	AVERAGE DEMAND	PEAK DEMAND	ENERGY DEMAND	PEAK DEMAND	ENERGY DEMAND	
1	1988	99	170W	17KW	52MWH	164KW	470MWH
2	1989	133	179W	24KW	74MWH	227KW	652MWH
3	1990	162	187W	30KW	92MWH	291KW	833MWH
4	1991	178	197W	35KW	107MWH	332KW	951MWH
5	1992	190	207W	39KW	120MWH	369KW	1,058MWH
6	1993	200	217W	43KW	132MWH	401KW	1,152MWH
7	1994	208	228W	47KW	144MWH	434KW	1,248MWH
8	1995	216	239W	52KW	159MWH	469KW	1,349MWH
9	1996	224	251W	56KW	172MWH	506KW	1,457MWH
10	1997	233	264W	62KW	190MWH	549KW	1,583MWH
11	1998	241	277W	67KW	205MWH	590KW	1,703MWH
12	1999	251	291W	73KW	224MWH	639KW	1,845MWH
13	2000	260	305W	79KW	242MWH	690KW	1,992MWH
14	2001	270	321W	87KW	267MWH	745KW	2,157MWH
15	2002	280	337W	94KW	288MWH	808KW	2,338MWH
16	2003	291	353W	103KW	316MWH	870KW	2,521MWH
17	2004	303	371W	112KW	343MWH	942KW	2,729MWH
18	2005	314	390W	122KW	374MWH	1,017KW	2,949MWH
19	2006	326	409W	133KW	408MWH	1,097KW	3,186MWH
20	2007	339	430W	146KW	448MWH	1,189KW	3,457MWH

TABLE 4-3
1 of 4

PERCENTAGE OF ENERGIZED HOUSEHOLDS FOR TOWN AND RURAL COMMUNITIES

TUBTUB				SAMARINIANA				TASPERARA				
INCREASE RATE OF POPULATION 4.4%				INCREASE RATE OF POPULATION 4.4%				INCREASE RATE OF POPULATION 4.4%				
YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	
1	1988	1,082	208	40%	1988	795	153	40%	1988	1,236	238	40%
2	1989	1,130	217	50%	1989	830	160	50%	1989	1,290	248	50%
3	1990	1,179	227	60%	1990	866	167	60%	1990	1,347	259	60%
4	1991	1,235	247	60%	1991	944	174	60%	1991	1,408	270	60%
5	1992	1,285	258	60%	1992	986	182	60%	1992	1,468	282	60%
6	1993	1,342	269	60%	1993	1,029	190	60%	1993	1,533	295	60%
7	1994	1,401	281	60%	1994	1,075	198	60%	1994	1,600	308	60%
8	1995	1,463	294	60%	1995	1,122	207	60%	1995	1,671	321	60%
9	1996	1,527	307	60%	1996	1,171	216	60%	1996	1,744	335	60%
10	1997	1,594	320	60%	1997	1,223	225	60%	1997	1,821	350	60%
11	1998	1,664	334	60%	1998	1,277	235	60%	1998	1,901	366	60%
12	1999	1,738	349	60%	1999	1,333	245	60%	1999	1,985	382	60%
13	2000	1,814	364	60%	2000	1,391	255	60%	2000	2,072	398	60%
14	2001	1,894	380	60%	2001	1,451	268	60%	2001	2,163	416	60%
15	2002	1,977	397	60%	2002	1,517	279	60%	2002	2,259	434	60%
16	2003	2,064	414	60%	2003	1,583	292	60%	2003	2,358	453	60%
17	2004	2,155	433	60%	2004	1,653	304	60%	2004	2,462	473	60%
18	2005	2,250	452	60%	2005	1,726	318	60%	2005	2,570	494	60%
19	2006	2,349	472	60%	2006	1,802	332	60%	2006	2,683	516	60%
20	2007	2,452	493	60%	2007	1,882	347	60%	2007	2,801	539	60%

ORINGORING				SALOGON				SARAZA				
INCREASE RATE OF POPULATION 4.4%				INCREASE RATE OF POPULATION 4.4%				INCREASE RATE OF POPULATION 4.4%				
YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	
1	1988	1,313	253	40%	1988	2,272	437	40%	1988	2,258	434	40%
2	1989	1,371	264	50%	1989	2,372	456	50%	1989	2,357	453	50%
3	1990	1,431	275	60%	1990	2,476	476	60%	1990	2,461	473	60%
4	1991	1,494	287	60%	1991	2,585	497	60%	1991	2,569	494	60%
5	1992	1,560	300	60%	1992	2,699	519	60%	1992	2,682	516	60%
6	1993	1,628	313	60%	1993	2,819	542	60%	1993	2,800	538	60%
7	1994	1,700	327	60%	1994	2,942	566	60%	1994	2,924	562	60%
8	1995	1,775	341	60%	1995	3,071	591	60%	1995	3,052	587	60%
9	1996	1,853	356	60%	1996	3,206	617	60%	1996	3,187	613	60%
10	1997	1,935	372	60%	1997	3,347	644	60%	1997	3,327	640	60%
11	1998	2,020	388	60%	1998	3,495	672	60%	1998	3,473	669	60%
12	1999	2,108	405	60%	1999	3,648	702	60%	1999	3,626	697	60%
13	2000	2,201	423	60%	2000	3,809	733	60%	2000	3,786	728	60%
14	2001	2,298	442	60%	2001	3,977	765	60%	2001	3,952	760	60%
15	2002	2,399	461	60%	2002	4,152	798	60%	2002	4,126	793	60%
16	2003	2,505	482	60%	2003	4,334	833	60%	2003	4,308	828	60%
17	2004	2,615	503	60%	2004	4,525	870	60%	2004	4,497	865	60%
18	2005	2,730	525	60%	2005	4,724	908	60%	2005	4,695	903	60%
19	2006	2,850	548	60%	2006	4,932	948	60%	2006	4,902	943	60%
20	2007	2,976	572	60%	2007	5,149	990	60%	2007	5,117	984	60%

TABLE 4-3
2 of 4

MALIS				INGOBONG				BOMBONG						
INCREASE RATE OF POPULATION 4.4%				INCREASE RATE OF POPULATION 3.3%				INCREASE RATE OF POPULATION 3.3%						
YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE			
1	1988	2,291	441	40%	1	1988	744	158	40%	1	1988	744	158	40%
2	1989	2,392	460	50%	2	1989	1,000	213	40%	2	1989	759	164	50%
3	1990	2,497	480	60%	3	1990	1,033	230	50%	3	1990	794	169	60%
4	1991	2,607	501	60%	4	1991	1,067	237	60%	4	1991	820	174	60%
5	1992	2,722	523	60%	5	1992	1,102	242	60%	5	1992	847	180	60%
6	1993	2,841	546	60%	6	1993	1,176	250	60%	6	1993	875	186	60%
7	1994	2,966	570	60%	7	1994	1,215	259	60%	7	1994	904	192	60%
8	1995	3,097	596	60%	8	1995	1,255	267	60%	8	1995	934	199	60%
9	1996	3,233	622	60%	9	1996	1,297	276	60%	9	1996	963	203	60%
10	1997	3,375	649	60%	10	1997	1,339	285	60%	10	1997	996	212	60%
11	1998	3,524	678	60%	11	1998	1,384	294	60%	11	1998	1,029	219	60%
12	1999	3,679	708	60%	12	1999	1,429	304	60%	12	1999	1,063	226	60%
13	2000	3,841	739	60%	13	2000	1,476	314	60%	13	2000	1,098	234	60%
14	2001	4,010	771	60%	14	2001	1,525	324	60%	14	2001	1,135	241	60%
15	2002	4,186	805	60%	15	2002	1,575	335	60%	15	2002	1,172	249	60%
16	2003	4,371	841	60%	16	2003	1,627	346	60%	16	2003	1,211	258	60%
17	2004	4,563	878	60%	17	2004	1,681	359	60%	17	2004	1,251	266	60%
18	2005	4,764	916	60%	18	2005	1,737	370	60%	18	2005	1,292	275	60%
19	2006	4,973	956	60%	19	2006	1,794	382	60%	19	2006	1,335	284	60%
20	2007	5,192	998	60%	20	2007	1,853	394	60%	20	2007	1,379	293	60%

MALINDO				BATARAHA					
INCREASE RATE OF POPULATION 3.3%				INCREASE RATE OF POPULATION 4.2%					
YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE		
1	1988	448	95	40%	1	1988	2,872	511	65%
2	1989	463	99	50%	2	1989	2,993	537	75%
3	1990	478	102	60%	3	1990	3,118	563	85%
4	1991	494	105	60%	4	1991	3,249	591	85%
5	1992	510	109	60%	5	1992	3,386	620	90%
6	1993	527	112	60%	6	1993	3,528	651	85%
7	1994	544	116	60%	7	1994	3,676	682	85%
8	1995	562	120	60%	8	1995	3,831	715	93%
9	1996	581	124	60%	9	1996	3,991	749	85%
10	1997	600	128	60%	10	1997	4,159	785	85%
11	1998	620	132	60%	11	1998	4,334	822	85%
12	1999	640	136	60%	12	1999	4,516	861	85%
13	2000	661	141	60%	13	2000	4,705	901	85%
14	2001	683	145	60%	14	2001	4,903	943	85%
15	2002	706	150	60%	15	2002	5,109	987	85%
16	2003	729	155	60%	16	2003	5,324	1,033	85%
17	2004	753	160	60%	17	2004	5,547	1,080	85%
18	2005	778	166	60%	18	2005	5,780	1,130	85%
19	2006	804	171	60%	19	2006	6,023	1,181	85%
20	2007	830	177	60%	20	2007	6,276	1,235	85%

BULALPACAO
INCREASE RATE OF
POPULATION 3.1%

YEAR	POPULA- TION	HOUSE- HOLD	ENERGIZED RATE HOUSEHOLD
1 1988	641	136	40%
2 1989	661	141	50%
3 1990	681	145	60%
4 1991	702	149	80%
5 1992	724	154	80%
6 1993	747	159	80%
7 1994	770	164	80%
8 1995	794	169	80%
9 1996	818	174	80%
10 1997	844	180	80%
11 1998	870	185	80%
12 1999	897	191	80%
13 2000	925	197	80%
14 2001	953	203	80%
15 2002	989	209	80%
16 2003	1,013	216	80%
17 2004	1,045	222	80%
18 2005	1,077	229	80%
19 2006	1,110	236	80%
20 2007	1,145	244	80%

SANDIGUAL
INCREASE RATE OF
POPULATION 3.3%

YEAR	POPULA- TION	HOUSE- HOLD	ENERGIZED RATE HOUSEHOLD
1 1988	1,033	233	50%
2 1989	1,123	240	60%
3 1990	1,166	248	70%
4 1991	1,205	256	70%
5 1992	1,243	265	70%
6 1993	1,286	274	70%
7 1994	1,328	283	70%
8 1995	1,372	292	70%
9 1996	1,417	301	70%
10 1997	1,464	311	70%
11 1998	1,512	322	70%
12 1999	1,562	332	70%
13 2000	1,614	343	70%
14 2001	1,667	355	70%
15 2002	1,722	366	70%
16 2003	1,779	379	70%
17 2004	1,837	391	70%
18 2005	1,898	404	70%
19 2006	1,961	417	70%
20 2007	2,025	431	70%

RIO TUBA
INCREASE RATE OF
POPULATION 3.7%

YEAR	POPULA- TION	HOUSE- HOLD	ENERGIZED RATE HOUSEHOLD
1 1988	1,269	270	70%
2 1989	1,316	280	80%
3 1990	1,363	290	90%
4 1991	1,415	301	90%
5 1992	1,467	312	90%
6 1993	1,522	324	90%
7 1994	1,578	336	90%
8 1995	1,636	348	90%
9 1996	1,697	361	90%
10 1997	1,760	374	90%
11 1998	1,825	388	90%
12 1999	1,892	403	90%
13 2000	1,962	417	90%
14 2001	2,035	433	90%
15 2002	2,110	449	90%
16 2003	2,188	466	90%
17 2004	2,269	483	90%
18 2005	2,353	501	90%
19 2006	2,441	519	90%
20 2007	2,531	539	90%

TARUSAN
INCREASE RATE OF
POPULATION 3.7%

YEAR	POPULA- TION	HOUSE- HOLD	ENERGIZED RATE HOUSEHOLD
1 1988	1,650	351	50%
2 1989	1,711	364	60%
3 1990	1,774	377	70%
4 1991	1,840	391	70%
5 1992	1,908	406	70%
6 1993	1,979	421	70%
7 1994	2,052	437	70%
8 1995	2,128	453	70%
9 1996	2,207	470	70%
10 1997	2,288	487	70%
11 1998	2,373	505	70%
12 1999	2,461	524	70%
13 2000	2,552	543	70%
14 2001	2,646	563	70%
15 2002	2,744	584	70%
16 2003	2,846	606	70%
17 2004	2,951	628	70%
18 2005	3,060	651	70%
19 2006	3,173	675	70%
20 2007	3,291	700	70%

COLANDRANUM
INCREASE RATE OF
POPULATION 2%

YEAR	POPULA- TION	HOUSE- HOLD	ENERGIZED RATE HOUSEHOLD
1 1988	1,007	214	0%
2 1989	1,027	219	40%
3 1990	1,048	223	50%
4 1991	1,069	227	60%
5 1992	1,090	232	60%
6 1993	1,112	237	60%
7 1994	1,134	241	60%
8 1995	1,157	246	60%
9 1996	1,180	251	60%
10 1997	1,203	256	60%
11 1998	1,228	261	60%
12 1999	1,252	266	60%
13 2000	1,277	272	60%
14 2001	1,303	277	60%
15 2002	1,329	283	60%
16 2003	1,355	288	60%
17 2004	1,382	294	60%
18 2005	1,410	300	60%
19 2006	1,438	306	60%
20 2007	1,467	312	60%

BOAVAN
INCREASE RATE OF
POPULATION 3.1%

YEAR	POPULA- TION	HOUSE- HOLD	ENERGIZED RATE HOUSEHOLD
1 1988	514	109	0%
2 1989	530	113	50%
3 1990	546	116	60%
4 1991	563	120	70%
5 1992	581	124	70%
6 1993	599	127	70%
7 1994	617	131	70%
8 1995	636	135	70%
9 1996	656	140	70%
10 1997	677	144	70%
11 1998	698	149	70%
12 1999	719	153	70%
13 2000	741	158	70%
14 2001	764	163	70%
15 2002	788	168	70%
16 2003	813	173	70%
17 2004	838	178	70%
18 2005	864	184	70%
19 2006	890	189	70%
20 2007	918	195	70%

TABLE 4-3

TABLE 4-3
4 of 4

IMRHIG				SARWING				TOTAL					
INCREASE RATE OF POPULATION 1.7%				INCREASE RATE OF POPULATION 2.5%									
YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE		
1	1988	583	0%	1	1988	779	166	0%	1	1988	24,802	5,047	
2	1989	1,000	213	0%	2	1989	798	170	0%	2	1989	25,739	5,238
3	1990	1,017	216	0%	3	1990	818	174	0%	3	1990	26,706	5,430
4	1991	1,034	220	40%	4	1991	839	179	40%	4	1991	27,718	5,632
5	1992	1,052	224	50%	5	1992	860	183	50%	5	1992	28,770	5,848
6	1993	1,069	227	60%	6	1993	881	187	60%	6	1993	29,862	6,067
7	1994	1,088	231	60%	7	1994	903	192	60%	7	1994	30,996	6,287
8	1995	1,106	235	60%	8	1995	926	197	60%	8	1995	32,179	6,536
9	1996	1,125	239	60%	9	1996	949	202	60%	9	1996	33,405	6,783
10	1997	1,144	243	60%	10	1997	973	207	60%	10	1997	34,680	7,040
11	1998	1,163	247	60%	11	1998	997	212	60%	11	1998	36,010	7,307
12	1999	1,183	252	60%	12	1999	1,022	217	60%	12	1999	37,387	7,585
13	2000	1,203	256	60%	13	2000	1,048	223	60%	13	2000	38,822	7,875
14	2001	1,224	260	60%	14	2001	1,074	229	60%	14	2001	40,315	8,175
15	2002	1,245	265	60%	15	2002	1,101	234	60%	15	2002	41,868	8,485
16	2003	1,266	269	60%	16	2003	1,128	240	60%	16	2003	43,483	8,814
17	2004	1,287	274	60%	17	2004	1,156	246	60%	17	2004	45,159	9,149
18	2005	1,308	279	60%	18	2005	1,185	252	60%	18	2005	46,906	9,503
19	2006	1,331	283	60%	19	2006	1,215	259	60%	19	2006	48,723	9,868
20	2007	1,354	288	60%	20	2007	1,245	265	60%	20	2007	50,612	10,247

ISRWING				
INCREASE RATE OF POPULATION 2%				
YEAR	POPULATION	HOUSEHOLD	ENERGIZED RATE	
1	1988	555	118	0%
2	1989	566	120	0%
3	1990	577	123	0%
4	1991	589	125	0%
5	1992	601	128	40%
6	1993	613	130	50%
7	1994	625	133	60%
8	1995	638	136	60%
9	1996	650	138	60%
10	1997	663	141	60%
11	1998	677	144	60%
12	1999	690	147	60%
13	2000	704	150	60%
14	2001	718	153	60%
15	2002	732	156	60%
16	2003	747	159	60%
17	2004	762	162	60%
18	2005	777	165	60%
19	2006	793	168	60%
20	2007	809	173	60%

TABLE 4-4

DEMAND FORECAST OF RIO TUBA MINING CORPORATION (CASE 1)

Year	Facilities		Drier System		Total	
	Excepting	Drier	Peak Demand (kW)	Energy Demand (MWH)	Peak Demand (kW)	Energy Demand (MWH)
	Demand (kW)	Demand (MWH)				
1984	322	2,014	900	200	1,222	2,214
85	335	2,095	900	200	1,235	2,295
86	349	2,179	900	200	1,249	2,379
87	363	2,666	900	200	1,263	2,866
1988	377	2,357	900	3,793	1,277	6,150
89	392	2,546	900	3,793	1,292	6,339
90	408	2,749	900	3,793	1,308	6,542
91	424	2,969	900	3,793	1,324	6,762
92	441	3,207	900	3,793	1,341	7,000
93	459	3,463	900	3,793	1,359	7,256
94	477	3,740	900	3,793	1,377	7,533
95	496	4,039	900	3,793	1,396	7,832
96	516	4,363	900	3,793	1,416	8,156
97	536	4,712	900	3,793	1,436	8,505
1998	558	4,900	900	3,793	1,458	8,693
99	581	5,096	900	3,793	1,481	8,889
2000	604	5,300	900	3,793	1,504	9,903
01	628	5,512	900	3,793	1,528	9,305
02	653	5,733	900	3,793	1,553	9,526
03	679	5,962	900	3,793	1,579	9,755
04	706	6,201	900	3,793	1,606	9,994
05	735	6,449	900	3,793	1,635	10,242
06	764	6,707	900	3,793	1,664	10,500
07	795	6,975	900	3,793	1,695	10,768

TABLE 4-5

SUMMARY OF DEMAND FORECAST

Year	Rural		Rio Tuba					
	Electrification		Case-1		Case-2		Case-3	
	Peak Demand (kW)	Energy Demand (MWH)	Peak Demand (kW)	Energy Demand (MWH)	Peak Demand (kW)	Energy Demand (MWH)	Peak Demand (kW)	Energy Demand (MWH)
1988	614	1,731	1,277	6,150	3,450	19,645	8,500	59,568
89	677	1,913	1,292	6,339	3,450	19,645	8,500	59,568
90	741	2,094	1,308	6,542	3,450	19,645	8,500	59,568
91	782	2,212	1,324	6,762	3,450	19,645	8,500	59,568
92	819	2,319	1,341	7,000	3,450	19,645	8,500	59,568
93	851	2,413	1,349	7,256	3,450	19,645	8,500	59,568
94	884	2,509	1,377	7,553	3,450	19,645	8,500	59,568
95	919	2,610	1,396	7,832	3,450	19,645	8,500	59,568
96	956	2,718	1,416	8,156	3,450	19,645	8,500	59,568
97	999	2,844	1,436	8,505	3,450	19,645	8,500	59,568
1998	1,040	2,964	1,458	8,693	3,450	19,645	8,500	59,568
99	1,089	3,106	1,481	8,889	3,450	19,645	8,500	59,568
2000	1,140	3,253	1,504	9,093	3,450	19,645	8,500	59,568
01	1,195	3,418	1,528	9,305	3,450	19,645	8,500	59,568
02	1,258	3,599	1,553	9,526	3,450	19,645	8,500	59,568
03	1,320	3,782	1,579	9,755	3,450	19,645	8,500	59,568
04	1,392	3,990	1,606	9,994	3,450	19,645	8,500	59,568
05	1,467	4,210	1,635	10,242	3,450	19,645	8,500	59,568
06	1,547	4,447	1,664	10,500	3,450	19,645	8,500	59,568
07	1,639	4,718	1,695	10,768	3,450	19,645	8,500	59,568

**AVAILABLE HYDROPOWER ENERGY
FOR RIO TUBA
MINING CORPORATION**

TABLE 4-6

Year	Available Energy ^{1/} (MWH)	Energy A ^{2/} (MWH)	Demand B ^{3/} (MWH)
1988	19,087	1,731	17,356
89	19,087	1,913	17,174
90	19,087	2,094	16,993
91	19,087	2,212	16,875
92	19,087	2,319	16,768
93	19,087	2,413	16,674
94	19,087	2,509	16,578
95	19,087	2,610	16,477
96	19,087	2,718	16,369
97	19,087	2,844	16,243
1998	19,087	2,844	16,243
99	19,087	2,844	16,243
2000	19,087	2,844	16,243
01	19,087	2,844	16,243
02	19,087	2,844	16,243
03	19,087	2,844	16,243
04	19,087	2,844	16,243
05	19,087	2,844	16,243
06	19,087	2,844	16,243
07	19,087	2,844	16,243

^{1/} Available Annual Produced Energy

^{2/} Energy Demand for Rural Electrification

^{3/} Available Energy for Rio Tuba Mining Corp.

TABLE 4-7

**BALANCE BETWEEN POWER DEMAND AND SUPPLY
FOR RIO TUBA MINING CORPORATION (CASE 1)**

Year	Power Demand		Supply			Surplus	
	Peak Demand (kW)	Energy Demand (MWH)	Hydropower		Diesel Generation	Peak (kW)	Energy (MWH)
			Peak (kW)	Energy (MWH)	(MWH)		
1988	1,277	6,150	3,450	17,356	252	2,173	11,458
89	1,292	6,339	3,450	17,174	252	2,158	11,087
90	1,308	6,542	3,450	16,993	252	2,142	10,703
91	1,324	6,762	3,450	16,875	252	2,126	10,365
92	1,341	7,000	3,450	16,768	252	2,109	10,020
93	1,359	7,256	3,450	16,674	252	2,091	9,670
94	1,377	7,533	3,450	16,578	252	2,073	9,297
95	1,396	7,832	3,450	16,477	252	2,054	8,573
96	1,416	8,156	3,450	16,369	252	2,034	8,465
97	1,436	8,505	3,450	16,243	252	2,014	7,990
1998	1,458	8,693	3,450	16,243	252	1,992	7,802
99	1,481	8,889	3,450	16,243	252	1,969	7,606
2000	1,504	9,093	3,450	16,243	252	1,946	7,402
01	1,528	9,305	3,450	16,243	252	1,922	7,190
02	1,553	9,526	3,450	16,243	252	1,897	6,969
03	1,579	9,755	3,450	16,243	252	1,871	6,740
04	1,606	9,994	3,450	16,243	252	1,844	6,501
05	1,635	10,242	3,450	16,243	252	1,815	6,253
06	1,664	10,500	3,450	16,243	252	1,786	5,995
07	1,695	10,768	3,450	16,243	252	1,755	5,727

TABLE 4-8

**BALANCE BETWEEN POWER DEMAND AND SUPPLY
FOR RIO TUBA MINING CORPORATION (CASE 2)**

Year	Power Demand			Supply		Shortage
	Peak Load (kW)	Energy Demand (MWH)	Hydropower	Existing Diesel Power		Peak (kW)
			(MWH)	Peak (kW)	Energy (MWH)	
1988	3,450	19,645	17,356	2,100	2,289	1,350
89	3,450	19,645	17,174	2,100	2,471	1,350
90	3,450	19,645	16,993	2,100	2,650	1,350
91	3,450	19,645	16,875	2,100	2,770	1,350
92	3,450	19,645	16,768	2,100	2,877	1,350
93	3,450	19,645	16,674	2,100	2,971	1,350
94	3,450	19,645	16,578	2,100	3,067	1,350
95	3,450	19,645	16,477	2,100	3,168	1,350
96	3,450	19,645	16,369	2,100	3,276	1,350
97	3,450	19,645	16,243	2,100	3,402	1,350
1998	3,450	19,645	16,243	2,100	3,402	1,350
99	3,450	19,645	16,243	2,100	3,402	1,350
2000	3,450	19,645	16,243	2,100	3,402	1,350
01	3,450	19,645	16,243	2,100	3,402	1,350
02	3,450	19,645	16,243	2,100	3,402	1,350
03	3,450	19,645	16,243	2,100	3,402	1,350
04	3,450	19,645	16,243	2,100	3,402	1,350
05	3,450	19,645	16,243	2,100	3,402	1,350
06	3,450	19,645	16,243	2,100	3,402	1,350
07	3,450	19,645	16,243	2,100	3,402	1,350

TABLE 4-9

**BALANCE BETWEEN POWER DEMAND AND SUPPLY
FOR RIO TUBA MINING CORPORATION (CASE 3)**

Year	Power Demand		Supply			Shortage	
	Peak Load (kW)	Energy Demand (MWH)	Hydropower (MWH)	Existing Diesel Power		Peak (kW)	Energy (MWH)
				Peak (kW)	Energy (MWH)		
1988	8,500	59,568	17,356	2,100	9,198	6,400	33,014
89	8,500	59,568	17,174	2,100	9,198	6,400	33,196
90	8,500	59,568	16,993	2,100	9,198	6,400	33,377
91	8,500	59,568	16,875	2,100	9,198	6,400	33,495
92	8,500	59,568	16,768	2,100	9,198	6,400	33,602
93	8,500	59,568	16,674	2,100	9,198	6,400	33,696
94	8,500	59,568	16,578	2,100	9,198	6,400	33,792
95	8,500	59,568	16,477	2,100	9,198	6,400	33,893
96	8,500	59,568	16,369	2,100	9,198	6,400	34,001
97	8,500	59,568	16,243	2,100	9,198	6,400	34,127
1998	8,500	59,568	16,243	2,100	9,198	6,400	34,127
99	8,500	59,568	16,243	2,100	9,198	6,400	34,127
2000	8,500	59,568	16,243	2,100	9,198	6,400	34,127
01	8,500	59,568	16,243	2,100	9,198	6,400	34,127
02	8,500	59,568	16,243	2,100	9,198	6,400	34,127
03	8,500	59,568	16,243	2,100	9,198	6,400	34,127
04	8,500	59,568	16,243	2,100	9,198	6,400	34,127
05	8,500	59,568	16,243	2,100	9,198	6,400	34,127
06	8,500	59,568	16,243	2,100	9,198	6,400	34,127
07	8,500	59,568	16,243	2,100	9,198	6,400	34,127

V. SCHEME OF DEVELOPMENT

CHAPTER V SCHEME OF DEVELOPMENT

5.1 Optimum Development Plan

5.1.1 Basic Considerations in Planning

The hydro-electric power plant will supply electricity required for operation of the Rio Tuba Mine, and at the same time supply electricity to local residents for domestic use. Although an exact figure has not yet been determined, approximately 7.5MW is preferable for mine operation. However, from the viewpoint of economic head and discharge of the Tamlang River at the optimum hydropower development site, power output will be limited to approximately 4MW. To compensate for the resultant shortage in output, use of the existing diesel generators will be continued on an auxiliary basis. At the same time, development of an additional hydropower site or of another electrical power source is urgently required. To be considered economically feasible, hydropower costs must be less than costs for the selected alternative energy source, namely diesel, coal or alternative power plant.

As for domestic electric supply, the Project must satisfy future demand increases, including electrification of rural communities which presently lack any electric facilities, and also supplement older PALECO diesel generators, contributing about 1MW to PALECO's demand and thus reducing fees.

From the viewpoint of immediate benefits, a plan with low preliminary capital cost is preferable. In consideration of future increases in fuel prices and unreliable supply for energy sources other than hydropower however, the Project should be evaluated not on simple construction costs per kW and kWh of the hydropower plant alone but rather on the benefit/cost ratio where benefit is equivalent to the unit cost per kW and kWh for the alternative power plant.

Although the run-of-river type generation method is generally used for mini-hydropower, from the viewpoint of low dry season discharge and power demand characteristics, comparative study of a canal type with regulating pond is necessary for selection of the most appropriate plan. The proposed power plant is to serve both the mine and local residents and will be located approximately 44km from the mine. The power station will

have a full-time supervision system with a simple and maintenance free automatic control system.

5.1.2 Comparative Cost Analysis for Alternative Power Generation Plant and Determination of Benefit Value of kW and kWh

The Rio Tuba Mining Corporation is presently investigating new electrical smelting processes to reduce production costs and thus increase the viability of the mine. Comparative study of power sources other than hydro including diesel, coal, oil, wood, and geothermal plants, was conducted for a 10MW scale electric power generation system and a coal-fired plant was selected as the most suitable plant for the following reasons:

- a) coal has the highest overall reliability in terms of supply and efficiency;
- b) diesel generation is considered a supplementary rather than a main power source;
- c) petroleum is too expensive;
- d) combined use of coal and wood for fuel is possible, but supply of firewood is insufficient and cost is too high for economic use;
- e) geothermal power development is considered to be costly with lengthy implementation and should particularly be avoided by private enterprises; and,
- f) cost and supply of coal is likely to remain stable for a long period of time.

For the above reasons therefore, fixed cost and fuel cost (variable cost) for a 10MW coal-fired thermal plant should be selected for comparative cost analysis to determine the optimum scale of hydropower development plan. However, a diesel power plant was adopted for comparative cost analysis or benefit value of kW and kWh in place of the above 10MW coal-fired thermal plant due to the following points; i) ash treatment is comparatively difficult; ii) small plant capacity results in a higher power cost; iii) power cost of diesel and coal plants is almost the same; and, iv) investment cost for the diesel plant is smaller than that for the plant.

Although use of equal scale diesel and hydropower plants in comparative analysis is generally desirable, a 10MW scale plant was selected for the diesel plant as a plant smaller than 10MW would result in higher estimated production costs and would be conservative (Detailed


Project economic evaluation is presented in Chapters VII and VIII). The result of above study is shown in TABLE 5-1.

5.1.3 Optimum Development Plan


A case study was conducted to determine the optimum development scheme, comparing run-of-river and canal with regulating pond type generation methods. A total of 15 cases were compared including 3 different maximum turbine discharges with 2 intake water levels for the former, and 3 maximum turbine discharges with 3 different dam heights for the latter. On the basis of unit construction cost and benefit/cost ratio for each case, and after overall evaluation of capital cost, plant management, operation and maintenance, and effective use of the island's limited water resources, Case 5 was judged the optimum development plan (Refer to TABLE 5-2 and FIG. 5-1).

Optimum benefit/cost ratio for each case is obtained with a maximum turbine discharge of $5\text{m}^3/\text{s}$. However, in the event of 24-hour mine operation, the yearly period in which the said turbine discharge is available is greatly reduced while unit kWh costs correspondingly increase. For this reason, a maximum turbine discharge of less than $5\text{m}^3/\text{s}$ was adopted. An outline of the development plan for Case-5 is presented in TABLE 5-3.

FIG. 5.1 STUDY OF SCALE



UNIT CONSTRUCTION COST (¥/KWH)



Cost Benefit (B/C)

TABLE 5-1 COMPARATIVE COST ANALYSIS

As of Feb. 1984 (1 US\$/14 ¥/233 ¥)

Description	Unit	Remarks
I. Diesel Plant		
-Plant Capacity	5,000kW x 2	
-Standard Annual Operation	7,000Hr	Assumed Plant Factor 80%
-Service Life	15 years	
-Generator Terminal Output	70 GWH	
-Plant Energy Consumption	18%	
-Annual Produced Energy	$70 \times (1-0.18) = 57.4$ GWH	Including Re-investment Cost after 15 years
-Construction Cost	2.18×10^6 yen	
<u>Annual Cost</u>		
II. Fixed Charge		
1) Capital Recovery Cost.	$2,118 \times 10^6 \times 0.124 = 262.63 \times 10^6$ yen	Interest 9%, C.V.F. = 0.124
2) O & M and Administrative Cost	$2,118 \times 10^6 \times 0.03 = 63.54 \times 10^6$ yen	Ratio 3.0%
3) Total Fixed Charge	326.17×10^6 yen	1) + 2)
4) Unit Fixed Charge Per kW	32,620 yen	
5) kW value	$32,620 \times 1.06 = 34,577$ yen/kW	*Revised Factor, per kW Value $\alpha = 1.06$
III. Variable Cost		
1) Fuel Cost	38.12 yen/¥	
2) Fuel Consumption per KWH	0.329 ¥/KWH	
3) Unit Cost per KWH	$38.12 \times 0.329 = 12.54$ yen/KWH	
4) KWH Value	$12.54 / (1-0.18) = 15.29$ yen/KWH	*Revised Factor for KWH Value $\beta = 1.00$
<u>Assumption</u>		
Transmission Loss	Hydro 4.0%	Diesel 1.0%
Fault	-	2.0
Station Service Use	0.3	3.0
Check and Repair	2.0	6.0
$\alpha = \frac{(1-0.04) \times (1-0.003) \times (1-0.02)}{(1-0.01) \times (1-0.002) \times (1-0.03)} \times (1-0.06)$		$= 1.06$
$\beta = \frac{(1-0.04) \times (1-0.003)}{(1-0.01) \times (1-0.03)}$		$= 1.00$

TABLE 5-2. COMPARISON OF DEVELOPMENT SCALE

ALTERNATIVE	CANAL WITH REGULATING POND TYPE										RUN-OF-RIVER-TYPE								
	190	185	180	175	170	165	160	155	150	145	140	135	130	125	120	115	110	105	100
DAM CREST EL. m	190	185	180	175	170	165	160	155	150	145	140	135	130	125	120	115	110	105	100
CASE	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15				
INTAKE EL. m	194.1	188.7	183.3	177.9	172.5	167.1	161.7	156.3	150.9	145.5	140.1	134.7	129.3	123.9	118.5	113.1	107.7	102.3	96.9
OUTLET EL. "	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0	85.0
EFFECTIVE HEAD "	106.6	106.9	107.2	102.0	102.3	102.6	96.4	96.7	98.0	101.0	101.0	101.0	101.0	68.0	68.0	68.0	68.0	68.0	68.0
MAXIMUM DISCHARGE m ³ /s	5.0	4.5	4.0	5.0	4.5	4.0	4.0	5.0	4.5	4.0	4.5	3.5	4.5	4.0	3.5				
MAXIMUM OUTPUT KW	4,390	3,960	3,530	4,200	3,790	3,380	3,970	3,580	3,230	3,740	3,320	2,910	2,520	2,240	1,950				
GENERATING CAPACITY 10 ⁶ kWh	21.90	21.44	20.76	20.95	20.51	19.87	19.81	19.39	18.98	17.38	17.33	16.54	12.93	12.88	12.33				
CONSTRUCTION COST 10 ⁶ ¥	4,450	4,350	4,280	4,030	3,920	3,840	3,820	3,730	3,660	3,240	3,168	3,108	2,588	2,526	2,472				
CONSTRUCTION COST PER KWH ¥/kWh	203.2	202.9	206.2	192.3	191.1	193.3	192.9	192.4	192.9	186.5	182.8	187.9	200.0	196.1	200.5				
BENEFIT/COST RATIO B/C	1.020	0.997	0.959	1.077	1.058	1.022	1.076	1.053	1.023	0.860	0.867	0.837	0.793	0.801	0.771				

TABLE 5-3

OUTLINE OF DEVELOPMENT PLAN

ITEM	DESCRIPTION	REMARKS
Name of River	Tamlang River	
Power Plant Location	Brookes Point	
Catchment Area (km ²)	39.0	
POWER PLANT SCHEME		
Generation Method	Canal Type with Regulating Pond	
Intake Water Level (m)	188.7	At Maximum Output
Tailrace Water Level(m)	85.0	"
Gross Head (m)	103.7	
Maximum Output (kW)	3,800	
Maximum Discharge (m ³ /s)	4.50	
Effective Head (m)	101.3	At Maximum Output
Annual Produced Energy (GWH)	20.51	
OUTLINE OF FACILITIES		
Regulating Pond		
Maximum high water level (m)	188.7	
Available depth (m)	1.8	
Effective capacity (10 ³ m ³)	360	
Dam		
Type	Concrete Gravity Dam	
Height (m)	46.0	
Crest length (m)	49.0	
Dam concrete volume (m ³)	17,000	
Headrace length (m)	1,493	Including Pressure Pipe
Tailrace Length (m)	300	

**VI. POWER PLANT: COST AND
CONSTRUCTION IMPLEMENTATION**

CHAPTER VI POWER PLANT; COST AND CONSTRUCTION IMPLEMENTATION

6.1 Power Plant

6.1.1 Main Structures

The main structures of the Project are dam, diversion tunnel, penstock and power plant. These structures are explained in brief below, while related preliminary designs are presented in APPENDIX I as FIG. 4-1, 4-3, 4-4, 4-7 and 4-9.

(1) Dam

Type	: concrete gravity dam
Height	: 46.0m
Length	: 49.0m
Design Flood	: 505m ³ /s
Overflow Width	: 25.0m
Overflow Depth	: 4.7m

An automatic inflatable rubber dam 3.7m in height will be installed at overflow crest to increase the available head. The upstream dam face will have a slope of 0.2 while the downstream face will be 0.8.

(2) Diversion Tunnel

The tunnel section will be rectangular horseshoe shaped with a bottom width of about 4.0m to allow use as an access road during construction. Approximately 70% of the total length will be unlined while 30% will be concrete lined.

Tunnel Length	: 1,277m
Lined Canal Slope	: 1/1,000

(3) Penstock

A 1.5m diameter FRPM (Fiberglass Reinforced Plastic Mortar Pipe) will be used for the penstock which will be embedded.

(4) Power Plant

The river side of the powerhouse building will be waterproof to ensure water tightness for the horizontal-shaft turbine during floods.

Powerhouse	: 8.5m x 16.0m
------------	----------------

6.1.2 Main Electrical Facilities

The main electrical facilities of the Project are provided below.

(1) Dam

Type : 1 horizontal-shaft,
Francis-type turbine
Maximum Output : 4,000kW (turbine efficiency = 91.1%)
Maximum Discharge : 4.5m³/s
Rotation Speed : 720RPM
Speed with
Closed Governor : 2.5s

(2) Generator

Type : 1 horizontal axis 3-phase alternating
current synchronized generator
Output : 4,700 kVA
Voltage : 4.16kV
Power Ratio : 0.81
Frequency : 60HZ

(3) Main Transformer

Type : 2 outdoor, 3-phase, self-cooling type
transformers
Capacity : 4,700kVA
Voltage: : 4.16/34.5 + 5%kV

(4) Transmission Line

No. of Circuits : 1
Cables : Aluminum Cable Steel Reinforced (ACSR)
176.9MCM (89.7mm²)
Insulators : 4 suspension insulators (250mm)
Overhead Ground Wire: 1 zinc-coated steel cable AWG 2
(33.62mm²)
Support : Wood pole
Voltage : 34.5kV
Total Length : 44km

6.2 Estimated Construction Cost

Estimated construction costs have been worked out in terms of the 1984 price index and are presented hereunder.

(1)	<u>Civil Construction Costs</u>	unit: million yen
	Dam	1,333.9
	Intake	70.3
	Diversion Tunnel	737.4
	Surge Tank	93.6
	Penstock	63.9
	Diversion Channel	65.5
	Powerhouse (building and equipment foundation)	293.7
(2)	<u>Electrical Facilities</u>	
	Power Plant Equipment (turbine, generator)	448.0
	Transmission Line	165.0
(3)	<u>Technical Maintenance Cost</u>	300.0
(4)	<u>Contingency</u> (including land compensation)	278.7
(5)	<u>Cost Escalation</u>	181.3
	Total	4,031.3

6.3 Annual Disbursement Schedule

The construction period required is estimated to be approximately 4 years. The annual disbursement schedule is shown in the following table and the total construction cost is about 4,000 million yen.

ANNUAL DISBURSEMENT SCHEDULE

Unit: million. yen

Item	Year	1st	2nd	3rd	4th	Total
Civil Construction		1,030.4	1,174.0	159.9	294.0	2,658.3
Electrical Facilities		44.8	358.4	-	44.8	448.0
Transmission Line		16.5	132.0	-	16.5	165.0
Contingency		60.6	184.0	25.1	-	278.7
Engineering Services		120.0	120.0	60.0	-	300.0
Cost Escalation		105.7	73.8	1.8	-	181.3
Total		1,387.0	2,042.2	246.8	355.3	4,031.3

6.4 Implementation Schedule

The envisaged implementation schedule is presented in TABLE 6-1 and shows a period of approximately 28 months commencing upon award of contract as required for completion of the same. Approximately one year will be required prior to contract award for lining up financing, preparation of detailed design works, tender bidding and tender evaluation.

VII. FINANCIAL ANALYSIS

CHAPTER VII FINANCIAL ANALYSIS

7.1 General

The objective of project analysis, or financial and economic analysis, methods of which were developed primarily by UNIDO and OECD, is efficient allocation of scarce resources (usually potential capital for investment). These methods have been adopted by all international financing and bilateral aid agencies in implementation of feasibility studies.

Originally, both methods were developed to analyse such production sectors as industry and agriculture, etc. Evaluation of feasibility and infeasibility thus depended upon whether a certain standard of surplus benefit by production could be achieved during the project life. One indicator used to express this standard is Internal Rate of Return (IRR). Application of this approach has been expanded, mainly by the World Bank Group, to evaluate such sectors as infrastructure and utility in which neither transactions nor competitive market prices exist.

In project analysis of those sectors, for example, benefit is often measured by cost savings with other second best alternatives, while turnover of the products is regarded as project benefit in the evaluation of production sectors. Likewise, in communication projects, consumer surplus is regarded as benefit.

It should be noted that IRR is affected by identification of benefits for each project. IRR is thus often inappropriate as a standard for selection of optimum resource allocation of projects in the same sector as well as in different sectors. Most feasibility studies of power projects in Japan, for example, have adopted costs of alternative power plants using different energy sources (opportunity costs of capital) as a project benefit. In this case, different and more accurate values of IRR could be obtained as compared to internationally recognized cases where the savings in operation and maintenance (O & M) or revenues from electric rates are regarded as benefits of power projects.

It is therefore essential not to merely compare values of benefit but to clearly identify the benefit used in the evaluation for determining whether a newly proposed project should be implemented or not.

7.2 Conditions of Financial Analysis

Financial analysis of a project compares benefit expressed as revenues, and costs expressed as expenditures from the perspective of the implementation agencies of the project. In financial analysis of a power project, investment and O & M costs are generally regarded as expenditures while sale of electricity is regarded as revenue. However, unlike ordinary projects, in the proposed Tamlang River Hydropower Project, electricity will be supplied by a dual system to two groups of consumers; neighbouring rural residents who are or will be served through PALECO, and the Rio Tuba Mine. Revenues for the former are equivalent to total power rates to be collected from end-users. For the latter, however, no such revenues exist; rather power production is regarded as one item of mine operation costs.

Projects are generally formulated corresponding to present and future demand. In this case, however, future demand for the Rio Tuba Mine itself has not yet been clearly determined. The primary reason for initiating the present study was to reduce power production costs by conversion to hydropower generation, and in addition, to provide an inexpensive electric supply for future expected demand for the envisioned new smelting plant. However, the smelting plant is still under study, and the present report will likely be a contributing factor in determination of scale, required electric energy, etc. Accordingly, financial analysis of this Project is necessarily different from ordinary projects and conducted assuming three possible energy demand cases as described in Chapter 4.

Based upon the premises mentioned above, it might be appropriate to consider that the benefit for the Rio Tuba Mine itself should be as follows:

(1) Case-1: Substitution of Existing Diesel Generator

This case substitutes hydropower generation for supply by the existing diesel generator alone. Where energy consumption is for the Mine's own use, benefit is regarded as the difference or the savings in costs between the two cases, i.e., generation by the construction of a hydropower plant and generation by the existing diesel facilities without construction of a hydro plant.

(2) Case-2: Peak Load 3,600kW

As fulfillment of power demand during the dry season is impossible with the planned hydropower plant, this case compares O & M costs for generation by diesel facilities alone including installation of a new diesel power plant with two 1,500kW diesel generators and by the combination of a hydropower plant and existing diesel facilities. Difference in the said costs is regarded as benefit.

(3) Case-3: Peak Load 9,500kW

In this case, installation of additional generators is required for both cases not only in the dry season but also during the rainy season. Benefit for this case is determined as for Case-2 in comparison of O & M costs with diesel facilities alone and combined use of the hydropower plant and existing diesel facilities.

Costs can be evaluated in the same way as benefit, the difference between construction and installation costs for the hydropower plant and for diesel plants being adopted as cost. Following the above framework in financial analysis, further considerations concerning benefit and costs for this Project are presented below, and are directly related to discussion in Chapter 4 and 5.

7.3 Benefit/Cost Calculation

7.3.1 Benefit

As stated above, Rio Tuba Mine revenues from sale of electricity to PALECO is regarded as benefit for rural electrification while the difference in cost between diesel generation only and combined use of hydro and diesel generation is regarded as benefit in the case of production by the Mine for its own consumption.

If electricity is supplied by public power corporations, the electric rate will be determined by Long-Run Marginal Costs (LRMC). In this Project, however, as electricity is supplied by a private company, the electric rate can be determined by multiplication of the capital recovery factor (CRF) and coefficients of maintenance and fair return for construction cost as practiced in Japan.

Therefore, system rates for the Project are as tabulated below.

Item	Unit	Amount	
Construction Cost	Yen	$4,031 \times 10^6$	
Available Electric Energy	kWh	$19,087 \times 10^3$	
Construction Cost	kWh	$(4,031 \times 10^6) \div (19,087 \times 10^3) = 211.2$	
CRF:		$0.045 \times (1 + 0.045)^{45}$	
			$= 0.0522 \quad 5.2\%$
		$(1 + 0.045)^{45} - 1$	
Maintenance Cost Coefficient			1.5%
Fair Return Coefficient			3.3%
			Total 10.0%
System Rate		$211.2 \text{ yen} \times 0.10 = 21.1 = 21.0 \text{ yen/kWh}$	

The above system rate is relatively inexpensive in comparison with the present PALECO system rate of 29.4 yen and that of NPC, 24.9 yen,^{1/} and consequently may be expected to contribute to reduction of present PALECO deficits. As for benefit of savings, the main component is savings resulting from reduction of diesel fuel use. According to the principles of project evaluation, increases in costs caused by inflation can be offset by the same effect on items of benefit. In cases where some specific costs of goods and/or services are expected explicitly to rise in relation to other costs and benefits, however, those costs can be allowed to escalate. According to 'Commodity Price Forecasts' by World Bank/IFC, oil-related energy prices during 1984-95 will increase by 1.8% annually in comparison with other principal items. Thus, a 1.8% annual escalation in diesel costs alone was adopted for this study^{2/}.

^{1/} Calculations based on PALECO's Annual Report and Profit and Loss Report.

^{2/} Commodity Price Forecasts (Revisions), The World Bank, Jan. 6, 1984. Calculated from P.11 Table 3 "Weighted Index of Commodity Prices".

7.3.2 Cost

As the difference in O & M cost was adopted as project benefit, cost was determined as the difference in costs for construction and replacement of equipment for hydropower generation (including cogeneration of hydro and diesel) and those for diesel generation alone. Moreover, residual cost of diesel generators at the end of project life was regarded as the same as removal costs.

Interest rates during the construction period have increasingly been considered in financial analysis for recent feasibility studies in Japan. The main reason seems to be facilitation of book-keeping and accounting, as well as evaluation by funding agencies after completion of the feasibility study. Project evaluation or internal rate of return in financial analysis, however, is in reality unrelated to interest rates or depreciation, evaluating only the rate of returns within the Project itself. Accordingly, interest rates during the construction period were not included within the present Report in conformity with the principles of project analysis.

Finally, project life for the hydropower generation facilities such as dam, generators, transmission lines, etc., is estimated at 45 years after completion of construction; residual costs in the last year of project implementation is estimated at zero.

In addition, a fixed depreciation method was adopted for the replaced diesel plant facilities and residual values were calculated at the final project year. However, although these residual values appear in the costs cash/flow column, these costs are minus by nature and are clearly considered as benefit.

7.4 Financial Internal Rate of Return (FIRR)

Based on the conditions outlined above, FIRR for each case were calculated as follows, details of which are presented in TABLE 7-1:

Case-1	Substitution of Existing Diesel Generator:	FIRR 3.2%
Case-2	Peak load 3,600kW	: " " 7.9%
Case-3	Peak load 9,500kW	: " " 9.0%

7.5 Sensitivity Analysis

Sensitivity analysis was conducted for Case 3 (peak load 9,500kW) which would be considered most realistic and achieved the highest FIRR. The following results were obtained:

- 10% increase in construction costs	8.1%
- 20% increase in construction costs	7.3
- fuel prices remain constant from 1984	7.8
- fuel prices increase 5% from 1984	11.4
- fuel prices increase 10% from 1984	15.6
- combination of first and third items above (worst case can be assumed)	6.2
- combination of first and forth items above	10.4

THREE CASE STUDIES FOR FIRR

Y	FIRM	HYDRO INV	DIESEL W/HY	DIESEL ONLY	HYDRO OM	ELECTRICITY
1	1985	1261000	0	0	0	0
2	1986	1968000	0	0	0	1731
3	1987	2450000	0	0	0	1913
4	1989	3560000	0	0	0	2092
5	1990	0	0	0	0	2212
6	1991	0	0	0	0	2319
7	1992	0	0	17600	0	2413
8	1993	0	0	0	0	2509
9	1994	0	0	0	0	2510
10	1995	0	105900	0	0	2616
11	1996	0	0	0	0	2844
12	1997	0	0	0	0	2844
13	1998	0	0	0	0	2844
14	2000	0	0	0	0	2844
15	2001	0	0	0	0	2844
16	2002	0	0	0	0	2844
17	2003	0	0	0	0	2844
18	2004	0	0	0	0	2844
19	2005	0	0	0	0	2844
20	2006	0	0	0	0	2844
21	2007	0	0	0	0	2844
22	2008	0	0	0	0	2844
23	2009	0	0	0	0	2844
24	2010	0	0	0	0	2844
25	2011	0	0	0	0	2844
26	2012	0	0	0	0	2844
27	2013	0	0	0	0	2844
28	2014	0	0	0	0	2844
29	2015	0	0	0	0	2844
30	2016	0	0	0	0	2844
31	2017	0	0	0	0	2844
32	2018	0	0	0	0	2844
33	2019	0	0	0	0	2844
34	2020	0	0	0	0	2844
35	2021	0	0	0	0	2844
36	2022	0	0	0	0	2844
37	2023	0	0	0	0	2844
38	2024	0	0	0	0	2844
39	2025	0	0	0	0	2844
40	2026	0	0	0	0	2844
41	2027	0	0	0	0	2844
42	2028	0	0	0	0	2844
43	2029	0	0	0	0	2844
44	2030	0	0	0	0	2844
45	2031	0	0	0	0	2844
46	2032	0	0	0	0	2844
47	2033	0	0	0	0	2844
48	2034	0	0	0	0	2844
49	2035	0	0	0	0	2844
50	2036	0	0	0	0	2844
51	2037	0	0	0	0	2844
52	2038	0	0	0	0	2844
53	2039	0	0	0	0	2844
54	2040	0	0	0	0	2844
55	2041	0	0	0	0	2844
56	2042	0	0	0	0	2844
57	2043	0	0	0	0	2844
58	2044	0	0	0	0	2844
59	2045	0	0	0	0	2844
60	2046	0	0	0	0	2844
61	2047	0	0	0	0	2844
62	2048	0	0	0	0	2844
63	2049	0	0	0	0	2844
64	2050	0	0	0	0	2844
65	2051	0	0	0	0	2844
66	2052	0	0	0	0	2844
67	2053	0	0	0	0	2844
68	2054	0	0	0	0	2844
69	2055	0	0	0	0	2844
70	2056	0	0	0	0	2844
71	2057	0	0	0	0	2844
72	2058	0	0	0	0	2844
73	2059	0	0	0	0	2844
74	2060	0	0	0	0	2844
75	2061	0	0	0	0	2844
76	2062	0	0	0	0	2844
77	2063	0	0	0	0	2844
78	2064	0	0	0	0	2844
79	2065	0	0	0	0	2844
80	2066	0	0	0	0	2844
81	2067	0	0	0	0	2844
82	2068	0	0	0	0	2844
83	2069	0	0	0	0	2844
84	2070	0	0	0	0	2844
85	2071	0	0	0	0	2844
86	2072	0	0	0	0	2844
87	2073	0	0	0	0	2844
88	2074	0	0	0	0	2844
89	2075	0	0	0	0	2844
90	2076	0	0	0	0	2844
91	2077	0	0	0	0	2844
92	2078	0	0	0	0	2844
93	2079	0	0	0	0	2844
94	2080	0	0	0	0	2844
95	2081	0	0	0	0	2844
96	2082	0	0	0	0	2844
97	2083	0	0	0	0	2844
98	2084	0	0	0	0	2844
99	2085	0	0	0	0	2844
100	2086	0	0	0	0	2844
101	2087	0	0	0	0	2844
102	2088	0	0	0	0	2844
103	2089	0	0	0	0	2844
104	2090	0	0	0	0	2844
105	2091	0	0	0	0	2844
106	2092	0	0	0	0	2844
107	2093	0	0	0	0	2844
108	2094	0	0	0	0	2844
109	2095	0	0	0	0	2844
110	2096	0	0	0	0	2844
111	2097	0	0	0	0	2844
112	2098	0	0	0	0	2844
113	2099	0	0	0	0	2844
114	2100	0	0	0	0	2844
115	2101	0	0	0	0	2844
116	2102	0	0	0	0	2844
117	2103	0	0	0	0	2844
118	2104	0	0	0	0	2844
119	2105	0	0	0	0	2844
120	2106	0	0	0	0	2844
121	2107	0	0	0	0	2844
122	2108	0	0	0	0	2844
123	2109	0	0	0	0	2844
124	2110	0	0	0	0	2844
125	2111	0	0	0	0	2844
126	2112	0	0	0	0	2844
127	2113	0	0	0	0	2844
128	2114	0	0	0	0	2844
129	2115	0	0	0	0	2844
130	2116	0	0	0	0	2844
131	2117	0	0	0	0	2844
132	2118	0	0	0	0	2844
133	2119	0	0	0	0	2844
134	2120	0	0	0	0	2844
135	2121	0	0	0	0	2844
136	2122	0	0	0	0	2844
137	2123	0	0	0	0	2844
138	2124	0	0	0	0	2844
139	2125	0	0	0	0	2844
140	2126	0	0	0	0	2844
141	2127	0	0	0	0	2844
142	2128	0	0	0	0	2844
143	2129	0	0	0	0	2844
144	2130	0	0	0	0	2844
145	2131	0	0	0	0	2844
146	2132	0	0	0	0	2844
147	2133	0	0	0	0	2844
148	2134	0	0	0	0	2844
149	2135	0	0	0	0	2844
150	2136	0	0	0	0	2844
151	2137	0	0	0	0	2844
152	2138	0	0	0	0	2844
153	2139	0	0	0	0	2844
154	2140	0	0	0	0	2844
155	2141	0	0	0	0	2844
156	2142	0	0	0	0	2844
157	2143	0	0	0	0	2844
158	2144	0	0	0	0	2844
159	2145	0	0	0	0	2844
160	2146	0	0	0	0	2844
161	2147	0	0	0	0	2844
162	2148	0	0	0	0	2844
163	2149	0	0	0	0	2844
164	2150	0	0	0	0	2844
165	2151	0	0	0	0	2844
166	2152	0	0	0	0	2844
167	2153	0	0	0	0	2844
168	2154	0	0	0	0	2844
169	2155	0	0	0	0	2844
170	2156	0	0	0	0	2844
171	2157	0	0	0	0	2844
172	2158	0	0	0	0	2844
173	2159	0	0	0	0	2844
174	2160	0	0	0	0	2844
175	2161	0	0	0	0	2844
176	2162	0	0	0	0	2844
177	2163	0	0	0	0	2844
178	2164	0	0	0	0	2844
179	2165	0	0	0	0	2844
180	2166	0	0	0	0	2844
181	2167	0	0	0	0	2844
182	2168	0	0	0	0	2844
183	2169	0	0	0	0	2844
184	2170	0	0	0	0	2844
185	2171	0	0	0	0	2844
186	2172	0	0	0	0	2844
187	2173	0	0	0	0	2844
188	2174	0	0	0	0	2844
189	2175	0	0	0	0	2844
190	2176	0	0	0	0	2844
191	2177	0	0	0	0	2844
192	2178	0				

Y	EL CT REVENUE	MUH DSL ONLY	MUH DSL W/HY	D ONLY OM	D W/HY OM
1985	000	000	000	000	000
1986	6351	19645	2289	34403	64857
1987	40173	19645	2289	37958	69048
1988	47974	19645	2289	37509	73356
1989	48699	19645	2289	35075	76575
1990	50673	19645	2289	36215	79675
1991	50673	19645	2289	36801	82606
1992	52689	19645	2289	37997	85665
1993	52689	19645	2289	38003	88920
1994	54810	19645	2289	38621	92420
1995	55724	19645	2289	38621	96416
1996	55724	19645	2289	38621	96416
1997	55724	19645	2289	38621	96416
1998	55724	19645	2289	38621	96416
1999	55724	19645	2289	38621	96416
2000	55724	19645	2289	38621	96416
2001	55724	19645	2289	38621	96416
2002	55724	19645	2289	38621	96416
2003	55724	19645	2289	38621	96416
2004	55724	19645	2289	38621	96416
2005	55724	19645	2289	38621	96416
2006	55724	19645	2289	38621	96416
2007	55724	19645	2289	38621	96416
2008	55724	19645	2289	38621	96416
2009	55724	19645	2289	38621	96416
2010	55724	19645	2289	38621	96416
2011	55724	19645	2289	38621	96416
2012	55724	19645	2289	38621	96416
2013	55724	19645	2289	38621	96416
2014	55724	19645	2289	38621	96416
2015	55724	19645	2289	38621	96416
2016	55724	19645	2289	38621	96416
2017	55724	19645	2289	38621	96416
2018	55724	19645	2289	38621	96416
2019	55724	19645	2289	38621	96416
2020	55724	19645	2289	38621	96416
2021	55724	19645	2289	38621	96416
2022	55724	19645	2289	38621	96416
2023	55724	19645	2289	38621	96416
2024	55724	19645	2289	38621	96416
2025	55724	19645	2289	38621	96416
2026	55724	19645	2289	38621	96416
2027	55724	19645	2289	38621	96416
2028	55724	19645	2289	38621	96416
2029	55724	19645	2289	38621	96416
2030	55724	19645	2289	38621	96416

Y	CASH FLOW	COST SAVING	BENEFIT	COST
1985	1281000	0	0	1281000
1986	1968000	0	0	1968000
1987	214000	0	0	214000
1988	2150887	09546	45897	356000
1989	2250625	110740	250826	0
1990	2250625	114182	270635	0
1991	2250625	117322	295431	0
1992	2270220	119552	273022	0
1993	2277741	225052	277741	0
1994	2280709	229799	280308	0
1995	2282877	229799	284607	105900
1996	2286952	229799	289523	0
1997	2289523	229799	289523	0
1998	2290723	229799	289523	408000
1999	2290723	229799	289523	0
2000	2290723	229799	289523	0
2001	2290723	229799	289523	0
2002	2290723	229799	289523	0
2003	2290723	229799	289523	0
2004	2290723	229799	289523	0
2005	2290723	229799	289523	0
2006	2290723	229799	289523	0
2007	2290723	229799	289523	0
2008	2290723	229799	289523	0
2009	2290723	229799	289523	0
2010	2290723	229799	289523	0
2011	2290723	229799	289523	0
2012	2290723	229799	289523	0
2013	2290723	229799	289523	0
2014	2290723	229799	289523	0
2015	2290723	229799	289523	0
2016	2290723	229799	289523	0
2017	2290723	229799	289523	0
2018	2290723	229799	289523	0
2019	2290723	229799	289523	0
2020	2290723	229799	289523	0
2021	2290723	229799	289523	0
2022	2290723	229799	289523	0
2023	2290723	229799	289523	0
2024	2290723	229799	289523	0
2025	2290723	229799	289523	0
2026	2290723	229799	289523	0
2027	2290723	229799	289523	0
2028	2290723	229799	289523	0
2029	2290723	229799	289523	167326

INTERNAL RATE OF RETURN IS 1.07869121998192
PRESENT VALUE IS -.08991000022888184

FTIF NAME/PAI A3-1

TIME/15:33:36

FILE PRINT OUT DATE/59/07/07

Y	HYDRO INV	DIESEL W/ HY	DIESEL ONLY	HYDRO OM	ELECTRICITY
1	1985	0	0	0	0
2	1986	594000	0	0	1774
3	1987	0	0	0	1943
4	1988	0	0	0	2094
5	1989	0	0	0	2212
6	1990	264000	384000	0	2319
7	1991	0	0	0	2413
8	1992	0	0	0	2413
9	1993	0	0	0	2509
10	1994	0	0	0	2610
11	1995	0	0	0	2718
12	1996	0	0	0	2844
13	1997	0	0	0	2844
14	1998	0	0	0	2844
15	1999	0	0	0	2844
16	2000	0	0	0	2844
17	2001	528000	152000	0	2844
18	2002	0	0	0	2844
19	2003	0	0	0	2844
20	2004	0	0	0	2844
21	2005	0	0	0	2844
22	2006	264000	384000	0	2844
23	2007	0	0	0	2844
24	2008	0	0	0	2844
25	2009	0	0	0	2844
26	2010	0	0	0	2844
27	2011	0	0	0	2844
28	2012	0	0	0	2844
29	2013	0	0	0	2844
30	2014	0	0	0	2844
31	2015	528000	152000	0	2844
32	2016	0	0	0	2844
33	2017	0	0	0	2844
34	2018	0	0	0	2844
35	2019	0	0	0	2844
36	2020	0	0	0	2844
37	2021	0	0	0	2844
38	2022	0	0	0	2844
39	2023	0	0	0	2844
40	2024	0	0	0	2844
41	2025	0	0	0	2844
42	2026	0	0	0	2844
43	2027	0	0	0	2844
44	2028	0	0	0	2844
45	2029	0	0	0	2844
46	2030	0	0	0	2844
47	2031	0	0	0	2844
48	2032	0	0	0	2844
49	2033	0	0	0	2844
50	2034	0	0	0	2844
51	2035	0	0	0	2844
52	2036	0	0	0	2844
53	2037	0	0	0	2844
54	2038	0	0	0	2844
55	2039	0	0	0	2844
56	2040	0	0	0	2844
57	2041	0	0	0	2844
58	2042	0	0	0	2844
59	2043	0	0	0	2844
60	2044	0	0	0	2844
61	2045	0	0	0	2844
62	2046	0	0	0	2844
63	2047	0	0	0	2844
64	2048	0	0	0	2844
65	2049	0	0	0	2844
66	2050	0	0	0	2844
67	2051	0	0	0	2844
68	2052	0	0	0	2844
69	2053	0	0	0	2844
70	2054	0	0	0	2844
71	2055	0	0	0	2844
72	2056	0	0	0	2844
73	2057	0	0	0	2844
74	2058	0	0	0	2844
75	2059	0	0	0	2844
76	2060	0	0	0	2844
77	2061	0	0	0	2844
78	2062	0	0	0	2844
79	2063	0	0	0	2844
80	2064	0	0	0	2844
81	2065	0	0	0	2844
82	2066	0	0	0	2844
83	2067	0	0	0	2844
84	2068	0	0	0	2844
85	2069	0	0	0	2844
86	2070	0	0	0	2844
87	2071	0	0	0	2844
88	2072	0	0	0	2844
89	2073	0	0	0	2844
90	2074	0	0	0	2844
91	2075	0	0	0	2844
92	2076	0	0	0	2844
93	2077	0	0	0	2844
94	2078	0	0	0	2844
95	2079	0	0	0	2844
96	2080	0	0	0	2844
97	2081	0	0	0	2844
98	2082	0	0	0	2844
99	2083	0	0	0	2844
100	2084	0	0	0	2844
101	2085	0	0	0	2844
102	2086	0	0	0	2844
103	2087	0	0	0	2844
104	2088	0	0	0	2844
105	2089	0	0	0	2844
106	2090	0	0	0	2844
107	2091	0	0	0	2844
108	2092	0	0	0	2844
109	2093	0	0	0	2844
110	2094	0	0	0	2844
111	2095	0	0	0	2844
112	2096	0	0	0	2844
113	2097	0	0	0	2844
114	2098	0	0	0	2844
115	2099	0	0	0	2844
116	2100	0	0	0	2844
117	2101	0	0	0	2844
118	2102	0	0	0	2844
119	2103	0	0	0	2844
120	2104	0	0	0	2844
121	2105	0	0	0	2844
122	2106	0	0	0	2844
123	2107	0	0	0	2844
124	2108	0	0	0	2844
125	2109	0	0	0	2844
126	2110	0	0	0	2844
127	2111	0	0	0	2844
128	2112	0	0	0	2844
129	2113	0	0	0	2844
130	2114	0	0	0	2844
131	2115	0	0	0	2844
132	2116	0	0	0	2844
133	2117	0	0	0	2844
134	2118	0	0	0	2844
135	2119	0	0	0	2844
136	2120	0	0	0	2844
137	2121	0	0	0	2844
138	2122	0	0	0	2844
139	2123	0	0	0	2844
140	2124	0	0	0	2844
141	2125	0	0	0	2844
142	2126	0	0	0	2844
143	2127	0	0	0	2844
144	2128	0	0	0	2844
145	2129	0	0	0	2844
146	2130	0	0	0	2844
147	2131	0	0	0	2844
148	2132	0	0	0	2844
149	2133	0	0	0	2844
150	2134	0	0	0	2844
151	2135	0	0	0	2844
152	2136	0	0	0	2844
153	2137	0	0	0	2844
154	2138	0	0	0	2844
155	2139	0	0	0	2844
156	2140	0	0	0	2844
157	2141	0	0	0	2844
158	2142	0	0	0	2844
159	2143	0	0	0	2844
160	2144	0	0	0	2844
161	2145	0	0	0	2844
162	2146	0	0	0	2844
163	2147	0	0	0	2844
164	2148	0	0	0	2844
165	2149	0	0	0	2844
166	2150	0	0	0	2844
167	2151	0	0	0	2844
168	2152	0	0	0	2844
169	2153	0	0	0	2844
170	2154	0	0	0	2844
171	2155	0	0	0	2844
172	2156	0	0	0	2844
173	2157	0	0	0	2844
174	2158	0	0	0	2844
175	2159	0	0	0	2844
176	2160	0	0	0	2844
177	2161	0	0	0	2844
178	2162	0	0	0	2844
179	2163	0	0	0	2844
180	2164	0	0	0	2844
181	2165	0	0	0	2844
182	2166	0	0	0	2844
183	2167	0	0	0	2844
184	2168	0	0	0	2844
185	2169	0	0	0	2844
186	2170	0	0	0	2844
187	2171	0	0	0	2844
188	2172	0	0	0	2844
189	2173	0	0	0	2844
190	2174	0	0	0	2844
191	2175	0	0	0	2844
192	2176	0	0	0	2844
193	2177	0	0	0	2844
194	2178	0	0	0	2844
195	2179	0	0	0	2844
196	2180	0	0	0	2844
197	2181	0	0	0	2844
198	2182	0	0	0	2844
199	2183	0	0	0	2844
200	2184	0	0	0	2844
201	2185	0	0	0	2844
202	2186	0	0	0	2844
203	2187	0	0	0	2844
204	2188	0	0	0	2844
205	2189	0	0	0	2844
206	2190	0	0	0	2844
207	2191	0	0	0	2844
208	2192	0	0	0	2844
209	2193	0	0	0	2844
210	2194	0	0	0	2844
211	2195	0	0	0	2844
212	2196	0	0	0	2844
213	2197	0	0	0	2844
214	2198	0	0	0	2844
215	2199	0	0	0	2844
216	2200	0	0	0	2844
217	2201	0	0	0	2844
218	2202	0	0	0	2844
219	2203	0	0	0	2844
220	2204	0	0	0	2844
221	2205	0	0	0	2844
222	2206	0	0	0	2844
223	2207	0	0	0	2844
224	2208	0	0	0	2844
225	2209	0	0	0	2844
226	2210	0	0	0	2844
227	2211	0	0	0	2844
228	2212	0	0	0	2844
229	2213	0	0	0	2844
230	2214	0	0	0	2844
231	2215	0	0	0	2844
232	2216	0	0	0	2844
233	2217	0	0	0	2844
234	2218	0	0	0	2844
235	2219	0	0	0	2844
236	2220	0	0	0	2844
237	2221	0	0	0	2844
238	2222	0	0	0	2844
239	2223	0	0	0	2844
240	2224	0	0	0	2844
241	2225	0	0	0	2844
242	2226	0	0	0	2844
243	2227	0	0	0	2844
244	2228	0	0	0	2844
245	2229	0	0	0	2844
246	2230	0	0	0	2844
247	2231	0	0	0	2844
248	2232	0	0	0	2844

Y	COST SAVING	BENEFIT	COST	CASH FLOW
1	0	0	1281000	-1281000
2	0	0	1968000	-1968000
3	711111	674662	457000	-457000
4	233036	273209	0	273209
5	234961	278935	0	278935
6	240969	284788	0	284788
7	247341	290714	120000	209514
8	254198	296767	0	296767
9	257096	303677	0	303677
10	257096	311474	0	311474
11	257096	316820	0	316820
12	257096	316820	0	316820
13	257096	316820	624000	254420
14	257096	316820	0	316820
15	257096	316820	0	316820
16	257096	316820	0	316820
17	257096	316820	0	316820
18	257096	316820	0	316820
19	257096	316820	0	316820
20	257096	316820	0	316820
21	257096	316820	0	316820
22	257096	316820	0	316820
23	257096	316820	0	316820
24	257096	316820	0	316820
25	257096	316820	0	316820
26	257096	316820	0	316820
27	257096	316820	0	316820
28	257096	316820	0	316820
29	257096	316820	0	316820
30	257096	316820	0	316820
31	257096	316820	0	316820
32	257096	316820	0	316820
33	257096	316820	0	316820
34	257096	316820	0	316820
35	257096	316820	0	316820
36	257096	316820	0	316820
37	257096	316820	0	316820
38	257096	316820	0	316820
39	257096	316820	0	316820
40	257096	316820	0	316820
41	257096	316820	0	316820
42	257096	316820	0	316820
43	257096	316820	0	316820
44	257096	316820	0	316820
45	257096	316820	244320	321650

INTERNAL RATE OF RETURN IS 1.090402494952135
PRESENT VALUE IS -.06139588356018066

VIII. ECONOMIC ANALYSIS

CHAPTER VIII ECONOMIC ANALYSIS

8.1 Approach

Financial analysis focuses on profitability of project implementation itself while economic analysis on the other hand, studies the degree of benefit to the national economy resulting from project implementation. As in financial analysis, benefit and cost are estimated first. In financial analysis, however, the same are expressed in terms of market price while in economic analysis they are expressed in terms of economic value (shadow price).

The economic benefit of electric power projects is actually the marginal value or productivity of economic activity arising from power output and the value of efficiency. It is almost impossible however, to quantify power output benefit in such terms especially for the latter. Accordingly, in lieu of the above, the cost of the second best alternative plan is often adopted as project benefit using the so-called "alternative facilities method" in many feasibility studies in Japan. The above calculation method is an application of the opportunity cost concept in which cost input into one project can be transferred to another project, thereby obtaining a different benefit.

In this Project, for example, benefit arising from implementation of a hydropower plan (With Project) should be compared to benefit which can be obtained by investing the same costs in other different types of opportunities (Without Project). In the "alternative facilities method", however, the cost for the alternative plan is not invested in other economic activities but in the same activities, and consequently this cost can not logically be considered as economic benefit. In this economic analysis therefore, as in financial analysis, benefit was divided into two kinds, economic prices of the savings in the case of Rio Tuba Mine's own use, and PALECO revenues from sale of electricity to rural residents in the case of rural electrification as explained below.

Actual quantification of efficiency for electric power use is impossible. A common method of estimating the same is the consumer's willingness to pay (WTP). However, for accurate evaluation of WTP, an interview survey, informing people of the efficiency of electricity,

should be conducted, which is a difficult task to accomplish in a limited period of time. On the other hand, except for those households which must bear the cost of long extension lines, the majority of households within electrified areas are being served by PALECO and there is no particular problem for PALECO in collection of system rates. In Brookes Point Municipality, for example, 97% of residential consumers pay their system rates at a fixed time. From this fact it can be assumed that the current rates are equivalent to or less than the willingness to pay for the residential consumer.

In addition, areas to be covered by this Project are unelectrified excluding a part of Brookes Point Municipality and the Rio Tuba Town Site, and almost all households use oil lamps for lighting and about 60% have transistor radios. Price of kerosene required for the lamps averages ₱3.3 (₱55) per 0.375ℓ according to the data collected in Sitios and Barangays, while minimum consumption is 1.6ℓ/month for 2-3 hours use per day, and, average purchase and cost reaches about 3.0ℓ/month and about ₱26.4/month (about ₱438/month), respectively. Battery consumption, moreover, averages approximately 5 batteries/month at about ₱3/battery, or a total monthly expenditure of ₱15. Kerosene and batteries are purchased at kiosks or weekly markets on specific days and some people must walk several kilometers to purchase the same.

In comparison to the above, minimum PALECO system rates as of March '84 were ₱31.10 (up to 12kWh) and few households are paying more than the minimum rates. Conversion from present kerosene and battery consumption to electricity will thus result in real and significant savings and sufficient willingness to pay may therefore also be assumed.

8.2 Benefit Estimates

8.2.1 Benefit for Rio Tuba Mine Use

As previously stated, benefit was expressed as the economic value of the savings in O & M costs. The majority of O & M costs consist of diesel fuel and its economic value is given in border prices. The Philippines has a large petroleum refining capacity, producing for both domestic consumption and an equivalent amount on consignment for PERTAMINA, the national oil company of Indonesia. Accordingly, FOB rather

than CIF prices are most appropriate for diesel border prices. FOB diesel prices in the Philippines are approximately US\$1 less per barrel (about 159%) than international prices (Singapore price) the average prices of which is US\$31.20/barrel as of February 1984^{1/}.

Although savings also occur in cost of lubricating oil and maintenance, the above are insignificant in comparison with costs of diesel fuel and can therefore be disregarded.

8.2.2 Residential Supply Benefit

Benefit of the proposed rural electrification was generally estimated as willingness to pay reflected by revenues from PALECO system rates. As the PALECO unit rate for residential consumers in economic analysis is estimated at ¥43.0/kWh (P2.59/kWh) versus the purchase rate of ¥21.0/kWh (P1.27kWh) from the Rio Tuba Mining Corp., a unit rate more than twice that of the financial analysis may be obtained, indicating a substantial benefit to the national economy.

8.3 Cost Estimates

Economic costs, as stated previously, are the difference in costs between construction of the hydropower generation plant (including auxiliary diesel generation) and the alternative diesel generation plant, expressed in terms of economic prices. Construction costs are divided into those paid in foreign currencies, and those paid in domestic currencies such as labor, fuel, etc. which are procured domestically. In principle, a portion of the Project will be in Japanese yen which is assumed to reflect economic price in a free competitive market. Distortion of market prices is presumed for the domestic portion, on the other hand, and shadow prices are used to convert to economic prices as presented below.

^{1/} Platt's Oilgram Price Report, Vol. 62 No. 33, McGraw-Hill Inc., N.Y., P6-A.

8.3.1 Tax

In economic analysis, taxes are regarded simply as the transfer of resources within the country itself and are therefore deducted from cost. As the Rio Tuba Mining Corp. is an export oriented enterprise and as the objective of the present plan is conversion of energy generation to non-oil consuming sources, the Project is exempted from import duties on capital goods according to Presidential Decree No.1789. Taxes for the present Project are, therefore, not included within costs for financial evaluation and conversion of the same to economic price is unnecessary.

8.3.2 Exchange Rate

Due to political and economic uncertainties, fluctuation in the exchange rate within the Philippines is rather large. A shadow exchange rate rather than the official rate is therefore used to convert domestic currency to foreign currency for economic analysis. Although the shadow exchange rate is obtained by a weighted average of past import-export duties and subsidies from the past few years, statistical data during the present study period was available only up to September '83, after which period the Philippine economy underwent significant change. Consequently, the shadow exchange rate derived by the above method will naturally vary from the exchange rate of February '84. For this reason, the shadow exchange rate used by NEDA (official rate x standard conversion factor of 1.2)^{1/} was adopted for the present Study as follows: US\$1 = P1, 4 x 1.2 = P16.8.

8.3.3 Labor Wage

Shadow wages are also used for unskilled labor. NEDA multiplies real wages by a coefficient of 0.80 to obtain shadow wages for unskilled labor. The above coefficient however, is the average for the entire country rather than for Palawan Island where underemployment is higher than average, and a lower coefficient should be required for opportunity costs of laborers.

^{1/} As explained by NEDA in a meeting of NEDA, Economic Staff and Infrastructure Staff on February 17, 1984.

Unskilled laborers on Palawan Island also receive the minimum wage fixed by the Philippine Government when they are hired as seasonal or day labor, and the total minimum wage is equivalent to P38 per day (minimum wage P20 plus daily allowances P18 per day). The Rio Tuba Mine employs about 480 unskilled laborers on a regular basis, and a monthly average of 70 unskilled laborers are employed on a seasonal basis. A survey of seasonal employees revealed that they were employed by the Mine for an average of three months per year with a total income of approximately P1,500 per person. Income for the remaining 9 months is derived from the sale of bananas, bamboo, chickens, etc., at the market, amounting to less than P100.

Seasonal employees are still more fortunate however, than those who are not employed as the majority of able workers are engaged in low household agricultural production. Non-cash economic activities such as fishing and hunting for supplementary food supply are also common. Accordingly, opportunity cost for unskilled labor in the present Report has been determined at an average of P1,500/year, with 300 working days a year and a P5/day shadow wage. The coefficient used therefore, is 0.13 rather than the NEDA value of 0.80.

8.3.4 Land

The proposed Project dam site is located on public land with no residences in the reservoir area, while, except for an application fee to NWRC for hydropower development, no payment to the government is required for the Project. For these reasons land acquisition and compensation costs were not included in calculations for the financial analysis of the present Report.

In economic evaluation, economic price is given by the opportunity cost of land or marginal productivities of land. The total area for reservoir pondage, temporary access roads, building etc. for the present Project is approximately 100,000m². The majority of the said area is unused jungle and accordingly any losses in economic land value due to temporary roads or ponding may be disregarded. Any items other than the above, such as use of temporary roads by local residents, should be regarded as benefit rather than loss. In the present Report therefore,

economic losses related to land use were regarded as minimal, offset by potential benefits and accordingly, as in financial analysis, land costs were regarded as zero.

8.3.5 Fuel

About 17% of domestic portions or costs for civil works consist of fuel costs. As in 8.2 above, the conversion of fuels to economic costs was performed by using border prices which were equivalent to the FOB price of US\$31.20/barrel.

8.4 Economic Internal Rate of Return (EIRR)

The EIRR for each case was calculated as follows according to the basic approach discussed above while details of the same are presented in TABLE 8-1 (1 to 9):

Case-1	Substitution of Existing Diesel Generator:	5.7%
Case-2	Peak Load 3,600kW	: 10.1
Case-3	Peak Load 9,500kW	: 11.6

Y-	COST SAVING	BENEFIT	COST	CASH FLOW
1985	0	0	0	0
1986	0	0	0	0
1987	0	0	0	0
1988	48964	119290	699000	-179000
1989	53394	131476	1671000	-179000
1990	58203	143719	285000	0
1991	63423	152831	0	0
1992	69072	168774	0	0
1993	75215	187052	0	0
1994	81889	209300	0	0
1995	89125	23944	0	0
1996	97070	29362	0	0
1997	97070	31623	0	0
1998	97070	34622	0	0
1999	97070	38622	0	0
2000	97070	43622	0	0
2001	97070	49622	0	0
2002	97070	56622	0	0
2003	97070	64622	0	0
2004	97070	73622	0	0
2005	97070	83622	0	0
2006	97070	94622	0	0
2007	97070	106622	0	0
2008	97070	119622	0	0
2009	97070	133622	0	0
2010	97070	148622	0	0
2011	97070	164622	0	0
2012	97070	181622	0	0
2013	97070	200622	0	0
2014	97070	221622	0	0
2015	97070	244622	0	0
2016	97070	269622	0	0
2017	97070	296622	0	0
2018	97070	325622	0	0
2019	97070	356622	0	0
2020	97070	389622	0	0
2021	97070	424622	0	0
2022	97070	461622	0	0
2023	97070	501622	0	0
2024	97070	544622	0	0
2025	97070	590622	0	0
2026	97070	639622	0	0
2027	97070	691622	0	0
2028	97070	746622	0	0
2029	97070	804622	0	0
2030	97070	865622	131172	88190

TIME/17:13:09

INTERNAL RATE OF RETURN IS 1.056883005194288
 PRESENT VALUE IS -1.3589859008789060-04
 PRINT OUT FILE

Y	FILE	PRINT OUT	DATE	FILE NAME/PAI A	HYDRO OM	DIESEL ONLY	DIESEL W/ HY	HYDRO INV	FILTRICITY
1	1985	999000	1985/07/07	FIRR CALCULATION	0	0	0	0	0
2	1986	1671000	1986/07/07	FIRR CALCULATION	402800	0	0	0	1731
3	1988	210000	1988/07/07	FIRR CALCULATION	49000	0	0	0	1913
4	1989	0	1989/07/07	FIRR CALCULATION	49000	0	0	0	2094
5	1991	0	1991/07/07	FIRR CALCULATION	49000	0	0	0	2212
6	1992	0	1992/07/07	FIRR CALCULATION	49000	265200	0	0	2319
7	1993	0	1993/07/07	FIRR CALCULATION	49000	0	0	0	2413
8	1994	0	1994/07/07	FIRR CALCULATION	49000	0	0	0	2509
9	1995	0	1995/07/07	FIRR CALCULATION	49000	0	0	0	2509
10	1997	0	1997/07/07	FIRR CALCULATION	49000	0	0	0	2610
11	1997	100300	1997/07/07	FIRR CALCULATION	49000	0	0	0	2718
12	1998	0	1998/07/07	FIRR CALCULATION	49000	0	0	0	2844
13	1998	0	1998/07/07	FIRR CALCULATION	49000	0	0	0	2844
14	1999	0	1999/07/07	FIRR CALCULATION	49000	0	0	0	2844
15	2000	0	2000/07/07	FIRR CALCULATION	49000	0	0	0	2844
16	2001	0	2001/07/07	FIRR CALCULATION	49000	0	0	0	2844
17	2002	0	2002/07/07	FIRR CALCULATION	49000	0	0	0	2844
18	2003	0	2003/07/07	FIRR CALCULATION	49000	0	0	0	2844
19	2004	0	2004/07/07	FIRR CALCULATION	49000	0	0	0	2844
20	2005	0	2005/07/07	FIRR CALCULATION	49000	0	0	0	2844
21	2007	0	2007/07/07	FIRR CALCULATION	49000	0	0	0	2844
22	2008	0	2008/07/07	FIRR CALCULATION	49000	0	0	0	2844
23	2010	0	2010/07/07	FIRR CALCULATION	49000	0	0	0	2844
24	2011	0	2011/07/07	FIRR CALCULATION	49000	0	0	0	2844
25	2012	0	2012/07/07	FIRR CALCULATION	49000	0	0	0	2844
26	2013	0	2013/07/07	FIRR CALCULATION	49000	0	0	0	2844
27	2014	0	2014/07/07	FIRR CALCULATION	49000	0	0	0	2844
28	2016	0	2016/07/07	FIRR CALCULATION	49000	0	0	0	2844
29	2017	0	2017/07/07	FIRR CALCULATION	49000	0	0	0	2844
30	2018	0	2018/07/07	FIRR CALCULATION	49000	0	0	0	2844
31	2021	0	2021/07/07	FIRR CALCULATION	49000	0	0	0	2844
32	2022	0	2022/07/07	FIRR CALCULATION	49000	0	0	0	2844
33	2023	0	2023/07/07	FIRR CALCULATION	49000	0	0	0	2844
34	2024	0	2024/07/07	FIRR CALCULATION	49000	0	0	0	2844
35	2025	0	2025/07/07	FIRR CALCULATION	49000	0	0	0	2844
36	2026	0	2026/07/07	FIRR CALCULATION	49000	0	0	0	2844
37	2027	0	2027/07/07	FIRR CALCULATION	49000	0	0	0	2844
38	2028	0	2028/07/07	FIRR CALCULATION	49000	0	0	0	2844
39	2029	0	2029/07/07	FIRR CALCULATION	49000	0	0	0	2844
40	2029	0	2029/07/07	FIRR CALCULATION	49000	0	0	0	2844
41	2029	0	2029/07/07	FIRR CALCULATION	49000	0	0	0	2844
42	2029	0	2029/07/07	FIRR CALCULATION	49000	0	0	0	2844
43	2029	0	2029/07/07	FIRR CALCULATION	49000	0	0	0	2844
44	2029	0	2029/07/07	FIRR CALCULATION	49000	0	0	0	2844
45	2029	0	2029/07/07	FIRR CALCULATION	49000	0	0	0	2844

Table 8-1
5 of 9

Y	EL CT REVENUE	MMH DSL ONLY	MMH DSL W/HY	D ONLY OM	D W/HY OM
1985	000	000	000	000	000
1986	4433	19645	22471	280856	57272
1987	80042	19645	2452	285247	60669
1988	95717	19645	2570	289717	64202
1989	103759	19645	2677	298899	66842
1990	110787	19645	3067	307615	71787
1991	112270	19645	3168	313307	74295
1992	116274	19645	3202	318442	76835
1993	122292	19645	3402	322342	82111
1994	122292	19645	3402	323342	83111
1995	122292	19645	3402	323342	83111
1996	122292	19645	3402	323342	83111
1997	122292	19645	3402	323342	83111
1998	122292	19645	3402	323342	83111
1999	122292	19645	3402	323342	83111
2000	122292	19645	3402	323342	83111
2001	122292	19645	3402	323342	83111
2002	122292	19645	3402	323342	83111
2003	122292	19645	3402	323342	83111
2004	122292	19645	3402	323342	83111
2005	122292	19645	3402	323342	83111
2006	122292	19645	3402	323342	83111
2007	122292	19645	3402	323342	83111
2008	122292	19645	3402	323342	83111
2009	122292	19645	3402	323342	83111
2010	122292	19645	3402	323342	83111
2011	122292	19645	3402	323342	83111
2012	122292	19645	3402	323342	83111
2013	122292	19645	3402	323342	83111
2014	122292	19645	3402	323342	83111
2015	122292	19645	3402	323342	83111
2016	122292	19645	3402	323342	83111
2017	122292	19645	3402	323342	83111
2018	122292	19645	3402	323342	83111
2019	122292	19645	3402	323342	83111
2020	122292	19645	3402	323342	83111
2021	122292	19645	3402	323342	83111
2022	122292	19645	3402	323342	83111
2023	122292	19645	3402	323342	83111
2024	122292	19645	3402	323342	83111
2025	122292	19645	3402	323342	83111
2026	122292	19645	3402	323342	83111
2027	122292	19645	3402	323342	83111
2028	122292	19645	3402	323342	83111
2029	122292	19645	3402	323342	83111
2030	122292	19645	3402	323342	83111
2031	122292	19645	3402	323342	83111
2032	122292	19645	3402	323342	83111
2033	122292	19645	3402	323342	83111
2034	122292	19645	3402	323342	83111
2035	122292	19645	3402	323342	83111
2036	122292	19645	3402	323342	83111
2037	122292	19645	3402	323342	83111
2038	122292	19645	3402	323342	83111
2039	122292	19645	3402	323342	83111
2040	122292	19645	3402	323342	83111
2041	122292	19645	3402	323342	83111
2042	122292	19645	3402	323342	83111
2043	122292	19645	3402	323342	83111
2044	122292	19645	3402	323342	83111
2045	122292	19645	3402	323342	83111
2046	122292	19645	3402	323342	83111
2047	122292	19645	3402	323342	83111
2048	122292	19645	3402	323342	83111
2049	122292	19645	3402	323342	83111
2050	122292	19645	3402	323342	83111

FILE NAME/PAI A E3
TIME/17:31:07
DATE/59/07/07

Y	HYDRO OM	DIESEL W/ HY	DIESEL ONLY	ELCTRICITY
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	90000	562600	1227500	1731
5	490000	0	0	1913
6	490000	0	0	2094
7	490000	0	0	2212
8	490000	250000	363700	2319
9	490000	0	0	2413
10	490000	0	0	2509
11	490000	0	0	2509
12	490000	0	0	2610
13	490000	0	0	2718
14	490000	0	0	2844
15	490000	0	0	2844
16	490000	450000	1091100	2844
17	490000	0	0	2844
18	490000	250000	363700	2844
19	490000	0	0	2844
20	490000	0	0	2844
21	490000	0	0	2844
22	490000	0	0	2844
23	490000	0	0	2844
24	490000	0	0	2844
25	490000	450000	1091100	2844
26	490000	0	0	2844
27	490000	250000	363700	2844
28	490000	0	0	2844
29	490000	0	0	2844
30	490000	0	0	2844
31	490000	0	0	2844
32	490000	0	0	2844
33	490000	0	0	2844
34	490000	0	0	2844
35	490000	0	0	2844
36	490000	0	0	2844
37	490000	0	0	2844
38	490000	0	0	2844
39	490000	0	0	2844
40	490000	0	0	2844
41	490000	0	0	2844
42	490000	0	0	2844
43	490000	0	0	2844
44	490000	0	0	2844
45	490000	0	0	2844
46	490000	0	0	2844
47	490000	0	0	2844
48	490000	0	0	2844
49	490000	0	0	2844
50	490000	0	0	2844
51	490000	0	0	2844
52	490000	0	0	2844
53	490000	0	0	2844
54	490000	0	0	2844
55	490000	0	0	2844
56	490000	0	0	2844
57	490000	0	0	2844
58	490000	0	0	2844
59	490000	0	0	2844
60	490000	0	0	2844
61	490000	0	0	2844
62	490000	0	0	2844
63	490000	0	0	2844
64	490000	0	0	2844
65	490000	0	0	2844
66	490000	0	0	2844
67	490000	0	0	2844
68	490000	0	0	2844
69	490000	0	0	2844
70	490000	0	0	2844
71	490000	0	0	2844
72	490000	0	0	2844
73	490000	0	0	2844
74	490000	0	0	2844
75	490000	0	0	2844
76	490000	0	0	2844
77	490000	0	0	2844
78	490000	0	0	2844
79	490000	0	0	2844
80	490000	0	0	2844
81	490000	0	0	2844
82	490000	0	0	2844
83	490000	0	0	2844
84	490000	0	0	2844
85	490000	0	0	2844
86	490000	0	0	2844
87	490000	0	0	2844
88	490000	0	0	2844
89	490000	0	0	2844
90	490000	0	0	2844
91	490000	0	0	2844
92	490000	0	0	2844
93	490000	0	0	2844
94	490000	0	0	2844
95	490000	0	0	2844
96	490000	0	0	2844
97	490000	0	0	2844
98	490000	0	0	2844
99	490000	0	0	2844
100	490000	0	0	2844

Y-Y	ELCT REVENUE	MWH DSL ONLY	MWH DSL W/HY	D ONLY OM	D W/HY OM
1985	7433	6150	522	10769	7512
1986	8259	6339	522	11552	7587
1987	9042	6542	522	11605	7664
1988	9916	7000	522	12424	7742
1989	10759	7257	522	13167	7821
1990	10788	7572	522	13859	7901
1991	10788	7872	522	14452	7981
1992	11220	8150	522	15218	8067
1993	11687	8505	522	16039	8152
1994	12292	8805	522	16839	8239
1995	12292	9005	522	17039	8319
1996	12292	9205	522	17239	8399
1997	12292	9405	522	17439	8479
1998	12292	9605	522	17639	8559
1999	12292	9805	522	17839	8639
2000	12292	10005	522	18039	8719
2001	12292	10205	522	18239	8799
2002	12292	10405	522	18439	8879
2003	12292	10605	522	18639	8959
2004	12292	10805	522	18839	9039
2005	12292	11005	522	19039	9119
2006	12292	11205	522	19239	9199
2007	12292	11405	522	19439	9279
2008	12292	11605	522	19639	9359
2009	12292	11805	522	19839	9439
2010	12292	12005	522	20039	9519
2011	12292	12205	522	20239	9599
2012	12292	12405	522	20439	9679
2013	12292	12605	522	20639	9759
2014	12292	12805	522	20839	9839
2015	12292	13005	522	21039	9919
2016	12292	13205	522	21239	9999
2017	12292	13405	522	21439	10079
2018	12292	13605	522	21639	10159
2019	12292	13805	522	21839	10239
2020	12292	14005	522	22039	10319
2021	12292	14205	522	22239	10399
2022	12292	14405	522	22439	10479
2023	12292	14605	522	22639	10559
2024	12292	14805	522	22839	10639
2025	12292	15005	522	23039	10719
2026	12292	15205	522	23239	10799
2027	12292	15405	522	23439	10879
2028	12292	15605	522	23639	10959
2029	12292	15805	522	23839	11039
2030	12292	16005	522	24039	11119
2031	12292	16205	522	24239	11199
2032	12292	16405	522	24439	11279
2033	12292	16605	522	24639	11359
2034	12292	16805	522	24839	11439
2035	12292	17005	522	25039	11519
2036	12292	17205	522	25239	11599
2037	12292	17405	522	25439	11679
2038	12292	17605	522	25639	11759
2039	12292	17805	522	25839	11839
2040	12292	18005	522	26039	11919
2041	12292	18205	522	26239	12000
2042	12292	18405	522	26439	12080
2043	12292	18605	522	26639	12160
2044	12292	18805	522	26839	12240
2045	12292	19005	522	27039	12320
2046	12292	19205	522	27239	12400
2047	12292	19405	522	27439	12480
2048	12292	19605	522	27639	12560
2049	12292	19805	522	27839	12640
2050	12292	20005	522	28039	12720
2051	12292	20205	522	28239	12800
2052	12292	20405	522	28439	12880
2053	12292	20605	522	28639	12960
2054	12292	20805	522	28839	13040
2055	12292	21005	522	29039	13120
2056	12292	21205	522	29239	13200
2057	12292	21405	522	29439	13280
2058	12292	21605	522	29639	13360
2059	12292	21805	522	29839	13440
2060	12292	22005	522	30039	13520
2061	12292	22205	522	30239	13600
2062	12292	22405	522	30439	13680
2063	12292	22605	522	30639	13760
2064	12292	22805	522	30839	13840
2065	12292	23005	522	31039	13920
2066	12292	23205	522	31239	14000
2067	12292	23405	522	31439	14080
2068	12292	23605	522	31639	14160
2069	12292	23805	522	31839	14240
2070	12292	24005	522	32039	14320
2071	12292	24205	522	32239	14400
2072	12292	24405	522	32439	14480
2073	12292	24605	522	32639	14560
2074	12292	24805	522	32839	14640
2075	12292	25005	522	33039	14720
2076	12292	25205	522	33239	14800
2077	12292	25405	522	33439	14880
2078	12292	25605	522	33639	14960
2079	12292	25805	522	33839	15040
2080	12292	26005	522	34039	15120
2081	12292	26205	522	34239	15200
2082	12292	26405	522	34439	15280
2083	12292	26605	522	34639	15360
2084	12292	26805	522	34839	15440
2085	12292	27005	522	35039	15520
2086	12292	27205	522	35239	15600
2087	12292	27405	522	35439	15680
2088	12292	27605	522	35639	15760
2089	12292	27805	522	35839	15840
2090	12292	28005	522	36039	15920
2091	12292	28205	522	36239	16000
2092	12292	28405	522	36439	16080
2093	12292	28605	522	36639	16160
2094	12292	28805	522	36839	16240
2095	12292	29005	522	37039	16320
2096	12292	29205	522	37239	16400
2097	12292	29405	522	37439	16480
2098	12292	29605	522	37639	16560
2099	12292	29805	522	37839	16640
2100	12292	30005	522	38039	16720

IX. INDIRECT PROJECT EFFECTS

CHAPTER IX INDIRECT PROJECT EFFECTS

9.1 Introduction

One of the major disparities between the life styles of people in developed countries versus those in developing countries is the wide distribution of domestic electrical networks in the former which serve not only urban but rural areas as well. Electrification and rural development are closely interrelated. The Philippines however is presently highly dependent on oil as an energy source which, due to world inflation, hinders reduction in electrical utility fees and thus the spread of electrical facilities to less affluent rural areas. To reduce costs and promote rural electrification therefore, it is necessary to develop domestic energy sources such as hydropower, geothermal power, etc. The proposed Project will accordingly be designed to have substantial effects on rural communities as described below.

9.2 Effect on Productivity of Plain, Mountain and Fishing Villages

Upon review of local data and spot field survey, the possible effect on productivity of plain, mountain and fishing villages by extension of the power network can be listed as follows:

- a) overall improvement in agricultural system management through use of well and irrigation pumps;
- b) preservation of perishable agricultural produce by refrigeration;
- c) development of fish farms by installation of pump facilities;
- d) development of light industries such as lumber mills, flour mills, etc. through electricity; and,
- e) storage of caught fish by refrigeration.

The increase in income and stabilization of the rural economy resulting from the above effects will in turn contribute to increased employment opportunities.

9.3 Improvement of Non-Agricultural Sector and Socio-Economy

It is also apparent that with the provision of adequate power supply, improvement of the non-agricultural sector and socio-economy would occur in the following ways:

- a) increased development of industries and income from the same through use of electricity;
- b) increased participation of women in society and the work force as a result of electrification and consequent decrease in time required for housework, etc.; and
- c) intensification of production from light industries and commerce.

9.4 Improvement of Living Environment in Rural Areas

The following improvements in the conditions of rural areas are also expected:

- a) potential use of limited educational facilities for evening classes;
- b) increased use of audio-visual materials in educational programs, and expansion of media and information transfer;
- c) improved public sanitation and medical services through electrical illumination and refrigeration of medicines; and,
- d) reduction in crime due to electrical lighting at night.

9.5 Effect on National Economy

The effect on the national economy can be estimated as follows:

- a) increased national stability and reduction of dependency on foreign capital due to decreased oil imports;
- b) promotion of rural development and improvement of the service sector for rural residents due to strengthened rural economy and increased income; and,
- c) decreased migration of rural population to urban areas.

9.6 Effect of Dam Construction on Erosion

At present, devastation of downstream lowland areas is a major problem in the Project area due to annually increasing riverbed deposits. Construction of the proposed regulating pondage dam upstream will arrest sediment deposits arising from flood discharge and result in a drop in the riverbed and increased river stabilization. This will in turn allow possible agricultural development of a larger level area downstream.

Although it is difficult to measure the above effects numerically, EIRR calculations were carried out with all figures calculated on the safe side.

A P P E N D I X

APPENDIX I

TECHNICAL REPORT

CONTENTS

	<u>Page</u>
1. TOPOGRAPHY AND GEOLOGY	1
1.1 Site Location	1
1.2 Topography	1
1.3 Geology	2
2. HYDROLOGY AND METEOROLOGY	3
2.1 Meteorological and Hydrological Data	3
2.2 River Basin	3
2.2.1 Introduction	3
2.2.2 Tamlang River	4
2.3 Tamlang River Flow Status	5
2.3.1 Measurement of Flow Discharge	5
2.3.2 Precipitation	6
2.3.3 Estimation of Long-Term Daily Discharge	8
2.4 Design Flood Flow and Sedimentation in the Reservoir	10
2.4.1 Estimation of Design Flood Flow	10
2.4.2 Estimation of Sedimentation in the Reservoir	10
3. GENERAL PLAN	26
3.1 Tamlang River Hydropower Plant	26
3.2 Transmission Lines	27
3.3 Rio Tube Mine Substation	27
3.4 PALECO Power Distribution Network	27

	<u>Page</u>
4. BASIC DESIGN	
4.1 Climatic Conditions	31
4.2 Civil Works	31
4.2.1 Dam	31
4.2.2 Intake	33
4.2.3 Headrace	33
4.2.4 Surge Tank	34
4.2.5 Penstock	35
4.2.6 Powerhouse	35
4.2.7 Tailrace	35
4.3 Electro-Mechanical Equipment	36
4.3.1 Type and Turbine-Generator Unit	36
4.3.2 Main Transformer	37
4.3.3 Switch Gear	38
4.3.4 Control System	38
4.3.5 Transmission Lines	38
5. CONSTRUCTION PROCEDURES AND COST ESTIMATE	55
5.1 Construction Procedures	55
5.1.1 Dam Construction	55
5.1.2 Headrace Construction	56
5.1.3 Waterways and Powerhouse	56
5.1.4 Construction Equipment	57
5.1.5 Concrete Aggregate	58
5.1.6 Power Supply	59
5.1.7 Transportation Plan	59
5.2 Cost Estimate	60
5.2.1 Preconditions	60
5.2.2 Cost Estimate and Expenditure Schedule	61

ILLUSTRATIONS

Figure	<u>Page</u>
2-1 Philippine Climate Map	12
2-2 Meteorology, Rio Tuba Mine	13
2-3 Collected Meteorological and Hydrological Records	14
2-4 Profile of Tamlang River	15
2-5 Riverbed Elevation at NIA Gauging Station	16
2-6 Rating Curve, 1980 Tamlang River	17
2-7 Tamlang River Flow-Duration Curve	18
3-1 Catchment Basin & Transmission Route Map	29
3-2 Power System Diagram (in 1988)	30
4-1 General Layout	40
4-2 General Profile	41
4-3 Dam: Plan, Typical Section, Downstream Face	42
4-4 Powerhouse: Plan, Typical Section	43
4-5 Intake & Surge Tank Structural Detail	44
4-6 Waterway (Surge Tank - Tailrace) Plan	45
4-7 Waterway (Surge Tank - Tailrace) Profile	46
4-8 Rubber Dam	47
4-9 Power System Diagram (in 1988)	48
4-10 Single Line Diagram	49
4-11 Substation	50
4-12 Detail of Pole: Dimension & Diagram 34.5KV Transmission Line, Tension, Suspension	51
4-13 Turbine Type Selection Chart	52
4-14 Performance Curves	53
5-1 Tentative Facilities for Construction Works: Plan	63

LIST OF TABLES

	<u>Page</u>
2-1 Maximum and Minimum Temperature, Rio Tuba Mine	19
2-2 Maximum and Minimum Relative-Humidity, Rio Tuba Mine	20
2-3 Maximum and Average Wind Velocity, Rio Tuba 1979-83	21
2-4 Monthly Rainfall Brookes Point Palawan	22
2-5 Daily River Discharge Converted from NIA Gauging Records (1980)	23
2-6 Results of Discharge Measurement, Tamlang River, 1984	24
2-7 Simulated Flow Duration	25
4-1 Headrace Comparison	54
5-1 Implementation Schedule	64