

IV. BASIC DESIGN

CHAPTER IV BASIC DESIGN

4.1 Climatic Conditions

The climate of the Project area is distinctly divided into a dry season (January - May) and a wet season (June - December) with an average annual rainfall of 1,600mm. Annual average temperature is 27.10°C while the maximum temperature is 37.4°C and the minimum is 20.9°C. Average humidity is 84%. Maximum wind velocity is about 24m/sec and although there was a typhoon in November 1968, direct typhoons occur only once every few decades.

Although the number of days of thunderstorm during a one year period (IKL) is unclear due to lack of data, approximately 30 days per year is estimated due to the fact that about 7 days of thunderstorm occur in May just at the beginning of the rainy season and 35 days of thunderstorm were recorded on Cebu Island.

An earthquake has not occurred in the area for over 20 years and accordingly 0.12 was selected as design seismic coefficient for the dam. Design conditions for transmission lines are designated as follows:

- Maximum Temperature	40°C
- Average Temperature	30°C
- Minimum Temperature	10°C
- Average Humidity	84%
- Maximum Wind Velocity	40m/sec
- Seismic Factor (Horizontal)	0.2G

4.2 Civil Works

Preliminary designs of the civil works structures are presented as FIG 4-1 through 4-8. Detailed description of the principal structures is provided hereunder.

4.2.1 Dam

A concrete gravity-type dam was selected for the following reasons:

- (1) The CH-grade grano diorite foundation indicates sufficient stability and safety with regards to bearing, sliding and percolation of water. Moreover, except on the upper face of the right bank, weathered rock is rare and foundation

treatment is for the most part unnecessary. The narrow gorge is also appropriate for concrete dam construction and particularly for arch dams.

- (2) Adoption of an arch-type concrete dam was eliminated in consideration of construction procedures, cement quality, sedimentation, flood flow treatment, etc.
- (3) Supply of sufficient volume and quantity of core materials in the case of a fill-type dam is difficult in the vicinity of the dam site. In addition, although a spillway will be installed on the right bank, the amount of excavation and concrete works required would be increased in the case of the fill-type dam due to topographical and geological factors and consequently, construction of the same would be uneconomical.

Although the narrow gorge at the proposed dam site may present a few difficulties for river diversion work, the location requiring the least construction work was selected. Said site is approximately 1,400m upstream from the point where the river meets the alluvial fan, and the riverbed slope at the same changes from 1/35 to 1/20.

As far as topography permits, the dam will be constructed to overflow at design flood discharge of $510\text{m}^3/\text{sec}$ along the crest of the dam without a sand flush gate. An automatic collapsible rubber dam 3.7m in height will be installed along the entire length of the dam crest to increase effective head. The said rubber dam will collapse automatically when overflow depth exceeds the set point at the top of the same and can be inflated back into position by motor.

The dam cross section will have an upstream slope of 0.2 and a downstream slope of 0.8. Design horizontal seismic coefficient was determined to be 0.12 and non-overflow level to be 192.0m (design flood elevation + 2.30m). Both downstream banks consist of hard grano diorite outcroppings and, although bank protection is not required, a 6.0m auxiliary dam for water cushion will be constructed to reduce overflow velocity and stabilize river flow. Although sediment deposits, including gravel deposits 3-4m in thickness, occur along the riverbed upstream from the dam, there are no significant landslides within the catchment area and

sediment deposit level was determined to be 179.0m based on the annual sediment volume estimate of about 10,000m³.

The effective depth of the regulating pond is 5.5m including the 3.7m of the raised rubber dam, and regulating capacity is approximately 400,000m³.

4.2.2 Intake

As the headrace proposed under the Plan is a tunnel type to be constructed on the right bank, the intake structure will be located about 100m upstream from and independent of the dam site, thus reducing headrace length and avoiding complicated construction entailed by installation of an intake in the dam. The intake includes a float log protection, a trash rack (net interval 30mm) and a regulating gate. The latter will be an electrical remote control type. Intake site elevation will be such that power generation can take place even when the crest rubber dam is in the collapsed position.

4.2.3 Headrace

Two alternative plans, tunnel construction and open excavation, were considered for headrace installation from the intake to the head tank.

(1) Tunnel

The 1,102m of the total tunnel length (1,277m) would be designed with a section of 4.0m x 4.0m to use as a dam construction road. The 175.0m not used as a construction road would have a section of 2.0m x 2.0m for use as a water canal and the entire tunnel length would be used as a headrace. Approximately 70% of the tunnel would be unlined while 30% would have a mortar or concrete lining. Regulating gates would be installed at the upper and lower entrances of the tunnel. When water is shut-off the tunnel could be used for tunnel inspection and maintenance and as a connecting road to the dam site.

(2) Open Excavation Method

A bed for the headrace conduit 1,400m in length would be excavated and used as a construction road. Upon dam completion an FRPM pipe with an inner diameter of 1.50m would be embedded in the

road surface and used as the headrace. Earth fill would be spread over the same to form protective layers and the surface would be used as a future access road.

Comparison of the two alternatives is presented in TABLE 4-1. As can be seen from the same, the open excavation method results in higher construction costs and decreased energy due to loss of head, and is thus considered economically disadvantageous compared to the tunnel method. Accordingly, the latter alternative was adopted as the headrace for the present Project.

Geologically the tunnel route consists mainly of hard rocks including grano diorite from the central construction portal to the upstream portion and metamorphic rock, particularly basaltic lava, in the downstream portion. Some weathered portions occur on the surface near the central construction portal and bore samples revealed a weathered layer about 4m thick near the tunnel's downstream portion.

Although there is minimal chance of leakage from the tunnel due to excellent foundation rock quality, a portion of the tunnel will be lined with shotcrete for reinforcement.

Tunnel excavation features are as follows:

Section	Headrace Tunnel	Temporary Road	Summary
4.0m x 4.0m	1,102.0m	220.0m	Downstream 70m Upstream 150m
2.0m x 2.0m	175.0m	-	Used only as headrace
Total	1,277.0m	220.0m	

4.2.4 Surge Tank

The surge tank site is located between the penstock and the headrace. As the weathered rock layer at this site is over 4m in depth, the surge tank foundation will be excavated to the level of good quality foundation rock to increase stability.

A steel shaft simple surge tank will be installed on the side of the excavated bank.

4.2.5 Penstock

The penstock route will follow the right bank where the lower mountains join the alluvial fan and the slope is a comparatively moderate 30°. Weathered layer along the route extends to a depth of 2-4m. Use of a steel conduit would consequently require increased earthworks to excavate the penstock bed to a stable foundation. FRPM pipe with an inner diameter of 1.35m has therefore been selected for penstock use and the same will be embedded for a total length of 216.0m. Portions where backfill may be subject to wash out will be sodded or reinforced with rubble masonry.

4.2.6 Powerhouse

River sediment layer thickness at the powerhouse site is about 4m. Part of the site will therefore be excavated from the steep hillside to ensure that the entire foundation of the powerhouse rests directly upon bedrock. A horizontal-shaft Francis turbine was selected and the elevation of the turbine and generator floor will be 85.80m. As the flood flow elevation is 92.0m, the side walls of the equipment room will be constructed of water tight reinforced concrete and the auxiliary control panel, etc. will be installed in a second storey at an elevation of 94.2m.

The floor area of the equipment room will be 136.0m² while that of the second storey will be 59.5m². As the elevation of the connecting road to the powerhouse will be 92.0m, heavy equipment will be lowered into the equipment room through an opening in the roof (elevation 94.2m). The opening will be fitted with a roof cover.

Equipment will be moved within the equipment room itself by a simple travelling crane with a maximum lifting load capacity of 12.0 tons. The outdoor substation will be set-up near the powerhouse on the right bank where the penstock is also located, and the foundation of the same will have an area of about 200m².

4.2.7 Tailrace

The shortest possible distance between the powerhouse and the Tamlang River was selected as the tailrace route and the sediment layer will be excavated along the same. The bottom width of the tailrace will

be 2.20m and both side walls will have a slope of 1:0.5. The side walls will be reinforced with rubble masonry as high as flood water level to prevent collapse, while the surface of the tailrace bed will be left as is.

The right bank of the Tamlang River upstream from the point where the tailrace flows into it will also be reinforced with rubble masonry. Tailrace slope will be 1/1000 to increase the effective head including drop structures in part of the Tamlang riverbed.

4.3 Electro-Mechanical Equipment

Preliminary designs of the electro-mechanical equipment are presented as FIG. 4-4 and 4-9 through 4-12. Detailed description of the principal structures is provided hereunder.

4.3.1 Type and Turbine-Generator Unit

(1) Turbine

The proposed hydropower plant is a canal with regulating-pond type with an effective head of 101.3m at maximum output and a maximum turbine discharge of $4.5\text{m}^3/\text{sec}$.

A horizontal-shaft Francis turbine was selected from among those turbines suitable for mini-hydropower use presented in FIG. 4-13. Vertical-shaft turbine were also studied; however, the same entail greater civil works cost resultant from complexity of concrete foundation and building structures, although excavation works for the foundation would be less than the horizontal-shaft turbine. Moreover, vertical-shaft turbines require longer installation time, are less convenient for operation and maintenance. In consideration of the above, the horizontal-shaft turbine was selected as most advantageous.

Water quality studies indicate that water quality should have no significant influence on turbine operation. The turbine performance curve is presented in FIG. 4-14. Installation of one turbine unit is considered sufficient for daily operation by a regulating pond.

Turbine Features are set-in below.

- Type : Horizontal-shaft Francis Turbine
- Effective Head : 101.3m
- Maximum Turbine Discharge : 4.5m³/sec
- Rated Output : 4,000kW
- Rated Speed : 720rpm
- Specific Speed : 142m-kW
- Inlet Valve : Butter fly Valve
- Operation System : Electricity

(2) Generator

As the generator which is directly coupled to the turbine must be capable of independent operation and regulating voltage and frequency of transmission line, a horizontal-shaft, 3-phase, AC synchronized, air-cooled generator was selected.

Rated power factor was designated as 0.81 in consideration of the power factor of actual load at the Tuba Mine, rated power factor of the existing diesel generator, etc. The brushless excitation method was selected.

Generator Features are also set-in below.

- Type : Horizontal-shaft 3 Phase AC Synchronized Generator
- Rated Output : 4,700kVA
- Rated Voltage : 4.16kV
- Rated Power Factor : 0.81
- Rated Frequency : 60Hz
- Rated Speed : 720rpm
- Excitation Method : Brushless-type

4.3.2 Main Transformer

An outdoor, 3-phase, oil-immersed, self-cooled type transformer was selected with triangular primary connections, star secondary connections and neutral resistance grounding. The primary side conforms to the voltage of the generator while the secondary side conforms to the voltage of the transmission lines.

Transformer Features are set-in below.

- Type : Outdoor 3-phase Oil-immersed
Self-cooled Transformer
- Rated Capacity : 4,700kVA
- Rated Voltage : 4.16/34.5 \pm 5% kV
- Rated Frequency : 60Hz

4.3.3 Switch Gear

A vacuum circuit breakers with 4.16kV on the generator side and 34.5kV on the transmission line side was selected for minimal maintenance. An indoor-type metal-clad will be installed on the 4.16kV side and a conventional-type will be installed outside on the 34.5kV side. Both outside switchgears and insulators were designed in consideration of possible salt damage.

4.3.4 Control System

The hydropower plant will be supervised and controlled by the one-man control type system with operation located in the control room. A program controller capable of setting and controlling output and plant operation hours was selected to facilitate operation of the Rio Tuba Mine and PALECO diesel generators. In addition, the Rio Tuba Mine and PALECO will be in communication with the hydropower plant control panel by radio telecommunication. A cubicle built-in seal type alkali storage battery will be used as the power source for the control panel to minimize maintenance.

4.3.5 Transmission Lines

(1) Voltage

Transmission line voltage used in the Philippines is generally greater than 34.5kV. For the present Project however, 34.5kV was selected based upon study of transmission loss and transmission line construction cost including cost of the substations.

(2) Conductors

Aluminum conductor steel reinforced cable (ACSR) which is widely used for transmission and distribution lines in the Philippines was selected. As the transmission line route is only about 1.5km from the seacoast in some places, the above ACSR with several stranded steel reinforced cables was considered most reliable against salt damage. A 176.9MCM (89.7mm²) conductor was selected for transmission capacity, minimal loss and minimal drop in (less than 5%) voltage.

(3) Insulators


Four 250mm suspension insulator types will be used as close proximity of the transmission line route to the seacoast (1.5-10km) results in potential salt damage.

(4) Overhead Ground Wire

As the estimated IKL of the Project area is about 30 days, one overhead ground wire will be provided. AWG 2 (33.62mm²) zinc coated stranded steel wire will be used with an oblique angle of within 45°.

(5) Support Poles

Wooden poles will be erected at an average interval of 75m. Wooden poles are widely used in the Philippines as supports for transmission voltages of less than 69kV and also for 138kV. Hard Apiton trees impregnated with creosote will be used.



IA = 60°00'
R = 200.00
TL = 115.470
CL = 209.439

Total headrace tunnel length 1,102.065 (D=4.00)
1,277.065






FIG. 4-1





RNO TUBA HYDROPOWER PROJECT		
Republic of the Philippines		
GENERAL LAYOUT		
JAPAN INTERNATIONAL COOPERATION AGENCY		
DWG. NO.	SHEET	OF

PROFILE OF WATERWAY S=1/2,000




TYPICAL SECTION S=1/100


HEADRACE




PENSTOCK



TAILRACE




PROFILE OF WATERWAY $s=1/2,000$




TYPICAL SECTION $s=1/100$


HEADRACE



PENSTOCK





TAILRACE




RIO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
GENERAL PROFILE	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF

FIG. 4-3




TYPICAL CROSS SECTION




RIO TUBA HYDROPOWER PROJECT		
Republic of the Philippines		
DAM		
PLAN, TYPICAL SECTION, DOWNSTREAM FACE		
JAPAN INTERNATIONAL COOPERATION AGENCY		
DWG. NO.	SHEET	OF


TURBINE & GENERATOR
PLAN



CONTROL ROOM
PLAN




SECTION A - A




RIO TUBA HYDROPOWER PROJECT		
Republic of the Philippines		
POWERHOUSE		
PLAN, TYPICAL SECTION		
JAPAN INTERNATIONAL COOPERATION AGENCY		
DWG. NO.	SHEET	OF

FIG. 4-5


INTAKE DETAIL
PROFILE




SURGE TANK DETAIL
PLAN



SECTION A - A




SECTION




RIO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
INTAKE & SURGE TANK STRUCTURAL DETAIL	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF

FIG. 4-6





RIO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
WATERWAY	
(SURGE TANK - TAILRACE)	
PLAN	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF

FIG. 4-7




RIO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
WATERWAY (SURGE TANK - TAILRACE) PROFILE	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF

FIG. 4-8




RIO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
RUBBER DAM	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF



- LEGEND**
- ⊙ Gen Generator
 - ⊙ DE Diesel Engine
 - ⊙ WT Water Turbine
 - Disconnect Switch
 - Transformer
 - Circuit Breaker
 - VCB Vacuum Circuit Breaker
 - SOCB Small Oil Circuit Breaker

RIO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
POWER SYSTEM DIAGRAM	
(IN 1988)	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF

FIG. 4-10



LEGEND

- | | | |
|--------------------------------|-----------------------------|---|
| OCR Over Current Relay | 60 Voltage Matcher | SA Surge Absorber |
| OVR Overvoltage Relay | 15 Speed Matcher | Ex.TR: Exiting Transformer |
| UVR Undervoltage Relay | 25 Synchronizer | TD Tochometer Dynamo |
| DGR Directional Ground Relay | CD Crawling Detector | NGPT: Neutral Grounding Potential Transformer |
| DFR Differential Relay | W Wattmeter | AC.Ex.: AC Exciter |
| LFR Loss-of-field Relay | WH Watt-hourmeter | |
| RPR Reverse Power Relay | VAR Var-meter | |
| FGR Field Ground Relay | N Speed Meter | |
| DVGR Over Voltage Ground Relay | Rectifier | |
| VR Voltage Relay | Shyristor | |
| GR Ground Relay | Current Transformer | |
| OSR Over Speed Relay | Potential Transformer | |
| NSR Nominal Speed Relay | VCB: Vacuum Circuit Breaker | |
| LSR Low Speed Relay | CB: Circuit Breaker | |
| V Voltmeter | MCB: Molded Circuit Breaker | |
| Vo Grounding Voltmeter | DS: Disconnecting Switch | |
| A Ammeter | PF: Power Fuse | |
| A D.C. Ammeter | LA: Lightning Arrester | |
| V D.C. Voltmeter | PT: Potential Transformer | |
| F Frequency meter | CT: Current Transformer | |
| SY Synchroscope | BCT: Bushing Type C.T. | |


RIO TUBA HYDROPOWER PROJECT
 Republic of the Philippines

SINGLE LINE DIAGRAM


JAPAN INTERNATIONAL COOPERATION AGENCY

DWG. NO. SHEET OF


POWER STATION SIDE





RIO-TUBA MINING SIDE





SINGLE LINE DIAGRAM
(RIO-TUBA MINING SIDE)



TRANSMISSION LINE 34.5kV



DISTRIBUTION LINE 13.2kV



RIO TUBA HYDROPOWER PROJECT		
Republic of the Philippines		
SUBSTATION		
JAPAN INTERNATIONAL COOPERATION AGENCY		
DWG. NO.	SHEET	OF

SUSPENSION

TENSION





FIG. 4-12

RIO TUBA HYDROPOWER PROJECT Republic of the Philippines	
DETAIL OF POLE DIMENSION & DIAGRAM 34.5KV TRANSMISSION LINE TENSION, SUSPENSION	
JAPAN INTERNATIONAL COOPERATION AGENCY DWG. NO.	SHEET OF

FIG. 4-13 TURBINE TYPE SELECTION CHART



Source: Design Criteria for Mini-Hydro Power in Bicol Region, Feb. '8

FIG. 4-14 PERFORMANCE CURVES




TABLE 4-1

HEADRACE COMPARISON

Item	Tunnel	Cut-and-Cover Method
	Width: 4m Height: 4m	Width of conduit bed: 6.0mm
Construction	<ul style="list-style-type: none"> - used as temporary road during dam construction - gate installed at upper and lower terminus - used as inspection/maintenance road during water shutdown 	FRPM pipe: dia 1.50m <ul style="list-style-type: none"> - embedded pipe, covered with earth fill, the surface to be used as a roadway
Headrace Length (m)	1,500 (including entrance)	1,400
" Excavation (m ³)	22,500	119,000
" Friction Loss (m)	0.20 when, $0.0084 \times Q = 0-4.5 \text{ m}^3/\text{sec}$	5.9 when $0.2908 \times Q = 0-4.5 \text{ m}^3/\text{sec}$
Effective Head (m)	101.3	95.6
Generation Capacity MWH	20,510	$20,510 \times \frac{95.6}{101.3} = 19,360$
Direct Construction Cost (¥)	313,000 ¥/m = 472.8 million	378,000 ¥/m = 529.2 million
Direct Construction Cost for Headrace/Generation Capacity (¥/kWh)	23.2	27.3
Inspection Road	<ul style="list-style-type: none"> - tunnel may be used as access road to dam site during water shutdown; however, no access road exists when power plant is in operation 	<ul style="list-style-type: none"> - surface over bedded conduit may be used as access road

V. CONSTRUCTION PROCEDURES
AND COST ESTIMATE

CHAPTER V CONSTRUCTION PROCEDURES AND COST ESTIMATE

5.1 Construction Procedures

The construction works of this Project consist mainly of civil works including the dam and represents large scale development on the island. In consideration of the steep terrain of the proposed construction site and the resultant scale and complexity of civil works, 28 months was allotted for the construction period (TABLE 5-1). The major portion of the said period is devoted to construction of the temporary access road to the dam site which will follow the headrace tunnel route, and dam concrete placing. Both of these activities are key points in the entire construction schedule and accordingly, particular attention will be given to the same. Construction facilities, materials, etc. required for tunnel excavation will be lifted in by helicopter as far as the central tunnel portal and, when necessary, certain tasks will be performed in 2 shifts to ensure smooth work progress. The overall tentative facilities for the construction works is presented as FIG. 5-1. Detailed description of the principal activities is given hereunder.

5.1.1 Dam Construction

Construction of temporary cofferdams and temporary diversion conduits, excavation of the riverbed and concrete placing work will all be undertaken during the dry season. As the maximum flow discharge in dry season is estimated at about $4.0\text{m}^3/\text{sec}$, a corrugated conduit (inner dia:1,350mm) will be installed on the right bank for temporary drainage. During concrete placing river flow will be diverted through a temporary by-pass in the dam (1.5m x 2.0m) which will be closed upon completion of concrete work.

The cofferdam consists of a primary cofferdam made from riverbed deposits and a secondary concrete cofferdam located inside the former. An impervious clayey material from the right bank will be used as a blanket for the primary cofferdam.

Main temporary facilities required for concrete placing will be installed so as to be operational within 3 months after tunneling has been accomplished. During the above 3-month interval, foundation excavation works and river diversion works will be undertaken, upon completion of

which concrete placing will occur. A total of approximately 17,000m³ of concrete will be placed by a 4.5 ton tower crane (R=20m) with a 1.0m³ bucket at an average daily rate of 200m³ for an average 11 days per month, covering a total period of about 9 months.

5.1.2 Headrace Construction

As the headrace tunnel will be used during dam construction as a transportation road, progress of headrace construction must proceed according to a strict schedule. To facilitate construction, an additional portal will be installed mid-way along the tunnel and equipment and materials required will be transported by helicopter to a heliport set-up in the vicinity of the same.

All tunnel excavation from the portal near the head tank and the central portal will be performed in the upstream direction at a rate of 150m per month. For the 14.28m² excavation area, a hydraulic jumbo will be used for rock drilling and blasting, while a RS-85 rock shovel and an 8 ton diesel locomotive will be used for transportation of the excavated materials.

The 175.0m of the tunnel length which will not be used as a construction road (excavation area:5.58m²) will be excavated after the completion of the construction road.

5.1.3 Waterways and Powerhouse

Construction of waterways other than the headrace and of the powerhouse will be completed during the dam construction period. Equipment for the same consists mainly of earthwork machinery to be appropriated from headrace and dam construction. Concrete work equipment, etc. for the dam and headrace will also be used in common for powerhouse and waterway construction.

5.1.4 Construction Equipment

The main equipment for dam construction is as follows:

<u>Equipment</u>	<u>Specifications</u>	<u>No. of Units</u>
Crawler Drill	10m ³ /min air consumption	5
Leg Drill	3m ³ /min air consumption	16
Coal Pick Hammer	1m ³ /min air consumption	16
Bull Dozer	11t	5
Backhoe	0.4m ³ bucket capacity	5
Breaker	800kg	2
Dump Truck	11t	9
Compressor	7m ³ /min.	8
Compressor	10.5m ³ /min.	9
Truck Mixer	4.5m ³	5
Concrete Pump	30-35m ³ /Hr	1
Vibrator	Maximum Frequency	8
Vibrator	Rod-Type	5
Cycle Converter		1
Belt Conveyor	Portable $l=5.0m$	4
Belt Conveyor	B=600 $l=150m$	1
Aggregate Plant	60t/h	1
Batch Plant	1.0m ³ x 2 units	1
Cart	1.0m ³ x 2 units	1
Locomotive	8t	1
Bucket	1.0m ³	3
Tower Crane	R=30m, 4.5t	3
Power Generator	125KVA	9
Grouting Machine		1
Conduits	∅125-∅200	1

The main equipment for tunnel construction is as follows:

1) Surface

<u>Equipment</u>	<u>Use</u>	<u>No. of Units</u>
Portable Compressor 100Hp	Rock shovel	2
5-Step Turbine Pump 75kw	Drilling	2

<u>Equipment</u>	<u>Use</u>	<u>No. of Units</u>
Fan 6800 22kw	Ventilation	2
D4-class Bull Dozer	Disposal of excavated material	2
Car Dumper 4,5m ³	Earth extraction	2
Water Tank 5m ³	Turbine pump	2
Truck 2t	Light on-site transport	2
Generator 180kVA	Jumbo motor	2
Mobile Crane 13t	Rail shipping	2

2) Tunnel

Hydraulic 3-boom Jumbo	Rock drilling	2
Rock Shovel 0.4m ³	Slag loading	2
Granby 4.5m ³	Slag transport	1.6
Diesel Locomotive 8t	Slag transport	2
Cherry Picker	Shift of steel car	2
Leg Drill 3m ³ /min	Rock trimming	2
Coal Pick Hammer 1m ³ /min	Rock trimming	4

Main materials required are as follows:

<u>Material</u>	<u>Specifications</u>	<u>Quantity</u>
Cement	Ordinary	4,500t
Steel	Deformed bar	400t
Rubber Dam	H 3.7m, L 25m	1 no
Gate	2.5m-3.5m	3 no
FRPM Pipe	D 1.35m	300m
Turbine-Generator	4,000kW	1 unit
Control Panel		1 lot
Substation and Transmission Line Facility		1 lot

5.1.5 Concrete Aggregate

Total concrete volume is approximately 21,000m³ including 17,000m³ for the dam, and the volume of aggregate required for the same is about 30,000m³. Possible aggregate borrow sites include the tunnel excavation

site, the riverbed upstream from the dam site, the area downstream from the powerhouse, and the mountains in the area. Of these, use of riverbed deposits upstream from the dam is least economical due to the combined deposits of boulders and gravel. The site downstream from the powerhouse on the other hand, has a very small percentage of boulders and will therefore be used as the main aggregate borrow site. The quantity of aggregate at the same is insufficient however, and accordingly any shortage will be compensated by material obtained from tunnel excavation, particularly from the upstream side of the tunnel's central entrance where soil content is less and material is easily obtained.

Good quality fine aggregate can be found in large quantities about 1km from the powerhouse and collection efforts will therefore be concentrated at the same. As aggregate obtained from the riverbed, mountains and tunnel site will vary in size, a crushing plant has been planned at the site downstream from the powerhouse to sort necessary aggregate size.

5.1.6 Power Supply

As supply of electricity for construction works is not possible from the existing power system (Refer to Chapter III & IV) all power will be supplied by diesel generators while air will be supplied by portable compressors. Capacity and number of generator units required are as follows:

- Dam Site	125kVA x 5 units
- Powerhouse Site	125kVA x 4 units
- Total	125kVA x 9 units

5.1.7 Transportation Plan

The largest and heaviest piece of equipment to be shipped from Japan under the present Project is the main transformer, with a height of 4.3m, a width of 3.5m, a depth of 3.8m and a weight of 13.5 tons. Puerto Princessa, which has port facilities, and Brookes Point were both considered as possible unloading sites. Puerto Princessa, however, is 200km from the Project site on the Tamlang River and inland transportation would thus be difficult, while port facilities at Brookes Point, although presently undergoing improvement to allow side docking of 1,000 ton vessels, are inadequate.

About 9km south of the powerhouse site is Salogon, a village located where heavy equipment is hauled overland. A road 4m in width extends from the seacoast to the national highway, about 2km away. Although the width is fairly narrow, the said road is completely straight and level, sufficient for passage of a large truck. The powerhouse site is 7km from the junction of the seacoast road and the national highway, resulting in a total combined length of 9km. Overland shipping from Salogon is therefore recommended and also the Rio Tuba Mine's pier which is used for ore shipment may be used for unloading. As the sea around eastern Palawan Island can become quite rough during the dry season hindering shipping and unloading, heavy equipment will be shipped during the rainy season.

In addition to the road from the powerhouse to the surge tank, a construction road will be constructed at the dam site for on-site transportation. The majority of dam construction materials will be transported along the headrace tunnel while tunnel materials will be carried in by helicopter.

5.2 Cost Estimate

5.2.1 Preconditions

Construction cost was estimated according to the following preconditions:

- a) Cost estimate was based on construction procedure natural conditions at the proposed site, construction scale, technical standards, etc.
- b) The estimated scope covered all construction work, including dam, waterways, powerhouse, civil works and electrical facilities, transmission lines from the Rio Tuba Mine and related transformer facilities.
- c) Estimates of the amount of construction work were based on basic plan drawings.
- d) The majority of construction equipment, engineering equipment and main materials will be imported from foreign countries.
- e) Generator, transmission, and transformer machines will be designed, manufactured and supplied by foreign countries.

- f) Unit construction costs were estimated from Philippine domestic prices and Japan domestic prices of March 1984 with an exchange rate of P1/¥16.6.
- g) Estimated cost of consulting services includes cost of detailed implementation design and construction supervision.
- h) Physical contingency was calculated as approximately 15% of direct construction cost.
- i) Price escalation during construction was estimated according to construction schedule and expenditure schedule.


5.2.2 Cost Estimate and Expenditure Schedule


Estimated costs are as given below while expenditure schedule is presented in the subsequent table.

1.	<u>Civil Works Cost</u>	<u>Million Yen</u>
	Dam	1,333.7
	Intake	70.3
	Headrace Tunnel	737.4
	Surge Tank	93.6
	Penstock	63.9
	Tailrace	65.5
	Powerhouse (building, equipment foundation)	293.7
2.	<u>Electrical Facilities</u>	
	Powerhouse Equipment (turbine, generator, etc.)	448.0
	Transmission Lines	168.0
3.	<u>Consulting Services</u>	300.0
4.	<u>Physical Contingency</u> (including land compensation)	278.7
5.	<u>Price Escalation</u>	181.3
	<u>Total</u>	<u>4,031.3</u>

million yen

Expenditure Schedule						
Item & Cost	Year	1	2	3	4	Total
Civil Works		1,030.4	1,174.0	159.9	294.0	2,658.3
Electrical Facilities		44.8	358.4	-	44.8	448.0
Transmission Lines		16.5	132.0	-	16.5	165.0
Physical Contingency		67.6	184.0	25.1	-	278.7
Consulting Services		120.0	120.0	60.0	-	300.0
Price Escalation		105.7	73.8	1.8	-	181.3
Total		1,387.0	2,042.2	246.8	355.3	4,031.3





IA = 60°00'
R = 200.00
TL = 115.470
CL = 209.438

IA = 16°00'
R = 500.00
TL = 70.270
CL = 139.626

IA = 40°00'
R = 100.00
TL = 36.397
CL = 69.813

1,102.065 (D=4.00)

Total headrace/tunnel length 1,277.065

EL. 92.00

EL. 92.00

EL. 176.50

175.00

320.00

139.626

69.813
(D=400)

150.00

Penstock #135 L=216.00

Sub Station

Power house


Rail and surge

Loading hopper

Second

Tailrace L=130

FIG. 5-1



RIO TUBA HYDROPOWER PROJECT	
Republic of the Philippines	
TENTATIVE FACILITIES	
FOR	
CONSTRUCTION WORKS	
PLAN	
JAPAN INTERNATIONAL COOPERATION AGENCY	
DWG. NO.	SHEET OF

JICA