

Chapter 5.
Refinery Utility Design

Chapter 5. Refinery Utility Design

5.1 General

The refinery utility consists of such facilities as water system, steam system, instrument and air systems, fuel system, inert gas system and effluent water treatment system, etc.

The design basis for these facilities has been in accordance with TENDER DOCUMENT Vol. II Sect. 11, Page 32 through 46 of 60.

The design philosophies for the each system mentioned above are described respectively in the following paragraphs.

In addition, the flow sheet and the main equipment list of the each system are appended hereto.

5.2 Water system

(1) Water treatment

Capacity of raw water shall be given by all consumption of the water for drinking water, cooling tower make-up, miscellaneous process users, supply to demineralization plant, irrigation and fire system, etc.

Water treatment plant shall be schemed two stages of treatment such as clarification and filtration for raw water, and demineralization for filtered water.

Since the water treatment plant areas indicated on the Dwg. No. 40. E2 included in the TENDER DOCUMENTS are not enough to plan the above two-stage treatment the areas shall be made the expansion. Clarification and filtration plant is plotted with the effluent treatment plant

on the east edge area of refinery, and then demineralization plant is plotted on the utility plant area on the west side of process area.

The analysis value of Shatt-Al-Arab river water is given on Table 5 attached to TENDER DOCUMENT Vol. II Sect. 14, 14.3.1 Concerning the Figures given on Table 5, we have not taken into account any large variation through some variation has been into account.

Difinitive figures are given in Chapter 9, Design Engineering Article 9.1.2, (3) Water system herein.

(2) Cooling water

Cooling water maximum demand is considered as that under the design conditions.

Meanwhile, no additional cooling water demand under conditions severer than the design climatic conditions is considered.

In accordance with the requirement "Maximum economic use of air cooling is required" given in TENDER DOCUMENT Vol. II Sect. 10, 10.13.1.6 "Air Cooling", we have established the design criteria as follows:

- (a) Break point between air and water is 60°C (140°F) in principle.
- (b) Surface condenser for the steam turbine exhaust is the water cooled type.

5.3 Steam system

(1) Steam level

Regarding steam levels, as no specific requirements are indicated in the TENDER DOCUMENTS and as no steam power generation is planned in this project, the steam levels

have been decided so as to be convenient for the operation of the PROCESS UNITS.

Also, the steam balance has been provided based on the decided steam levels.

Details of these are as shown below.

- (a) High pressure steam : 32 kg/cm²G, 350°C

This has been decided with consideration given to the design of the waste heat boiler in the HYDROGEN PLANT and the economics of the distribution system.

- (b) Middle pressure steam: 15 kg/cm²G, 300°C and saturated

To meet the temperature required in the process reboiler, the pressure has been decided on, and this middle pressure steam will be superheated for general use in the process, general pump turbine drive, fuel oil steam atomizing, steam supply to hose stations, etc.

- (c) Low pressure steam : 3.5 kg/cm²G saturated

This steam is intended for heating in process reboilers, tank heating and other protective heating.

The steam pressure (3.5 kg/cm²G) has been decided with consideration given to the jacket heating of liquid sulfur.

- (2) Steam balance

The steam balance has been maintained based on the above-mentioned steam levels, so that steam generation in the boiler and low pressure steam release to the atmosphere will be minimum in normal operation.

In this case, turbine driver selection has been made on the basis of the TENDER DOCUMENTS and steam generation in the waste heat boilers has been taken into account.

Turbine drive has been used only for the pumps required to shut down the PROCESS UNITS safely at an emergency (power failure, etc.) and the boiler capacity has been decided so as to cover the steam consumption at power failure.

Meanwhile, motor drive has been considered even for furnace feed pumps in cases where turbine drive has been used for the compressors on the gas sides of combined feed design.

(3) Condensate recovery

(a) Clean condensate

Condensate from the surface condensers and the reboilers in which the process fluid pressure is lower than the steam pressure, will be recovered as clean condensate and will be used in the waste heat boilers in the process area together with boiler feed water from the utility facilities.

(b) Oil contaminated condensate

Condensate from the reboilers in which the process fluid pressure is higher than the steam pressure will be returned as oil contaminated condensate to the condensate recovery system in the utility area since it is possible that the condensate will be contaminated with process fluid.

(c) Process condensate

Process condensate will be treated in respective PROCESS UNITS and will be reused in the PROCESS UNITS, depending on the quality of the treated condensate.

- (d) Condensate from steam traps for steam tracers, steam jackets and header drains will not be recovered.

5.4 Instrument and plant air system

Air shall be generated at 7.7 kg/cm²G by two parallel sets of equipment each set consisting of a compressor, inter and after coolers and a receiver.

The driver of one of the compressors shall be designed a steam turbine to provide security of supply during power failure.

After the air receivers the air shall be separated into two streams, i.e., instrument air and plant air.

5.5 Fuel system

Fuel system consists of fuel gas and fuel oil system.

Fuel gas and fuel oil shall be stored in tanks plotted on the tank yard.

Specification of storage tank shall be referred to tank list herein.

(1) Fuel gas

The generating system shall consist of 3 vessels.

The first of these shall be an LPG storage drum into which shall be fed the liquid streams. It shall be maintained at a pressure above that of the fuel gas system by means of a pressure controller. Any flashed-off vapour from the surge drum shall pass to the second vessel - the fuel gas mix drum. The surge drum shall be level controlled and fitted with a small heating coil to provide the necessary operating pressure by vaporisation.

Liquid LPG from the surge drum shall be passed via a pressure reset level control valve to an evaporator, together with the gas from the surge drum, natural gas and all gaseous streams from the refinery shall pass to the fuel gas mix drum to equalise the differing calorific values of the H₂ rich gas, refinery gas and Natural Gas.

Fuel gas shall be distributed to the process furnaces and off-site boiler and for burners at the flare stack, etc.

(2) Fuel oil

Fuel oil for firing the steam generators and refinery furnaces shall be blended and stored in fixed roof tanks and situated close to the main process, and utility users.

The oil in the distribution pipework shall be maintained at a constant pressure by a pressure control system which will have its sensing element at the furthest point of the fuel oil pipework and the control valve located immediately after the most distant user. Any fuel oil surplus to demand shall be returned to the pump suction via the control valve.

5.6 Inert gas system

N₂ gas shall be produced as 7.7 kg/cm²G by N₂ gas generator. A part of produced N₂ gas shall be compressed to 28.0 kg/cm²G move for use in process plant 28.0 kg/cm²G compressed N₂ gas shall be stored in sphere storage tank planned on utility plant area.

5.7 Miscellaneous utilities

(1) Flare and blow-down system

The main flare header and the flare stack have been sized on the basis that relief valves on all the units should not open simultaneously.

(2) Electric power consumptions

It is understood that the limitations on power consumptions need not be considered and that insufficiency will not be met by supply from any power generator.

Refer: Minutes of meeting on Export Refinery between SCOP and CONTRACTOR at Baghdad held on April 29, 1976 Item 5.10.

(3) Refinery effluent system

The elevation of each area has been decided based on Topographic Site Survey Dwg. No. 508-C-01 included in the TENDER DOCUMENT (Vol. VI a-soil information and topographic; map), and the refinery layout has been planned on the basis that refinery liquid effluent should be passed from west to east.

MAIN EQUIPMENT LIST

1. WATER SYSTEM

Main Equipment	Q'ty	Description (Per One)	Remarks
Raw water pond	1	32M x 30M x 3.6H	
Hi-rate mixing tank	2	3M x 28M x 3.6H	with Flash mixer chemical dosing equipments
Coagulator	4	30M ϕ x 4.8H	
Thickner	1	20M ϕ x 3.1H	
Sand filter	5	11.3M x 9.4M x 2.8H	
Filtered water storage tank	1	72.7M ϕ x 19.3M (80000M ³)	
Drinking water tank	1	4.75M ϕ (50M ³)	elevated sphere tank
Demineralizer unit	3	840 T/H (MAX.)	with measuring hopper and regeneration tower
Demineralized water storage tank	1	43M ϕ x 15.2H (22000M ³)	
Cooling tower	2	25,000 T/H	

2. STEAM SYSTEM

Main Equipment	Q'ty	Description (Per One)	Remarks
Boiler	4	135 T/H	
Dearator	2		with condensate cooler and condensate tank

3. INSTRUMENT AND PLANT AIR SYSTEM

Main Equipment	Q'ty	Description (Per One)	Remarks
Air compressor	2	13000 Nm ³ /h	with air receiver and air dryer

4. FUEL SYSTEM


Main Equipment	Q'ty	Description (Per One)	Remarks
LPG storage tank	1	12.7M ϕ (sphere) (1082M ³)	with LPG drum, balance drum and vaporizer
Fuel oil tank	2	27.5M ϕ x 16H (9503M ³)	with heat exchanger

5. INERT GAS SYSTEM


Main Equipment	Q'ty	Description (Per One)	Remarks
N ₂ generator	3	400 Nm ³ /h	
N ₂ holder	1	500m ³ , 28 kg/cm ² G	sphere tank

6. EFFLUENT SYSTEM


Main Equipment	Q'ty	Description (Per One)	Remarks
API oil separator	7		
Holding basin	2	60M x 60M x 1.5H	




JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
FLOW SHEET FOR WATER SYSTEM	
DWG. NO.	52-G-001




JAPAN INTERNATIONAL COOPERATION AGENCY
EXPORT REFINERY PROJECT
FLOW SHEET FOR STEAM, BW & CONDENSATE
DWG. NO. 52-G-002



JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
FLOW SHEET FOR INSTRUMENT & PLANT AIR & N ₂ SYSTEM	
DWG. NO.	52-G-003



JAPAN INTERNATIONAL COOPERATION AGENCY
EXPORT REFINERY PROJECT
FLOW SHEET FOR FUEL GAS SYSTEM
DWG. NO. 52-G-004



JAPAN INTERNATIONAL COOPERATION AGENCY
EXPORT REFINERY PROJECT
FLOW SHEET FOR HOME FUEL OIL SYSTEM
DWG. NO. 52-G-005

Chapter 6.

Refinery Off-site Tankage Design

Chapter 6. Refinery Off-site Tankage Design

6.1 General

Refinery off-site tankage facilities shall be prepared to store and to blend the miscellaneous oil products and the design basis for these tankage facilities is to be in accordance with TENDER DOCUMENTS Vol. II Sect. 11, Page 2 through 31 of 60.

The schemes of oil systems have been intended based on refinery scheme which was planned from modified crude assay in Sect. 1 & 2 herein. The schemes have not taken into account any large variation though some variation has been into account on the TENDER DOCUMENT.

The tankage capacity, blending and shipping plan have been designed in accordance with the TENDER DOCUMENT as far as possible.

Deviations made in connection with the deviations in the PROCESS UNITS are as shown in the subsequent paragraphs.

The individual specifications of the storage tank are given in the tank list herein.

(1) Adjusted items of tankage equipment and facilities

- (a) The capacities of the intermediate oil tanks have been checked with reference to the changes in the capacities of the PROCESS UNITS.

Though some tanks underrun or overrun the ten-day or five-day storage capacity called for in the TENDER DOCUMENTS, as almost all the tanks satisfy the requirements, it has been decided that the tank capacities should not be altered.

- (b) Since un-desulfurized naphtha from the CRUDE UNITS will be fed directly to the N-HDS UNITS, the vapor pressure of the naphtha will be too high for the un-desulfurized naphtha tanks.

However, the tank will not be eliminated since it can be used to receive un-desulfurized naphtha run down through the N-HDS UNIT and stabilizers at start-up when the naphtha bypasses the N-HDS UNIT reactor section.

- (c) For the atmospheric bottoms tanks, the cone roof type is indicated at TENDER DOCUMENTS, but it has been changed to the floating roof type in connection with the process requirements of the GULF-HDS UNITS.

The booster pumps on the streams from these tanks have been eliminated and the lines to the pumps in the GULF-HDS UNITS are regarded as suction lines.

- (d) Component oil tanks have been provided in accordance with the TENDER DOCUMENTS. Since desulfurized heavy naphtha will not be produced by PROCESS UNIT, desulfurized heavy naphtha tanks can be eliminated, but as they can be used for other purposes, their elimination has not been considered.

(2) Tankage layout

The tankage layout shown on the plot plan included in the TENDER DOCUMENTS has been used after adjustment to the expanded PROCESS UNITS and utility facility areas.

6.2 Crude oil system

Two crude oils will be delivered to the refinery by one pipeline, the N-Rumaila crude oil and Mischerif crude oil. The N-Rumaila and Mischerief crude will each be

stored in three floating roof tanks. The two crude oils shall be routed to six respective storage tanks through the pipeline. Automatic operating pigging equipment shall be provided on the pipeline to avoid the mix of two crude oils.

The sizing of the crude oil tankage is based on providing storage for five days normal feed to the crude oil distillation units.

The crude storage tanks shall be fitted with high level alarms whose signals will be used for the automatic cut-out of the crude pumps.

The crude oils will be transferred from their storage tanks to their respective CRUDE DISTILLATION UNITS.

6.3 Intermediate oil system

Intermediate storage facilities shall be provided for the outputs from the N-Rumaila and Mischerief CRUDE DISTILLATION UNITS to allow the plant to continue operating for a limited number of days in the event of a shutdown of either or both of the CRUDE UNITS.

The sizing of the intermediate oil tankage is, in general, based on providing storage for ten days normal output from the PROCESS UNIT.

6.4 Component oil system

Component storage facilities shall be provided for all input streams to the blenders to allow production of the final products to continue in the event of shutdown of the process plant.

The sizing of the component oil tankage is, in general, dependent upon the product oil tankage in that the size of each component tank is based on the total quantity of that particular component used in blending one storage tank of each and every product, and the number of each component's tank allows discharge and rundown to occur simultaneously using separate tanks.

6.5 Product oil system

The component oils shall be blended in predetermined quantities in three blenders and the resulting black and white product oils shall be stored prior to despatch from the refinery to export terminal.

Blending of the component oils into the black and white product oils shall be accomplished in three in-line digital type blenders.

Automatic operating changing-over valve for control of product shall be attached to this blender.

The blend rates are based on the daily refinery output being blended in 8 hours.

Blender	Blend Rate	Product Oil
Gasoline (blend header No. 1)	1,135 m ³ /hr	Petrochemical naphtha Regular gasoline Premium gasoline Aviation turbine fuel
Kerosine/gas oil (blend header No. 2)	1,039 m ³ /hr	Kerosine Automotive diesel fuel Heating oil
Fuel oil (blend header No. 3)	2,993 m ³ /hr	0.3%S fuel oil 1.0%S fuel oil

Blending will be carried out on a percentage volume basis using turbine or positive displacement meters having automatic temperature compensation to 15.6°C.

All meters shall be provided with twin heads for actual and compensated readings.

The meters with their associated control valve sets shall be located in the discharge lines of the component oil pumps, any ancillary electronic equipment being located in the off-sites control room.

The pumps related to each blender shall be located in a common area with the exception of the butane pumps.

Pump controls and indications shall be located on the blender control panel in the off-sites control room.

Each blender controller shall comprise a master panel and separate component panels.

6.6 Ancillary systems

(1) Additive

In this export refinery, an anti-oxidant additive will be used for the batch blending of aviation turbine fuel, premium gasoline and regular gasoline in their respective storage tanks and in the petrochemical naphtha swing tank.

Other additive will be charged in the above oils in the export terminal.

(2) Slop oil

Slop oil collected on the refinery shall be disposed of into either a single unleaded slop tank for re-use or into the refinery fuel oil tanks for burning.

The slop oil tank shall have heaters and mixers.
The size of the tank is based on providing storage for
10% of the feed to one CRUDE DISTILLATION UNIT.

The slop oil shall be discharged to either the N-Rumaila
or Mischerief crude oil storage tanks or CRUDE DISTILLA-
TION UNIT.

TANK LIST

1. CRUDE OIL TANKS

SERVICE	QTY	CAPACITY (m ³)	SIZE	ROOF TYPE	BOTTOM TYPE	REMARKS
NORTH RUMAILA CRUDE OIL TANK	3	45,931	57m DIA x 18m ST	FLOATING	CONE DOWN	MIXERS FITTED
BUZURGAN/ABU GRAB CRUDE OIL TANK	3	45,931	57m DIA x 18m ST	FLOATING	CONE DOWN	MIXERS FITTED

2. INTERMEDIATE OIL TANKS

SERVICE	QTY	CAPACITY (m ³)	SIZE	ROOF TYPE	BOTTOM TYPE	REMARKS
ATMOSPHERIC BOTTOMS (BUZURGAN) TANK	1	73,286	72m DIA x 18m ST	FLOATING CONE	CONE DOWN	HEATERS FITTED
ATMOSPHERIC BOTTOMS (RUMAILA) TANK	1	73,286	72m DIA x 18m ST	FLOATING CONE	CONE DOWN	HEATERS FITTED
UNDESULPHURIZED MIXED GAS OIL TANK	1	38,933	54m DIA x 17m ST	CONE	CONE DOWN	MIXERS FITTED
UNDESULPHURIZED KEROSENE (BUZURGAN) TANK	1	36,643	54m DIA x 16m ST	FLOATING	CONE DOWN	MIXERS FITTED ALSO USED AS COMPONENT TANK
UNDESULPHURIZED KEROSENE (RUMAILA) TANK	2	14,540	33m DIA x 17m ST	FLOATING	CONE DOWN	FITTED ALSO USED AS COMPONENT TANK
UNDESULPHURIZED NAPHTHA TANK	1	58,160	66m DIA x 17m ST	FLOATING	CONE DOWN	
DESULPHURIZED NAPHTHA REFORMER FEED TANK	1	38,933	54m DIA x 17m ST	FLOATING	CONE DOWN	
REFORMATE TANK	2	28,627	45m DIA x 18m ST	CONE	CONE DOWN	BLANKET PURGE ALSO USED AS COMPONENT TANK
MIXED XYLENE FEED TANK	1	10,691	27m DIA x 18m ST	FLOATING	CONE DOWN	
BUTANE TANK	1	1,082	12.7m DIA	-	-	PRESSURIZED SPHERE

3. COMPONENT OIL TANKS

SERVICE	QTY	CAPACITY (m ³)	SIZE	ROOF TYPE	BOTTOM TYPE	REMARKS
1.0%S BOTTOMS TANK	2	50, 893	60m DIA x 18m ST	CONE	CONE DOWN	HEATERS & MIXERS FITTED
0.3%S BOTTOMS TANK	2	73, 286	72m DIA x 18m ST	CONE	CONE DOWN	HEATERS & MIXERS FITTED
UNDESULPHURIZED HEAVY GAS OIL TANK	2	4, 329	17.5m DIA x 18m ST	CONE	CONE DOWN	MIXERS FITTED
UNDESULPHURIZED MEDIUM GAS OIL TANK	2	11, 309	30m DIA x 16m ST	CONE	CONE DOWN	MIXERS FITTED
DESULPHURIZED HEAVY GAS OIL TANK	2	12, 016	30m DIA x 17m ST	CONE	CONE DOWN	MIXERS FITTED
DESULPHURIZED MEDIUM GAS OIL TANK	2	8, 835	25m DIA x 18m ST	CONE	CONE DOWN	MIXERS FITTED
DESULPHURIZED KEROSENE TANK	2	12, 016	30m DIA x 17m ST	FLOATING	CONE DOWN	MIXERS FITTED
DESULPHURIZED HEAVY KEROSENE TANK	2	4, 329	17.5m DIA x 18m ST	FLOATING	CONE DOWN	MIXERS FITTED
DESULPHURIZED HEAVY NAPHTHA TANK	2	4, 088	17.5m DIA x 17m ST	FLOATING	CONE DOWN	MIXERS FITTED
HEAVY AROMATICS TANK	2	4, 088	17.5m DIA x 17m ST	CONE	CONE DOWN	MIXERS FITTED
DEHEPTANISER OVERHEAD TANK	2	8, 835	25 m DIA x 18m ST	FLOATING	CONE DOWN	MIXERS FITTED
REFFINATE TANK	2	9, 503	27.5m DIA x 16m ST	FLOATING	CONE DOWN	
LIGHT STRAIGHT RUN GASOLINE TANK	2	24, 937	42m DIA x 18m ST	FLOATING	CONE DOWN	MIXERS FITTED
BUTANE TANK	2	2, 081	15.8m DIA	-	-	PRESSURIZED SPHERES
BENSENE	1	17, 303	36.0m DIA x 17m ST	WEATHER MASTER	CONE UP	HEATERS FITTED ALSO USED AS PRODUCT TANK

4. PRODUCT OIL TANKS

SERVICE	QTY	CAPACITY (m ³)	SIZE	ROOF TYPE	BOTTOM TYPE	REMARKS
1.0%S FUEL OIL TANK	3	61,581	66m DIA x 18m ST	CONE	CONE UP	HEATERS & MIXERS FITTED
0.3%S FUEL OIL TANK	3	61,581	66m DIA x 18m ST	CONE	CONE UP	HEATERS & MIXERS FITTED
HEATING OIL TANK	2	15,395	33m DIA x 18m ST	CONE	CONE UP	MIXERS FITTED
AUTOMOTIVE DIESEL FUEL TANK	2	15,395	33m DIA x 18m ST	CONE	CONE UP	MIXERS FITTED
KEROSINE TANK	2	15,395	33m DIA x 18m ST	FLOATING	CONE UP	MIXERS FITTED
ADIATION TURBINE FUEL TANK	2	3,004	15m DIA x 17m ST	FLOATING	CONE UP	MIXERS FITTED
PREMIUM GASOLINE TANK	2	5,340	20m DIA x 17m ST	FLOATING	CONE UP	MIXERS FITTED
REGULAR GASOLINE TANK	2	30,624	51m DIA x 15m ST	FLOATING	CONE UP	MIXERS FITTED
PETROCHEMICAL NAPHTHA TANK	2	8,344	25m DIA x 17m ST	FLOATING	CONE UP	MIXERS FITTED
PARA-XYLENE TANK	1	15,395	33m DIA x 18m ST	WEATHER MASTER	CONE UP	HEATERS FITTED

5. ANCILLARY TANKS

SERVICE	QTY	CAPACITY (m ³)	SIZE	ROOF TYPE	BOTTOM TYPE	REMARKS
REFINERY FUEL OIL TANK	2	9,503	27.5m DIA x 16m ST	CONE	CONE DOWN	HEATERS & MIXERS FITTED
SLOP OIL TANK	1	2,650	15m DIA x 15m ST	CONE	CONE DOWN	HEATERS & MIXERS FITTED
ADDITIVE TANK	2			FLAT	FLAT	

6. LIQUID SULPHUR TANKS

SERVICE	QTY	CAPACITY (m ³)	SIZE	ROOF TYPE	BOTTOM TYPE	REMARKS
LIQUID SULPHUR HEAD TANK	2	100				HEATERS FITTED CYLINDRICAL TANKS

Chapter 7.
Refinery Layout

Chapter 7. Refinery Layout

7.1 Refinery plot plan

(1) We made a study of Dwg. No. 40.E2 Refinery Plot Plan included in the TENDER DOCUMENTS, resulting particularly in the enlargement of PROCESS UNITS (A), PROCESS UNITS (B) and the Utility areas indicated in the attached drawing. Based on this study, we prepared the Refinery Plot Plan as shown in Dwg. No. 00-G-003.

(2) Coordination procedure of refinery plot plan

All locations relative to the refinery plot plan are based on the Bench Mark "A" (South +0, East +0) indicated on Topographic Site Survey Dwg. No. 508-C-01 contained in TENDER DOCUMENT Vol. VI Para. a.

According to the above, the straight road from the main gate which passes on the north side of PROCESS UNITS (B) and goes to the tankage is to be S +920,000 whereas the road between the utility areas located on the west side of PROCESS UNITS (A) and (B) is to be E +440,000. As indicated on Dwg. No. 00-G-021-B "Process General Plot Plan", intersection of the above two roads is indicated as E +440,000, S +920,000.

7.2 General process plot plan

(1) After carefully studying PROCESS UNITS (A), PROCESS UNITS (B) and the pipe tracks to be installed in the area between them, we prepared the General Process Plot Plan shown in Dwg. No. 00-G-021-B.

(2) Configuration of process units

On the refinery plot plan shown on Dwg. No. 40-E2 included in the TENDER DOCUMENTS (Vol. V), the Process Units are grouped into two and located in two separate areas.

This plot plan has been reviewed carefully and the PROCESS UNITS have been grouped into PROCESS UNITS (A) and PROCESS UNITS (B); namely, the HDS COMPLEX have been located together based on the view that they should be covered by the same control room.

(3) Battery limits of process areas

The battery limits of the process areas are as shown by using two-dot chain lines on the process general plot plan Dwg. No. 00-G-021-B.

As seen from the drawing, the substation and the common stack are located outside the process area. The facilities outside the areas will be provided in accordance with the off-site design specification

(4) Enlargement of process plant area

(a) As the result of detailed studies on the areas for both PROCESS UNITS (A) and (B), the plot plan will be a little larger in area than can be estimated from Dwg. No. 40-E2 attached to the TENDER DOCUMENT Vol. V, namely east-west dimension (center line of road) is 500 m and north-south dimension is 270 m for both PROCESS UNITS (A) and (B).

Center spacing between the above two process units (pipe truck area) is laid to be 76 m from the above drawing and thus remains unchanged.

(b) Both spacing between PROCESS UNITS (A) north side battery limit and road, and between PROCESS UNITS (B) south side battery limit and road are enlarged where the substation and common stack are planned to be located.

(5) Plot plan of process control rooms

(a) After an overall study on operation and maintenance, it has been decided not to use the north-west and south-west ends plotted in Dwg. No. 40-E2 but to locate the control rooms at the pipe truck area side of each process unit.

(b) In the PROCESS UNITS (A) area, the control room has been divided into three; one for the N-RUMAILA train, another for the MISCHRIF train and a third for the Common Units. For control in one control room considerably long panels must be provided, and excessively long panels are inadequate for monitoring. Meanwhile, even if the control room is divided into three, no demerits are expected.

7.3 Refinery utility plot plan

Utility plant shall be plotted on the west of on-site, and, water treatment and effluent treatment plant shall be plotted on the east edge of refinery indicated on TENDER DOCUMENT Dwg. No. 40-E2.

It was described in the above section 7.2 that area of these facilities are planned as expanded area than the above indicated area since the area on TENDER DOCUMENT is not enough to these facilities.

In utility plant area, water treatment facilities such as filtrated water storage tank, demineralizer units and demineralized water storage tank shall be planned with utility facilities such as cooling tower, inert gas generator, etc.


Facilities of filtration and effluent treatment facilities basin shall be plotted on water treatment plant on the east side of refinery.

Fuel oil tank and fuel gas tank shall be plotted on the tank yard. Plot plan of these facilities shall be given on Dwg. No. 50-G-001 herein.

7.4 Refinery elevation

On the basis of the contour lines specified in the drawing captioned as Topographic Site Survey (Dwg. No. 508-C-01) which is included in the TENDER DOCUMENTS, the level was decided so that the soil movement may be carried out economically.

The level decided in this manner is specified in this report Section 8.1 Basic Engineering Design Data, Article 8.1.3 Site Conditions, Item 6) and a drawing (Dwg. No. 00-G-002) is attached thereto for reference.




JAPAN INTERNATIONAL
COOPERATION AGENCY

EXPORT REFINERY PROJECT

REFINERY PLOT PLAN

DWG. NO. 00-G-003



FROM B.M.A.
E + 440,000
S + 1574,000


FROM B.M.A.
E + 440,000
S + 1574,000

FROM B.M.A.
E + 440,000
S + 1574,000


JAPAN INTERNATIONAL
COOPERATION AGENCY
EXPORT REFINERY PROJECT

PROCESS PLOT PLAN


DWG. NO. 00-G-021



DETAIL OF
UTILITY PLANT



DETAIL OF
WATER TREATMENT PLANT,
EFFLUENT WATER TREATMENT PLANT



JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
REFINERY UTILITY PLOT PLAN	
DWG. NO.	50-G-001

Chapter 8.
Pipeline Design

Chapter 8. Pipeline Design

8.1 General

For supplying crude oil and raw water to the refinery, and for loading products from the refinery, the following pipelines (including despatching and/or loading stations) have been studied.

	<u>Service</u>	<u>From</u>	<u>To</u>	<u>Length</u> (km)
(i)	Crude oil	N-Rumaila Pumping station	Refinery	50
(ii)	Products			
	o Benzen	Refinery	Muftieh jetty	40
	o Para-xylene	Refinery	Muftieh jetty	40
(iii)	Raw water	Shat Al Arab	Refinery	40
(iv)	Effluent	Refinery	Khor Al Zubair	9
(v)	Others			
	o Butane	Refinery	LPG plant	1
	o Pure butane	LPG plant	Refinery	1
	o Natural gas	LPG plant	Refinery	1

The other pipelines such as White product lines, Black product lines and Ballast water lines, etc. called for in TENDER DOCUMENT will be studied after deciding the location of the Storage Terminal.

(1) Proposed pipeline routes

The pipeline routes for each pipeline were roughly examined in accordance with "Key Plant Pipeline Routes" provided by the ENGINEER during site survey performed on July, 1976.

On the basis of the examination, the pipeline routes as shown in Dwg. No. 00-M-001, "Proposed Pipeline Routes" are recommended.

The difference between original routes and proposed routes is the water pipeline route. The difference comes from no availability of land space for water intake station in Muftieh site.

(2) Basic engineering design data

In addition to the basic engineering design data stipulated in Sect. 9.1, the following site conditions are considered in the design of the pipelines.

Temperature

(i) Air temperature

Minimum	Winter	0°C
Maximum	Summer	46°C

(ii) Soil temperature

Minimum	Winter	4°C
Maximum	Summer	38°C

(iii) Sun exposure temperature

Maximum		82°C
---------	--	------

(3) Pipeline design

(a) Code and standards

Following code and standards are applied to the design of the pipelines.

- (i) ANSI (American National Standard Institute)
- (ii) ASTM (American Society for Testing and Material)
- (iii) ASME (American Society of Mechanical Engineering)
- (iv) API (American Petroleum Institute)
- (v) JIS (Japanese Industrial Standard)
- (vi) ACI (American Concrete Institute)
- (vii) AISC (American Institute of Steel Construction)

(b) The pipelines except Effluent pipeline are planned to be protected against pressure surge hammering due to the starting and stopping of pumps by pressure relief valves.

(c) The pipelines are buried with suitable soil coverages and the cathodic protections are provided by means of the impressed current system.

(d) Where each pipeline crosses roads and railways, the pipeline is protected with steel casing pipe.

8.2 Crude oil pipeline

The pipeline is designed to transport two (2) kinds of crude, i.e., N-Rumaila and Mischrif, from N-Rumaila pumping station to the refinery.

The despatching pump station will be constructed in the area of the existing pumping station, and existing crude tanks and booster pumps will be used for this pump system.

(1) Design flow rate

The design flow rate of the pipeline is 2,700 m³/hr.

The flow rate was decided in considering the capacity of existing booster pumps at the pumping station which is operating at the flow rate from 2,700 m³/hr to 6,400 m³/hr.

(2) Transfer pump system

The pump station has been planned to have the flexibility for operation of two (2) kinds of crude oil and in considering the existing facilities.

The schematic main pump system is shown in Dwg. No. 90-M-001 "Mechanical Flow Sheet". This system consists of four (4) horizontal centrifugal pumps which shall be operated in series and driven by gas turbines.

This system is designed by taking account of the following conditions.

(a) Pressure variation

The pressure loss in the pipeline will vary widely (approximate from 15 kg/cm² to 25 kg/cm²) due to the change of crude oil to be transported and its temperature.

(b) Capacity of existing electricity

The capacity of the existing electricity is already used for the existing facilities and no surplus for new equipments. (It is estimated to be necessary approximate 6,000 KW, if new pumps are driven by electric motors.)

(3) Pipeline sizing

From the calculation of friction loss, the 30 inches of pipe diameter is derived expecting pressure drop as 24.5 kg/cm^2 in the maximum for Mischrif.

Flow sheet of the pipeline is shown in Dwg. No. 90-M-001 "Mechanical Flow Sheet".

8.3 Products pipelines

Two (2) pipelines are designed to transport products from the refinery to Muftieh jetty, one is for benzen and the other is for para-xylene.

(1) Design flow rate

The design flow rate of each pipeline is $800 \text{ m}^3/\text{hr}$.

(2) Transfer pump system

The transfer pump system for each pipeline consists of two (2) horizontal centrifugal pumps driven by electric motors, one is for normal operation and the other is standby.

(3) Pipeline sizing

For benzen pipeline, from the calculation of friction loss, the 16 inches of pipe diameter is derived, expecting the pressure drop as approximate 31.0 kg/cm^2 and for para-xylene, the 16 inches is derived, expecting as 31.0 kg/cm^2 .

(4) Heating up system

Notwithstanding heating up of benzene and para-xylene to approximate 90°C at the refinery, our calculation for heat loss indicates that benzene and para-xylene will be solidified during transportation through the insulated pipelines in winter.

So, it is recommended to apply electrical heat tracing system with insulation such skin electric current tracing system on the pipelines so as to avoid the solidification.

(5) Muftieh terminal

For loading the products to tankers from Muftieh jetty, receiving facilities such as pig receivers, slop pumps and separators, etc. and loading facilities such as loading arms and metering devices shall be installed at Muftieh jetty.

But we found that the spaces needed for both receiving and loading facilities are not available there at present. So we would like to recommend that remodeling and cleaning the old refinery having stopped operation to get the space for receiving facilities, and remodeling the existing wooden jetty located next to the existing concrete jetty and reconstructing new concrete jetty for new loading facilities. (It is estimated to need 10 m in length for installation of two 12" loading arms for two products and one 8" loading arm for deballast water.)

Flow sheets of the pipelines are shown in Dwg. No. 92-M-001, 92-M-002, "Mechanical Flow Sheet".

8.4 Raw water pipeline

The pipeline is designed to transport river water from Shat Al Arab river to the refinery. This pipeline consists of water intake station and pipeline itself.

(1) Design flow rate

Considering the future expansion of refinery, the design capacity of each facility is determined as follows.

For pipeline : 4,500 m³/hr
For raw water transfer pump: Max. 2,900 m³/hr
system Nor. 2,100 m³/hr
For water intake system : 4,500 m³/hr

(2) Water intake system

The location of the water intake station is recommended to shift to the point approximate 10 km down stream from Muftieh site which is indicated in TENDER DOCUMENT, because of no availability of space for constructing new water intake to be estimated as approximate 3,000 m² (60 m x 50 m).

The river water is carried into the sedimentation basin by gravity through intake pipes. The sedimentation basin is equipped with bar screens, scraper and rotating screens (traveling screens) and divided into two parts by partition wall for inspection and maintenance.

The system is shown in "Water Intake System Block Flow Diagram" (Dwg. No. 94-M-010).

(3) Transfer pump system

The transfer system consists of three vertical pump which are operated in parallel and driven by electric motors, two of them are for normal operation and one is standby.

Considering the future expansion, the space for one additional pump in the pump system is provided.

(4) Pipeline

As the location of water intake system is changed, accordingly the route of the pipeline is also changed. Recommended route is shown in "Proposed Routs Drawing", and the length of the route is approximate 40 km.

(5) Pipeline sizing

From the calculation of friction loss, the 38 inches of pipe diameter is derived, expecting the pressure drop as approximate 20.0 kg/cm² at flow rate 4,500 m³/hr, and approximate 10.6 kg/cm² at flow rate 2,900 m³/hr.

Flow sheet of the pipeline is shown in Dwg. No. 94-M-001 "Mechanical Flow Sheet".

8.5 Effluent pipeline

(1) Design flow rate

The design capacity of each facility is determined as follows.

For pipeline : 2,100 m³/hr

For transfer pump system: Max. 2,100 m³/hr

Nor. 1,150 m³/hr

(2) Transfer pump system

The transfer pump system consists of two (2) horizontal centrifugal pumps driven by electric motors, one is for normal operation.

(3) Pipeline

On the route of the pipeline, it is anticipated that the pipeline will pass through flooded area near Khor Al Zubair. At this area, the pipeline shall be installed on pipe sleepers having enough height not to expose the pipeline to flooded water.

(4) Pipeline sizing

From the calculation of friction loss, the 20 inches of pipe diameter is derived, expecting the pressure drop as approximate 20.7 kg/cm² at flow rate 2,100 m³/hr.

Flow sheet of the pipeline is shown in Dwg. No. 54-M-001 "Mechanical Flow Sheet".

8.6 Other pipelines

Three (3) pipelines are designed to transport butan and natural gas between the LPG plant and the refinery.

(1) Design flow rate

The design of the pipelines is based on the following flow rates.

For butan pipeline : 28,400 kg/hr
(Refinery LPG plant)

For butan pipeline : 9,200 kg/hr
(LPG plant Refinery)


For natural gas pipeline: 82,000 Nm³/hr
(LPG plant Refinery)

(2) Pipeline sizing

From the calculation of friction loss, the 3 inches of pipe diameter is derived for the butan pipeline (from the refinery to the LPG plant), the 2 inches is derived for the butan pipeline (from the LPG Plant to the refinery), and the 10 inches is derived for the natural gas pipeline (from the LPG plant to the refinery).


Flow sheets of the pipelines are shown in Dwg. No. 98-M-001, 98-M-002 and 98-M-003, "Mechanical Flow Sheet".


JAPAN INTERNATIONAL
COOPERATION AGENCY
EXPORT REFINERY PROJECT
PROPOSED PIPELINE ROUTES
DWG. NO. 00-M-001




0 1 2 3 4 5 6 7 8 9 10 KILOMETERS
SCALE 1:100,000

FOR PIPELINE ROUTES IN
THIS AREA SEE DWG. NO. 00-15
EXPORT TERMINAL







JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
CRUD OIL FLOW SHEET	
DWG. NO.	90-M-001



JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
BENZENE FLOW SHEET	
DWG. NO.	92-M-001




JAPAN INTERNATIONAL COOPERATION AGENCY
EXPORT REFINERY PROJECT
PARA-XYLENE FLOW SHEET
DWG. NO. 92-M-002




BASRAH CANAL


UNDER GROUND LENGTH L = 40 M
 API 5L-B 38"



JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
WATER INTAKE SYSTEM BLOCK FLOW DIAGRAM	
DWG. NO.	94-M-010




JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
RAW WATER FLOW SHEET	
DWG. NO.	94-M-001




WASTE WATER
POND


UNDER GROUND
APL 51-B 20"



JAPAN INTERNATIONAL COOPERATION AGENCY
EXPORT REFINERY PROJECT
EFFLUENT FLOW SHEET
DWG. NO. 54-M-001





KNOI
DB




UMAILA P.S. I
PILING STATION


JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
BUTANE FLOW SHEET	
DWG. NO.	98-M-001





JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
BUTANE GAS FLOW SHEET	
DWG. NO.	98-M-002





JAPAN INTERNATIONAL COOPERATION AGENCY	
EXPORT REFINERY PROJECT	
NATURAL GAS FLOW SHEET	
DWG. NO.	98-M-003