

THE KINGDOM OF SAUDI ARABIA

STUDY REPORT ON
REVERSE OSMOSIS BRINE REJECT TREATMENT
IN THE CITY OF RIYADH

MARCH 1981

JAPAN INTERNATIONAL COOPERATION AGENCY

TOKYO, JAPAN

THE KINGDOM OF SAUDI ARABIA

STUDY REPORT ON
REVERSE OSMOSIS BRINE REJECT TREATMENT
IN THE CITY OF RIYADH

JICA LIBRARY



1044552[6]

MARCH 1981

JAPAN INTERNATIONAL COOPERATION AGENCY

TOKYO, JAPAN

312

6.8

MPN

14799

国際協力事業団	
受入 月日 84. 9. 28	312
登録No. 09335	61.8
	MPN

PREFACE


In response to the request of the Government of the Kingdom of Saudi Arabia, the Japanese Government decided to conduct a study on the Reverse Osmosis brine treatment Project in the City of Riyadh and entrusted the study to the Japan International Cooperation Agency (J.I.C.A.). The J.I.C.A. sent to Saudi Arabia a survey team headed by Mr. Masaru Ikai from September 27th to October 12th, 1980.

The team exchanged views with the officials concerned of the Saudi Arabian Government and conducted a field survey in the Riyadh area. After the team returned to Japan, further studies were made and the present study report has been prepared.

I hope that this report will serve for the development of the Project and contribute to the promotion of friendly relations between our two countries.

I wish to express my deep appreciation to the officials concerned of the Government of the Kingdom of Saudi Arabia for their kind cooperation extended to the team.

March, 1981

A handwritten signature in dark ink, reading "Keisuke Arita", is written over a horizontal line.

Keisuke Arita
President

Japan International Cooperation Agency

0


0

0

0


C O N T E N T S

1. Summary	1
2. Abbreviations, Definitions of Terms and Units	3
3. Introduction	5
4. Principles of the Study	7
5. Basic Study Data	8
6. Scope of Study	12
7. Conceptual Design	15
7.1 Outline of the Plant	15
7.2 Process Description	17
7.2.1 Pretreatment Section	17
7.2.2 Electrodialysis (ED) Section	20
7.2.3 Evaporator/Crystallizer Section	24
7.2.4 Auxiliary Facilities	26
7.3 Water Balance	27
7.4 Process Flow Scheme	29
7.5 Major Equipment List	30
7.6 Plan of Buildings	35
7.7 Required Plot Area	36
7.8 Single-Line Diagram	37
8. Estimate of Utility and Chemical Consumption and Direct Operation Cost	38
9. Estimate of Operating Personnel	39
10. Estimate of Capital Investment Cost	40
11. Estimate of Project Schedule	42
12. Remarks	45
13. Attachment	
13.1 Related matters annex to Minutes of Meeting	
(1) Minutes of Meeting, dated September 28, 1980	
(2) Minutes of Meeting, dated October 8, 1980	
(3) Minutes of Meeting, dated February 7, 1981	
13.2 Tentative Report, Document No. SAJ/RO-101	
13.3 Interim Report, Document No. SAJ/RO-102	



معمل معالجة المياه الفائضة بالرياض لوزارة الزراعة والمياه

MINISTRY OF AGRICULTURE AND WATER
SIMPLIFIED FLOW CHART
R. O. BRINE REJECT TREATMENT PLANT
IN RIYADH



معمل معالجة المياه الفائضة بالرياض
لوزارة الزراعة والمياه

1. Summary

This study report was prepared by the Japan International Cooperation Agency (JICA) in response to a request from the Ministry of Agriculture and Water of the Government of the Kingdom of Saudi Arabia (MOAW) to solve certain problems concerning the disposal of brine reject which would be produced following the completion of reverse osmosis (RO) plants in the three water treatment plants (Malez, Manfouha and Shemessy) in the city of Riyadh.

One method was selected by MOAW from the methods described in the Interim Report prepared by the Japanese team sent by JICA for an on-the-spot survey.

The method, called an integrated plant, has numerous advantages compared to the others in capital investment, operation, number of workers, etc. The integrated plant consists of several process facilities: pretreatment and electrodialysis facilities, evaporator/crystallizer and required auxiliary facilities.

A brief outline of the integrated plant is as follows:

Capacity: $12,340 \text{ m}^3/\text{d}$ of brine reject of $12,720 \text{ mg/l}$ in TDS

Recovered water: $11,281 \text{ m}^3/\text{d}$ of $1,500 \text{ mg/l}$ in TDS

Extracted solid waste: 269 ton/d

Capital investment cost: US\$58,650,000 on full turn-key basis

Fuel and chemical consumption: US\$6,064,000 per year
(365 days, 8,000 hours of operation)

Required area: $15,200 \text{ m}^2$ (160 m x 95 m)

The above capital cost does not include brine-gathering systems as it has been decided that MOAW would conduct study and construction of the transportation systems of RO brine reject.

This report consists of a conceptual design of the integrated plant, an estimate of utility and chemical consumption and direct operation costs, operating personnel, capital investment cost, project schedule and attachments.

The attachments are the Annex to the Minutes of Meetings between MOAW and the Japanese site survey team and the related reports.

2. Abbreviations, Definitions of Terms and Units

Abbreviations, definitions of terms and units used in this report are as follows:

2.1 Abbreviations

- (1) ED: Electrodialysis process
- (2) RO: Reverse Osmosis process
- (3) MOAW: The Ministry of Agriculture and Water of the Government of the Kingdom of Saudi Arabia
- (4) JICA: Japan International Cooperation Agency
- (5) JIS: Japanese Industrial Standards
- (6) TDS: Total dissolved solids
- (7) DC: Direct current

2.2 Definitions of Terms

- (1) "Three RO Plants": the three RO plants at Manfouha, Shemessy and Malez in the city of Riyadh
- (2) "Integrated Plant": the independent plant to be constructed to treat brine reject from the Three RO Plants
- (3) "Brine Reject": the concentrated brine produced at the Three RO Plants
- (4) "Recovered Water": the water which is produced by the Integrated Plant
- (5) "Battery Limit": the battery limits shown on the drawing "Plot Plan" in section 7.7 of this report.

2.3 Units

- (1) mm: Millimeter
- (2) cm: Centimeter
- (3) m: Meter

- (4) km: Kilometer
- (5) cm²: Square Centimeter
- (6) m²: Square meter
- (7) m³: Cubic meter
- (8) l: Liter
- (9) kl: Kiloliter
- (10) mg: Milligram
- (11) kg: Kilogram
- (12) ton: Metric ton
- (13) h: Hour
- (14) d: Day
- (15) y: Year (365 days)
- (16) A: Ampere
- (17) Hz: Hertz
- (18) V: Volt
- (19) KW: Kilowatt
- (20) KV: Kilovolt
- (21) Kcal: Kilocalorie
- (22) RPM: Revolution per Minute
- (23) °C: Centigrade

3. Introduction

This feasibility study has been carried out at the request of the Government of the Kingdom of Saudi Arabia for a method of disposing of Brine Reject from the Three RO Plants at Malez, Manfouha and Shemessy, which has been installed to treat ground water pumped up from deep wells in the city of Riyadh.

In order to cope with the demand for fresh water by the increasing population of the Riyadh area, the Government of the Kingdom of Saudi Arabia have decided to supply potable water from aquifers at 1,200 to 1,500 meters below the surface.

The ground water from the aquifers has high values in hardness, sulfate ions and total dissolved solids, and is supplied as potable water after treatment by a lime-soda process which is mainly aimed at softening the water at the existing Malez, Manfouha and Shemessy Water Treatment Plants.

As a result of studies by MOAW, a new method containing the RO process was adopted to improve the quality of the potable water.

Improvements in the quality of the water supplied will be attained by the RO plants, but the disposal of concentrated brine that is rejected by the RO plants raises new problems; that is, the Three RO Plants require the installation of adequate facilities to treat and dispose of the Brine Reject effectively in order to facilitate the practical operation of the RO plants.

For the purpose of solving this serious problem, a Japanese study team was organized by JICA in September, 1980, and the JICA sent a site survey team to Riyadh from September 26 to October 13, 1980.

The site survey team proposed several methods of disposing of the Brine Reject in two reports (Tentative Report [Document No. SAJ/RO-101] and Interim Report [Document No. SAJ/RO-102]) to MOAW during their stay in Riyadh.

The latter was prepared on the basis of MOAW data and suggestions. It contains the idea of an integrated plant to treat all Brine Reject from all of the Three RO Plants and five other ideas on treating Brine Reject separately in each water treatment plant.

On November 29, 1980, MOAW requested the Japanese Government to draw up a final report on the lines of the Integrated Plant with auxiliary facilities.

The Integrated Plant described in the following sections is based on a unified plan which clarifies the ideas involved in the disposal method selected for the Brine Reject. In the Integrated Plants, the Brine Reject is processed to produce Recovered Water and solid waste. The volume of Recovered Water is the largest compared to the other methods. The Recovered Water is an excellent water resource, and the solid waste can be disposed of easily due its smaller volume compared to the solution.

The Brine Reject gathering systems are not included in the following conceptual design, as it has been decided that MOAW would conduct study and construction.

4. Principles of the Study

The Integrated Plant has been studied on the basis of the following principles:

- (1) The water recovered should be as much as possible.
- (2) The Recovered Water should be usable for irrigation, recharge, industry and other purposes.
- (3) The Integrated Plant should not produce any aqueous waste, only solid waste.
- (4) Only fuel and chemicals should be supplied to the Integrated Plant. Utilities, such as electric power, water and steam should be produced by the Integrated Plant itself.
- (5) The Integrated Plant should be an independent plant containing all necessary auxiliary facilities.
- (6) The Integrated Plant should be more economical in construction and operation costs than three separate plants.
- (7) The design of the Integrated Plant should be simple to provide ease of operation and maintenance.
- (8) The Integrated Plant should be designed to operate continuously for 8,000 hours a year (365 days) with a shutdown once a year for periodic inspection, maintenance and repair work.
- (9) The Integrated Plant should not be provided with a full stand-by process train. However, the process train should be provided with stand-by mechanical equipment, such as pumps, required for continuous operation and for daily maintenance.

5. Basic Study Data

Basic data for the study of the Integrated Plant is as follows:

5.1 Volume of Brine Reject to be treated

from the Malez Plant	2,230 m ³ /d
from the Manfouha Plant	6,800 m ³ /d
from the Shemessy Plant	<u>3,310 m³/d</u>
Total	12,340 m ³ /d

The flow of Brine Reject is assumed to be continuous and drastic fluctuations in the flow rate are not anticipated.

5.2 Analysis of Brine Reject

Sodium	(as Na ⁺)	3,520 mg/l
Calcium	(as Ca ⁺⁺)	160 mg/l
Magnesium	(as Mg ⁺⁺)	470 mg/l
Chloride	(as Cl ⁻)	3,120 mg/l
Fluoride		0
Bicarbonate		0
Sulfate	(as SO ₄ ⁻⁻)	3,350 mg/l
Silica	(as SiO ₂)	85 mg/l
Phosphate	(as PO ₄)	20 mg/l
TDS		12,720 mg/l
pH		5 - 6
Temperature		30°C

Note: (1) Analytical data was provided by MOAW.

(2) Analytical methods conform to the Standard Methods for the Examination of Water and Waste Water (14th Edition), APHA-AWWA-WPCF.

5.3 Projected Quality of Recovered Water

- (1) Dilute water from the ED section

TDS 1,500 mg/l or less

- (2) Steam Condensate from the Evaporator/Crystallizer section

TDS 30 mg/l or less

5.4 Brine Reject Supply and Recovered Water Delivery Conditions

- (1) Supply pressure of the Brine Reject at the Battery

Limits of the Integrated Plant 0.3 kg/cm²G

- (2) Delivery pressure of the Recovered Water at the

Battery Limits of the Integrated Plant 3 kg/cm²G

Note: It is assumed that the Brine Reject will be pumped from the Three RO Plants to the Integrated Plant.

5.5 Plant Location

The Integrated Plant will be located near the existing Manfouha Sewage Treatment Plant in the city of Riyadh.

5.6 Site Conditions

5.6.1 General

It is assumed that site is sufficiently flat that land preparation and leveling work will not be required and that there are no aboveground or underground obstacles to construction.

5.6.2 Soil Bearing Capacity 20 ton/m²

5.6.3 Seismic Factor None

5.7 Meteorological Data

5.7.1 Ambient Temperature

Minimum -5.6°C

Maximum 47.7°C

5.7.2 Relative Humidity

Winter 100 - 6%

Summer 68 - 2%

5.7.3 Rainfall

Daily maximum 51.5 mm/d

Annual minimum 21.6 mm/y

Annual maximum 176.6 mm/y

5.7.4 Wind Velocity

Maximum 32 km/h

5.7.5 Evaporation Rate

Average 2,890 mm/y

5.8 Fuel and Chemicals Conditions

5.8.1 Fuel

Light diesel oil

Heat Value: 10,280 kcal/kg

Specific Gravity: 0.82 - 0.85

Delivery: by tank lorry

Unit Price: 21 US\$/kl

5.8.2 Chemicals

	<u>Type</u>	<u>Purity</u>	<u>Delivery</u>	<u>Unit Price at site (US\$/ton)</u>
(1) Calcium Hydroxide (Ca(OH) ₂)	Powder	> 72% as CaO	1 m ³ container bag	82
(2) Sodium Carbonate (Na ₂ CO ₃)	Powder (Heavy)	> 99%	1 m ³ container bag	312
(3) Polyelectrolyte	Powder	100%	20 kg paper drum	6,363
(4) Sodium Sulfite (Na ₂ SO ₃)	Granular	> 67%	25 kg paper bag	857
(5) Sulfuric Acid (H ₂ SO ₄)	Liquid	> 98%	tank lorry	318
(6) Caustic Soda (NaOH)	Flake	> 99%	25 kg paper bag	380
(7) Hydrochloric Acid (HCl)	Liquid	35%	tank lorry	100

5.9 Technical Codes & Standards

In general, JIS codes and standards are applied to this study.

Manufacturer's standards, however, are also applied to special equipment.

Analytical methods for water conform to the Standard Method for Examination of Water and Waste Water (14th Edition), APHA-AWWA-WPCF.

6. Scope of Study

This study covers the conceptual design, estimates of utility and chemical consumption, capital investment cost, direct operating costs, operational personnel and overall project schedule for the Integrated Plant.

6.1 Items Included

The following facilities and works inside the Battery Limits of the Integrated Plant, as shown on the drawing "Plot Plan" in Section 7.7, are included.

6.1.1 Process Plant with Instrumentation, Piping and Structure

- (1) Cold lime-soda softeners
- (2) Filter units
- (3) ED units
- (4) Evaporator/crystallizer units
- (5) Chemical feed units
- (6) Sludge dehydration units

6.1.2 Auxiliary Facilities

- (1) Brine reject storage
- (2) Recovered Water storage and transfer pumps
- (3) Fuel oil system
- (4) Boiler and power generator for processing use
- (5) Diesel power generator for utility use
- (6) Buildings with air conditioning, lighting, furniture, etc.
 - 1) Control building
 - 2) Power station
 - 3) Warehouse

- 4) Guard box
- 5) ED building
- 6) Perimeter fence and gates
- 7) Drainage system
- 8) Road and pavement
- 9) Parking lot
- 10) Lighting system
- 11) Telecommunication system
- 12) Fire hydrant system
- 13) Drinking water system

6.1.3 Construction Work

- (1) Site grading work
- (2) Civil engineering work
- (3) Architectural work
- (4) Fabrication and erection work
- (5) Piping work
- (6) Instrumentation work
- (7) Electrical work
- (8) Painting and insulation work

6.1.4 Indirect Work

- (1) Project management
- (2) Engineering work
- (3) Procurement and delivery of equipment and materials
- (4) Temporary work
- (5) Insurances related to construction
- (6) Construction supervision work
- (7) Pre-commissioning work and performance test to be

conducted by MOAW operating personnel under the supervision of the contractor

6.2 Items Excluded

The following facilities and works are excluded from this study:

- (1) Gathering and transportation system for Brine Reject from the Three RO Plants to the Battery Limits of the Integrated Plant
- (2) Transportation pipeline for Recovered Water outside the Battery Limits
- (3) Transportation and permanent dump facilities for solid waste and sludge
- (4) Transportation facilities for operating personnel
- (5) Catering facilities for operating personnel
- (6) Laboratory
- (7) Dormitory for operating personnel
- (8) Landscaping
- (9) All other facilities and works outside the Battery Limits of the Integrated Plant
- (10) Site selection and land aquisition
- (11) Commissioning and training of MOAW operating personnel

7. Conceptual Design

7.1 Outline of the Integrated Plant

The Integrated Plant consists of the following:

- (1) Pretreatment Section
- (2) Electrodialysis (ED) Section
- (3) Evaporator/Crystallizer Section
- (4) Auxiliary Facilities

The Integrated Plant has the capacity to process 12,340 m³/d of brine reject from the Three RO Plants, and to produce approximately 11,000 m³/d of Recovered Water for irrigation and other purposes and approximately 270 ton/d of solid waste for disposal.

7.1.1 Pretreatment Section

The pretreatment section employs a cold lime-soda softening process to remove calcium and silica from the Brine Reject in order to prevent scale formation on the ED membranes.

7.1.2 ED Section

The ED Section recovers low-salinity water from the softened brine and also concentrates the softened brine in order to reduce the volume of water to be evaporated in the evaporator/crystallizer section.

Approximate 85% of the volume of brine can be recovered as dilute water; at the same time, the volume of water sent to the evaporator/crystallizer section is reduced to approximate one-seventh of its previous volume.

7.1.3 Evaporator/Crystallizer Section

The evaporator/crystallizer section employs a triple-effect forced-circulation system. The concentrated brine is evaporated and salts dissolved in the brine are crystallized as solid waste.

The solid waste is sent by trucks to a permanent dump site outside the Integrated Plant.

Steam condensate around 40,000 m³/d from the evaporator is used as boiler feed, cooling tower makeup, utility and process water, and the remaining approximately 570 m³/d of high purity water produced by the evaporator is sent to the Recovered Water pit.

7.1.4 Auxiliary Facilities

The main auxiliary facilities are the boiler plant, steam turbine power generator, diesel engine power generator, cooling tower and water storage pits.

This combination of ED and evaporator/crystallizer is the most suitable technique for the Brine Reject treatment.

This technique has been developed in Japan for producing table salt from sea water and has been in commercial use for over ten years.

The following technical improvements have been made in this technique:

- (1) High-conductivity and high-permselectivity
ED membrane
- (2) Large-scale, high-efficiency ED unit
- (3) Anti-scale formation technique for the
evaporator

- (4) Anti-corrosion materials for the high temperature brine

With these improvements, efficient production of table salt from sea water has been attained with lower energy consumption.

Salt production plants using this process combination have been operated successfully.

7.2 Process Description

7.2.1 Pretreatment Section

The pretreatment section consists of two cold lime-soda softeners, four sand filters, two filter presses for sludge dewatering and chemicals storage and feeders.

The cold lime-soda softening process is designed to remove calcium salts, magnesium salts and silica contained in the Brine Reject and which cause scale formation on the ED membranes.

Preliminary beaker tests on the Brine Reject softening were carried out during the site survey in September - October 1980.

The test results are shown on the next page :

Brine Reject		Test No.1	Test No.2
Chemicals Feed Rate - mg/l		NaOH 2,000	Ca(OH) ₂ 1,600
		NaCO ₃ 500	Na ₂ CO ₃ 2,500
pH	3.7	12.3	11.5
Ca mg/l (as Ca ⁺⁺)	540	6.7	3.2
SiO ₂ mg/l	107	28.4	10.8
TDS mg/l	12,200	11,900	11,200

This results indicated that a cold lime-soda softening process would provide sufficient water quality for the ED process, although a combined process of cold lime softening and cation exchange was proposed in the Tentative Report.

(1) Cold lime-soda Softeners

Two cold lime-soda softeners, with a capacity of 280 m³/h each, are normally operated in parallel.

At the softener inlets, sufficient amounts of lime slurry, soda ash solution and poly-electrolyte solution are injected into the Brine Reject.

Calcium and magnesium salts contained in the Brine Reject react with the injected chemicals in the reaction chambers of the softeners and are converted to insoluble calcium hydroxide and magnesium hydroxide which are precipitated in the

precipitation chambers of the softeners.

Silica is also precipitated together with magnesium hydroxide. The softened brine overflows from the top of the softeners into the filters.

The settled sludge is collected by rake to the center of the softener and pumped to the filter presses for dewatering.

(2) Sand Filters

The sand filters are designed to remove residual suspended solids from the softened brine.

Four sand filters, with a capacity of 135 m³/h each, are normally operated in parallel.

While one of the sand filters is being backwashed, the remaining three filters are capable of filtering the full water flow.

The filtered brine is sent to the ED section via the filtered water pit.

The filters are automatically backwashed periodically using air and filtered brine.

The backwash waste water is sent back to the softener inlets for retreatment via a backwash waste pit.

(3) Chemicals Storage and Feeding System

The chemicals storage and feeding system consist of chemicals silos for lime and soda ash storage, chemicals tanks and chemicals injection pumps.

Three chemical silos have a total storage capacity for one week's normal operation.

Lime and soda ash are measured by dry chemical feeders and fed by pumps into the Brine Reject as a slurry.

The poly-electrolyte is dissolved in water and fed by controlled volume reciprocating pump.

The chemical feeding rates are manually set to correspond with the water flow rate and water quality.

(4) Filter Press

The sludge from the softeners is dehydrated by the filter presses.

Two filter presses are provided and the sludge charging, pressing and discharging cycles are carried out in sequence.

The dehydrated sludge is dropped directly from the filter presses to a sludge yard for temporary storage and then sent out by trucks to permanent dump site outside the Integrated Plant.

The volume of dehydrated sludge is approximate 104 ton/d.

7.2.2 Electrodialysis (ED) Section

The filtered brine from the pretreatment section is treated by the ED units to produce dilute water and concentrated brine.

The volume of the brine is reduced to approximately one-seventh of that of the Brine Reject by the ED

units and the recovery rate for dilute water is around 85%.

Four Model DS-V* ED units are installed in the ED section. Each unit comprises four blocks of ED stacks which have one pair of electrodes, 400 pairs of ion-exchange membranes and 400 pairs of dilution and concentration chambers in each stack.

As design basis, 511 m³/h of the filtered brine is supplied to the ED section. Around 435 m³/h of the filtered brine is continuously fed to the dilute pit and the remainder is fed to the concentrate pit. The diluted and concentrated liquors are recycled to the ED units and all units are operated in parallel.

DC electricity is applied to the units by the constant voltage method and estimated average voltage is around 420 V. Although the electric current to the units is varied with the temperature of the brine, the estimated average value is around 1,900 A/unit.

During normal operation, around 435 m³/h of the dilute water, with less than 1,500 mg/l of TDS, is discharged from the dilute pit to the Recovered Water pit. And around 76 m³/h of

- - - - -
* To make rather clear explanation, a specific model is used.

concentrated brine, with around 75,700 mg/l of TDS, is sent to the evaporator/crystallizer section after being used as the electrode rinse liquor.

The results of ED are: approximately 85% of the softened brine is recovered as dilute water and around 90% of the solid content of the brine is accumulated in the concentrated brine.

During normal operation, filtered brine is continuously supplied to the pits by the automatic flow rate control system, and dilute water is discharged from the dilute pit at approximately same flow rate as the filtered brine is supplied.

Overflow from the concentrate pit is supplied to the electrode rinse pit and recycled to the electrode chambers of the units.

To prevent the scale formation in the concentration and cathode chambers, small amounts of acid are injected into the filtered brine.

Overflow from the electrode rinse pit is sent to the evaporator section after neutralization of the excess acid with caustic soda and the reduction of free chlorine generated in the anode chambers of the units with sodium sulfite.

The DC voltage is automatically regulated within desired range and amperage to the ED units is adjusted within desired range accordingly.

There is no need to readjust voltage or amperage for the units during steady-state operation.

When the flow rate or pressure of the liquor deviates outside the designed range, warnings are given to indicate the fact for manual adjustment of the flow conditions. If there is an extraordinary deviation in the flow conditions, such as might be caused by extreme failure of pumps or other equipment, an interlock circuit detects the phenomena and all equipment is shutdown immediately.

Thus, there is no need for frequent inspections of the equipment during normal operation.

In so far as the pretreatment of the Brine Reject is performed properly, there is no need for frequent maintenance of the ED units. However, very small amounts of suspended matter will deposit in the ED units during long-term operations. Special chemical cleaning, using oxidizing and reducing agents and detergents, is necessary once or twice a year. Maintenance on the other equipment is performed according to a predetermined maintenance schedule.

When disassembling the ED units, each ED stack is disassembled separately after replacement with a spare stack.

7.2.3 Evaporator/Crystallizer Section

In the evaporator/crystallizer section, water is evaporated from the concentrated brine from the ED section. Various salts dissolved in the brine are crystallized and discarded as solid waste. This section consists of triple-effect evaporators with a crystallizer, and centrifuges for dewatering the salts. The evaporators and the crystallizer are of the forced circulation type to avoid scale formation on the surface of the heating tubes.

The exhaust steam from the power generator is utilized as the heat source for the first heater and the crystallizer heater.

The concentrated brine from the ED section is fed to triple-effect evaporators with a crystallizer by the backward flow. First, the brine is fed to the third vapor body through the pre-heater where the brine is heated by the condensate from the second and the third heaters. Next, it flows through the second vapor body, the first vapor body and finally the crystallizer. The results of evaporation is the crystallization of the dissolved salts into a mixed salt slurry in the first vapor body and the crystallizer. This mixed salt slurry is sent to the centrifuge feed tank. In this tank, the slurry is thickened and fed to a continuous push-type centrifuge. The dehydrated mixed salts from the centrifuge are discarded as solid waste. The water from the centrifuge

is fed back to the crystallizer.

In addition, a part of the mother liquor is discarded from the crystallizer to avoid scale formation. This mother liquor is rich in magnesium chloride at high temperature and the discarded magnesium chloride crystallizes into crystal by cooling.

At the same time, the condensate from the first heater and the crystallizer heater is returned to the boiler. The condensate from the second and the third heaters is used as process water and makeup water for the boiler and the cooling tower after it is cooled with the feed brine in the pre-heater. The vapor from the third vapor body is cooled in the direct condenser with circulating cooling water. Non-condensable gases from the vapor body are discharged by means of a vacuum system which consists of a two-stage steam ejector.

The evaporator/crystallizer are shutdown a few times a year for cleaning by water and chemicals.

During the shutdown, the concentrated brine from the ED section is stored in a 1,000 m³ concentrate pit in order to maintain the continuous operation of the pretreatment and ED sections.

165 ton/d of dehydrated salts are discarded from the centrifuges and sent out by trucks to a permanent dump site outside the Integrated Plant.

7.2.4 Auxiliary Facilities

The major auxiliary facilities are described below:

(1) Boiler and Steam Turbine Power Generator

A package-type boiler with a capacity of 45 kg/cm² and 60 m³/h is provided.

High pressure steam from the boiler is supplied to a steam turbine power generator with a capacity of 8,000 KVA.

The steam turbine power generator supplies electric power for the main process equipment, including the ED units.

The low-pressure exhaust steam from the steam turbine is supplied to the evaporator/crystallizer section for heating.

(2) Diesel Engine Power Generator

Two diesel engine power generators are provided to produce electric power for process control, lighting, utilities, and the start-up and shut-down operations of the Integrated Plant.

The diesel engine power generators have a capacity of 625 KW each. Normally one is in operation and the other is in stand-by.

(3) Fuel System

The fuel system consists of a 1,000 kl oil storage tank and fuel pumps.

Light diesel oil is supplied by tank lorry to the oil storage tank and pumped to the boiler and

the diesel engines.

(4) Cooling Tower

A cooling tower with a capacity of 2,000 m³/h is provided to supply cooling water to all process equipment and utility facilities.

Steam condensate from the evaporator/crystallizer is supplied to the cooling tower as makeup water.


(5) Water Storage pit

Two 500 m³ water storage pits are provided for receiving the Brine Reject and storing the Recovered Water.

7.3 Water Balance

A rough water balance for the Integrated Plant is shown on the attached drawing.

A total of 11,281 m³/d of water is recovered from the Brine Reject and 269 ton/d of solid waste is produced.



No.	1	2	3	4	5	6	7	8	9	10	11
Name of Flow	Brine	Brine	Softened Brine	Filtered Brine	Backwash waste	Slurry	Sludge	Filtrate	Recov'd Water	Conc. Brine	Conc. Brine
H ₂ O ton/d	12,340	13,288	13,007	12,267	740	281	73	208	10,427	1,840	2,017
Solids ton/d	-	-	-	-	-	31	31	-	-	-	-
TDS mg/l	12,720	-	-	12,630	-	-	-	-	1,500	75,700	-

No.	12	13	14	15	16	17	18	19	20	21
Name of Flow	Slurry	Salts	Sludge	Water from Centrifuge	Steam	Condensate	Recov'd Water	Condensate	Cooling Water	Evaporation Loss
H ₂ O ton/d	203	26	99	177	790	790	854	39,360	38,400	1,200
Solids ton/d	139	139	170	-	-	-	-	-	-	-
TDS mg/l	-	-	-	-	-	< 10	< 30	< 30	-	-

Rough Water Balance Sheet for the Integrated Plant

7.4 Process Flow Scheme

The process flow scheme for the Integrated Plant is shown on the attached drawing No. SAJ/RO-101.

The drawing shows all process equipments and controls.

7.5 Major Equipment List

Major process equipment and auxiliary facilities for the Integrated Plant are listed in the attached list.

1. Pretreatment Section

Item	No. Req'd	Capacity	Type	Remarks
Cold Lime-Soda Softener	2	280 m ³ /h x 2	14,000 ϕ Cylindrical Precipitator with Rake	Concrete/Carbon Steel
Sand Filter	4	135 m ³ /h x 4	4,800 ϕ Cylindrical, Double Layer Gravity Filter Automatic Backwashing	Carbon Steel with Epoxy Coating
Filter Press	2	12 m ³ /h	Automatic	
Chemical Silo	3	250 m ³ x 3	Cylindrical, with dry Chemical Feeder and Pneumatic Loading System	Carbon Steel
Raw Water Pit	1	500 m ³	Semi-underground, with Pumps	Concrete
Filtered Water Pit	1	600 m ³	Semi-underground, with Pumps	Concrete
Backwash Waste Pit	1	300 m ³	Semi-underground, with Pumps	Concrete

2. Electrodialysis Section

Electrodialysis Unit	4	130 m ³ /h x 4	Model DS-V Membrane: Selemion CMV/AMV 1600 Pairs/Unit	
Dilution/ Concentration/ Electrode Rinse Pit	1	360 m ³	Semi-underground, with Pumps	Concrete with Epoxy Lining

Service	No. Req'd	Capacity	Type	Remarks
Rectifier with Transformer	4	1,000 KVA	460 V x 2,050 A	
<u>3. Evaporator/Crystallizer Section</u>				
First Vapor Body	1		4,500 Ø Cylindrical	SUS 316 Clad
Second Vapor Body	1		4,500 Ø Cylindrical	SUS 316 Clad
Third Vapor Body	1		6,000 Ø Cylindrical	SUS 316 Clad
Crystallizer	1		2,300 Ø Cylindrical	Monel Clad
Pre-Heater	1		Plate Type	Titanium
Crystallizer Heater	1		Shell and Tube	Cupronickel/ Monel Clad
First Heater	1		Shell and Tube	Aluminium Brass/ SUS 316 Clad/ Carbon Steel
Second Heater	1		Shell and Tube	Aluminium Brass/ SUS 316 Clad
Third Heater	1		Shell and Tube	Aluminium Brass/ SUS 316 Clad
Vacuum System	1		Two-Stage Ejector and Direct Condenser	SUS 304/Carbon Steel

Service	No. Req'd	Capacity	Type	Remarks
Hot Well	1		4,000 Ø Cylindrical	Carbon Steel
Centrifuge Feed Tank	1		3,600 Ø Cylindrical	SUS 316L Clad
Centrifuged water Tank	1		2,500 Ø Cylindrical	SUS 316L Clad
Flow Tank	2		4,500 Ø Cylindrical	Carbon Steel SUS 316L
Centrifuge	1 + 1		Continuous Push-Type	
Concentrate Pit	1	1,000 m ³	Semi-underground, with Neutralizing Equipment and Pumps	Concrete

4. Auxiliary Facilities

Boiler	1	70 m ³ /h x 45 kg/cm ²	Packaged Water Tube-Type	
Steam Turbine Power Generator	1	8,000 KVA	Basket-Type	
Diesel Engine Power Generator	1 + 1	625 KW	3.3 KV, 60 Hz, 9,000 RPM	
Cooling Tower	1	2,000 m ³ /h	Cross Flow-Type	
Oil Storage Tank	1	1,000 kl	10,600Ø Cone Roof-Type	Carbon Steel

Service	No. Req'd	Capacity	Type	Remarks
Steam Condensate Tank	2	140 m ³ 330 m ³	for Boiler Feed Water for Cooling Tower Makeup and Utility Water	Carbon Steel
Recovered Water Pit	1	500 m ³	Semi-underground, with Pumps	Concrete
Instrument Air System	1 + 1	150Nm ³ /h 7 kg/cm ²	Reciprocating Compressor with Air Dryer and Air Receiver	

7.6 Plan of Buildings

Buildings for the Integrated Plant are described below. The plans for the control and ED buildings are shown, as examples, on the attached drawings Nos. SAJ/RO-102, -103, -104 and -105.

(1) Control Buildings

14 x 25 m, 350 m²

Reinforced concrete, with air conditioner and utility facilities

(2) Electrodialysis (ED) Building

14.5 x 33 m, 478.5 m²

Steel structure, asbestos cement sheet wall and roof with spot air conditioner and overhead traveling crane

(3) Power Station

28 x 19 m, 532 m²

Reinforced concrete

1) Switch gear room with air conditioner

2) Generator room with ventilator and overhead traveling crane

(4) Warehouse

14 x 10 m, 140 m²

Reinforced concrete, with air conditioner

(5) Guard Box

4 x 3 m, 12 m²

Reinforced concrete, with air conditioner

7.7 Required Plot Area

The plot plan of the Integrated Plant is shown on the attached drawing No. SAJ/RO-106.

An area of 15,200 m² is required.

7.8 Single-Line Diagram

A single-line diagram of the electric power distribution system for the Integrated Plant is shown on the attached drawing No. SAJ/RO-107.

The steam turbine power generator normally supplies electric power to the process equipment.

The diesel engine power generator supplies electric power for process control, lighting and utility use as well as for the start-up and shutdown operations of the Integrated Plant.

8. Estimates of Utility and Chemical Consumption and of Direct Operating Cost

The utility and chemical consumptions are estimated on the Basic Study Data described in Section 5 and 8000-hour annual operation.

Utility, Chemical and Consumable	Annual Consumption	Unit Price (US\$)	Annual Cost (US\$)
Lime	6,580 ton	82/ton	540,000
Soda Ash	11,105 ton	312/ton	3,465,000
Poly-electrolyte	8 ton	6,363/ton	51,000
Sulfuric Acid	143 ton	318/ton	45,000
Caustic Soda	117 ton	380/ton	45,000
Sodium Sulfite	80 ton	857/ton	69,000
Hydrochloric Acid	16 ton	100/ton	2,000
Light Diesel Oil	73,600 kl	21/kl	1,546,000
ED Membranes	640 Pairs	190/Pair	121,000
Other Consumables	-	-	180,000
Total Direct Operating Cost			6,064,000

Unit Treatment Cost

Brine Reject Base 1.5 US\$/m³ of brine
Recovered Water Base 1.6 US\$/m³ of water

9. Estimate of Operating Personnel

A total of 54 operating personnel are required for the normal operation of the Integrated Plant excluding drivers and laborers for transporting the solid waste.

1)	Manager	1 x 1 shift	1
2)	Engineers		
	Mechanical	2 x 1 shift	2
	Electrical	2 x 1 shift	2
	Chemical	1 x 1 shift	1
3)	Operators		
	Chief Operators	2 x 4 shifts	8
	Operators	7 x 4 shifts	28
4)	Laborers		
	Skilled Laborers	2 x 1 shift	2
	Common Laborers	7 x 1 shift	7
5)	Other		
	Clerical Staff	1 x 1 shift	1
	House Boy	2 x 1 shift	2

Total	54
-------	----

10. Estimate of Capital Investment Cost

The estimate is based on the Basic Study Data in Section 5, Scope of Study in Section 6 and current market prices. The estimate is intended for use in defining the size of the project, but not for budgetary purposes.

Cost escalator scale is not considered in the estimate.

(1) Direct Costs

1) Supply of Materials and Equipment

- (A) Pretreatment Section
- (B) ED Section
- (C) Evaporator/Crystallizer Section
- (D) Auxiliary and Common Facilities

Sub-total	28,840,000	US\$
-----------	------------	------

2) Field Construction Work

- (A) Installation, piping, painting
and insulation work
- (B) Electric and instrumentation work
- (C) Civil engineering and building work
including bulk materials

Sub-total	14,990,000	US\$
-----------	------------	------

Direct Costs Total	43,830,000	US\$
--------------------	------------	------

(2) Indirect Work

1) Engineering fee

2) Other expenses including:

Temporary facilities, construction
equipment, transportation and insurance,
field office expenses, precommissioning
expenses and home office expenses

Sub-total	14,820,000	US\$
Grand Total	58,650,000	US\$

11. Estimate of Project Schedule

Over-all project schedules for the Integrated Plant is studied for two cases of contracting method as follows:

(1) Separate Contracting Method

The engineering contractor and the construction contractor are selected in separate bids.

(2) Single Contracting Method


An engineering and construction contractor is selected in a single bid.


The single contracting method will resulting shorter time schedule than the separate contracting method will.

Over-all project schedule sheets for the both methods are attached.

The single contracting method will resulting shorter time schedule than the separate contracting method will.

Over-all project schedule sheets for the both methods are attached.





Over-all Project Schedule
in the Case of Single Contracting Method

12. Remarks

1) Capital Investment Cost

The Integrated Plant studied in this report will offer less investment cost and more ease of operation and maintenance than the three separate plants discussed in the Interim Report.

However, construction costs and difficulties in construction of the Brine Reject pipelines from the three existing water treatment plants to the Integrated Plant should also be considered in the final decision.

2) Temperature of the Brine Reject

In this study, it is assumed that the Brine Reject pipelines will be laid underground and that the brine temperature will not increase during transportation.

If there is a possibility that the brine temperature will exceed 40°C, a cooling tower should be provided before the ED section.

3) Chemical Consumption

The chemical consumption for the cold lime-soda softeners is calculated on the basis of the results of the preliminary tests conducted during the site survey. For establishing optimum chemicals feed conditions, further tests will be required.

4) Transportation of Solid Waste

Transportation of the solid waste is considered by trucks in this report on the assumption that a permanent solid waste dump site will be located at a distance from the Integrated Plant site.

If the permanent solid waste dump site could be located beside the Integrated Plant site, a conveyer system should be studied.



5) Diesel Engine Power Generators

If public electric power is easily available at the Integrated Plant site, the diesel engine power generators could be replaced with the public electric power source.

6) There is no boiler feed water at the initial start-up of the Integrated Plant, although steam condensate is supplied from the evaporators as boiler feed water during normal operation.

Approximate 120 m^3 of high purity water must be transferred from other boiler plants near the Integrated Plant site as the initial charge for the boiler plant.

M-01
LIME FEED SYSTEM
(CHEMICAL SILO)



01
FEED SYSTEM
AL SILO)

M-02AB
SODA ASH FEED SYSTEM
(CHEMICAL SILO)

M-03A
COLD LIME-SODA SOFTENER

M-03B
COLD LIME-SODA SOFTENER

V-01A
SAND FILTER

V-01B
SAND FILTER

V-01C
SAND FILTER

V-01D
SAND FILTER

PU-05AB
SLUDGE PUMP

PU-05C/D
SLUDGE PUMP

M-04AB
FILTER PRESS

PT-05
SLUDGE YARD

PU-04AB
SLUDGE PUMP

PT-04
BACKWASH
WASTE PIT

PU-03
BACK
WASHING
PUMP

PT-03
FILTERED
WATER PIT

PU-2AB
E/D FEED PUMP

B-02
BLOWER

PU-15
NaOH FEED
PUMP

TA-05
NaOH TANK

PU-16 A.B
WASTE WATER PUMP

PU-
RECOVERED
PU

MX-03
MIXER


MX-02
NaOH MIXER


PU-14
NaOH PUMP


TA-04
NaOH MIXING TANK

PT-09
CONCENTRATE PIT



01AB
WATER FEED
PUMP







PART NO.	PART NAME	MAT'L	WOPX	SPARE	REMARK
			QUANT/SET		
FOR: THE MINISTRY OF AGRICULTURE AND WATER THE GOVERNMENT OF THE KINGDOM OF SAUDI ARABIA					
PROJECT: RO BRINE REJECT TREATMENT					
TITLE: PROCESS FLOW SHEME					
DATE: JANUARY 15, 1981			SCALE: NONE		
DRAWING NO.: SAJ/RO-101					
JAPAN INTERNATIONAL COOPERATION AGENCY					





FLOOR PLAN



FLOOR AREA: 350 m²

INTERIOR FINISH SCHEDULE							EXTERIOR FINISH SCHEDULE		
ROOM NAME	FLOOR	BASE H=100	WAINSCOT	WALL	CEILING	REMARKS	SURFACE	MATERIAL AND FINISH	REMARKS
LOBBY AND CORRIDOR	VINYL ASBESTOS TILE	VINYL ASBESTOS TILE BASE		CEMENT PLASTER W/VINYL PAINT	ACOUSTICAL FIBER BOARD H=2,400		STRUCTURAL FRAME	REINFORCED CONCRETE	
ENGINEER STAFF ROOM	"	"		"	ACOUSTICAL FIBER BOARD H=2,800	A/C	FOUNDATION	"	
MANAGER ROOM	"	"		"	"	"	ROOF	REINFORCED CONCRETE W/VINYL WATER PROOFING SLOPE: 1/100	
MEETING ROOM	"	"		"	"	"	COLUMN AND GIRDER	REINFORCED CONCRETE EXPOSED W/VINYL PAINT	
STAFF ROOM	"	"		"	"	"	WALL	CONCRETE BLOCK W/CEMENT MORTAR STUCCO SPRAY FINISH	
CONTROL ROOM	"	"		"	"	"	BASE	REINFORCED CONCRETE EXPOSED W/VINYL PAINT H=300	
OPERATOR AND RESTING ROOM	"	"		"	"	"	STOOP	REINFORCED CONCRETE STEEL TROWEL FINISH	
WORKING AND RESTING ROOM	"	"		"	"	"	DOOR AND FRAME	STEEL W/OIL PAINT	
UTILITY ROOM	PORCELAIN UNGLAZED MOSAIC TILE			SEMI-PORCELAIN GLAZED TILE	ASBESTOS CEMENT BOARD W/VINYL PAINT H=2,600		WINDOW AND FRAME	ALUMINUM	
MEN'S WOMEN'S TOILET AND SHOWER & JANITORS CLOSET	"			"	"		DOWNSPOUT	POLY VINYL CHLORIDE 100 ⁸ W/METAL ROOF ORAIN OIL PAINT FINISH	
MECHANICAL ROOM (A/C MACHINE RM)	CONCRETE STEEL TROWEL			CEMENT PLASTER W/VINYL PAINT	EXPOSED CEILING W/VINYL PAINT		LEGEND ■■■■■ : REINFORCED CONCRETE ■■■■■ : CONCRETE BLOCK, EXT 200 & INT 150, 100		

PART NO.	PART NAME	MAT'L	WORK QUANTY/SET	SPARE	REMARK
FOR: THE MINISTRY OF AGRICULTURE AND WATER THE GOVERNMENT OF THE KINGDOM OF SAUDI ARABIA					
PROJECT: RO BRINE REJECT TREATMENT					
TITLE: CONTROL BUILDING PLAN & FINISH SCHEDULE					
DATE: JANUARY 15, 1981			SCALE: NONE		
DRAWING NO.: SAJ/RO-102					
JAPAN INTERNATIONAL COOPERATION AGENCY					



PART NO.	PART NAME	MAT'L	WORK	SPARE	REMARK
			QUANT/SET		
FOR: THE MINISTRY OF AGRICULTURE AND WATER THE GOVERNMENT OF THE KINGDOM OF SAUDI ARABIA					
PROJECT: RO BRINE REJECT TREATMENT					
TITLE: CONTROL BUILDING ELEVATIONS & SECTION					
DATE: JANUARY 15, 1981			SCALE: NONE		
DRAWING NO.: SAJ/RO-103					
JAPAN INTERNATIONAL COOPERATION AGENCY					



FLOOR PLAN

FLOOR AREA: 478.5 m²

INTERIOR FINISH SCHEDULE

ROOM NAME	FLOOR	BASE H=100	WAINSCOT	WALL	CEILING	REMARKS
ELECTRODIALYSIS ROOM	CONCRETE SHEEL TROWEL		CEMENT MORTAR STEEL TROWEL H=1,000	CORRUGATED ASB. CEMENT SHEET EXPOSED	EXPOSED ROOF	A/C
MAINTENANCE ROOM	"		"	"	"	"
A/C MACHINE ROOM	"		"	"	STEEL DECK PLATE EXPOSED W/O.P.	
PIPING PIT	CEMENT MORTAR STEEL TROWEL FL=2,000			CEMENT MORTAR STEEL TROWEL	GRATING EXPOSED	


LEGEND

CONCRETE BLOCK 150^{THK} & 100^{THK}
 REINFORCED CONCRETE

EXTERIOR FINISH SCHEDULE

SURFACE	MATERIAL AND FINISH	REMARKS
STRUCTURAL FRAME	STEEL W/OIL PAINT	
FOUNDATION	REINFORCED CONCRETE	
ROOF	CORRUGATED ASBESTOS CEMENT SHEET SLOPE: 3/10	
WALL	CORRUGATED ASBESTOS CEMENT SHEET W/TRANSLUCENT F.R.P. SHEET	
WAINSCOT	CONCRETE BLOCK W/CEMENT MORTAR STUCCO SPRAY FINISH	
BASE	REINFORCED CONCRETE EXPOSED W/VINYL PAINT H=200	
STOOP	REINFORCED CONCRETE STEEL TROWEL FINISH	
DOOR AND FRAME	STEEL W/OIL PAINT	
WINDOW AND FRAME	ALUMINUM	
DOWNSPOUT	POLY VINYL CHLORIDE 100 ^Ø W/GUTTER	


PART NO.	PART NAME	MAT'L	WORK	SPARE	REMARK
			QUANT/SET		
FOR: THE MINISTRY OF AGRICULTURE AND WATER THE GOVERNMENT OF THE KINGDOM OF SAUDI ARABIA					
PROJECT: RO BRINE REJECT TREATMENT					
ELECTRODIALYSIS BUILDING					
TITLE: PLAN & FINISH SCHEDULE					
DATE: JANUARY 15, 1981			SCALE: NONE		
DRAWING NO.: SAJ/RO-104					
JAPAN INTERNATIONAL COOPERATION AGENCY					



PLOT PLAN FOR R.O. BRINE REJECT TREATMENT PLANT

PART NO.	PART NAME	MAT'L	WORK / SPARE	QUANT/SET	REMARK
FOR: THE MINISTRY OF AGRICULTURE AND WATER THE GOVERNMENT OF THE KINGDOM OF SAUDI ARABIA					
PROJECT: RO BRINE REJECT TREATMENT					
TITLE: PLOT PLAN					
DATE: JANUARY 15, 1981			SCALE: NONE		
DRAWING NO.: SAJ/RO-106					
JAPAN INTERNATIONAL COOPERATION AGENCY					

SINGLE LINE DIAGRAM (R.O. BRINE REJECT TREATMENT)




PART NO.	PART NAME	MAT'L	WORK QUANT/SET	SPARE	REMARK
FOR: THE MINISTRY OF AGRICULTURE AND WATER THE GOVERNMENT OF THE KINGDOM OF SAUDI ARABIA					
PROJECT: RO BRINE REJECT TREATMENT					
TITLE: SINGLE LINE DIAGRAM					
DATE: JANUARY 15, 1981			SCALE:		
DRAWING NO.: SAJ/RO-107					
JAPAN INTERNATIONAL COOPERATION AGENCY					

13. Attachment

Through the study, three minutes of meetings between MOAW and study team have been made by both parties. The minutes are attached concerning matters which offer important information to this study report.

It is supposed useful to record those data in this report for the future development of this project.

Those matters show questionnaires, perspective of the study, the attendants of the meetings and actual schedule of the site survey, etc.



13.1 (1) Annex to the Minutes dated September 28, 1980.

At the site survey, following matters are proposed and agreed by the both parties:

1. List of Attendants
2. Schedule
3. Scope of Feasibility Study
4. Step of Works
5. Method of RO Brine Reject Treatment
6. Tentative Report (see next chapter)
7. Questionnaires

Annex 1: List of Attendants

1. JAPANESE DELEGATION

Masaru Ikai	Delegation Leader, Water Re-Use Promotion Center
Masahiro Miyazaki	Industrial Water Division Ministry of International Trade and Industry
Keiichi Kato	Japan International Cooperation Agency (JICA)
Koh Tsuda	Water Re-Use Promotion Center
Shigeru Itoi	Water Re-Use Promotion Center
Yo Takahashi	Water Re-Use Promotion Center
Junzo Hori	Water Re-Use Promotion Center
Gennosuke Inoue	Water Re-Use Promotion Center
Hisao Ogasawara	Water Re-Use Promotion Center

2. Japanese Observers

Naotoshi Osada	Deputy Japanese Representative for the Secretariat to the Saudi-Japanese Joint Committee
Takashi Komori	Resident Representative Riyadh Office JICA

3. MOAW

H.E. Abdulla Al Gholaikha	Deputy Minister for Water Affairs MOAW
Mohamed Aquil Khan	Deputy Director General Projects Execution Department MOAW
Amer Hossein	Assistant Director General Water Resources Development Department MOAW
Omar Al-Sheikh	Civil Engineer Projects Execution Department MOAW

Annex 2: Schedule

Date	Schedule	Person to Meet
Sept 26, Fri	Leave Japan	
" 27, Sat	Arrive in Riyadh	
" 28, Sun	Visit to Min. of Agr. & Water Explanation of scope of work, step of works, site survey and tentative report	H.E. Al Gholaikha
" 29, Mon	Visit to Water & Sewage Authority (WSA) Same explanation as above	
" 30, Tue	Visit to Manfouha Sewage Treatment Plant Visit to Manfouha Water Treatment Plant	Mr. M. El-Baker
Oct 1, Wed	Visit to Water Division, WSA Visit to Malez Water Treatment Plant	
" 2, Thu		
" 3, Fri		
" 4, Sat	Visit to Haiyr Pretreatment Plant	
" 5, Sun	Visit to Salbukh Water Treatment Plant	
" 6, Mon	Visit to Sewage Division, WSA Visit to Shemessy Water Treatment Plant	
" 7, Tue	Pigeonholing of obtained data & preparation of interim report	
" 8, Wed	Explanation of interim report	H.E. Al Gholaikha
" 9, Thu		
" 10, Fri		
" 11, Sat	(Reserved for the above explanation)	
" 12, Sun	Leave Riyadh	
" 13, Mon	Return to Japan	

Annex 3: Scope of Feasibility Study

1. Assessment and investigation of RO brine reject disposal
 - (1) Disposal into the municipal sewage pipeline
 - (2) Disposal into the sewage treatment plant
 - (3) Water re-use program
 - (4) Proposition and evaluation of effective concentration method of RO brine reject
2. Selection of disposal method
3. Planning
 - (1) Conceptual design of selected method
 - (2) Cost estimation
 - (3) Economical analysis
4. Conclusion
 - (1) Conclusion
 - (2) Proposal and comment
5. Explanation of the result to the Ministry of Agriculture and Water, the Government of the Kingdom of Saudi Arabia

Annex 4: Step of Works

1. On the spot survey in Riyadh
 - (1) Meetings
 - (2) Visits to plants
 - (3) Interim reporting
 - (4) Confirmation of figures (data)
2. Works in Japan
 - (1) Analysis
 - (2) Planning
 - (3) Evaluation
 - (4) Drafting of final report
3. Explanation of draft of final report to the Ministry of Agriculture and Water, the Government of the Kingdom of Saudi Arabia

Annex 5: Method of RO Brine Reject Treatment

1. Evaporation pond in the suburbs
2. Deep well injection
3. Concentration by electrodialysis (ED) process
 - 3.1 ED process followed by evaporation pond in the suburbs
 - 3.2 ED process followed by evaporation pond in the RO plant site
 - 3.3 ED process followed by Evaporator/Crystallizer
 - 3.4 ED process followed by deep well injection
4. Concentration by reverse osmosis (RO) process
5. Disposal into municipal sewage pipeline
6. Recovery of valuables

Annex 6: Tentative Report

TENTATIVE REPORT ON
FEASIBILITY STUDY OF
RO BRINE REJECT TREATMENT IN
THE KINGDOM OF SAUDI ARABIA

(DOCUMENT NO. SAJ/RO-101)

SEPTEMBER 1980

JAPAN INTERNATIONAL COOPERATION AGENCY
TOKYO, JAPAN

Annex 7: Questionnaires

Questionnaire (1) -- Water Treatment Plant in Riyadh

1. Capacity and expansion program

Name of Plant	Design Capacity (m ³ /day)	Operational Record (m ³ /day)			Expansion Program (m ³ /day by year)
		Maximum	Minimum	Average	
Malez					
Manfouha					
Shemessy					
Haiyr					

2. Quality of treated water

Items	Plant	Malez	Manfouha	Shemessy
Total dissolved solids (TDS), mg/l		1,100	900	800
Chloride, Cl ⁻ , mg/l		270	180	170
Sulphate, SO ₄ ²⁻ , mg/l		450	370	300
Calcium, Ca ²⁺ , mg/l		40	40	40
meqv./l		2	2	2
Magnesium, Mg ²⁺ , mg/l		36	36	36
meqv./l		3	3	3
Total hardness, meqv./l		5	5	5

Source: Proceedings of Nice Int'l Congress in 1979

3. Layout drawings, both present & expansion program

Questionnaire (2) -- Sewage Treatment Plant

1. Manfouha Sewage Treatment Plant

Design capacity: _____ m³/dayOperational record: Maximum _____ m³/dayMinimum _____ m³/dayAverage _____ m³/dayExpansion program: _____ m³ by _____
(Year)_____ m³ by _____

2. Planned plant

Location: _____

Design capacity: _____ m³/day

Year of completion: _____

3. Quality of influent, both design & operational record

a) Temperature: _____ / _____ l) Pb: _____ / _____

b) pH: _____ / _____ m) Cr
(6 valence): _____ / _____

c) BOD: _____ / _____ n) As: _____ / _____

d) SS: _____ / _____ o) Total Hg: _____ / _____

e) n-Hesan
Extract
Substances: _____ / _____ p) Cr: _____ / _____

q) Cu: _____ / _____

f) Iodine
consumed: _____ / _____ r) Zn: _____ / _____g) Phenols: _____ / _____ s) Fe
(soluble): _____ / _____h) Cyanide: _____ / _____ t) Mn
(soluble): _____ / _____

i) Alkyl Hg: _____ / _____ u) F: _____ / _____

j) Organic P: _____ / _____

k) Cd: _____ / _____

4. Layout drawings, both present & expansion program

Questionnaire (3) -- Sewage Re-Use Program

1. Capacity and expansion program

Name of Plant	Design Capacity (m ³ /day)	Operational Record (m ³ /day)			Expansion Program (m ³ /day by year)
		Maximum	Minimum	Average	

2. Quality of reclaimed water, both design & operation record

a) Temperature:	_____ / _____	l) Pb:	_____ / _____
b) pH:	_____ / _____	m) Cr (6 valence):	_____ / _____
c) BOD:	_____ / _____	n) As:	_____ / _____
d) SS:	_____ / _____	o) Total Hg:	_____ / _____
e) n-Hexan Extract Substance:	_____ / _____	p) Cr:	_____ / _____
f) Iodine consumed:	_____ / _____	q) Cu:	_____ / _____
g) Phenols:	_____ / _____	r) Zn:	_____ / _____
h) Cyanide:	_____ / _____	s) Fe (soluble):	_____ / _____
i) Alkyl Hg:	_____ / _____	t) Mn (soluble):	_____ / _____
j) Organic P:	_____ / _____	u) F:	_____ / _____
k) Cd:	_____ / _____		

3. Layout drawings, both present & expansion program

Questionnaire (4) -- Governmental Office in Charge of
Water Administration

1. Basic Plan of Water Resources Development:

2. Potable Water:

3. Industrial Water:

4. Agricultural Water:

5. Sewage:

6. Organization Chart of the above

7. Law and Regulation related to Water Administration:

8. Budgetary System:

#

Questionnaire


1. Bearing capacity in the Riyadh area
2. Boring log of deep well more than 1,000 m in the Riyadh area
3. Permeability coefficient of aquifer
4. Atmospheric pressure in the Riyadh area
5. Wind velocity and direction in the Riyadh area
6. Evaporation rate in the Riyadh area
7. Topographical map of the Riyadh area
8. Available utilities and their unit prices
 - 1) Electric power
 - 2) Fuel
 - 3) Steam: Pressure ($\text{kg/cm}^2\text{G}$), Temperature ($^{\circ}\text{C}$), Quantity (kg/h)
 - 4) Water (for cooling):
Quantity (m^3/h), Temperature ($^{\circ}\text{C}$), Quality
 - 5) Chemicals
 - (1) Hydrazin
 - (2) Coagulation aid
 - (3) Biocide
 - (4) Na_2CO_3
 - (5) NaOH
 - (6) NaCl
 - (7) H_2SO_4
 - (8) Na_2SO_4
9. Labor
 - 1) Cost per hour
 - 2) Cost per year
 - 3) Working day per year
10. Depreciation

Formula used by MAW and WSA

13.1 (2) Annex to the Minutes dated October 8, 1980.

After the site survey following matters are confirmed:

1. Actual Schedule of the Japanese Delegation
2. List of Attendants
3. References obtained by the Japanese Delegation
4. General Conditions
5. Summary of Interim Report



Annex 1: Actual Schedule of the JAPANESE DELEGATION

Date	Actual Schedule
Fri., Sept. 26	Leave Japan
Sat., " 27	Arrive in Riyadh
Sun., " 28	Visit to Ministry of Agriculture and Water (MOAW) to explain scope of work, step of works, site survey and tentative report
Mon., " 29	Visit to Water and Sewage Authority (WSA) to explain the same items as above
Tue., " 30	Visit to Manfouha Sewage Treatment Plant Visit to Manfouha Water Treatment Plant
Wed., Oct. 1	Visit to Water Division, WSA Visit to Malez Water Treatment Plant
Thu., " 2	
Fri., " 3	
Sat., " 4	Visit to Haiyr Pretreatment Plant Visit to Shemessy Water Treatment Plant Visit to Water Division, WSA, to receive data
Sun., " 5	Visit to Salbukh Water Treatment Plant
Mon., " 6	Visit to MOAW to receive data and to discuss general conditions Visit to Sewage Division, WSA, to receive data
Tue., " 7	Visit to MOAW to receive additional data Preparation of interim report

Annex 2: List of Attendants

1. JAPANESE DELEGATION

Masaru Ikai	Delegation Leader, Water Re-Use Promotion Center
Masahiro Miyazaki	Industrial Water Division Ministry of International Trade and Industry
Koh Tsuda	Water Re-Use Promotion Center
Gennosuke Inoue	Water Re-Use Promotion Center

2. Japanese Observers

Naotoshi Osada	Deputy Japanese Representative for the Secretariat to the Saudi-Japanese Joint Committee
Takashi Komori	Resident Representative Riyadh Office Japan International Cooperation Agency

3. MOAW

H.E. Abdulla Al Gholaikha	Deputy Minister for Water Affairs MOAW
Mohamed Aquil Khan	Deputy Director General Projects Execution Department MOAW
Amer Hossein	Assistant Director General Water Resources Development Department MOAW
Omar Al-Sheikh	Civil Engineer Projects Execution Department MOAW

Annex 3: References obtained by the JAPANESE DELEGATION

1. Water treatment facilities

1.1 Water treatment plants

(1) Quality of treated water

Month: August 1979

Plants: Malez, Shemessy and Manfouha

Items: pH, total hardness, total alkalinity

Range: Minimum, average and maximum

(2) Results of water analysis (average)

Month: August 1979

Plants: Malez, Shemessy and Manfouha

Items: Temperature

pH

Hardness (TTL Ca, Mg)

Alkalinity (TTL Phenolphthalein)

Chloride

Conductivity

KMnO₆ demand

Manganese

Aluminium

Free Chlorine

Dissolved oxygen

Checking point: Parsh Flume

Before filters*

After pumps

Note: * Items from Chloride to dissolved oxygen are not indicated.

- (3) Capacity and expansion program (design capacity) in m³/h
- Malez: 1,200
- Manfouha: No.1 -- 1,800 (plus 600 from Hayir)
- No.2 -- 2,400
- Shemessy: 3,600
- Haiyr: 900
- (4) Available utilities and their unit prices
- Electric power: SR 0.07/KHW
- Fuel (diesel oil): SR 0.055/liter
- (5) Prices of chemicals
- Coagulant aid (polyelectrolite): SR 21,000/ton
- Na₂CO₃: SR 1,030/ton
- H₂SO₄: SR 1,050/ton
- (6) Operator
- Cost per year: SR 100,000 (approximate)
- Working days per year: 365
- (7) Depreciation
- Depreciation or amortization is not applied
- (8) Drawings
- 1) General layout of Malez Plant
 - 2) General layout of Shemessy Plant
 - 3) General layout of Manfouha Plant

1.2 Salbukh RO Plant (verbal information)

(1) Capacity (m^3/d)

Design: 60,000

Maximum: 65,000

Minimum 55,000

Average: 60,000

(2) Quality of permeate water

Items	Raw	Softened	Permeate	Brine Reject
TTL dissolved solids mg/l	1,300	1,300	75	10,000 - 12,000
Chloride, Cl^- mg/l	300	200 - 300	14-15	3,000
Sulphate, SO_4^{2-} mg/l	375	475	20	500
Calcium Ca^{2+} mg/l	450	70	40	600
meqv/l	2.5			
Magnesium, Mg^{2+} mg/l	225	140	14	900
meqv/l				
Silica mg/l	22- 28	8	trace	80
TTL hardness mg/l	14			
meqv/l		6.8	(6.6) *	5.5

*: read from meter

(3) TTL operating volume (m^3/h)

After cooling: 2,824

RO feed: 2,112

RO permeate 1,950

Brine reject: 195

2. Sewage Treatment

2.1 Manfouha Sewage Treatment Plant

- (1) Capacity (m^3/d)
Design: 40,000
Maximum: 57,000
Minimum: 42,000
Average: 45,000
- (2) Check items of effluent quality
BOD and SS
- (3) Reduction ratio of BOD
80% (designed and operational record)
- (4) Expansion program
80,000 m^3/d in 1981
200,000 m^3/d in 1983
- (5) Quantity of influent
 - 1) Monthly maximum, minimum and average
 - 2) Daily maximum, minimum and average
 - 3) Hourly change
- (6) Quality of effluent
 - 1) Effluent standard
None
 - 2) TDS variation of effluent
2,000 to 3,000 mg/l

2.2 Sewage pipeline

- (1) Drawings
- (2) Profiles
 - 1) Trunk line
 - 2) Branch line connecting water treatment plant
and trunk line

Annex 4: General Conditions

1. Sewage

- (1) TTL volume: 80,000 m³/d in 1981
200,000 m³/d in 1983

(2) Quality of influent and effluent

<u>Items</u>	<u>Influent</u>	<u>Effluent</u>
TDS	910 - 3,130	1,800 - 2,340
BOD	207 - 269	77 - 95
SS	333 - 460	82 - 117
pH	7.2 - 7.8	7.2 - 8.0

2. Re-Use

- (1) Standard of effluent from sewage treatment plant:

None

(2) Object for re-use

- 1) Agriculture
- 2) Ground water increase by injection
- 3) Industry

3. Design basis of RO brine reject treatment method

- (1) Quantity of RO brine reject (m³/d)

- 1) Malez: 2,230
- 2) Manfouha: 6,800
- 3) Shemessy: 3,310

- (2) Recovery ratio: 90%

- (3) Salt rejection: 97%

4. Weather conditions

Items	Data in Tentative Report	Present Data
Temperature		
Minimum	-4°C	-5.6°C
Maximum	52°C	47.7°C
Relative Humidity		
Winter	100-16%	100-6%
Summer	51-5%	68-2%
Highest Total Daily Rainfall		
Maximum	57 mm/d	51.5 mm/d
Annual Reainfall		
Minimum	15 mm	12.6 mm
Maximum	230 mm	176.6 mm
Wind Velocity		
Maximum	128 km/h	32 km/h
Wettest Month	March - April	November - February
Driest Month	June - October	June - September
Evaporation rate	3,000 mm/y	2,890 mm/y

Annex 5: Summary of Interim Report

1. Disposal method of RO brine reject

(1) Manfouha

- 1) Concentration by electrodialysis (ED) followed by evaporator/crystallizer

* Construction cost: 17 million US\$

* Required area: 2,450 m²

- 2) Concentration by ED followed by evaporation pond

* Construction cost: 10 million US\$

* Required area: 188,000 m²

(2) Shemessy

- 1) Concentration by ED followed by evaporator/crystallizer

* Construction cost: 11 million US\$

* Required area: 1,200 m²

- 2) Evaporation pond in the suburbs

* Construction cost: 8 million US\$

* Required area: 150 m² (in plant site)
420,000 m² (present lagoon)

(3) Malez

Disposal into sewage pipeline

2. Schedule

Method \ Year	1980	1981	1982	1983	1984	1985
ED plant in Manfouha		(P) —○—	(C) —○—	(O) —○—		
ED plant in Shemessy		(P) —○—	(C) —○—	(O) —○—		
Brine disposal from Malez		○—				
(Reference) Expansion of Sewage treatment plant		—○—	80,000 m ³ /d	—○—	200,000 m ³ /d	

(P)=Preparation; (C)=Construction; (O)=Operation

0


0

0

1

13.1 (3) Annex to the Minutes dated February 7, 1981.

1. Attendants to the Meetings



ANNEX I

Attendants to the Meetings

MOAW Side:

H.E. Dr. Abdullah Al-Ghulaikah	Deputy Minister for Water Affairs MOAW (partly attended)
Mr. Mustafa Noori	Director General, Water Resources Development Dept.
Mr. Amer Husein	Assistant Director General, Water R. D. Dept.
Mr. M. Aquil Khan	Assistant Director General, Projects Execution Dept.
Mr. Mosa Robaian	Assistant Director General, Water Resources D. Dept.
Mr. Musfir Al Kalthan	W.R.D. Dept.
Mr. Ibrahim Saqabi	" "
Mr. Fahad Marshond	" "
Mr. Omar Al-Sheikh	Project Execution Dept.
Mr. Abdullah Sadhan	W.R.D. Dept.

JICA Side:

Mr. Masaru Ikai	Team Leader JICA Study Team
Mr. Hiroyuki Maki	Deputy Director Industrial Water Division Ministry of International Trade and Industry
Mr. Akira Nishimura	JICA Study Team

(With attendance of -)

Mr. Susumu Akiyama	Representative for the Secretariat to the Saudi-Japanese Joint Committee
Mr. Michio Hirano	1st Secretary, Embassy of Japan/Jeddah
Mr. Naotoshi Osada	Deputy Representative for the secre- tariat to the Saudi-Japanese Joint Committee
Mr. Takeshi Komori	Resident Representative Japan International Cooperation Agency

1

2

3

4

