

CHAPTER 8

RESERVOIR OPERATION STUDY FOR THE AGOS RIVER SYSTEM

8.1 Generated Discharge Series

Case No.	River	Place	Remarks
8-1	Agos	Banugao G.S.	Recorded
8-2	Agos	Agos Dam	Natural
8-3	Kanan	Kanan No.1 Dam	
8-4	Kanan	Kanan No.5 Dam	
8-5	Kaliwa	Kaliwa Dam	
8-6	Agos	Agos Afterbay Weir	
8-7	Agos	between the confluence and afterbay weir	
8-8	Kanan	between Kanan No.1 Dam and the confluence	
8-9	Kaliwa	between Kaliwa Dam and the confluence	

8.2 Alternative Development Plan A-1

Case No.	Dam	H.W.L. (m AMSL)	Pr (MW)
8-10	Agos	175	200
8-11	-do-	165	185
8-12	-do-	155	170
8-13	-do-	145	155

Note: Results of the operation study for Kaliwa dam are same with that of plan A-2 (Refer to Case No.8-14).

8.3 Alternative Development Plan A-2

Case No.	Dam	H.W.L. (m AMSL)	Pr (MW)
8-14	Kaliwa	270	- /1
8-14	Kanan No.2	295	- /1
8-15	Agos	175	152
8-16	-do-	165	140
8-17	-do-	155	128
8-18	-do-	145	116

Note: /1; Power generation at Pantay P/S is calculated separately because its data was not available in the course of the study.

8.4 Alternative Development Plan A-3

8.4.1 Kanan No.1 Dam

Case No.	H.W.L. (m AMSL)	T.W.L. (m AMSL)	Pr (MW)
8-19	300	175	138
8-20	300	165	149
8-21	300	155	158
8-22	300	145	168
8-23	290	175	127
8-24	290	165	138
8-25	290	155	147
8-26	290	145	157
8-27	280	175	115
8-28	280	165	127
8-29	280	155	135
8-30	280	145	144

8.4.2 Kaliwa Dam

Same with plan A-2 except the independent operation of Kaliwa pumped storage plant. Refer to Section 7.2 of Appendix A: Hydrology and Reservoir Operation.

8.4.3 Agos Dam

Case No.	H.W.L. (m AMSL)	Pr (MW)	H.W.L. of Kanan No.1 Dam (m AMSL)
8-31	175	152	300
8-32	175	152	290
8-33	175	152	280
8-34	165	140	300
8-35	165	140	290
8-36	165	140	280
8-37	155	128	300
8-38	155	128	290
8-39	155	128	280
8-40	145	116	300
8-41	145	116	290
8-42	145	116	280

8.4.4 Kaliwa Pumped Storage Plant

Case No.	Pr (MW)	Dia. of H.R. Tunnel (m)	H.W.L. of Agos Dam
8-43	250	8.3	175
8-44	250	8.3	165
8-45	250	8.3	155
8-46	250	8.3	145
8-47	250	7.6	175
8-48	250	7.6	165
8-49	250	7.6	155
8-50	250	7.6	145
8-51	250	6.5	165
8-52	250	6.5	155
8-53	250	6.5	145
8-54	180	8.3	175
8-55	180	8.3	165
8-56	180	8.3	155
8-57	180	8.3	145
8-58	180	7.6	175
8-59	180	7.6	165
8-60	180	7.6	155
8-61	180	7.6	145
8-62	180	6.5	175
8-63	180	6.5	165
8-64	180	6.5	155
8-65	180	6.5	145
8-66	100	8.3	175
8-67	100	8.3	165
8-68	100	8.3	155
8-69	100	8.3	145
8-70	100	7.6	175
8-71	100	7.6	165
8-72	100	7.6	155
8-73	100	7.6	145
8-74	100	6.5	175
8-75	100	6.5	165
8-76	100	6.5	155
8-77	100	6.5	145

Note: H.W.L. of Kanan No.1 dam of 290 m AMSL is assumed.

8.5 Alternative Development Plan B

8.5.1 Kanan No.5 Dam

Case No.	H.W.L. (m AMSL)	T.W.L. (m AMSL)	Pr (MW)
8-78	260	25	280
8-79	260	25	200

8.5.2 Kaliwa Dam

Same with plan A-2.

8.6 Water Supply Benefit

Case No.	Plan	Reservoir	Remarks
8-80	A-2	Kaliwa	Common for every plan
8-81	A-2	Kanan No.2	- do -
8-82	A-3	Agos	Common for every scale of Agos and Kanan No.1 dams. Water requirement can be fulfilled.
8-83	A-2	Kaliwa	Simulated spilt water series.
8-84	A-2	Kaliwa	Simulated supplied water series.
8-85	A-2	Kanan No.2	- do -

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT
 NIPPON KOEI
 RECORDED MONTHLY DISCHARGE SERIES AT RANIGAD ON AGOS RIVER

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
1950	237.16	118.92	135.28	55.67	31.06	30.09	59.70	73.07	55.33	211.04	217.44	274.75	124.96
1951	198.22	118.41	44.74	34.72	24.72	42.29	54.04	162.27	47.49	81.44	401.81	386.36	141.58
1952	240.30	135.38	49.80	47.46	32.66	55.31	50.26	157.82	143.73	109.90	297.24	143.26	
1953	180.02	188.07	54.84	56.21	27.88	56.10	34.37	106.79	48.31	182.14	100.28	410.10	128.01
1954	160.50	106.40	183.45	55.18	32.42	26.51	32.66	45.13	51.11	62.60	123.77	414.52	107.00
1955	333.78	77.20	46.94	49.98	31.86	65.03	58.33	32.45	71.54	160.01	282.56	491.60	116.77
1956	163.45	118.30	151.42	173.07	76.06	75.83	97.91	99.65	154.16	260.76	275.66	550.70	183.08
1957	254.14	79.98	41.15	31.36	21.65	23.66	32.53	81.86	61.98	89.04	106.15	73.54	75.14
1958	145.97	78.63	73.31	86.02	78.19	74.29	91.39	66.20	90.36	203.70	180.50	68.95	103.96
1959	140.80	92.21	137.06	33.50	21.23	28.40	41.75	60.09	69.82	85.15	220.91	205.25	94.60
1960	154.06	183.22	55.40	46.78	69.95	88.11	77.20	238.56	150.40	247.50	189.78	192.26	140.27
1961	194.73	154.70	119.01	77.43	100.88	76.30	64.69	60.61	112.18	197.45	289.52	117.67	130.51
1962	167.20	135.01	77.71	76.82	34.82	34.82	92.44	72.98	203.40	116.71	200.80	183.91	112.71
1963	147.76	161.74	81.04	69.57	25.04	48.27	61.80	103.67	143.33	113.13	106.90	192.50	104.56
1964	151.03	151.59	126.17	80.05	45.43	65.87	96.23	113.68	115.67	120.05	316.35	297.78	140.24
1965	195.82	111.66	70.88	31.20	26.83	27.27	68.14	58.37	72.58	143.85	233.91	306.72	111.42
1966	100.49	73.65	50.97	20.82	24.82	21.24	32.22	32.24	82.62	122.24	284.13	281.62	102.40
1967	201.66	77.33	74.45	55.51	44.97	65.33	51.04	105.50	76.42	64.83	222.95	183.30	102.19
1968	149.48	149.49	149.11	98.38	32.86	29.37	48.79	90.55	93.67	127.85	131.68	78.94	98.35
1969	82.09	34.49	43.11	27.38	15.52	12.60	37.42	57.70	69.06	70.08	111.90	300.75	71.84
1970	140.59	56.51	24.58	41.50	16.47	24.36	37.47	26.97	116.77	209.79	391.53	228.58	110.26
1971	128.61	175.54	161.45	48.88	124.26	232.70	267.25	103.18	53.56	233.52	256.11	341.03	183.62
1972	137.71	66.55	77.72	66.97	64.93	66.17	314.99	193.14	130.04	109.34	192.60	231.45	137.63
1973	90.90	103.30	56.50	67.10	44.70	59.80	64.20	44.80	23.40	184.70	316.00	512.60	123.51
1977	206.90	191.70	118.20	54.10	45.60	33.10	101.00	85.80	123.80	98.70	262.40	128.10	120.95
1978	96.70	75.20	42.20	19.80	32.20	43.40	55.00	130.50	148.90	328.20	224.10	285.10	122.25
TOTAL	4410.67	3013.70	2225.01	1777.42	1115.82	1428.46	2026.61	2421.28	2523.13	4326.85	5849.64	6819.12	31637.55
MEAN	169.64	115.91	85.58	56.82	50.61	54.94	77.94	93.13	97.04	166.42	224.99	254.58	120.63

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT NIPPON KOEI
 ESTIMATED INFLOW SERIES INTO AGOS RESERVOIR FOR THE TARGET YEAR 1984

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
1	211.78	107.92	120.93	47.53	76.44	24.50	51.30	67.83	51.46	187.57	198.73	250.03	112.17
2	177.01	107.46	39.46	31.41	80.18	40.05	46.43	151.29	62.76	22.38	370.90	351.60	122.58
3	214.59	122.86	44.52	40.52	27.80	45.03	45.19	146.51	100.67	386.58	100.45	270.50	128.58
4	160.26	170.67	59.02	48.00	22.73	45.67	29.33	99.33	45.86	161.88	173.91	373.21	115.12
5	143.33	96.56	163.99	38.58	27.34	21.58	78.06	41.89	47.53	55.64	113.12	377.23	96.24
6	298.07	67.34	41.98	42.68	27.21	52.94	48.23	34.82	66.53	142.22	258.25	174.36	104.55
7	145.86	107.36	135.36	141.78	64.75	61.75	84.13	92.51	143.37	231.76	251.94	501.16	163.99
8	226.95	72.58	30.72	28.78	18.43	39.26	33.92	75.99	52.64	29.14	97.02	-66.92	67.62
9	130.35	71.36	65.53	73.45	66.56	60.48	78.53	61.45	84.03	181.05	174.11	62.75	92.67
10	125.73	83.68	122.52	28.60	18.07	21.49	35.87	55.78	64.91	76.57	201.90	182.79	85.16
11	317.58	168.27	49.52	39.94	59.54	71.73	66.33	221.46	130.52	219.98	173.45	174.96	125.95
12	175.14	140.39	106.39	66.11	85.70	62.12	55.59	56.26	104.33	175.49	264.61	106.90	116.59
13	149.31	120.71	69.47	65.45	29.67	28.35	85.44	74.25	189.16	100.18	189.01	169.19	105.85
14	131.95	146.78	72.64	59.40	21.32	39.30	53.00	96.24	133.30	100.55	97.70	175.18	93.94
15	137.55	137.57	112.79	68.35	38.67	53.63	82.69	105.33	107.57	108.70	289.13	270.99	125.93
16	173.08	103.16	63.56	26.64	28.67	22.20	58.55	54.19	67.50	127.85	204.65	279.13	100.25
17	89.92	68.65	26.88	17.84	63.02	25.69	29.15	34.57	72.77	173.79	259.69	232.90	92.67
18	180.08	70.18	66.55	47.40	38.28	53.19	43.86	97.94	73.86	57.62	205.77	166.81	91.65
19	133.49	135.66	133.29	84.00	27.92	23.91	41.92	84.06	87.11	113.63	120.35	71.84	88.10
20	73.51	51.50	58.54	23.38	13.21	10.26	32.15	53.56	64.22	62.29	102.27	273.70	64.85
21	130.91	51.28	21.97	35.44	14.02	19.83	32.20	25.94	110.45	186.46	357.85	206.02	99.45
22	114.83	159.20	154.32	41.74	165.96	125.15	229.64	95.78	49.81	202.55	234.08	312.17	162.53
23	122.98	60.39	69.48	57.18	55.27	53.87	270.66	179.29	120.94	97.18	176.03	210.63	122.82
24	81.17	95.56	50.51	40.22	38.05	48.69	55.25	41.59	51.52	164.16	288.81	375.48	110.92
25	186.55	173.97	105.66	46.19	38.82	26.95	86.78	79.65	115.13	87.72	239.83	116.58	108.65
26	80.35	65.98	37.72	16.91	27.41	35.33	38.67	121.14	118.48	289.92	204.82	256.64	110.29
TOTAL	3938.74	2734.94	1989.00	1261.52	1120.08	1162.98	1741.22	2242.70	2346.50	3845.66	5346.38	6023.68	33758.60
MEAN	151.49	105.19	76.50	48.52	43.08	44.73	66.97	86.45	90.25	147.91	205.63	231.68	108.20

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT NIPPON KOEI
 ESTIMATED INLEW SERIES INTO KAMAN NO.1 RESERVOIR

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
1950	123.19	81.95	78.25	30.36	16.44	13.75	6.82	6.26	8.76	79.78	86.28	106.42	52.19
1951	104.64	61.66	25.53	20.09	49.86	22.48	6.12	13.96	10.68	30.79	161.02	149.85	55.21
1952	126.85	77.35	28.81	25.88	17.29	25.28	5.74	13.52	17.13	16.34	63.61	115.13	55.08
1953	95.03	102.46	31.72	30.66	14.26	25.64	3.92	9.15	7.80	88.85	75.50	138.85	52.45
1954	84.72	60.80	106.11	24.84	17.00	12.12	3.73	3.87	8.09	23.66	49.11	160.56	46.20
1955	175.20	42.40	27.16	27.26	16.92	29.72	6.41	11.32	60.49	132.11	74.21	48.95	48.95
1956	86.28	67.59	87.59	94.39	40.26	34.67	11.18	8.54	24.40	98.57	109.38	213.31	73.01
1957	131.16	45.70	23.80	17.10	11.66	10.81	4.21	7.01	8.81	33.66	42.12	28.82	30.72
1958	71.05	44.93	42.40	46.91	41.59	33.95	10.44	5.67	14.30	77.00	75.59	26.71	41.36
1959	74.33	52.69	79.28	18.27	11.24	12.07	4.77	5.15	11.05	32.57	87.65	79.50	39.05
1960	81.33	104.69	32.04	25.31	17.03	40.27	8.82	20.44	22.22	93.56	75.30	74.42	51.31
1961	103.53	88.39	68.84	42.23	53.50	34.87	7.39	5.19	17.76	74.64	114.88	45.50	54.71
1962	88.26	76.00	44.95	41.80	18.45	15.91	11.36	6.85	32.19	62.61	82.05	72.01	44.37
1963	78.00	92.42	46.88	37.64	13.26	22.06	17.06	8.88	22.69	42.77	42.42	74.56	40.74
1964	81.31	86.62	72.98	43.66	24.05	30.11	10.99	9.76	18.31	45.38	125.52	115.34	55.33
1965	103.31	64.95	41.00	17.02	14.10	12.46	7.78	5.00	11.49	54.38	88.84	118.81	44.85
1966	53.15	43.23	17.39	11.59	39.19	14.42	3.87	3.19	13.24	73.92	112.74	101.26	40.58
1967	106.45	44.19	43.06	30.27	23.81	29.86	5.83	9.04	12.57	24.51	88.66	71.00	40.75
1968	78.91	85.42	86.25	53.65	17.52	13.52	2.57	7.26	14.83	68.33	52.25	30.58	41.20
1969	43.33	19.71	24.94	14.93	8.22	5.76	4.27	4.94	10.93	26.49	44.40	116.69	27.03
1970	77.38	32.29	14.22	22.63	8.72	11.13	4.28	2.31	18.80	79.31	155.35	88.54	42.91
1971	67.89	190.30	93.59	26.66	103.20	102.55	30.52	8.84	8.48	88.28	101.82	132.87	72.63
1972	76.69	58.03	44.96	36.52	54.57	30.24	35.97	16.55	20.58	41.33	76.42	89.65	44.78
1973	47.98	60.17	32.68	25.69	23.66	27.33	2.34	3.84	8.72	69.82	125.38	159.82	49.37
1977	110.27	109.53	68.37	29.80	24.14	15.13	11.53	7.35	19.59	37.31	104.92	49.82	48.87
1978	51.05	41.54	24.41	18.80	17.05	19.84	5.14	11.18	13.57	123.31	88.92	110.51	43.94
TOTAL	2328.30	1721.98	1287.00	805.74	696.54	652.86	231.40	202.48	399.36	1635.66	2321.02	2563.86	14851.20
MEAN	89.55	66.23	69.50	30.99	26.79	25.11	8.90	7.98	15.36	62.91	89.27	98.61	47.60

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.F. PROJECT NIPPON KOEI
 ESTIMATED INFLOW SERIES INTO KAMAN NO.5 RESERVOIR

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
1	150.07	95.79	98.80	38.53	20.76	17.56	8.61	7.91	11.06	100.73	108.93	134.37	65.89
2	132.11	85.42	32.24	25.33	62.95	28.19	12.63	13.49	13.49	38.82	203.30	188.95	69.71
3	160.16	97.67	32.68	21.83	21.83	31.92	7.25	17.08	21.63	207.50	55.06	145.37	69.54
4	113.98	132.68	40.03	38.71	18.63	32.37	4.96	13.55	9.85	86.93	95.33	200.56	68.22
5	105.97	76.76	133.88	31.11	21.47	15.30	6.71	6.88	10.21	29.88	62.01	202.72	58.33
6	222.47	53.53	34.30	34.42	21.36	37.53	8.02	4.05	14.30	26.37	141.56	93.70	61.81
7	108.94	85.35	110.59	19.17	50.84	43.77	14.12	10.78	30.81	124.66	138.10	269.32	92.19
8	169.38	57.70	30.95	21.59	14.47	13.65	5.70	8.86	32.39	82.50	53.18	35.92	35.79
9	91.29	56.73	53.34	59.23	52.26	42.87	13.18	7.16	18.06	97.23	95.44	33.72	52.22
10	93.84	66.52	100.10	23.07	14.19	15.23	6.02	6.50	13.95	41.42	110.57	100.38	49.30
11	102.68	132.18	60.66	32.21	46.75	50.84	11.13	25.81	28.06	118.13	95.08	94.03	64.78
12	130.72	111.61	86.92	53.52	67.29	44.03	9.33	6.56	22.42	94.24	145.04	57.45	69.08
13	111.44	95.96	56.75	52.78	23.29	20.09	14.34	8.65	40.65	53.80	103.60	90.92	56.02
14	98.48	116.68	59.19	47.90	16.74	27.85	8.91	11.22	28.64	54.00	53.55	94.14	51.44
15	102.06	100.36	92.14	55.12	30.36	38.01	13.87	12.30	21.12	57.30	158.68	145.63	69.86
16	129.06	82.01	51.77	21.48	17.80	15.74	9.82	6.32	14.50	68.66	112.17	150.00	56.62
17	61.11	54.58	21.96	14.38	49.48	38.21	4.82	5.03	16.71	21.33	142.38	127.85	51.24
18	134.41	55.79	54.37	38.22	30.06	37.70	7.36	11.41	15.87	30.94	111.69	89.64	51.46
19	99.63	127.85	108.90	62.74	21.94	14.95	2.03	8.80	18.72	61.02	65.82	38.61	52.01
20	54.71	24.88	51.48	18.85	10.57	7.47	5.40	6.24	13.80	33.45	56.06	147.08	34.13
21	97.70	40.77	17.95	28.58	11.01	14.06	5.40	2.92	23.74	100.13	196.15	111.79	54.18
22	89.72	126.64	117.91	33.66	130.51	138.32	38.52	11.16	10.70	111.46	128.31	167.74	91.71
23	91.78	48.01	56.76	46.11	43.40	38.18	45.41	20.90	23.99	52.19	96.49	113.19	56.53
24	60.59	75.97	41.26	32.43	29.88	34.51	9.27	6.85	11.02	88.16	158.31	201.72	62.34
25	130.23	138.30	86.32	37.25	30.48	19.10	14.56	9.28	24.74	47.11	131.66	62.65	61.71
26	64.45	52.45	30.82	13.53	21.52	25.04	6.49	14.12	29.76	155.69	112.27	139.53	55.48
TOTAL	2959.72	2174.18	1624.97	1017.33	879.45	824.30	292.17	261.97	504.23	2065.19	2930.53	3237.14	18751.20
MEAN	113.07	83.62	62.50	39.13	33.83	31.70	11.24	10.08	19.39	79.43	112.71	124.51	60.10

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT NIPON KOEI

ESTIMATED IN-FLOW SERIES INTO KAIWA PICUREM RESERVOIR

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
1950	20.93	6.74	1.85	2.59	3.10	27.06	38.35	25.35	47.66	68.84	83.43	24.29	
1951	17.49	6.75	1.83	1.71	5.02	24.50	85.54	30.93	18.39	91.14	89.19	31.51	
1952	21.21	7.72	2.07	2.20	1.95	5.70	22.60	28.84	49.60	24.68	68.62	32.29	
1953	15.89	10.72	2.61	1.64	1.64	5.78	15.58	56.05	22.60	41.12	62.74	94.67	25.97
1954	14.76	6.07	7.61	2.10	1.92	2.73	14.80	23.69	23.42	16.13	27.80	95.69	19.51
1955	29.45	4.23	1.95	2.32	1.51	4.10	25.44	19.66	32.78	38.12	63.45	44.21	22.36
1956	14.42	6.75	6.28	8.04	4.54	7.81	44.38	52.30	70.64	58.87	61.91	127.13	38.59
1957	22.63	4.56	1.71	1.60	1.29	2.64	17.92	42.97	28.40	20.10	23.84	16.98	15.34
1958	12.88	4.48	3.04	4.00	4.67	7.65	41.43	34.75	41.41	45.99	42.78	15.92	21.58
1959	12.42	5.26	5.69	1.56	1.27	2.72	18.93	31.54	31.99	13.45	49.61	47.38	18.98
1960	13.60	10.65	2.30	2.17	4.17	9.08	34.99	125.22	64.34	55.88	42.62	44.38	34.10
1961	17.31	8.82	4.94	3.60	6.01	7.86	29.32	31.81	51.41	48.58	65.02	27.12	24.82
1962	14.75	7.59	3.22	3.56	2.08	3.59	43.08	41.28	93.21	23.45	46.45	42.92	27.49
1963	13.04	9.22	3.36	3.23	1.49	4.97	28.01	54.41	65.68	25.54	24.01	44.44	23.12
1964	13.59	8.64	2.23	2.72	2.71	6.79	43.62	59.67	53.01	27.10	21.05	68.74	30.32
1965	17.10	6.48	2.94	1.45	1.59	2.81	30.89	30.64	33.26	38.48	50.29	70.81	23.39
1966	8.89	4.31	1.25	0.97	4.42	3.23	15.33	19.55	38.32	44.14	61.81	40.33	22.05
1967	17.80	4.41	3.09	2.58	2.68	6.73	23.14	55.37	36.39	14.64	50.07	42.31	21.60
1968	13.19	8.52	6.19	4.57	1.96	3.03	22.12	47.53	42.92	28.86	29.57	18.22	18.89
1969	7.24	1.97	1.79	1.27	0.93	1.30	16.96	30.29	31.65	13.82	25.13	69.43	16.98
1970	12.94	3.22	1.02	1.93	0.98	2.51	16.99	14.16	54.43	47.36	87.93	52.77	24.69
1971	11.35	10.01	6.70	2.27	11.83	24.89	221.36	54.16	24.54	52.72	57.52	29.19	37.99
1972	12.15	3.80	3.22	3.11	3.87	6.82	142.78	101.38	59.59	24.68	43.26	53.43	38.17
1973	8.02	6.00	2.34	2.19	2.07	6.10	29.35	23.51	25.39	41.70	70.97	95.25	26.11
1974	18.43	10.93	4.90	2.51	2.72	3.41	45.78	45.03	56.73	22.28	58.93	29.57	25.10
1975	8.53	2.13	1.75	0.92	1.92	4.37	20.40	68.50	68.23	73.64	50.33	65.86	30.73
TOTAL	389.22	171.86	92.30	68.64	78.52	147.76	918.28	1270.88	1156.22	976.82	1313.78	1528.02	8112.00
MEAN	14.97	6.61	3.55	2.64	3.02	5.66	35.33	48.88	44.47	37.57	50.53	58.77	26.00

NIPPON KOEI

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT

ESTIMATED INFLOW SERIES INTO AGOS AFIERRAY WEIR (NATURAL)

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
26	220.94	112.89	126.65	69.75	27.64	25.50	51.80	68.29	52.10	191.40	203.04	257.81	115.98
26	184.66	112.40	41.32	32.87	83.82	41.49	46.89	152.31	63.55	74.63	382.67	362.55	131.61
26	223.86	128.51	46.62	42.42	29.07	46.88	43.61	147.49	101.92	398.40	103.63	278.92	132.61
26	167.71	178.53	51.36	50.23	24.81	47.25	29.82	99.80	48.43	166.22	123.43	354.82	118.95
26	149.52	101.00	171.75	40.38	28.58	27.57	28.34	42.18	48.12	57.37	116.71	358.97	99.62
26	310.95	170.44	43.94	44.62	28.44	55.12	48.20	35.00	67.36	146.64	246.65	179.79	108.13
26	152.27	112.30	141.76	154.68	67.49	64.29	84.95	93.13	145.15	236.97	259.94	516.76	169.32
26	238.76	73.92	38.23	58.03	12.27	20.32	34.30	28.50	58.36	81.60	100.10	69.01	69.87
26	135.98	73.64	68.63	76.88	69.58	62.97	79.29	61.87	85.08	186.68	179.64	64.70	95.50
26	131.17	87.53	124.32	29.94	18.89	22.18	36.22	56.16	65.74	78.95	208.31	192.60	88.02
26	143.52	173.93	51.87	51.81	62.25	74.68	64.98	222.95	132.20	226.82	328.96	180.41	129.70
26	182.71	148.85	111.42	69.20	89.60	64.67	56.13	56.64	103.62	180.95	273.01	110.23	120.59
26	155.76	126.26	72.75	68.51	31.01	29.31	86.27	74.75	191.51	103.29	195.01	174.45	109.09
26	137.65	153.54	75.87	62.18	22.28	40.91	53.62	96.89	134.95	103.68	100.80	180.63	96.92
26	143.49	143.90	118.12	71.56	40.33	52.83	83.49	104.24	108.21	110.02	223.31	222.33	122.28
26	180.56	107.91	66.36	27.88	23.70	25.11	59.12	54.55	68.34	131.83	211.14	287.81	103.53
26	93.80	71.81	28.15	18.07	65.68	26.73	29.44	34.80	78.73	179.20	267.93	245.31	95.04
26	187.87	71.41	89.70	49.61	40.02	55.37	44.28	98.60	74.78	59.41	210.24	172.00	94.61
26	130.25	141.91	139.60	87.93	29.34	24.89	42.33	84.63	86.20	117.17	124.17	74.07	91.12
26	76.47	32.74	40.36	24.47	13.81	10.68	32.47	53.93	65.02	64.22	105.52	282.21	66.83
26	136.56	53.64	23.01	37.09	14.66	20.65	32.51	25.21	111.83	192.26	369.20	214.49	102.59
26	119.81	166.64	131.15	41.69	123.80	203.16	231.87	284.53	50.43	214.00	241.53	321.89	167.84
26	126.29	63.17	72.76	59.85	57.78	56.08	273.29	180.50	128.44	100.20	181.62	217.18	126.10
26	84.68	99.96	52.90	42.10	39.78	50.68	55.79	41.87	52.16	169.24	297.98	387.12	114.53
26	194.61	181.98	110.66	48.35	40.58	28.05	87.63	80.19	116.57	90.45	247.44	120.20	112.23
26	20.09	69.01	32.51	17.20	28.68	36.78	39.04	121.94	140.20	288.94	211.32	267.71	113.44
TOTAL	4108.96	2840.83	2083.09	1320.43	1171.00	1210.71	1758.14	2262.87	2375.70	3965.24	5516.07	6211.12	36844.16
MEAN	158.04	110.03	80.12	50.79	45.04	46.57	67.62	87.03	91.37	152.51	212.16	238.89	111.68

ESTIMATION OF DISCHARGE SERIES OF AGOS. RIVER SYSTEM FOR AGOS H.E. PROJECT
 ESTIMATED DISCHARGE SERIES BEIN. CONFLUENCE & AFTERBAY WEIR

NIPPON KOEI

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
26	9.15	4.97	5.72	2.22	1.20	1.01	0.50	0.46	0.64	5.83	6.31	7.78	3.82
26	4.95	1.87	1.47	3.65	1.64	0.65	1.02	0.78	2.25	11.77	10.94	4.04	4.04
26	9.27	5.66	2.11	1.89	1.26	1.85	0.82	0.99	1.25	12.01	3.19	8.42	4.03
26	8.55	7.86	2.22	2.24	1.08	1.87	0.52	0.67	0.57	5.03	5.52	11.61	3.83
26	6.19	4.44	7.76	1.80	1.74	0.89	0.77	0.28	0.59	1.73	3.59	11.74	3.38
26	12.88	3.10	1.99	1.99	1.24	2.17	0.67	0.23	0.83	4.62	8.20	5.43	3.58
26	6.31	4.94	6.40	6.90	2.94	2.55	0.82	0.62	1.78	7.21	8.00	15.59	5.34
26	9.81	3.34	1.74	1.23	0.82	0.79	0.73	0.51	0.72	2.56	3.08	2.08	2.25
26	5.63	3.28	3.10	3.43	3.03	2.48	0.76	0.41	1.05	5.63	5.53	1.95	3.02
26	5.43	3.85	5.80	1.34	0.82	0.88	0.35	0.38	0.81	2.38	4.41	5.81	2.85
26	5.95	7.65	2.34	1.87	2.71	2.94	0.64	1.49	1.62	6.84	5.51	5.44	3.75
26	7.57	6.46	5.03	3.09	3.90	2.55	0.54	0.38	1.30	5.46	8.40	3.33	4.00
26	6.45	5.56	3.29	3.06	1.35	1.16	0.83	0.50	2.35	3.11	6.00	5.26	3.26
26	5.70	6.74	3.43	2.77	0.97	1.61	0.52	0.65	1.68	5.13	5.10	5.45	2.98
26	3.21	6.33	3.24	3.19	1.76	2.20	0.80	0.71	1.34	3.32	9.18	8.43	4.05
26	7.48	4.75	3.00	1.24	1.03	0.91	0.57	0.37	0.84	3.98	6.50	8.69	3.28
26	3.89	3.16	1.27	0.83	2.87	1.05	0.28	0.23	0.92	5.40	8.24	7.40	2.97
26	7.78	3.23	3.15	2.21	1.72	2.18	0.53	0.66	0.92	1.79	6.47	5.19	2.98
26	5.77	6.24	6.31	3.92	3.27	0.28	0.41	0.37	1.68	3.53	3.82	2.26	3.01
26	3.17	1.44	1.82	1.09	0.60	0.42	0.31	0.36	0.80	1.94	3.25	8.52	1.98
26	5.66	2.36	1.04	1.65	0.66	0.81	0.31	0.17	1.37	5.80	11.36	6.47	3.14
26	4.96	7.33	6.83	1.95	7.25	8.01	2.21	0.65	0.62	6.45	7.43	9.21	5.34
26	5.31	2.78	3.29	2.67	2.51	2.21	2.63	1.21	1.50	3.02	5.59	6.55	3.27
26	3.51	4.40	2.39	1.88	1.73	2.00	0.54	0.28	0.64	5.10	9.17	11.68	3.61
26	8.06	8.01	5.00	2.16	1.72	1.11	0.84	0.54	1.43	2.73	7.61	3.63	3.57
26	3.73	3.04	1.78	0.75	1.25	1.43	0.38	0.82	1.72	5.02	6.50	8.08	3.21
TOTAL	170.22	125.89	94.09	58.91	50.92	47.73	16.92	15.17	29.20	119.58	189.69	187.44	1085.76
MEAN	6.55	4.84	3.62	2.27	1.96	1.84	0.65	0.58	1.12	4.60	6.53	7.21	3.48

ESTIMATION OF DISCHARGE SERIES OF AGQS RIVER SYSTEM FOR AGQS H.F. PROJECT
 ESTIMATED DISCHARGE SERIES FROM LOWER KANAN BASIN

NIPPON KOEI

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
1950	43.67	27.30	10.58	5.73	4.80	2.37	2.16	3.05	27.81	30.09	37.13	18.20	18.20
1951	36.50	23.60	8.91	6.99	17.38	7.84	2.15	4.84	3.72	10.73	56.15	52.21	19.25
1952	44.95	26.98	10.05	9.02	6.03	8.82	2.00	4.71	5.97	57.29	15.21	40.16	19.21
1953	33.43	27.48	11.47	10.68	5.15	3.94	1.37	3.19	2.72	24.00	26.33	55.41	18.20
1954	29.56	21.20	37.02	8.59	5.93	4.23	1.30	1.55	2.82	8.25	17.13	56.01	16.11
1955	61.47	14.79	9.48	9.50	5.90	10.37	2.23	1.12	3.94	21.09	39.10	25.89	17.07
1956	30.10	23.58	30.56	32.89	16.04	12.09	3.89	2.97	8.50	34.36	38.14	74.41	25.46
1957	46.80	13.94	8.30	5.24	5.00	5.27	1.52	2.44	3.62	41.73	14.68	8.94	19.71
1958	26.88	15.67	14.79	16.35	13.43	11.85	3.63	1.98	4.98	26.84	26.36	8.52	14.42
1959	25.93	18.38	27.66	16.37	3.92	4.21	1.66	1.79	3.85	11.15	30.57	27.73	13.62
1960	28.37	36.51	11.18	8.89	12.91	14.05	3.02	7.12	7.74	32.61	26.26	25.98	17.89
1961	36.12	30.83	24.02	14.72	18.58	12.17	2.57	1.81	6.18	26.02	40.06	15.87	19.08
1962	30.79	26.51	15.68	14.57	6.53	5.55	3.96	2.39	11.21	14.85	28.61	25.12	15.47
1963	27.21	32.23	16.35	13.22	4.62	7.70	2.46	3.09	7.90	14.91	14.79	26.01	14.21
1964	28.27	30.51	25.46	15.21	8.38	10.50	3.81	3.39	6.38	15.82	43.77	40.24	19.30
1965	35.69	22.66	14.30	5.93	6.91	4.35	2.71	1.74	4.00	18.96	30.98	41.45	15.64
1966	18.54	15.08	6.07	3.97	13.66	5.03	1.35	1.11	4.61	25.77	39.31	35.32	14.15
1967	37.14	15.41	15.02	10.55	8.30	10.42	2.03	3.15	4.38	8.54	30.85	24.77	14.21
1968	27.53	29.79	30.09	18.70	6.04	4.68	1.94	2.20	5.16	16.85	18.22	10.67	14.37
1969	15.12	6.87	8.70	5.20	2.86	2.01	1.49	1.72	3.81	9.23	15.48	40.64	9.43
1970	27.00	11.26	4.96	7.89	3.04	3.88	1.49	0.81	6.55	27.65	54.17	30.89	14.96
1971	23.68	34.98	32.58	9.29	32.98	38.22	10.63	3.08	2.95	30.77	35.44	46.35	25.33
1972	25.36	13.26	15.68	12.73	11.98	10.55	12.53	5.77	7.17	14.41	26.65	31.27	15.61
1973	16.74	20.99	11.40	8.95	8.25	9.53	2.56	1.34	3.05	24.34	43.72	55.75	17.22
1977	38.47	38.20	23.85	10.28	8.42	5.28	4.02	2.56	6.83	13.01	36.31	17.31	17.04
1978	17.81	14.59	8.52	3.76	5.94	6.92	1.79	3.90	8.21	42.99	31.01	38.55	15.32
TOTAL	812.24	600.60	449.02	280.80	242.84	227.76	80.60	22.28	139.10	570.18	809.38	894.40	5179.20
MEAN	31.24	23.10	17.27	10.80	9.34	8.76	3.10	2.78	5.35	21.93	31.13	34.40	16.60

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT
 ESTIMATED DISCHARGE SERIES FROM LOWER KALIMA BASIN
 NIPPON KOEI

YEAR	JAN.	FEB.	MAR.	APR.	MAY	JUNE	JULY	AUG.	SEP.	OCT.	NOV.	DEC.	ANNUAL
1950	21.99	9.49	9.77	4.01	2.41	2.85	15.04	21.04	14.29	33.34	33.54	43.06	17.49
1951	18.38	9.45	3.19	2.65	7.31	4.66	13.62	46.92	17.64	12.48	62.59	60.55	21.60
1952	22.28	18.80	3.60	3.42	2.34	5.23	12.67	45.43	17.96	65.61	16.95	46.59	22.01
1953	18.62	12.01	3.96	4.05	2.17	5.11	8.66	30.74	12.74	27.91	29.35	64.27	18.40
1954	14.68	8.49	13.25	3.25	2.49	2.51	8.23	12.99	13.20	9.59	19.09	64.97	14.41
1955	30.95	5.92	3.39	3.60	2.68	6.15	14.14	10.78	18.48	24.52	43.58	30.03	16.77
1956	15.16	0.44	10.93	12.46	5.91	7.18	24.67	28.69	39.83	33.96	42.52	86.31	26.92
1957	23.57	6.38	2.97	2.26	1.88	2.24	2.52	23.52	34.01	19.64	16.37	14.53	10.85
1958	13.54	6.27	5.29	6.19	6.07	7.03	23.03	19.06	23.34	31.21	29.38	10.81	15.10
1959	13.06	7.36	9.90	2.41	1.65	2.50	10.52	17.30	18.04	11.20	36.07	32.17	13.51
1960	15.29	14.62	4.00	3.37	5.43	8.34	12.55	68.68	36.27	37.92	29.27	30.13	22.65
1961	18.19	12.35	8.59	5.57	7.82	7.22	16.30	17.45	28.98	30.26	44.65	18.41	17.98
1962	15.50	10.61	5.61	5.52	2.71	3.30	25.06	23.03	52.55	17.27	31.90	29.14	18.52
1963	13.70	12.91	5.85	5.01	1.94	4.57	15.57	29.85	31.03	11.33	16.49	30.17	15.87
1964	13.24	12.10	9.11	3.76	3.23	6.23	24.25	32.73	29.88	18.40	48.79	46.07	20.98
1965	17.97	9.07	5.12	2.25	2.07	2.58	17.17	16.80	18.75	22.04	34.53	48.07	16.37
1966	9.34	6.04	2.17	1.50	5.25	2.99	8.55	30.72	21.60	28.96	43.82	60.92	15.28
1967	18.70	6.17	5.38	4.00	3.69	6.18	12.86	30.57	20.52	9.93	34.39	28.73	15.06
1968	13.86	11.93	10.77	7.08	2.95	2.28	12.22	26.02	24.20	19.59	20.31	32.32	13.65
1969	7.61	2.75	3.11	1.97	1.21	1.19	9.43	16.61	17.84	10.74	17.26	47.16	11.40
1970	13.59	4.51	1.78	2.99	1.28	2.31	9.44	7.76	30.68	32.15	60.39	35.82	16.89
1971	11.93	14.01	11.66	3.52	15.14	22.69	62.34	29.70	13.84	15.78	39.50	53.76	26.52
1972	12.77	5.31	5.61	4.82	5.04	6.26	79.37	55.60	31.59	16.75	29.71	36.27	24.26
1973	8.43	8.40	4.08	3.39	3.47	5.66	16.20	12.90	14.31	28.30	48.74	64.62	18.21
1977	19.37	15.30	8.54	3.89	3.34	3.13	25.45	24.70	31.98	15.12	40.47	20.08	17.63
1978	8.92	5.80	3.03	1.43	2.30	4.31	11.34	37.52	34.47	69.98	34.56	44.71	20.24
TOTAL	408.98	240.50	190.68	106.34	102.18	135.20	510.64	682.06	651.82	663.00	902.20	1032.60	5616.00
MEAN	15.73	9.25	6.18	4.09	3.93	5.20	19.64	26.81	25.07	25.50	34.70	39.90	18.00

NIPPON KOEI TOKYO/JAPAN

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-1 KANAN HML 290
 HIGH WATER LEVEL IN METER 175,000 LOW WATER LEVEL IN METER 135,000 RATED HEAD IN METER ***** 108,270
 INSTALLED CAPACITY IN MW 200,000 DEPENDABLE CAPACITY IN MW 149,738 TARGET OPERATION HOUR A DAY 6,116
 RATED DISCHARGE IN CMS 219,178 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN HWH JAN, FEB, MAR, APR, MAY, JUNE, JULY, AUG, SEP, OCT, NOV, DEC,
 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188

LENGTH OF INFLOW SERIES IN YEAR 24

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

O, HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550,0 160,25 0,0234
 1950,0 111,76 0,0425
 0, 63,35 0,0482

YEAR	ANNUAL POWER ENERGY (GWH)		ANNUAL ENERGY (M US D)		TOTAL ENERGY (M US D)		P, W, F		PRESENT OPERATION	
	(MWH)	(GWH)	(M US D)	(M US D)	(M US D)	(M US D)	(M US D)	(M US D)	(MWH)	(HOUR)
1989	200,0	843,19	32,05	51,78	0,90909	47,07	42261	42,39	4121	42261
1990	200,0	822,36	32,05	51,29	0,82645	42,39	4037	38,17	4037	4037
1991	200,0	801,52	32,05	50,81	0,75131	38,17	3912	34,37	3912	3912
1992	200,0	780,68	32,05	50,32	0,68301	34,37	3809	30,94	3809	3809
1993	200,0	759,85	32,05	49,83	0,62092	30,94	3704	27,85	3704	3704
1994	200,0	739,01	32,05	49,34	0,56447	27,85	3704	25,12	3704	3704
1995	200,0	739,01	32,05	49,34	0,56447	27,85	3704	25,12	3704	3704
2037	200,0	739,01	32,05	49,34	0,00937	0,16	3704	0,16	3704	3704
2038	200,0	739,01	32,05	49,34	0,00852	0,12	3704	0,12	3704	3704
SUMMARY	200,0	745,26	32,05	49,49	9,91481	495,12	3735			

*** RESULTS OF THE CASE HML= 175,000 INSTALLED CAPACITY= 200,0 STOKED IN DISK FILE A1818*02 NO, 1

*** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR ***

YEAR	INFLOW (CMS)	EVAPOR (CMS)	SPILL (CMS)	Q24 (CMS)	QG (CMS)	S2 (CMS)	R, W, L (M)	T, N, L (M)	E, HEAD EFFICI, (M)	POWER (MWH)	O, HOUR (H)	P, E, (GWH)	S, E, (GWH)	T, E, (GWH)
1989	100,74	1,89	10,12	89,53	188,07	405,77	171,269	41,000	126,063	199,13	4225,7	458,25	384,94	843,19
1994	84,43	1,58	5,53	78,77	188,32	400,08	171,058	41,000	125,844	199,14	3703,6	469,50	269,21	739,01

*** DEPENDABLE DISCHARGE, POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	100,0 (CMS)	DEPENDABLE (MWH)	95,0 (CMS)	DEPENDABLE (MWH)	90,0 (CMS)	DEPENDABLE (MWH)	85,0 (CMS)	DEPENDABLE (MWH)
1989	46,85	153,33	38,19	47,34	200,00	38,19	48,72	200,00
1994	48,05	152,53	39,13	48,40	200,00	39,13	49,75	200,00

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-1 KANAN HILL 290 NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 175,000 LOW WATER LEVEL IN METER 125,000 RATED HEAD IN METER 108,270
 INSTALLED CAPACITY IN MW 200,000 DEPENDABLE CAPACITY IN MW 149,738 TARGET OPERATION HOUR A DAY 6.16
 RATED DISCHARGE IN CMS 219.178 TYPE OF RULE CURVE ** VARIABLE MASS CURVE

RULE CURVE IN MMH JAN, FEB, MAR, APR, MAY, JUNE, JULY, AUG, SEP, OCT, NOV, DEC,
 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188 38,188

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1989 ***

MONTH	INFLOW (CMS)	EVAPORATION (CMS)	SPILL (CMS)	Q24 (CMS)	QG (CMS)	S2 (MCH)	R.W.L. (M)	T.H.L. (M)	E-HEAD EFFICIENCY (%)	POWER (MW)	O-HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN,	148.95	1.07	7.19	132.20	183.07	682.69	174.853	41,000	129.654	0.860	200.0	538.3	38.19	107.67
FEB,	99.15	1.39	9.1	98.44	182.51	681.03	174.802	41,000	129.611	0.860	200.0	362.1	38.19	72.42
MAR,	72.95	1.61	0.	75.45	183.52	670.05	174.537	41,000	129.528	0.860	200.0	306.8	38.19	61.56
APR,	45.88	1.82	0.	55.56	184.56	640.25	173.569	41,000	128.602	0.860	200.0	217.0	38.19	5.22
MAY	40.06	1.46	0.	53.97	187.05	599.10	172.118	41,000	126.937	0.860	200.0	215.2	38.19	4.86
JUNE	39.60	1.03	0.02	56.38	190.52	552.87	170.076	41,000	124.734	0.860	200.0	214.1	38.19	4.82
JULY	46.03	0.80	3.84	61.63	194.67	498.68	167.586	41,000	122.047	0.860	199.7	238.4	38.19	9.43
AUG,	74.66	0.42	1.17	67.42	195.45	512.74	166.416	41,000	120.861	0.860	198.2	261.8	38.19	13.78
SEP,	82.15	0.82	0.	75.44	193.95	526.03	166.324	41,000	121.424	0.860	197.4	285.2	38.19	18.26
OCT,	140.51	0.82	14.56	99.51	190.45	597.19	169.115	41,000	123.908	0.860	198.0	396.0	38.19	40.52
NOV,	198.28	0.80	34.44	147.10	186.15	638.52	171.841	41,000	126.785	0.860	198.5	376.1	38.19	76.63
DEC,	224.28	0.88	59.07	151.32	184.56	673.35	173.747	41,000	128.740	0.860	200.0	614.6	38.19	114.82
MEAN	100.74	1.09	10.12	89.53	188.07	605.77	171.269	41,000	126.063	0.860	199.3	4225.7	458.25	384.94

*** THESE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURRED 5 TIMES
 LONGEST DURATION FROM 20-TH YEAR 7-TH MONTH TO 20-TH YEAR 11-TH MONTH
 LOWEST POWER 153.3 MW

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPORATION (CMS)	SPILL (CMS)	Q24 (CMS)	QG (CMS)	S2 (MCH)	R.W.L. (M)	T.H.L. (M)	E-HEAD EFFICIENCY (%)	POWER (MW)	O-HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN,	132.01	1.06	4.61	124.54	184.51	667.58	174.036	41,000	128.985	0.860	200.0	506.0	39.13	101.19
FEB,	97.27	1.36	0.	97.51	184.03	663.66	174.059	41,000	129.011	0.860	200.0	357.4	39.13	71.48
MAR,	71.95	1.59	0.	75.77	184.74	649.17	173.544	41,000	128.565	0.860	200.0	306.5	39.13	61.30
APR,	47.59	1.79	0.	56.33	186.21	621.85	172.226	41,000	127.580	0.860	200.0	218.3	39.13	4.53
MAY	44.36	1.44	0.	54.92	188.31	593.34	171.443	41,000	126.201	0.860	200.0	216.0	39.13	4.08
JUNE	44.36	1.03	0.	56.65	190.44	555.83	169.583	41,000	125.545	0.860	199.6	214.9	39.13	3.77
JULY	48.53	0.81	0.	56.51	192.34	532.28	168.475	41,000	123.049	0.860	199.1	219.7	39.13	4.60
AUG,	58.46	0.84	0.	58.34	193.31	530.89	167.777	41,000	122.319	0.860	198.5	226.3	39.13	5.79
SEP,	59.01	0.83	0.	57.14	192.66	533.59	167.700	41,000	122.264	0.860	198.0	214.5	39.13	5.23
OCT,	86.86	0.81	3.67	70.78	191.17	564.70	168.607	41,000	123.263	0.860	198.1	278.9	39.13	16.18
NOV,	140.09	0.78	7.23	105.86	188.23	632.63	171.351	41,000	126.149	0.860	199.5	411.1	39.13	43.00
DEC,	182.56	0.88	38.84	131.79	185.06	662.77	173.591	41,000	128.411	0.860	200.0	534.3	39.13	67.33
MEAN	84.43	1.08	4.58	78.77	188.39	600.08	171.066	41,000	125.844	0.860	199.4	3703.6	489.51	739.01

*** THESE ARE POWER DEFICIT OF THE LONGEST DURATION 6 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURRED 2 TIMES
 LONGEST DURATION FROM 21-TH YEAR 6-TH MONTH TO 21-TH YEAR 11-TH MONTH
 LOWEST POWER 152.5 MW

**** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN #1 KANAN MHL 290 NIPPON KOEI TOKYO/JAPAN**
 HIGH WATER LEVEL IN METER 165,000 LOW WATER LEVEL IN METER 125,000 RATED HEAD IN METER 90,200
 INSTALLED CAPACITY IN MW 185,000 DEPENDABLE CAPACITY IN MW 139,524 TARGET OPERATION HOUR A DAY 5.45
 RATED DISCHARGE IN CMS 231,277 TYPE OF RULE CURVE VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN, FEB, MAR, APR, MAY, JUNE, JULY, AUG, SEP, OCT, NOV, DEC
 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250

LENGTH OF INFLOW SERIES IN YEAR 26
***** BENEFIT CALCULATION *****
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0
 0 HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550,0 160,25 0,0234
 1950,0 111,76 0,0425
 0, 0,0682

YEAR	DEPENDABLE		ANNUAL ENERGY		BENEFIT		TOTAL		P.M.F.		PRESENT OPERATION	
	(MW)	(GWH)	(M US D)	(M US D)	(M US D)	(M US D)	(M US D)	(M US D)	(M US D)	(M US D)	(H)	(H)
1989	185.0	780.24	29.65	18.26	47.90	0.150509	43.55	4226				
1990	185.0	760.76	29.65	17.80	47.45	0.152845	39.21	4120				
1991	185.0	741.29	29.65	17.35	46.99	0.155131	35.31	4015				
1992	185.0	721.81	29.65	16.89	46.54	0.168301	31.72	3910				
1993	185.0	702.34	29.65	16.43	46.08	0.162092	28.61	3804				
1994	185.0	682.86	29.65	15.98	45.63	0.156447	25.75	3699				
1995	185.0	663.38	29.65	15.52	45.16	0.151316	23.41	3594				
2037	185.0	682.86	29.65	15.98	45.63	0.100937	0.43	3499				
2038	185.0	663.38	29.65	15.52	45.16	0.150952	0.32	3394				
SUMMARY	185.0	663.71	29.65	16.12	45.76	9.91481	457.88	3731				

***** RESULTS OF THE CASE MHL= 165,000 INSTALLED CAPACITY= 185,0 STORED IN DISK FILE A1818#02 NO. 2**
***** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR *****

YEAR	INFLOW		EVAPO.		SPILL		OG		S2		P.M.F.		T.M.L.		E.HEAD EFFICI.		POWER		P.E.		S.E.		T.E.			
	(CMS)	(CMS)	(CMS)	(CMS)	(CMS)	(CMS)	(CMS)	(CMS)	(CMS)	(CMS)	(M)	(M)	(M)	(M)	(M)	(M)	(M)	(MW)	(H)	(GWH)	(GWH)	(MW)	(GWH)	(MW)	(GWH)	
1989	100.74	0.92	10.46	89.36	187.63	485.82	152.015	41.000	116.877	0.860	184.4	4225.9	375.00	405.24	780.24	184.5	3698.9	450.75	262.11	682.66						
1994	84.43	0.91	4.81	79.62	189.31	469.12	151.110	41.000	115.804	0.860																

***** DEPENDABLE DISCHARGE , POWER OUTPUT AND ENERGY OUTPUT *****

YEAR	DEPENDABLE		DISCHARGE		POWER		OUTPUT		ENERGY	
	(CMS)	(GWH)	(CMS)	(GWH)	(MW)	(H)	(GWH)	(GWH)	(MW)	(H)
1989	41.53	141.66	31.25	185.00	185.00	31.25	48.59	185.00	31.25	48.59
1994	46.60	142.03	35.06	185.00	185.00	35.06	48.33	185.00	35.06	48.33

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-1 KAMAN HWL 290 NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 165,000 LOW WATER LEVEL IN METER 128,000 RATED HEAD IN METER 99,200
 INSTALLED CAPACITY IN MW 185,000 DEPENDABLE CAPACITY IN MW 139,526 TARGET OPERATION HOUR A DAY 5.45
 RATED DISCHARGE IN CMS 221,277 TYPE OF RULE CURVE 1 VARIABLE MASS CURVE
 RULE CURVE IN MMW JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250 31,250

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1989 ***

MONTH	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	OG (CMS)	S2 (CMS)	R.W.L. (M)	T.W.L. (M)	E-HEAD EFFICI. (%)	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	143.95	0.91	7.16	182.92	540.42	164.944	41,000	120,000	0.860	185.0	546.3	31.25	101.07
FEB.	99.15	1.17	0.	98.98	538.72	164.956	41,000	119,991	0.860	185.0	362.6	31.25	67.08
MAR.	72.95	1.35	0.	74.33	531.41	164.971	41,000	119,983	0.860	185.0	302.0	31.25	55.87
APR.	45.88	1.53	0.	52.41	510.82	164.919	41,000	118,983	0.860	185.0	204.3	31.25	37.80
MAY	40.06	1.23	0.	52.29	480.04	162.714	41,000	117,581	0.860	185.0	201.1	31.25	37.20
JUNE	39.60	0.87	0.01	51.99	445.62	160.677	41,000	115,581	0.860	185.0	197.9	31.25	36.62
JULY	49.03	0.88	3.85	57.41	403.01	158.617	41,000	113,128	0.860	184.6	223.0	31.25	41.18
AUG.	74.66	0.53	1.18	67.13	418.62	157.755	41,000	112,309	0.860	183.2	261.9	31.25	46.11
SEP.	82.15	0.70	0.	76.26	432.06	158.289	41,000	112,872	0.860	183.2	290.4	31.25	53.25
OCT.	140.51	0.70	4.63	104.86	486.149	160.549	41,000	115,434	0.860	183.5	420.3	31.25	77.57
NOV.	199.28	0.68	36.62	151.85	510.16	162.608	41,000	117,594	0.860	183.7	594.9	31.25	109.78
DEC.	224.28	0.74	60.87	152.95	535.16	164.333	41,000	119,522	0.860	185.0	621.2	31.25	114.92
MEAN	100.74	0.92	10.46	89.36	485.82	162.015	41,000	116,877	0.860	184.4	4225.9	375.00	780.24

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURED 3 TIMES
 LONGEST DURATION FROM 20-TH YEAR 7-TH MONTH TO 20-TH YEAR 11-TH MONTH

LOWEST POWER 141.7 MW

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	OG (CMS)	S2 (CMS)	R.W.L. (M)	T.W.L. (M)	E-HEAD EFFICI. (%)	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	132.03	0.89	4.59	124.60	527.127	164.144	41,000	119,109	0.860	185.0	505.3	35.06	93.48
FEB.	97.28	1.16	0.	97.49	523.96	164.202	41,000	119,173	0.860	185.0	356.8	35.06	66.00
MAR.	71.98	1.33	0.	75.24	511.67	163.788	41,000	118,724	0.860	185.0	303.8	35.06	56.21
APR.	47.67	1.50	0.	55.35	487.85	162.851	41,000	117,115	0.860	185.0	214.0	35.06	39.59
MAY	44.29	1.21	0.	53.48	460.00	161.515	41,000	116,273	0.860	185.0	211.2	35.06	39.09
JUNE	44.42	0.86	0.	55.56	428.65	159.853	41,000	114,479	0.860	184.8	209.7	35.06	38.76
JULY	48.61	0.67	0.	55.80	408.14	158.334	41,000	112,852	0.860	183.7	212.3	35.06	39.50
AUG.	58.50	0.53	0.	57.11	408.83	157.844	41,000	112,129	0.860	183.7	222.1	35.06	40.78
SEP.	58.99	0.69	0.	56.95	412.32	157.662	41,000	112,180	0.860	183.1	212.0	35.06	38.78
OCT.	86.71	0.68	3.83	70.81	442.86	158.733	41,000	113,352	0.860	183.2	275.8	35.06	50.97
NOV.	139.89	0.66	7.42	109.67	500.25	161.564	41,000	116,475	0.860	184.6	425.4	35.06	78.62
DEC.	182.53	0.74	38.64	135.82	522.03	163.597	41,000	118,610	0.860	185.0	546.5	35.06	104.11
MEAN	84.43	0.91	4.61	78.92	469.17	161.140	41,000	115,190	0.860	184.5	3698.9	428.75	682.66

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURED 2 TIMES
 LONGEST DURATION FROM 21-TH YEAR 6-TH MONTH TO 21-TH YEAR 10-TH MONTH

LOWEST POWER 142.0 MW

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-1 KAMAN HML 300 NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 155,000 LOW WATER LEVEL IN METER 121,000 RATED HEAD IN METER 17,130
 INSTALLED CAPACITY IN MW 170,000 DEPENDABLE CAPACITY IN MW 127,534 TARGET OPERATION HOUR A DAY 4,87
 RATED DISCHARGE IN CMS 221,342 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656
 LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0
 O, HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0334
 1950.0 111.76 0.0225
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	BENEFIT ENERGY (M US D)	TOTAL (M US D)	P, H, F, (M US D)	PRESENT OPERATION HOUR (H)
1989	170.0	717.35	27.24	16.79	44.03	0.30909	4228
1990	170.0	699.25	27.24	16.36	43.60	0.32645	4122
1991	170.0	681.14	27.24	15.94	43.18	0.34381	4015
1992	170.0	663.04	27.24	15.52	42.76	0.36117	3909
1993	170.0	644.93	27.24	15.09	42.33	0.37853	3802
1994	170.0	626.83	27.24	14.67	41.91	0.39589	3695
1995	170.0	608.73	27.24	14.25	41.49	0.41325	3588
2037	170.0	626.83	27.24	14.67	41.91	0.00937	3695
2038	170.0	626.83	27.24	14.67	41.91	0.00852	3695
SUMMARY	170.0	632.26	27.24	14.79	42.04	9.91481	420.66

*** RESULTS OF THE CASE HML 155,000 INSTALLED CAPACITY 170.0 STORED IN DISK FILE A1818*02 NO. 3

*** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR ***

YEAR	INFLOW (CMS)	EVAP. (CMS)	SPIII (CMS)	Q24 (CMS)	Q6 (CMS)	Q2 (CMS)	R, W, L, (M)	T, W, L, (M)	E HEAD EFFICI. (M)	POWER (MW)	O, HOUR (H)	P, E, (GWH)	S, E, (GWH)	T, E, (GWH)
1989	400.74	0.77	10.59	89.37	187.45	384.10	152.1544	41,000	107.437	0.860	169.13	4228.4	307.88	403.48
1994	84.24	0.76	4.38	79.10	190.16	365.19	151.302	41,000	105.084	0.860	169.13	3695.3	381.00	245.83
100.0	DEPENDABLE (MW)	95.0	DEPENDABLE (G(CMS))	90.0	DEPENDABLE (G(CMS))	85.0	DEPENDABLE (G(CMS))	80.0	DEPENDABLE (G(CMS))	80.0	DEPENDABLE (H)	80.0	DEPENDABLE (GWH)	80.0
1989	37.20	127.73	25.66	37.71	170.00	25.66	38.54	170.00	25.66	39.09	170.00	25.66	39.90	170.00
1994	46.03	129.33	31.75	46.65	170.00	31.75	47.64	170.00	31.75	47.94	170.00	31.75	48.55	170.00

*** DEPENDABLE DISCHARGE , POWER OUTPUT AND ENERGY OUTPUT ***

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN #1 KANAN-HML 300 NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 158,000 LOW WATER LEVEL IN METER 121,000 RATED HEAD IN METER 91.130
 INSTALLED CAPACITY IN MMH 170,000 DEPENDABLE CAPACITY IN MMH 127,534 TARGET OPERATION HOUR A DAY 4.87
 RATED DISCHARGE IN CMS 221,342 TYPE OF RULE CURVE 11 VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN, FEB, MAR, APR, MAY, JUNE, JULY, AUG, SEP, OCT, NOV, DEC,
 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656 25,656

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1989 ***

MONTH	INFLOW (CMS)	EVAPOR (CMS)	SPILL (CMS)	G24 (CMS)	OG (CMS)	S2 (CMS)	R.H.L. (M)	T.H.L. (M)	E-HEAD EFFICI.	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN,	143.95	0.75	7.11	136.08	183.30	421.78	155.000	41,000	110,1045	0.860	170.0	552.4	25.66	93.90
FEB,	99.15	0.97	0.	98.88	183.30	420.32	154.969	41,000	110,005	0.860	170.0	361.7	25.66	35.94
MAR,	72.95	1.13	0.	73.35	183.30	416.47	154.803	41,000	109,832	0.860	170.0	297.4	25.66	24.91
APR,	45.88	1.28	0.	49.89	184.68	402.75	154.257	41,000	109,241	0.860	170.0	194.8	25.66	7.47
MAY,	40.06	1.03	0.	47.78	186.85	379.32	153.123	41,000	108,111	0.860	170.0	191.0	25.66	6.81
JUNE	39.80	0.73	0.00	48.09	190.24	353.88	151.483	41,000	106,213	0.860	170.0	185.5	25.66	5.89
JULY	46.03	0.57	3.93	54.21	194.16	320.16	149.389	41,000	103,939	0.860	169.5	211.0	25.66	10.12
AUG,	74.66	0.45	1.17	67.56	193.81	334.87	148.686	41,000	103,290	0.860	167.9	265.1	25.66	19.03
SEP,	82.15	0.59	0.	76.06	192.03	349.13	149.392	41,000	103,103	0.860	167.5	291.2	25.66	23.37
OCT,	140.51	0.59	14.58	111.86	188.03	385.23	151.555	41,000	106,602	0.860	168.4	449.4	25.66	50.42
NOV,	198.28	0.57	36.79	152.86	185.49	406.13	153.265	41,000	109,255	0.860	168.9	598.4	25.66	75.88
DEC,	224.28	0.62	62.42	159.39	183.45	421.78	154.784	41,000	109,960	0.860	170.0	630.4	25.66	101.54
MEAN	100.74	0.77	10.59	89.37	187.45	384.10	152.544	41,000	101,437	0.860	169.5	4228.4	307.88	409.48

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURED 2 TIMES

LONGEST DURATION FROM 20-TH YEAR 7-TH MONTH TO 20-TH YEAR 11-TH MONTH

LOWEST POWER 127.7 MW

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR (CMS)	SPILL (CMS)	G24 (CMS)	OG (CMS)	S2 (CMS)	R.H.L. (M)	T.H.L. (M)	E-HEAD EFFICI.	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN,	131.23	0.75	4.52	124.63	184.67	418.16	154.323	41,000	109,306	0.860	170.0	504.5	31.75	54.01
FEB,	97.18	0.96	0.	97.32	184.57	418.48	154.359	41,000	109,346	0.860	170.0	355.5	31.75	28.69
MAR,	72.33	1.11	0.	74.90	185.34	400.63	153.965	41,000	108,917	0.860	170.0	301.9	31.75	19.58
APR,	47.88	1.25	0.	54.92	187.23	379.13	152.983	41,000	108,890	0.860	170.0	211.7	31.75	4.24
MAY	45.02	1.00	0.	53.14	190.08	354.70	151.544	41,000	106,281	0.860	170.0	208.8	31.75	3.74
JUNE	45.68	0.71	0.	55.47	193.52	327.47	149.801	41,000	104,380	0.860	169.9	207.4	31.75	3.49
JULY	50.36	0.56	0.	55.60	196.16	311.95	148.283	41,000	102,738	0.860	169.4	212.4	31.75	4.23
AUG,	60.29	0.44	0.	58.90	196.45	315.83	147.778	41,000	102,223	0.860	168.6	223.4	31.75	5.92
SEP,	86.00	0.57	0.	88.09	195.42	321.16	147.974	41,000	102,466	0.860	168.0	215.5	31.75	4.42
OCT,	136.00	0.57	3.61	71.28	193.39	349.37	149.179	41,000	103,767	0.860	168.4	278.7	31.75	15.27
NOV,	183.51	0.59	5.98	110.58	189.08	391.86	151.902	41,000	106,775	0.860	169.6	428.1	31.75	40.95
DEC,	180.35	0.61	37.66	135.86	185.82	409.57	153.613	41,000	106,827	0.860	170.0	547.3	31.75	61.29
MEAN	84.24	0.76	4.38	79.10	190.16	365.19	151.907	41,000	106,054	0.860	169.5	3695.3	381.00	245.83

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURED 3 TIMES

LONGEST DURATION FROM 21-TH YEAR 6-TH MONTH TO 21-TH YEAR 10-TH MONTH

LOWEST POWER 129.3 MW

NIPPON KOEI TOKYO/JAPAN

DAM ** PLAN A-1 KARAN-HML 500

** RESERVOIR OPERATION STUDY OF AGOS

HIGH WATER LEVEL IN METER 145,000 LOW WATER LEVEL IN METER 114,000 RATED HEAD IN METER 82,600
 INSTALLED CAPACITY IN MW 155,000 DEPENDABLE CAPACITY IN MW 116,326 TARGET OPERATION HOUR A DAY 4.31
 RATED DISCHARGE IN CMS 222,452 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MHH JAN, FEB, MAR, APR, MAY, JUNE, JULY, AUG, SEP, OCT, NOV, DEC;
 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

O, HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	ENERGY (M US D)	BENEFIT ENERGY (M US D)	TOTAL BENEFIT (M US D)	P, M, F.	WORTH (M US D)	PRESENT OPERATION HOUR
1989	155.0	654.52	24.84	15.32	40.15	0.90909	36.50	4229.	
1990	155.0	638.07	24.84	14.93	39.77	0.82645	32.87	4124.	
1991	155.0	621.62	24.84	14.55	39.38	0.75131	29.59	4018.	
1992	155.0	605.17	24.84	14.16	39.00	0.68301	26.64	3912.	
1993	155.0	588.73	24.84	13.78	38.61	0.62092	23.98	3807.	
1994	155.0	572.28	24.84	13.39	38.23	0.56847	21.58	3701.	
1995	155.0	572.28	24.84	13.39	38.23	0.51316	19.62	3701.	
2037	155.0	572.28	24.84	13.39	38.23	0.20937	0.36	3701.	
2038	155.0	572.28	24.84	13.39	38.23	0.10052	0.33	3701.	
SUMMARY	155.0	577.21	24.84	13.51	38.35	9.91461	383.70	3733.	

*** RESULTS OF THE CASE HML= 145,000 INSTALLED CAPACITY= 155,0 STORED IN DISK FILE A1018*02 NO. 4

*** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR ***

YEAR	INFLOW (CMS)	EVAPORATION (CMS)	SPILL (CMS)	Q24 (CMS)	OG (CMS)	S2 (CMS)	R, W, L.	T, H, L.	E, HEAD EFFICI.	POWER (MW)	O, HOUR (H)	P, E. (GWH)	S, E. (GWH)	T, E. (GWH)
1989	100.74	0.64	10.67	89.42	197.36	303.12	143.17	41,000	98.030	154.5	4229.1	248.63	405.90	654.52
1994	84.124	0.63	4.36	79.25	190.18	287.16	141.845	41,000	96.620	154.4	3701.2	330.59	241.90	572.28

*** DEPENDABLE DISCHARGE / POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MW)	E (GWH)	DEPENDABLE Q (CMS)	P (MW)	E (GWH)	DEPENDABLE Q (CMS)	P (MW)	E (GWH)
1989	33.22	119.23	20.72	33.71	155.00	20.72	35.24	155.00	20.72
1994	44.107	118.194	27.53	44.64	155.00	27.53	45.49	155.00	27.53

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-1 KANAN HWL 300 NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 145,000 LOW WATER LEVEL IN METER 114,000 RATED HEAD IN METER 31,000 82,600
 INSTALLED CAPACITY IN MW 155,000 DEPENDABLE CAPACITY IN MW 116,326 TARGET OPERATION HOUR A DAY 4.31
 RATED DISCHARGE IN CMS 222,652 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN, FEB, MAR, APR, MAY, JUNE, JULY, AUG, SEP, OCT, NOV, DEC,
 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719 20,719

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1989 ***

MONTH	INFLOW (CMS)	EVAPOR (CMS)	SPILL (CMS)	G24 (CMS)	OG (CMS)	S2 (MCM)	R.W.L. (M)	T.W.L. (M)	E-HEAD EFFICI.	POWER (MW)	O. HOUR (H)	P.L.E. (GMH)	S.L.E. (GMH)	T.L.E. (GMH)
JAN.	143,95	0,62	7,05	136,27	183,82	327,41	145,000	41,000	100,050	0,860	551,6	20,72	64,77	85,49
FEB.	99,15	0,81	0,	98,66	185,88	324,64	144,972	41,000	100,019	0,860	360,7	20,72	35,18	55,90
MAR.	72,95	0,93	0,	72,78	184,08	324,61	144,870	41,000	99,968	0,860	294,4	20,72	24,91	45,63
APR.	45,98	1,06	0,	48,32	184,93	315,54	144,464	41,000	99,461	0,860	188,4	20,72	8,49	29,21
MAY	40,56	0,86	0,	45,19	186,90	299,49	143,534	41,000	98,447	0,860	180,7	20,72	7,29	28,00
JUNE	39,60	0,61	0,	46,06	190,07	281,16	142,156	41,000	96,924	0,860	175,8	20,72	6,54	27,26
JULY	46,93	0,48	3,90	51,56	193,88	251,91	140,315	41,000	94,912	0,860	201,3	20,72	10,40	31,12
AUG.	74,66	0,38	1,15	68,11	192,92	268,35	139,818	41,000	94,533	0,860	265,6	20,72	20,57	41,29
SEP.	82,15	0,50	0,	75,28	190,95	289,86	140,695	41,000	95,418	0,860	152,9	20,72	25,78	44,50
OCT.	140,51	0,50	14,50	117,10	187,30	303,40	142,704	41,000	97,705	0,860	470,9	20,72	52,08	72,80
NOV.	198,28	0,47	36,65	155,68	185,48	323,59	144,083	41,000	99,106	0,860	603,4	20,72	73,54	94,26
DEC.	224,28	0,52	63,66	157,92	183,85	321,41	144,944	41,000	100,037	0,860	632,1	20,72	78,34	99,04
MEAN	100,74	0,64	10,67	89,42	187,36	303,12	143,117	41,000	98,030	0,860	422,1	248,63	405,90	634,92

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***

THESE DEFICITS OCCURED 2 TIMES

LONGEST DURATION FROM 20-TH YEAR 7-TH MONTH TO 20-TH YEAR 11-TH MONTH

LOWEST POWER 119,2 MW

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR (CMS)	SPILL (CMS)	G24 (CMS)	OG (CMS)	S2 (MCM)	R.W.L. (M)	T.W.L. (M)	E-HEAD EFFICI.	POWER (MW)	O. HOUR (H)	P.L.E. (GMH)	S.L.E. (GMH)	T.L.E. (GMH)
JAN.	131,23	0,62	4,46	124,63	185,08	322,23	144,437	41,000	99,430	0,860	503,2	27,53	50,47	78,00
FEB.	97,19	0,80	0,	97,11	184,83	320,48	144,537	41,000	99,541	0,860	351,1	27,53	27,35	54,88
MAR.	72,36	0,92	0,	74,05	185,51	315,49	144,212	41,000	99,183	0,860	290,1	27,53	18,67	46,20
APR.	47,94	1,04	0,	53,23	187,37	297,08	143,335	41,000	98,224	0,860	205,1	27,53	4,25	31,78
MAY	45,08	0,84	0,	51,29	190,28	278,20	142,008	41,000	96,745	0,860	201,4	27,53	3,68	31,21
JUNE	45,74	0,59	0,	53,76	194,19	255,88	140,332	41,000	94,988	0,860	200,5	27,53	3,55	31,58
JULY	50,41	0,46	0,	53,79	196,72	245,57	138,927	41,000	93,366	0,860	205,1	27,53	4,14	31,67
AUG.	60,31	0,37	0,	57,44	196,23	252,25	138,675	41,000	93,157	0,860	220,2	27,53	6,28	33,81
SEP.	60,89	0,48	0,	58,17	194,77	257,52	139,080	41,000	93,627	0,860	216,9	27,53	5,64	33,17
OCT.	85,91	0,48	3,73	72,58	192,21	281,94	140,387	41,000	95,089	0,860	285,2	27,53	16,32	43,85
NOV.	133,39	0,46	5,84	118,06	188,30	305,35	142,502	41,000	97,460	0,860	457,5	27,53	40,22	70,75
DEC.	180,31	0,51	37,51	137,51	186,34	318,14	143,896	41,000	98,899	0,860	551,0	27,53	58,34	85,87
MEAN	84,24	0,63	4,36	79,25	190,18	287,16	141,845	41,000	96,620	0,860	370,2	330,38	241,90	572,28

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***

THESE DEFICITS OCCURED 2 TIMES

LONGEST DURATION FROM 21-TH YEAR 6-TH MONTH TO 21-TH YEAR 10-TH MONTH

LOWEST POWER 118,9 MW

NIPPON KOEI

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.F. PROJECT

TABLE OF AVERAGE MONTHLY DISCHARGE OF THE TARGET YEAR 1987 (UNIT : C.M.S.)

MONTH	KALAWA RIVER		LOWER KALAWA		SUB TOTAL		KAWAN RIVER		LOWER KAWAN		SUB TOTAL		AGOS NO.1 DAM	
	PICOREM DAM-SITE INFLOW	SUPPLY	SPILL	SUPPLY	INFLOW	SPILL	INFLOW	SPILL	INFLOW	SPILL	INFLOW	SPILL	NATURAL AVAILA.	K(CJ)
JAN.	1.77	1.77	12.31	15.23	28.04	68.55	0.	68.55	31.24	120.79	151.49	148.85	0.87230	
FEB.	6.61	1.77	3.72	9.25	12.97	66.23	0.	66.23	23.10	89.33	105.19	105.30	0.86258	
MAR.	3.55	1.77	0.92	6.18	7.17	49.50	0.	49.50	17.27	66.77	76.50	73.94	0.86596	
APR.	2.64	1.77	0.79	4.09	4.38	30.99	0.	30.99	10.80	41.79	48.52	46.17	0.81251	
MAY	3.02	1.77	0.55	3.93	4.48	26.79	0.	26.79	9.34	34.13	43.08	40.61	0.80266	
JUNE	5.66	1.77	2.24	5.20	7.44	25.11	0.	25.11	8.76	33.87	44.73	41.31	0.85191	
JULY	55.33	1.77	31.64	16.64	51.08	8.20	0.	8.20	3.10	12.00	66.92	63.08	0.80932	
AUG.	48.88	1.77	46.51	26.81	73.32	7.98	0.	7.98	2.78	10.76	86.45	84.08	0.90291	
SEP.	44.47	1.77	41.93	25.07	67.00	15.34	0.	15.34	5.35	20.71	90.25	87.21	0.90382	
OCT.	37.57	1.77	35.06	25.50	60.56	62.91	0.	62.91	21.93	84.84	147.91	145.40	0.87368	
NOV.	50.53	1.77	48.07	38.70	82.77	82.27	0.	82.27	31.13	120.40	205.63	203.17	0.90302	
DEC.	58.77	1.77	56.26	39.90	96.16	98.61	0.	98.61	34.40	133.01	231.68	229.17	0.90016	
TOTAL	312.00	21.22	279.36	216.00	495.36	571.20	0.	571.20	199.20	770.40	1298.60	1265.74	0.28364	
MEAN	26.00	1.77	23.28	18.00	41.28	47.60	0.	47.60	16.60	64.20	108.20	105.48	0.85697	

*** VOLUME USED FROM INITIAL STORAGE IN C.M.S. MONTH
 PICOREM DAM 0.
 KAWAN NO.2 DAM 0.

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT NIPPON KOGI
 TABLE OF AVERAGE MONTHLY DISCHARGE OF THE TARGET YEAR 1989 (UNIT C.M.S.)

MONTH	KALIMA RIVER		KALIMA RIVER		KANAN RIVER		AGOS NO.1 DAM	
	INFLOW	SUPPLY	SPILL	LOWER	TOTAL	INFLOW	SUB	AGOS NO.1 DAM
JAN.	14.27	6.66	7.43	15.73	23.16	89.55	0.	143.95
FEB.	6.91	6.66	0.57	9.25	9.82	66.23	0.	98.15
MAR.	3.55	6.66	0.	6.18	6.18	49.50	0.	75.95
APR.	2.64	6.66	0.	4.09	4.09	30.99	0.	45.88
MAY	3.02	6.66	0.	3.23	3.23	26.79	0.	40.66
JUNE	5.66	6.66	0.53	5.20	5.73	25.11	0.	38.60
JULY	35.33	6.66	14.39	19.64	19.64	8.20	0.	46.03
AUG.	48.88	6.66	37.09	26.81	63.90	7.98	0.	74.66
SEP.	44.47	6.66	36.37	25.07	61.44	15.36	0.	82.15
OCT.	37.57	6.66	30.17	25.50	55.67	62.91	0.	147.91
NOV.	50.53	6.66	43.18	36.70	71.88	89.27	0.	198.28
DEC.	58.77	6.66	51.37	39.90	91.27	98.61	0.	231.68
TOTAL	312.00	79.87	221.10	216.00	437.10	571.20	0.	1207.50
MEAN	26.00	6.66	18.42	18.00	36.42	47.60	0.	100.62

*** VOLUME USED FROM INITIAL STORAGE IN C.M.S. MONTH
 PICOREM DAM 0.
 KANAN NO.2 DAM 0.

NIPPON KOEI

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT

TABLE OF AVERAGE MONTHLY DISCHARGE OF THE TARGET YEAR 1994 (UNIT C.M.S.)

MONTH	KALIIWA RIVER		KALIIWA RIVER		KALIIWA RIVER		KALIIWA RIVER		KALIIWA RIVER		KALIIWA RIVER		KALIIWA RIVER		KALIIWA RIVER		KALIIWA RIVER	
	INFLOW	SUPPLY	SPILL	SUB	INFLOW	SUPPLY	SPILL	SUB	INFLOW	SUPPLY	SPILL	SUB	INFLOW	SUPPLY	SPILL	SUB	INFLOW	SUPPLY
JAN.	14.97	22.98	0.	15.73	15.73	89.55	1.46	87.24	31.24	118.48	151.49	134.21	0.79116					
FEB.	6.61	22.98	0.	9.25	9.25	66.23	1.46	63.97	23.10	86.77	105.19	96.02	0.82843					
MAR.	3.53	22.98	0.	6.18	6.18	52.50	1.46	46.77	17.27	58.04	76.50	70.22	0.62051					
APR.	2.64	21.77	0.	4.09	4.09	30.99	1.46	28.07	10.80	38.87	48.52	42.96	0.75598					
MAY	3.02	19.97	0.	3.93	3.93	26.79	1.46	24.13	2.34	33.47	43.08	37.40	0.73892					
JUNE	2.66	19.46	0.	3.20	3.20	25.11	1.46	22.77	8.76	31.53	44.73	36.73	0.66862					
JULY	35.33	22.37	0.39	19.64	20.03	8.90	1.46	6.73	3.10	9.83	64.92	29.87	0.38321					
AUG.	48.88	22.64	3.36	26.81	30.17	7.98	1.46	5.96	2.78	8.74	86.45	38.90	0.41776					
SEP.	44.47	22.98	1.41	25.02	26.48	15.16	1.46	13.17	5.35	18.52	96.25	45.00	0.46310					
OCT.	37.57	22.98	3.93	25.50	29.43	62.91	1.46	60.74	21.93	82.67	147.91	112.11	0.67366					
NOV.	50.53	22.98	7.44	34.70	52.14	89.27	1.46	82.15	31.13	113.28	205.63	140.42	0.71303					
DEC.	58.77	22.98	19.06	39.90	58.96	98.61	1.46	96.44	34.40	130.84	231.68	189.81	0.74557					
TOTAL	312.00	267.11	35.59	216.00	251.59	571.20	17.47	542.86	199.20	742.06	1298.40	993.65	8.00059					
MEAN	26.00	22.26	2.97	18.00	20.97	47.60	1.46	45.24	16.60	61.84	108.20	82.80	0.66672					

*** VOLUME USED FROM INITIAL STORAGE IN C.M.S. MONTH

PICOREM DAM 0.
KANAN NO.2 DAM 0.

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.A.E. PROJECT NIPPON KOEI

TABLE OF AVERAGE MONTHLY DISCHARGE OF THE TARGET YEAR 2000 (UNIT: C.M.S.)

MONTH	PICOREM DAM-SITE		KALIMA RIVER		SUB		KANAN RIVER		LOWER KANAN		SUB		AGOS NO.1 DAM	
	INFLOW	SUPPLY	SPILL	KALIMA	LOWER	SUB	TOTAL	INFLOW	SUBELT	SRILL	KANAN	TOTAL	NATURAL	AVAILA
JAN.	16.97	22.98	0.	15.73	15.73	89.55	23.50	63.00	31.24	94.24	151.49	109.97	0.64824	
FEB.	6.61	22.98	0.	9.25	66.23	23.50	41.73	23.10	64.83	105.19	74.08	0.63916		
MAR.	3.55	22.98	0.	6.18	42.50	23.50	25.48	17.27	62.73	76.50	48.51	0.52148		
APR.	2.64	21.77	0.	4.09	30.99	23.50	8.63	10.80	19.43	48.52	23.52	0.41393		
MAY	3.02	19.97	0.	3.93	26.79	23.50	6.92	9.34	16.33	43.08	20.24	0.40029		
JUNE	5.66	19.46	0.	5.20	25.11	23.50	5.72	8.76	14.48	44.73	19.88	0.35819		
JULY	35.33	22.37	0.39	19.64	20.03	8.90	23.50	0.69	3.10	3.79	66.97	23.83	0.30571	
AUG.	48.88	22.64	3.36	26.81	30.17	7.98	23.50	0.	2.78	2.78	86.45	32.95	0.35380	
SEP.	44.47	22.98	1.41	25.07	26.58	15.36	23.51	0.	5.35	5.35	90.25	31.83	0.32298	
OCT.	37.57	22.98	3.93	25.50	20.63	62.91	23.50	11.21	21.93	33.14	147.91	62.57	0.37600	
NOV.	50.53	22.98	7.44	34.70	52.74	89.27	23.50	46.81	31.13	77.94	205.63	120.07	0.53369	
DEC.	58.77	22.98	19.06	39.90	58.96	98.61	23.50	68.20	34.40	102.60	231.68	161.56	0.63462	
TOTAL	312.00	267.11	35.59	216.00	251.59	571.20	281.85	278.44	199.20	477.64	1298.40	729.23	5.56309	
MEAN	26.00	22.26	2.97	18.00	20.97	47.60	23.49	23.20	16.60	39.80	108.20	60.77	0.46359	

*** VOLUME USED FROM INITIAL STORAGE IN C.M.S. MONTH
 PICOREM DAM 0.
 KANAN NO.2 DAM 0.

NIPPON KOEI

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT

TABLE OF AVERAGE MONTHLY DISCHARGE OF THE TARGET YEAR 2005 (UNIT: C.M.S.)

MONTH	PICOREM DAM-SITE			KALIMA RIVER			KAMAN RIVER			AGOS NO.1 DAM			
	INFLOW	SUPPLY	SPILL	LOWER	SUR	TOTAL	LOWER	SUR	TOTAL	LOWER	SUR	TOTAL	
JAN.	16.97	22.98	0.	15.73	15.73	89.55	33.07	51.35	31.24	82.59	151.69	98.32	0.57959
FEB.	6.61	22.98	0.	9.25	9.25	66.23	33.07	32.27	23.10	55.37	105.19	64.62	0.55752
MAR.	3.55	22.98	0.	6.18	6.18	49.50	33.07	18.50	17.27	35.77	76.50	41.95	0.49020
APR.	2.64	21.77	0.	4.09	4.09	30.99	32.97	4.17	10.80	14.97	48.22	19.06	0.33443
MAY	3.02	19.97	0.	3.93	3.93	28.79	32.12	3.32	9.34	12.66	43.05	16.59	0.32787
JUNE	5.66	19.46	0.	5.20	5.20	25.11	32.02	2.97	8.76	11.73	44.73	16.93	0.30816
JULY	35.33	22.32	0.	19.64	20.03	8.90	31.14	0.	3.10	3.10	66.97	23.13	0.29680
AUG.	48.88	22.64	3.36	26.81	30.17	7.98	26.38	0.	2.78	2.78	86.45	32.95	0.35380
SEP.	44.47	22.98	1.41	25.07	26.48	13.16	23.22	0.	5.35	5.35	90.23	31.83	0.32398
OCT.	37.57	22.98	3.93	25.50	29.43	62.91	32.26	2.00	21.93	23.99	147.91	53.42	0.32101
NOV.	50.53	22.98	7.44	34.70	42.14	89.27	33.07	19.44	31.13	50.57	205.63	92.70	0.41204
DEC.	58.77	22.98	19.06	39.90	58.96	98.61	33.07	51.22	34.40	85.62	231.68	144.58	0.56793
TOTAL	312.00	267.11	35.99	216.00	251.59	571.20	375.49	185.31	199.20	384.51	1298.40	636.10	4.87834
MEAN	26.00	22.26	3.00	18.00	20.97	47.60	31.29	15.44	16.60	32.04	108.20	53.01	0.40653

*** VOLUME USED FROM INITIAL STORAGE IN C.M.S. MONTH

PICOREM DAM 0
KAMAN NO.2 DAM 0

NIPPON KOEI

ESTIMATION OF DISCHARGE SERIES OF AGOS RIVER SYSTEM FOR AGOS H.E. PROJECT

TABLE OF AVERAGE MONTHLY DISCHARGE OF THE TARGET YEAR 2009 (UNIT: C.M.S.)

MONTH	PICOREM DAM-SITE		KALIMA RIVER		KANAWA RIVER		KANAN NO.2 DAM		KANAN		AGOS NO.1 DAM			
	INFLOW	SUPPLY	SPILL	LOWER	SUR	TOTAL	INFLOW	SUBRFLY	SPILL	LOWER	SUR	TOTAL NATURAL AVAILABLE		
JAN.	14.97	22.98	0.	15.73	15.73	15.73	89.55	38.17	43.55	31.24	74.79	151.79	90.52	0.53344
FEB.	6.01	22.98	0.	9.25	9.25	66.23	38.17	27.31	23.10	50.41	105.19	59.66	0.51486	
MAR.	3.55	22.98	0.	6.18	6.18	43.50	37.49	15.21	17.22	32.98	76.50	59.46	0.45763	
APR.	2.64	21.77	0.	4.09	4.09	30.99	37.27	2.98	10.80	13.78	48.52	17.87	0.31453	
MAY	3.02	19.97	0.	3.93	3.93	26.79	32.02	2.54	9.34	11.88	43.08	15.81	0.34273	
JUNE	5.66	19.46	0.	5.30	5.30	25.11	36.52	2.71	8.76	11.47	44.75	16.67	0.30345	
JULY	35.33	22.37	0.39	19.84	20.03	8.20	31.79	0.	3.10	3.10	66.92	23.33	0.29650	
AUG.	43.88	22.64	3.36	26.81	30.17	7.98	21.37	0.	2.78	2.78	86.45	32.95	0.35380	
SEP.	44.47	22.98	1.41	25.07	26.48	15.36	19.66	0.	5.35	5.35	90.25	31.83	0.32798	
OCT.	37.57	22.98	3.93	25.50	29.43	62.91	35.93	1.16	21.93	23.09	107.91	52.53	0.31564	
NOV.	50.53	22.98	7.44	34.70	42.14	83.27	38.17	18.72	31.13	41.92	205.63	84.08	0.37303	
DEC.	50.77	22.98	19.06	39.80	58.86	98.61	57.91	43.05	33.40	79.45	231.68	138.41	0.54369	
TOTAL	312.00	267.11	35.59	216.00	251.59	571.20	609.65	151.81	199.20	351.01	1298.40	602.61	4.64786	
MEAN	26.00	22.26	2.97	18.00	20.97	47.60	51.14	12.65	16.60	29.25	108.20	50.22	0.38232	

*** VOLUME USED FROM INITIAL STORAGE IN C.M.S/MONTH
 PICOREM DAM 0.
 KANAN NO.2 DAM 0.

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-2 KAHAN HVL 295 NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 175.000 LOW WATER LEVEL IN METER 155.000 RATED HEAD IN METER ***** 108.000
 INSTALLED CAPACITY IN MW 152.000 DEPENDABLE CAPACITY IN MW 117.209 TARGET OPERATION HOUR A DAY 8.22
 RATED DISCHARGE IN CMS 160.992 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MWH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN 95.0
 O-HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	ENERGY (M US D)	TOTAL (M US D)	BENEFIT ENERGY (M US D)	P.W.F.	PRESENT OPERATION WORTH (M US D)	OPERATION HOUR (H)
1989	152.0	72.92	24.36	18.09	42.44	0.90909	38.59	5095	
1990	152.0	73.70	24.36	17.64	41.99	0.82645	34.71	4969	
1991	152.0	73.48	24.36	17.19	41.54	0.75151	31.21	4843	
1992	152.0	715.26	24.36	16.74	41.10	0.68301	28.07	4717	
1993	152.0	696.04	24.36	16.29	40.65	0.62092	25.24	4590	
1994	152.0	676.82	24.36	15.84	40.20	0.56447	22.69	4464	
1995	152.0	648.70	24.36	15.48	39.54	0.51316	20.52	4279	
1996	152.0	620.57	24.36	14.52	38.88	0.46651	18.14	4093	
1997	152.0	592.44	24.36	13.86	38.22	0.42510	16.21	3907	
1998	152.0	564.31	24.36	13.20	37.56	0.38554	14.48	3722	
1999	152.0	536.18	24.36	12.55	36.90	0.35049	12.93	3536	
2000	152.0	508.05	24.36	11.89	36.25	0.31863	11.55	3350	
2001	152.0	496.74	24.36	11.61	35.97	0.28968	10.42	3272	
2002	152.0	484.42	24.36	11.44	35.69	0.26353	9.40	3194	
2003	152.0	472.60	24.36	11.06	35.42	0.23939	8.48	3116	
2004	152.0	460.79	24.36	10.78	35.14	0.21743	7.65	3038	
2005	152.0	448.97	24.36	10.51	34.86	0.19784	6.90	2960	
2006	152.0	443.67	24.36	10.38	34.74	0.17986	6.25	2925	
2007	152.0	438.37	24.36	10.26	34.62	0.16351	5.66	2890	
2008	152.0	433.06	24.36	10.13	34.49	0.14864	5.13	2855	
2009	152.0	427.76	24.36	10.01	34.37	0.13513	4.64	2820	
2010	152.0	427.76	24.36	10.01	34.37	0.12285	4.22	2820	
2037	152.0	427.76	24.36	10.01	34.37	0.00937	0.32	2820	
2038	152.0	427.76	24.36	10.01	34.37	0.00852	0.29	2820	
SUMMARY	152.0	486.61	24.36	11.39	35.74	9.91481	362.14	3208	

*** RESULTS OF THE CASE HULE 175.000 INSTALLED CAPACITY 152.0 STORED IN DISK FILE A1818-02 NO. 1

NIPPON KOEI TOKYO/JAPAN

DAM ** PLAN A-2 KAVAN HWL 295

** RESERVOIR OPERATION STUDY OF AGOS

HIGH WATER LEVEL IN METER 175.000 LOW WATER LEVEL IN METER 135.000 RATED HEAD IN METER 108.000
 INSTALLED CAPACITY IN MW 152.000 DEPENDABLE CAPACITY IN MW 117.209 TARGET OPERATION HOUR-A-DAY 8.22
 RATED DISCHARGE IN CMS 166.992 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MW 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750
 JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750 38.750

LENGTH OF INFLOW SERIES IN YEAR 26

*** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR ***

YEAR	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	Q24 (CMS)	QG (CMS)	S2 (CMS)	R.W.L. (CM)	T.W.L. (CM)	E-HEAD EFFICI. (CM)	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)	
1989	100.74	1.09	18.52	81.13	141.07	605.85	171.273	39.299	127.826	0.860	151.6	5095.2	465.00	307.92	772.92
1994	82.82	1.08	10.29	71.45	142.12	585.31	170.319	39.272	126.869	0.860	151.5	4464.3	420.75	254.02	474.82
2000	68.79	1.07	6.32	53.40	142.09	583.07	170.233	39.255	126.785	0.860	151.4	3350.2	262.88	243.18	508.05
2005	53.05	1.06	4.63	47.36	142.70	574.81	169.829	39.250	126.337	0.860	151.5	2960.2	248.63	200.35	448.92
2009	50.28	1.06	4.02	45.20	142.96	571.09	169.662	39.249	126.153	0.860	151.5	2820.1	245.25	182.51	427.76

*** DEPENDABLE DISCHARGE * POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	100.0 % DEPENDABLE P (MW)	100.0 % DEPENDABLE Q (CMS)	95.0 % DEPENDABLE P (MW)	95.0 % DEPENDABLE Q (CMS)	90.0 % DEPENDABLE P (MW)	90.0 % DEPENDABLE Q (CMS)	85.0 % DEPENDABLE P (MW)	85.0 % DEPENDABLE Q (CMS)	80.0 % DEPENDABLE P (MW)	80.0 % DEPENDABLE Q (CMS)
1989	46.87	120.17	38.75	47.36	48.25	38.75	48.74	38.75	49.58	38.75
1994	42.40	119.89	35.06	42.61	43.52	35.06	44.01	35.06	44.43	35.06
2000	26.51	117.93	21.91	26.73	22.29	21.91	22.31	21.91	22.71	21.91
2005	25.08	117.88	20.72	25.28	23.65	20.72	26.04	20.72	26.19	20.72
2009	24.77	117.46	20.44	24.99	23.41	20.44	25.67	20.44	25.82	20.44

NIPPON KOEI TOKYO/JAPAN

DAM ** PLAN A-2 KANAN HML 295

** RESERVOIR OPERATION STUDY OF AGOS

HIGH WATER LEVEL IN METER 165.000 LOW WATER LEVEL IN METER 126.000 RATED HEAD IN METER 99.000
 INSTALLED CAPACITY IN MW 140.000 DEPENDABLE CAPACITY IN MW 108.044 TARGET OPERATION HOUR-A-DAY 7.32
 RATED DISCHARGE IN CMS 167.791 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781

LENGTH OF INFLOW SERIES IN YEAR 26

** BENEFIT CALCULATION **

DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0
 O. HOUR / YEAR KW VALUE IN US. D KWH VALUE IN US. D
 2550.0 160.25 0.0234
 1950.0 113.76 0.0425
 0. 0. 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	BENEFIT ENERGY (M US D)	TOTAL (M US D)	R.M.F.	PRESENT OPERATION MONTH (M US D)	HOUR (H)
1989	140.0	211.48	22.43	16.65	39.08	0.90909	35.53	5091
1990	140.0	694.05	22.43	16.24	38.68	0.82645	31.96	4966
1991	140.0	676.61	22.43	15.83	38.27	0.75131	28.75	4841
1992	140.0	659.18	22.43	15.42	37.86	0.68301	25.86	4716
1993	140.0	641.74	22.43	15.02	37.45	0.62092	23.25	4591
1994	140.0	624.31	22.43	14.61	37.04	0.56447	20.91	4466
1995	140.0	598.53	22.43	14.01	36.44	0.51316	18.70	4282
1996	140.0	572.74	22.43	13.40	35.84	0.46651	16.72	4098
1997	140.0	546.96	22.43	12.80	35.23	0.42430	14.94	3914
1998	140.0	521.18	22.43	12.20	34.63	0.38554	13.35	3730
1999	140.0	495.39	22.43	11.59	34.03	0.35049	11.93	3546
2000	140.0	469.61	22.43	10.99	33.42	0.31863	10.65	3362
2001	140.0	458.85	22.43	10.74	33.17	0.28986	9.61	3285
2002	140.0	448.10	22.43	10.49	32.92	0.26333	8.67	3208
2003	140.0	437.34	22.43	10.23	32.67	0.23939	7.82	3131
2004	140.0	426.59	22.43	9.98	32.42	0.21763	7.05	3054
2005	140.0	415.83	22.43	9.73	32.17	0.19786	6.36	2976
2006	140.0	411.02	22.43	9.62	32.03	0.17984	5.72	2942
2007	140.0	406.35	22.43	9.51	31.94	0.16351	5.22	2908
2008	140.0	401.60	22.43	9.40	31.83	0.14864	4.73	2874
2009	140.0	396.86	22.43	9.29	31.72	0.13513	4.29	2840
2010	140.0	396.86	22.43	9.29	31.72	0.12285	3.90	2840
2037	140.0	396.86	22.43	9.29	31.72	0.00937	0.30	2840
2038	140.0	396.86	22.43	9.29	31.72	0.00852	0.27	2840
SUMMARY	140.0	450.47	22.43	10.54	32.98	9.91481	352.24	3224

*** RESULTS OF THE CASE HML= 165.000 INSTALLED CAPACITY= 140.0 STORED IN DISK FILE A1818-02 NO. 4

NIPPON KOEI TOKYO/JAPAN

DAM ** PLAN A-2 KAHAN HWL 295

** RESERVOIR OPERATION STUDY OF AGOS

HIGH WATER LEVEL IN METER 165.000 LOW WATER LEVEL IN METER 128.000 RATED HEAD IN METER ***** 99.000
 INSTALLED CAPACITY IN MW 140.000 DEPENDABLE CAPACITY IN MW 108.944 TARGET OPERATION HOUR A DAY 7.32
 RATED DISCHARGE IN CMS 167.791 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MWH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781 31.781

LENGTH OF INFLOW SERIES IN YEAR 26

*** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR ***

YEAR	INFLOW (CMS)	EVAP. (CMS)	SPILL (CMS)	Q24 (CMS)	Q6 (CMS)	S2 (CMS)	R.W.L. (M)	T.W.L. (M)	E HEAD EFFICI. (%)	POWER (MW)	O HOUR (HR)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)	
1989	100.74	0.92	19.39	80.43	139.94	485.73	162.010	39.297	118.663	0.860	139.6	5091.2	381.38	330.11	711.48
1994	82.82	0.92	11.18	70.73	140.58	472.84	161.588	39.268	118.221	0.860	139.7	4464.1	341.63	282.68	624.31
2000	60.79	0.90	6.79	53.41	141.07	455.37	160.324	39.255	118.903	0.860	139.4	3362.1	228.00	241.61	469.61
2005	53.05	0.89	4.76	42.41	142.37	451.53	160.108	39.249	119.652	0.860	139.5	2928.4	215.23	200.58	415.83
2009	50.28	0.89	4.12	45.27	142.42	451.54	160.129	39.247	119.670	0.860	139.6	2839.8	212.25	184.61	390.86

*** DEPENDABLE DISCHARGE / POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MW)	% DEPENDABLE	E (GWH)	Q (CMS)	P (MW)	% DEPENDABLE	E (GWH)	Q (CMS)	P (MW)	% DEPENDABLE	E (GWH)			
1989	41.58	110.55	31.78	42.14	140.00	31.78	43.12	140.00	31.78	53.83	140.00	31.78	44.23	140.00	31.78
1994	37.25	111.37	28.47	37.59	140.00	28.47	38.63	140.00	28.47	39.10	140.00	28.47	39.10	140.00	28.47
2000	24.89	110.09	19.00	25.15	140.00	19.00	25.63	140.00	19.00	25.81	140.00	19.00	26.15	140.00	19.00
2005	23.54	110.54	17.94	23.82	140.00	17.94	24.30	140.00	17.94	24.64	140.00	17.94	24.67	140.00	17.94
2009	23.15	110.36	17.89	23.42	140.00	17.89	23.89	140.00	17.89	24.07	140.00	17.89	24.26	140.00	17.89

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-2 KAMAN HWL 295 NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 155.000 LOW WATER LEVEL IN METER 121.000 RATED HEAD IN METER 91.000
 INSTALLED CAPACITY IN MW 128.000 DEPENDABLE CAPACITY IN MW 99.312 TARGET OPERATION HOUR / DAY 4.58
 RATED DISCHARGE IN CMS 106.895 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 JAN. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 RULE CURVE IN MWH 26,125 26,125 26,125 26,125 26,125 26,125 26,125 26,125 26,125 26,125 26,125

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 90.0
 0. HOUR / YEAR KW VALUE IN US \$ KWH VALUE IN US \$
 2550.0 160.25 0.0234
 1950.0 111.74 0.0425
 0. 63.55 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	ANNUAL POWER (M US \$)	BENEFIT ENERGY (M US \$)	TOTAL (M US \$)	P.W.F.	PRESENT OPERATION WORTH (M US \$)	OPERATION HOUR (H)
1989	128.0	651.80	20.51	13.25	33.76	0.30809	12.51	5102
1990	128.0	635.99	20.51	14.88	35.39	0.82645	29.25	4978
1991	128.0	620.17	20.51	14.51	35.02	0.75131	26.31	4853
1992	128.0	604.36	20.51	14.16	34.65	0.68301	23.57	4729
1993	128.0	588.55	20.51	13.77	34.28	0.62092	21.29	4605
1994	128.0	572.73	20.51	13.40	33.91	0.56447	19.14	4481
1995	128.0	556.93	20.51	12.85	33.36	0.51316	17.12	4296
1996	128.0	541.12	20.51	12.29	32.80	0.46651	15.30	4110
1997	128.0	525.32	20.51	11.74	32.25	0.42410	13.68	3925
1998	128.0	477.91	20.51	11.18	31.70	0.38554	12.22	3740
1999	128.0	454.20	20.51	10.63	31.14	0.35049	10.91	3554
2000	128.0	430.49	20.51	10.07	30.58	0.31863	9.52	3362
2001	128.0	406.78	20.51	9.84	30.36	0.28966	8.79	3193
2002	128.0	410.85	20.51	9.61	30.13	0.26333	7.93	3017
2003	128.0	401.03	20.51	9.38	29.90	0.23939	7.16	2840
2004	128.0	391.21	20.51	9.15	29.67	0.21763	6.46	2664
2005	128.0	381.39	20.51	8.92	29.44	0.19784	5.82	2488
2006	128.0	371.20	20.51	8.83	29.34	0.17986	5.28	2312
2007	128.0	375.00	20.51	8.73	29.24	0.16351	4.78	2136
2008	128.0	369.80	20.51	8.63	29.14	0.14864	4.33	1960
2009	128.0	364.60	20.51	8.53	29.04	0.13513	3.92	1784
2010	128.0	364.60	20.51	8.53	29.04	0.12285	3.57	1608
2037	128.0	364.60	20.51	8.53	29.04	0.00937	0.27	2854
2038	128.0	364.60	20.51	8.53	29.04	0.00852	0.25	2854
SUMMARY	128.0	413.49	20.51	9.68	30.19	9.91481	322.61	3237

*** RESULTS OF THE CASE HWL 155.000 INSTALLED CAPACITY 128.0 STORED IN DISK FILE A1818-02.NO. 7

** RESERVOIR OPERATION STUDY OF AGOS DAM ** PLAN A-2 KANAN HWL 295 NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 155.000 LOW WATER LEVEL IN METER 121.000 RATED HEAD IN METER ***** 91.000
 INSTALLED CAPACITY IN MW 128.000 DEPENDABLE CAPACITY IN MW 99.312 TARGET OPERATION HOUR A DAY 6.58
 RATED DISCHARGE IN CMS 166.895 TYPE OF RULE CURVE ** VARIABLE MASS CURVE

RULE CURVE IN MW: JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 26.125 26.125 26.125 26.125 26.125 26.125 26.125 26.125 26.125 26.125 26.125 26.125

LENGTH OF INFLOW SERIES IN YEAR: 20

*** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR ***

YEAR	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	OG (CMS)	S2 (CMS)	R.W.L. (M)	T.W.L. (M)	E.HEAD EFFICI. (%)	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
1989	100.74	0.77	19.97	80.00	138.86	384.15	152.548	39.295	109.278	0.860	127.6	5101.7	313.50
1994	82.82	0.77	11.62	26.38	139.35	323.66	152.288	39.264	102.000	0.860	127.7	4484.1	228.25
2000	60.79	0.75	6.76	53.28	131.72	324.61	150.595	39.255	107.202	0.860	127.6	3369.1	195.75
2005	53.05	0.74	4.90	47.42	142.25	327.53	150.088	39.250	105.345	0.860	127.4	2988.0	186.75
2009	50.28	0.74	4.23	45.31	142.17	329.81	150.293	39.246	106.838	0.860	127.5	2854.2	184.13

*** DEPENDABLE DISCHARGE - POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE	Q (CMS)	P (MW)	E (GWH)
1989	37.23	99.62	28.12	17.73	128.00	26.13	39.10	128.00	26.13	39.82	128.00	26.13	39.82	128.00	26.13
1994	33.04	100.57	23.19	33.34	128.00	23.19	34.42	128.00	23.19	34.92	128.00	23.19	34.92	128.00	23.19
2000	23.25	100.71	16.31	23.51	128.00	16.31	24.27	128.00	16.31	24.54	128.00	16.31	24.54	128.00	16.31
2005	22.30	101.60	15.56	22.43	128.00	15.56	23.16	128.00	15.56	23.44	128.00	15.56	23.44	128.00	15.56
2009	21.89	102.22	15.34	22.09	128.00	15.34	22.77	128.00	15.34	22.97	128.00	15.34	22.97	128.00	15.34

HIIPPON KOEI TOKYO/JAPAN

DAM ** PLAN A-2 KANAN HWL 295

** RESERVOIR OPERATION STUDY OF AGOS

HIGH WATER LEVEL IN METER 145.000 LOW WATER LEVEL IN METER 114.000 RATED HEAD IN METER 82.500
 INSTALLED CAPACITY IN MW 116.000 DEPENDABLE CAPACITY IN MW 90.368 TARGET OPERATION HOUR-A-DAY 5.88
 RATED DISCHARGE IN CMS 166.832 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MW JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 90.0

0. HOUR / YEAR KW VALUE IN US D. KW.H. VALUE IN US D.
 2550.0 160.25
 3950.0 111.26
 0. 63.35

YEAR	DEPENDABLE ANNUAL		BENEFIT		TOTAL (M US D)	P.W.F.	PRESENT OPERATION	
	POWER (MW)	ENERGY (GWH)	ENERGY (M US D)	WORTH (M US D)			WORTH (M US D)	HOUR (CM)
1982	116.0	522.25	18.59	13.82	32.41	0.80909	22.51	5112
1990	116.0	578.46	18.59	13.54	32.12	0.82645	26.55	6993
1991	116.0	564.16	18.59	13.20	31.79	0.75131	23.88	4820
1992	116.0	509.87	18.59	12.87	31.46	0.68101	21.48	4747
1993	116.0	535.58	18.59	12.53	31.12	0.80092	19.52	4623
1994	116.0	521.29	18.59	12.20	30.79	0.56447	17.38	4500
1995	116.0	499.90	18.59	11.70	30.29	0.51316	15.54	4315
1996	116.0	478.52	18.59	11.20	29.79	0.46651	13.90	4131
1997	116.0	457.13	18.59	10.70	29.29	0.42410	12.42	3946
1998	116.0	435.74	18.59	10.20	28.79	0.38554	11.10	3761
1999	116.0	414.35	18.59	9.70	28.28	0.35049	9.91	3577
2000	116.0	392.96	18.59	9.20	27.78	0.31863	8.83	3392
2001	116.0	383.92	18.59	8.98	27.57	0.28966	7.99	3314
2002	116.0	374.89	18.59	8.77	27.36	0.26333	7.21	3237
2003	116.0	365.85	18.59	8.56	27.15	0.23939	6.50	3159
2004	116.0	356.81	18.59	8.35	26.94	0.21763	5.86	3082
2005	116.0	347.77	18.59	8.14	26.73	0.19784	5.29	3004
2006	116.0	338.93	18.59	8.05	26.64	0.17986	4.79	2921
2007	116.0	330.09	18.59	7.86	26.55	0.16351	4.34	2838
2008	116.0	321.25	18.59	7.67	26.46	0.14864	3.93	2803
2009	116.0	312.41	18.59	7.78	26.37	0.13513	3.56	2872
2010	116.0	303.57	18.59	7.78	26.37	0.12285	3.24	2872
2037	116.0	332.41	18.59	7.78	26.37	0.00937	0.25	2872
2038	116.0	332.41	18.59	7.78	26.37	0.00852	0.22	2872
SUMMARY	116.0	376.85	18.59	8.82	27.41	9.91481	292.71	3255

*** RESULTS OF THE CASE HULE 145.000...INSTALLED CAPACITIVE 116.0 SIGNED IN DISK FILE A1818-02-NO..10

NIPPON KOEI TOKYO/JAPAN

DAM ** PLAN A-2 KAVAN HWL 295

** RESERVOIR OPERATION STUDY OF AGOS

HIGH WATER LEVEL IN METER 145.000 LOW WATER LEVEL IN METER 114.000 RATED HEAD IN METER 82.500
 INSTALLED CAPACITY IN MW 110.000 DEPENDABLE CAPACITY IN MW 90.368 TARGET OPERATION HOUR A DAY 5.88
 RATED DISCHARGE IN CMS 166.832 TYPE OF RULE CURVE ** VARIABLE MASS CURVE

RULE CURVE IN MAH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156 21.156

LENGTH OF INFLOW SERIES IN YEAR 26

*** SUMMARY OF RESERVOIR OPERATION STUDY FOR EACH TARGET YEAR ***

YEAR	INFLW (CMS)	EVAPD (CMS)	SPILL (CMS)	O24 (CMS)	O6 (CMS)	S2 (CMS)	R.W.L. (CM)	T.W.L. (CM)	E. HEAD (CM)	EFFICI. (%)	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
1989	100.74	0.64	20.50	79.59	13.67	308.11	143.117	39.291	99.924	0.860	115.7	5116.6	253.88	338.87	592.75
1994	82.82	0.69	12.06	70.11	13.25	284.22	143.233	32.241	99.531	0.860	115.7	4500.1	227.25	294.04	521.29
2000	60.79	0.63	7.06	53.10	14.025	283.29	141.536	39.250	98.231	0.860	115.7	3391.9	156.38	236.59	392.96
2005	53.95	0.62	5.08	47.34	14.171	271.35	140.549	39.248	97.145	0.860	115.5	3094.2	154.38	191.39	347.77
2009	50.28	0.62	4.55	45.31	14.166	271.25	140.532	39.245	97.155	0.860	115.5	2872.4	155.25	177.16	332.41

*** DEPENDABLE DISCHARGE & POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MW)	% DEPENDABLE	E (GWH)	Q (CMS)	P (MW)	% DEPENDABLE	E (GWH)	Q (CMS)	P (MW)	% DEPENDABLE	E (GWH)
1989	33.26	92.59	21.16	116.00	21.16	34.55	116.00	21.16	33.25	116.00	21.16	30.56
1994	29.83	91.11	18.94	116.00	18.94	30.66	116.00	18.94	31.15	116.00	18.94	31.82
2000	20.41	81.58	13.03	116.00	13.03	21.18	116.00	13.03	21.34	116.00	13.03	21.64
2005	20.47	91.28	13.03	116.00	13.03	21.18	116.00	13.03	21.35	116.00	13.03	21.65
2009	20.22	92.89	12.94	116.00	12.94	20.97	116.00	12.94	21.37	116.00	12.94	21.50

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 TUL = 175,000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 300.000 LOW WATER LEVEL IN METER 270.000 RATED HEAD IN METER 106.200
 INSTALLED CAPACITY IN MW 138.000 DEPENDABLE CAPACITY IN MW 114.503 TARGET OPERATION HOUR A DAY 4.66
 RATED DISCHARGE IN CMS 154.181 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN. 19.938 FEB. 19.938 MAR. 19.938 APR. 19.938 MAY 19.938 JUNE 19.938 JULY 19.938 AUG. 19.938 SEP. 19.938 OCT. 19.938 NOV. 19.938 DEC. 19.938

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

0. HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2520.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	BENEFIT ENERGY (M US D)	TOTAL (M US D)	P.W.F. (M US D)	PRESENT WORTH (M US D)	OPERATION HOUR
1994	138.0	411.62	22.11	9.63	31.75	0.90909	28.86	2886.
1995	138.0	411.62	22.11	9.63	31.75	0.82645	26.24	2886.
2042	138.0	411.62	22.11	9.63	31.75	0.00937	0.30	2886.
2043	138.0	411.62	22.11	9.63	31.75	0.00852	0.27	2886.
SUMMARY	138.0	411.62	22.11	9.63	31.75	9.91481	314.76	2886.

NIPPON KOEI TOKYO/JAPAN

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 T.W.L = 175.000 **

HIGH WATER LEVEL IN METER 300.000 LOW WATER LEVEL IN METER 270.000 RATED HEAD IN METER ***** 106.200
 INSTALLED CAPACITY IN MW 138.000 DEPENDABLE CAPACITY IN MW 114.503 TARGET OPERATION HOUR A DAY 4.66
 RATED DISCHARGE IN CMS 154.181 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MWH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 19.938 19.938 19.938 19.938 19.938 19.938 19.938 19.938 19.938 19.938 19.938 19.938

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	Q24 (CMS)	GG (CMS)	S2 (CMS)	R.W.L. (M)	T.W.L. (M)	E-HEAD EFFICI. (%)	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	89.55	0.93	1.70	82.55	133.02	443.57	299.185	175.000	123.152	0.860	138.0	464.0	44.09	64.03
FEB.	66.23	1.21	0.	64.82	132.61	444.07	299.522	175.000	123.493	0.860	138.0	329.2	25.49	45.43
MAR.	49.50	1.40	0.	48.84	132.64	442.09	299.490	175.000	123.462	0.860	138.0	274.5	17.95	37.88
APR.	50.99	1.60	0.	52.89	132.94	433.02	299.220	175.000	123.188	0.860	138.0	178.4	4.68	24.61
MAY	26.79	1.30	0.	31.69	133.63	416.41	298.608	175.000	122.569	0.860	138.0	169.4	3.43	23.37
JUNE	25.11	0.93	0.	27.11	134.75	397.18	297.647	175.000	121.586	0.860	138.0	147.4	0.41	20.34
JULY	8.90	0.72	0.	27.27	140.10	293.26	292.968	175.000	116.800	0.860	137.7	144.8	0.	19.94
AUG.	7.98	0.54	0.	28.87	142.68	256.65	290.295	175.000	114.103	0.860	137.0	145.6	0.	19.94
SEP.	15.36	0.66	0.	34.06	141.07	330.37	291.500	175.000	115.512	0.860	137.0	181.7	4.97	24.91
OCT.	62.91	0.65	0.67	59.73	135.97	403.14	295.726	175.000	119.972	0.860	137.2	320.8	24.20	44.14
NOV.	89.27	0.66	0.80	80.98	134.06	431.86	298.200	175.000	122.276	0.860	137.9	453.9	42.69	62.62
DEC.	98.61	0.76	0.15	80.98	135.88	386.20	296.496	175.000	120.469	0.860	137.7	286.5	172.37	411.62
MEAN	47.53	0.94	0.79	45.80	135.88	386.20	296.496	175.000	120.469	0.860	137.7	286.5	172.37	411.62

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 5 CONTINUOUS MONTH ***

THESE DEFICITS OCCURRED 2 TIMES

LONGEST DURATION FROM 20-TH YEAR 8-TH MONTH TO 20-TH YEAR 12-TH MONTH

LOWEST POWER 116.4 MW

*** DEPENDABLE DISCHARGE , POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE
1994	25.67	116.39	19.94	25.84	138.00	19.94	26.19	138.00
1994	100.0	100.0	100.0	95.0	138.00	19.94	26.19	138.00
1994	100.0	100.0	100.0	90.0	138.00	19.94	26.19	138.00
1994	100.0	100.0	100.0	85.0	138.00	19.94	26.19	138.00
1994	100.0	100.0	100.0	80.0	138.00	19.94	26.19	138.00

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 TUL = 165,000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 300,000 LOW WATER LEVEL IN METER 270,000 RATED HEAD IN METER 116,200
 INSTALLED CAPACITY IN MW 149,000 DEPENDABLE CAPACITY IN MW 122,016 TARGET OPERATION HOUR A DAY 4.61
 RATED DISCHARGE IN CMS 152,144 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

O-HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	ENERGY (M US D)	TOTAL (M US D)	P.W.F.	PRESENT OPERATION WORTH (M US D)	OPERATION HOUR (HR)
1994	149.0	439.20	23.88	10.28	34.15	0.90909	31.05	2953
1995	149.0	439.20	23.88	10.28	34.15	0.82645	28.23	2953
2042	149.0	439.20	23.88	10.28	34.15	0.00937	0.32	2953
2043	149.0	439.20	23.88	10.28	34.15	0.00852	0.29	2953
SUMMARY	149.0	439.20	23.88	10.28	34.15	9.91481	338.64	2953

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 THL = 165.000 ** NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 300.000 LOW WATER LEVEL IN METER 270.000 RATED HEAD IN METER ***** 110.200
 INSTALLED CAPACITY IN MW 149.000 DEPENDABLE CAPACITY IN MW 122.016 TARGET OPERATION HOUR A DAY 4.61
 RATED DISCHARGE IN CMS 152.144 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313 21.313

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPD. (CMS)	SPILL (CMS)	GZ4 (CMS)	QG (CMS)	S2 (CMS)	R.W.L. (M)	T.W.L. (M)	F.HEAD EFFECT. (M)	POWER (MW)	O.HOUR (HR)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	89.55	0.93	1.59	82.66	134.77	43.55	299.185	165.000	131.233	149.0	458.5	21.31	47.01	68.32
FEB.	66.23	1.21	0.	64.82	134.37	44.03	289.520	165.000	131.587	149.0	324.9	21.31	27.10	48.41
MAR.	49.50	1.40	0.	48.86	134.40	44.20	289.487	165.000	131.552	149.0	271.0	21.31	19.07	40.58
APR.	30.99	1.60	0.	32.94	134.70	43.81	289.213	165.000	131.264	149.0	176.3	21.31	4.95	26.26
MAY	26.79	1.30	0.	31.72	135.38	41.63	298.595	165.000	130.620	149.0	174.7	21.31	4.71	26.03
JUNE	25.11	0.93	0.	31.66	136.49	39.675	297.629	165.000	129.599	149.0	167.5	21.31	3.64	24.96
JULY	8.90	0.72	0.	27.17	138.62	34.589	295.778	165.000	127.651	149.0	145.9	21.31	0.43	21.74
AUG.	7.98	0.54	0.	27.31	141.38	292.68	292.913	165.000	124.661	148.4	143.7	21.31	0.	21.31
SEP.	15.36	0.66	0.	28.88	143.91	255.93	290.234	165.000	121.885	147.7	144.5	21.31	0.	21.31
OCT.	62.91	0.65	0.63	34.05	142.10	329.80	291.463	165.000	123.347	147.5	180.1	21.31	5.27	20.58
NOV.	89.27	0.66	0.75	59.64	137.48	402.94	295.709	165.000	127.951	148.0	316.4	21.31	25.86	46.92
DEC.	98.61	0.76	5.85	81.21	135.62	431.86	298.195	165.000	130.329	148.8	449.3	21.31	45.61	66.92
MEAN	47.53	0.94	0.75	45.84	137.45	385.88	296.479	165.000	128.457	148.6	2952.8	255.75	183.45	439.20

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 6 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURRED 5 TIMES
 LONGEST DURATION FROM 20-TH YEAR 7-TH MONTH TO 20-TH YEAR 12-TH MONTH

LOWEST POWER 123.7 MW

*** DEPENDABLE DISCHARGE , POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q(CMS)	% DEPENDABLE P(MW)	% DEPENDABLE Q(CMS)	E(GWH)	P(MW)	% DEPENDABLE P(MW)	% DEPENDABLE Q(CMS)	E(GWH)
1994	25.75	123.73	21.31	25.92	149.00	21.31	26.27	149.00
	100.0	95.0	90.0	85.0	80.0	80.0	80.0	80.0

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 TML = 155,000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 300,000 LOW WATER LEVEL IN METER 270,000 RATED HEAD IN METER ***** 124,000
 INSTALLED CAPACITY IN MW 158,000 DEPENDABLE CAPACITY IN MW 131,518 TARGET OPERATION HOUR A DAY 4.64
 RATED DISCHARGE IN CMS 151,186 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MWR JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 22,719 22,719 22,719 22,719 22,719 22,719 22,719 22,719 22,719 22,719 22,719 22,719

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

0. HOUR / YEAR KW VALUE IN US.0 KWH VALUE IN US.0
 2550.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE ANNUAL ENERGY (GWH)		POWER (MW)		BENEFIT ENERGY (M US D)		TOTAL (M US D)		P.W.F.	PRESENT OPERATION WORTH (M US D)	
	1994	1995	1994	1995	1994	1995	1994	1995		1994	1995
1994	158.0	466.85	25.32	10.92	36.24	0.90909	32.93	2959.			
1995	158.0	466.85	25.32	10.92	36.24	0.82645	29.95	2959.			
2042	158.0	466.85	25.32	10.92	36.24	0.00937	0.34	2959.			
2043	158.0	466.85	25.32	10.92	36.24	0.00852	0.31	2959.			
SUMMARY	158.0	466.85	25.32	10.92	36.24	9.91481	359.35	2959.			

NIPPON KOEI TOKYO/JAPAN

PLAN A-3 T.W.L. = 155.000 **

** RESERVOIR OPERATION STUDY OF KAMAN NO.1 DAM

HIGH WATER LEVEL IN METER 300.000 LOW WATER LEVEL IN METER 270.000 RATED HEAD IN METER ***** 124.000
 INSTALLED CAPACITY IN MW 158.000 DEPENDABLE CAPACITY IN MW 131.518 TARGET OPERATION HOUR A DAY 4.64
 RATED DISCHARGE IN CMS 151.186 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MW JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 22.719 22.719 22.719 22.719 22.719 22.719 22.719 22.719 22.719 22.719 22.719 22.719

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAP. (CMS)	SPILL (CMS)	Q24 (CMS)	OG (CMS)	S2 (CMS)	R.W.L. (M)	T.W.L. (M)	E-HEAD EFFICI. (M)	POWER (MW)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	89.55	0.93	1.60	82.66	134.48	443.72	299.184	155.000	139.464	158.0	459.4	22.72	49.87	72.59
FEB.	66.23	1.21	0.	64.83	134.09	443.99	299.518	155.000	139.827	158.0	325.0	22.72	28.73	51.45
MAR.	49.50	1.40	0.	48.88	134.12	441.89	299.483	155.000	139.788	158.0	271.7	22.72	20.21	42.93
APR.	30.99	1.60	0.	32.99	134.42	432.58	299.204	155.000	139.486	158.0	176.9	22.72	5.23	27.95
MAY	26.79	1.30	0.	31.75	135.08	415.83	298.582	155.000	138.819	158.0	175.2	22.72	4.96	27.68
JUNE	25.11	0.93	0.	31.72	136.15	396.31	297.609	155.000	137.766	158.0	168.2	22.72	3.85	26.57
JULY	8.90	0.72	0.	27.22	138.20	345.30	295.750	155.000	135.758	158.0	146.7	22.72	0.45	23.17
AUG.	7.98	0.54	0.	27.34	140.88	291.89	292.876	155.000	132.690	157.4	144.4	22.72	0.	22.72
SEP.	15.36	0.65	0.	28.89	143.33	255.72	290.213	155.000	129.845	156.7	145.1	22.72	0.	22.72
OCT.	62.91	0.65	0.63	34.00	141.60	329.21	291.425	155.000	131.348	156.5	180.4	22.72	5.54	28.26
NOV.	89.87	0.66	0.76	50.48	137.12	402.74	295.690	155.000	136.083	157.0	316.3	22.72	27.08	49.80
DEC.	98.61	0.76	5.89	81.10	135.31	431.84	298.190	155.000	138.531	157.8	449.7	22.72	48.30	71.02
MEAN	47.53	0.94	0.75	45.83	137.08	385.55	295.461	155.000	136.600	157.6	2959.4	272.63	194.22	466.85

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 6 CONTINUOUS MONTH ***

THESE DEFICITS OCCURED 5 TIMES
 LONGEST DURATION FROM 20-TH YEAR 7-TH MONTH TO 20-TH YEAR 12-TH MONTH
 LOWEST POWER 133.1 MW

*** DEPENDABLE DISCHARGE, POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	% DEPENDABLE	P (MW)	E (GWH)	Q (CMS)	% DEPENDABLE	P (MW)	E (GWH)	Q (CMS)	% DEPENDABLE	P (MW)	E (GWH)
1994	25.82	133.09	22.72	25.99	158.00	22.72	26.35	158.00	22.72	26.62	158.00	22.72
	100.0	% DEPENDABLE	95.0	% DEPENDABLE	90.0	% DEPENDABLE	85.0	% DEPENDABLE	80.0	% DEPENDABLE	75.0	% DEPENDABLE

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 T.W.L = 145.000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 300.000 LOW WATER LEVEL IN METER 270.000 RATED HEAD IN METER ***** 134.000
 INSTALLED CAPACITY IN MW 168.000 DEPENDABLE CAPACITY IN MW 142.112 TARGET OPERATION HOUR A DAY 4.70
 RATED DISCHARGE IN CMS 148.758 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MHW JAN. 24.469 24.469 24.469 24.469 24.469 24.469 24.469 24.469 24.469 24.469 24.469 24.469 24.469
 FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0
 O. HOUR / YEAR KWH VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (MW)	ENERGY (M US D)	TOTAL ENERGY (M US D)	BENEFIT (M US D)	P.W.F.	PRESENT OPERATION WORTH (M US D)	OPERATION HOUR
1994	168.0	500.75	26.92	11.72	38.64	0.90909	35.13	2985.	
1995	168.0	500.75	26.92	11.72	38.64	0.82645	31.93	2985.	
...	
2042	168.0	500.75	26.92	11.72	38.64	0.00937	0.36	2985.	
2043	168.0	500.75	26.92	11.72	38.64	0.00852	0.33	2985.	
SUMMARY	168.0	500.75	26.92	11.72	38.64	9.91481	383.10	2985.	

** RESERVOIR OPERATION STUDY OF KAMAN NO.1 DAM PLAN A-3 TWL = 175.000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 290.000 LOW WATER LEVEL IN METER 260.000 RATED HEAD IN METER 96.600
 INSTALLED CAPACITY IN MW 127.000 DEPENDABLE CAPACITY IN MW 103.241 TARGET OPERATION HOUR A DAY 4.33
 RATED DISCHARGE IN CMS 153.992 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MWH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 17.063 17.063 17.063 17.063 17.063 17.063 17.063 17.063 17.063 17.063 17.063 17.063

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0
 O. HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0234
 1950.0 111.76 0.0625
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	BENEFIT ENERGY (M US D)	TOTAL (M US D)	P.M.F.	PRESENT OPERATION WORTH (M US D)	OPERATION HOUR (H)
1994	127.0	380.66	20.35	8.91	29.26	0.00909	26.60	3001.
1995	127.0	380.66	20.35	8.91	29.26	0.82645	26.18	3001.
.
.
.
2042	127.0	380.66	20.35	8.91	29.26	0.00937	0.27	3001.
2043	127.0	380.66	20.35	8.91	29.26	0.00852	0.25	3001.
SUMMARY	127.0	380.66	20.35	8.91	29.26	9.914R1	290.10	3001.

*** RESERVOIR OPERATION STUDY OF KAMAN NO.1 DAM PLAN A-3 TWL = 175.000 ** NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 290.000 LOW WATER LEVEL IN METER 260.000 RATED HEAD IN METER ***** 96.600
 INSTALLED CAPACITY IN MW 127.000 DEPENDABLE CAPACITY IN MW 103.241 TARGET OPERATION HOUR A DAY 4.33
 RATED DISCHARGE IN CMS 153.992 TYPE OF RULE CURVE ** VARIABLE MASS CURVE

RULE CURVE IN MMW JAN. 17.063 FEB. 17.063 MAR. 17.063 APR. 17.063 MAY 17.063 JUNE 17.063 JULY 17.063 AUG. 17.063 SEP. 17.063 OCT. 17.063 NOV. 17.063 DEC. 17.063

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	Q24 (CMS)	QG (CMS)	SZ (CMS)	R.W.L. (CM)	T.W.L. (CM)	E.HEAD (CM)	EFFICI. (%)	POWER (MW)	O.HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	89.53	0.75	1.74	83.31	132.47	346.00	280.484	175.000	113.798	0.860	127.0	469.4	17.06	42.56	59.62
FEB.	66.23	0.97	0.	64.92	138.07	346.83	280.810	175.000	114.184	0.860	127.0	330.7	17.06	24.93	41.99
MAR.	49.50	1.13	0.	48.50	138.04	346.49	280.831	175.000	114.125	0.860	127.0	235.5	17.06	17.67	34.73
APR.	30.99	1.29	0.	32.70	133.33	336.73	280.588	175.000	113.878	0.860	127.0	178.1	17.06	5.55	22.61
MAY	26.79	1.04	0.	30.93	133.12	324.85	280.931	175.000	113.215	0.860	127.0	133.5	17.06	4.94	22.00
JUNE	25.11	0.74	0.	30.40	136.31	309.20	287.974	175.000	112.242	0.860	127.0	138.2	17.06	3.71	20.77
JULY	8.90	0.57	0.	25.40	136.89	283.49	283.946	175.000	110.186	0.860	127.0	134.4	17.06	0.49	17.55
AUG.	7.98	0.42	0.	25.51	141.19	215.41	283.666	175.000	106.856	0.860	126.9	135.2	17.06	0.	17.06
SEP.	15.86	0.50	0.	27.18	146.67	183.46	279.588	175.000	103.738	0.860	126.2	135.2	17.06	0.	17.06
OCT.	62.91	0.51	0.40	34.70	141.70	255.52	281.299	175.000	105.730	0.860	125.9	135.3	17.06	6.30	23.36
NOV.	89.27	0.53	1.23	65.59	133.89	312.34	280.023	175.000	110.547	0.860	126.2	335.6	17.06	27.72	44.79
DEC.	98.61	0.61	6.35	82.84	133.69	335.93	280.475	175.000	112.865	0.860	127.0	435.5	17.06	42.05	59.11
MEAN	47.53	0.75	0.86	45.92	135.88	297.92	286.618	175.000	110.925	0.860	126.8	3000.6	204.75	175.91	380.66

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 4 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURRED 5 TIMES
 LONGEST DURATION FROM 20-TH YEAR 8-TH MONTH TO 20-TH YEAR 11-TH MONTH

LOWEST POWER 105.9 MW

*** DEPENDABLE DISCHARGE * POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q(CMS)	P(MW)	E(GWH)	% DEPENDABLE	Q(CMS)	P(MW)	E(GWH)	% DEPENDABLE
1994	23.82	105.88	17.06	127.00	24.32	127.00	17.06	24.83
1994	23.82	105.88	17.06	127.00	24.32	127.00	17.06	24.83

NIPPON KOEI TOKYO/JAPAN

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 IWL = 165,000 **
 HIGH WATER LEVEL IN METER 290,000 LOW WATER LEVEL IN METER 260,000 RATED HEAD IN METER 106,200
 INSTALLED CAPACITY IN MW 138,000 DEPENDABLE CAPACITY IN MW 114,503 TARGET OPERATION HOUR A DAY 4.35
 RATED DISCHARGE IN CMS 154,181 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MMH. JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC. OFC
 18,625 18,625 16,625 18,625 18,625 18,625 18,625 18,625 18,625 18,625 18,625 18,625 18,625

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

O.HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0236
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE ANNUAL		BENEFIT		TOTAL		PRESENT OPERATION	
	POWER (MW)	ENERGY (GWH)	POWER (M US D)	ENERGY (M US D)	POWER (M US D)	ENERGY (M US D)	WORTH (M US D)	HOUR
1994	138.0	413.49	22.11	9.68	31.79	0.90909	28.90	2999.
1995	138.0	413.49	22.11	9.68	31.79	0.82645	26.27	2999.
.
.
.
2042	138.0	413.49	22.11	9.68	31.79	0.00937	0.30	2999.
2043	138.0	413.49	22.11	9.68	31.79	0.00652	0.27	2999.
SUMMARY	138.0	413.49	22.11	9.68	31.79	9.91481	315.19	2999.

** RESERVOIR OPERATION STUDY OF KAMAN NO.1 DAM PLAN A-3 TWL = 165.000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 290.000 LOW WATER LEVEL IN METER 260.000 RATED HEAD IN METER ***** 106.200
 INSTALLED CAPACITY IN MW 138.000 DEPENDABLE CAPACITY IN MW 114.503 TARGET OPERATION HOUR A DAY 4.35
 RATED DISCHARGE IN CMS 154.181 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 RULE CURVE IN MWH 18.625 18.625 18.625 18.625 18.625 18.625 18.625 18.625 18.625 18.625 18.625 18.625

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	Q24 (CMS)	Q6 (CMS)	S2 (MCM)	R.W.L. (M)	T.W.L. (M)	E-HEAD (M)	EFFECT.	POWER (MW)	O-HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	89.55	0.75	1.72	83.35	132.64	345.99	289.486	165.000	123.481	0.860	138.0	468.9	18.63	48.08	64.71
FEB.	66.23	0.97	0.	64.93	132.28	346.79	289.809	165.000	123.787	0.860	138.0	330.2	18.63	26.94	45.56
MAR.	69.50	1.13	0.	48.53	132.26	346.36	289.826	165.000	123.804	0.860	138.0	273.2	18.63	19.08	37.70
APR.	50.99	1.29	0.	32.78	132.54	338.40	289.573	165.000	123.546	0.860	138.0	178.2	18.63	5.97	24.59
MAY	26.79	1.04	0.	31.02	135.28	328.29	288.904	165.000	121.847	0.860	138.0	173.5	18.63	5.32	23.94
JUNE	25.11	0.74	0.	30.46	134.40	308.50	287.931	165.000	119.794	0.860	138.0	138.7	18.63	3.96	22.59
JULY	8.90	0.57	0.	25.48	136.80	262.56	285.889	165.000	119.794	0.860	138.0	138.0	18.63	0.52	19.14
AUG.	7.98	0.42	0.	25.55	140.75	214.38	282.592	165.000	113.432	0.860	137.2	135.8	18.63	0.	18.63
SEP.	15.36	0.50	0.	27.16	143.94	182.49	279.508	165.000	113.295	0.860	136.9	184.9	18.63	6.72	25.35
OCT.	62.91	0.51	0.78	54.56	141.20	254.96	281.238	165.000	119.515	0.860	137.2	356.3	18.63	28.87	68.50
NOV.	89.27	0.53	1.22	65.40	135.82	312.30	286.007	165.000	120.202	0.860	138.0	464.9	18.63	45.53	64.16
DEC.	98.61	0.61	6.30	82.86	133.76	335.97	288.477	165.000	120.566	0.860	138.0	2998.3	223.50	189.99	423.49
MEAN	47.53	0.75	0.85	45.93	135.83	297.48	286.586	165.000	120.563	0.860	137.8	2998.3	223.50	189.99	423.49

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 4 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURED 5 TIMES
 LONGEST DURATION FROM 20-TH YEAR 8-TH MONTH TO 20-TH YEAR 11-TH MONTH
 LOWEST POWER 116.8 MW

*** DEPENDABLE DISCHARGE, POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q(CMS)	P(MW)	E(GWH)	% DEPENDABLE	Q(CMS)	P(MW)	E(GWH)	% DEPENDABLE	Q(CMS)	P(MW)	E(GWH)	% DEPENDABLE
1994	23.97	136.80	18.62	24.14	138.00	18.63	24.44	139.00	18.63	24.76	138.00	18.63
1995	100.0	138.00	18.62	95.0	138.00	18.63	24.44	139.00	18.63	24.76	138.00	18.63

** RESERVOIR OPERATION STUDY OF KAMAN NO.1 DAM PLAN A-3 T.W.L = 155.000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 290.000 LOW WATER LEVEL IN METER 260.000 RATED HEAD IN METER 114.200
 INSTALLED CAPACITY IN MW 147.000 DEPENDABLE CAPACITY IN MW 120.340 TARGET OPERATION HOUR A DAY 4.31
 RATED DISCHARGE IN CMS 152.731 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MMH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625

LENGTH OF FLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

O. HOUR / YEAR KW VALUE IN US D KW VALUE IN US D
 2550.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682.

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	ENERGY (M US D)	TOTAL (M US D)	P.W.F.	PRESENT OPERATION WORTH (M US D)	OPERATION HOUR (H)
1994	146.7	435.81	23.51	10.20	33.71	0.90909	30.64	2970.
1995	146.7	435.81	23.51	10.20	33.71	0.82645	27.86	2970.
.
.
.
2042	146.7	435.81	23.51	10.20	33.71	0.00937	0.32	2970.
2043	146.7	435.81	23.51	10.20	33.71	0.00852	0.29	2970.
SUMMARY	146.7	435.81	23.51	10.20	33.71	9.91481	334.22	2970.

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 TWL = 155.000 ** NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 290.000 LOW WATER LEVEL IN METER 260.000 RATED HEAD IN METER ***** 114.200
 INSTALLED CAPACITY IN MW 147.000 DEPENDABLE CAPACITY IN MW 120.340 TARGET OPERATION HOUR A DAY 4.31
 RATED DISCHARGE IN CMS 152.731 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MHH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625 19.625

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	024 (CMS)	06 (CMS)	52 (CMS)	R.W.L. (CM)	T.W.L. (CM)	E-HEAD EFFICI. (CM)	POWER (MW)	0-HOUR (H)	P.E. (GWH)	S.E.E. (GWH)	T.E.E. (GWH)
JAN.	69.55	0.75	1.61	83.67	134.17	345.94	289.484	155.000	130.037	0.860	147.0	464.3	19.63	48.62
FEB.	66.23	0.97	0.	64.93	153.80	346.74	289.806	155.000	130.365	0.860	147.0	326.4	19.63	28.36
MAR.	48.50	1.13	0.	48.54	153.77	346.30	289.823	155.000	130.384	0.860	147.0	270.1	19.63	20.09
APR.	30.99	1.29	0.	32.77	154.06	338.35	289.570	155.000	130.112	0.860	147.0	170.2	19.63	6.27
MAY	26.79	1.04	0.	31.03	154.82	324.21	288.900	155.000	128.391	0.860	147.0	171.6	19.63	5.60
JUNE	25.11	0.74	0.	30.47	155.96	308.59	287.925	155.000	128.336	0.860	147.0	161.9	19.63	4.17
JULY	8.90	0.57	0.	25.50	158.41	262.39	285.879	155.000	128.119	0.860	147.0	137.2	19.63	0.54
AUG.	7.98	0.42	0.	25.58	142.21	214.14	282.575	155.000	119.262	0.860	146.7	133.8	19.63	0.
SEP.	15.36	0.50	0.	27.18	144.96	182.19	279.484	155.000	119.262	0.860	145.5	135.0	19.63	0.
OCT.	62.91	0.51	0.75	34.59	142.22	254.70	281.214	155.000	121.405	0.860	145.2	183.5	19.63	7.08
NOV.	89.27	0.53	1.14	65.41	137.04	312.20	285.995	155.000	129.573	0.860	145.9	348.6	19.63	31.45
DEC.	98.61	0.61	6.04	83.10	135.23	335.95	288.675	155.000	129.062	0.860	146.9	461.0	19.63	48.13
MEAN	47.53	0.75	0.81	45.97	137.24	297.56	286.577	155.000	128.948	0.860	146.6	2969.5	235.50	200.31
														455.81

*** THESE ARE POWER DEFICIT OF THE LONGEST DURATION 4 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURRED 6 TIMES
 LONGEST DURATION FROM 20-TH YEAR 8-TH MONTH TO 20-TH YEAR 11-TH MONTH
 LOWEST POWER 122.4 MW

*** DEPENDABLE DISCHARGE / POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MW)	E (GWH)	Q (CMS)	P (MW)	E (GWH)	Q (CMS)	P (MW)	E (GWH)	Q (CMS)	P (MW)	E (GWH)
1994	23.98	122.42	19.62	24.15	146.72	19.63	24.45	147.00	19.63	24.78	147.00	19.63
	100.0	X	DEPENDABLE	90.0	X	DEPENDABLE	85.0	X	DEPENDABLE	80.0	X	DEPENDABLE

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 YML = 145.000 ** NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 200.000 LOW WATER LEVEL IN METER 240.000 RATED HEAD IN METER ***** 122.000
 INSTALLED CAPACITY IN MW 157.000 DEPENDABLE CAPACITY IN MW 130.653 TARGET OPERATION HOUR A DAY 4.30
 RATED DISCHARGE IN CMS 152.692 TYPE OF RULE CURVE .. VARIABLE MASS CURVE

RULE CURVE IN MMH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 20.938 20.938 20.938 20.938 20.938 20.938 20.938 20.938 20.938 20.938 20.938 20.938

LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0

0. HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 160.25 0.0234
 1950.0 111.76 0.0425
 0. 63.35 0.0682

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	ENERGY (M US D)	TOTAL (M US D)	P.M.F.	PRESENT WORTH (M US D)	PRESENT OPERATION HOUR
1994	156.7	463.78	25.11	10.85	35.97	0.90909	32.70	2958.
1995	156.7	463.78	25.11	10.85	35.97	0.82665	29.72	2958.
...
2042	156.7	463.78	25.11	10.85	35.97	0.00937	0.34	2958.
2043	156.7	463.78	25.11	10.85	35.97	0.00852	0.31	2958.
SUMMARY	156.7	463.78	25.11	10.85	35.97	9.91481	356.59	2958.

** RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 TML = 145,000 ** NIPPON KOEI TOKYO/JAPAN

HIGH WATER LEVEL IN METER 290,000 LOW WATER LEVEL IN METER 260,000 RATED HEAD IN METER 122,000
 INSTALLED CAPACITY IN MW 157,000 DEPENDABLE CAPACITY IN MW 130,653 TARGET OPERATION HOUR A DAY 4.50
 RATED DISCHARGE IN CMS 152,692 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MWH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 20,938 20,938 20,938 20,938 20,938 20,938 20,938 20,938 20,938 20,938 20,938 20,938

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPOR. (CMS)	SPILL (CMS)	Q24 (CMS)	QG (CMS)	S2 (CMS)	R.W.L. (CM)	T.W.L. (CM)	E.HEAD EFFICI. (%)	POWER (MW)	O.HOUR (CH)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	89.55	0.75	1.39	83.49	134.75	345.90	289.682	145,000	138.280	0.860	157.0	462.4	20.94	51.65
FEB.	66.23	0.97	0.	64.94	134.39	346.69	289.803	145,000	138.618	0.860	157.0	325.0	20.94	30.09
MAR.	49.50	1.13	0.	48.55	134.37	346.20	289.818	145,000	138.635	0.860	157.0	269.0	20.94	21.50
APR.	30.99	1.29	0.	32.81	134.65	338.16	289.541	145,000	138.552	0.860	157.0	175.6	20.94	6.63
MAY	26.79	1.04	0.	31.08	135.39	323.89	288.884	145,000	137.605	0.860	157.0	171.1	20.94	5.92
JUNE	25.11	0.74	0.	30.51	136.51	307.96	287.900	145,000	136.516	0.860	157.0	161.4	20.94	4.61
JULY	8.90	0.57	0.	25.55	138.89	261.83	285.844	145,000	134.232	0.860	157.0	137.0	20.94	0.57
AUG.	7.98	0.42	0.	25.61	142.56	213.68	282.579	145,000	130.561	0.860	156.7	133.6	20.94	0.
SEP.	15.38	0.50	0.	27.18	145.23	181.53	279.430	145,000	127.199	0.860	155.5	134.7	20.94	0.
OCT.	62.91	0.53	0.75	34.53	142.00	254.74	281.169	145,000	129.404	0.860	155.2	182.6	20.94	7.66
NOV.	89.27	0.53	1.11	85.31	137.57	312.10	285.978	145,000	134.722	0.860	155.9	346.6	20.94	33.51
DEC.	98.61	0.61	5.93	83.18	135.78	335.91	288.471	145,000	137.278	0.860	156.9	459.4	20.94	51.18
MEAN	47.53	0.75	0.79	45.98	137.74	297.06	286.555	145,000	135.098	0.860	156.6	2958.5	251.25	463.78

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 4 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURED 6 TIMES.
 LONGEST DURATION FROM 20-TH YEAR 8-TH MONTH TO 20-TH YEAR 11-TH MONTH
 LOWEST POWER 132.5 MW

*** DEPENDABLE DISCHARGE, POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE	Q (CMS)	P (MW)	E (GWH)	% DEPENDABLE
1994	24.06	132.45	20.94	24.23	156.71	20.94	24.52	157.00	20.94	24.86	157.00	20.94
				95.0				90.0				85.0
												80.0

*A RESERVOIR OPERATION STUDY OF KANAN NO.1 DAM PLAN A-3 TWL = 175.000 ** NIPPON KOEI TOKYO/JAPAN
 HIGH WATER LEVEL IN METER 280.000 LOW WATER LEVEL IN METER 250.000 RATED HEAD IN METER ***** 86.600
 INSTALLED CAPACITY IN MW 115.000 DEPENDABLE CAPACITY IN MW 91.192 TARGET OPERATION HOUR A DAY 3.79
 RATED DISCHARGE IN CFS 157.563 TYPE OF RULE CURVE .. VARIABLE MASS CURVE
 RULE CURVE IN MWH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500
 LENGTH OF INFLOW SERIES IN YEAR 26

*** BENEFIT CALCULATION ***
 DISCOUNT RATE 10.0 POWER DEPENDABILITY IN % 95.0
 O. HOUR / YEAR KW VALUE IN US D KWH VALUE IN US D
 2550.0 0.0234
 1950.0 111.76
 0. 63.35

YEAR	DEPENDABLE POWER (MW)	ANNUAL ENERGY (GWH)	POWER (M US D)	BENEFIT ENERGY (M US D)	TOTAL (M US D)	P. M. F.	PRESENT OPERATION WORTH (M US D)	OPERATION HOUR (H)
1994	115.0	349.03	18.43	8.17	26.60	0.90909	24.18	3038.
1995	115.0	349.03	18.43	8.17	26.60	0.82645	21.98	3038.
.
.
.
2042	115.0	349.03	18.43	8.17	26.60	0.00937	0.25	3038.
2043	115.0	349.03	18.43	8.17	26.60	0.00852	0.23	3038.
SUMMARY	115.0	349.03	18.43	8.17	26.60	9.91481	263.69	3038.

NIPPON KOEI TOKYO/JAPAN

** RESERVOIR OPERATION STUDY OF KANAR NO.1 DAM PLAN A-3 THL = 175.000 **

HIGH WATER LEVEL IN METER 280.000 LOW WATER LEVEL IN METER 250.000 TARGET HEAD IN METER ***** 86.600
 INSTALLED CAPACITY IN MW 115.000 DEPENDABLE CAPACITY IN MW 91.192 RATED OPERATION HOUR A DAY 3.79
 RATED DISCHARGE IN CMS 137.503 TYPE OF RULE CURVE ** VARIABLE MASS CURVE
 RULE CURVE IN MWH JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.
 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500 13.500

LENGTH OF INFLOW SERIES IN YEAR 26

*** MONTHLY SUMMARY OF RESERVOIR OPERATION STUDY FOR THE TARGET YEAR 1994 ***

MONTH	INFLOW (CMS)	EVAPD. (CMS)	SPILL (CMS)	Q24 (CMS)	QG (CMS)	S2 (MCM)	R.W.L. (CM)	T.W.L. (CM)	F.HEAD (CM)	EFFICI.	POWER (MWH)	O. HOUR (H)	P.E. (GWH)	S.E. (GWH)	T.E. (GWH)
JAN.	89.55	0.59	1.83	85.21	130.97	260.31	279.809	175.000	104.193	0.860	115.0	484.6	13.50	42.23	55.73
FEB.	66.23	0.76	0.	65.62	130.78	259.94	279.986	175.000	104.336	0.860	115.0	337.2	13.50	25.28	38.78
MAR.	49.50	0.88	0.	48.94	130.84	259.09	279.939	175.000	104.288	0.860	115.0	278.4	13.50	18.51	32.01
APR.	30.99	1.01	0.	31.82	131.12	254.32	279.721	175.000	104.067	0.860	115.0	174.9	13.50	6.61	20.11
MAY	26.79	0.82	0.	29.22	131.78	245.63	279.207	175.000	103.522	0.860	115.0	165.3	13.50	5.51	19.01
JUNE	25.11	0.84	0.	28.47	132.85	235.41	278.418	175.000	102.748	0.860	115.0	154.9	13.50	4.31	17.81
JULY	8.90	0.45	0.	22.33	135.61	198.25	276.412	175.000	100.711	0.860	115.0	122.7	13.50	0.61	14.11
AUG.	7.98	0.22	0.	22.19	140.65	159.31	272.956	175.000	97.202	0.860	115.0	117.4	13.50	0.	13.50
SEP.	15.36	0.38	0.	23.76	144.41	130.54	269.785	175.000	93.990	0.860	115.0	118.4	13.50	0.	13.50
OCT.	62.91	0.40	1.00	35.70	139.90	205.70	272.372	175.000	90.870	0.860	115.0	196.4	13.50	8.68	22.18
NOV.	89.27	0.42	1.86	73.71	134.06	240.66	277.053	175.000	101.534	0.860	115.0	408.6	13.50	32.71	46.21
DEC.	98.61	0.48	6.83	85.88	131.77	255.17	279.125	175.000	103.634	0.860	115.0	487.5	13.50	42.57	56.07
MEAN	47.53	0.59	0.96	45.98	134.58	225.68	277.050	175.000	101.412	0.860	114.8	3038.3	162.00	187.03	269.03

*** THERE ARE POWER DEFICIT OF THE LONGEST DURATION 4 CONTINUOUS MONTH ***
 THESE DEFICITS OCCURED 5-TIMES
 LONGEST DURATION FROM 20-TH YEAR 8-TH MONTH TO 20-TH YEAR 11-TH MONTH
 LOWEST POWER 92.6 MW

*** DEPENDABLE DISCHARGE / POWER OUTPUT AND ENERGY OUTPUT ***

YEAR	Q (CMS)	P (MWH)	E (GWH)	Q (CMS)	P (MWH)	E (GWH)	% DEPENDABLE	% DEPENDABLE
1994	20.70	92.62	13.50	20.90	115.00	13.50	21.26	115.00
							85.0	80.0
							21.49	21.72
							13.50	13.50
							115.00	115.00
							80.0	80.0
							115.00	115.00
							13.50	13.50
							115.00	115.00
							80.0	80.0
							115.00	115.00