

THE KINGDOM OF THAILAND

FINAL REPORT ON THE WATER SUPPLY PROJECT

FOR

THE CAMBODIAN REFUGEE CAMPS (SAKAEO DIVERSION FACILITIES)

TABLE OF CONTENTS

	PREFACE	
Chapter I	BASIC DESIGNING OF WATER INTAKE FACILITIES.....	1
1.1	Aims.....	1
1.2	Team Formation.....	1
1.3	Itinerary.....	2
1.4	Final Design.....	2
(1)	Aims of the Project	2
(2)	Water Intake Point.....	3
(3)	The Volume of Water Intake	3
(4)	Regulated Intake Water Level.....	6
(5)	Various Dimensions for the Water Intake Facilities..	6
(6)	Pipe-lining for Agricultural Purposes.....	9
(7)	Construction Cost.....	20
1.5	Construction Work.....	20
(1)	General	20
(2)	Temporary Works.....	21
(3)	Principal Works.....	25
Chapter II	OPERATION AND MAINTENANCE STANDARDS OF WATER INTAKE FACILITIES.....	27
2.1	Diversion Weir.....	27
(1)	Stop Log.....	27
(2)	Upperstream Apron.....	27
2.2	Water Intake Opening.....	28
2.3	Pumps.....	28
2.4	Removal of Mud/Sand from the Pipe	28
2.5	Valve Control between Distributing Tank and Trough....	29
2.6	Trough.....	30
ANNEX I	Operation Manual for Pump.....	32
ANNEX II	PumpData Sheet.....	38
ANNEX III	Instruction Manual for Vertical Mixed Flow Pump.....	47
ANNEX IV	Drawings of the Sakaao Diversion Facilities.....	81

CHAPTER 1 : BASIC DESIGNING OF WATER INTAKE FACILITIES

1.1 Aims

The inception of the Sa Kaeo Water Intake Facilities Project dates back to a visit of the Second Cambodian Refugee Study Mission (headed by Mr Sakamoto, Director of Planning Division, Ministry of Foreign Affairs) which was sent by the Government of Japan in the latter part of February 1980. On this occasion, the Provincial Government of Prachin Buri (where the Cambodian Refugee Holding Centers are located) made a strong request for the provision of water utilization facilities, and the Government of Japan subsequently decided to accommodate such a request in terms of an emergency grant aid programme.

The content of the work assigned to this Team comprises of the final design of such facilities for assuring the supply of subsistence water on behalf of the Cambodian refugees being accommodated in No.2 Camp of the Sa Kaeo Holding Center and the provision of subsistence water as well as irrigation water to the local Thai villagers in the neighbourhood of the said Camp as a diversion weir across the Khlong Phra Prong River running northward of the same Camp, a pumping station on its left bank, and a distribution network of the pumped water to respective consumers.

The Team was also expected to give any necessary technical advice to the local contractor who undertook construction of such facilities as referred to in the above.

1.2 Team Formation

Overall Coordination	Hiroshi YONEHARA
General Designing	Fumio TAMURA
Designing (diversion-weir)	Shuntaro KODERA

Designing (pipelining)	Chu NAKAJIMA
Geology	Akinori TAKAKU
Overall inspection	Mitsumasa UENO
Economic Evaluation	Ken-ichi HIDAKA
Construction Machinery	Yooichi HIGAKI

1.3 Itinerary

The Team's work commenced on April 20, 1980 and the final designing was completed by June 15, 1980. Technical advice to the local contractor called for the construction of the diversion weir, pumping station, distributing tank, trough and pipelining inside the Camp which were completed by September 30 of the same year; and also for pipelining outside the Camp which was started on November 8, after a lapse of one month because of the monsoon rain and paddy cultivation, and completed on December 25, 1980. The actual work regarding the latter job was completed by December 13, but test operation was necessary before official hand-over which was successfully effected on December 22, 1980.

1.4 Final Design

(1) Aims of the Project

The Water Supply Plan for the Sa Kaeo No.2 Camp was originally based on the groundwater obtainable by means of deepwells (50-60m), but in consideration of the poor results of groundwater exploitation by 3 deepwells existing in Sa Kaeo No.1 Camp (poor yield due to insufficient pump capacity and frequent breakdowns, inadequate water supply pipelining, shortages of water supply equipment, etc.), the decision was made to pump the perennial riverwater from the Khlong Phra Prong which runs along the border of the Camp as a reliable source of water supply.

The pumped riverwater will be used not only for such purposes as washing and bathing by the Camp refugees but also for miscellaneous as well as irrigation purposes by the local Thai villagers in the neighbourhood of the Camp.

(2) Water-Intake Point

Three (3) water-intake points were proposed at the northern part of the Camp which lies closest to the Khlong Phra Prong and, after comparative studies on economic feasibility, engineering workability, maintenance & operation conveniences, etc., the final water-intake point was decided.

(3) The Volume of Water Intake - Design and Purpose

- (1) The Volume of Design Water-intake - In the absence of reliable observation data regarding the Khlong Phra Prong's levels and seasonal flows in the vicinity of the proposed diversion-weir, the observation data available in its lower stream in Kabin Buri and information obtainable from the local inhabitants were used as the basis for estimating its dry season flow.

The figure for specific discharge of $0.0004 \text{ m}^3/\text{sec}/\text{km}^2$ has been arrived at from the dry season flow as recorded at Kabin Buri during the last 5 years, and $0.56 \text{ m}^3/\text{sec}$ has been estimated as the dry season flow at the intake point, judging from the size of the catchment area extending over $1,400 \text{ km}^2$.


The dry season flow has been subsequently increased to about $0.89 \text{ m}^3/\text{sec}$ based on information received from the local inhabitants as to the river water level and running conditions. Consequently, a mean figure of $0.6 \text{ m}^3/\text{sec}$ has been adopted as the Khlong Phra Prong's dry season flow and the volume of design water-intake was decided at $0.2 \text{ m}^3/\text{sec}$.

(ii) Distribution Volume - The intake-water will be meant for the following three (3) purposes:

- (a) Subsistence water for
Refugee Camp ... $q = 0.0167 \text{ m}^3/\text{sec}$
- (b) Subsistence water for the
neighbouring villagers ... $q = 0.0055 \text{ "}$
- (c) Irrigation water for the
neighbouring villagers ... $q = 0.1778 \text{ "}$

The above allocation has been made on the assumption that 40,000 Camp dwellers will consume 20 per day per head, while the neighbouring villagers numbering 2,500 will consume 100 per day per head, and the remainder has been allocated for irrigation purpose.

45—Fig. 1-1 LOCATION OF WATER INTAKE FACILITIES



SCALE 1:50,000

(4) Regulated Intake Water Level

The given topography defied the possibility of gravity flow of the river water taken from the diversion weir, hence lifting by pump is necessary. Pump-lifting favours the higher intake water level in view of both operational and construction costs of the pump itself, but it is accompanied by the drawbacks of the higher construction cost called for the bigger dam-body and the untoward effects to the upper-stream areas due to the higher weir level.

In consideration of this, the Team made the necessary hydraulic calculations and eventually determined the optional intake water level to be 1.50 m.

Backwater calculations based on a flood discharge of $400 \text{ m}^3/\text{sec}$ and a river-bed slope of $1/3000$ resulted in a possible rise of approximately 5.0 cm in the water level at the weir-site. Taking into account a minor expansion of the flow area at the weir-site from 271.7 m^2 as it is to 277.1 m^2 after construction, the water level can be assumed to alter as such due to the waves driven by wind. Thus, the upper-stream area should suffer little or no adverse effects from constructing the proposed weir.

(5) Various Dimensions of the Water-Intake Facilities

(1) Diversion Weir

The floating type diversion weir has been adopted in view of the fact that the geological formation of the proposed weir foundation was identified as sandy soil; the foundation height has been determined at 3.00 m, because the existing river-bed level is between 2.5 m and 3.5 m, and the width of the weir has been made 16.0 m according to the cross-section of the existing river.

A 1.5 m width stop log has been provided for as deposited sand measure towards the upper-stream as well as discharge measure when the dry-season flow happens to be less than the design dry-season flow (0.6 m³/s.)

(ii) Intake Opening and Sluice

The foundation height and the width of the intake opening have been given such cross-sections in order to prevent the invasion of sand and to maintain a flow velocity of about 0.3 m/s.

A sluice cross-section which is generally determined to maintain the intra-sluice flow velocity at around 0.6 m/s has been made ϕ 800 mm in this specific case from O&M consideration.

(iii) Pumping Facilities

The actual head has been determined at 21.8 m, having been concluded from the water-intake level at dry season (- 1.80 m) and the Distributing Tank's storage water level (HWL + 20.0 m); the foundation height of the pumping station has been fixed at + 6.50 m to avoid inundation at the time of flood.

A pair of vertical mixed flow pumps has been adopted in consideration of the required duty and O&M conveniences.

(iv) Water Pipe

The water pipe has been routed along the road for the convenience of construction and O&M and the minimal distance to the Distributing Tank. Its diameter has been fixed at ϕ 400 mm in view of maintaining the intra-pipe velocity of the lift water

(0.2 m³/sec) at the standard rate of 1.0 m/sec. In consideration of the waterhammering effects which are obviously anticipated because the water pipe is directly connected to the pump, we decided to use steel pipe.

(v) Distributing Tank

It has been located at the highest point inside the Camp and its HWL has been increased by 3.0 m above the existing ground level. Its capacity has been fixed at 100 m³ which corresponds to a 10 minute lift volume, as approximately 80% of the lift water will be destined for irrigation.

(vi) Distributing Pipe

Its alignment has been determined to assure the most satisfactory supply of subsistence water on behalf of the neighbouring villagers and irrigation water for their paddyfields as well as to assure efficient O&M.

The diameter of the distributing pipe has been determined from the design discharge and the standard intra-pipe velocity of the distributing water, while asbestos-cement pipe has been selected because of the low hydrostatic pressure of around 0.3 kg/cm² and low cost.

(vii) Trough

It has been located just outside the Camp compound at a diverging point of the villagers' subsistence water pipe and the irrigation water pipe. It also serves as a sand settling basin.

(viii) Water Storage Tower

As the total length of the villagers' subsistence water pipe is approximately 2.5 km and the gravity flow of the water is unexpected, the height of the Water Storage Tower has been decided so as to make the permanent water pressure more than 0.3 kg/cm^2 at the end of the pipe.

Its capacity has been fixed at 30 m^3 which corresponds to 90 minutes' worth of the suppliable water.

(6) Pipe-lining for Agricultural Purposes

(i) Irrigation Plan

1) Volume of Irrigation Water $0.1778 \text{ m}^3/\text{sec}$

2) Area to be irrigated

Estimation of the area to be irrigated (paddyfield) has been made on varying assumptions of 8 mm, 10 mm, and 12 mm (water requirements in depth) and pump operation of 10 hrs, 12 hrs, 15 hrs and 18 hrs (per day), but the conveyance loss was fixed at 15%. As a result, it has been found that approximately 80 ha (500 rai) could be irrigated during dry season. Twice as much paddyfield area will be assured with irrigation water during the rainy season, as the effective rainfall (out of the average annual rainfall for the last 10 years) would provide 50% of the total amount of water required for paddy cultivation.


3) Irrigation Area

The cumulative total of the paddyfields in the neighbourhood of the Camp is approximately 150 ha as are shown on Fig. 1-7: Irrigation Area. Priority of irrigation water supply has been determined from A to E on the basis of the elevation and soil conditions of respective plots of paddyfield.

(ii) Alignment, Diameter and Type of Irrigation Water Pipe

Irrigation water pipe has been extended for a total length of 450 m through Priority A area, from Block No. 1 towards Block No. 2 . Its diameter has been decided at ϕ 400 mm from the design discharge and the intra-pipe velocity of flow. Asbestos-cement pipe has been chosen from the economic point-of-view. Two turnouts have been arranged for diversion towards Blocks Nos. 4 & 3 . It is deemed proper to start digging irrigation channels from A Blocks onward.

Fig. 1-2 PLAN OF DISTRIBUTING PIPE
Scale 1 : 5,000



T : Turning point
H : Hydrant

Fig. I-3 Distributing Pipe S_v=1:200 SH=1:5,000




Fig. 1-4. Distributing Pipe $S_v=1:200$ $SH=1:5,000$




Fig.1-5. Distributing Pipe Sv=1:200 SH=1:5.000





Fig.1-6. Distributing Pipe Sv=1:200 SH=1:5.000






Fig.1-8 IRRIGATION NET WORK





Fig.1-10. Irrigation Water Pipe Sv = 1:200 SH = 1:2 000



(7) Construction Cost

The total construction cost earmarked for the emergency grant aid is 200,000,000 Yen which will be spent under different construction heads as follows:

Breakdown of Construction Cost

1. Diversion weir works	2,679,055	Bhats
2. Pumping facility works	5,326,237	"
3. Water distribution piping works	3,088,398	"
4. Temporary works	3,235,140	"
5. Additional water distribution piping works	193,106	"
6. Irrigation water distribution piping works	1,078,022	"
Sub-Total	15,599,958	"
7. Project overhead	1,264,627	"
8. Office overhead	1,486,000	"
<hr/>		
Grand Total	18,350,585	Bhats =
	200,000,000	Yen

1.5 Construction Work

(1) General

The construction period of this project was originally set to last for 4 months, from May to the end of August 1980, to assure water supply for the next dry season in 1980. Among the facilities envisaged, two riparian works, viz., diversion weir and pumping station, were scheduled for completion by the end of July, before the arrival of full-scale monsoon rains, and the other land works would be completed by the end of August 1980.

However, extraordinary rains which started falling around June 10 disturbed the excavation work of the diversion weir and the resulting rise of the river water level necessitated the elevation of the coffer-dam within a month's time after commencement of the construction work. Moreover, the foundation ground proved to be unexpectedly hard which necessitated a change in the original method of protection for the weir-body. The result of these adverse conditions was the postponement of the completion date to the end of August 1980, completion dates being altered to the end of September for the to diversion weir, trough and water storage tower, and the end of October to mid-December (with a one month interval) for the other works between the trough and the terminal ends of the villagers' subsistence water pipeline and the irrigation water pipeline.

In spite of the initial delay as mentioned above, the entire construction work was completed on December 13, 1980.


(2) Temporary Works

For the completion of the riparian works, construction of a coffer-dam across the entire width of the river, associated with the bypass canal method, was preferred because of the narrow distance between the two banks and also to shorten the construction period.


(1) By-pass Canal

As is shown in Fig. 1-11: By-pass Canal Plan, a bypass canal was prepared by excavating the bed of a feeder to the depth of 0.5 m - 0.8 m and slightly widening its opening. Thus, the total length of the bypass canal has been limited to 70 m. Its cross-section was pre-decided from the flow available at the end of July, and the flow increment due to extraordinary precipitation did not cause any trouble because its cross-section was naturally enlarged through the failure of the slopes.


Fig. I-II BY-PASS CANAL PLAN



TRIBUTARY CROSS SECTION



NEW CANAL CROSS SECTION



(ii) Cofferdam

The crest of the cofferdam was originally planned at + 2.70 m from the flood water level as estimated in mid-July when the bypass canal cross-section was determined. It was eventually raised to + 4.40 m to cope with the ensuing water level rises. Clay soil transported from the nearby low-lying area was used as embankment material to prevent leakage and slope failure as the soil available on the spot was made up of sandy soil.

Fig.I-12 COFFERDAM CROSS SECTION





Fig.I-13 THE KHLONG PHRA PRONG— WATER LEVEL



(3) Principal Works

(i) Diversion Weir Works

Extraordinary rainfall which followed the completion of the cofferdam caused a considerable slope failure along the excavation cross-sections which helped refilling the excavation sites of the previous days and increased the duty of the drainage work. This was the main reason why many more days were required for completion of the excavation work. Moreover, the foundation ground proved to be unexpectedly hard (betraying insufficient soil survey) and steel sheet piles could not be easily inserted into the foundation ground; the sheet-piling method was eventually changed to the cutoff method. All of these adverse conditions cumulatively helped postpone the completion date by two months to the end of September.

(ii) Water Distribution Piping Works

The above-said delay in completion of the diversion weir works made it necessary postpone the commencement of the water distribution piping works which was originally scheduled in mid-June. In the meanwhile, the route of the \varnothing 100 mm pipe and the paddyfield through which the irrigation water pipe was planned to be set were immersed in water, threatening a considerable increase in the construction cost. Accordingly, the distributing pipe works and the piping works down to the trough were completed by the end of September and the remaining piping works (\varnothing 100 L = 2,900 m, \varnothing 400 L = 450 m) were undertaken from the end of October to mid-December.

Upon completion of the piping works, leakage and pressure tests to confirm the pipelines' water tightness and safety were effected and proved a success.

Table I-1 CONSTRUCTION SCHEDULE

Item	MAY	JUN.		JUL.		AUG.		SEP.		OCT.		NOV.		DEC.		Remarks
	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	10 20	
Preparatory Works																
Temporary Works																
Division Weir Works																
Main																
Intake																
Riprap																
Revetment																
Pumping Station Works																
Suction Well																
Pump																
Pump House																
Water Pipe Works																
Distributing Tank Works																
Distributing Pipe Works																
Pipe Arrangement																
Water Tower, Trough																
Irrigation Water Pipe Works																

CHAPTER 11 : OPERATION-AND-MAINTENANCE STANDARDS OF WATER INTAKE FACILITIES

Periodical O&M according to the following standards will ensure the smooth and proper functioning of various facilities provided under the Project.

2.1 Diversion Weir

(1) Stop Log

A stop log is meant, through its proper opening-closing operation, to prevent sand accumulated on the upper-stream side of the diversion weir to flow into the intake opening. A stop log should be installed at some time during the beginning of the dry season to the beginning of the rainy season; it should be installed/removed when the river water level rises 0.2 m above the weir crest.

While it is not actually in use, it should be stored inside the pumping station, and shall be coated with creosote or some other antiseptic once a year.

(2) Upper-stream Apron

Sand accumulated on the upper-stream apron needs to be swept away once a year through the operation of the stop log, but a complete sand dredging work must be done once in three years.

2.2 Water-Intake Opening

Floating rubbish stuck to the front-screen will bring down the pump-well and, thereby, impede the proper functioning of the pump(s). It is, therefore, necessary to remove such rubbish once a week.


2.3 Pumps

No.1 Pump and No.2 Pump must be put in operation each alternative week; no single pump shall be operated continuously for longer than one week.

The completion of irrigation channels down to their terminal ends will take another two-three years; in the meanwhile, operation of the pump(s) will be limited to within ten (10) hours a day, from 08:00 hrs to 18:00 hrs. The pump operator must be on duty in the pumping room, accordingly. Supply of oil to the pump(s) and inspection thereof will follow the descriptions in the attached "Pump Manual".

2.4 Removal of Mud/Sand from the Pipe


Mud and sand deposited inside the pipe needs to be removed more than once a year to prevent the choking of the pipe.



Operational Order for Removal of Sand/mud:

1. Open Valve ③ , and closed Valve ② ;
 2. Closed Valve ① , and open Valve ② ;
 3. Open Valve ① , and closed Valve ③ .
- 1 - 2 : for 20 minutes
2 - 3 : for 10 minutes

2.5 Valve Control between Distributing Tank and Trough




Approximately 80% of the entire design lift water volume is destined for irrigation which, however, will be available in a few years. In the meanwhile, it is necessary to control the volume of water running into the distributing pipe. Until the irrigation channel network is completed, Valves ① through ④ must be 90% closed.

The consumption of the subsistence water by the villagers in Ban Kaeng will fluctuate from time to time throughout the day, and it is necessary to attach one watchman at the Trough so that he will regulate Valve ④ whenever the Trough overflows.

2.6 Trough

The blow-off valve of the Trough needs to be opened for about 10 minutes, more than once a year, to remove mud and sand which will be deposited inside the Trough.

DIVISION OF MANAGEMENT OF WATER INTAKE FACILITIES



FACILITIES	MANAGEMENT	
	Case-1	Case-2
DIVERSION WEIR	UNHCR	R.I.D.
PUMP STATION	"	"
WATER PIPE	"	"
DISTRIBUTING TANK	"	"
DISTRIBUTING PIPE	"	"
CITY WATER INTAKE TANK	R.I.D.	"
WATER STORAGE TOWER	"	"
CITY WATER PIPE	"	"
IRRIGATION WATER PIPE	"	"

Case-1 : During the refugees are staying in camp

Case-2 : After the camp has been vacated by the refugees

R.I.D. : Including PRACHIN BURI PROVINCE

- 31 -

Scale 1:6000


S = 1 : 6000

WATER SUPPLY PROJECT FOR CAMBODIAN REFUGEE CAMPS	
THE KINGDOM OF THAILAND	
LOCATION MAP (GENERAL LAYOUT)	
Date	OWG No. 1
JAPAN INTERNATIONAL COOPERATION AGENCY	

ANNEX I


OPERATION MANUAL

FOR PUMP



PUMP NO. 1

PUMP NO. 2



วิธีใช้

เปิด เมนสวิตช์ (MAIN SWITCH) จุด (1)

วิธีใช้แบบอัตโนมัติ (AUTOMATIC CONTROL)


เปิดสวิตช์ จุดเครื่องหมาย (2) ไปทางตำแหน่ง "A" (AUTOMATIC)
 ถ้าน้ำในถังต่ำกว่าระดับที่ตั้งเอาไว้ ปั๊ม (PUMP) จะทำงานตามปกติ แต่เมื่อน้ำในถัง
 เกินความที่กำหนดไว้ ปั๊ม (PUMP) จะหยุดโดยอัตโนมัติ

วิธีใช้แบบมือหมุน (MANUAL CONTROL)

จะใช้ควบคุมการทำงานของเครื่องอย่างเดี่ยว

- 1) หมุนจุดเครื่องหมาย (2) ไปทางตำแหน่ง "H" (MANUAL)
- 2) กดปุ่มตรงจุดเครื่องหมาย (4) ปั๊ม (PUMP) ก็จะทำงาน
- 3) กดปุ่มตรงจุดเครื่องหมาย (3) ปั๊ม (PUMP) ก็จะหยุดทำงาน


ข้อระวัง เมื่อเราจะใช้ปั๊ม NO. 1 ทำงานจะต้องมีคนปุ่มเครื่องหมาย (2) ไปทาง "H" (MANUAL) หรือมีคนที่กดเมนสวิตช์ (MAIN SWITCH) ของตู้ NO. 2 เลียบก่อนอย่าเดินเครื่องพร้อมกัน 2 เครื่อง ปั๊ม NO. 1 และปั๊ม NO. 2 นั้น ควรสลับกันใช้ครั้งละ 1 เครื่องตลอดไป และก่อนเปิดปั๊มนั้นอย่าลืมเปิดประตูระบายความร้อนเสียบก่อนทุกครั้ง ก่อนที่จะทดลองปั๊มหรือเปิดให้ปั๊มทำงาน หรือมีคนที่กดเปิดประตูระบายความร้อนนั้นตลอดเราทั้งสองเครื่อง ถ้ามีอะนันั้นแล้วจะทำให้เครื่องเสีย.




AIR RELIEF VALVE (ประทุระบายอากาศออก)

VALVE (ORDINARY TIME : OPEN)

ประทุปิดเปิดน้ำ (เวลาปกติต้องเปิดน้ำนาน)






OIL GAUGE COCK (หลอดวัดน้ำมันหล่อลื่น)

(SHELL TELLUS 68)

ขอระวัง อย่าใช้น้ำมันหล่อลื่นต่ำกว่าขีดแดง


SIGHT GLASS FOR COOLING WATER

กระจกที่จะแสดงการไหลของน้ำที่จะระบายความร้อน




VALVE (ORDINARY TIME : OPEN)

ประตูปกติเปิด (เวลาปกติต้องเปิดให้น้ำผ่านตลอดเวลา)



FRONT VIEW



INSIDE VIEW




RIGHT SIDE VIEW

SYMBOL	NAME
NP	NAME PLATE OF PANEL
A	AC AMMETER
V	AC VOLT METER
RL	OPERATING DISPLAY LIGHT
GL	STOPPING DISPLAY LIGHT
MCB	CIRCUIT BREAKER
ON	START PUSH BUTTON SWITCH
OFF	STOP PUSH BUTTON SWITCH
F	FUSE
TB	TERMINAL BLOCK
52	MAIN CONTACTOR
42	OPERATING CONTACTOR
6	STARTING CONTACTOR
2	TIME RELAY
CT	CURRENT TRANSFORMER
Tr	TRANSFORMER
R	MULTIPLIER

WALL MOUNTING TYPE

WEIGHT Kg
Q'ty 2 UNIT



ACME		
TITLE STARTER PANEL OUTLINE DIAGRAM		
DRAWN	MR. CHOKHAI	AICHI ELECTRIC INDUSTRY CO., LTD.
DESIGNED		
CHECKED	<i>Shinji W.</i>	
APPROVED	<i>Shinji W.</i>	
COLOR		
FINISHED		
SCALE	1/10	SHEET NO.



ACME		DRAWN MR. CHOKCHAI V.	DESIGNED:	AICHI ELECTRIC INDUSTRY CO. LTD.
TITLE CONTROL CIRCUIT		CHECKED <i>P. W.</i>	APPROVED: <i>Direct W.</i>	
SCALE	SHEET NO. OF	COLOUR:	DATE: 9-9-60	

エハラ立軸斜流ポンプ仕様書 PUMP DATA SHEET

ANNEX II

DOCUMENT NO. 番		RA10191-84		REV. NO.	0														
注文主 Customer.																			
使用先 End User																			
プロジェクト Project	WATER SUPPLY PROJECT FOR CAMBODIAN REFUGEE CAMPS																		
ポンプ名称 Service	WATER PUMP	Ebara MFG. No.	RA10191																
Job No.		Ebara Model	250 VY2M																
Item No.		Page	5 in all																
<p>設計変更 ENGINEERING CHANGE</p> <p>Rev. 0 / BY</p> <p>Rev. 1 / BY</p> <p>Rev. 2 / BY</p> <p>Rev. 3 / BY</p> <p>Rev. 4 / BY</p>																			
<table border="1"> <thead> <tr> <th>配付先 DISTRIBUTION</th> <th>部数 Q'TY</th> </tr> </thead> <tbody> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> </tbody> </table>						配付先 DISTRIBUTION	部数 Q'TY												
配付先 DISTRIBUTION	部数 Q'TY																		
Prepared by 設計 DESIGN SECTION	承認 Approved by	調査 Checked by	担当 Prepared by	B 付 Date															
				Aug. 7 '80															

EBARA CORPORATION KAWASAKI PLANT, Kawasaki Cty. Japan

荏原製作所 川崎工場

1. 一般 GENERAL

注文数量	NUMBER OF UNITS	Z SETS
駆動方式	DRIVING FORM	MOTOR
原動機の支給	SUPPLIER OF DRIVER UNITS	
<input checked="" type="checkbox"/> モーター	MOTOR <input type="checkbox"/> 使用先 END USER, <input type="checkbox"/> 注文主 CUSTOMER, <input checked="" type="checkbox"/> 荏原 EBARA	
<input type="checkbox"/> エンジン	ENGINE <input type="checkbox"/> 使用先 END USER, <input type="checkbox"/> 注文主 CUSTOMER, <input type="checkbox"/> 荏原 EBARA	
<input type="checkbox"/> ギアヘッド	GEAR HEAD <input type="checkbox"/> 使用先 END USER, <input type="checkbox"/> 注文主 CUSTOMER, <input type="checkbox"/> 荏原 EBARA	
設置場所	INSTALLATION PLACE	屋内 <input checked="" type="checkbox"/> INDOOR, 屋外 <input type="checkbox"/> OUTDOOR

2. 運転条件 OPERATION CONDISION

揚液	LIQUID to be pumped	WATER
比重	SPECIFIC GRAVITY	1.0
液温	TEMPERATURE . °C	NOR.
吐出量	RATED CAPACITY . m ³ /min	6
全揚程	RATED TOTAL HEAD m	32
回転数	RATED SPEED . r.p.m	S.S. 1500
許容最大吐出量	MAX. ALLOWABLE FLOW . m ³ /min	7.5
連続運転可能最小吐出量	MIN. DISCHARGE FLOW . m ³ /min	1.2
ポンプ軸馬力	PUMP SHAFT POWER . KW or PS	42.9
原動機出力	DRIVER OUTPUT . KW or PS	45
ポンプ効率	PUMP EFFICIENCY . %	73
回転方向	ROTATION(VIEWED RFOM DRIVER)	時計方向C.W.
水圧試験	HYDROSTATIC TEST . kgf/cm ²	20

記事 NOTE. ポンプ性能判定はJIB B 8301-1976による。

Judgenet of Pumping Performance shall be made in accordance with JIS B 8301-1976.





3. ポンプの構造 CONSTRUCTION

起動最低水位	LOW WATER LEVEL (FROM GLAND LEVEL), mm	8380
ベルマウス径	SUCTION BELL DIA. (INNER DIA), mm	300
吐出口径	DISCHARGE CASING LD., mm	250
吐出フランジ	DISCHARGE FLANGE	JIS 10K F.F.
羽根車径	IMPELLER DIA., mm	282/292
羽根車型式	IMPELLER TYPE	<input checked="" type="checkbox"/> CLOSED, <input type="checkbox"/> SEMI-OPEN
羽根車段数	STAGE OF IMPELLER	2
ラジアル軸受形式 & 材料	RADIAL BEARING TYPE & MATERIAL	SLEEVE <input checked="" type="checkbox"/> GRAPHITE <input type="checkbox"/> BC

ラジアル軸受潤滑方式 LUBRICATING METHOD

潤滑方式系統図

LUBRICATION DIAGRAM



☐EXTERNAL FLASH, ☒SELF FLASH, ☐MIXED FLASH, ☐SPECIAL

021	羽根車	IMPELLER	BC6	
107	ライナーリング	LINER RING	BC6	
147	軸継手	MAIN COUPLING	FC20	
	液に触れるボルト	BOLTS exposed to Liquid	SS41	
	ナット	NUTS		
	ワッシャー	WASHERS		

5. 塗装 PAINTING

○接液部 PART exposed to Liquid

下塗 Zinc Chromate
☐ PRIMER Primer

Acrylic Alkyd
 Resin base COLOR
 上塗 (DNT. SUBOID Z#10) ☐ 塗装色

○地上部 PART upper BASE

下塗 Zinc Chromate
☐ PRIMER Primer

Alkyd Resin
 Enamel COLOR
☐ 塗装色 Z.5 PB4/2

6. 付属品 ACCESSORIES

○印付属致します。 ○ shall be supplied by EBARA

<input type="checkbox"/>	ベース	BASE	Z
<input type="checkbox"/>	基礎ボルト	ANCHOR BOLT	Z SETS
<input type="checkbox"/>	軸継手	COUPLING	Z SETS
<input type="checkbox"/>	達成計(配管共)	COMPOUND GAUGE (with piping instrument)	Z SETS
<input type="checkbox"/>	相フランジ (250φ)	ACCESSORY FLANGE JIS 10 K, <input type="checkbox"/> ANSI LBS	6
	仕切弁 (φ)	SLUETH VALVE <input type="checkbox"/> JIS K, <input type="checkbox"/> ANSI LBS	
<input type="checkbox"/>	逆止弁 (250φ)	CHECK VALVE JIS 10 K, <input type="checkbox"/> ANSI LBS	Z
<input type="checkbox"/>	空気抜弁(配管共)	AIR EXHAUST VALVE (with piping instrument)	Z SETS
<input type="checkbox"/>	分解工具	TOOLS	Z SETS
<input type="checkbox"/>	吸込ストレーナ	SUCTION STRAINER	Z
<input type="checkbox"/>	潤滑配管	PIPING FOR LUBRICATION	
	内訳 (THE ITEMS)		
	<input type="checkbox"/> フローリレー	FLOW RELAY	<input type="checkbox"/> ストレーナ STRAINER
	<input type="checkbox"/> 電磁弁	SOLENOID VALVE	
	<input checked="" type="checkbox"/> ストップバルブ	BALL VALVE	
	<input type="checkbox"/> チェッキバルブ	CHECK VALVE	
	<input checked="" type="checkbox"/> フローサイト	FLOW SIGHT	
	<input checked="" type="checkbox"/> 配管小物部品	PIPING & FITTING	Z SETS
	その他		

記事 NOTE

補機操作電源 ———— AC ———— V ———— Hz ———— DC ———— V
 (ELECTRIC RESOURCE BY OTHERS) - 41 -

7. 予備品(), SPARE PARTS LIST

○印付属致します。 ○ shall be supplied by EBARA

[illegible]

8. 提出書類, DRAWINGS

○印の図面は提出されます。

ODWG shall be prepared by EBARA.

[illegible]

PERFORMANCE CURVE

50 Hz
(ESTIMATED)

ITEM NO.

FOR MESSRS: WATER SUPPLY PROJECT FOR CAMBODIAN REFUGEE CAMPS

MFG. NO: RA10191

TYPE: 250VY2M


Liquid Handled WATER

RATING: 6 $\frac{m^3}{min}$ \times 32 $\frac{m}{m}$ \times 1500 $\frac{rpm}{S.S.}$ \times 45 $\frac{kW}{kW}$


S.G. 1.0

Temp. NOR.

Vis.



CAPACITIES (m³/min)




Date: Aug. 7 '80

EBARA CORPORATION

DWG. NO.

RA10191-83



- | SIGNS | SIZE | CONNECTING PLACE | PARTS at the shipment |
|-------|-------|---------------------------------|---------------------------------------|
| PN | PS1/2 | Outlet of oil lubricating water | Oil Piping |
| LN | PS1/2 | Entrance of lubricating water | Piping outlet |
| GO | PS1/2 | Outlet of compound gauge | Piping outlet |
| A1 | PS3/4 | Outlet of the breather | Air breather outlet |
| OH | PS3/4 | Entrance of drainage | 3/8 UNION |

(光 1,481) 80-6


T1: GRAY IRON CASTING
~~T2: STAINLESS STEEL~~

TYPE	FRAME NO.	P	PUMP WEIGHT _{lb}	WATER WEIGHT _{lb}
150VY M	FF240S	352	630 + (0.08 x L')	30 + (0.03 x L')
150VYIM M	FF240S	534	665 + (0.08 x L')	30 + (0.03 x L')
150VYIIM M	FF240S	706	700 + (0.08 x L')	30 + (0.03 x L')
150VYVM M	FF240S	878	735 + (0.08 x L')	30 + (0.03 x L')
150VYVM M	FF240L	878	835 + (0.08 x L')	30 + (0.03 x L')
150VYVM M	FF240S	1050	770 + (0.08 x L')	30 + (0.03 x L')
150VYVM M	FF240L	1050	870 + (0.08 x L')	30 + (0.03 x L')
150VYVM M	FF240L	1222	905 + (0.08 x L')	30 + (0.03 x L')
150VYVM M	FF240L	1394	940 + (0.08 x L')	30 + (0.03 x L')
150VYVM M	FF240L	1556	975 + (0.08 x L')	30 + (0.03 x L')
150VYIM M	FF240L	1728	1010 + (0.08 x L')	30 + (0.03 x L')
200VZ M	EE240S	480	620 + (0.14 x L')	40 + (0.05 x L')
200VY M	GG240S	465	620 + (0.14 x L')	40 + (0.05 x L')
200VY M	GG240L	465	880 + (0.14 x L')	40 + (0.05 x L')
200VYIIM M	GG240S	735	740 + (0.14 x L')	60 + (0.05 x L')
200VYIIM M	GG240L	735	1010 + (0.14 x L')	60 + (0.05 x L')
200VYIIM M	GG260	735	1460 + (0.15 x L')	60 + (0.05 x L')
200VYIIM M	GG260	1005	1560 + (0.15 x L')	80 + (0.05 x L')
200VYIIM M	GG260	1275	1660 + (0.15 x L')	110 + (0.05 x L')

TYPE	FRAME NO.	P	PUMP WGT.	WATER WGT.
250VZ M	CE240T	580	720 + (0.17 x L)	60 + (0.07 x L)
250VZ M	CE240S	510	720 + (0.17 x L)	60 + (0.07 x L)
250VZ M	CE240T	580	730 + (0.17 x L)	60 + (0.07 x L)
250VY M	GE240S	485	710 + (0.17 x L)	50 + (0.07 x L)
250VY M	GE240L	485	990 + (0.17 x L)	50 + (0.07 x L)
250VY IIM	GE240L	785	1140 + (0.17 x L)	80 + (0.07 x L)
250VY IIM	GE260	785	1530 + (0.19 x L)	80 + (0.07 x L)
250VY IIM	GE260	1085	1680 + (0.19 x L)	100 + (0.07 x L)
250VY IIM	GE260	1385	1840 + (0.19 x L)	130 + (0.07 x L)
300VZ M	BE240N	690	1090 + (0.17 x L)	90 + (0.07 x L)
300VZ M	BE240N	690	1090 + (0.17 x L)	90 + (0.07 x L)
300VZ M	BE240N	690	1100 + (0.17 x L)	90 + (0.07 x L)
300VY M	GF240L	570	1080 + (0.17 x L)	60 + (0.07 x L)
300VY M	GF260	570	1440 + (0.19 x L)	60 + (0.07 x L)
300VY M	GE240L	570	1040 + (0.17 x L)	60 + (0.07 x L)
300VY M	GE260	570	1430 + (0.19 x L)	60 + (0.07 x L)
300VY IIM	GE260	900	1620 + (0.19 x L)	100 + (0.07 x L)
300VY IIM	GE260	1230	1820 + (0.19 x L)	140 + (0.07 x L)

FOR MESSRS: WATER SUPPLY PROJECT FOR CAMBODIAN REFUGEE CAMPS				ITEM NO.	
MTG. NO. RA10191		PUMP TYPE 250VY2M		SETS 2	
CAPACITY 6 m ³ /m		HEAD 32 m		REMARKS	
R.P.M. S.S. 1500		DRIVER O.P. 45 kw			
EBARA CORPORATION				DRAWING NO. RA10191-81	

- 44 -



RA10191 250 VY 2M

EBARA CORPORATION DWG. NO. S8-7501614

TYPE VYM WATER LUBE

(#11009) 75-5

NO. 3

PART. No.										PART. No.									
L.	034-1	034-2	039-3	045 142	052-1	057 171-2 172-2	115-3	117-3	171-1	L.	034-1	034-2	039-3	045 142	052-1	057 171-2 172-2	115-3	117-3	171-1
1400-2600(1400)	0	0	2	1	2	1	5	4(3)	1(0)	5600-6800(5600)	1	1	6	3	5	4	11	10(9)	1(0)
2800-4000(2800)	0	1	4	2	3	2	7	6(5)	1(0)	7000-8200(7000)	2	0	6	3	6	5	13	12(11)	1(0)
4200-5400(4200)	1	0	4	2	4	3	9	8(7)	1(0)	8400-9600(8400)	2	1	8	4	7	6	15	14(13)	4(0)

244	SUCTION STRAINER	: 空 気 抜	SS41 & SUS304	1	
285	AIR BREATHER	: 空 気 抜	POLY CARBONATE	1	
277-2	"V" RING	: "V" リ ン グ	RUBBER	1	
277-1	"V" RING	: "V" リ ン グ	RUBBER	1	
274	SNAP RING	: 止 め 輪	SK5	1	
255	LEVEL GAUGE	: 油 面 計	Bs & ACRYL	1	
177	DISCHARGE BEND PIPE	: 吐 出 曲 管	FC20	1	
172-2	INTERMEDIATE TUBE	: 中 間 内 管	SGP	6	
172-1	UPPER TUBE	: 上 部 内 管	SGP	1	
171-2	INTERMEDIATE COLUMN PIPE	: 中 間 外 管	FC20	6	
171-1	UPPER COLUMN PIPE	: 上 部 外 管	FC20	1	
168	BASE	: ベ ー ス	FC20	1	
167	PEDESTAL	: 柱 受 台	FC20	1	
162	MOTOR FRAME	: モ ー タ 台	SS41	1	
147	FLEXIBLE SHAFT COUPLING	: 弾 性 軸 手	FC20	1 SET	
142	SOCKET TYPE SHAFT COUPLING	: ソケットカップリング	SUS420J1	4	
129	SHAFT NUT	: 軸 頂 ナット	SS41	1	
123	COUPLING BOLT	: 軸 継 手 ボルト	SS41 & RUBBER	8	
120	SET BIS	: セ ッ ト ビ ス	SCM435	1	
119	GLAND PACKING	: グランドパッキン	VALQUA #134	3	
117-4	GASKET	: ガ ス ケ ッ ト	VALQUA #1501	2	T = 0.5 n
117-3	GASKET	: ガ ス ケ ッ ト	VALQUA #1501	13	T = 0.5
117-2	GASKET	: ガ ス ケ ッ ト	VALQUA #1501	1	T = 0.5
117-1	GASKET	: ガ ス ケ ッ ト	PAPER	1	T = 0.2
115-3	"O" RING	: "O" リ ン グ	RUBBER	15	G - 65
115-2	"O" RING	: "O" リ ン グ	RUBBER	1	G - 115
115-1	"O" RING	: "O" リ ン グ	RUBBER	1	
114	OIL SEAL	: オイルシール		1	TB - 2011513
107	LINER RING	: ライナリング	BC6	4	2n
091	GLAND	: パッキン押入	BsF	1	
064	OIL RESERVOIR	: 油 筒	SS41 & SGP	1	
057	INTERMEDIATE BEARING SUPPORT	: 中 間 軸 受 支 え	FC20	6	
056	BALL BEARING	: 玉 軸 受		1	# 6314
053	BEARING COVER	: 軸 受 カバ ー	FC20	1	
052-3	SLEEVE BEARING - CASING	: ケーシング用軸受	FC20 & GRAPHITE	1	n-1
052-2	SLEEVE BEARING - TOP CASING	: 上部ケーシング用軸受	FC20 & GRAPHITE	1	
052-1	SLEEVE BEARING - INTERMEDIATE	: 中 間 軸 受	FC20 & GRAPHITE	7	
051	BEARING CASING	: 軸受ケーシング	FC20	1	
048	IMPELLER NUT	: 羽 根 車 ナット	SUS316	1	
046	SPLIT RING	: 割 リ ン グ	SUS420J1	4 SETS	
045	DISTANCE PIECE	: ディスタンスピース	SUS420J1	1	n-1
044	BEARING ADAPTER	: 軸 受 アダプタ	SS41	1	
041-2	SHAFT SLEEVE	: 軸 ス リ ー ブ	SUS420J1	2	n
041-1	PACKING SLEEVE	: パッキン用スリーブ	SUS420J1	1	
039-4	KEY	: キ ー	SUS316	2	n
039-3	KEY	: キ ー	SUS316	8	
039-2	KEY	: キ ー	S45C	1	
039-1	KEY	: キ ー	S45C	1	
034-2	INTERMEDIATE SHAFT - LOWER	: 下 部 中 間 軸	SUS420J1	1	L = 1400
034-1	INTERMEDIATE SHAFT	: 中 間 軸	SUS420J1	2	L = 2800
033	UPPER SHAFT	: 上 部 軸	SUS420J1	1	
032	PUMP SHAFT	: ポ ン プ 軸	SUS420J1	1	
021	IMPELLER	: 羽 根 車	BC6	2	n
008	STUFFING BOX	: スタフingボックス	FC20	1	
006	BOTTOM CASING	: 下 部 ケーシング	FC20	1	
005	INTERMEDIATE CASING	: 中 間 ケーシング	FC20	1	n-1
004	TOP CASING	: 上 部 ケーシング	FC20	1	
PART NO.	NAME OF PART	MATERIAL (JIS)	NO. FOR 1 SET	REMARKS	

FOR MESSRS. WATER SUPPLY PROJECT
FOR CAMBODIAN REFUGEE CAMPS

ITEM NO.

MFG. NO.

RA10191

PUMP TYPE

Z50VY2M

SETS

2

EBAHA CORPORATION

DRAWING NO.

RA10191-82

(光 1.447) 13-12

GENERAL SECTION VIEW DWG. NO. S8-7501614

MODEL 2 VZ 多 分 割

- 46 -

