

CHAPTER 4

GEOLOGY



CHAPTER 4 GEOLOGY

4.1 Nam Chon Site

(1) Reservoir Geology

(a) Reservoir Scale and Investigation Method

The reservoir scale of the Upper Quae Yai Project is as indicated below.

Dam height	185 m
Normal high water level	370 m
Catchment area	4,908 km ²
Reservoir surface area	137 km ²

The investigations and study methods used to clarify the reservoir watertightness were as listed below.

- Aerial photogeological interpretation
- Summit level analysis
- Drainage pattern analysis
- Surface geologic survey
- Chemical analysis of river water and rocks

The summarizations of these investigations and studies are shown in Figs. 4-1, 4-2 and 4-3, and Tables 4-1 and 4-2.

(b) Topography

The topography may be broadly divided into the two areas below.

- Area along Quae Yai mainstream

The area is along the mainstream excluding the vicinity of the confluence with the Mae Chan River. The slopes at

the right and left banks are extremely steep and the whole valley is in the form of a long gorge. The average valley width at the high water level elevation of 370 m is less than 420 m. The river gradient is approximately 1/400 and many rapids are formed at the riverbed.

• Area along Mae Chan river

The Mae Chan river is the largest tributary in the project area which joins the Quae Yai river at the right bank approximately 28 km upstream from the damsite. The river width is large and as a whole a hill area of gentle relief is indicated. The maximum reservoir width at El. 370 m is approximately 7 km.

(c) Geology

The general geological stratigraphic sequence of the project area is indicated in Table 4-1. Excepting the area along the Mae Chan river, river deposit, slope wash and large-scale landslide topography are not seen in the reservoir area, and therefore, descriptions of these will be omitted in this Report.

Regarding the formations distributed, Tertiary deposits consists of unconsolidated sand-gravel and silt. Formation D consists of limestone and dolomite, Formations C and B of calcareous sandstone, shale, etc., and Formation A of sandstone, shale, slate, etc.

Besides these sedimentary rocks, there are distributions of metamorphic and igneous rocks in the vicinities of the eastern and western watersheds.

Of the formations distributed, the one requiring the most attention in connection with watertightness of the reservoir is Formation D. Regarding the other formations, judged by data on the water flow conditions of tributaries, results of chemical analysis of rocks, etc., they are regarded as the impervious or semi-impervious rocks.

The detail of geology and geologic structure of the reservoir is reported in Appendix 2 and the reasons assured the reservoir watertightness are described below.

(d) Conclusions

- The formations comprising the backbones of the eastern and western watersheds consist of non-calcareous rocks. These rocks can serve as reliable barriers against leakage to other catchment areas.
- Formation D which is considered as a risky rock with respect to leakage is widely distributed in the northeastern part of the catchment area. However, this distribution is gradually narrowed at the left bank (eastern side) of the damsite and vanishes at a place of elevation approximately 700 m in the southern part of the left bank of the damsite. Consequently, this Formation D is enclosed on the whole by Formations A, B and C.

- Formation D distributed at places other than the above, especially the right bank at the damsite, is at an elevation above the high water level of 370 m. Further, Formation D seen at the right bank approximately 5 km upstream of the damsite is continuous to below the reservoir surface, but the thickness of this Formation D is small, and it is judged from results of geological investigations that the boundary between Formation D and the underlying Formation B is above the reservoir high water level.
- Swallets have not been found in formations other than Formation D, while running water is seen throughout the year at the main gullies having formations other than Formation D as their basement rocks. This indicates that formations other than Formation D, even if calcareous, have adequate resistance against karstic erosion, and that ample watertightness is possessed as a whole.
- According to chemical analysis results of rock samples collected from various formations, as indicated in Table 4-2, there are fairly large differences in CaCO_3 and MgCO_3 contents of samples from Formation D and samples from other formations. And, these differences in contents indicate that Formation A, B and C have stronger resistances against karstic erosion compared with Formation D.
- On comparisons of SiO_2 contents in rocks, the contents in Formation D samples are less than 1%, whereas samples from other formations contain 5% or more. Other than SiO_2 contents, according to microscopic examinations of the rocks, a layer

arrangement of several millimeters of SiO_2 mineral is recognized on the calcareous sandstone of Formation B. And, according to results of drillholes, karstic erosion has not progressed at deep parts in Formation B at the left bank of the damsite. It may be judged from this phenomenon that the above-mentioned SiO_2 contents and mineral arrangement provide strong resistance against karstic erosion.

(2) Site Geology

(a) Selection of Damsite

As mentioned below, the detailed studies of the damsite selection were carried out on the previous stages (preliminary and pre-feasibility stages) and the two site (No.6 and No.9A sites) were selected from 12 alternative as the representative damsites to evaluate development scheme of this Project.

However, No.5 and No.6 sites are close each other and they have similar topographic conditions.

Some detailed surface geological investigations were, therefore, done to compare both sites, and it was judged that No.6 site (Nam Chon site) is superior to No.5 site. Consequently, the Nam Chon site was selected as a representative damsite to compare with No.9A site, because No.5 site has many unknown geological problems as mentioned in the Chapter of Damsite Selection in Appendix 2.

Regarding the proposed damsites of this Project, comparison studies of the development schemes were made for the Nam Chon site (Site No.6) and the No.9A site in the Preliminary Report (August

1978, EGAT) and the Pre-feasibility Report (June 1979, EGAT). As a result, superiority of the Nam Chon site is cited in the two reports. Studies of the two sites (Nam Chon site and No.9A site) are made in Chapter 6 of this feasibility report, and a conclusion has been obtained that Nam Chon site is suitable as the damsite for this Project. It may be said from geological viewpoints also that subjects to be solved would be fewer with the Nam Chon site.

(b) Outline of Geology

The surface deposit distributed at the damsite is as a whole thick on the right bank and thin on the left. On the right bank, it is widely distributed at high portion above El. 360 m, and according to seismic prospecting, the thickness is from 4 m to 10 m. Besides the above, in the vicinity of approximately 600 m upstream of Huai Tong Thai, talus deposit of horizontal thickness of approximately 9 m and approximately 18 m has been confirmed by Test Adits AR-1 (El. approximately 206 m) and AR-2 (El. approximately 302 m), respectively. Judging by geological conditions inside the adits, the slope which the adits are located is considered to be a creep zone. At the left bank, deposit of thickness approximately 12 m has been confirmed by Drillhole L-6 near the river bank, but at all other drillholes the surface deposit is thin at less than 1 m.

The rocks distributed at the dam and other structure sites are karstic limestone, dolomite, conglomerate and calcareous sandstone.

At the left bank, all areas in which structures are to be layouted consist of good calcareous sandstone.

The four kinds of rocks mentioned above are distributed at the right bank. The stratigraphic sequence and qualities of the rocks at the right bank are as indicated below.

Karstic Limestone and Dolomite	— Dipped 25° - 35° to west (toward mountain)
	Unconformity
Conglomerate	
	Unconformity
Calcareous Sandstone	— Dipped 10° - 30° to west (toward mountain), anticlinal axis exists near river bank

The rocks at the right bank are prominently weathered and cracked as a whole. Particularly, karstic erosion is remarkably seen in the limestone and dolomite at the top. The elevation of this karstic limestone is low in the downstream of the damsite, and is high in the upstream. In other words, the karstic limestone crops out at the riverbed in the vicinity of the confluence at Huai Tong Thai, but is at an elevation of about 400 m approximately 850 m upstream from the confluence. This karstic limestone is a rock mass which continues further downstream from Huai Tong Thai, and since sink holes and underflow streams are seen in the rock mass, this is an important geological point which requires attention to selection of the dam axis.

The conglomerate is prominently weathered near the ground surface and is deteriorated, but is well cemented at fresh portions. Since the gravels in the conglomerate are all calcareous rocks, as has been confirmed with Drillhole R-5, many porous parts which will require careful foundation treatment are found.

The calcareous sandstone which is the basement rock at the right bank is more prominently weathered, cracked, and deteriorated compared with that at the left bank.

The permeability of left bank foundation rock is low as a whole, with 2 to 20 Lu (Lugeon) indicated. The ground-water table is located below 60 m from the ground surface (September 17, 1979). The left bank foundation rock can be judged to be in good condition from the data on permeability and ground-water table in addition to the data of the drillholes.

The permeability of the right bank foundation rocks indicates more than 20 Lu while the ground-water table is generally deep being from 50 m to 85 m from the surface. Particularly, ground-water has not yet been confirmed in the karstic limestone rock mass. It is necessary for additional investigations to confirm the ground-water table at the wider area of the right bank.

The fault at this site may be summarized as described below.

- Faults have been confirmed by a number of drillholes made at the right bank, but these faults have not yet been verified at the ground surface because of covering by slope wash. On the whole, faults at the right bank are more soft and brittle than those at the left bank.
- There are two prominent cliffs formed at the left bank. There are faults of dips of 30° - 40°S (toward mountain), and sheared zone widths of 1-2 m at the bottoms of these cliffs, but these sheared zones are tight, with some parts

reconsolidated. Other faults confirmed by drillholes are tight compared with sheared zones at the right bank.

- It was confirmed that faults exist at the riverbed through Drillholes R-1 and L-4. Sheared zones are tight and permeability low, but the permeability of cracked zones in the surroundings is high.
- It has been confirmed through Drillholes PH-2, 3 and 5 that fault exists at the gully at the left bank immediately downstream of the damsite.

(c) Geological Investigation Works Completed

The geological investigations carried out between April 1978 and August 1979 are as indicated below.

- Surface geological investigations of dam and other structure sites, 1/1,000 geological maps
- Surface geological investigations of quarry and soil borrow areas, 1/5,000 geological maps
- Drilling Investigations

	Drillhole	
Damsite	16	1,199 m*
Powerhouse site	5	184 m*
Penstock site	3	400 m*
Quarry (2 sites)	5	200 m
Total	29	1,983 m

* Including permeability tests

- Test Adit

Damsite 3 adits (left bank 1, right bank 2) 90 m

- Seismic Prospecting

Area of talus deposited at high elevations on right bank

9 measuring lines 4.77 km

(d) Geological Considerations Regarding Design and Construction

According to the geological investigations completed, the foundation rock at the left bank consisting of hard and massive calcareous sandstone is low in permeability (2 - 20 Lu), while groundwater distribution is also good, and it can be judged that there are no serious problems regarding the dam abutment and foundation rock for other structures.

Faults exist at the riverbed of this site which consists of calcareous sandstone similar to that at the left bank, but these riverbed faults can be coped with by thorough foundation treatment.

The foundation rocks at the right bank are complex compared with the left bank and the riverbed, and karstic limestone, dolomite, conglomerate and calcareous sandstone are seen. These rocks are prominently weathered and cracked on the whole, and judged from the permeability (more than 20 Lu) and the groundwater distribution, it may be said they are deteriorated compared with foundation rock at the left bank. Particularly, there is a creep zone near the downstream end of the proposed damsite, while above approximately El. 320 m at this place, there is distribution of karstic limestone continuing to Huai Tong Thai.

Needless to say, geological problems as described above can be solved by means of removal of poor quality portions and careful foundation treatment. However, in the event of the dam axis is selected upstream as shown on Fig. 4-4, it will be possible to avoid these geological problems. Especially, the karstic limestone continuing to Huai Tong Thai is distributed above El. 400 m at this place, and this may be said to be a favorable condition from the viewpoints of reservoir watertightness near the dam and of dam foundation treatment.

Furthermore, the additional geological investigations recommended in (3) of this Chapter are necessary for detail design and should be carried out without delay.

(3) Recommendations for Additional Geological Investigations

The additional geological investigations indicated in Table 4-3 and Fig. 4-4 should be completed before detail design is started.

The additional investigation work quantities including the quarry and filter material borrow areas are as indicated below.

◦ Dam and Other Structure Sites

Drillhole	21	1,930 m
Test adit	2	120 m

◦ Quarry and Filter Material Areas

Drillholes	32	750 m
Total		
Drillholes	32	2,680 m
Test adits	2	120 m

4.2 Thi Khong Site

(1) Geology of Regulating Pond

The Thi Khong damsite is located approximately 8 km downstream of the Nam Chon damsite. The geology between the two sites, except for the vicinity of the Thi Khong damsite, consists of limestone at parts of high elevation. Consequently, caves are formed here and there at cliffs facing the river, and this comprises a problem as the foundation of a large-scale reservoir. However, the high water level of this regulating pond will be at El. 197 m, only a raise in water level of about 10 m above the present river surface. Further, as a result of surface geological investigations, it has been confirmed that the low elevation parts in the pond area consist mainly of dolomite, and that at the tributaries in the regulating pond there are confirmed outcrops of calcareous sandstone and shale as the basement rock under the dolomite. Based on these geological conditions, it may be judged that the watertightness of this regulating pond will be no problem.


(2) Foundation Rock of Structure


The topography at the damsite shows slopes of approximately 25° at the right bank and approximately 30° at the left bank. The left bank shows a uniform slope as a whole, but at the right bank there is a cliff formed at a location approximately 200 m distant from the river bank. In selection of the dam axis, care was exercised to make it as distant as possible from the cliff to avoid collapses. The riverbed elevation is 180 m and the width approximately 40 m.


The damsite, except for localized outcrops at the riverbed, is covered as a whole by slope wash. The thickness of the cover is


approximately 4 m at the right bank dam axis, and approximately 8 m at the left bank dam axis. The foundation rock is red-to-light green calcareous siltstone, and according to the results of drillholes carried out at both abutments, good cores have been collected, while with regard to permeability, 10 to 47 Lu are indicated at the right abutment between 0 to 20 m in depth, and 5 to 19 Lu between 20 to 30 m in depth, while similarly, at the left abutment, 20 - 30 Lu are indicated between 0 and 20 m, and then 4 - 20 Lu. According to these data, the permeability of the foundation rock is high as a whole, but drilled cores have few seams and good cores have been recovered so that it may be judged that the bedrock can be adequately improved by means of grouting.


Although there are no geological problems as the foundations for the planned dam and powerhouse, it will be necessary for the recommended riverbed drillhole to be carried out.

















Table 4-1 General Geologic Sequence of Upper Quae Yai Project Area

Era	Stratigraphic Unit	Rock	Main Distribution	Characteristic
Cenozoic	Quaternary to Tertiary System Unconformity	Gravel, Sand, Silt and Clay	Junction between Mae Chan & Quae Yai	Moderately consolidated, horizontal bedding
Mesozoic	Intrusive rock Intrusion	Granite	at eastern & western divide	Medium to coarse biotite Granite
Palaeozoic	Formation D	Massive pure LS (locally bedded), cataclastic Dolomite, Dolomitic LS, near base often Red Conglomerate	Many places, especially eastern half of catchment area, except both divides	Remarkable karstic phenomena, folded
	Unconformity or Disconformity Formation C	Shale, Sandstone, calcareous Sandstone, Conglomerate and thin impure LS. locally alternation	Whole project area	Thick deposit, folded
	Formation B	Banded calcareous Sandstone, banded sandy LS. alternation of Sandstone & Shale and locally lenticular LS.	Along main river including proposed dam-site and other many places	Massive, folded, partially strongly folded and rock like Schist locally
	Formation A	Quartzite, Sandstone, Slate and like Schist	Along eastern divide and continuously from Srinagarind reservoir area	Very hard, thick deposit
	Metamorphic rocks	Schist and semi Schist	At both divides and about 20 km downstream of damsite	Locally show gneissose structure

Table 4-2 Quantitative Analysis of Calcareous Rock

Locality No.	Locality	Rock Name	Result of analysis		1/ Result of norm calculation		2/ Result of norm calculation		4/
			Composition	% (wt)	Composition	% (wt)	Composition	% (wt)	
①	Right bank near No. 8 site	Dolomitic limestone (Formation D)	CaO	51.6	CaCO ₃	92.0	CaCO ₃	87.2	1
			MgO	2.4	MgCO ₃	4.5	CaMg(CO ₃) ₂	9.3	
			SiO ₂	2.3	—	—	SiO ₂	2.3	
			Al ₂ O ₃	0.36	—	—	Al ₂ O ₃	0.36	
			Total	56.66	Total	96.5	Total	99.16	
②	Sink hole at left bank of Huai Tong Thai EL. 470m	Calclitic dolomite (Formation D)	CaO	35.1	CaCO ₃	62.64	CaCO ₃	19.93	2
			MgO	17.2	MgCO ₃	35.98	CaMg(CO ₃) ₂	78.69	
			SiO ₂	0.2	—	—	SiO ₂	0.2	
			Total	52.5	Total	98.62	Total	98.64	
③	Right bank of Huai Tong Thai EL. 250m	Dolomite (Formation D)	CaO	32.3	CaCO ₃	57.64	CaCO ₃	8.72	
			MgO	19.7	MgCO ₃	41.21	CaMg(CO ₃) ₂	90.13	
			SiO ₂	0.1	—	—	SiO ₂	0.1	
			Total	51.6	Total	98.85	Total	98.86	
④	Right bank of Huai Tong Thai EL. 430m	Dolomite (Formation D)	CaO	30.9	CaCO ₃	55.14	CaCO ₃	2.75	
			MgO	21.1	MgCO ₃	44.13	CaMg(CO ₃) ₂	96.52	
			SiO ₂	0.2	—	—	SiO ₂	0.2	
			Total	52.2	Total	99.27	Total	99.47	
⑤	Huai Du Ngau EL. 590m	Calclitic dolomite (Formation D)	CaO	30.8	CaCO ₃	55.0	CaCO ₃	14.6	
			MgO	20.3	MgCO ₃	38.1	CaMg(CO ₃) ₂	78.5	
			SiO ₂	1.3	—	—	SiO ₂	1.32	
			Al ₂ O ₃	0.33	—	—	Al ₂ O ₃	0.33	
			Total	52.73	Total	93.1	Total	94.73	
⑥	Left bank near No. 2 site	Dolomite (Formation D)	CaO	30.6	CaCO ₃	54.61	CaCO ₃	1.72	
			MgO	21.3	MgCO ₃	44.55	CaMg(CO ₃) ₂	97.44	
			SiO ₂	0.1	—	—	SiO ₂	0.1	
			Total	52.0	Total	99.16	Total	99.26	
⑦	Huai Pachi EL. 790m	Calcareous shale (Formation C)	CaO	2.2	CaCO ₃	3.9			5
			MgO	1.8	MgCO ₃	3.4			
			SiO ₂	58.8	—	—			
			Al ₂ O ₃	19.20	—	—			
			Total	92.0	Total	7.3			
⑧	Left bank at Nam Chon damsite	Banded sandy limestone (Formation B)	CaO	39.3	CaCO ₃	70.13	CaCO ₃	65.42	7
			MgO	1.9	MgCO ₃	3.97	CaMg(CO ₃) ₂	8.68	
			SiO ₂	20.2	—	—	SiO ₂	94.3	
			Total	61.4	Total	74.1	Total	94.3	
⑨	Left bank near Nam Chon damsite	Banded sandy limestone (Formation B)	CaO	2.2	CaCO ₃	84.6	CaCO ₃	78.8	
			MgO	1.2	MgCO ₃	2.3	CaMg(CO ₃) ₂	4.66	
			SiO ₂	7.3	—	—	SiO ₂	5.16	
			Al ₂ O ₃	3.43	—	—	3/ CaAl ₂ Si ₂ O ₈	9.45	
			Total	59.33	Total	86.9	Total	98.07	
⑩	Huai Tong Thai EL. 480m	Banded sandy limestone (Formation D)	CaO	49.9	CaCO ₃	89.1	CaCO ₃	87.9	
			MgO	0.6	MgCO ₃	1.13	CaMg(CO ₃) ₂	2.33	
			SiO ₂	5.9	—	—	SiO ₂	5.9	
			Al ₂ O ₃	1.54	—	—	Al ₂ O ₃	1.54	
			Total	57.94	Total	90.23	Total	97.67	
⑪	Huai Ong Thang Yai (downstream of Nam Chon damsite) EL. 250m	Quartzite (Formation A)	CaO	0.0					10
			MgO	0.6					
			SiO ₂	89.1					
			Al ₂ O ₃	4.44					
			Total	94.14					

1/ All CaO are calculated as CaCO₃ and all MgO are calculated as MgCO₃.2/ All MgO are calculated as CaMg(CO₃)₂ and remaining CaO are calculated as CaCO₃.3/ Al₂O₃ is calculated as CaAl₂Si₂O₈ (Anorthite) by way of example.

4/ Locality No. for micrograph of rock sample.

Quantitative Analysis of Limestone at Khao Laem Damsite (Quae Noi River)

Locality	Rock Name	Result of analysis		Result of norm calculation		Result of norm calculation	
		Composition	% (wt)	Composition	% (wt)	Composition	% (wt)
Inside of gallery at right bank	Limestone (Formation D)	CaO	54.2	CaCO ₃	96.72	CaCO ₃	94.24
		MgO	1.0	MgCO ₃	2.09	CaMg(CO ₃) ₂	4.57
		SiO ₂	0.2	—	—	SiO ₂	0.2
		Total	55.4	Total	98.81	Total	99.01

Table 4-3

Location of Additional Drill Hole

Site	Hole No.	X	Y	EL(m)	Direction	Length(m)
Dam	R-9	490445E	1682800N	220	N90°W 50°	100
	R-10	490400	1682725	240	N90°E 160°	130
	R-11	490345	1682800	280	90°	80
	R-12	490215	1682820	380	90°	80
	R-13	490200	1682755	380	90°	80
	R-14	490265	1682755	335	90°	80
	R-15	490320	1682700	290	90°	100
	R-16	490095	1682655	470	90°	150
	R-17	490160	1682600	410	90°	130
	R-18	490150	1682415	400	90°	100
R-19	490400	1682265	200	N90°E 60°	100	
L-7	490535	1682725	240	S65° E 50°	100	
L-8	490450	1682640	River bottom	90°	50	
R-20	490270	1682650	335	90°	130	

Site	Hole No.	X	Y	EL(m)	Direction	Length(m)
Quarry	Q-4	487000E	1681600N	540	90°	60
	Q-5	487600	1681600	540	90°	60
	Q-6	488100	1681400	560	90°	80
	NQ-1	489290	1681300	475	90°	80
	NQ-2	489430	1681300	530	90°	100
	NQ-3	489500	1681130	530	90°	100
	NQ-4	489290	1681050	475	90°	50
	NQ-5	489430	1680920	530	90°	100
Sub-Total	8 Holes					630m
Borrow	BB-1	485300E	1682310N	560	90°	10
	BB-2	485300	1682300	560	90°	40
	BB-3	485300	1681860	540	90°	40
Sub-Total	3 Holes					120m
	Drill Holes Total					32 Holes
						2,680m

* No permeability test hole

Location of Adit						
Site	Adit No.	X	Y	EL(m)	Direction	Length(m)
Dam	AR-3	490340	1682765	290	N70° W	60
	AR-1	490230	1682630	360	N80° W	60
Adits Total						120m

CHAPTER 5

MATERIALS

CHAPTER 5 MATERIALS

5.1 Materials for Nam Chon Dam

(1) Impervious Soil Core Materials

Borrow areas for impervious soil core materials are located at both sides of Huai Tong Thai approximately 6 km west of the Nam Chon Damsite. The foundation rock of this site consists of sandy limestone, shale and dolomite. Soil materials investigations were mainly made on the shale layer distributed in the north-south direction in the form of a belt approximately 2 km in width, and 30 test pits of depths ranging from 1 to 5 m were excavated. The locations of the test pits are indicated in Fig. 5-1.

As a result of surface reconnaissance and observations of test pits, the materials at this site may be broadly divided into weathered shale, talus deposit of shale, fine-grained terrace deposit, coarse-grained terrace deposit, and talus deposit of dolomitic limestone depending on the topography, mother rock, and degree of weathering.

(a) Test Items and Test Quantities

The items and quantities of tests performed on samples taken from every 1 m depth of the test pits and representative samples classified based on gradation are as indicated below.

Test Item	Sample from Every 1 m Depth	Representative Sample
Water content on arrival	100	-
Specific gravity	11	9
Gradation	97	-
Atterberg's limits	100	6
Compaction		
ASTM D 698, A Method	10	-
ASTM D 698, C Method	22	6
ASTM D 1557, C Method	--	6
ASTM D 1557, D Method	--	3
Permeability	-	9
Triaxial compression	-	3
Gradation after compaction	-	6

(b) Selection of Representative Samples

Based on the test results of samples collected from every 1 m depth in the test pits, the materials at this site were classified as indicated below depending on content of materials passing 0.075 mm sieve and under.

Fine, -0.075 mm content	30%+
Medium, -0.075 mm content	30 - 15%
Coarse, -0.075 mm content	15%-

Representative samples were selected from the weathered shale, talus deposit of shale, and fine-grained terrace deposit.

(c) Test Results and Considerations

The test results of representative samples are indicated in Table 5-1, and the conditions of distributions of the various materials in Fig. 5-2. Based on field reconnaissances and test results, the following can be considered regarding the materials

at this site:

- The impermeability of the core materials at this site are considered to be the following based on results of gradation tests and permeability tests on representative samples.
The coefficients of permeability of fine-grained and medium-grained materials at optimum water contents are from 1.3×10^{-8} to 3.8×10^{-8} cm/sec. The contents of gravels larger than 19.1 mm (3/4") in these materials are less than 25%, and it is judged that an impermeability of core materials can be obtained. Permeability tests of coarse-grained materials were performed on samples of minus 0.075 mm size content more than 9%. As a result, the coefficients of permeability were indicated to be from 2.0×10^{-7} to 4.5×10^{-8} cm/sec. However, since there are coarse-grained materials containing more than 40% of sizes over 19.1 mm (3/4"), it is desirable for permeability tests using large-sized mold to be carried out.
- The strength constants of soil, according to triaxial compression tests performed at AIT, in terms of angle of internal friction ($\bar{\phi}$) obtained by effective stress analysis were 20° to 27° , while in terms of cohesion (\bar{c}) they were 0.8 to 1.3 kg/cm².
- Judging the materials of this site from the results of the various tests, the talus deposit of weathered shale has relatively fine-grained material at the ground surface and tends to become coarser as the depth increases. However, the coarse materials are also comparatively weathered, and considering crushing and mixing during borrowing by heavy machinery, it is thought material in a fairly depth can be used.

Terrace deposit having high contents of fine-grained soil is of 27 to 74% contents of sizes 0.075 mm and under, and especially, the contents around P-25 are 54 to 74%. It is desirable for this fine-grained material to be blended with coarse-grained weathered shale distributed in the vicinity to improve quality.

- Talus deposit with dolomitic limestone as the base rock comprises silty soil with low dry density of 1.35 to 1.45 t/m³ to indicate different properties from other materials, and are not desirable as impervious core materials.

(d) Estimated Available Quantities

Based on the above, the estimated available quantities at this site are the following:

Weathered shale	2,050,000 m ³
Talus deposit of shale	840,000 m ³
Terrace deposit of fine-grained soil	1,560,000 m ³
Total	4,450,000 m ³

The requirement for 1,800,000 m³ of impervious core material of Nam Chon Dam will thus be satisfied.

(2) Filter Materials

Since riverbed deposit having suitable particle sizes is not found in the vicinity of the Nam Chon damsite, it will be necessary to make filter materials artificially from quarry materials, or, to investigate materials having the proper particle sizes. One candidate site will be Area A-1, but it is also desirable for investigations to be made of deeper parts of the borrow areas.

(3) Rock Materials

The quarry site A-1 originally planned is at the right bank of the Huai Tong Thai approximately 2 km to the west from the Nam Chon Damsite. Three drillholes were made at this quarry site. According to the boring cores, the rock here is crushable dolomite and readily becomes fragmented. Consequently, it cannot be collected in the form of large blocks, but it is conceivable for use as a part of rock materials or as transition materials.

EGAT carried out two drillholes at Site B along the Huai Nam Chon approximately 1.8 km downstream from the dams site as another quarry site. As a result, it was found that Site B consists of calcareous sandstone and extremely good cores were recovered. Judging from these investigations, this site is a fairly good candidate source of rock materials and concrete aggregates.

However, when conditions such as transportation roads are considered, it is desirable for the investigation area at Area A along the Huai Tong Thai indicated in Fig. 5-1 to be expanded.

Other than the above, the excavation material from sites of structures such as the powerhouse and spillway consists of calcareous sandstone and can be used as good rock material.

(4) Concrete Aggregates

Regarding concrete aggregates, since natural materials are not seen in this vicinity, it will be necessary for them to be manufactured artificially from quarry materials. Materials from the rock material candidate site A-1 cannot be expected very much to serve as concrete aggregates.

Site B at the Huai Nam Chon consists of calcareous sandstone which has been judged to be material of good quality as a result of boring. On looking at the results of tests on materials collected from outcrops at Site B, values of 1.55% for soundness and 15.1% for abrasion loss are indicated, and this site can be said to be superior as a source of concrete aggregates.

(5) Recommendations for Additional Investigations

(a) Impervious Soil Core Materials

The investigations required to be made based on the results of studies up to the present in order to carry out future detail design are the following:

• Location of Test Pit

22 pits (locations shown in Fig. 5-1)

• Test Item

Tests on samples taken at every 1 m depth in all test pits:

Water content on arrival

Specific gravity

Gradation (full-size sample)

Atterberg's limits

Tests on representative samples:

* Selection of representative samples

Representative samples are classified as indicated below according to geological conditions and grain-size distributions.

Weathered Shale

Fine, -0.075 mm	content: 30%+
Medium, -0.075 mm	content: 15 - 30%
Coarse, -0.075 mm	content: 15%-

Talus Deposit of Shale

Fine, -0.075 mm content: 20%+
Coarse, -0.075 mm content: 20%-

Terrace Deposit with fine-grained soil

Terrace deposits with fine-grained soil are distributed at three locations around this site. One test pit at each site or a total of three test pits are selected from these three places.

* Test items and numbers of test samples

The test items and the numbers of test samples selected are indicated in Table 5-2.

(b) Filter Materials

On investigations for filter materials, 3 drillholes have been planned in the shale formation at the borrow area as indicated in Chapter 4. If judged to be suitable as filter materials as a result of investigations, test adits or test pits will be excavated and specific gravity, gradation, permeability and shear tests required for filter materials carried out.


(c) Rock Materials and Concrete Aggregates

In addition to the A-1 and B sites which have been investigated up to the present, 8 drillholes have been planned at the A-2, A-3 and A-4 sites along the Huai Tong Thai as indicated in Chapter 4, Geology, and Fig. 5-1. The test items and test quantities are as listed below.

Site	A-1	B	A-2	A-3	A-4
Specific Gravity	1	1	1	1	1
Soundness	-	-	1	1	1
Abrasion	-	-	1	1	1
Unconfined compression strength	3	3	3	3	3

5.2 Materials for Thi Khong Dam

The surroundings of Thi Khong Damsite consists of limestone. The results of surface investigations show this limestone to be hard and it can be expected to serve adequately as concrete aggregate.






Table 5-1 Results of Soil Tests for Representative Samples

Area No.	Sample No.	Depth (m)	Soil Classification		Water Content as received (%)	Specific Gravity	Atterberg Limits			Gradation						Compaction*1 & Permeability (I)		
			Unified System	Revised P.R. System			L L (%)	P L (%)	P I	-38.1 ^{mm} (1 1/2") (%)	-19.0 ^{mm} (3/4") (%)	-4.75 ^{mm} (No.4) (%)	-2.0 ^{mm} (No.10) (%)	-0.425 ^{mm} (No.40) (%)	-0.075 ^{mm} (No.200) (%)	Optimum Water Content (%)	Maximum Dry Density (t/m ³)	Coefficient of Permeability (cm/sec.)
(Fine Materials)																		
	P - 10	2.5	SC	A-7-6(2)	14.5	2.71	42.2	23.2	19.0		100	90	76	52	37	20.0	1.680	2.8x10 ⁻⁸
	P - 25	3.0	CL	A-6 (5)	12.2	2.61	30.8	17.2	13.6	100	98	92	84	74	54	17.8	1.773	1.3x10 ⁻⁸
	P - 27	1.5	SC	A-7-6(3)	14.8	2.64	40.6	22.8	17.8		100	86	70	52	41	-	-	-
(Medium Materials)																		
	P - 19	1.5	SC	A-2-6(1)	9.9	2.67	36.2	22.1	14.1		100	83	60	37	29	18.5	1.790	2.6x10 ⁻⁸
	P - 26	2.5	GC	A-2-6(0)	7.2	2.70	34.2	20.8	13.4	100	89	49	31	24	21	-	-	-
	P - 29	4.5	SC	A-2-6(0)	14.8	2.71	37.0	19.8	17.2	100	93	66	52	36	22	15.2	1.792	3.3x10 ⁻⁸
(Coarse Materials)																		
	P - 20	4.5	GW-GC	A-2-6(0)	10.4	2.77	36.4	21.5	14.9	100	56	29	19	13	10	17.2	1.753	4.5x10 ⁻⁸
	P - 25	4.7	GC	A-2-6(0)	12.0	2.65	28.1	15.7	12.4	100	89	49	32	21	16	14.6	1.880	1.3x10 ⁻⁸
	P - 27	3.7	GP-GM	A-2-6(0)	15.6	2.64	33.3	24.0	9.3		100	42	27	15	9	-	-	-

Sample	Compaction** & Permeability (II)				Triaxial Compression Strength (CIU) *4			
	Optimum Water Content (%)	Maximum Dry Density (t/m ³)	Coefficient of Permeability (cm/sec.)	Water Content (%)	Total Stress		Effective Stress	
					C (kg/cm ²)	φ (deg.)	C̄ (kg/cm ²)	φ̄ (deg.)
P-10	17.5	1.812 *2	—	—	—	—	—	—
P-25	14.0	1.910 *2	—	—	—	—	—	—
P-27	12.2	1.923 *3	3.8x10 ⁻⁸	12.2	1.2	22.5	0.78	27.0
P-19	14.0	1.904 *2	—	—	—	—	—	—
P-26	11.2	2.010 *3	2.1x10 ⁻⁸	11.2	0.5	19.6	0.96	20.9
P-29	12.4	1.910 *2	—	—	—	—	—	—
P-20	13.6	1.910 *2	—	—	—	—	—	—
P-25	12.2	1.968 *2	—	—	—	—	—	—
P-27	11.3	1.952 *3	2.0x10 ⁻⁷	11.3	2.2	17.8	1.35	27.0

*1 ASTM D 698-70 METHOD C

*2 ASTM D 1557-70 METHOD C

*3 ASTM D 1557-70 METHOD B

*4 Specimens were compacted by ASTM D 1557-70 METHOD B and they were at optimum water content, maximum dry density.

In permeability tests, falling head permeability tests were performed on specimens compacted by ASTM D 698-70, METHOD C (*1) and constant head permeability tests were performed on specimens compacted by ASTM D 1557-70 METHOD B (*3).

Coefficient of permeability is at optimum water content.

Table 5-2 Items of Tests and Quantity of Test Samples

Items of Tests	Weathered Shale			Talus Deposit of Weathered Shale		Terrace Deposit	Total	Note
	Fine	Medium	Coarse	Fine	Coarse			
Water Content as received	3	3	3	2	2	3	16	ASTM D 2216
Specific Gravity								
Fine Particle	3	3	3	2	2	3	16	ASTM D 854
Coarse Particle	3	3	3	2	2	3	16	ASTM C 127
Gradation (Full Size)	3	3	3	2	2	3	16	ASTM D 422
Atterberg Limits								
Liquid Limit	3	3	3	2	2	3	16	ASTM D 423
Plastic Limit	3	3	3	2	2	3	16	ASTM D 424
Compaction	3	3	3	2	2	3	16	* 1
Permeability	3	3	3	2	2	3	16	* 2
Triaxial Compression	1	1	1	1	1	1	6	* 3
Gradation after Compaction Test	3	3	3	2	2	3	16	

- * 1 ASTM D698-70 Method C Used specimens are not to be used
- * 2 5 different water content specimens compacted by ASTM D698-70 Method C shall be tested from each sample. Large Permeability Test shall be applied for coarse samples.
- * 3 4 different confined pressure x 2 different water content (Wopt and Wopt+2%) 8 specimens per sample.

CHAPTER 6

DEVELOPMENT SCHEME

CHAPTER 6 DEVELOPMENT SCHEME

6.1 Fundamentals

Investigations were carried out by EGAT from the backwater end of Srinagarind Reservoir to approximately 160 km upstream in order to effectively utilize the undeveloped water power remaining upstream of Srinagarind Reservoir. According to the results of these investigations, prospective damsites on the Upper Quae Yai where it is judged possible to provide large reservoirs are the Nam Chon site approximately 141 km upstream of Srinagarind Power Station and the No. 9A site located about 20 km still farther upstream.

The study in this Chapter consists of comparing these two sites to select the most suitable one for a large-scale reservoir, and further, of determining the optimum development scheme for the Upper Quae Yai Project.

In order to effectively utilize the abundant flow of the Quae Yai River which is a precious domestic hydro-resource for Thailand, and moreover, is a circulating resource, considerations were given in this study not to remain idle head between Upper Quae Yai and Srinagarind Reservoir.

As described in Chapter 2, the increasing electric power demand in Thailand has been prominent in recent years, and especially, the trend is for the peak portion to be extremely sharp. The power station to be developed as the Upper Quae Yai Project is to be a large-scale peaking power station to carry the peak portion of the demand curve.

The dam constructed at Nam Chon or the No. 9A site is developed to provide a large-scale reservoir as much as possible within limits permitted by topographical and geological conditions and by economical aspects.

In study of the reservoir high water level, the influence of fill-up of this reservoir on the power generating capability of the downstream Srinagarind Power Station is to be taken into consideration, and an optimum scheme is decided.

The electric power increased at the downstream Srinagarind Power Station after completion of the Upper Quae Yai Project is added to the benefit of this Project.

Regarding economic analysis, a detailed one will be made in Chapter 12, but in this Chapter an economic evaluation of the Project with construction costs at 1980 price level without escalation is made, and the optimum scheme will be selected from comparison schemes. Comparison studies were made by B/C and (B-C) and annual cost (C) and benefit (B) during the service life concerned.

The expenses of a hydroelectric power station consist of interest, depreciation, repair costs, and operation and maintenance costs, and the annual cost, considering the service life of this Project, is estimated to be 11.586% of the construction cost. The benefit of a hydroelectric power station is taken to be the annual cost of an alternative power station possessing a capacity equal to that of the hydroelectric power station.

As the alternative for this site, the combined power sources of the gas turbine and oil-fired thermal plant (200 MW x 1) indicated in Table 12-3 were selected.

The fuel cost of the oil-fired thermal plant for calculation of the benefits is nearly equal to US\$24 per barrel which is the minimum price decided at the OPEC meeting held in Caracas in December 1979.

The kW and kWh prices obtained based on the above are as shown below.

Unit kW price :		1,224 Bahts
Unit kWh price :	Firm	1.013 Bahts
	Secondary	0.864 Bahts

6.2 Reservoir Operation Plan and Electric Energy Calculation

(1) Reservoir Operation Plan

The operation rules of the reservoir at Nam Chon or No. 9A to be the key point of the Upper Quae Yai Project are determined considering the following:

- The reservoir is to be operated to store and regulate the inflows of wet years for supplementing in dry years to increase the firm discharges of dry years as much as possible.
- During a year, the reservoir is also to be operated to store inflows during the wet season for supplementing in the dry season.
- Operation of the reservoir is to be done to make it possible for stable electric power to be secured for as long a period as possible.

- The water requirements at the downstream Vajiralongkorn Diversion Dam are to be secured through comprehensive operation of Khao Laem Reservoir and Srinagarind Reservoir.

(2) Electric Energy Calculation

The electric energy is calculated by computer based on the conditions described below and the procedure as shown in Fig. 6-1.

- The monthly runoffs obtained by the seasonal correlation method are used, considering the evaporation from the reservoir surface, calculations are made for the 26 years from April 1952 to March 1978.
- Calculations to determine the reduction in energy production at the downstream Srinagarind Power Station with filling up reservoir of this Project are to be simulated for commence of fill-up from May 1985. For the natural inflow during the filling up period, 1964 - 1966 where the 3 years total inflow is taken to be average is corresponded.
- The downstream water requirements are satisfied with comprehensive operation of Srinagarind Reservoir and Khao Laem Reservoir. Under those requirements, as shown in Table 6-1, used in the calculation during fill-up the values from May 1985 were adopted. And for the calculation after completion of the Project, values at the year 2,000 onward were adopted.
- The operation of Srinagarind Power Station is to secure the minimum energy production 1,440 MWh/day (60 MW). The operation of Khao Laem Power Station is also to secure 1,080 MWh/day (45 MW), same as figures in the Pre-feasibility Report on Upper Quae Yai Project by EGAT.

- The effective output is to be the smaller of the critical maximum output and the equivalent output in the required peaking generation hours.
- The electric energy produced during the required peaking generation hours is to be taken as firm and the energy produced at other times as secondary.
- The Second Stage Project of Srinagarind Power Station (pumped storage) is scheduled to be completed in October 1985 according to the plans of EGAT. Consequently, in the energy calculation after completion, in order to effectively utilize Srinagarind Dam as a multi-purpose one, in case the downstream water requirement is satisfied with the Quae Noi and the remaining catchment area runoff, Srinagarind Reservoir be stored as much as possible, and the minimum energy to be secured at Srinagarind Power Station will be met by the second stage pumped storage power station.

Regarding the period of fill-up, since the downstream water requirements are comparatively small, operation of Srinagarind Reservoir is considered without the operation of the pumped storage power station.

- Storage during fill-up is to be done considering the rate of surface rise of the reservoir and within limits that the downstream water requirements or the minimum energy production to be secured at Srinagarind Power Station can be satisfied.

6.3 Study of Development Scheme

(1) Study of Nam Chon Damsite

(a) Effective Storage Capacity

The mass curve for the Nam Chon dams site based on monthly inflows between 1952 and 1977 is as shown in Fig. 6-2.

The runoff characteristics at this site, as described in Chapter 3, "Hydrology", are that periodical cycle is of about 10 years and the driest year is occurring approximately in the seventh year from top of the mass curve as shown in Fig. 6-2.

The study of the effective storage capacity, as described in the reservoir operation plan of 6.2, is for water of wet years to be carried over to increase the firm discharges of dry years as much as possible, and studies were made for the 3 cases of carry-over of 5 years, 7 years, and, corresponding to the maximum-size development at this site, 10 years.

The firm discharges for the these cases are $81.8 \text{ m}^3/\text{sec}$, $87.9 \text{ m}^3/\text{sec}$ and $93.4 \text{ m}^3/\text{sec}$. The effective reservoir capacities required to secure these firm discharges are $1,670 \times 10^6 \text{ m}^3$, $2,940 \times 10^6 \text{ m}^3$, and $4,100 \times 10^6 \text{ m}^3$. As a result of study, and as can be seen in Tables 6-2, 6-3, and Fig. 6-3, in case of the reservoir high water level being lower than about 365 m, it is slightly more advantageous to make the effective capacity on the small side, while in case of being higher, it will be more advantageous to make the effective capacity $4,100 \times 10^6 \text{ m}^3$, approximately the maximum capacity at this site. This is because a small-scale dam requires a large available drawdown to secure effective capacity.

On comprehensive judgment, it was found that effective capacity of $4,100 \times 10^6 \text{ m}^3$, with which the inflow at this damsite would be about completely regulated, would be the most advantageous. The storage capacity curve of Nam Chon Reservoir used for this study is shown in Fig. 6-4.

(b) High Water Level

It was decided to study the high water level at Nam Chon Dam between elevations of 350 m and 380 m taking into consideration the topographical and geological conditions at the damsite and the reservoir.

Since Nam Chon Dam is to be built upstream of Srinagarind Power Station having a large-scale reservoir, study was made from the hydrological and economical aspects with respect to the period required for fill-up and the reduction in energy production at Srinagarind Power Station during fill-up.

Firstly, the study from the standpoint of hydrology was carried out on the possibility of fill-up from May 1985 to October 1987 when power operation is to be started as indicated in the construction schedule (Fig. 10-1) for this Project. That is, using runoff data for 1952 to 1978, and as a result of studying the storable volume during the fill-up period by stochastic techniques, it was found that up to approximately $5,000 \times 10^6 \text{ m}^3$ can be stored without the influence on the downstream area (see Fig. 6-5).

Because of the above, it was decided to make comparison studies of 13 cases from dead storage of $584 \times 10^6 \text{ m}^3$ to $5,769 \times 10^6 \text{ m}^3$ as indicated in Tables 6-2 and 6-3.

The amounts of energy reduction during fill-up for carrying out economic analyses were estimated by the methods described below.

As can be seen Fig. 3-5, the year 1985 when fill-up is to be started corresponds to an average water year from the standpoint of hydrologic cycles. Then the average years of 3 years total inflows were adopted for the calculations.

Regarding the energy reduction due to fill-up, since there is ample reserve capacity from the standpoint of demand and supply balance, the electric energy reduction was evaluated merely by the unit cost of secondary kWh of thermal, and this was added to the construction cost.

The results of studies are also as indicated in Tables 6-2, 6-3, and Fig. 6-3, and it was found that a high water surface level of 370 m would be the most advantageous.

(c) Maximum Available Discharge

Firm discharge is obtained from inflow and effective storage capacity, but for the firm discharge, it is necessary to decide the maximum available discharge and installed capacity corresponding to the equivalent peaking generation hours demanded from the aspect of demand and supply balance.

As described in Chapter 2, according to studies from the aspect of demand and supply, it will be desirable for the Upper Quae Yai Project to take charge of peaking generation of 5 hours in the daily load curve.

However, based on discussions with EGAT, it was decided to make comparison studies for peaking generation of 4 hours and 5 hours.

In this study, it was assumed there would be no latent capacity in any case. The results of studies, as indicated in Tables 6-4 and 6-5, show that peaking generation of 5 hours is slightly more advantageous from the economical aspects.

In this study, latent capacity was ignored, but since it is considered that the possibility of latent capacity is greater with the case for peaking generation of 4 hours, there is a risk of the economics of the 4-hour case to be further impaired.

(d) Power Plant Location

In order to select the optimum location for the power plant, a dam-type power plant and a water-way type (2 cases), comparison studies of the cases indicated in Fig. 6-6 and Table 6-6 were made between immediately downstream of the Nam Chon damsite and the end of the Srinagarind Reservoir backwater. The results of the studies are as indicated in Table 6-7.

It was made clear that the dam-type power plan in which a power station of maximum available discharge of $460 \text{ m}^3/\text{sec}$ and maximum output of 580 MW is provided would be the most advantageous.

However, by adopting a dam-type power plan, there will be a head remaining between the power station and Srinagarind Reservoir, and it is necessary to make studies from a different viewpoint of schemes such as a two-stage development project as explained in the next section.

(2) Study of Thi Khong Site

As mentioned in the previous section, in order to effectively utilize the head remaining downstream of Nam Chon Power Station, a scheme to provide a dam-type power station having a regulating pond at the Thi Khong site near the end of the backwater of Srinagarind Reservoir was studied.

(a) High Water Level of Regulating Pond

In deciding the high water level of Thi Khong Regulating Pond, the study was made on the premise that the head would be utilized to the maximum within limits that the backwater of Thi Khong Dam does not affect the tailwater level of Nam Chon Power Station. As a result, the high water level of Thi Khong Regulating Pond was at 197 m corresponding with the maximum available discharge at Nam Chon Power Station of $460 \text{ m}^3/\text{sec}$.

(b) Maximum Available Discharge

Since Thi Khong Power Station would carry out power generation corresponding with the power generation discharge of Nam Chon Power Station intact, the operation is peaking generation of 5 hours to be in step with the peaking generation hours of Nam Chon Power Station. Therefore, the maximum available discharge was selected to be $480 \text{ m}^3/\text{sec}$, the maximum available discharge of Nam Chon Power Station

of $460 \text{ m}^3/\text{sec}$ to which was added the daily-regulated runoff of the remaining catchment area at the Thi Khong site.

(c) Regulating Pond Capacity

In order to effectively utilize the remaining runoff at the Thi Khong site during the wet season, an effective capacity of $0.3 \times 10^6 \text{ m}^3$ was set for Thi Khong Regulating Pond during normal operation. As can be seen by the reservoir capacity curve indicated in Fig. 6-7, the available drawdown required to secure this effective capacity is 0.2 m.

Further, since Thi Khong Power Station has 2 units, decided basing on comprehensive viewpoints such as operation, manufacturing, and transportation of electrical equipment, the intake orifice beds were made as low as possible so that even in case one unit cannot be operated for a long period due to faulting or other cause, operation of Nam Chon Power Station will not be hindered and waste overflow will not be produced at Thi Khong. The regulating capacity required under such unusual conditions was estimated approximately $4.3 \times 10^6 \text{ m}^3$. Available drawdown required in these conditions was secured with 3.5 m taking into consideration manufacture and operation of electrical equipment.

It can be said that Thi Khong power plan is economical, as indicated in Table 6-7, according to the results of studies on the conditions without producing remaining head between Nam Chon Power Station and Srinagarind Power Station.

(3) Study of No. 9A Site

The No. 9A site is located approximately 20 km upstream of the Nam Chon site, and the accessibility of this site is worse than that of Nam Chon site. However, a comparison study was made of a large-scale reservoir scheme at the No. 9A site to formulate the optimum scheme for the Upper Quae Yai Project.

(a) No. 9A Dam

◦ High Water Level

Regarding high water level, comparison studies were made of elevations between 370 m and 390 m taking into account the topographical and geological conditions of this site.

The alternative schemes were studied comparatively and the results of the studies are as indicated in Tables 6-8, 6-9, and Fig. 6-8, and as a high water level elevation 380 m is the most advantageous.

◦ Effective Storage Capacity

As the result of study on the Nam Chon site, it was found that a plan where the reservoir inflow could be completely regulated would be advantageous. Because of this, the effective storage capacity for the No. 9A site was made $3,860 \times 10^6 \text{ m}^3$ according to the same kind of manner. The storage capacity curve is shown in Fig. 6-9.

◦ Maximum Available Discharge

The maximum available discharge was made $430 \text{ m}^3/\text{sec}$ with peaking generation of 5 hours similarly to Nam Chon Power Station.

• Power Plant Location

In order to select the optimum location for the power plant, a dam-type power plan and a water-way type, as shown in Fig. 6-10, comparison studies were made between immediately downstream of the No. 9A site and the Nam Chon site. The schemes of the study and the results are indicated in Tables 6-10 and 6-11. As seen in the figure and tables, the dam-type power plan with maximum available discharge of $430 \text{ m}^3/\text{sec}$ and maximum output of 380 MW is more advantageous than the water-way type.

However, the scheme for the No. 9A site was found to be much poorer in economic effect than the scheme for the Nam Chon site.

(4) Optimum Plan of Development Scheme

As the results of the studies of the development scheme for the Upper Quae Yai Project, it is the most advantageous, a large-scale dam-type power plan with a large reservoir at the Nam Chon site which can immediately cope with peak demand and a dam-type power plan with a regulating pond at the Thi Khong site located in the vicinity of the backwater of Srinagarind Reservoir. Plan of this optimum schemes is indicated in Tables 6-12 to 6-14. Reservoir simulations of the Nam Chon are also indicated in Figs. 6-11 and 6-12.

Fig. 6-1 Procedure of Calculation of Power, Energy and Water Requirement




Fig 6-2 Mass Curve at Nam Chon Site




Fig.6-3 Comparison of H.W.L. and Effective Storage Capacity of Reservoir at Nam Chon Site




Fig.6-4 Storage Capacity and Surface Area at Nam Chon Site




Fig.6-5 Relation between Fill-Up Volume and Probability of Exceedence at Nam Chon Site




Fig.6-6 Alternative Location of Nam Chon Power Plant




Fig.6-7 Storage Capacity and Surface Area at Thi Khong Site




Fig. 6-8 Comparison of H.W.L. of Reservoir at No.9A Site.




Fig.6- 9 Storage Capacity and Surface Area at No.9A Site




Fig.6-10 Alternative Location of NO.9A Power Plant




Fig. 6-11 Inflow, Power Discharge and Reservoir Water Surface at Nam Chon Power Station






Fig.6-12 Reservoir Simulation during Fill-Up



Note : Inflow of average years (1964~1965) is adopted for the reservoir simulation during fill-up

Table 6-1 Mae Klong Basin Stage of Water Requirements (Vajiralongkorn) (106m³)

Year	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Jan.	Feb.	Mar.	Total
1977	158.6	176.2	173.4	268.9	240.0	129.6	147.8	259.2	242.4	150.1	150.5	163.4	2,269.1
1978	168.2	182.9	176.5	282.6	252.3	129.6	150.0	273.2	256.6	167.4	160.4	173.3	2,373.0
1979	177.8	189.6	179.6	296.0	264.4	129.6	151.6	287.2	270.8	175.7	176.4	183.2	2,481.9
1980	187.4	196.3	182.7	309.6	276.7	129.6	153.7	300.9	284.7	184.0	180.2	193.1	2,578.9
1981	239.8	223.4	196.5	323.8	287.9	129.6	154.8	315.7	305.9	232.2	234.9	253.6	2,898.1
1982	292.1	250.2	210.5	338.3	299.2	129.6	156.2	330.7	326.8	280.4	289.6	314.4	3,218.0
1983	344.5	277.2	224.2	352.5	310.4	129.6	157.5	345.5	347.9	328.6	356.5	375.0	3,549.4
1984	376.1	331.9	246.2	378.7	339.4	129.6	162.6	373.2	361.6	420.5	450.5	488.0	4,058.3
1985	428.7	407.7	289.0	426.1	389.4	150.3	189.1	422.0	396.4	534.1	575.8	622.2	4,830.8
1986	460.3	462.3	311.0	452.1	418.1	150.3	194.2	450.0	410.1	625.9	682.0	735.0	5,351.3
1987	603.7	501.1	326.3	452.1	418.1	150.3	194.2	450.0	410.1	693.4	786.8	818.0	5,804.1
1988	746.8	540.0	341.6	452.1	418.1	150.3	194.2	450.0	410.1	760.7	837.0	901.0	6,201.9
1989	890.4	579.3	356.4	452.4	418.4	150.3	194.5	450.2	410.3	828.4	914.2	984.3	6,629.1
1990 ~1994	991.2	636.1	396.3	499.3	460.1	176.3	221.2	493.3	463.1	917.4	1,008.3	1,089.0	7,351.6
1995 ~1999	1,027.5	673.6	432.6	536.8	497.6	212.5	258.7	529.5	500.6	954.8	1,042.2	1,126.5	7,792.9
2000 Onward	1,063.8	711.1	468.9	574.2	535.1	248.8	296.2	565.8	538.1	992.3	1,076.1	1,164.0	8,234.4

Table 6-2 Plan of the Alternative Schemes at Nam Chon Site

Item	Unit	Ve = 4,100 x 10 ⁶ m ³					Ve = 2,940 x 10 ⁶ m ³					Ve = 1,670 x 10 ⁶ m ³			
		HWL 360	HWL 365	HWL 370	HWL 375	HWL 380	HWL 350	HWL 360	HWL 370	HWL 380	HWL 350	HWL 360	HWL 370	HWL 380	
STREAM FLOW															
Catchment Area	km ²	4,908	4,908	4,908	4,908	4,908	4,908	4,908	4,908	4,908	4,908	4,908	4,908	4,908	
Average Annual Runoff	10 ⁶ m ³	2,975	2,975	2,975	2,975	2,975	2,975	2,975	2,975	2,975	2,975	2,975	2,975	2,975	
RESERVOIR															
Normal High Water Level	m	360	365	370	375	380	350	360	370	380	350	360	370	380	
Total Storage Capacity	10 ⁶ m ³	4,684	5,260	5,950	6,700	7,439	3,550	4,684	5,950	7,439	3,550	4,684	5,950	7,439	
Minimum Water Level	m	303	320	331	341	348	305	330	345	359	332	345	357	369	
Available Drawdown	m	57	45	39	34	32	45	30	25	21	18	15	13	11	
Inactive Storage Capacity	10 ⁶ m ³	584	1,160	1,850	2,600	3,339	610	1,744	3,010	4,499	1,880	3,014	4,280	5,769	
Effective Storage Capacity	10 ⁶ m ³	4,100	4,100	4,100	4,100	4,100	2,940	2,940	2,940	2,940	1,670	1,670	1,670	1,670	
DAM															
Type		Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	Rockfill	
Height	m	175	180	185	190	195	165	175	185	195	165	175	185	195	
Volume	10 ⁶ m ³	10.7	11.8	12.7	14.1	16.1	9.0	10.7	12.7	16.1	9.0	10.7	12.7	16.1	
HEADRACE															
Inner Diameter x Number of Lines	m	7.9 x 2	7.9 x 2	7.9 x 2	7.9 x 2	7.9 x 2	7.6 x 2	7.6 x 2	7.6 x 2	7.6 x 2	7.2 x 2	7.2 x 2	7.2 x 2	7.2 x 2	
Total Length	m	840	830	820	817	815	880	840	820	815	880	840	820	815	
PEN STOCK															
Inner Diameter x Number of Lines	m	5.0 x 4	5.0 x 4	5.0 x 4	5.0 x 4	5.0 x 4	4.8 x 4	4.8 x 4	4.8 x 4	4.8 x 4	4.6 x 4	4.6 x 4	4.6 x 4	4.6 x 4	
Total Length	m	994	1,020	1,040	1,056	1,070	952	994	1,040	1,070	952	994	1,040	1,070	
POWER GENERATING															
Normal Intake Level	m	341	347	353	360	366	334	347	358	370	342	353	364	375	
Tailwater Level	m	200.5	200.5	200.5	200.5	200.5	200	200	200	200	200	200	200	200	
Normal Effective Head	m	134.5	140.5	146.5	153.5	159.5	128	141	152	164	136	147	158	169	
Maximum Discharge	m ³ /s	460	460	460	460	460	430	430	430	430	385	385	385	385	
Installed Capacity	MW	530	560	580	610	630	470	520	560	610	450	490	520	560	
Number of Units		4	4	4	4	4	4	4	4	4	4	4	4	4	

Table 6-3 Economic Evaluation of the Alternative Schemes at Nam Chon Site

Item	Unit	Ve = 4,100 x 10 ⁶ m ³					Ve = 2,940 x 10 ⁶ m ³					Ve = 1,670 x 10 ⁶ m ³			
		HWL 360	HWL 365	HWL 370	HWL 375	HWL 380	HWL 350	HWL 360	HWL 370	HWL 380	HWL 350	HWL 360	HWL 370	HWL 380	
Dependable Capability	MW	541(15)	571(15)	591(15)	619(15)	638(15)	481(13)	530(14)	571(14)	616(14)	461(12)	501(13)	532(13)	572(13)	
Loss & Stopping	%	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	
Effective Capability	MW	522	551	570	597	616	464	511	551	594	445	483	513	552	
Value per kW	₺/kW	1,224	1,224	1,224	1,224	1,224	1,224	1,224	1,224	1,224	1,224	1,224	1,224	1,224	
Benefit of kW (B1)	ME	639	674	698	731	754	568	625	674	727	545	591	628	676	
Annual Firm Energy	GWH	975(14)	1,024(18)	1,075(23)	1,124(29)	1,173(35)	850(5)	945(2)	1,019(2)	1,107(8)	802(17)	873(18)	928(20)	1,001(19)	
Loss & Stopping	%	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	
Effective Firm Energy	GWH	941	988	1,037	1,085	1,132	820	912	983	1,068	774	842	896	966	
Value per kWh	₺/kWH		1.013	1.013	1.013	1.013	1.013	1.013	1.013	1.013	1.013	1.013	1.013	1.013	
Benefit of kWh (B2)	ME	953	1,001	1,050	1,099	1,147	831	924	996	1,082	784	853	908	979	
Annual Secondary Energy	GWH	72(1)	41(5)	33(10)	6(16)	2(23)	142(19)	113(11)	109(9)	85(1)	206(33)	196(28)	209(27)	221(30)	
Loss & Stopping	%	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	3.5	
Effective Secondary Energy	GWH	69	40	32	6	2	137	109	105	82	199	189	202	213	
Value per kWh	₺/kWH	0.864	0.864	0.864	0.864	0.864	0.864	0.864	0.864	0.864	0.864	0.864	0.864	0.864	
Benefit of kWh (B3)	ME	60	35	28	5	2	118	94	91	71	172	163	175	184	
Total Annual Benefit (B) (B) = (B1) + (B2) + (B3)	ME	1,652	1,710	1,776	1,835	1,899	1,517	1,643	1,761	1,880	1,501	1,607	1,711	1,839	
Construction Cost	ME	10,833	10,997	11,244	11,724	12,256	10,570	10,745	11,242	12,207	10,464	10,682	11,038	12,050	
Decreased Energy Cost	"	803	900	1,064	1,261	1,610	629	846	1,124	1,689	646	856	1,215	1,879	
Total Cost	"	11,636	11,897	12,308	12,985	13,866	11,199	11,591	12,366	13,896	11,110	11,538	12,253	13,929	
Annual Cost (C)	"	1,348	1,378	1,426	1,504	1,607	1,298	1,343	1,433	1,610	1,287	1,337	1,420	1,614	
Surplus Benefit (B - C)	ME	304	332	350	331	292	219	300	328	270	214	270	291	225	
Benefit - Cost Ratio (B/C)	-	1.23	1.24	1.25	1.22	1.18	1.17	1.22	1.23	1.17	1.17	1.20	1.20	1.14	

Note: Values in parenthesis mean increased energy after completion
for the down stream power plant

Table 6-4 Comparative Plan of Nam Chon Power Plant
(study of maximum discharge)

Item	Unit	5 hours Peak	4 hours Peak
STREAM FLOW			
Catchment Area	km ²	4,908	4,908
Average Annual Runoff	10 ⁶ m ³	2,975	2,975
RESERVOIR			
Normal High Water Level	m	370	370
Total Storage Capacity	10 ⁶ m ³	5,950	5,950
Minimum Water Level	m	331	331
Available Drawdown	m	39	39
Inactive Storage Capacity	10 ⁶ m ³	1,850	1,850
Effective Storage Capacity	10 ⁶ m ³	4,100	4,100
DAM			
Type		Rockfill	Rockfill
Height	m	185	185
Volume	10 ⁶ m ³	12.7	12.7
HEADRACE			
Inner Diameter x Number of Lines	m	7.9 x 2	8.8 x 2
Total Length	m	820	820
PEN STOCK			
Inner Diameter x Number of Lines	m	5.0 x 4	5.6 x 4
Total Length	m	1,040	1,040
POWER GENERATING			
Normal Intake Level	m	353	353
Tailwater Level	m	200.5	201
Normal Effective Head	m	146.5	146
Maximum Discharge	m ³ /s	460	575
Installed Capacity	MW	580	730
Number of Units		4	4

Table 6-5 Economic Evaluation of the Comparative Plan
(study of maximum discharge)

Item	Unit	5 Hours Peak	4 Hours Peak
Dependable Capability	MW	591 (15)	737 (15)
Loss & Stopping	%	3.5	3.5
Effective Capability	MW	570	711
Value per kW	£/kW	1,224	1,224
Benefit of kW (B1)	ME	698	870
Annual Firm Energy	GWH	1,075 (23)	1,078 (23)
Loss & Stopping	%	3.5	3.5
Effective Firm Energy	GWH	1,037	1,040
Value per kWh	£/kWh	1.013	1.013
Benefit of kWh (B2)	ME	1,050	1,054
Annual Secondary Energy	GWH	33 (Δ10)	23 (Δ10)
Loss & Stopping	%	3.5	3.5
Effective Secondary Energy	GWH	32	22
Value per kWh	£/kWh	0.864	0.864
Benefit of kWh (B3)	ME	28	19
Total Annual Benefit (B) (B) = (B1) + (B2) + (B3)	ME	1,776	1,943
Construction Cost	ME	11,244	12,896
Decreased Energy Cost	"	1,064	1,064
Total Cost	"	12,308	13,960
Annual Cost (C)	"	1,426	1,617
Surplus Benefit (B - C)	ME	350	326
Benefit — Cost Ratio (B/C)	—	1.25	1.20

Note: Values in parenthesis mean increased energy after completion
for the down stream power plant

Table 6-6 Comparative Plan of the Nam Chon Power Plant (study of power plant location)

Item	Unit	Dam-Type		Water Way-Type	
		Nam Chon	Thi Khong	(1)	(2)
STREAM FLOW					
Catchmen Area	km ²	4,908	5,154	4,908	4,908
Average Annual Runoff	10 ⁶ m ³	2,975	3,090	2,975	2,975
RESERVOIR					
Normal High Water Level	m	370	197	370	370
Total Storage Capacity	10 ⁶ m ³	5,950	16	5,950	5,950
Minimum Water Level	m	331	196.8	331	331
Available Drawdown	m	39	0.2 (3.5)	39	39
Inactive Storage Capacity	10 ⁶ m ³	1,850	15.7 (11.7)	1,850	1,850
Effective Storage Capacity	10 ⁶ m ³	4,100	0.3 (4.3)	4,100	4,100
DAM					
Type		Rockfill	Gravity	Rockfill	Rockfill
Height	m	185	32	185	185
Volume	10 ⁶ m ³	12.7	0.046	12.7	12.7
HEADRACE					
Inner Diameter x Number of Lines	m	7.9 x 2	—	7.9 x 2	7.9 x 2
Total Length	m	820	—	14,960	12,900
PEN STOCK					
Inner Diameter x Number of Lines	m	5.0 x 4	—	5.0 x 4	5.0 x 4
Total Length	m	1,040	—	1,200	1,500
POWER GENERATING					
Normal Intake Level	m	353	197	353	353
Tailwater Level	m	200.5	183.5	183.5	184.5
Normal Effective Head	m	146.5	12.5	153.5	154
Maximum Discharge	m ³ /s	460	480	460	460
Installed Capacity	MW	580	51	610	610
Number of Units		4	2	4	4

Note: Values in parenthesis mean
in the case of urgent need

Table 6-7 Economic Evaluation of the Comparative Plan of Nam Chon Power Plant
(study of power plant location)

Item	Unit	Dam-Type			Water Way-Type	
		Nam Chon	Thi Khong	Total	(1)	(2)
Dependable Capability	MW	591 (15)	48	639 (15)	621 (15)	622 (15)
Loss & Stopping	%	3.5	3.5	—	3.5	3.5
Effective Capability	MW	570	46	616	599	600
Value per kW	₪/kW	1,224	1,224	—	1,224	1,224
Benefit of kW (B1)	M₪	698	56	754	733	734
Annual Firm Energy	GWH	1,075 (23)	89	1,164 (23)	1,130 (23)	1,131 (23)
Loss & Stopping	%	3.5	3.5	—	3.5	3.5
Effective Firm Energy	GWH	1,037	86	1,123	1,090	1,091
Value per kWh	₪/kWh	1.013	1.013	—	1.013	1.013
Benefit of kWh (B2)	M₪	1,050	87	1,137	1,104	1,105
Annual Secondary Energy	GWH	33 (Δ10)	4	37 (Δ10)	37 (Δ10)	39 (Δ10)
Loss & Stopping	%	3.5	3.5	—	3.5	3.5
Effective Secondary Energy	GWH	32	4	36	36	38
Value per kWh	₪/kWh	0.864	0.864	—	0.864	0.864
Benefit of kWh (B3)	M₪	28	3	31	31	33
Total Annual Benefit (B) (B) = (B1) + (B2) + (B3)	M₪	1,776	146	1,922	1,868	1,872
Construction Cost	M₪	11,244	1,103	12,347	15,066	14,615
Decreased Energy Cost	"	1,064	—	1,064	1,064	1,064
Total Cost	"	12,308	1,103	13,411	16,130	15,679
Annual Cost (C)	"	1,426	128	1,554	1,869	1,817
Surplus Benefit (B - C)	M₪	350	18	368	Δ1	55
Benefit — Cost Ratio (B/C)	—	1.25	1.14	1.24	1.00	1.03

Note: Values in parenthesis mean increased energy after completion
for the down stream power plant

Table 6-8 Plan of the Alternative Schemes at No. 9A Site

Item	Unit	HWL 370	HWL 380	HWL 390
STREAM FLOW				
Catchment Area	km ²	4,524	4,524	4,524
Average Annual Runoff	10 ⁶ m ³	2,802	2,802	2,802
RESERVOIR				
Normal High Water Level	m	370	380	390
Total Storage Capacity	10 ⁶ m ³	5,100	6,449	7,970
Minimum Water Level	m	330	347	362
Available Drawdown	m	40	33	28
Inactive Storage Capacity	10 ⁶ m ³	1,243	2,592	4,113
Effective Storage Capacity	10 ⁶ m ³	3,857	3,857	3,857
DAM				
Type		Rockfill	Rockfill	Rockfill
Height	m	125	135	145
Volume	10 ⁶ m ³	5.3	6.7	9.0
HEADRACE				
Inner Diameter x Number of Lines	m	7.6 x 2	7.6 x 2	7.6 x 2
Total Length	m	635	615	600
PEN STOCK				
Inner Diameter x Number of Lines	m	4.8 x 4	4.8 x 4	4.8 x 4
Total Length	m	1,520	1,600	1,680
POWER GENERATING				
Normal Intake Level	m	353	365	337
Tailwater Level	m	257	257	257
Normal Effective Head	m	90	101	114
Maximum Discharge	m ³ /s	430	430	430
Installed Capacity	MW	330	380	420
Number of Units		4	4	4

Table 6-9 Economic Evaluation of the Alternative Schemes at No. 9A Site

Item	Unit	HWL 370	HWL 380	HWL 390
Dependable Capability	MW	344 (15)	392 (15)	430 (13)
Loss & Stopping	%	3.5	3.5	3.5
Effective Capability	MW	332	378	415
Value per kW	£/kW	1,224	1,224	1,224
Benefit of kW (B1)	ME	406	463	508
Annual Firm Energy	GWH	620 (18)	704 (16)	758 (Δ4)
Loss & Stopping	%	3.5	3.5	3.5
Effective Firm Energy	GWH	598	679	731
Value per kWH	£/kWH	1.013	1.013	1.013
Benefit of kWH (B2)	ME	606	688	741
Annual Secondary Energy	GWH	65 (Δ11)	32 (Δ6)	41 (9)
Loss & Stopping	%	3.5	3.5	3.5
Effective Secondary Energy	GWH	63	31	40
Value per kWH	£/kWH	0.864	0.864	0.864
Benefit of kWH (B3)	ME	54	27	35
Total Annual Benefit (B) (B) = (B1) + (B2) + (B3)	ME	1,066	1,178	1,284
Construction Cost	ME	8,753	9,323	10,305
Decreased Energy Cost	"	918	1,314	1,989
Total Cost	"	9,671	10,637	12,294
Annual Cost (C)	"	1,120	1,232	1,424
Surplus Benefit (B - C)	ME	Δ54	Δ54	Δ140
Benefit - Cost Ratio (B/C)	—	0.95	0.95	0.90

Note: Values in parenthesis mean increased energy after completion for the down stream power plant.

Table 6-10 Comparative Plan of No. 9A Power Plant (study of power plant location)

Item	Unit	Dam-Type			Water Way-Type	
		No. 9A	Nam Chon	Thi Khong	No. 9A	Thi Khong
STREAM FLOW						
Catchment Area	km ²	4,524	4,908	5,154	4,524	5,154
Average Annual Runoff	10 ⁶ m ³	2,802	2,975	3,090	2,802	3,090
RESERVOIR						
Normal High Water Level	m	380	252	197	380	197
Total Storage Capacity	10 ⁶ m ³	6,449	50	16	6,449	16
Minimum Water Level	m	347	251.9	196.5	347	196.5
Available Drawdown	m	33	0.1	0.5	33	0.5
Inactive Storage Capacity	10 ⁶ m ³	2,592	49.6	15.3	2,592	15.3
Effective Storage Capacity	10 ⁶ m ³	3,857	0.4	0.7	3,857	0.7
DAM						
Type		Rockfill	Rockfill	Gravity	Rockfill	Gravity
Height	m	135	62	32	135	32
Volume	10 ⁶ m ³	6.7	0.55	0.046	6.7	0.046
HEADRACE						
Inner Diameter x Number of Lines	m	7.6 x 2	7.9 x 2	—	7.6 x 2	—
Total Length	m	800	885		33,760	
PEN STOCK						
Inner Diameter x Number of Lines	m	4.8 x 4	7.1 x 2	—	4.8 x 4	—
Total Length	m	1,600	320		1,600	—
POWER GENERATING						
Normal Intake Level	m	365	252	197	365	197
Tailwater Level	m	257	200.5	184	200.5	184
Normal Effective Head	m	102	46.5	12.5	137	12.5
Maximum Discharge	m ³ /s	430	460	480	430	480
Installed Capacity	MW	380	180	51	510	51
Number of Units		4	2	2	4	2

Table 6-11 Economic Evaluation of the Comparative Plan of No. 9A Power Plant
(study of power plant location)

Item	Unit	Dam-Type				Water Way-Type		
		No. 9A	Nam Chon	Thi Khong	Total	No 9A	Thi Khong	Total
Dependable Capability	MW	392 (15)	169	48	609 (15)	523 (15)	47	570 (15)
Loss & Stopping	%	3.5	3.5	3.5		3.5	3.5	
Effective Capability	MW	378	163	46	587	505	45	550
Value per kW	฿/kW	1,224	1,224	1,224		1,224	1,224	
Benefit of kW (B1)	ME	463	200	56	719	618	55	673
Annual Firm Energy	GWH	704 (16)	309	87	1,100 (16)	944 (16)	87	1,031 (16)
Loss & Stopping	%	3.5	3.5	3.5		3.5	3.5	
Effective Firm Energy	GWH	679	298	84	1,061	911	84	995
Value per kWh	฿/kWh	1.013	1.013	1.013		1.013	1.013	
Benefit of kWh (B2)	ME	688	302	85	1,075	923	85	1,008
Annual Secondary Energy	GWH	32 (Δ6)	17	5	54 (Δ6)	61 (Δ6)	6	67 (Δ6)
Loss & Stopping	%	3.5	3.5	3.5		3.5	3.5	
Effective Secondary Energy	GWH	31	16	5	52	59	6	65
Value per kWh	฿/kWh	0.864	0.864	0.864		0.864	0.864	
Benefit of kWh (B3)	ME	27	14	4	45	51	5	56
Total Annual Benefit (B) (B) = (B1) + (B2) + (B3)	ME	1,178	516	145	1,839	1,592	145	1,737
Construction Cost	ME	9,323	3,355	1,103	13,781	18,101	1,103	19,204
Decreased Energy Cost	"	1,314	—	—	1,314	1,314	—	1,314
Total Cost	"	10,637	3,355	1,103	15,095	19,415	1,103	20,518
Annual Cost (C)	"	1,232	389	128	1,749	2,249	128	2,377
Surplus Benefit (B — C)	ME	Δ54	127	17	90	Δ657	17	Δ640
Benefit — Cost Ratio (B/C)	—	0.96	1.33	1.13	1.05	0.71	1.13	0.73

Note: Values in parenthesis mean increased energy after completion
for the down stream power plant

Table 6-12 Plan of the Optimum Scheme

Item	Unit	Nam Chon	Thi Khong
STREAM FLOW			
Catchment Area	Km ²	4,908	5,154
Average Annual Runoff	10 ⁶ m ³	2,975	3,090
RESERVOIR			
Normal High Water Level	m	370	197
Total Storage Capacity	10 ⁶ m ³	5,950	16
Minimum Water Level	m	331	196.8
Available Drawdown	m	39	0.2 (3.5)
Inactive Storage Capacity	10 ⁶ m ³	1,850	15.7 (11.7)
Effective Storage Capacity	10 ⁶ m ³	4,100	0.3 (4.3)
DAM			
Type		Rock fill	Gravity
Height	m	185	32
Volume	10 ⁶ m ³	12.7	0.046
HEADRACE			
Inner Diameter x Number of Lines	m	7.9 x 2	—
Total Length	m	820	—
PENSTOCK			
Inner Diameter x Number of Lines	m	5.0 x 4	—
Total Length	m	1,040	—
POWER GENERATING			
Normal Intake Level	m	353	197
Tailwater Level	m	200.5	183.5
Normal Effective Head	m	146.5	12.5
Maximum Discharge	m ³ /S	460	480
Installed Capacity	MW	580	51
Number of Units		4	2

Note: Values in parenthesis mean in the case of urgent need.

Table 6-13 Construction Cost of the Optimum Scheme

Item	Unit	Nam Chon	Thi Khong	Total
Preparation Works	M\$	1,227	65	1,292
Civil Works	"	4,507	430	4,937
Hydraulic Equipment	"	353	77	430
Electric Equipment	"	1,367	345	1,712
Transmission Line and Telecommunication	"	1,164	—	1,164
Engineering and Supervision	"	414	47	461
Total Direct Cost	"	9,032	964	9,996
Escalation Price	"	—	—	—
Import Duty and Taxes	"	450	53	503
Interest During Construction	"	2,212	139	2,351
Grand Total	"	11,694	1,156	12,850

Remarks: Construction Cost was estimated at the 1980 Price level.

Import duty is

Preparation Works	5 percent
Civil Works	10 "
Hydraulic Equipment	20 "
Electric Equipment	10 "
Transmission and Telecommunication	10 "

Table 6-14 Estimation of Economic Evaluation

Item	Unit	Nam Chon	Thi Khong	Total
Dependable Capability	MW	591 (15)	48	639 (15)
Loss & Stopping	%	3.5	3.5	—
Effective Capability	MW	570	46	616
Value per kW	฿/kW	1,224	1,224	—
Benefit of kW (B1)	ME	698	56	754
Annual Firm Energy	GWH	1,075 (23)	89	1,164 (23)
Loss & Stopping	%	3.5	3.5	—
Effective Firm Energy	GWH	1,037	86	1,123
Value per kWh	฿/kWh	1.013	1.013	—
Benefit of kWh (B2)	ME	1,050	87	1,137
Annual Secondary Energy	GWH	33 (Δ10)	4	37 (Δ10)
Loss & Stopping	%	3.5	3.5	—
Effective Secondary Energy	GWH	32	4	36
Value per kWh	฿/kWh	0.864	0.864	—
Benefit of kWh (B3)	ME	28	3	31
Total Annual Benefit (B) (B) = (B1) + (B2) + (B3)	ME	1,776	146	1,922
Construction Cost	ME	11,244	1,103	12,347
Decreased Energy Cost	"	1,064	—	1,064
Total Cost	"	12,308	1,103	13,411
Annual Cost (C)	"	1,426	128	1,554
Surplus Benefit (B - C)	ME	350	18	368
Benefit - Cost Ratio (B/C)	—	1.25	1.14	1.24

Note: Values in parenthesis mean increased energy after completion for the down stream power plant.

Construction cost is estimated without import duties and taxes.

CHAPTER 7

PRINCIPAL STRUCTURES



CHAPTER 7 PRINCIPAL STRUCTURES

7.1 Nam Chon Project

Selection of Dam Type

As stated in Appendix 3 "Design of Structures", it can be found that a rockfill dam is superior to a concrete dam as Nam Chon dam from the view of technical points, economical points and other all condition to be considered.

Consequently, an impervious core rockfill dam having tunnel spillways at the left bank and a powerhouse at the left bank immediately downstream of the dam as shown in Fig. 7-1 and Fig. 7-2 provides the optimum layout for this Nam Chon site.

(1) Dam

The dam planned for construction at the Nam Chon site is a rock-fill dam of dam height of 185 m and crest length of 450 m, having a central impervious core and a total embankment volume of 12,700,000 m³. This height of Nam Chon dam will be in one of the highest in the Asian countries.

As described in Chapter 4, the geological conditions are that the left bank consists of hard and massive calcareous sandstone, while the right bank consists of formations of limestone, dolomite, conglomerate and calcareous sandstone which are cracky as a whole with weathering advanced.

On consideration of the layout of the whole, various comparison studies were made, and the location of the dam was selected in the sense of avoiding as much as possible the limestone distributed at

the right bank downstream side which poses problems with regard to the watertightness of the dam.

Providing a water cutoff curtain for the whole foundation will be amply possible through grouting. Besides, blanket grouting is to be done prior to curtain grouting and embankment. The rows, spacings and depths of grouting holes are to be carefully decided upon consideration of the geological conditions of dam foundation.

(2) Spillway

It was judged that spillway, intake and powerhouse should be arranged at the left bank based on the previously described geological conditions, and further, taking into account the topographical conditions of gullies of streams cutting into the left bank at upstream and downstream of the dam axis planned.

Considering economy, the diversion tunnels are to be converted into tunnel spillways.

The required capacity of the spillways was taken to be 2,500 m³/sec based on inflow of PMF 5,900 m³/sec and considering a surcharge of 3.84 m above normal high water level of 370 m.

The spillways consist of two tunnels of 10 m diameters, each having a radial gate of width of 11.5 m and height of 10.5 m.

Fig 7-4 shows the relation between reservoir water level and spill discharge.

It can be said that the arrangement of spillway was determined from the standpoint of economy and safety of dam.

When carrying out detail design, it is thought necessary for hydraulic problems to be solved performing hydraulic model tests. Since these are closely related with the diversion tunnels, it is desirable for the tests to be carried out at an early date considering the timing of development of this Project.

(3) Diversion Tunnel

Considering the 20-year return period flood and past maximum flood, it is thought a design capacity of 1,600 m³/sec will be appropriate for diversion at this Project site.

Two diversion tunnels each of inner diameter of 8.00 m at the upstream half and 10.00 m at the downstream half are to be provided in the left bank which comprises hard bedrock. The downstream halves are to be converted to spillway tunnels.

Tunnel No.1 (length 1,080 m) is to have its inlet portal at El. 205.00 m, and Tunnel No.2 (length 1,150 m) at El. 210.00 m, and if the elevations of the outlets of the two tunnels are made to match the estimated tailrace bay water level of about 200.00 m at maximum power discharge (460 m³/sec), it is thought a height of about 250.00 m is appropriate as the crest height of the cofferdam, taking also economical and technical points into consideration.

(4) Intake, Headrace Tunnel and Penstock

Studies were made with the objective of making the length of the water-way system from the intake to the powerhouse as short as possible and to minimize the quantity of open-cut excavation as much as possible. The intake structure is to be of reinforced concrete with two roller gates each of 8 m width and 10 m height.

The headrace is to consist of two tunnels each of inner diameter of 7.9 m for passage of a maximum 460 m³/sec for power generation. The lengths are to be 370 m and 450 m, and these are to connect to chamber-type surge tanks of 11 m inner diameter each.

The penstocks are to be embedded steel pipes bifurcated at upper parts so that two lines will become four (inner diameter 5.00 m to 4.20 m, length 260 m) to connect to each turbine.

(5) Powerhouse and Switchyard

As stated in (2) of this Chapter, the powerhouse is to be arranged at the left bank, but since the topography at this site is very steeply sloped, with the purpose of minimizing the open-cut excavation for the powerhouse as much as possible, the location was made closer to the middle of the river, in addition to which the part above the tail-race bay was considered for the switchyard to result in the layout shown in Fig. 7-1 and Fig. 7-3.

The powerhouse is to be a surface type of reinforced concrete structure of 110 m in length and 20 m in width.

7.2 Thi Khong Project


This Project site is located approximately 8 km downstream from the Nam Chon damsite and has slopes of approximately 25° at the right bank side and approximately 30° at the left bank side, but conversely, good foundation rock is reached under approximately 4 m of talus deposit at the right bank and approximately 8 m at the left bank.


Regarding the arrangement of structures, as indicated in Fig. 7-5, the spillway is to be located at the present thalweg to quickly discharge the runoff of approximately $2,800 \text{ m}^3/\text{sec}$ during floods, while it was judged best to locate the powerhouse at the right bank side where the talus deposit is thinner.

The powerhouse is to be a reinforced concrete structure of 65 m in length and 20 m in width. The casing is to be of concrete structure.

The spillway is to be a dam spillway with four roller gates (width 11 m, height 13-15 m) including a sand flush gate, for discharge of design flood of $2,800 \text{ m}^3/\text{sec}$.

GENERAL PLAN FOR NAM CHON PROJECT










Fig.7-4 Nam Chon Reservoir — Flood Routing —





•

CHAPTER 8

ELECTRICAL EQUIPMENT

1000

1000

1000

CHAPTER 8 ELECTRICAL EQUIPMENT

8.1 Nam Chon Power Station

(1) Main Equipment of Power Station

This power station is planned for normal effective head of 146.5 m, maximum available discharge of 460 m³/sec and power plant output of 580 MW.

For this development scale, the number of units is to be four, each unit consisting of a combination of a 150 MW vertical-shaft Francis turbine, 162 MVA synchronous generator and a 162 MVA main transformer.

The unit system where the four generators and main transformers are connected one on one is to be adopted for the main circuits, with the generators and main transformers to be installed outdoors connected by metal enclosed buses.

(2) Switchyard Equipment

Four main transformers and other necessary equipment are to be installed at the outdoor switchyard. The switchyard equipment is planned for nominal voltage of 230 kV and GIS (SF₆ gas insulated switchgear) type.

The 230 kV buses are of the double-bus system, and two transmission lines are to be connected.

In adopting GIS types, consideration was given to the fact that it would be difficult to secure a lot with the required area for a conventional type switchyard in the vicinity of this power station.

The outlined specifications of the main equipment at Nam Chon Power Station aggregating the above are as listed below, while the single-line diagram, plan and cross-sectional drawings of the power station are as indicated in Figs. 8-1, 8-2 and 8-3.

Specifications of Main Equipment for Nam Chon Power Station

Power Plant Output	580,000 kW
--------------------	------------

Turbines

Type	Vertical-shaft Francis Turbine
Number of units	4
Normal effective head	146.5 m
Max. discharge	115 m ³ /sec
Output	150,000 kW (at normal effective head)
Revolving speed	188 rpm

Generators

Type	3-phase, a.c., synchronous generator
Number of units	4
Capacity	162,000 kVA (power factor 0.9, lagging)
Frequency	50 Hz

Main Transformers

Type	3-phase, outdoor, oil-immersed
Number of units	4
Capacity	162,000 kVA
Voltage	230/13.8 kV

Switchyard Equipment

Type	Outdoor, SF ₆ gas insulated switchgear
Bus connection system	Double-bus system
Number of transmission lines	2

8.2 Thi Khong Power Station

(1) Main Equipment of Power Station

This power station is planned for normal effective head of 12.5 m, maximum available discharge of 480 m³/sec and power plant output of 51 MW.

The number of units of this power station is two, each unit consisting of a combination of a 26.4 MW vertical-shaft Kaplan turbine, a 27 MVA synchronous generator and a 27 MVA main transformer.

A unit system is adopted for the main circuits similarly to Nam Chon Power Station, and the two generators and the two main transformer sets installed outdoors are respectively connected by metal enclosed buses.

(2) Switchyard Equipment

An outdoor switchyard is to be provided at the right bank close to the powerhouse.

The switchyard equipment is planned to be conventional types of nominal voltage of 230 kV, and are to be connected by overhead conductors to the two sets of main transformers installed at the power station side and to the transmission line between Nam Chon Power Station and Srinagarind Switchyard passing a point approximately 5 km distant from the switchyard.

The outlined specifications of the main equipment at Thi Khong Power Station aggregating the above are as listed below, while the single-line diagram, plan and cross-sectional drawings are as indicated in Figs. 8-4 and 8-5.

Specifications of Main Equipment for Thi Khong Power Station

Power Plant Output 51,000 kW

Turbines

Type	Vertical-shaft Kaplan Turbine
Number of units	2
Normal effective head	12.5 m
Max. discharge	240 m ³ /sec
Output	26,400 kW (at normal effective head)
Revolving speed	94 rpm

Generators


Type	3-phase, a.c., synchronous generator
Number of units	2
Capacity	27,000 kVA (power factor 0.95, lagging)
Frequency	50 Hz


Main Transformers



Type	3-phase, outdoor, oil-immersed
Number of units	2
Capacity	27,000 kVA
Voltage	230/138 kV

Switchyard Equipment

Type	Outdoor, air-insulated
Bus connection system	Single-bus system
Number of transmission line	1








LEGEND

SIGN	DESCRIPTION
①	Carbon dioxide extinguisher cubicle
②	Governor and turbine control board
③	Pressure oil tank
④	Stationary washing strainer
⑤	Water pump
⑥	Oil sump tank
⑦	Leaked oil tank and pump
⑧	15kV metal enclosed bus
⑨	15kV metal enclosed cubicle
⑩	11kV metal enclosed cubicle
⑪	Main air tank

UPPER QUAE YAI PROJECT	
SECTION	
NAM CHON P/S	
Fig.8-3	March, 1980



LEGEND

CB : Circuit breaker
 DS : Disconnecting switch
 GS : Grounding switch
 PD : Coupling capacitor potential device
 PT : Potential transformer
 CT : Current transformer
 LA : Lightning arrester
 LT : Line trap
 SC : Static condenser
 M.Tr : Main transformer
 E.Tr : Excitation transformer
 NG.T : Neutral grounding transformer
 S.Tr : Station service transformer

UPPER QUAE YAI PROJECT
SINGLE LINE DIAGRAM
THI KHONG P/S
Fig. 8-4 March, 1980

