

CHAPTER 9

POWER SYSTEM ANALYSIS, TRANSMISSION LINE AND TELECOMMUNICATION SYSTEM

CHAPTER 9. POWER SYSTEM ANALYSIS, TRANSMISSION LINE AND TELECOMMUNICATION SYSTEM

9.1 Power Transmission System

The Upper Quae Yai Project can be regarded to have an large effect on Regions 1 and 4 of EGAT's power system. The outline of the power system in these regions and the power system development plan in the future are shown on Fig. 9-1 and Fig. 9-2, respectively.

The power transmission system conceivable just before the Upper Quae Yai Project is incorporated was studied from the viewpoints of reliability, power flow and stability.

The following were confirmed:

- It is necessary to connect Srinagarind Switchyard with Ban Pong 2 Substation by a 230 kV, 4-cct transmission line (conductor used : ACSR 1272 MCM) and Ban Pong 2 Substation with Sai Noi Substation by a 230 kV, 3-cct transmission line (conductor used : ACSR 1272 MCM).
- It is also desirable from the standpoint of supply reliability, voltage and power flow aspects to construct a 230 kV, 1-cct transmission line (conductor used : ACSR 1272 MCM x 2) connecting Ang Thong Substation and Ang Thong 2 Substation.

The above strengthened system is considered as the system which is formed before the Upper Quae Yai Project is incorporated. The transmission system required to add for reinforcement for the Upper Quae Yai Project will be examined with this as the basis.

(1) Selection of Power Transmission Scheme

The following are the items considered in examining the transmission system required when the Upper Quae Yai Project is incorporated in the power system.

- The electric power generated by Nam Chon and Thi Khong Power Stations are to be transmitted to Bangkok, the load center.
- The transmission line is to be the most advantageous from a comprehensive viewpoint considering construction cost, convenience of maintenance and inspection, and transmission losses. Moreover, it is essential that power can be transmitted even during faulting outage of a single circuit.
- The power transmission system should be comprehensively advantageous considering the method of power transmission of the Quae Yai Pumped Storage Project (ultimate output 1,000 MW) which is planned to develop in the first half of the 1990's following the Upper Quae Yai Project.

The electric power generated by Nam Chon and Thi Khong Power Stations will have to be transmitted to Bangkok over a distance more than 270 km. It could not be sent by only a 230 kV, 2-cct transmission line with high reliability from the standpoint of stability.

Consequently, for transmission of the electric power generated at these plants, it is necessary either to adopt a 230 kV, 3-cct transmission system, or a 230 kV, 2-cct transmission system, to provide a switchyard at a midway point to Bangkok.

The three alternatives below were examined.

A. Schemes for Construction of 230 kV Transmission Lines Only

- ① Construction of a 230 kV, 2-cct transmission line
(conductor used : ACSR 1272 MCM) from Nam Chon Power Station to Srinagarind Switchyard and to Ang Thong 2 Substation respectively.
- ② Construction of a 230 kV, 2-cct transmission line
(conductor used : ACSR 1272 MCM x 2) from Nam Chon Power Station to Srinagarind Switchyard and strengthening of section between Srinagarind Switchyard and Sai Noi Substation with 230 kV transmission lines.

B. Scheme for Construction of 500 kV Transmission Line

Construction of a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2) from Nam Chon Power Station to Srinagarind Switchyard and a 500 kV, 2-cct transmission line between Srinagarind Switchyard and Sai Noi Substation. The latter is planned to construct in advance aiming at transmission of the power of the Quae Yai Pumped Storage Project (scheduled to be developed in 1990 according to EGAT's Power Development Plan), and will be initially operated at 230 kV.

(a) Schemes for Construction of 230 kV Transmission Lines Only

The results of economic comparisons made for the various strengthening patterns under the A-① and A-② schemes are shown in Table 9-1.

A-① is free from problems regarding power flow and stability, but the construction cost is high, while there are also problems in maintenance of the transmission lines.

A-②-a is a scheme for construction of a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2) between Nam Chon Power Station and Srinagarind Switchyard, and strengthening of the transmission line between Srinagarind Switchyard and Sai Noi Substation. The section between Srinagarind Switchyard and Ban Pong 2 Substation is formed by a 230 kV, 5-cct transmission line (conductor used : ACSR 1272 MCM), and the section between Ban Pong 2 Substation and Sai Noi Substation by a 230 kV, 4-cct transmission line (conductor used : 1272 MCM).

A-②-c is identical with A-②-a with regard to the transmission lines between Nam Chon Power Station and Srinagarind Switchyard, and between Ban Pong 2 Substation and Sai Noi Substation. However, between Srinagarind Switchyard and Ban Pong 2 Substation, a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2) is to be added to the existing 230 kV, 4-cct transmission line.

A-②-b is a scheme for strengthening ranking between the preceding two.

A-(2)-a is the lowest in construction cost, and there are no problems in the aspects of power flow and stability. However, transmission loss will be the greatest.

Meanwhile, the scheme A-(2)-c is considerably improved with respect to transmission loss, but the construction cost is higher than the other schemes.

As for annual costs including transmission line losses, the scheme A-(1) costs most, followed by A-(2)-a, while A-(2)-c costs least.

When only energy loss is taken into account, the annual cost for the scheme A-(1) will be highest, followed by A-(2)-c, while the scheme A-(2)-a will cost least. If there will be sufficient reserve capacity in a power system, the transmission loss may be rather practically evaluated only by energy loss. In such a case, the scheme A-(2)-a will be advantageous at the present point in time.

However, it is quite conceivable that the cost of transmission loss will be increased by the continued sharp rises in petroleum prices in the future. Therefore, it is judged that the scheme A-(2)-c would ultimately be economically advantageous.

The outlines of the schemes A-(2)-c and A-(2)-a are as follows.

- Nam Chon Power Station and Srinagarind Power Station are to be connected by a 230 kV, 2-cct transmission

line (conductor used : ACSR 1272 MCM x 2). As the present switchyard of Srinagarind Power Station has not such a large space that the equipment related to this line can be provided, it is necessary to enlarge it or to construct a new switchyard at a suitable place near Srinagarind Power Station.

- Thi Khong Power Station is to be connected with the above transmission line by a single-circuit T-branch (conductor used : ACSR 795 MCM).
- The new switchyard, if planned to construct, and the existing switchyard of Srinagarind Power Station are to be connected by a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2). The transmission line for the Khao Laem Project will be usable for this purpose.
- A 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2) for the scheme A-②-c is to be constructed, or a 230 kV, 1-cct transmission line (conductor used : ACSR 1272 MCM) for the scheme A-②-a, between the switchyard of Srinagarind Power Station and Ban Pong 2 Substation.
- A 230 kV, 1-cct transmission line (conductor used : ACSR 1272 MCM) is to be constructed between Ban Pong 2 Substation and Sai Noi Substation.

•

In these schemes, a 500 kV transmission line for the Quae Yai Pumped Storage Project must be planned to construct when it is developed in the future.

The outline of the facilities to be constructed is shown in Table 9-2. The diagrams of these power transmission schemes are shown in Figs. 9-3 and 9-4.

(b) Scheme for Construction of 500 kV Transmission Line

The outline of this scheme is as follows.

- A new switchyard is to be constructed at a suitable location near Srinagarind Power Station.

This switchyard, initially operated at 230 kV, will be upgraded to a 500 kV substation when the Quae Yai Pumped Storage Project is developed in the future.

- Nam Chon Power Station and the new switchyard of Srinagarind Power Station are to be connected by a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2).
- Thi Khong Power Station is to be connected by a single-circuit T-branch (conductor used : ACSR 795 MCM) with the above transmission line.
- The existing switchyard and the new switchyard of Srinagarind Power Station are to be connected by a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2).

The transmission line for the Khao Laem Project will be usable for this purpose like the schemes A-②-c and A-②-a.

- A 500 kV, 2-cct transmission line is to be constructed between the new switchyard of Srinagarind Power Station and Sai Noi Substation, and is to be connected to the 230 kV buses of them at first.

The conductor used for the 500 kV transmission line is to be ACSR 1272 MCM x 3 which is more advantageous than ACSR 795 MCM x 4 from the aspect of transmission losses. A conductor of ACSR 1272 MCM is used most widely for 230 kV transmission lines in Thailand.

The 500 kV transmission line constructed between Srinagarind Power Station and Sai Noi Substation should be initially energized at 230 kV and should be upgraded to 500 kV by the 500 kV/230 kV transformers that are to be installed at both the new switchyard of Srinagarind Power Station and Sai Noi Substation when the Quae Yai Pumped Storage Project is developed. The 500 kV transmission line should be used in parallel with the existing 230 kV transmission system.

The outline of the facilities to be constructed is shown in Table 9-2. The power transmission system diagram when the Upper Quae Yai Project is incorporated is shown in Fig. 9-5.

(2) Power System Analysis

Power flow study and stability study on the schemes of A-②-a, A-②-c and B cleared that all three schemes will fulfill their functions satisfactorily.

The scheme A-②-a has the least load carrying capability of the schemes constructing 230 kV transmission lines only. Therefore, power system analysis was carried out chiefly on the scheme A-②-a.

Stability calculations for the scheme A-②-c were not carried out, since it was confirmed that the scheme A-②-a has no problems in stability.

(a) Examination from System Voltage and Power Flow Aspects

Power flow calculations were carried out based on EGAT's power development plan and load forecast for 1987. The results are indicated in Fig. 9-6 to Fig. 9-10. The reason why the reactive power required at Rangsit and Phitsanulok became fairly large is that the voltages of the 230 kV buses at both substations were settled at 102% of the nominal voltage.

The 230 kV bus voltages of the substations in the Bangkok Area will be maintained at 95% or higher, and the transmission voltages of the remote power stations will be under 105% on this condition. A considerable quantity of reactive power will be required to regulate the voltages of the whole power system in 1987. The voltage regulation of the entire power system should be thoroughly studied.

All three schemes will not have parts which will become overloaded even though there may be faulting and outage of one circuit of the transmission system between Nam Chon Power Station and Sai Noi Substation.

(b) Examination of Stability Aspect

Transient stability calculations on the two schemes of A-②-a and B were carried out for the power systems at the peak time in 1987. The study led to the conclusion that both schemes have no problems as to stability. Transient stability calculations for off-peak time in 1987 were not carried out, but there must be no problem at all in stability at off-peak time. Because the transient stability calculation for off-peak time in 1986 showed the stableness of the power system, and the power system in 1987 will be even more strengthened than that in 1986, stability must be further improved.

A change of an angular position of each rotor succeeding to a disturbance in the power system was calculated in the transient stability study. The result is shown as a function of time (swing curve).

A three-phase fault of a line with a fault-clearing time of 5 cycles was adopted as a disturbance.

Fault locations selected are shown below and thought to give the most severe effect to transient stability.

• Case of Scheme A-②-a

The point near the 230 kV bus of Nam Chon Power Station for 230 kV Nam Chon - Srinagarind transmission line, and the point

near the 230 kV bus of Srinagarind Power Station for 230 kV
Srinagarind - Ban Pong 2 transmission line.

◦ Case of Scheme B

The point near the 230 kV bus of Srinagarind Power Station for
the 500 kV Srinagarind - Sai Noi transmission line.

The swing curves are indicated in Figs. 9-11-a, b and 9-12.

(3) Economical Comparison

The construction costs of the transmission lines and equipment of
the stations required for the Upper Quae Yai Project, annual costs and
transmission line losses are estimated for the schemes of A-②-a,
A-②-b, A-②-c and B.

Construction costs in 1987 will be approximately ฿880 million for
the scheme A-②-a and approximately ฿1170 million for the scheme
A-②-c, but with the scheme B, it will be approximately ฿2500 million,
more than ฿1300 million higher than the scheme A-②-c. Regarding
annual cost including transmission losses, the scheme B is the highest
and approximately ฿140 million higher than the two other schemes.

(a) Schemes for Construction of 230 kV Transmission
Lines Only (A-②-a, A-②-b and A-②-c)

	A-②-a	A-②-b	A-②-c
Construction cost of trans- mission lines and equipment in 1987	882 million฿	999 million฿	1169 million฿
Annual cost	107 "	121 "	141 "
Annual cost of transmission loss kW value	73 "	67 "	59 "
kWh value	128 "	115 "	102 "
Total Annual Cost	308 "	303 "	302 "
(Not including kW value)	(235) "	(236) "	(243) "

(b) Scheme for Construction of 500 kV Transmission Line (B)

Construction cost of transmission lines and equipment in 1987	(million ฿) 2504
Annual cost	302
Annual cost of transmission loss	
kW value	50
kWh value	89
<hr/>	
Total Annual Cost	441
(Not including kW value)	(391)

For the scheme A-②-a and A-②-c, a 500 kV transmission line only used for Quae Yai Pumped Storage Power Station should be constructed and be connected to Sai Noi Substation, when the power station is developed. The line will be approximately 166 km long.

While, for the scheme B, construction of a 500 kV transmission line of several kilometer length between this Pumped Storage Power Station and Srinagarind Power Station is sufficient when the power station is developed. However, with this scheme, the capacity of the 230 kV Srinagarind - Sai Noi transmission line is insufficient, so it must be used in parallel with the 500 kV transmission line with transformers (taken to be 400 MVA x 2 banks) installed at Srinagarind Substation. That will make the total construction cost, including the facility cost for the pumped storage, higher than the other two schemes.

Regarding the strengthening of the system accompanying development of Quae Yai Pumped Storage Power Station, economic studies including energy losses have resulted in the conclusion that if

Quae Yai Pumped Storage Power Station is developed in 1990, it is disadvantageous to construct a 500 kV transmission line at the time of development of the Upper Quae Yai Project in 1987.

(4) Conclusions

The following are recommended as measures for the necessary strengthening of the system accompanying development of the Upper Quae Yai Project.

(a) Construction of a 230 kV, 2-cct, ACSR 1272 MCM x 2 transmission line from Nam Chon Power Station to the Srinagarind Power Station.

(b) Connection of Thi Khong Power Station by a single-circuit T-branch (conductor used : ACSR 795 MCM) with the above transmission line.

(c) Since there is no open space left in the switchyard of Srinagarind Power Station, either expansion of the switchyard, or construction of a new switchyard at a suitable place in the neighborhood for leading in of the above-mentioned 230 kV, 2-cct transmission line coming from Nam Chon Power Station.

(d) Connection of the second switchyard of Srinagarind newly constructed and the existing switchyard by a 230 kV, 2-cct 1272 MCM x 2 transmission line. It is conceivable to use a part of the Khao Laem Transmission Line for this purpose.

(e) The 230 kV transmission system between Srinagarind Power Station and Sai Noi Substation is to be strengthened as below.

- Construction of a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM x 2) parallel to the existing (as of 1986) 230 kV, 4-cct transmission line (conductor used : ACSR 1272 MCM) between Srinagarind Power Station and Ban Pong 2 Substation for a total of 6 circuits.
- Strengthening of the existing (as of 1986) 230 kV, 3-cct transmission line between Ban Pong 2 Substation and Sai Noi Substation to form 230 kV, 4-cct transmission line (conductor used : ACSR 1272 MCM)

As for the scheme for construction of a 230 kV, 2-cct transmission line (conductor used : ACSR 1272 MCM) from Nam Chon Power Station to Srinagarind Power Station and to Ang Thong 2 Substation respectively, the annual cost will be higher than the above-mentioned scheme, and it will have problems in maintenance. Therefore, it cannot be recommended.

9.2 Construction and Maintenance of Transmission Line

As stated in the previous section, two alternatives are conceivable regarding the transmission line route from Upper Quae Yai Power Stations to substations in the outskirts of Bangkok. One alternative would be to lead from Nam Chon Power Station to Srinagarind Power Station along the access road for the Upper Quae Yai Project now being constructed at the right bank of Srinagarind Reservoir, after which the route would be the same as for the existing transmission line leading via Ban Pong 2 Substation to Sai Noi Substation, an outer-loop substation of Bangkok. The other alternative is to divide the power into two and transmit the power by separate routes. Of the two, one would be the above-mentioned route to Sai Noi Substation via Srinagarind Power Station, while the other transmission line route would run parallel with the former for approximately 11 km from Nam Chon Power Station after which it would branch east, cross the Quae Yai River, run through mountainous land along the Huai Hae Phhi to emerge at the plain area, then run further east to reach Ang Thong 2 Substation.

The pros and cons in construction and maintenance of these transmission line routes are as follows. The transmission line route connecting Nam Chon Power Station and Srinagarind Power Station can be selected along the access road for the Upper Quae Yai Project, while the section from Srinagarind Power Station to Sai Noi Substation via Ban Pong 2 Substation will be parallel to the existing transmission line of the Srinagarind Project, and both construction and maintenance will be easy.

In contrast, the section of approximately 55 km of the transmission line route connecting from Nam Chon Power Station to Ang Thong 2 Substation where it crosses the Quae Yai River does not have roads, while

especially, approximately 40 km of this goes through a mountainous area of very rugged terrain. Therefore, considerable expense will be required for construction of access roads for transmission line construction and for maintenance and administration of these roads for transmission line maintenance. Furthermore, this transmission line route is accompanied by the drawback that maintenance at Srinagarind Reservoir will be divided into two.

On consideration of the above conditions, as the transmission line route for transmission of the electric power generated with Upper Quae Yai Power Stations, the route from Nam Chon Power Station to Sai Noi Substation via Srinagarind Power Station and Ban Pong 2 Substation is recommended from the standpoints of construction and maintenance.

The construction cost of the transmission line and the economic analysis including losses are described in summary form in 9.1(a) and Table 9-1.

9.3 Telecommunication System

The telecommunication system required for this Project are to be designed based on the conditions below.

- Load dispatching orders to Nam Chon Power Station are to be issued from North Bangkok Substation.
- Offices for transmission line maintenance are to be provided at Nam Chon Power Station and Srinagarind Power Station.
- Interconnections with the existing system and the Khao Laem Project are to be considered.

The outlines of the telecommunication system are as described below.

(1) Multi-channel Radio Link System

Multiplex radio channels are to be structured between Nam Chon Power Station and North Bangkok Substation and between Nam Chon Power Station and Srinagarind Power Station after comparison studies from the standpoints of economy and operation. And, these are to be used as telephone channels for the load dispatching and maintenance of Nam Chon Power Station.

For this purpose, the existing UHF multiplex radio channels between North Bangkok Substation and Srinagarind Power Station are to be increased and the existing UHF Radio Link is to be extended to Nam Chon Relay Station.

(2) Power Line Carrier System

Power line carrier channels are to be structured utilizing the transmission lines constructed under this Project. The sections and

the purposes of these channels are as described below.

- Nam Chon Power Station - Thi Khong Power Station
Used for load dispatching, maintenance and data transmission required for operation of Thi Khong Power Station.
- Nam Chon Power Station - Srinagarind Power Station
Used as reserve channels for the multiplex radio channels in this section.

(3) Carrier Protective Relaying System

For protection of transmission lines constructed in this Project, power line carrier protective relaying equipment is to be provided at the sections below.

- Nam Chon Power Station - Thi Khong Power Station -
Srinagarind Power Station
Three-terminal type power line carrier protective relaying system is to be used at this section.
- Srinagarind Power Station - Ban Pong 2 Substation
- Ban Pong 2 Substation - Sai Noi Substation

(4) Transmission Line Fault Locating System

In order to aim for rapid restoration of faults of transmission lines to be constructed under this Project, fault locating equipment of the pulse radar type is to be installed at Srinagarind Power Station and Ban Pong 2 Substation and used for fault locating of the two sections below.

- Srinagarind Power Station - Nam Chon Power Station

Since Thi Khong Power Station will be T-branched midway, the fault locating range will be to the branching point.

- Srinagarind Power Station - Ban Pong 2 Substation
- Ban Pong 2 Substation - Sai Noi Substation

(5) Mobile Radio Telecommunication System

VHF mobile radio channels are to be structured and controlled from Nam Chon Power Station and Srinagarind Power Station to make possible communication with maintenance personnel working along the transmission line in this section.

For this purpose, a VHF base station is to be installed at the Huai Mun Sae Relay Station in UHF radio link, and together with the existing Ban Takian Duan Base Station, the service area along the entire transmission line route is to be secured.

(6) Data acquisition and Control System

(a) A terminal apparatus for EGAT's data acquisition and control system (REDAC) is to be installed at Nam Chon Power Station, and a data transmission channel is to be structured using the multiplex radio channels described in (1).

(b) Data transmission apparatus of the cyclic digital telemetering type are to be installed at Nam Chon Power Station and Thi Khong Power Station, and a data transmission channel necessary for operation of Thi Khong Power Station is to be structured at this section.

(7) Other Telecommunication System

Private Automatic Exchanger (PAX) and paging equipment are to be provided at Nam Chon Power Station and Thi Khong Power Station and are to be used for telephone communications for intrastation work and maintenance.

Further, with regard to PAX, a tie line telephone network in EGAT is to be formed through the multiplex radio channels.

Fig.9-1 Electric Power System of Main Part of Thailand




Fig.9-2 EGAT's Power System Development Plan (1979-1995)




Fig.9-3 Transmission System for Upper Quae Yai Project

Scheme A-②-a




Fig. 9-4 Transmission System for Upper Quae Yai Project

Scheme A-②-c




Fig. 9-5 Transmission System for Upper Quae Yai Project

Scheme B




Fig. 9-6 Power Flow - Peak Time in Sept., 1987

Scheme A-2-a




Fig. 9-7 Power Flow-Peak Time in Sept., 1987


Scheme A - ② - c

Note

$P+jQ$; Active Power (MW)
and Reactive Power (MVAR)

V/θ ; Bus Voltage (%)
and Leading Angle (deg)

— ; Line 230 kV



Scheme B

V/θ ; Bus Voltage (%)
and Leading Angle (deg)




Fig. 9 -10 Power Flow -Off -peak Time in Sept., 1987

Scheme B

Note

$P+jQ$; Active Power (MW)
and Reactive Power (MVAR)

V/θ ; Bus Voltage (%)
and Leading Angle (deg)




Fig. 9-11-b Transient Stability Study for Upper Quae Yal - Bangkok Transmission System
 Scheme A-2-a







Fig. 9-12 Transient Stability Study for Upper Quae Yai - Bangkok Transmission System






SUSPENSION TOWER



TENSION TOWER



Unit : mm

Scale : 1/200


UPPER QUAE YAI PROJECT

230kV TRANSMISSION LINE
TOWER FOR 1272 MCM x 2


Fig. 9 - 14

March 1980

SUSPENSION TOWER



TENSION TOWER



Unit : mm

Scale : 1/200

UPPER QUAE YAI PROJECT

230kV TRANSMISSION LINE
TOWER FOR 1272 MCM x 1

Fig. 9 - 15

March 1980




Fig. 9 - 17 Telecommunication System Diagram





Fig.9-18 UHF Radio Link System Diagram

Existing UHF Radio Link



UHF Radio Link for Upper Quae Yai Project




Fig. 9-19 UHF Radio Link Channel Plan




Fig.9-20 Baseband Frequency Allocation of UHF Radio Link





Fig. 9 - 21 Tie Line Telephone Network



Legend :

PAX : Private Automatic Toll Exchange

PABX : Private Automatic Branch Exchange

○ } By Upper Quae Yai Project
 — }

Table 9-1 Economic Comparison for the Selection of 230 kV Power System for Upper Quae Yai Project

Number		A - ①	A - ② - a	A - ② - b	A - ② - c
Power System Diagram	Before 1987				
Items					
(1) Construction Cost (M฿)					
1 Lines		889*	648	731	901
2 Equipments of Stations		184	234	268	268
3 Total		1,073	882	999	1,169
(2) Annual Cost (M฿)		149	107	121	141
(3) Line Losses in 1987					
1 Power (MW)	16.4	47	60	55	48
2 Annual Energy (GWH)	52.6	107	126	114	101
(4) Cost of Losses (M฿)					
1 Power	20	58	73	67	59
2 Annual Energy	53	108	128	115	102
3 Total	73	166	201	182	161
(5) Total Annual Cost Including Line Losses (M฿)					
(2) + (4). 3		315	308	303	302
(2) + (4). 2		257	235	236	243

Note: 1. * Including 139 M฿ for road construction
 2. ---- Planed transmission line for Upper Quae Yai
 3. Annual Cost Factor 0.2638 for roads
 0.1173 for lines
 0.1302 for equipments

4. Construction Cost includes the cost for the line bays of NC and TK.
 5. Cost of Losses 1.224 M฿/MW, 1.013 ฿/KWH

Table 9-2 Transmission Lines and Main Equipments of the Power System for Upper Quae Yai Project

Scheme Item	A - ② - a	A - ② - c	B
Transmission Lines	Nam Chon-Srinagarind 1 double-circuit line 115 km 230 kV, 2 x ACSR 1272 MCM	Nam Chon-Srinagarind 1 double-circuit line 115 km 230 kV, 2 x ACSR 1272 MCM	Nam Chon-Srinagarind 1 double-circuit line 115 km 230 kV, 2 x ACSR 1272 MCM
	Thi Khong-Transmission Line 1 single-circuit line 5 km 230 kV, ACSR 795 MCM	Thi Khong-Transmission Line 1 single-circuit line 5 km 230 kV, ACSR 795 MCM	Thi Khong-Transmission Line 1 single-circuit line 5 km 230 kV, ACSR 795 MCM
	Srinagarind-Banpong 2 1 single-circuit line 108 km 230 kV, ACSR 1272 MCM	Srinagarind-Banpong 2 1 double-circuit line 108 km 230 kV, 2 x ACSR 1272 MCM	Srinagarind-Sai Noi 1 double-circuit line 162 km 500 kV, 3 x ACSR 1272 MCM
	Banpong 2-Sai Noi 1 single-circuit line 54 km 230 kV, ACSR 1272 MCM	Banpong 2-Sai Noi 1 single-circuit line 54 km 230 kV, ACSR 1272 MCM	
Main Equipments of Substations	Srinagarind 7 230 kV line bays	Srinagarind 8 230 kV line bays	Srinagarind 2 500 kV line bays
	Banpong 2 2 230 kV line bays	Banpong 2 3 230 kV line bays	G 230 kV line bays
	Sai Noi 1 230 kV line bay	Sai Noi 1 230 kV line bay	Sai Noi 2 500 kV line bays

CHAPTER 10

CONSTRUCTION SCHEDULE AND PROCEDURE

CHAPTER 10 CONSTRUCTION SCHEDULE AND PROCEDURE

10.1 Nam Chon Project

The construction schedule with the start of operation of Nam Chon Power Station planned in October 1987 determined from the demand and supply balance described in Chapter 2, is shown in Fig. 10-1.

This schedule was prepared considering the project scale, work execution method, and conditions of structures and the site. The major points in this construction schedule are as follows:

Before starting on the Project, it is necessary for an access road from the Srinagarind to Nam Chon, and the camps in the vicinity of the Nam Chon site, etc. to be built and completed as soon as possible.

Regarding electric power for construction purposes, it will be necessary for diesel generators to be used since the site is far from the Srinagarind.

Driving of the diversion tunnels is to be started in the dry season of 1981 and diversion into these tunnels is scheduled to be completed before the rainy season of 1983.

Embankment and foundation treatment of the dam is to be started in 1983, and these works are to be done in parallel. Foundation treatment is to be completed by May 1985 when impoundment is to be started. Embankment work is scheduled to be finished in the first half of 1987.

Outlet works are to be started in 1983, and installation of valves for discharge downstream during impounding should be completed before the start of impoundment.

Since installation of electrical equipment such as turbines and generators will be from 1985, the powerhouse works should be executed from 1982.

Works on the spillway, intake, headrace tunnels, surge tanks and penstocks are scheduled to be carried out between 1983 and 1986.

The excavation material from the various works is to be used for dam embankment as much as possible.

Transmission line work would be performed from 1984 with all work completed in the first half of 1987 and operation scheduled to be started in October 1987.

10.2 Thi Khong Project

The construction schedule with the start of operation of Thi Khong Power Station planned in March 1989 determined from the demand and supply balance described in Chapter 2, is shown in Fig. 10-2. This construction schedule was prepared considering factors such as construction scale, construction method, conditions of the structure, and the site, etc.

The essential points of this construction schedule are as described below. The access road from Nam Chon to Thi Khong should be completed before starting on the Project. The camp should be prepared in the vicinity of Thi Khong site.

Electric power for construction purposes should be supplied by diesel generators as in the case of Nam Chon Project.

For reasons of economy, the electric power for the camp and construction purposes is to be that for the Nam Chon Project as much as possible.

On this Project, it will be necessary for civil main works to be started on the diversion channel, that is the right half of the river flow, from May 1985 when impoundment of Nam Chon Reservoir will be started.

Diverting the flow to this diversion channel, work on the dam and the spillway is to be done from the latter half of 1985 to the first half of 1987. After these works have been completed and the river flow switched to the former channel, works such as on the intake and the powerhouse at the right bank side are scheduled to be performed by the end of 1988. Excavation material from the various works is expected as concrete aggregate.

Installation of electrical equipment such as turbines and generators is to be started in 1987, and operation is to begin in March 1989.

Fig. 10-1 Construction Schedule of Nam Chon Project



























Fig. 10-2 Construction Schedule of Thi Khong Project

Description	Unit	Quantity	1985	1986	1987	1988	1989
Preparation Works	L.S.	1					
Construction Facilities	L.S.	1					
Clearing	L.S.	1					
Care of River	L.S.	1					
Excavation	m ³	720,000					
Concrete (Dam & Spillway)	m ³	46,000					
Concrete (Intake)	m ³	24,000					
Concrete (Powerhouse)	m ³	35,000					
Concrete (Tailrace)	m ³	10,000					
Gate (Spillway)	L.S.	1					
Gate (Intake)	L.S.	1					
Gate (Tailrace)	L.S.	1					
Switchyard	L.S.	1					
Electrical Equipment	L.S.	1					
Transmission Line	L.S.	1					

CHAPTER 11

CONSTRUCTION COST AND FINANCIAL PROGRAM

CHAPTER 11 CONSTRUCTION COST AND FINANCIAL PROGRAM

11.1 Construction Cost

The construction costs of Nam Chon Project and Thi Khong Project are shown in Tables 11-1 and 11-2. The summary of construction costs is as shown below. The construction costs were estimated by the price level as of October 1979, and were increased by 15% to obtain 1980 prices. Of wages, materials and machinery costs required for the works, those procurable in Thailand were estimated in local currency and the rest in foreign currency.

(1) Nam Chon Project

Project Cost	(million US\$)	(million ฿)
Local currency	344.8	(7,069)
Foreign currency	225.6	4,625
Total	570.4	(11,694)

Note: 1US\$ = 20.5฿

(2) Thi Khong Project

Project Cost	(million US\$)	(million ฿)
Local currency	31.7	(650)
Foreign currency	24.7	506
Total	56.4	(1,156)

Note: 1US\$ = 20.5฿

11.2 Financial Program

The annual financial programs were made based on the construction schedules, and these are indicated in Tables 11-3 and 11-4.

Table 11-1 Nam Chon Project Construction Cost

Item	Currency US\$ (Million)		Total US\$ (Million)
	Foreign	Local	
Preparation Works			
Camp, Road, Compensation and Contingency	14.2	45.7	59.9
Civil Works			
Diversion, Outlet Works and Care of River	6.1	20.1	26.2
Dam	59.5	45.8	105.3
Spillway	5.9	15.5	21.4
Intake, Headrace, Surge Tank and Penstock	4.1	17.0	21.1
Powerhouse and Tailrace	3.4	17.1	20.5
Miscellaneous	2.4	3.5	5.9
Contingency	7.9	11.6	19.5
Sub-total	89.3	130.6	219.9
Hydraulic Equipment			
Spillway Gates	1.5	0.3	1.8
Outlet Valve	1.1	0.3	1.4
Intake Gates	2.0	0.3	2.3
Penstock	6.9	2.3	9.2
Draft Gates	0.8	0.1	0.9
Contingency	0.8	0.8	1.6
Sub-total	13.1	4.1	17.2
Electrical Equipment	56.7	10.0	66.7
Transmission Line and Telecommunication	40.2	16.5	56.7
Engineering Fee	12.1	8.1	20.2
Total	225.6	215.0	440.6
Interest During Construction	-	107.9	107.9
Import Duties	-	21.9	21.9
Total Project Cost (Million US\$)	225.6	344.8	570.4
(Million Bahts)	4,625	7,069	11,694

Table 11-2 Thi Khong Project Construction Cost

Item	Currency US\$ (Million)		Total US\$ (Million)
	Foreign	Local	
Preparation Works			
Camp, Road, Compensation and Contingency	0.9	2.3	3.2
Civil Works			
Dam and Spillway	1.0	4.3	5.3
Intake, Powerhouse, Tailrace and Switchyard	3.2	9.7	12.9
Care of River	0.2	0.2	0.4
Miscellaneous	0.1	0.4	0.5
Contingency	0.5	1.4	1.9
Sub-total	5.0	16.0	21.0
Hydraulic Equipment			
Spillway Gates	1.4	0.3	1.7
Intake Gate, Trashrack and Draft Gate	1.6	0.3	1.9
Contingency	0.1	-	0.1
Sub-total	2.1	0.6	3.7
Electrical Equipment	14.3	2.5	16.8
Engineering Fee	1.4	0.9	2.3
Total	24.7	22.3	47.0
Interest During Construction	-	6.8	6.8
Import Duties	-	2.6	2.6
Total Project Cost (Million US\$)	24.7	31.7	56.4
(Million Bahts)	506	650	1,156

Table 11-3 Financial Program of Nam Chon Project

Unit: Million US\$ (Million ₩)

Year	Foreign Currency	Local Currency	Total
1981	10.9 (223)	23.2 (477)	34.1 (700)
1982	18.3 (376)	45.3 (928)	63.6 (1,304)
1983	22.5 (462)	51.0 (1,044)	73.5 (1,506)
1984	38.6 (791)	46.7 (957)	85.3 (1,748)
1985	54.4 (1,115)	64.4 (1,320)	118.8 (2,435)
1986	47.7 (977)	57.1 (1,172)	104.8 (2,149)
1987	33.2 (681)	57.1 (1,171)	90.3 (1,852)
Total	225.6 (4,625)	344.8 (7,069)	570.4 (11,694)

Notes: * These prices are based on the level as of 1980.

* 1US\$ = 20.5₩

Table 11-4 Financial Program of Thi Khong Project

Unit: Million US\$ (Million ₩)

Year	Foreign Currency	Local Currency	Total
1985	1.9 (39)	4.3 (88)	6.2 (127)
1986	2.9 (59)	5.2 (108)	8.1 (167)
1987	6.1 (125)	9.4 (192)	15.5 (317)
1988	12.3 (253)	10.6 (217)	22.9 (470)
1989	1.5 (30)	2.2 (45)	3.7 (75)
Total	24.7 (506)	31.7 (650)	56.4 (1,156)

Notes: * These prices are based on the level as of 1980.

* 1US\$ = 20.5₩

CHAPTER 12

ECONOMIC JUSTIFICATION

115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900
901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000

CHAPTER 12 ECONOMIC JUSTIFICATION

12.1 Scope of Economic Analysis

The economic analysis of an electric power generating project is made in the form of comparison with an alternative project providing equal service with the project contemplated. In the case of a hydroelectric power generating project, the technique recognized throughout the world is to select thermal power generating facilities as alternative project and compare the cost of the objective hydroelectric power station with those of the alternative thermal power station. Accordingly, the economic analysis of this project was made by this manner.

Since the character of this hydroelectric power project is that of a peaking station, in order that the alternative thermal power station would match this power generating character, combinations of gas turbine power plant, which has the capability of quickly responding to peak loads, and oil-fired thermal power plant were considered, and the combination with the cheapest power generating cost was selected and this was considered as the alternative power station.

Economic analyses were made for the two cases of Nam Chon Power Station developed alone, and Nam Chon Power Station and Thi Khong Power Station constructed simultaneously as a two-stage development project. Since development of Thi Khong Power Station alone is obviously not practical as a hydroelectric power generating project both technically and economically, this case was not taking this economical study into consideration. To start construction of Thi Khong Power Station after completion of Nam Chon Power Station would mean an enormous expense for

construction of a diversion waterway to construct Thi Khong Power Station and this is not realistic.

The economic analysis was made by the discounted cash flow method with the cost of the alternative power station substituted as the benefit of this hydroelectric power project. Base case of the economic justification is a case in consideration of Shadow Price Factor in accordance with EGAT's consent.

Since it is very difficult to foresee the fuel prices and discount rate, influences on the project economy were examined by sensitive analysis concerning fuel price increase and changing the discount rate.

Basic criteria for the economic study is shown in Table 12-1.

12.2 Selection of Alternative Power Generating Facility

The electric power produced by this hydroelectric power project is to be supplied to meet the peak load of the whole power system of Thailand, therefore, the alternative thermal power station is considered to be installed near Bangkok area. As the alternative thermal power project, economical combination of several units of 60 MW gas turbine power plant and oil-fired thermal power plant were studied taking the generating cost into consideration. The result is summarized in Table 12-2. In this study, the annual available energy of the alternative plants is considered to be $1,160 \times 10^6 \text{ kWh}$ (in the case of the project with Thi Khong Power Station) at Bangkok area which is the same amount of that of the Upper Quae Yai Project. In addition, annual plant factors of gas turbine and oil-fired thermal power plants were restricted to be not less than 5% and within 80%, respectively.

In the study of the scale of development of the project, unit kW and kWh benefits and unit surplus kWh benefit were estimated basing on the combination of six units of 60 MW gas turbine power plant and a 200 MW oil-fired thermal power plant with referring to the above study. The details are shown in Table 12-3.

Economic analysis of the selected project by the preliminary study is based on a suitable combination of the thermal power plants in consideration of the study result shown in Table 12-2.

Accordingly, the alternative power project to be considered for the Upper Quae Yai Project with Thi Khong Power Station was selected to be eight units of 60 MW gas turbine power plant and a 170 MW oil-fired thermal power plant (Refer to Table 12-4).

12.3 Project Cost

As described in Chapter 11, the total construction cost of this hydroelectric power generation project in case of simultaneous development of Thi Khong Power Station was estimated to be US\$626.8 million.

The period considered for the economic analysis was taken to be 57 years, and the total amount of the equipment investment cost and operation and maintenance costs of each year during this period was taken as the annual cost of the Project and converted to present value, and the total for the 57 years was taken as the cost of the Project. A discount rate of 10% was employed for conversion of present value.

The annual operation and maintenance costs of the electric power facilities of this Project, with the concurrence of EGAT, were obtained as follows:

Facilities	Operation & Maintenance Cost
Dam & Reservoir	1.0%
Power Station	2.0%
Substation	2.0%
Transmission Line	1.5%

12.4 Project Benefit

12.4.1 Alternative Thermal Power Generating Facility

The outline of the alternative thermal power generating facility selected as the basis for economic analysis is as indicated below.

- (1) The location is to be near the Bangkok Metropolis.
- (2) The construction cost is to be calculated referring to unit construction costs of similar thermal power station contracts recently awarded by EGAT upon international bidding.
- (3) The scale of the alternative thermal power generating facility is to be equal in electricity output to this hydroelectric power generating facility.
- (4) Relation between Installed Capacity and Dependable Capacity

For the thermal power plants in the EGAT's system, records of operations in FY. 1975 ~ 1978 showed that there are several occasions that the thermal plants are not able to generate up to full rated capacity. Therefore, dependable capacity of thermal power plants including gas turbines should be used for the following criteria for planning:

Average figure of dependable capacity of thermal plants (oil/gas/lignite) is 95 percent in which the diversity of the rated installed capacity of several power plants were taken into account. Therefore, total installed capacity of gas turbines and oil fired thermal plants are:

$$\text{Total installed capacity} = \frac{\text{Dependable capacity}}{0.95}$$

The details of the alternative thermal power generating facilities considered based on the above conditions are given in Table 12-4.

12.4.2 Fuel Cost of Alternative Thermal Power Plant

Fuel prices in this study were estimated taking those for 550 MW oil-fired thermal power unit and 60 MW gas turbine power unit in EGAT's Ban Pakong Thermal Power Plant into consideration.

Following to the OPEC's decision of export crude oil price-up to 16 ~ 18 US\$/barrel in June 1979, the further price increase was agreed by OPEC at Caracas in Venezuela in December 1979.

In the study for determination of the scale of development of the project, the fuel prices in 1980 were estimated to be 2.62฿/ℓ and 3.80 ฿/ℓ for heavy oil and diesel oil, respectively. Estimation of benefits of the Upper Quae Yai Project was made based on the 20% higher prices than the above price taking rapid escalation of oil prices into consideration.

Judging from these matters, prices of fuel oil are not stable and nobody guesses how much price would be increased by the time when this report is completed. Therefore, the economic analysis on the selected case of the project was made based on the fuel prices suggested by EGAT

January 1980, i.e. 3.48฿/ℓ for heavy oil and 4.68฿/ℓ for diesel oil. In addition to this study, the similar economic analysis based on the 5% to 150% higher fuel price than the above prices for examining the influence of fuel price increase against the project economy, what is called sensitivity analysis, was made.

Further study based on the different fuel prices will not be made even the fuel prices be changed during preparation of this report because this sensitivity analysis cover all cases concerning fuel price changing.

12.5 Annual Available Energy

The annual available energy of the Upper Quae Yai Project was estimated taking the following matters into consideration:

- (1) Energy decrease at the downstream power plants by storing water in Nam Chon Reservoir in 1985 and 1986.
- (2) Power and energy increases at the downstream power plants after completion of the Upper Quae Yai Project.
- (3) Transmission line loss from the power stations to the 230 kV outer-ring transmission line in Bangkok (Refer to Chapter 9)

12.6 Economic Justification

The results of economic analysis made by the discounted cash flow rate method are shown in Table 12-5 and Table 12-6. As seen in these tables, the internal rate of return (IRR) of this Project in case of simultaneous development of Nam Chon Power Station and Thi Khong Power Station will be 15.2%, while the benefit-cost ratio (B/C) in case of a discount rate of 10% will be 1.45, and it is judged that this Project is worth implementing from an economic viewpoint. It is similarly

judged that the Project will still be economical in the case that Thi Khong Power Station is not developed.

Studies were made of the effects on the economics of the Project when discount rates were varied, and when the unit fuel costs of the alternative thermal power generating facilities were increased, and the results are indicated in Fig. 12-1, Fig. 12-2, Fig. 12-3, and Fig. 12-4.

Fig. 12 - 1 Sensitivity Analysis (1A)




Fig. 12 - 2 Sensitivity Analysis (1B)




Fig. 12 - 3 Sensitivity Analysis (2 A)




Fig. 12 - 4 Sensitivity Analysis (2 B)




Table 12-1 BASIC CRITERIA FOR ECONOMIC STUDY

Method of Analysis:	Discounted Cash Flow Method
Study Period:	57 years (1981 - 2012)
Discount Rate:	10%
Escalation:	Not considered
Shadow Price Factor:	
Foreign Currency	1.10
Local Currency for Hydro	0.85
Local Currency for Thermal	0.95
Fuel Price	1.0
Service Life of Facilities:	
Dam & Reservoir	50 years
Hydro Power Plant	25 years
Oil Fired Thermal Plant	25 years
Gas Turbine Plant	20 years
Substation	25 years
Transmission Line	40 years
Conversion Rate of Currency:	US\$1.00 = ₪20.5

Table 12-2 GENERATING COST RATIO OF ALTERNATIVE THERMAL PLANT

No. of 60 MW Gas Turbine Unit	Total Installed Capacity of Thermal Power Plants				
	650 MW	600 MW	550 MW	500 MW	450 MW
3	-	-	-	-	94
4	-	-	-	98	94
5	-	-	101	97	95
6	-	104	<u>100</u>	100	-
7	107	103	106	-	-
8	106	111	-	-	-
9	117	-	-	-	-

Note: Annual Available Energy: 1,060 GWh (sending end)

Unit Construction Cost:

Gas Turbine Plant 240\$/kW

Oil-fired Thermal 495\$/kW

Fuel Cost Per Litre:

Gas Turbine 0.2283\$ (4.68¢)

Oil-fired Thermal 0.1698\$ (3.48¢)

Fuel Consumption Rate:

Gas Turbine 0.3977 l/kWh

Oil-fired Thermal 0.252 l/kWh

Table 12-3 ALTERNATIVE THERMAL POWER PLANT FOR STUDYING
OPTIMUM SCALE OF DEVELOPMENT

Interest Rate: 0.100
1980 Price Level

	Gas Turbine	Oil Fired	Line
Installed Capacity	6 x 60 MW	1 x 200 MW	560 MW
Dependable Capacity (MW)	342	188	-
Annual Plant Factor (%)	5	59	22.6
Annual Energy Production (10 ⁶ kWh)	158	1,026	-
Station Service Use (%)	2	7	-
Annual Available Energy (10 ⁶ kWh)	155	954	1,109
Unit Construction Cost (US\$/kW)	278	574	35
Construction Cost (10 ⁶ US\$)	100.1	114.8	19.6
Service Life (Year)	20	25	40
Capital Recovery Factor (p.u.)	0.11746	0.11016	0.10226
O & M Cost Rate w/o Fuel (%)	3.0	2.5	1.5
Fuel Consumption Rate (1/kWh)	0.3977	0.252	-
Unit Fuel Cost (US\$/1)	0.1854	0.1278	-
Annual Cost (10 ⁶ US\$)			
Capital	11.76	12.65	2.00
Fixed O & M cost	2.40	2.30	0.53
Fuel cost	11.65	33.04	-
Variable O & M cost w/o fuel	0.60	0.57	-
Combined Cost (Benefit of hydro project)			
kW cost (US\$/kW)	59.70 (= 1,224¢/kW)		
kWh cost (US\$/kWh)	0.04135 (= 0.848¢/kWh)		
2ry kWh benefit (US\$/kWh)	0.03523 (= 0.722¢/kWh)		
Combined Cost (Fuel 20% up)			
kW cost (US\$/kW)	59.70 (= 1,224¢/kW)		
kWh cost (US\$/kWh)	0.04941 (= 1.013¢/kWh)		
2ry kWh benefit (US\$/kWh)	0.04216 (= 0.864¢/kWh)		

Note: - Interest during construction is included in the unit construction costs.

- Net construction costs are 240\$/kW and 495\$/kW for gas turbine and oil-fired thermal power plants, respectively.
- Benefit of secondary energy of hydro is evaluated by the variable cost of oil-fired thermal plant.
- Costs of Fuel 20% up case are used for evaluation of the hydro taking the present oil crisis into consideration.

Table 12-4 ALTERNATIVE THERMAL POWER PLANT
FOR STUDYING ECONOMIC JUSTIFICATION

Item	Unit	Gas Turbine	Oil-fired Thermal
Installed Capacity	(MW)	480	170
Unit Capacity	(MW)	60	170
Dependable Capacity	(MW)	456	160
Annual Plant Factor	(%)	5	70
Annual Energy Production	(10 ⁶ kWh)	200	1,036
Station Service Power Use	(%)	2	7
Annual Available Energy	(10 ⁶ kWh)	196	963
Fuel Consumption Rate	(l/kWh)	0.3977	0.252
Unit Fuel Price	(p/kWh)	4.68	3.48
Construction Cost	(10 ⁶ US\$)	115.2	84.2
Unit Construction Cost	(US\$/kW)	240	495

Table 12-5 ECONOMY OF PROJECT (1)

- with Thi Khong Power Plant -

	Discount Rate (%)	Base Case (with shadow price factor)	Alternative Case (without shadow price factor)
B/C	10	1.45	1.37
B-C	10	152.9 x 10 ⁶ US\$ (3,134 x 10 ⁶ Baht)	129.4 x 10 ⁶ US\$ (2,653 x 10 ⁶ Baht)
IRR	--	15.2%	14.1%

Table 12-6 ECONOMY OF PROJECT (2)

- without Thi Khong Power Plant -

	Discount Rate (%)	Base Case (with shadow price factor)	Alternative Case (without shadow price factor)
B/C	10	1.45	1.36
B-C	10	140.9 x 10 ⁶ US\$ (2,888 x 10 ⁶ Baht)	119.0 x 10 ⁶ US\$ (2,440 x 10 ⁶ Baht)
IRR	--	15.0%	14.0%

JICA