

## 8-5 Maintenance of Large Synchronous Motor

### 8-5-1 General

Daily checkings are required for the electric current, noise, smell and power coefficient of high voltage panel, MG panel and synchronous motors on which troubles have occurred during actual operation.

Furthermore, checking of sliding condition and removal of carbon powder on the slip rings and brush shall be done once a month, which only are movable portion for the D.C power supply to rotor. In case of decreased contact pressure between brush and surface of commutator, sparking will occur and the surface of commutator will be striated. As short circuit between phases will occur, if conditions would be left as they are, appropriate maintenance has to be performed.

In addition, sequence test (trip condition, starting condition) and independent characteristic test of relays have to be performed systematically.


### 8-5-2 Control Circuit

During our staying periods, SYN-GAS COMP<sup>OR</sup> of ammonia plant was miss-stopped may be due to the trouble of ventilation slip ring. On this accident, it is the worse fact that the operation was restarted without any prompt investigation of sequence accident. In such case, the condition, cause and countermeasure have to be examined thoroughly and sufficiently. Sequence of Syn.gas Comp<sup>OR</sup> of Ammonia plant was investigated as shown in the next page. This investigation has revealed that the trouble of ventilation slip ring for trip in-put and trouble of auxiliary power source of Motor Air Temp can be indicated by alarm only and necessity of stopping may be made as dependent


upon the operator's judgement. Thus unnecessary equipment should be removed so far as practical and control circuit should be simplified as a whole. On the other hand, it is recommendable to instal ground relay, step-out relay, under-voltage relay and exciter accident relay for trip in-put.

# EXPLANATION OF SYNCHRONOUS MOTOR 2500 KW MAE MOH FACTORY


## (1) SINGLE LINE DIAGRAM



## (2) AUXILIARY SOURCE




## (3) STARTING - LOOP



## (4) STOP SYSTEM

- |    |  |
|----|--|
| 1  | STOP (MANUAL) D1 OFF                           |
| 2  | OVER CURRENT (Q10)                             |
| 3  | SHORT CIRCUIT (Q11)                            |
| 4  | LOAD SHEDDING                                  |
| 5  | EMERGENCY TRIPPING                             |
| 6  | AUXILIARY AC DISTURBED                         |
| 7  | MT DISTURBED                                   |
| 8  | UNDER EXCITATION/SLIP AND RUN UP DISTURBED     |
| 9  | OVER CURRENT RUN UP DISTURBED                  |
| 10 | VENTILATION SLIP RING BOX FAILURE              |
| 11 | STARTING CABINET FAILURE                       |
| 12 | MOTOR AIR TEMPERATURE FAILURE                  |
| 13 | COMPRESSOR FAILURE (MACHINE PART)              |
| 14 | AUXILIARY MACHINE FAILURE                      |
| 15 | COMPRESSOR FAILURE (PROCESS PART) AT UNLOCKING |



### 8-5-3 Insulation of Motor


For both in-door and weather-proof types, dew condensation will occur on the surface of motor coil, if the open-type motor is stopped for long periods. This phenomenon will occur due to the differences between the temperature of motor and that of surrounding atmosphere, as the temperature variation of motor is not proportional to that of atmosphere. This dew condensation will cause the decrease of insulation grade.

In addition, for the case of Mae Moh Factory, over-aged conditions of equipment aggravate the insulation grade. Appropriate counter-measures against such condition are as follows:

- (1) Providing space heater to be operated during motor stop.
- (2) Protecting motor from surrounding atmosphere by Cloth Cheet Cover upon motor stopping.
- (3) Cleaning of coil, varnish treatment and drying, in case surface of motor coil is dusty.

For Mae Moh Factory, cleaning of coil as stated in (3) above, is indispensable measure. Sample explanation of procedure for cleaning and drying of coil is as follows:

- (1) Pull out the rotator from stator.
- (2) General cleaning (surface of iron core and coil)
- (3) Cleaning by splashing the pure water
- (4) Drying by hot air (upto approximately 100 mΩ at point "B" of the Graph)



(5) Varnish treatment (Air-spraying)

(6) Re-drying by hot air (up to approximately 100 MΩ)

Total days required for the above procedure are about one week, and the supervision by the specialist is recommendable.

8-6 Record of Checking and Repairing of Grounding Facility


Grounding facility of Mae Moh Factory is net-work basically, covering wide area, and the grounding resistance can be deemed to be low enough through the year. However, since earthing electrode will be overaged by corrosion year by year, checking and maintenance of the facilities shall be properly practised. Our investigation and supervision of repair were made on the following point;

- (1) Condition of mechanical and chemical damage of lead wire connecting the earthing electrode and the earthing main wire on the ground.
- (2) Condition of earthing of main earthing wire on the ground and of lead wire for earthing of equipment.

Further, earthing resistance of earthing electrode was measured and entered the measured value and points on plot plan; result of which indicates to be good. Embedded earthing electrodes are newly installed around 05, Finished Dust Bunker of Gasification plant as shown on "Sketch of newly installed earthing electrode" in next page.


MAE MOH FACTORY  
 GROUNDING RESISTANCE(MΩ)  
 SEP./1978

NO.	PLANT NAME
1	PUMR HOUSE
2	EGAT BOILER
3	FEED WATER PLANT
4	AIR SEPARATION PLANT
5	O2 HOLDER
6	N2 HOLDER
7	GASIFICATION PLANT
8	DESULPURIZATION PLANT
9	SYN GAS HOLDER
10	AMMONIA PLANT
11	UREA PLANT
12	PRODUCTS WAREHOUSE
13	SULPHURIC ACID PLANT
14	AMM. SULPH. PLANT
15	WATER TREATMENT
16	MACHINE WORKSHOP
17	SPARE PARTS WARE HOUSE
18	LABORATORY
19	INST. ELEC. WORKSHOP
20	ELECTRICITY CONTROL ROOM
21	OFFICE
22	BAGGING




- Sketch of Newly Installed Earthing Electrode -

FROM 05 , ELECTRO FILTER & FINISHED DUST BUNKER  
OF GRINDING SECTION



Detail of embedded earthing electrode



Material : Fe

Steel flat bar from 0.5, Electro Filter & Finished Dust Bunker was welded with hexagonal embedded earthing electrodes and embedded in the ground. Earthing resistance value is  $0.2 \Omega$ , which is good.



8-7 Plan for Future Replacement

Following replacements are urgently required among electrical equipments, the cost of which is estimated as approximately Baht 570,000.-. For the replacement of the protection relay, its adjustment and cleaning of motor, two specialists have to be despatched for two weeks.

Cost for despatching Specialist:

(2 men x 14 days x @US\$300 x @¥200)  
+ ¥1,000,000.- = ¥2,680,000.-  
= ¥3,000,000.-  
= Baht 300,000.-

SECTION 9

REPORT FOR ANALYSIS WORK



Section 9 Report for Analysis Work

9-1	Summary	9 - 3
9-2	Present Status and Problem of Laboratory	9 - 4
9-3	Facility of Equipments	9 - 8
9-4	Chemist & Technician	9 -10
9-5	Future Direction for Laboratory	9 -11
9-6	Analysis Results	9 -17

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes the need for transparency and accountability in financial reporting.

2. The second part of the document outlines the various methods and techniques used to collect and analyze data. It includes a detailed description of the experimental procedures and the tools used for data collection.

3. The third part of the document presents the results of the study, including a comparison of the different methods and techniques used. It discusses the strengths and weaknesses of each method and provides a summary of the findings.

4. The fourth part of the document discusses the implications of the study and provides recommendations for future research. It highlights the need for further investigation into the effectiveness of the different methods and techniques used.

5. The fifth part of the document provides a conclusion and a summary of the key findings. It reiterates the importance of maintaining accurate records and the need for transparency and accountability in financial reporting.

6. The sixth part of the document provides a list of references and a bibliography. It includes a list of all the sources used in the study and provides a detailed description of each source.

7. The seventh part of the document provides a list of appendices and a bibliography. It includes a list of all the appendices used in the study and provides a detailed description of each appendix.

8. The eighth part of the document provides a list of figures and a bibliography. It includes a list of all the figures used in the study and provides a detailed description of each figure.

9. The ninth part of the document provides a list of tables and a bibliography. It includes a list of all the tables used in the study and provides a detailed description of each table.

10. The tenth part of the document provides a list of equations and a bibliography. It includes a list of all the equations used in the study and provides a detailed description of each equation.

11. The eleventh part of the document provides a list of definitions and a bibliography. It includes a list of all the definitions used in the study and provides a detailed description of each definition.

12. The twelfth part of the document provides a list of abbreviations and a bibliography. It includes a list of all the abbreviations used in the study and provides a detailed description of each abbreviation.

13. The thirteenth part of the document provides a list of acronyms and a bibliography. It includes a list of all the acronyms used in the study and provides a detailed description of each acronym.

## Section 9 Report for Laboratory Analysis Work

### 9-1 Summary

Main works of Laboratory is process analysis and finished products analysis, with its organization of 5 sections for category of raw materials and finished products. Analysis works are performed by technicians, and the results will be reported to each plant after checkings by chemists. Analysis equipments and instruments, as commonly required, are provided.

Laboratory has 13 years experiences after the completion of the Factory, and its technical level is of capable grade to cope with the normal operation of Mae Moh Factory.

Under the present situation, there are such points to be solved as, clarification of specified control standard, maintenance of analysis equipments and instruments, provision of spare parts, improvement of requested analysis system, etc.

To state for the future direction of Laboratory, it is advised that daily works shall be more fulfilled, as auxiliary division of factory, for maintaining the overaged factory, and cooperation with plant engineers is required for solving the problems of process concerned.

9-2 Present Situation and Problem of Laboratory

9-2-1 Organization and Work Obligation

Laboratory is composed of 5 sections of Lignite, Gas, Water, Finished Products and Standard. Its works are for process analysis and finished products inspection, while there are no sections for investigation and study work.

Total numbers of staffs are 23 personnels and management is composed of 1 manager and 3 chemists, while technicians are 17 staffs.

MANAGER	LIGNITE	- CHEMIST 1 Staff -	TECHNICIAN 3 Staffs
	GAS *1	- CHEMIST 1 Staff -	TECHNICIAN 8 Staffs (LIGNITE work)
	FINISHED PRODUCT	- CHEMIST 1 Staff -	TECHNICIAN 3 Staffs
	WATER	- CHEMIST 1 Staff -	TECHNICIAN 2 Staffs
	STANDARD	- CHEMIST 1 Staff -	TECHNICIAN 1 Staff (FINISHED PRODUCT work)
			(Others- 2 labours)

\*1 GAS SECTION is of 3 shift works.

(Contents of Work)

Following process analysis and finished product inspection works are executed by 5 sections.

As daily work, sampling of 40 numbers from all plants and analysis of 190 items are normally performed.


Method of analysis is of German style.

Results of the analysis of process and finished products are reported to each Plant after checking by chemists. In case that the abnormal results are produced or any problems are raised from plant side, solutions thereof are made by chemists and manager.

(Work for each Section)

- LIGNITE ... Coal analysis of RAW LIGNITE and LIGNITE DUST
- GAS ... Process gas analysis of each GAS, ADIP, AMMONIA, AIR SEPARATION and UREA Plant.
- FINISHED PRODUCTS ... Analysis of finished products of UREA, SULPHURIC ACID, AMMONIUM SULPHATE.
- WATER ... Analysis of Water Quality of RAW WATER, DRUM WATER, STEAM CONDENSATE, WASTE WATER.
- STANDARD ... Preparation of Standard liquid, reagents and measurement line, and management of reagents instruments.

(Report of DAILY WORK)





9-2-2 Study of Organization and Work

- (1) Main works for chemists are check and management of daily work as line engineers at laboratory. However, chemists keep reserved capabilities, which can be spared to staff work, and shall be shifted to the work of investigation and study apart from lines in future.
- (2) At present, specified standard values for judging the existence of abnormality in the analyzed results are not clear enough, and discrepancies sometimes occur among the judgements to abnormal values made by chemists and plant engineers. Specified standard values shall be established between laboratory and plants, so that the prompt and appropriate measures can be taken for abnormal values results by laboratory and plant side.
- (3) Analysis requests are conveyed to laboratory manager by plant engineers. These requests are made verbally but not by written form, whereas, sometimes, the data necessary for problem solution could not be obtained due to improper analysis items and methods. For more clarification, written form of requested analysis shall be made.
- (4) As the rotation of technicians has seldom been executed between each section, flexibility for works is not sufficient. Regular rotation of technicians is necessary.
- (5) At gas and standard sections, 2 chemists are in double obligations. If staffs are in short due to resigns, etc., works will be disturbed. Additional employment or training of successors is necessary.

(6) Records of previous work, preservation of technical data and transference of work at the time of resign, are not executed. These are the negative factors for proper function of laboratory. Improvement shall be made for documentation control.

9-3 Facility of Equipments and Instruments

(Analysis equipments and instruments)

As shown on attached Sheet-1, analysis equipments and instruments, as commonly required, are provided, and inquiries by operation side can be coped with.

However, most of them are of German made as having procured 10 some years before, and troubles occur sometimes due to overaged conditions. In addition, spare parts are not sufficiently provided at the time of troubles, due to totally imported commodities.

In future, appropriate consideration shall be paid for maintenance and spare parts.

(Analysis Reagents/Instruments)

Most of reagents are of imported ones. There are no problems for daily work, as the necessary quantities are reserved. It will take long time to obtain special reagents. On this regard, tie-up collaboration is necessary with adjacent universities and hospitals.

(Facility of Laboratory)

For the facilities of laboratory, gas distribution line and water purifying device for analysis work are not sufficient. Due to no gas distribution line, high pressure gas cylinders are brought in the room. This is dangerous. Water purifying device is treating the industrial water by ion exchanger and, as the quality of water purified therefrom is not good, it cannot be used for microanalysis.

(Recommendation)

1. Following equipments and instruments shall be procured immediately.

Cost (Baht 1000)

1) Element Analyzer (Damaged previously)	200.
2) Colorimeter (often troubled)	60.
3) Gas Chromatography Sample Device (heavily rusted)	10.
Total	270.

2. Counter Measure for Facilities of Laboratory

Construct the internal distribution line of N<sub>2</sub> Gas and analysis work fuel gas, and construct housing for high pressure cylinder at outside. N<sub>2</sub> Gas can be made available by branching from utility line.

Water Purifying Device:

Newly construct the distilled water production device, or draw in the purified water from plant and treat by ion exchanger.

Total cost is estimated as Baht 30,000.-.

9-4 Chemist & Technician

Chemists have enough chemical knowledge for factory.

They keep reserve-capacilities under checking and management of daily work. These reserve-capabilities shall be applied to cooperation work with plant engineers, without limiting to daily work of laboratory.

For maintaining factory, it is necessary to solve problems by cooperated work of plant side and laboratory without limiting to daily work only. For this purpose, it is important to keep close communications with engineers and to study plant (plant engineers' advices are also necessary).

Technicians' works are accurate and their analysis techniques are good. As their fundamental knowledges for chemicals and safety precautions are not sufficient, instructions on these points to them by manager and chemist will result the further level-up of their technical standards.

## 9-5 Future Direction of Laboratory

For the future direction of Laboratory, further fulfillments of daily works shall be established, together with solution of process problems due to overaged condition of factory, under cooperation with plant side, in consideration of the overaged condition of plant.

Following matters are recommended as future direction;

### 1. Work for Chemist and Technician

By transferring checking work of daily work for chemist to technician, reserve energy of chemist shall be used for solving the various problems of whole factory.

In future, investigation and study sections shall be established in laboratory, and chemists shall execute staff work, while daily work shall be managed by section leaders promoted from technicians.

### 2. Management of Specified Value for daily work.

For daily work, specified standard value shall be established, so that technician can check analysis results.

While there would be no problem for raw material coal and finished products inspection, specified standard value shall be established for the judgement of existence of process abnormality on water analysis and process gas analysis.

For water analysis, it is appropriate to establish specified standard value under confirmation between laboratory and plant managers, by referring Japan Boiler Code and examples of boiler water quality control as introduced by us at this time.

For process gas analysis, specified standard value shall be established after study and confirmation between managers, judging from Data comparison between stable period and abnormal period of plant, analysis designed value and previous investigation report. This specified standard value shall be thoroughly made known to technicians and abnormal case, if happen, shall be made possible to be promptly reported.

3. Requested Analysis

Written form shall be provided so that the requested analysis can be made easily by plant side and the result can be used effectively. In the request form, items of purpose, sample name, time, analysis items, and urgency shall be provided. In report form, items of analysis purpose, sample name, analysis result and comment shall be provided, and the reports shall be preserved as record.

Sample forms are shown on attached sheet 2 and 3.

4. Facilities of Equipments and Instruments

As the analysis equipments and instruments are imported, spare equipments and spare parts shall be stocked. Especially, for the one set equipment in the List as indicated in attached sheet-1, attention shall be paid.

As the repair makers for analysis equipments are not available, maintenance of them shall be considered and clarify the man of responsible for equipments handling.

Operation method shall be standardized and operation shall be performed with thorough knowledge by indicating important points of operation on indicating board, etc.

5. Training, Rotation and Staffs

For the further level up of technicians, work training and regular rotation are necessary.

Work trainins are,

Fundamental chemical knowledge (As understandable for analysis methods)

Pant characteristics (As understandable knowledge for analysis purpose)

Specified Standard Value for control

Safety Work Knowledge (Knowledge for high pressure gas, dangerous objects, poisonous substances, as handled in factory)

Rotation shall be performed regularly once a year and shall be planned so that one rotation for all sections can be completed for 4 years.

Manager shall consider the reserves of staffs for non-disturbance to daily work and the execution of aforesaid training and rotation can be helpful for the case of unexpected short of staff numbers.

6. Preservation of Record and Documents

As the preservation of previous work records and technical data, and the transference of work at the time of chemist resigning, have not been executed, systemization of them shall be established. In addition, as the reference documents and data are not sufficient for investigation and study for the problems on the work, the necessary volumes and kinds of such documents shall be provided.



INSTRUMENT OF LABORATORY

NO.	INSTRUMENT/APPARATUS	Q'TY	REMARKS
1	ELEMENT ANALYZER	0	LIGNITE ANALYSIS
2	CALORIMETER	1	LIGNITE ANALYSIS
3	ASH MELTING POINT METER	1	"
4	SMASH MACHINE	1	"
5	SMASH MACHINE SCREW TYPE	2	"
6	SHAKER	1	"
7	SIEVES	1	"
8	GASCHROMATOGRAPH	1	GAS ANALYSIS
9	ORSAT APPARATUS	2	"
10	GAS METER (WET TYPE)	2	"
11	LABO MINI PUMP	3	"
12	ELECTRIC PHOTOMETER	1	WATER & FINISHED PRODUCT ANALYSIS
13	PH METER	2	"
14	CONDUCTIVITY METER	1	"
15	ELECTRIC BALANCE (PRECISEN)	2	GENERAL ANALYSIS
16	ELECTRIC BALANCE	3	"
17	ELECTRIC FURNACE	2	"
18	ELECTRIC DRY OVEN	3	"
19	ELECTRIC REFRIGERATOR	1	"

FORM OF REQUEST FOR ANALYSIS

REQUEST FOR ANALYSIS

SAMPLE		SIGNATURE
SAMPLING DATE		
(PURPOSE)		
(Req, Finished Date)		
(ANALYSIS ITEM)		

PLANT

SIGNATURE

ANALYSIS REPORT

NO

DATE:

THEME		REQUESTED PLANT	
TEST TIME		ANALYSER	
(ANALYSIS PURPOSE)			
(ANALYSIS ITEM & METHOD)			
(ANALYSIS RESULTS)			
(OBSERVATION)			
(REMARKS)			
(EXAMINATION DATA)	OTHER	PIECE	

9-6 Analysis Results

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)	
Gasification	Raw Lignite	from the Train	H <sub>2</sub> O	Xyrol Extraction	35.11	wt%	33.0
			CO <sub>2</sub>	Ba(OH) <sub>2</sub> Titration	1.90	"	"
			C	Soda lime gravimetric		"	52.8
			H	"		"	3.9
			N	Hydrogenation		"	2.3
			S	Combustion	2.59	"	4.2
			Ash content	gravimetric	15.52	"	22.3
			SiO <sub>2</sub> in Ash	Absorption	9.0	"	31.1
			Al <sub>2</sub> O <sub>3</sub>	gravimetric	4.99	"	22.4
			CaO	Titration with EDTA	31.50	"	7.8
			Fe <sub>2</sub> O <sub>3</sub>	"	11.97	"	26.7
			MgO	"	2.19	"	2.0
			Softening point		1340	°C	1080°C
			Melting	"	1390	"	1300°C
			Flowing	"	1410	"	1300°C
			Heat of Combustion	Calorimeter	5712	Kcal/kg	5110 High & water free

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)	
Gasification	Lignite dust	Screw feeder	H <sub>2</sub> O	Xyrol Extraction	6.78	wt%	1/DAY
			CO <sub>2</sub>	Ba(OH) Titration	2.20	"	1/DAY
			C	Soda lime gravimetric	51.30	"	1/WEEK
			H	"	4.69	"	"
			O	"	17.53	"	"
			N	Hydrogenation	1.85	"	Calculated
			S	Combustion	1.75	"	"
			Ash content	gravimetric	16.10	"	1/DAY
			SiO <sub>2</sub> in Ash	Absorption	8.89	"	"
			Al <sub>2</sub> O <sub>3</sub>	gravimetric	7.54	"	"
			CaO	Titration with EDTA	27.85	"	"
			Fe <sub>2</sub> O <sub>3</sub>	"	14.77	"	"
			MgO	"	5.93	"	"
			Softening point		1430	°C	1/DAY
			Melting	"	1495	"	"
			Flowing	"	1535	"	"
			Heat of Combustion				1/DAY

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)	
Gasification	Lignite dust (Cont'd)	Screw feeder	Dust Size	Screening	1.2	1/DAY	
			>0.2 mm		wt%		
			>0.09		"		
			>0.06		"		
Syn. gas	Syn. gas	Effluent of final cooler	<0.06	Orsat	57.8	2/SHIFT	
			CO <sub>2</sub>		9.5		vol%
			O <sub>2</sub>		0.0		
			CO		60.6		
			H <sub>2</sub>		24.5		
			N <sub>2</sub> (+Ar)		5.3		
			CH <sub>4</sub>		0.1		
ADIP (Desulphurization)	ADIP inlet gas outlet gas vent gas	Before Absorber After " After Regenerator	H <sub>2</sub> S	Iodine Titration	0.16	1/DAY	
			H <sub>2</sub> S		ppm		
			H <sub>2</sub> S		2.68		vol%
			H <sub>2</sub> S				

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)	
Ammonia Synthesis	Inlet gas	before Saturator	CO <sub>2</sub>	Orsat	10.5	1/SHIFT	
			O <sub>2</sub>	Ditto	0.0	"	
			CO	Ditto	56.1	"	
			CH <sub>4</sub>	Ditto	0.0	"	
			H <sub>2</sub>	Ditto	27.6	"	
			N <sub>2</sub> (+Ar)	Ditto	5.8	"	
	Outlet of CCV#1			CO <sub>2</sub>	Orsat	38.0	1/SHIFT
				CO	Ditto	5.7	"
	Outlet of CCV#2			CO <sub>2</sub>	Orsat	40.3	1/SHIFT
				CO	Ditto	3.7	"
	Outlet of CO <sub>2</sub> Absorber			CO	Orsat	5.1	1/SHIFT
				N <sub>2</sub>	Ditto	7.8	"
				H <sub>2</sub>	"	87.6	"
	Outlet of Flash vessel			CO <sub>2</sub>	Orsat	65.9	1/SHIFT
				CO	Ditto	3.1	"
H <sub>2</sub>				Ditto	27.2	"	
N <sub>2</sub> (+Ar)				Ditto	5.8	"	

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)
Ammonia Synthesis	Syn. gas	Syn. gas Comp. 7th Stage	H <sub>2</sub>	Orsat	74.7	vol%
			N <sub>2</sub>	Ditto	25.0	"
			O <sub>2</sub>	Gaschromatograph	0.0	"
			Ar	Ditto	0.3	"
			CO	Ditto	0.0	"
			CO <sub>2</sub>	Ditto	46.8	ppm
	Return gas	CO Scrubber return line	CO <sub>2</sub>	Orsat	8.4	vol%
			CO	Ditto	78.6	"
			H <sub>2</sub>	Ditto	3.8	"
			N <sub>2</sub>	Ditto	9.2	"
	Ammonia converter inlet		H <sub>2</sub>	Orsat	61.5	vol%
			N <sub>2</sub>	Ditto	30.2	"
			CH <sub>4</sub>	Gaschromatograph	0.0	"
			CO	Ditto	0.0	"
			CO <sub>2</sub>	Ditto	40.0	ppm
			Ar	Ditto	3.6	vol%
			NH <sub>3</sub>	Absorption	4.7	"



Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)
Ammonia Synthesis	Ammonia Converter outlet		H <sub>2</sub>	Orsat	50.1	vol%
			N <sub>2</sub>	Ditto	28.8	"
			Ar	Gaschromatograph	4.2	"
			NH <sub>3</sub>	Absorption	17.0	"
Urea	Tail gas	Tail gas Scrubber	H <sub>2</sub>	Orsat	61.8	vol%
			N <sub>2</sub>		38.2	"
Feed Water	Raw water	inlet of Flocculator	CO <sub>2</sub>		96.4	vol%
			pH	pH meter	6.75	-
			P-alkalinity	Titration	0	mg/l
			M-	Ditto	2.35	"
			Total Hardness	Ditto	237.2	"
			Carbonate "	Ditto	117.8	"
			Silica	Absorption	1.0	"
			Chloride	Distillation	4.0	"
			Ammonium	"	20.0	"
			Nitrate	Absorption	14.0	"
			Sulphate	"	113.4	"

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)	
Feeder water (cont'd)	Clean Water	Outlet of sand filter	pH	pH meter	8.7	1/DAY	
			P-alkalinity	Titration	0.5		mg/l
			M- "	Ditto	1.0		"
			Total Hardness	Ditto	161.1		"
			Carbonate	Ditto	50.1		"
			Chloride	Absorption	5.8		"
	Soft water	Tank	pH	pH meter	8.8	1/DAY	
			P-alkalinity	Titration	0.25		mg/l
			M- "	"	0.30		"
			Total Hardness	"	2.68		"
			Conductivity	Conductance meter	54.0		µS/cm
Feed water	Deaerator outlet	pH	pH meter	8.8	1/DAY		
		P-alkalinity	Titration	0.3		mg/l	
		M- "	"	0.45		"	
		Ditto	Winkler method	1.78		"	
		P <sub>2</sub> O <sub>5</sub>	colorimetric	0.04		"	
		SO <sub>4</sub> <sup>2-</sup>	"	1.80		"	
		N <sub>2</sub> H <sub>4</sub>		0.33		"	
Conductivity		62					

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)
Gasification	Drum water		pH	pH meter	10.75	1/DAY
			P-alkalinity	Titration	3.35 mg/l	
			M-	Ditto	3.75 "	
			P <sub>2</sub> O <sub>5</sub>	Colorimetric	5.15 "	
			N <sub>2</sub> H <sub>4</sub>	Ditto	0.19 "	
			SO <sub>4</sub> <sup>2-</sup>	Ditto	70.20 "	
			Conductivity	Conductivity meter	1150. µS/cm	
Auxiliary Plant	Feed Water	Boiler	pH	pH meter	8.80	1/DAY
			P-value	Titration	0.30 mg/l	
			M-value	"	0.45 "	
			Ditto	Winkler method	1.78 "	
			P <sub>2</sub> O <sub>5</sub>	Absorption method	0.04 "	
			N <sub>2</sub> H <sub>4</sub>	"	0.33 "	
			SO <sub>4</sub> <sup>2-</sup>	"	1.80 "	
			Conductivity	Conductivity meter	62 µS/cm	

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)	
Gasification Plant	Drum Water		pH	pH meter	10.75	1/DAY	
			P-value	Titration method	3.35		mg/l
			M-value	"	3.75		"
			P <sub>2</sub> O <sub>5</sub>	Absorption method	5.15		"
			N <sub>2</sub> H <sub>4</sub>	"	0.19		"
			SO <sub>4</sub> <sup>2-</sup>	"	70.20		"
			Conductivity	Conductivity meter	1150		µS/cm
Ammonia Synthesis	Drum Water		pH	pH meter	8.95	1/DAY	
			P-value	Titration method	0.25		mg/l
			M-value	"	0.40		"
			P <sub>2</sub> O <sub>5</sub>	Colorimetric	0.04		"
			N <sub>2</sub> H <sub>4</sub>	"	0.54		"
			SO <sub>4</sub> <sup>2-</sup>	"	7.56		"
			Conductivity	Conductivity meter	110		µS/cm

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)					
Urea	Drum		pH	pH meter	9.70	1/DAY					
			P-value	Titration method	0.80		mg/l				
			M-value	"	1.10		"				
			N <sub>2</sub> H <sub>4</sub>	Colorimetric	0.13		"				
			SO <sub>4</sub> <sup>-</sup>	"	27.00		"				
			P <sub>2</sub> S <sub>5</sub>	"	0.78		"				
			Conductivity	Conductivity meter	370.0		µS/cm				
			Sulphuric Acid	Drum water			pH	pH meter	11.20	1/DAY	
							P-value	Titration	12.40		mg/l
							M-value	"	13.25		"
Ditto	Winkler	0				"					
N <sub>2</sub> H <sub>4</sub>	Colorimetric	1.13				"					
SO <sub>4</sub> <sup>-</sup>	"	180.0				"					
Conductivity	Conductivity	3500				µS/cm					
P <sub>2</sub> O <sub>5</sub>	Colorimetric	8.42				mg/l					
Feed water	Steam-Condensate	"				pH	pH meter	7.80	1/DAY		
						NH <sub>3</sub>	Nessler method	0			mg/l

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)	
Ammonium Sulphate	A.S waste water	A.S pond	pH Conductivity	pH meter Conductivity	8.40	L/DAY	
					10000		$\mu\text{S}/\text{cm}$
Urea Plant	N.P waste water	N.P pond	pH	pH meter Conductivity	8.10	L/DAY	
					8000		$\mu\text{S}/\text{cm}$
	Prilled Fertilizer Grade			N <sub>2</sub> total Biuret Moisture Size	Kjeldahl CuSO <sub>4</sub> Gravimetric Screening	45.53	% N $\geq$ 46
						0.9	% Biuret $\leq$ 1
						0.48	% Moisture $\leq$ 1
						<1mm = 2.0	"
						1-2mm = 84.0	"
						1-2.4mm = 98.0	"
	>2.4mm = 0.0	"					
	Urea Solution	Urea solution behind separator I		F-NH <sub>3</sub> NH <sub>3</sub> CO <sub>2</sub> Urea	Titration Volumetric " Gravimetric	0.03	%
21.49						%	
14.05						"	
48.54						"	

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)
Urea Plant	Urea solution (cont'd)	Urea solution behind separator II	NH <sub>3</sub> CO <sub>2</sub> Urea	Titration Volumetric Gravimetric	3.05	% 1/DAY
					1.45	"
		Calbamate solution outlet wash column	NH <sub>3</sub> CO <sub>2</sub>	Gravimetric "	35.16	% 1/DAY
					27.65	"
		Urea storage tank	NH <sub>3</sub> CO <sub>2</sub>	Gravimetric "	1.44	% 1/DAY
					0.72	"
		NH <sub>3</sub> , CO <sub>2</sub> gas behind separator II (collecting line to ammonium sulfate plant)	NH <sub>3</sub> CO <sub>2</sub>	Gravimetric "	50.44	% 1/DAY
					36.28	"
Sulphuric Acid	H <sub>2</sub> SO <sub>4</sub>	(NH <sub>4</sub> ) <sub>2</sub> SO <sub>4</sub>	H <sub>2</sub> SO <sub>4</sub>	Titration	98.4	% 98%± 1/DAY

Plant	Sample	Sampling Point	Analysis Item	Analysis Method	Analysis Result	Remarks (Spec.)
Sulphuric Acid	H <sub>2</sub> SO <sub>4</sub> (cont'd)	Absorber	Total - Fe	Colorimetric	105 mg/l	
		Dryer	SO <sub>2</sub>	Iodine titration	10.5 "	
Ammonium sulphate plant	(NH <sub>4</sub> ) <sub>2</sub> SO <sub>3</sub>		N <sub>2</sub>	Volumetric	27.0 %	%N ≥ 21 l/DAY
			H <sub>2</sub> O	Gravimetric	0.059 "	moisture ≤ 1
			Free-Acid	Volumetric	0.024 "	free H <sub>2</sub> SO <sub>4</sub> ≤ 0.5
			Free-Acid	Titration	0.85 %	
Saturate-Lye			P <sub>2</sub> O <sub>5</sub>	Colorimeter	0.0046 "	l/DAY
			Fe <sup>+2</sup>	"	12 f.p.m	
			Fe <sup>+3</sup>	"	1.5 "	
			Density		1.255	



.....

SECTION 10

POSTSCRIPT



## Section 10 Postscript

### 10-1 Explanation of Report

In Section 2 Process of Mae Moh Factory of this report, considerable many pages are spared for the process explanation. This might be considered as being slightly deviated from the original purpose of this report.

However, the reason of our venture to explain this process is for intending the followings and we are hoping to be understood for our true intention.

- (i) Without explanation of §2, thorough explanations for §3 Conclusion of Survey Team and §4 Result of Survey cannot be made.
- (ii) It is intended to save loss time of at least 3 months by using this report, for the specialists or engineers to be despatched to Mae Moh Factory from Japan in future.
- (iii) It is expected that the section will be useful for the training of common staffs as operators, etc., of Mae Moh Factory.

In addition, detailed reports are indicated for machinery, measurement, electricity and analysis. These are provided, especially considering the effective use of this report by the Engineers of Mae Moh Factory.

The intention of attachment of equipment list is the same as above, and this list is indispensable for PM execution while it is stated in this report that the PM is necessary for rehabilitation of Mae Moh Factory. It is expected to realize further improvement of this equipment list by Mae Moh Factory.

10-2      Gratitude

We would like to express our thanks to all of the staffs of Mae Moh Factory for their active cooperation for our survey of Mae Moh Factory.

Furthermore, express our thanks to all of CFC head office, Japanese Embassy and Japan International Cooperation Agency in Bangkok for their kind consideration during our stay in the Kingdom of Thailand.

As the last, express our thanks to all of the Japan International Cooperation Agency for their kind instructions and consideration to the despatching of survey team and preparation of this report.

## APPENDIX



## EQUIPMENT LIST

- Vessels List
- Heat Exchangers List
- Compressors/Blowers List
- Pump List

BOILER PLANT	1/3 ~ 3/3
FEED WATER ADIP PLANT	1/3 ~ 3/3
AIR SEPARATION PLANT	1/1
GASIFICATION PLANT	1/6 ~ 6/6
AMMONIA PLANT	1/7 ~ 7/7
UREA PLANT	1/5 ~ 5/5
SULPHURIC ACID PLANT	1/4 ~ 4/4
AMMONIUM SULPHATE PLANT	1/1





ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE OPERATION	PRESSURE (kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH	OUTSIDE DIA- METER		WALL THICK- NESS	OPERATION	DESIGN	OPERATION		DESIGN	INLET		
DRUM	2	6,700 <sup>L</sup>	1,400	30	52	270	St35.8/II	STEAM			CAPACITY 26.5 T/H		
WATER TUBE (BOTTOM)	2	530 <sup>W</sup>	70	4	"	"	"	HOT WATER					
HEADER	2	3951 4000 4490x2	191	16	"	"	"	"					
WATER TUBE (UPPER)	2	180 <sup>W</sup>	70	4	"	"	"	"					
DESUPER HEATER	2	4,100 <sup>L</sup>	191	CAP 25 16	"	415	"	STEAM HOT WATER	60 <sup>φ</sup> x8	60 <sup>φ</sup> x8			
INNER SHELL OF		TOTAL, 3005 <sup>L</sup>	146	4.25	"	"	"	"					
DESUPER HEATER		70 <sup>L</sup> 80 <sup>L</sup> 525 2300	(81) (146)	4.25 4.25	"	"	"	"					
STEAM OUTLET HEADER	2	978	191	16	"	465	15Mo3	STEAM	60 <sup>φ</sup> x8	150			
DEARATOR	2												
1ST SUPER HEATER	2				52	465							
2ND "	2				52	"							
NO.1-2 ECONOMIZER	2												
AIR PREHEATER	2										(SPARE YES)		

ITEM-NO EQUIPMENT	NUMBER	COMPRESSOR						MOTOR						REMARKS		
		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		CAPACITY (MM <sup>3</sup> /H, Kg/H)	REVOLUTION (r.p.m.)	TYPE NO.	FOLID	POWER (KW)	VOLT. (V)	AMP. (Amp)	REVOLUTION (r.p.m)		TYPE NO.	JOINT TYPE
		INLET	OUTLET	INLET	OUTLET											
1D FAN	2	185/205 mmH <sub>2</sub> O		D.T 190		105,000	71.4 KW 760 r.p.m.	WB-ST-S -11-LM -a	WASTE GRS	88	380	120	938	KG1406	COUP- LING	ψ=0.87
1ST AIR FAN	2	ATM	205/225 mmH <sub>2</sub> O			25,000	19.2 KW 1,450 r.p.m.	WB-ST-LM- JP 66/960g	AIR	20.4	380	56	1,450	ADM-4062	"	ψ=0.89
2ND AIR FAN	2	ATM	800/850 mmH <sub>2</sub> O			6,100	24.5 KW 2,900 rpm	WB-M-LM- 3.0/ 690g	AIR	33	380	61	2,935	ADM-4002	"	ψ=0.92
STOKER	6									2 HP	380	4.2	1,000			
TRAVELLING GRATE	2															

ITEM-NO EQUIPMENT	NUMBER	PUMP						MOTOR						REMARKS			
		PRESSURE (Kg/cm <sup>2</sup> )		SIZE (mm)	TOTAL- HEAD (m)	CAPA- CITY (M <sup>3</sup> /H)	MATERIAL		FULID	TEMP- ATURE (°C)	SHAFT HORSE POWER (P.S) REVOLUTION (r.p.m.)	POWER (KW)	VOLT. AMP (V)		REVOLA- TION (r.p.m)	TYPE NO.	JOYNT- TYPE
		IN- LET	OUT- LET				CAS- ING	IMPELLER SHAFT SLEEVE									
BOILER FEED WATER PUMP	2	0.8	70	100	75	616	49.5	S.C	CARBON STEEL		2930 r.p.m.	132	380	2960		COUP- LING	
STEAM TURBINE	2	0.7	70	100	75			"	"		N 3000 3000 r.p.m. TRIP 3450 r.p.m.	130 KW 44kg/cm <sup>2</sup> 450°C OUTLET 3.3kg/cm <sup>2</sup>		N 10500 r.p.m. TRIP 12100 r.p.m.	GT322		

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		WALL THICK- NESS	PRESSURE (kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH	OUTSIDE DIA- METER		OPERA- TION	DESIGN	OPERA- TION	DESIGN		INLET	OUTLET		
10 <sup>kg/cm<sup>2</sup></sup> COOLER	1	1,775 <sup>H</sup>	255	6	10	10	429	157	15MO3	180	180	STEAM HOT WATER	CAPACITY = 110 ℓ
3.5 <sup>kg/cm<sup>2</sup></sup> COOLER	1	1,500 <sup>H</sup>	368	6	3	3.5	190	157	HII	180 25	180	STEAM HOT WATER	" = 110 ℓ
(812007) REGENERATOR	1	15,650 <sup>H</sup>	1500	cap 5 6		1.0	150		St37-2 TRAY SUS	150	200 500	ADIP VAPOUR	CAPACITY 26.4 m <sup>3</sup> 16 PIECE (DEMISTER REPLACE)
(812005) ABSORBER	1	15,030 <sup>H</sup>	1900	cap 10 6		1.0	100		St37-2	500 150	500 150	GAS ADIP	CAPACITY 34.2 m <sup>3</sup> WELDING FACTOR $\mu = 0.8$
(812012) SEPARATOR FOR ABSORBER	1	4,800 <sup>H</sup>	1,300	6		1.5	80		St37-2	500	500	GAS	(DEMISTER REPLACE)
(812009) SCRUBBER	1	14,000 <sup>H</sup>	1,300	6		1.0	60		St37-2	500 100	500 100	GAS WATER	CAPACITY = 8.0 m <sup>3</sup> (EPOXY COATING AGAIN)
DEARATOR	1												

ITEM-NO EQUIPMENT	NUMBER	FLUID	CAPA- CITY (Kg/H)	TEMPERATURE (°C)			PRESSURE (Kg/cm <sup>2</sup> )	TUBE AREA (M <sup>2</sup> )	SIZE (mm)			MATERIAL	NOZL (mm)		REMARKS
				INLET	OUT- LET	DE- SIGN			OPER- ATION	DESIGN	HEIGHT LENGTH		OUTSIDE DIA- METER	WALL THICK- NESS	
HOT WATER HEAT EXCHANGER	SHELL	1 HOT WATER				177	24	4,924 L	521	COVER 5	HI	100	100	μ=0.8 TUBE PLATE 45t	
	TUBE									COVER 8					
(812003)	SHELL	1 WATER (V=400L)			120	8	998 H	1020		7	St37-2				
	TUBE									2					
(812004)	SHELL	1 ADIP			160	1.5	650 L	750x1100	CONE 6	HI	200	500	μ=0.8 TUBE		
	TUBE						160	3470 L	1100					5	188 PIECE
(812001)	SHELL	1 ADIP			160	6	3000	25	2.6	St35	200	50	SPIRAL TYPE		
	TUBE													5	
"	"	1 "			70	5	1870 H	1200	4					"	
	TUBE														5
(812006)	SHELL	1 WATER			45	6.2	1133 H	1050	4						
	TUBE														6.2
(812002)	SHELL	2 ADIP			5	5									
	TUBE														6

ITEM-NO EQUIPMENT	NUMBER	PUMP										MOTOR					REMARKS			
		PRESSURE (kg/cm <sup>2</sup> )		SIZE (mm)		TOTAL HEAD (M)	CAPA- CITY (M <sup>3</sup> /H)	CAS- ING	MATERIAL		FLUID	TEMPER- ATURE (°C)	SHAFT HORSE POWER (P.S) REVOLUTION (r.p.m.)	POWER (KW)	VOLT (V)	AMP (AMR.)		REGULA- TION (r.p.m)	TYPE NO.	JOYNT- TYPE
		IN- LET	OUT- LET	IN- LET	OUT- LET				IMPELLER SHAFT SLEEVE	IMPELLER SHAFT SLEEVE										
BOILER FEED WATER PUMP	3		31	65	50	390	13.5	S-C	C-S	HOT WATER		2900 r.p.m.	25	380	48	2960		COUP- LING		
STEAM TURBINE FOR B.F.P	1	D.P 28		65	50			"	"	STEAM HOT WATER	D.T 442	3000 r.p.m. TRIP 3450 r.p.m.						"		
L.P BOILE FEED WATER PUMP	2	6	40	40	60	7	FC	"	"	HOT WATER		2.2 PS	3.5	380	6.6	2900		"		
SOFT WATER PUMP	4	6.6	75	65	55	70	"	"	"	SOFT WATER		15.9 KW	22	380	13	2945	OR 1126-2	"	ψ=0.87	
"	1		150	125	15	200	"	"	"	"		10.4 KW	15	380	31	1450	OR 1126-4	"	ψ=0.83	
COOLING WATER PUMP	3			400	60	1600	"	FC C-S Cu ALLOY	Cu ALLOY	WATER C-S		990 r.p	360	6000	43	990	OR 3124-6B	"	ψ=0.86	
(81100103) ADIP SOLUTION PUMP	3	6	75	50	45	70	"	C-S	C-S	ADIP			13	380	26	2940	OR 1126-2	"		
(81100506) PROCESS WATER PUMP	2	3.2	75	50	30	30	"	"	"	WATER		5.5 PS 2930 r.p.m.	6.5	380	12.3	2935	OR 726-2	"		

ITEM-NO EQUIPMENT	NUMBER	COMPRESSOR						MOTOR						REMARKS		
		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		CAPACITY (NM <sup>3</sup> /H, Kg/H)	REVOLUTION (r.p.m)	TYPE NO.	FLUID	POWER (KW)	VOLT. (V)	AMP. (AMP)	REVOLUTION (r.p.m)		TYPE NO.	JOYNT TYPE
		INLET	OUTLET	INLET	OUTLET											
AIR TURBO	1	ATM	D.P 5.2			24,400	1,500 r.p.m.	VK25	AIR	2,200	6,000	290	1,500		COUPLING	$\psi = 0.95$
EXPANSION TURBINE	2					5,130	16,000 r.p.m.	ET18H		90	380	165	1,480	OR 2026-4	GEAR	
N <sub>2</sub> COMPRESSOR	2						375 r.p.m. S=200									
1 STAGE	1		2.26	25	136	1,928										
2 "	2.26	8.5	39	148	658											
3 "	8.5	24.2	39	138	225											



ITEM-NO	EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
			HEIGHT & LENGTH	OUTSIDE DIA-METER	WALL THICKNESS	OPERATION	DESIGN	OPERATION		DESIGN	INLET		
1	RAW LIGNITE BUNKER	1	16,300 <sup>H</sup>	7,500	500	ATM.			CEMENT			COAL	
1	HOT GAS PRODUCER	1	9,350 <sup>H</sup>	3,010	5 BRICK 250						800	N <sub>2</sub>	
1	ELECTRO FILTER	1											
2	CYCLONE	2		1,412	6							LIGNITE N <sub>2</sub>	
1	FINISHED DUST BUNKER	1	6,850 <sup>H</sup>	5,000	8		D.P 5,000 <sup>mm</sup>					"	
2	NITROGEN TANK	2				5000 <sup>mm</sup>						N <sub>2</sub>	
1	GASIFIER	1	5,926 <sup>L</sup>	2,910 2,694 2,474	10 12 12			JACKET 250	JACKET WRSt37-2	HT 100	100	WATER	
2	SERVICE BIN	2	6730 <sup>H</sup>	2,200 3,670 1,510 700	cap 10 8 8 7 7				St35.8	700	1,200	GAS	
1	WASHER	1	14,250 <sup>H</sup>	3,020	7 CONE 12 CASTABLE 75				MRSt37-2	410	400	LIGNITE N <sub>2</sub>	
									RSt37-2	900	600	GAS	
										20 <sup>A</sup> x64 <sup>PIECE</sup>	300	WATER	

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		WALL THICK- NESS	PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH	OUTSIDE DIA- METER		OPERA- TION	DESIGN	OPERA- TION	DESIGN		INLET	OUTLET		
STEAM DRUM	1					29			HI	300 50	40	STEAM WATER	VOLUME 3,750 ℓ
FINAL COOLER	1	10,350 <sup>H</sup> CONE 2,000 <sup>H</sup>	2,216 2216x420	cap 20 8 CONE 10		3,000 <sup>mm</sup>	H <sub>2</sub> O		St 00	600 40	600	GAS WATER	RASHING RING 200 x 2 <sup>H</sup>
SYNTHESIS FLARE STACK SEAL POT	1	1,200 <sup>H</sup>	1,016	8 BOTTOM 15		3,000 <sup>mm</sup>	H <sub>2</sub> O		MRSt37-2	400	400	GAS WATER	
NITROGEN SEAL POT	1	902 <sup>H</sup>	1,616	8 BOTTOM 20		3,000 <sup>mm</sup>	H <sub>2</sub> O		"	250	250	N <sub>2</sub>	
SYNTHESIS SEAL POT	1	3,258 <sup>H</sup>	2,016	8		3,000 <sup>mm</sup>	H <sub>2</sub> O		"	600	600	GAS	
NO REMOVAL TANK	2	6,725 <sup>H</sup>	6,000	8 BOTTOM 10		1,000 <sup>mm</sup>	H <sub>2</sub> O		"	600	600	"	
CASTABLE LINE TUBULAR BOILER WASHER	1	1,500 <sup>L</sup> 625 <sup>L</sup> 5,610 <sup>L</sup>	1400x900 900 920	7 4 7					HI+CASTABLE " "				625L EXPANSION ND 2 <sup>kg/cm<sup>2</sup></sup> INSIDE 103t CASTABLE N=3
GAS LINE PIPE SEAL POT+BOOSTER BOOSTER + ADIP (742001) SYNTHESIS GAS HOLDER	1	40M 150M	609.6 508	6 6		1,700 <sup>mm</sup>	H <sub>2</sub> O		MRSt37-2				

ITEM-NO EQUIPMENT	NUMBER	FLUID	CAPA- CITY (kg/h)	TEMPERATURE (°C)		PRESSURE (kg/cm <sup>2</sup> )		TUBE AREA (M <sup>2</sup> )	SIZE (mm)			MATERIAL	NOZL (mm)		REMARKS
				INLET	OUT- LET	DE- SIGN	OPERA- TION		DESIGN	HEIGHT LENGTH	OUTSIDE DIA- METER		WALL THICK- NESS	INLET	
COOLING WATER COOLER	SHELL 3	SOFT WATER COOLING WATER	1200 H 400 W				5	6	PLATE TYPE			CARBON STEEL	150	150	
	TUBE														
TUBULAR BOILER	SHELL 1	WATER	5,460		235			29	9,800 H	2,100	CAP 24 25 22	17Mn4 HI	200	300	TUBE PLATE 12t
													TUBE		
RADIATION BOILER	SHELL 1	STEAM	3,460			29		190	7,780 L 7,780 L	76.1 76.1	2.9 5.6	st35.8 15 Mo3	50	150	TOTAL 114
													TUBE		

ITEM-NO EQUIPMENT	NUMBER	COMPRESSOR						MOTOR						REMARKS		
		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		CAPACITY (NM <sup>3</sup> /H, Kg/H)	REVOLUTION (r.p.m)	TYPE NO.	FULID	POWER (KW)	VOLT. (V)	AMP. (AMP)	REVOLUTION (r.p.m)		TYPE NO.	JOYNT TYPE
		INLET	OUTLET	INLET	OUTLET											
RECYCLE VAPOUR FAN	1		D.P 790 mmWS		120	41,400	120 KW 1480 r.p.m	B2667	DUST N <sub>2</sub>	160	380	290	1,485	OR 2424-4	COUP- LING	
RAW MATERIAL BELT CONVEYOR	1					51,970 & 1,000 W 55°4'	20.5 r.p.m	KZN450	COAL	11	380	22.4	1,450		GEAR	
ELCO BELT	1						BYEL	FA2LC2	COAL	1.1	380	2.8	1,400	OR 424-4	GEAR	
HAMMER MILL	1					2600 ϕ 2600 W HAMMER 56 PIECE	260 KW 547 r.p.m.		COAL N <sub>2</sub>	340	6,000	39	1,492	OR 3024-2B	"	
AIR FAN	1	ATM.	D.P 375 mmH <sub>2</sub> O		25	11,520	1,460 r.p.m.		AIR	15.5	380		1,460		COUP- LING	
O5 CHAIN CONVEYOR	1						4 KW 37.5 r.p.m		LIGNITE N <sub>2</sub>		380		1,430		GEAR	
ROTARY VALVE (CYCLONE)	2					5,000 kg/H	BYEL		"		380				"	
RETURNED VAPOUR FAN	1								"	15	380	31	1,460		COUP- LING	
ROTARY VALVE (FINISHED DUST BUNKER)	1					1,200 kg/H	BYEL	FA31	"	1.5	380	3.7	1,470	OR 426-4	GEAR	
SCREW CONVEYOR (FOR SERVICE BIN)	2						3 KW 52 r.p.m.	2LGI 134	"		380	6.7	1,400		"	

ITEM-NO EQUIPMENT	NUMBER	COMPRESSOR						MOTOR						REMARKS		
		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		CAPACITY (NM <sup>3</sup> /H, Kg/H)	REVOLUTION (r.p.m)	TYPE NO.	FUID	POWER (KW)	VOLT. (V)	AMP. (Amp)	REVOLUTION (r.p.m)		TYPE NO.	JOINT TYPE
		INLET	OUTLET	INLET	OUTLET											
CHAIN CONVEYOR (FOR SERVICE BIN)	2						3 KW 52 r.p.m.		LIGNITE N <sub>2</sub>		380	6.7	1,400		GEAR	
SCREW FEEDER	4						BYEL	WAG 4	LIGNITE O <sub>2</sub>	7.5	380	15.6	1,440	OR 786-4	"	
VAPOUR PAN (CYCLONE)	1					16,200	14.5 KW 1,460 r.p.m.	B2301- 99	LIGNITE N <sub>2</sub>	8.5	380	37	1,460	OR 1324-4	COUP- LING	
O <sub>2</sub> BLOWER	2	HOLDER PRESS.	D.P			5,330	17,464 r.p.m.	RT-P315 G	O <sub>2</sub>	110	380	200	2,975	OR 2224-2	GEAR	
N <sub>2</sub> BLOWER	1	"	D.P			2,340	880 r.p.m.		N <sub>2</sub>	75	380	139	1,480	OR 2024-4	GEAR	
	1	"	D.P			474	1450 r.p.m.		"	18.5	"	37	1,460			
WET CONVEYOR	1								SYN.GAS WATER	160	380	290	985		COUP- LING	
GAS BLOWER	2			40		15,400 (0.868 kg/m <sup>3</sup> )	60.5 KW 2,970 r.p.m.		SYN. GAS	90	380	165	2,970	OR 2026-2	"	
BOOSTER	4		D.P	66		13,700 (0.996 kg/m <sup>3</sup> )	82.5 KW 4,700 r.p.m.		"	110	380	200	2,975		GEAR	

ITEM-NO EQUIPMENT	NUMBER	PUMP										MOTOR					REMARKS			
		PRESSURE (Kg/cm <sup>2</sup> )		SIZE (mm)		TOTAL HEAD (M)	CAPA- CITY (M <sup>3</sup> /H)	MATERIAL		FULID	TEMP- ERATURE (°C)	SHAFT HORSE POWER (P.S)	REVO- LUTION (R.P.M.)	POWER (KW)	VOLT (V)	AMP (AMR)		REVOLU- TION (R.P.M)	TYPE NO.	JOYNT- TYPE
		IN- LET	OUT- LET	IN- LET	OUT- LET			CAS- ING	IMPELLER SHAFT SLEEVE			(L.P.M.)								
COOLING WATER PUMP	2 + 1	5		150	125	45	220	FC	CARBON STEEL	WATER	40		4.5	380	84	1470	OR 1726-4	COUP- LING		
SPRAY WATER PUMP	2	16		25	25	130	3	"	"	SOFT WATER				380	8.2	2880		"		
WASHING WATER PUMP (FOR ELECTRIC FILTER)	1			40	25	50	10	"	"	WATER			5.5	380	11.3	2930		"		
FUEL OIL PUMP	2	6						"	"	FUEL OIL			0.55	380		1400				

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH	OUTSIDE DIA- METER	WALL THICK- NESS	OPERA- TION	DESIGN	OPERA- TION		DESIGN	INLET		
(292006) DEMISTURE	1	24,700H (8,328 1,320 4,600 1,350 9,102	1,200 1200x1500 1,500 1500x2000 2,000	CAP 12 13 16 16 21 21		24	200	HI	350 100 80 150	200 250	GAS HOT WATER	TOP 1200φx7M REPLACED (Aug., '78) RASHIG RING/3 LAYER X-RAY 25%, 100% =0.9
(292001) SATURATOR	1	20,185H (9,435 1,250 9,500	1,800 1,100	19 CAP 12		24	200	HI	200 250	200 80	GAS HOT WATER	RASHIG RING 2 LAYERS X-RAY 25%, 100% μ=0.9 (Nov. '77, REPLACED)
(292004) CO CONVERTER	1	8,941H	1,900	24		24	500	13CrMo44	350 "	350 "	GAS "	CATALYST 23,980% X-RAY 100% μ=0.9
(312001) CO <sub>2</sub> SCRUBBER	1	26,673H	2,500	TOP 17 18		23	50	BH36K	500 200	500 200	WATER GAS	TRAY 25 STAGES EPOXY COATING
(312002) FLASH VESSEL	1	5,000L	2,000	20	8	21	50	HI	600	600	WATER	EPOXY COATING
(312013) DEGASIFYING TOWER	1							SEMENT		700 350	WATER CO <sub>2</sub>	
(432102) COPPER SOLUTION SCRUBBER	1	20,000H	800	24		120	50	BH36K	80 100	80 50	GAS COPPER SOL'N	CAPACITY 8.4m <sup>3</sup> RASHIG RING 1. STAGE X-RAY 100% / ANNEALING
(432103) AMMONIA WATER SCRUBBER	1	15,705H	550	15		120	50	HSB50	80 25	80 50	GAS AMMONIA WATER	RASHIG RING 1 STAGE X-RAY 100%

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE OPERATION (kg/cm <sup>2</sup> )	TEMPERATURE (°C)	MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH	OUTSIDE DIA- METER				WALL THICK- NESS	INLET		
(432104) PRESSURE BLAST VESSEL	2	1,905H	323.9	14.2	120	HII	100	100	COPPER SLUTION	X-RAY 25%
(432101) OIL SEPARATOR	1	3,960H	620	26	120	HII	80	80	GAS	" $\mu=0.9$
(432001) REGENERATOR (FOR COPPER SOLUTION)	1	TOTAL 15,932H								
		(7,726)	1,000	6	0.5	SUS304	100	300	GAS	RASHIG RING (SUS304)
		(2,000)	1,000	8	3	HI	200	50	COPPER SDL'N	1 STAGE
		(2,000)	63.5	3	0.5	SUS304				CAPACITY 26.4m <sup>3</sup> 70 PIECES
		CONE								
		(1,304)	650	8	0.5	St37-2	150	150	COPPER SOL'N	" 45.5m <sup>3</sup> 72 PIECES
		(4,902)	650	8	0.5	SUS304				
		(4,225)	51	2.5	0.5					
(432006) SURGE TANK	1	16,100H	1,400	TOP 6 LOW 10 CAP 12	0.5	MRSt37-2 HI	300	150	"	" 16.4m <sup>3</sup>
AMMONIA RECEIVER	1	5,000L	400	6	20	HI	100	65	Liq NH <sub>3</sub>	$\mu=0.8$
(522001) FLASH VESSEL	1	4,830H	1,200	13	31	HII	125	50	"	X-RAY $\mu=0.9$
(522003) TAIL GAS SCRUBBER	1	8,590H	450	7	30	HII	50	50	"	$\mu=0.8$



ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH METER	OUTSIDE DIA- METER	WALL THICK- NESS	OPERA- TION	DESIGN	OPERA- TION		DESIGN	INLET		
(522107) HIGH PRESSURE OIL SEPARATOR	1	3,000H	830	COVER240 65 CAP 160		450	50	24CrMo5	90	90	GAS	X-RAY YES
(522106) HIGH PRESSURE HN <sub>3</sub> SEPARATOR	1	4,950H	1,000	COVER365 60 CAP 102		450	50	42CrMo4	90	90	"	"
(522101) NH <sub>3</sub> SYNTHESIS CONVERTER	1	13,000H	950	COVER285 TOP 250 75 BOTTOM250		450	200	24CrMo5	90 45	200	"	"
(111002) SYNTHESIS GAS COMP. 4TH STAGE SUCTION SEP.	2	1,700H	558	10		24	60	HI	150	200	"	
" 3TH STAGE SEPARATOR	2	1,685H	558	10		28	60	HI	125	250	"	
" 4TH STAGE SEPARATOR	2	1,750H	406.4	CAP 13 12.7		66	60	HI	67	100	"	
" 5TH STAGE SEPARATOR	2	1,950H	TOP 345 323.9	72.5 20		123	60	RSt42-2 St35.8	50	75	"	
" 6TH STAGE SUCTION SEPARATOR	2	1,250H	TOP 430 275	123 17.5		121	60	St35.4	175	200	"	
" 6TH STAGE SEPARATOR	2	1,959H	TOP 305 244.5	93.5 26		265	60	CK35N St35.8	43.5	50	"	
" 7TH STAGE SEPARATOR	2	1,750H	TOP 315 244.5	46		495	60	CK35N St45.8	35	45	"	

ITEM-NO EQUIPMENT	NUMBER	FLUID	CAPA- CITY (Kg/H)	TEMPERATURE (°C)			PRESSURE (Kg/cm <sup>2</sup> )	TUBE AREA (M <sup>2</sup> )	SIZE (mm)			MATERIAL	NOZL (mm)		REMARKS
				INLET	OUT- LET	DESIGN			HEIGHT LENGTH	OUTSIDE DIA- METER	WALL THICK- NESS		INLET	OUTLET	
(292002) HEAT EXCHANGER I	SHELL	1 SYN. GAS		236	24			3,182 L	700	CAP 15	HII	350	350	μ=0.8 EXPANSION 16CrMo4	
	INNER SHELL							3,182 L	600	CAP 8		350	350		131 PIECES
(292003) HEAT EXCHANGER II	TUBE	SYN. GAS		410	24		20	2,000 L	26.9	2.3	St35.8/II	350	350		
	SHELL	"		500	24			7,344 L	900	CAP 29	13CrMo44	350	350	x-RAY μ=0.9	
(292005) WATER PREHEATER	INNER SHELL	"		500	24			7,344 L	800	CAP 14	15Mo3	350	350	EXPANSION 13CrMo44	
	TUBE	"		500	24		150	5,600 L	26.9	2.6	15Mo3	350	350		
(292007) WATER PREHEATER	SHELL	1 WATER		200	27		120	COVER	622	14	HII	350	350	x-RAY	
	EXPAN- SION TUBE							463x2 650 L 5510 L 745 L 292	21 13 24 3	250		250	239 PIECES		
(292008) COOLER FOR CIRCULATING WATER	SHELL	1 COOLING WATER		100	5			8,430 H	670	COVER 11	HII	250	250		
	TUBE							HOT WATER	113	27		175	25		2
(432007) COPPER SOLUTION COLLER	SHELL	5 COOPER SOL'N		39	45			5,446	318	7.5	St35	80	80		
	TUBE							WATER	100	6			50		50
COPPER SOLUTION COLLER	SHELL	1 LQ NH <sub>3</sub> COPPER SOL'N		50	20			4,949	700	7	HI	150	150		
	TUBE							COPPER SOL'N	50	6		129	25		2
NH <sub>3</sub> CONDENSER	SHELL	1 NH <sub>3</sub> WATER		120	20			5,949	700	8	HI	150	100		
	TUBE							WATER	50	6		164	25		2

HEAT EXCHANGER LIST

ITEM-NO EQUIPMENT	NUMBER	FLUID	CAPA- CITY (Kg/H)	TEMPERATURE (°C)			PRESSURE (Kg/cm <sup>2</sup> )		TUBE AREA (M <sup>2</sup> )	SIZE (mm)			MATERIAL	NOZL (mm)		REMARKS
				INLET	OUT- LET	DE- SIGN	OPERA- TION	DESIGN		HEIGHT LENGTH	OUTSIDE DIA- METER	WALL THICK- NESS		INLET	OUTLET	
(522104) WASTE HEAT BOILER	SHELL 1 TUBE	BOILER WATER SYN.GAS	2.6 T/H	80	220	220	1.5	5	1600	4,150 H	10	25	200	x-RAY		
							450	75	1,565 M	5	90					
(522105) GAS COOLER	SHELL 1 TUBE	WATER SYN.GAS NH <sub>3</sub>		50	200	200	5	450	750	11,884 H HEADER	CAP 7	200	200			
							450	120	885 220x10	23 8 3.6	90					
(111002) SYNTHESIS GAS COMPRESSOR	SHELL 2 TUBE	SYN.GAS WATER		200	200	200	3.4		750	3,300	CAP 7	400	400	143 PIECES x 5 SECTION		
							4.6		690	15	1					
2ND "	SHELL 2 TUBE	GAS WATER		160	40	40	11.3		500	3,472	10	250	250	144 PIECES x 4 SECTION		
							4.6		690	15	1					
3RD "	SHELL 2 TUBE	GAS WATER		150	39	39	28		465	2,400	CAP 11	250	125			
							4.6		1,800	16	1.5					253 PIECES
4TH "	SHELL 2 TUBE	WATER GAS		40	40	40	4		127	5,120	4	100	100			
							66	16.1	76.1	4.5	65	65	65	15 "		
5TH "	SHELL 2 TUBE	" "		40	40	40	4		114.3	5,120	3.6	75	75			
							123	16.7	63.5	5.6	50	50	50	18 "		
6TH "	SHELL 2 TUBE	" "		40	40	40	4		114.3	5,120	3.6	75	75			
							265	13.2	63.5	10	43	43	43	13 "		
7TH "	SHELL 2 TUBE	" "		40	40	40	4		108	5,120	3.6	75	75			
							450	13.5	60.3	12.5	35	35	35	14 "		

ITEM-NO EQUIPMENT	NUMBER	COMPRESSOR										MOTOR				REMARKS
		PRESSURE (kg/cm <sup>2</sup> )		TEMPERATURE (°C)		CAPACITY (NM <sup>3</sup> /H, Kg/H)	REVOLUTION (r.p.m)	TYPE NO.	FUID	POWER (KW)	VOLT. (V)	AMP. (amp)	REVOLUTION (r.p.m)	TYPE NO.	JOYNT TYPE	
		INLET	OUTLET	INLET	OUTLET											
(521001) GAS CIRCULATING COMPRESSOR	2	D.P 431	D.P 451	70	70	8,220	180 r.p.m		GAS	153	380	280	990	OR- 2624-6	FLAT	
AMMONIA COMPRESSOR	2			150	75				NH <sub>3</sub>	175	380	310	1490	OR- 2426-4	"	
(111002) SYNTHESIS GAS COMPRESSOR	2	MIN 200	D.P 2.53	D.T 35			3035 PS 250 r.p.m STROK 500		GAS	2,500	6000 CYL.DIA	263 PISTON DIA(mm) 1052	250	PFW580 /18-24	COUP- LING	
1ST STAGE		2.5	9.5	"		N 5730 MAX 6875			"		708	705				MAIN METAL 300 H7
2ND "		9.5	24	"					"		415	413				CROSS METAL 140 H7
3RD "		21	56	"		N 6038			"		320	318				
4TH "		56	110	"		MAX 7245			"		215	213				
5TH "		100	234	"		N 5684			"		134	133				
6TH "		222	451	"		MAX 6820			"		94	92				
7TH "																

ITEM-NO EQUIPMENT	NUMBER	PUMP										MOTOR					REMARKS			
		PRESSURE (Kg/cm <sup>2</sup> )		SIZE (mm)		TOTAL- HEAD (M)	CAPA- CITY (M <sup>3</sup> /HR)	MATERIAL		FULID	TEMPER- ATURE (°C)	SHAFT HORSE POWER (P.S)	SHAFT REVOLUTION (r.p.m.)	POWER (KW)	VOLT (V)	AMP (AMR)		REVOLU- TION (r.p.m)	TYPE NO.	JOYNT- TYPE
		IN- LET	OUT- LET	IN- LET	OUT- LET			CAS- ING	IMPELLER SHAFT SLEEVE											
COOLING WATER PUMP	2	5.8	250	200	400	F.C	CARBON STEEL	WATER	35	66 KW	75	1480	139	380	1480	IIA2- 204	COUP- LING			
(291001) HOT WATER PUMP	2	28	250	250	62	SC	"	HOT WATER	170	2900 r.p.m.	64	2970	118	380	2970	OR- 2024-2	"			
(291002) WARM WATER PUMP	2	26	75	75		"	"	"			9.5	2935	18	380	2935	OR- 884-2	"			
(311001~2) WATER PUMP	1	0.4	250	250	1600	"	"	WATER	35	1480 r.p.m.	1100	1490	127	6000	1490	"	"			
WATER TURBINE I II		22.5	250	250		FC	SUS C-S	"												
(431001) COPPER SOLUTION PUMP	2	8.4	150	100	33	S.C	C-S	COPPER SOLUTION		190 PS 130 r.p.m.	180	990	330	380	990	OR- 2624-6	FIAT BELT			
(431002) H.P AMMONIA WATER PUMP	2	120	50	25	3	"	"	AMMONIA WATER		17.5 PS 250 r.p.m.	17	1465	34	380	1465	OR- 1324-4	"			
(431003) CONDENSATE PUMP	1	120	50	25	1	"	"	WATER		120 r.p.m.	6.8	1445	14	380	1445	IMA2078 -4BA	V-BELT			
CONDENSATE PUMP	1	32	50	25	2.8	"	"	"		4.5 PS 220 r.p.m.	5	1445	10.5	380	1445	IMA2072 -4BA	"			

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE (kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH	OUTSIDE DIA-METER	WALL THICKNESS	OPERATION	DESIGN	OPERATION		DESIGN	INLET		
(572101) 2ND REACTOR (LINING)	1	17,950H	1,000	TOP 165 50 5 7	200	230	170	190	WB35 WNR4404	40	40	UREA X-RAY 100% μ=1.0
(571001) CO <sub>2</sub> COMPRESSOR 4TH STAGE SEPARATOR	1	1,584H BOTTOM 40	TOP 220 168.3	TOP 525 11		108		MAX 70	St35.8	35	75	CO <sub>2</sub>
5TH STAGE SEPARATOR	1	2,015H	TOP 310 191	20		230		150	10CrMo10	45	45	CO <sub>2</sub>
(572006) WASHING COLUMN	1	6,820H { 4130 750 1940	412 720	6 10 CAP 14		25		150	WNR4550	80 25	80 25	GAS NH <sub>3</sub>
(572001) NH <sub>3</sub> FILTER	2	2,270H	509	10		30	45	100	MRSt37-2	50	50	NH <sub>3</sub> X-RAY 25%
(572005) 1ST STAGE SEPARATOR	1					25			WNR4550			
(572013) DISSOCIATION SEPARATOR	1					3						
(572009) AMMONIA STORAGE	1	3,110L	1,200	CAP 16 14		25		45	HII HI	50	40	HN <sub>3</sub> μ=0.8
(572020) SUPPLETION WATER TANK	1	1,500H	1,000	CAP 16 14		30	45	60	HII HI	25 15	20	WATER N <sub>2</sub> μ=0.8

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE (kg/cm <sup>2</sup> )	TEMPERATURE (°C)	MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH METER	OUTSIDE DIA- METER				WALL THICK- NESS	OPERATION		
(572021) STEAM CONDENSATE TANK	1	2,100H	2,200	10	ATM	140	St37-2	50	CONDEN- SATE	
(572031) SEAL TANK FOR CONDENSATE	1	2,300H	500	2	"	45	WNr4550			
(812002) UREA STORAGE TANK	1	5,000L	2,200				WNr4541	25	UREA	(INSIDE U-TUBE)
(812003) UREA FILTER	1	960H	400	3			WNr4541	50	UREA	
(572015) ABSORPTION COLUMN	1	2,996H	400	3	0.2	150	WNr4541	100	GAS	
(572014) NH <sub>3</sub> CONDENSATE TANK	1	3,178	2,000		ATM					
(812007) 2ND SEPARATOR	1	2,700H	700	6	2	200	WNr4541	200	250	
(812005) SEPARATOR	1									
PRILLING TOWER	1									
CO <sub>2</sub> DRYING ABSORBER	2	3,000L	1,800	8	500 <sup>mm</sup>	160			AIR CO <sub>2</sub>	

ITEM-NO EQUIPMENT	NUMBER	FLUID	CAPA- CITY (kg/h)	TEMPERATURE (°C)		PRESSURE (kg/cm <sup>2</sup> )		TUBE AREA (M <sup>2</sup> )	SIZE (mm)			MATERIAL		NOZL. (mm)		REMARKS
				INLET	OUT- LET	OPERA- TION	DESIGN		HEIGHT LENGTH	OUTSIDE DIA- METER	WALL THICK- NESS			INLET	OUTLET	
(571001) CO <sub>2</sub> -COMPRESSOR 4TH STAGE COOLER	1	WATER CO <sub>2</sub>				4		5,120	88.9	3.2	st35	65	65			DOUBLE TUBE TYPE (Aug. '78) (REPLACE)
"	1	WATER CO <sub>2</sub>				108	3.38	5,336	44.5	4.5	st35.8	35	35			
(572104) 3RD STAGE COOLER	1	STEAM		150	175	4	9.1	5,120	88.9	3.2	st35	65	65			DOUBLE TUBE TYPE
FIRST REACTOR		UREA		175	190	32		5,331	70	3.6	st35.29	65	65			DOUBLE TUBE TYPE
(812011) CONDENSATOR	1	GAS WATER		150	150	3.5		7,193	1500	13	HII	100	100			
(812009) CONDENSATOR 2ND STAGE EVAPORATOR	1	GAS WATER		150	150	230	12.7	8230x2 5950Vx12	40 25	3.5 3	Nr 4580	33	33			
(812004) HEATER 1ST STAGE EVAPORATOR	1	STEAM UREA		150	150	2		3,650	550	COVER 5 4	Nr 4541	250	32			
(812006) HEATER 2ND STAGE EVAPORATOR	1	STEAM UREA		200	200	2		2500Vx81	25	2	"	200	200			
(572007) NH <sub>3</sub> CONDENSER	1	NH <sub>3</sub> WATER		100	100	10		4750	550	COVER 5 4	Nr 4541	250	32			
(572008) NH <sub>3</sub> CONDENSER	1	NH <sub>3</sub> WATER		100	100	2		3650Vx81	25	2	"	200	200			
				200	200	10		2000	450	5	Nr 4404	100	40			
				200	200	10		2000	25	2	"	25	250			
				200	200	10		2000	273	4	Nr 4404	50	25			
				200	200	10		2000	25	2	"					
				100	100	25		5235	503	11	st35	125	100			
				100	100	4		4500	25	2	st35 8/I	150	150			
				100	100	25		3000	508	11	st35	125	100			
				100	100	4		3000	25	2	st35 8/I	150	150			



ITEM-NO EQUIPMENT	NUMBER	COMPRESSOR						MOTOR						REMARKS			
		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		CAPACITY (NM <sup>3</sup> /H,KG/H)	REVOLUTION (r.p.m.)	TYPE NO.	FUID	POWER (KW)	VOLT. (V)	AMP. (AMP)	REVOLUTION (r.p.m.)		TYPE NO.	JOYNT TYPE	
		INLET	OUTLET	INLET	OUTLET												
AIR BLOWER	1	ATM	500 mmH <sub>2</sub> O			6,720	14 KW 2940 r.p.m.		AIR	19	380	37	2,955	OR- 1126-2	COUP- LING		
CO <sub>2</sub> BLOWER	2	HOLDER PRESS.	718 mmH <sub>2</sub> O			3,660	2,900 r.p.m.		CO <sub>2</sub>	13	380	26	2,940	OR- 1126-2	"		
(571001) CO <sub>2</sub> COMPRESSOR	1					2,450	780 P.S 295 r.p.m. STROK 400 mm		CO <sub>2</sub>	680	6,000	80	295	CSPRY- 487/1820	"		
1ST STAGE		D.P 718					CYLINDER DIA. 673 φ		PISTON DIA. 672 φ								MAIN BEARING H7 236
2ND "		3.7		37			470		468								CROSS BEARING H7 112
3RD "		12.9					238		236								
4TH "		27.6					168		167								
5TH "		93			125		70		69								

ITEM-NO EQUIPMENT	NUMBER	PUMP										MOTOR						REMARKS	
		PRESSURE (Kg/cm <sup>2</sup> )		SIZE (mm)		TOTAL HEAD (m)	CAPA- CITY (M <sup>3</sup> /10)	MATERIAL		FULID	TEMPER- ATURE (°C)	SHAFT HORSE POWER (P.S) REVOLUTION (r.p.m.)	POWER (KW)	VOLT- AGE (V)	AMP (AMP)	REVOLU- TION (r.p.m)	TYPE NO.		JOYNT- TYPE
		IN- LET	OUT- LET	IN- LET	OUT- LET			CAS- ING	IMPELLER SHAFT SLEEVE										
(571006) H.P FLUSH WATER PUMP	1		20	10	2000	0.5	S.C	3 PLUNGERS	WATER		3.6 KW 155 r.p.m.	4.8	380	11.6	950	OR- 726-6	V-BELT		
(571002) AMMONIA PUNGER PUMP	1	21	65	40		10	S.C	"	LIQ- NH <sub>3</sub>		179 r.p.m.	1.00	380	190	1488	OR- 2244-4	GEAR		
(571006) FEED WATER PUMP	2		25	25	88.1	2.73	S.C	C-S	WATER		2850 r.p.m.	9.5	380	18	2935	OR- 824-2	COUP- LING		
(571010) CONDENSATE PUMP	1		25	25	48.1	3.6	F.C	C-S	WATER		2850 r.p.m.	4.6	380	8.8	2935	OR- 724-2	"		
(571007) ABSORPTION CIRCULATING PUMP	1		50	50	35.1	16	SUS	SUS	NH <sub>3</sub> WATER		2850 r.p.m.	4.6	380	8.8	2935		"		
(571011) N <sub>2</sub> COMPRESSOR	1		40	15	300	25	S.C	C-S	N <sub>2</sub>		1450 r.p.m.	6.8	380	14.1	1445	OR- 726-2	"		
(57100) SUPPLETION PUMP	2		25	25	250	1	SUS	SUS (3 PLUNGERS)	CONDEN- SATE		250 r.p.m.	2	380	4.45	1420	OR- 523-4	V-BELT		
(811002) UREA SOLUTION PUMP	2		25	25	85	35	SUS	SUS	UREA		2850 r.p.m.						COUP- LING		
(811003) UREA MELTING PUMP	2		50	40	47.5	54	SUS	SUS	UREA		2850 r.p.m.						"		

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE (Kg/cm <sup>2</sup> )	TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH METER	OUTSIDE DIA- THICK- NESS		OPERA- TION	DESIGN		INLET	OUTLET		
DRUM	1	3,000L	1,200			236	17Mn4	100	150	HOT WATER STEAM	
					32			75	75		
CONVERTER	1	10,500H	6,036					600	420	GAS	
			4,800					620	620	"	
DRYING TOWER	1	8,150H	4,420		0.3		MSt37	920	1,100		BRICK 80t
ABSORPTION TOWER	1	8,150H	4,420		0.3		MSt37	920	1,100		"
ACID TANK	2	7,000H	6,000								

ITEM-NO EQUIPMENT	NUMBER	FLUID	CAPA- CITY (Kg/H)	TEMPERATURE (°C)		PRESSURE (Kg/cm <sup>2</sup> )		TUBE AREA (M <sup>2</sup> )	SIZE (mm)			MATERIAL	NOZL (mm)		REMARKS
				INLET	OUT- LET	OPERA- TION	DESIGN		HEIGHT LENGTH	OUTSIDE DIA- METER	WALL THICK- NESS		INLET	OUTLET	
WASTE HEAT BOILER (ECONOMIZER) (SUPER HEATER)	SHELL	GAS	8 T/H	100	350		32	280	10150 H	3000	10		1400	1200	
	TUBE	STEAM						190	1536 M	60.3	3.2	St35.8			
AIR PREHEATER	SHELL	AIR							7725 H	2820	10	MRSt37	1000	1000	CASTABLE 65t
	TUBE	GAS							5570 5570	44.5 44.5	4 4.6		1000	1000	102 PIECES 944 "

ITEM-NO EQUIPMENT	NUMBER	COMPRESSOR						MOTOR						REMARKS		
		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		CAPACITY (NM <sup>3</sup> /H, Kg/H)	REVOLUTION (r.p.m)	TYPE NO.	FUID	POWER (KW)	VOLT. (V)	AMP. (amp)	REVOLUTION (r.p.m)		TYPE NO.	JOYNT TYPE
		INLET	OUTLET	INLET	OUTLET											
AIR FAN	2	AIM	1910 mm			25,920	170 KW 1460 r.p.m.		AIR	200	380	370	1480	OR- 1992-4D	COUP- LING	

ITEM-NO EQUIPMENT	NUMBER	PUMP							MOTOR					REMARKS					
		PRESSURE (Kg/cm <sup>2</sup> )		SIZE (mm)	TOTAL- HEAD (M)	CAPA- CITY (M <sup>3</sup> /H)	MATERIAL		FULID	TEMP- RATURE (°C)	SHAFT HORSE POWER (P.S)	SHAFT REVOLUTION (r.p.m.)	VOLT- AMP (V)		VOLT- AMP (AMR)	REVOLU- TION (r.p.m)	TYPE, NO.	JOYNT- TYPE	
		IN- LET	OUT- LET				CAS- ING	IMPELLER SHAFT SLEEVE											
ACID PUMP	8				22	45													

AMMONIUM SULPHATE PLANT

TOWER, VESSEL, TANK LIST

ITEM-NO EQUIPMENT	NUMBER	SIZE (mm)		PRESSURE (Kg/cm <sup>2</sup> )		TEMPERATURE (°C)		MATERIAL	NOZZLE (mm)		FLUID	REMARKS
		HEIGHT & LENGTH	OUTSIDE DIA- METER	WALL THICK- NESS	OPERA- TION	DESIGN	OPERA- TION		DESIGN	INLET		
(512001) SATURATOR	2	7,350H	4,000	10				MRSt37-2	300	150		BRICK 30t x 2 LAYER
(512003) LEY TANK		7,154L	2,800	4								

## INSTRUMENT

- INSPECTION SCHEDULE APP.- 35
- INSPECTION RECORD
  - INSTRUMENT APP.- 37 ~ APP.- 99
  - CONTROL VALVE APP.- 100 ~ APP.- 113
  - OTHER INSTRUMENT APP.- 114 ~ APP.- 159



INSTRUMENT TIME SCHEDULE FOR ANNUAL SHUT DOWN OF MAE MOH FACTORY

4. JUL. 1978

ITEM	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	REMARK		
1 Control valve over level Qualification LCV-3 to mail post Fuel water PCV-3-03-02 TCV-3-03-03 PCV-3-04-01 TCV-3-04-02 PCV-3-07-04 PCV-3-07-02 LCV-3-07-02 LCV-3-08-01 LCV-3-08-03 LCV A.S PCV-2-21-09 LCV-2-21-02 TCV-2-21-09 Fuel water LCV																							
2 Flows recorder over level Qualification Sulphuric acid Control over level Ammonia Ammonium sulphate																							diaphragm change
3 Valve Check Qualification Feed water Egat Boiler Ammonia Sulphuric acid Ammonium sulphate																							TRA-1, TR-2, TRA-3, TR-23, TR-24, TI-23-1, TI-7 TR-883-3, TR-883-6, TR-881-2
4 Protection take inspection Egat Boiler Qualification Adip Sulphuric acid Ammonium sulphate Ammonia																							FIC-3-27-03 PIC-3, PIC-4, PRCA-19, FRC-4A, TIC-88 PRC-2-51-02, PRC-251-09, TIC-2-51-09  41 ml 5 2 4 25 1 4
5 Disperser cleaning																							TI-2 TR-1-3, TR-23-1, TR-23-4, TR-24-3 TR-4-11-01-5, TR-4-11-01-2, TR-4-11-07 TI-881-1-1, TI-881-1-10, TI-880-11 TR-01-4, TIC-2-51-09 TR-3-29-01-3, TR-3-29-01-6, TR-3-29-01-11, TIC-3-29-04 TI-3-43-01-1, TI-3-43-01-4, TI-3-43-01-10, TR-3-52-04
6 Change new type																							LICA-3-29-01, LICA-3-29-02, LICA-3-31-01 PT-3-52-09 PT-3-52-04
7 PG & regaining check Qualification Feed water Adip Egat Boiler Ammonia Air separation Sulphuric acid Ammonium sulphate																							5 ml regaining AC 220T Line 10 15 20 30 30 20 20
8 Thermocouple change Qualification Ammonia Compenation wire change																							TRA-2/1-4, TRA-3/1-4, TR-20/1-4, TR-23/1-4 TR-24/1-4, TR-1/1-4 TR-3-29-01/1-12, TR-3-29-02/1-4, TIC-3-29-04 TR-3-43-01/1-11, TIC-3-43-02, TI/1-3-29-03 TR-23-1, TR-1/1 (Qualification)
9 Feed water valve system change Egat Boiler Fuel preparation control valve wiring I.A. line, Alarm Transmitter lead pipe Test																							FCE type 2 ml, SEA type 2 ml. Egat Boiler PCV-3-55-01 Cable 400m 5 ml
10 Ammonia M. line change Fuel preparation control PT PCV I.A. take out Test																							Ammonia & Air separation PIC, FIC Air separation Ammonia & separation PCV, PCV PT

NOTE:  
 Qualification PT-19 take off & on, LA-2-6 check FR-16 orifice.  
 Adip TI-4-11-01-7 TI-4-11-01-8  
 Ammonia TR-3-52-01/2-7 check HCV-3-52/02-08 action test  
 TI-3-52-01/2-7  
 Sulphuric acid FI-881-1 orifice  
 Air separation 4 way valve check (1/19-22)  
 Egat Boiler change SW at Temp meter oil pump check



GASIFICATION PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FIC-6A	NO.1 O <sub>2</sub> BLOWER	0~5000 Nm <sup>3</sup> /h	2850 Nm <sup>3</sup> /h	90%	-	0	0	0	0	-	CONTROLLER OVERHAULED / GOOD
FIC-6B	NO.2 O <sub>2</sub> BLOWER	"	0 STOP	0	-	0	0	0	0	-	CONTROLLER OVERHAULED / GOOD
FR-8	O <sub>2</sub> CONSUMPTION	0~5000 Nm <sup>3</sup> /h	2800 Nm <sup>3</sup> /h	-	0	-	-	0	-	-	
FR-9 A1	O <sub>2</sub> FLOW BLOW-PIPE 1	0~1500 Nm <sup>3</sup> /H	780 Nm <sup>3</sup> /H	-	0	0	-	0	-	H X	
" A2	" BLOW-PIPE 2	"	675 Nm <sup>3</sup> /H	-	0	0	-	0	-	H X	
" B1	" BLOW-PIPE 3	"	600 Nm <sup>3</sup> /H	-	0	0	-	0	-	H X	
" B2	" BLOW-PIPE 4	"	675 Nm <sup>3</sup> /H	-	0	0	-	0	-	H X	
FR-11	O <sub>2</sub> EMERSION SHAFT	0~200 Nm <sup>3</sup> /H	130 Nm <sup>3</sup> /H	-	-	0	-	0	-	-	
FI-13	COOLING WATER TO THE WASHER	0~200 m <sup>3</sup> /H	116 m <sup>3</sup> /H	-	-	0	-	0	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FI-14A	NO.1 THEISEN WATER	0~30 m <sup>3</sup> /H	15 m <sup>3</sup> /H	—	—	0	—	0	—	—	
" -14B	NO.2 THEISEN WATER	"	16.2 m <sup>3</sup> /H	—	—	0	—	0	—	—	
FI-15	COOLING WATER TO FINAL COOLER	0~20 m <sup>3</sup> /H	7 m <sup>3</sup> /H	—	—	0	—	0	—	—	
FR-16	SYNTHESIS GAS	0~12500 Nm <sup>3</sup> /H	8000 Nm <sup>3</sup> /H	—	0	—	—	0	—	—	ORIFICE CLEANED
FI-20	STEAM	0~11000 Nm <sup>3</sup> /H	1150 Nm <sup>3</sup> /H	—	—	0	—	0	—	—	
FI-21	N <sub>2</sub> GAS	0~300 Nm <sup>3</sup> /H	0 Nm <sup>3</sup> /H	—	—	0	—	0	—	—	
FI-23	WASHER WATER	0~100 %	46%	—	—	Δ	—	Δ	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PIC-3	NO.1 N <sub>2</sub> BLOWER	0~10000 mmWG	7500 mmWG	0%	-	0	0	0	0	-	CONTROLLER OVERHAULED / GOOD
PIC-4	NO.2 N <sub>2</sub> BLOWER	"	0	0	-	0	0	0	0	-	CONTROLLER OVERHAULED / GOOD
PIA-5	N <sub>2</sub> VESSELS	"	5400 mmWG	-	-	0	-	0	-	H x L	
PGA-8A	O <sub>2</sub> BLOWER	0~4 kp/cm <sup>2</sup>	1.0 kp/cm <sup>2</sup>	-	-	-	-	-	-	H x L	
PGA-8B	"	"	0	-	-	-	-	-	-	H x L	
PRA-10	O <sub>2</sub> MAIN	0~10000 mmWG	5000 mmWG	-	0	-	-	0	-	H x L	
PIA-11A1	O <sub>2</sub> PRESS	0~2500 mmWS	1300 mmWS	-	-	0	-	0	-	H x L	
" A2	"	"	1500 mmWS	-	-	0	-	0	-	H x L	
" B1	"	"	1350 mmWS	-	-	0	-	0	-	H x L	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PIA-11B2	O <sub>2</sub> PRESS	0~2500 mmWS	1200 mmWS	—	—	0	—	0	—	H x L	
PR-13	IMMERSION SHAFT	-160~0 ~+250 mmWS	+90 mmWS	—	0	—	—	0	—	—	
PRCA-19	SYN GAS BLOWER	-400~0 ~+250 mmWS	+250 mmWS	75%	0	0	0	0	Δ	H x L	CONTROLLER OVERHAULED / GOOD
PRCA-21	SYN GAS BOOSTERS	0~1000 mmWS	+400 mmWS	75%	0	0	0	0	Δ	H x L	
PI-22	SYN GAS BOOSTERS OUT	0~6000 mmWS	2400 mmWS	—	—	0	—	0	—	—	
PGA-23A	WASH SPRAY	0~6 kp/cm <sup>2</sup>	5 kp/cm <sup>2</sup>	—	—	Δ	—	—	—	x L	
PGA-23B	PUMP HOUSE	"	3 kp/cm <sup>2</sup>	—	—	Δ	—	—	—	x L	
PIA-25	SYN GAS SEAL POT	0~1600 mmWS	600 mmWS	—	—	0	—	0	—	H x	
PIA-27	COOLING WATER PUMP	0~10 kp/cm <sup>2</sup>	5.2 kp/cm <sup>2</sup>	—	—	0	—	—	—	x L	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PR-35A	SERVICE BIN A	0-1000 mmWS	1.00 mmWS	-	0			0	-	-	
PR-35B	" B	"	"	-	0			0	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LICA-5	STEAM DRUM	0~500 mm	250 mm	10%	-	0	0	0	X	H L	CONTROLLER AND CONTROL VALVE BOTH WERE OVERHAULED CV IS TO BE REDUCED
LA-2+6 I	SERVICE BIN	H 1m L 3m	-	-	-	-	-	Δ	-	H L	"L" ALARM NOT GOOD CHANGE ALL IS BETTER
LA-2+6 II	"	H 1m L 3m	-	-	-	-	-	Δ	-	H L	"L" ALARM NOT GOOD CHANGE ALL IS BETTER
SIA-1 A1	REVOLUTION OF SCREW A1	0 110 u/min	50 u/min	-	-	0	-	0	-	X L	SWITCH NOT GOOD
" A2	" A2	"	"	-	-	0	-	0	-	X L	SWITCH NOT GOOD
" B1	" B1	"	"	-	-	0	-	0	-	X L	SWITCH NOT GOOD
" B2	" B2	"	"	-	-	0	-	0	-	X L	SWITCH NOT GOOD
CO <sub>2</sub> R-2	THEISEN OUTLET	0~25 vol%CO <sub>2</sub>	-	-	Δ	-	-	X	-	-	TO BE REPLACED
O RA-1	SYN-GAS	0~1 0~5 vol%O <sub>2</sub>	-	-	Δ	0	-	X	-	-	TO BE REPLACED



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TGA-12B	O <sub>2</sub> BLOWER	0~160°C	90°C	0	—	0	—	0	OH	
" -12B	"	"	25°C	0	—	0	—	0	OH	
TR-20/1	O <sub>2</sub> MAIN	0~150°C	85°C	0	0	—	Δ	—	—	ELEMENT CHANGED / OK, RECORDER TO BE REPLACED
" 2										
" 3										
" 4										
" 5										
" 6										
TR-23/1	TUBULER BOILER IN LET	50~1600°C	630°C	0	Δ	0	Δ	—	—	ELEMENT CHANGED / OK, RECORDER TO BE REPLACED
" 2	"	"	"	0	Δ	0	Δ	—	—	
" 3	"	"	"	0	Δ	0	Δ	—	—	
" 4	TUBULER BOILER OUT LET	"	350°C	0	Δ	0	Δ	—	—	
" 5	"	"	"	0	Δ	0	Δ	—	—	
" 6	"	"	"	0	Δ	0	Δ	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-24/1	WASHER	0~100°C	62°C	0	0		Δ	—	—	ELEMENT CHANGED / OK AND RECORDER TO BE CHANGED
" 2	FINAL COOLER	"	32	0	0		Δ	—	—	"
" 3	BEFORE ORIFICE	"	51	0	0		Δ	—	—	"
" 4	WASHER	"	62	0	0		Δ	—	—	"
" 5	FINAL COOLER	"	32	0	0		Δ	—	—	"
" 6	BEFORE ORIFICE	"	51	0	0		Δ	—	—	"

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
IV-1A1	O <sub>2</sub> GASIFIER IN	0~100%	35%	-	-	0	-	-	0	Δ	SWITCH NOT GOOD / TO BE RENEWED
" -1A2	"	"	24	-	-	0	-	-	0	Δ	"
" -1B1	"	"	40	-	-	0	-	-	0	Δ	"
" -1B2	"	"	15	-	-	0	-	-	0	Δ	"
" -2A1	N <sub>2</sub> GASIFIER IN	0~600 μA	0%	-	-	0	-	-	0	Δ	"
" -2A2	"	"	0	-	-	0	-	-	0	Δ	"
" -2B1	"	0~100%	0	-	-	0	-	-	0	X	"
" -2B2	"	"	0	-	-	0	-	-	0	X	"
" -3	SYN GAS FLARE	"	0	-	-	0	-	-	0	Δ	"

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
HV-4	N <sub>2</sub> SEAL POT IN	0~100 %	100%	—	—	0	—	—	0	Δ	SWITCH NOT GOOD / TO BE RENEWED
" -5	N <sub>2</sub> BY-PASS	"	0	—	—	0	—	—	0	Δ	"
" -6	SYN GAS BLOWER	"	0	—	—	0	—	—	0	Δ	"
" -7A1	PIV-GEAR	0~30 A	6 A	—	—	0	—	—	—	Δ	"
" -7A2	"	"	5.5 A	—	—	0	—	—	—	Δ	"
" -7B1	"	"	5.1 A	—	—	0	—	—	—	Δ	"
" -7B2	"	"	5.5 A	—	—	0	—	—	—	Δ	"
P1A-1	HYDRAULIC OIL	32~42 kp/cm <sup>2</sup>	39 kp/cm <sup>2</sup>	—	—	0	—	0	—	H X L	PRESSURE GAUGE TO BE RENEWED

GRINDING PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FI-1	VAPOUR BLOWER	0~3100 Nm <sup>3</sup> /H		—	—	0	—	0	—	—	LEED PIPE NOT GOOD / CLEANING ONCE/YEAR
FI-2	VAPOUR BOOSTER	0~15000 Nm <sup>3</sup> /H	7500 Nm <sup>3</sup> /H	—	—	0	—	0	—	—	CLEANING ONCE/YEAR
FI-5	COMBUSTION AIR	0~11000 Nm <sup>3</sup> /H	4950 Nm <sup>3</sup> /H	—	—	0	—	0	—	—	
TRC-6	"	0~5500 Nm <sup>3</sup> /H	2750 Nm <sup>3</sup> /H	50%	0	—	Δ	0	Δ	—	CONTROLLER IS USED ONLY BY MANUAL
FI-9	BLOWER F5	0~11000 Nm <sup>3</sup> /H	7150 Nm <sup>3</sup> /H	—	—	0	—	0	—	—	CLEANING ONCE/YEAR
FI-10	N <sub>2</sub> BLOWER	0~8000 Nm <sup>3</sup> /H	400 Nm <sup>3</sup> /H	—	—	0	—	0	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PI-1	OUTLET HOT GAS PRODUCER	-150~0 ~+250 mmWS	+0 mmWS	-	-	0	-	0	-	-	
" -2	DUST SPARATOR	-630~0 ~+400 mmWS	-250 mmWS	-	-	0	-	0	-	-	
PRCA-4	ELECTRO FILTER	-160~0 ~+250 mmWS	+10 mmWS	x	x	0	x	Δ	x	0 <sub>L</sub>	TO BE REPLACED
PDI-10	PRIMARY AIR	0~63 mmWS	60 mmWS	-	-	0	-	0	-	-	
PIA-12	COMBUSTION FUEL	0~250 mmWS	60 mmWS	-	-	0	-	Δ	-	0 <sub>H</sub>	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LA-3	FINISHED DUST BUNKER	H 4m L 8m	-	-	-	-	-	X	-	H X L	TRANSMITTER TO BE RENEWED
LA-4	LIGHT FUEL OIL TANK		-	-	-	-	-	O	-	Δ L	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TRA-1/1	COAL SHAFT	50~750°C	360°C	0	Δ	0	Δ	—	X	RECORDER TO BE RENEWED
" 2	"	"	X	X	Δ	0	Δ	—	X	
" 3	"	"	430	0	Δ	0	Δ	—	X	
" 4	"	"	270	0	Δ	0	Δ	—	X	
" 5	"	"	X	X	Δ	0	Δ	—	X	
" 6	"	"	126°C	0	Δ	0	Δ	—	X	
TR-2/1	SICHTER	0~200°C	126°C	0	0	—	Δ	—	—	ELEMENT CHANGED / RECORDER TO BE RENEWED
" 2	BEHIND SEPARATOR	"	132	0	0	—	Δ	—	—	"
" 3	ELECTRO FILTER	"	130	0	0	—	Δ	—	—	"
" 4	SECONDARY AIR	"	73	0	0	—	Δ	—	—	"
" 5	MIXTURE	"	78	0	0	—	Δ	—	—	"
" 6	SEKUNDUR LUFF	"	137	0	0	—	Δ	—	—	"
TRA-3/1	FINISHED DUST BUNKER 1350mm	0~200°C	82	0	0	—	Δ	—	—	ELEMENT INSTALLED
" 2	"	"	—	—	—	—	Δ	—	—	SPACE RECORDER WAS REPAIRED AND MOUNTED,
" 3	FINISHED DUST BUNKER 6350mm	"	90	0	0	—	Δ	—	X	YET IT'S BETTER TO BE RENEWED
" 4	"	"	—	—	—	—	Δ	—	X	
" 5	FINISHED DUST BUNKER 3800mm	"	87	0	0	—	Δ	—	X	
" 6	OUTLET	"	55	0	0	—	Δ	—	X	
TI-7	OUTLET HOT GAS PRODUCER	50~120°C	590°C	0	Δ	—	—	0	—	



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
O <sub>2</sub> RA-1	HOT GAS PRODUCER	0~21	4.5%	—	X	0	—	0	—	H Δ <sub>L</sub>	SAMPLING SYSTEM AND SAMPLING PUMP TO BE RENEWED
O <sub>2</sub> RA-2	ELECTRO FILTER	"	10	—	X	0	—	0	—	H Δ <sub>L</sub>	"
O <sub>2</sub> RA-3	FINISHED DUST BUNKER	"	0.5	—	X	0	—	0	—	H Δ <sub>L</sub>	"

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
HV-1	BLOWER F2	0~100 %	—	45%	—	0	—	—	0	Δ	SWITCH TO BE RENEWED
" -2	BOOSTER F3	"	—	52	—	0	—	—	0	Δ	"
" -3	ROLLER FEEDER	"	—	35	—	0	—	—	0	Δ	"
" -4	ERKO BELT FEEDER	"	—	54	—	0	—	—	0	Δ	"
" -5	PRIMARY AIR	0~600 μA	—	200 μA	—	0	—	—	0	Δ	"
" -6	SECONDARY AIR	0~100 %	—	20%	—	0	—	—	0	Δ	"
" -7	ELECTRO FILTER OUT	"	—	42	—	0	—	—	0	Δ	"
" -8/1	BEHIND SEPARATOR	"	—	100	—	0	—	—	0	Δ	"
" -8/2	"	"	—	100	—	0	—	—	0	Δ	"

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
HV-9	STARTING STACK	0~100 %	—	0%	—	0	—	—	0	Δ	SWITCH TO BE RENEWED
" -10	FLUE GAS	0~600 μA	—	570 μA	—	0	—	—	0	Δ	"
" -11	N <sub>2</sub> INERTISATION	"	—		—	0	—	—	0	Δ	INDICATOR CHANGED / OK SWITCH TO BE CHANGED
HSVA-12	N <sub>2</sub> LINE	0~100 %	—	0%	—	0	—	—	Δ	Δ	SWITCH TO BE CHANGED
FSVA-11	COMBUSTION AIR	SHUT -OPEN	OPEN	—	—	—	—	—	Δ ON-OFF VALVE	—	MAGNET VALVE NOT GOOD
FSV-12	FUEL OIL	SHUT -OPEN	OPEN	—	—	—	—	—	Δ ON-OFF VALVE	Δ	HAND CONTROLLED MAGNET VALVE NOT GOOD TO BE REPLACED

FEED WATER PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FR-3-65-01	30 <sup>K</sup> STEAM	0~12 t/H	12 t/H	—	Δ	—	—	X	—	—	TRANSMITTER TO BE CHANGED
PRC-3-65-01	30 <sup>K</sup> STEAM	0~50 kg/cm <sup>2</sup>	25 kg/cm <sup>2</sup>	35%	0	—	0	0	0	—	CONTROL VALVE, CONTROLLER, RECORDER AND TRANSMITTER CHANGED
PRC-3-65-02	10 <sup>K</sup> STEAM	0~15 kg/cm <sup>2</sup>	7 kg/cm <sup>2</sup>	90%	0	—	0	0	0	—	CONTROLLER, RECORDER AND TRANSMITTER CHANGE CONTROL VALVE OVERHAULED / GOOD
PRC-3-65-03	3 <sup>K</sup> STEAM	0~5 kg/cm <sup>2</sup>	2.8 kg/cm <sup>2</sup>	100%	Δ	—	0	0	0	—	TRANSMITTER, CONTROLLER CHANGED CONTROL VALVE OVERHAULED / GOOD
PC-3-65-10	DEAREATOR	—	—	—	—	—	—	—	Δ	—	CONTROL SYSTEM TO BE CHANGED
PIA-3-65-13	STEAM TURBINE	0~63 kg/cm <sup>2</sup>	30 kg/cm <sup>2</sup>	—	—	0	—	—	—	—	
PIA-3-65-05	STEAM	"	15 kg/cm <sup>2</sup>	—	—	0	—	—	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PIA-3-65-02	10 <sup>K</sup> STEAM	0~25 kg/cm <sup>2</sup>	8 kg/cm <sup>2</sup>	—	—	0	—	—	—	0	
PIA-3-65-03	3 <sup>K</sup> STEAM	0~10 kg/cm <sup>2</sup>	3 kg/cm <sup>2</sup>	—	—	0	—	—	—	0	
PIA-3-65-04	DEAREATOR	0~1 kg/cm <sup>2</sup>	0.2 kg/cm <sup>2</sup>	—	—	0	—	—	—	0	TRANSMITTER, INDICATOR NEWLY INSTALLED
LIC-3-65-01	DEAREATOR	0~1200 mm	800 mm	25%	0	—	0	0	Δ	—	TRANSMITTER, CONTROLLER CHANGED

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
TIC-3-65-01	10 <sup>K</sup> STEAM	0~250 °C	200°C	0%	-	0	0	x	Δ	-	CONTROLLER RENEWED TRANSMITTER NOT GOOD
TC-3-65-02	3 <sup>K</sup> STEAM	0~250 °C	150°C	ON, OFF	-	-	x	x	x	-	CONTROL VALVE OVERHAULED } TRANSMITTER OVERHAULED } / NOT GOOD
TIA-3-65-04	OUTLET PIPE	0~250 °C	170°C	-	-	0	-	-	-	0	
TIA-3-65-05	"	0~200 °C	140°C	-	-	0	-	-	-	0	
TR-3-65-03	30 <sup>K</sup> STEAM	0~600 °C	400°C	-	x	-	-	-	-	-	RECORDER NOT GOOD RECORDER AND COMPENSATE WIRE TO BE RENEWED

AIR SEPARATION PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FR-1	AIR INLET APPARATUS	0~40000 Nm <sup>3</sup> /H	29000 Nm <sup>3</sup> /H	—	0	—	—	0	—	—	RECORDER OVERHAULED / OK TRANSMITTER ZERO ADJUSTED / OK
FR-2	O <sub>2</sub> PRODUCT	0~5000 Nm <sup>3</sup> /H	3350 Nm <sup>3</sup> /H	—	0	—	—	0	—	—	
FR-3	N <sub>2</sub> PRODUCT	0~4000 Nm <sup>3</sup> /H	3100 Nm <sup>3</sup> /H	—	0	—	—	0	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LRA-2	CONDENSATE TANK	0~2500 mm	2000 mm	—	0	—	—	0	—	0	
LIC-4	SPRAY COOLER CC	0~500 mm	260 mm	10%	—	0	0	0	0	—	CONTROL VALVE OVERHAULED / GOOD
LIC-7	EVAPORATION COOLER CE	0~1000 mm	560 mm	5%	—	0	0	0	0	—	CONTROL VALVE OVERHAULED / GOOD



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
P1-1	REGEN R1	0~10 kp/cm <sup>2</sup>	5.0 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -2	REGEN R2	"	5.0 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -3	REGEN R3	"	4.9 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -4	REGEN R4	"	4.9 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -5	PRESS. COL. C1	"	4.9 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -6	PRESS COL. C2	0~1 kp/cm <sup>2</sup>	0.47 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -7	INLET TUBE AT1	0~10 kp/cm <sup>2</sup>	4.7 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -8	INLET TUBE AT2	"	0 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -11	O2-AFTER EVAP. AE	0~1600 mmWS	460 mmWS	-	-	0	-	-	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PIA-14	OUTLET O <sub>2</sub> PUMP AP	0~4 kp/cm <sup>2</sup>	2.0 kp/cm <sup>2</sup>	-	-	0	-	-	-	0	
PI-15	AIR INLET APPARATUS	0~15 kp/cm <sup>2</sup>	5.0 kp/cm <sup>2</sup>	-	-	0	-	-	-	-	
" -16	N <sub>2</sub> PRODUCT	0~1600 mmWS	830 mmWS	-	-	0	-	-	-	-	
" -17	O <sub>2</sub> PRODUCT	"	350 mmWS	-	-	0	-	-	-	-	
PIC-8-21 -01	N <sub>2</sub> COMPER BY PASS	0~40 kg/cm <sup>2</sup>	20.5 kg/cm <sup>2</sup>	30%	-	0	0	0	0	-	THIS AUTOMATIC CONTROL SYSTEM NEWLY INSTALLED.

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
HC-1	LIQUID O <sub>2</sub> AFTER E2	0~100%	—	75%	—	0	—	—	0	—	
HC-2	LIQUID N <sub>2</sub> AFTER E3	"	—	65%	—	0	—	—	0	—	
HC-3	EVAPORATOR	"	—	25%	—	0	—	—	0	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TI-1	REGEN R1	-200~+50 0~+200°C	-104 °C	0	0	-	-	0	-	
" -2	" R2	"	-106	0	0	-	-	0	-	
" -3	" R3	"	-107	0	0	-	-	0	-	
" -4	" R4	"	-108	0	0	-	-	0	-	
" -5	VALVE BOX V1	"	-170	0	0	-	-	0	-	
" -6	" V2	"	-167	0	0	-	-	0	-	
" -7	" V3	"	X	X	0	-	-	0	-	
" -8	" V4	"	-174	0	0	-	-	0	-	
" -9	AIR AFTER TUBE. COILS	"	-142	0	0	-	-	0	-	
" -10	AIR BEFORE TUBE. INES	"	-142	0	0	-	-	0	-	
" -11	AIR BEFORE TURB. AT1	"	-142	0	0	-	-	0	-	
" -12	AIR AFTER TURB. AT1	"	-147	0	0	-	-	0	-	
" -13	AIR BEFORE TURB. AT2	"	+25	0	0	-	-	0	-	
" -14	AIR AFTER TURB. AT2	"	+25	0	0	-	-	0	-	
" -15	O <sub>2</sub> EVAP. AE	"	+28	0	0	-	-	0	-	
" -16	LIQUID O <sub>2</sub> AFTER E2	"	-186	0	0	-	-	0	-	
" -17	IMPURE N <sub>2</sub> AFTER E2	"	-178	0	0	-	-	0	-	
" -18	IMPURE N <sub>2</sub> AFTER E1	"	-177	0	0	-	-	0	-	
" -19	PURE N <sub>2</sub> AFTER E3	"	-178	0	0	-	-	0	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TI-20	LIQUID N2 AFTER E3	-200~+50°C	-183°C	0	0	-	-	0	-	
" -21	AIR INLET APPARATUS	"	+27	0	0	-	-	0	-	
" -22	PURE N2 PRODUCT	"	+21	0	0	-	-	0	-	
" -23	PURE O2 PRODUCT	"	+29	0	0	-	-	0	-	
" -24	IMPURE N2 OUTLET	"	+28	0	0	-	-	0	-	
" -25	O2 AFTER EVAP. AE	"	+35	0	0	-	-	0	-	
" -26	HEATING OUTLET A2	"	+25	0	0	-	-	0	-	
" -27	HEATING OUTLET A1	"	+25	0	0	-	-	0	-	
" -28	BEARING TURB. AT1	"	+46	0	0	-	-	0	-	
" -29	"	"	+56	0	0	-	-	0	-	
" -30	BEARING TURB. AT2	"	+25	0	0	-	-	0	-	
" -31	"	"	+25	0	0	-	-	0	-	
TR-3/1	REGENERATOR 1 Mitte	-170~-50°C	-114°C	0	0	-	-	0	-	
" 2	REGENERATOR 2 Mitte	"	-123	0	0	-	-	0	-	
" 3	REGENERATOR 3 Mitte	"	-108	0	0	-	-	0	-	
" 4	REGENERATOR 4 Mitte	"	-110	0	0	-	-	0	-	
" 5	Luff aus REGENERATOR	"	-169	0	0	-	-	0	-	
" 6	Luff Vorden Turbinen	"	-167	0	0	-	-	0	-	

ADIP PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FRC-4-11-01	IN ABS ADIP	0~10x9 3 m <sup>3</sup> /H	45 3 m <sup>3</sup> /H	30%	Δ	—	0	0	0	—	
FRC-4-11-03	REBOILER	0~ 10x9 T/H	3.7 T/H	30%	Δ	—	0	0	0	—	CONTROL VALVE OVERHAULED / GOOD
FI-4-11-04	COOLING WATER	0~35 T/H	10 T/H	—	—	0	—	0	—	—	
PIA-4-11-15	INST AIR	0~10 kg/cm <sup>2</sup>	3.5 kg/cm <sup>2</sup>	—	—	0	—	—	—	0	
LIA-4-11-12	ABSORBER		x	—	—	x		x	—	x	
LICA-4-11-02	ABSORBER	0.2~ 1.0 K	0.6 kg/cm <sup>2</sup>		—	0	0	0	0	H x L	
LIA-4-11-03	REGENERATOR	0~100%	50%	—	—	0	—	—	—	H x L	
LA-4-11-01	SCRUBER		—	—	—	—	—	0	—	x	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-4-11-01 / 1	ADIP SOLUTION	0~200°C	48°C	P+100 Δ	Δ	-	X	-	-	RECORDER TO BE RENEWED
2	SYNTHESIS GAS	"	65°C	Δ	Δ	0	X	-	-	PROTECTION TUBE INSPECTED / GOOD
3	ADIP SOLUTION	"	30°C	Δ	Δ	-	X	-	-	
4	"	"	47°C	Δ	Δ	-	X	-	-	
5	"	"	82	Δ	Δ	0	X	-	-	PROTECTION TUBE INSPECTED / GOOD
6	"	"	96	Δ	Δ	-	X	-	-	
7	REGENERATOR ACID GAS	"	72°C	Δ	Δ	0	X	-	-	PROTECTION TUBE INSPECTED / GOOD
8	ADIP SOLUTION	"	34	Δ	Δ	0	X	-	-	"
9	"	"	104	Δ	Δ	-	X	-	-	
10	STEAM	"	147°C	Δ	Δ	-	X	-	-	
11	SPARE	"	-	-	-	-	X	-	-	
12	"	"	-	-	-	-	X	-	-	

AMMONIA PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FR-3-29-01	GAS OUTLET CO-CONVERSION	0~25000 Nm <sup>3</sup> /H	18000 Nm <sup>3</sup> /H	—	0	—	—	0	—	—	
FRC-3-29-02	STEAM INLET CO-CONVERSION	0~9000 kg/H	6390 kg/H	25%	0	—	0	0	0	—	CONTROL VALVE OVERHAULED / GOOD
FI-3-29-03	HOT WATER TO SATURATOR	0~150 m <sup>3</sup> /H	105 m <sup>3</sup> /H	—	—	0	—	0	—	—	
FIC-3-29-04	CIRCULATING WATER TO DEMOISTURE	0~40 m <sup>3</sup> /H	29.6 m <sup>3</sup> /H	50%	—	0	0	0	0	—	CONTROL VALVE OVERHAULED / GOOD
FIC-3-29-05	WATER FROM TO SATURATOR TO DEMOISTURE	0~120 m <sup>3</sup> /H	81.6 m <sup>3</sup> /H	30%	—	0	0	0	0	—	CONTROLLER OVERHAULED / GOOD
FIC-3-29-06	WARM WATER TO DEMOISTURE	0~30 m <sup>3</sup> /H	13.5 m <sup>3</sup> /H	25%	—	0	0	0	0	—	
FR-3-31-01	GAS OUTLET CO <sub>2</sub> -REMOVAL	0~15000 Nm <sup>3</sup> /H	12900 Nm <sup>3</sup> /H	—	0	—	—	0	—	—	
FI-3-31-02	WATER TO SCRUBBER	0~2300 Nm <sup>3</sup> /H	1080 Nm <sup>3</sup> /H	—	—	0	—	0	—	—	CONTROL VALVE OVERHAULED / GOOD
FRC-3-31-03	N <sub>2</sub> TO CONVERTER GAS	0~3000 Nm <sup>3</sup> /H	2100 Nm <sup>3</sup> /H	50%	0	0	0	0	0	—	CONTROLLER and CONTROL VALVE INSTALLED TRANSMITTER ( 3600 mmWS → 1296 mmWS ) ΔP CHANGED ( 5000 Nm <sup>3</sup> /H → 3000 Nm <sup>3</sup> /H )



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FR-3-43-01	SYN GAS QUANTITY	0~20000 Nm <sup>3</sup> /H	10600 Nm <sup>3</sup> /H	-	0	-	-	0	-	-	
FI-3-43-02	QUANTITY OF RETURN-GAS	0~1200 Nm <sup>3</sup> /H	0 Nm <sup>3</sup> /H	-	-	0	-	0	-	-	
FR-3-52-01	NH <sub>3</sub> CONV INLET	0~100000 Nm <sup>3</sup> /H	51000 Nm <sup>3</sup> /H	-	0	-	-	0	-	-	TRANSMITTER ΔP CHECKED / GOOD
FIA-3-52-01/B	"	0~26300 Nm <sup>3</sup> /H	OVER SCALE	-	-	0	-	0	-	0	LOW ANN TRANSMITTER ΔP CHECKED / GOOD
FR-3-52-03	OUTLET FLOW TAIL GAS SCRUBBER	0~1200 Nm <sup>3</sup> /H	672 Nm <sup>3</sup> /H	-	0	-	-	0	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LICA-3-29-01	SATURATOR	0~1500 mm	1080 mm	20%	—	0	0	0	0	H O L	CHAMBER CLEANED / GOOD
LICA-3-29-02	DEMOISTURE	"	1020 mm	75%	—	0	0	0	0	H O L	CONTROL VALVE OVERHAULED / GOOD CHAMBER CLEANED / GOOD
LIA-3-29-04	TOP SATURATOR	0~1400 mm	1400 mm	—	—	0	—	0	—	H O L	
LICA-3-31-01	PRESSURE WATER SCRUBBER	0~1500 mm	1020 mm	25%	—	0	0	0	0	H O L	CHAMBER CLEANED / GOOD
LIA-3-31-02	"	0~1000 mm	1000 mm	—	—	0	—	0	—	H O L	
LIA-3-31-05	FLASH VESSEL	"	500 mm	—	—	0	—	0	—	H O L	
LICA-3-43-01	COPPER SOLUTION IN SCRUBBER	"	580 mm	75%	—	0	0	0	0	H O L	
LIA-3-43-02	"	"	590 mm	—	—	0	—	0	—	H O L	
LICA-3-43-03	NH <sub>3</sub> WATER IN SCRUBBER	"	560 mm	5%	—	0	0	0	0	H O L	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LIA-3-43-04	NH <sub>3</sub> WATER IN SCRUBBER	0~1000 mm	580 mm	—	—	0	—	0	—	H O L	
LI-3-43-06	SURGE TANK	0~2250 mm	—	—	—	Δ	—	X	—	—	THERE IS NO TRANSMITTER
LICA-3-52-01	NH <sub>3</sub> SEPARATOR	0~1000 mm	580 mm	40%	—	0	0	0	0	H O L	CONTROL VALVE OVERHAULED / GOOD
LIA-3-52-02	"	"	660 mm	—	—	0	—	0	—	H O L	
LICA-3-52-03	NH <sub>3</sub> FLASH VESSEL	"	500 mm	75%	—	0	0	0	0	H O L	CONTROL VALVE OVERHAULED / GOOD
LICA-3-52-04	TAIL GAS SCRUBBER	"	250 mm	10%	—	0	0	0	0	H O L	
LICA-3-52-05	WASTE HEAT BOILER	0~750 mm	430 mm	25%	—	0	0	0	0	H O L	
LI-3-74-01	SYN GAS HOLDER	0~6000 m <sup>3</sup>	5100 m <sup>3</sup>	—	—	0	—	0	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PR-3-29-02	GAS OULET CO-CONVERSION	0~40 kp/cm <sup>2</sup>	20 kp/cm <sup>2</sup>	-	0	-	-	0	-	-	
PR-3-29-08	STEAM INLET CO-CONVERSION	"	23 kp/cm <sup>2</sup>	-	0	-	-	0	-	-	
PaIA-3-31-02	PRESSURE WATER SCRUBBER	0~5000 mmws	1600 mmws	-	-	0	-	0	-	H 0	
PR-3-31-04	GAS OULET CO <sub>2</sub> -REMOVAL	0~40 kp/cm <sup>2</sup>	19.5 kp/cm <sup>2</sup>	-	0	-	-	0	-	-	
PRC-3-31-12	GAS FROM FLASH VESSEL	0~16 kp/cm <sup>2</sup>	7.7 kp/cm <sup>2</sup>	40%	0	-	-	0	-	-	CONTROL VALVE OVERHAULED / GOOD
PR-3-31-17	N <sub>2</sub> TO CONVERTER GAS	0~40 kp/cm <sup>2</sup>	19.5 kp/cm <sup>2</sup>	-	0	-	-	0	-	-	
PR-3-43-02	PRESSURE AFTER CUS SCRUBBER	0~160 kp/cm <sup>2</sup>	102 kp/cm <sup>2</sup>	-	-	0	-	0	-	-	
PI-3-43-04	PRESSURE AFTER RETURN GAS	0~630 mmws	410 mmws	-	-	0	-	0	-	-	
PI-3-52-02	SYN GAS INLET	0~630 kp/cm <sup>2</sup>	315 kp/cm <sup>2</sup>	-	-	0	-	0	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PI-3-52-04	SYN GAS INLET	0~630 kp/cm <sup>2</sup>	315 kp/cm <sup>2</sup>	-	-	0	-	0	-	-	TRANSMITTER CHANGED TO NEW TYPE
PR-3-52-09	INLET CONVERTER	"	330 kp/cm <sup>2</sup>	-	0	-	-	0	-	-	TRANSMITTER CHANGED TO NEW TYPE
PI-3-52-11	PRESSURE IN FLASH VESSEL	0~63 kp/cm <sup>2</sup>	29 kp/cm <sup>2</sup>	-	-	0	-	0	-	-	
PRC-3-52-12	OUTLET TAIL GAS SCRUBBER	"	28.5 kp/cm <sup>2</sup>	15%	0	-	0	0	0	-	
PIA-3-52-14	Ins. T AIR	0~10 kp/cm <sup>2</sup>	3.5 kp/cm <sup>2</sup>	-	-	0	-	-	-	0 L	
TIC-3-29-04	GAS OUTLET HEAT EXCHANGER I	0~400 °C	240°C	100%	-	0	0	0	Δ	-	POWER CYLINDER TO BE CHANGED ( TWO SET )
TIC-3-43-02	INLET SURGE TANK	0~100 °C	75°C	50%	-	0	0	0	0	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
HIC-3-52-02	VENT BEFORE CIRCULATING SYSTEM	0~100%	—	100%	—	0	—	—	0	—	
" -03	INLET NH <sub>3</sub> CONVERTER	"	—	"	—	0	—	—	0	—	
" -04	FRESH GAS 1st STAGE	"	—	48%	—	0	—	—	0	—	
" -05	FRESH GAS 2nd STAGE	"	—	35%	—	0	—	—	0	—	
" -06	FRESH GAS 3rd STAGE	"	—	17%	—	0	—	—	0	—	
" -07	VENT IN CIRCULATING SYSTEM	"	—	0%	—	0	—	—	0	—	
" -08	BY PASS CONVERTER	"	—	0%	—	0	—	—	0	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
DR-3-43-01	DENSITY NH <sub>3</sub> WASHER	0.3~0.5 kp/Nm <sup>3</sup>	0.55 kp/Nm <sup>3</sup>	-	0	-	-	0	-	-	
DR-3-52-01	DENSITY NH <sub>3</sub> CONV	0.3~0.7 kp/Nm <sup>3</sup>	0.58 kp/Nm <sup>3</sup>	-	0	-	-	0	-	-	
ARA-3-29-01	OUTLET CO-CONVERSION	0~10% CO	1% CO	-	Δ	-	-	Δ	-	OH	
AR-3-29-02	DRAIN WATER	3~9 pH	x	-	x	-	-	x	-	-	INSTRUMENT WAS MISSED
AR-3-31-01	OUTLET CO <sub>2</sub> REMOVAL	0~3 % CO <sub>2</sub>	x	-	x	-	-	x	-	-	"
ARA-3-43-01	SYN GAS	0~100 PPM CO <sub>2</sub>	28 PPM	-	0	-	-	0	-	OH	
ARA-3-43-02	"	0~50 PPM CO + CO <sub>2</sub>	x	-	x	-	-	x	-	-	INSTRUMENT WAS MISSED
ARA-8-21-01	O <sub>2</sub>	0~100 PPM O <sub>2</sub>	30 PPM	-	0	-	-	0	-	OH	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-3-29-01 /1	GAS OUTLET SATURATOR	0~600°C	164°C	0	Δ	-	0	-	-	ELEMENT CHANGED
" /2	I STAGE INLET CO-CONVERTER	"	351	0	Δ	-	0	-	-	"
" /3	I STAGE OUTLET CO-CONVERTER	"	481	0	Δ	0	0	-	-	" PROTECTION TUBE INSPECTED / GOOD
" /4	II STAGE INLET CO-CONVERTER	"	350	0	Δ	-	0	-	-	"
" /5	II STAGE OUTLET CO-CONVERTER	"	381	0	Δ	-	0	-	-	"
" /6	GAS INLET WATER PREHEATER	"	350	0	Δ	-	0	-	-	"
" /7	GAS INLET DEMOISTURE	"	163	0	Δ	-	0	-	-	" PROTECTION TUBE INSPECTED / GOOD
" /8	GAS OUTLET CO-CONVERSION	"	33	0	Δ	0	0	-	-	"
" /9	HOT WATER TO SATURATOR	"	172	0	Δ	-	0	-	-	"
" /10	STEAM INLET AFTER SEPARATOR	"	345	0	Δ	-	0	-	-	"
" /11	OUTLET CO2-REMOVAL	"	25	0	Δ	-	0	-	-	"
" /12	N2 TO CONVERTER GAS	"	28	0	Δ	-	0	-	-	"
TI-3-29-02 /1	GAS INLET SATURATOR	0~600°C	41°C	0	Δ	-	-	0	-	ELEMENT CHANGED
" /2	GAS AFTER STEAM SUPPLY		172	0	Δ	-	-	0	-	"
" /3	WATER INLET WATER PREHEATER		163	0	Δ	-	-	0	-	"
" /4	HOT WATER TO FEED WATER PLANT		153	0	Δ	-	-	0	-	"
" /5	HOT WATER FROM FEED WATER PLANT		67	0	Δ	-	-	0	-	"



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TI-3-29-02 /6	CIRCULATING WATER TO DEMOISTURE	0~600°C	41°C	0	Δ	-	-	0	-	ELEMENT CHANGED
" /7	WARM WATER TO DEMOISTURE	"	74	0	Δ	-	-	0	-	"
" /8	WATER TO DEMOISTURE	"	136	0	Δ	-	-	0	-	"
TI-3-43-01 /1	AFTER COPPER SOLUTION SCRUBBER	0~600°C	10°C	0	Δ	0	-	0	-	ELEMENT CHANGED, AND PROTECTION TUBE INSPECTED / GOOD
/2	OUTLET NH <sub>3</sub> WATER SCRUBBER	"	20	0	Δ	0	-	0	-	"
/3	AFTER RETURN GAS	"	28	0	Δ	-	-	0	-	
/4	OUTLET SUCTION TANK	"	15	0	Δ	0	-	0	-	" PROTECTION TUBE INSPECTED / GOOD
/5	AFTER REGENERATOR BEFORE HEATING PART	"	26	0	Δ	-	-	0	-	"
/6	AFTER UPPER PART	"	72	0	Δ	-	-	0	-	"
/7	OUTLET REGENERATOR	"	68	0	Δ	0	-	0	-	" PROTECTION TUBE INSPECTED / GOOD
/8	OUTLET SURGE TANK	"	80	0	Δ	-	-	0	-	"
/9	OUTLET WATER COOLER	"	75	0	Δ	-	-	0	-	"
/10	OUTLET COOLING UNIT	"	26	0	Δ	0	-	0	-	" PROTECTION TUBE INSPECTED / GOOD
/11		"	10	0	Δ	-	-	0	-	"
TIC-3-29-04	GAS OUTLET HEAT EXCHANGE I	0~100°C	240°C	0	Δ	0	-	0	-	ELEMENT CHANGED, AND PROTECTION TUBE INSPECTED / GOOD
TIC-3-43-02	INLET SURGE TANK	0~100°C	75°C	0	Δ	0	-	0	-	"

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-3-52-01 / 1	INLET CONVERTER	0~600°C	23°C	0	△	—	0	—	—	
" 2	INLET 1st STAGE	"	400	0	△	—	0	—	—	
" 3	OUTLET 1st STAGE	"	465	0	△	—	0	—	—	
" 4	INLET 2nd STAGE	"	422	0	△	—	0	—	—	
" 5	OUTLET 2nd STAGE	"	472	0	△	—	0	—	—	
" 6	INLET 3rd STAGE	"	450	0	△	—	0	—	—	
" 7	OUTLET 3rd STAGE	"	479	0	△	—	0	—	—	
" 8	OUTLET CONVERTER	"	179	0	△	—	0	—	—	
" 9	OUTLET TAIL GAS	"	30	0	△	0	0	—	—	PROTECTION TUBE INSPECTIONED / GOOD
" 10	SPARE	"	—	—	—	—	0	—	—	
" 11	"	"	—	—	—	—	0	—	—	
" 12	"	"	—	—	—	—	0	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TI-3-52-02 /1	INLET CONVERTER	0-600°C	26°C	0	Δ	-	-	0	-	
" 2	INLET 1ST STAGE	"	386	0	Δ	-	-	0	-	
" 3	OUTLET 1ST STAGE	"	433	0	Δ	-	-	0	-	
" 4	INLET 2nd STAGE	"	430	0	Δ	-	-	0	-	
" 5	OUTLET 2nd STAGE	"	462	0	Δ	-	-	0	-	
" 6	INLET 3rd STAGE	"	451	0	Δ	-	-	0	-	
" 7	OUTLET 3rd STAGE	"	463	0	Δ	-	-	0	-	
" 8	OUTLET CONVERTER	"	124	0	Δ	-	-	0	-	
" 9	OUTLET BOILER	"	136	0	Δ	-	-	0	-	
" 10	OUTLET NH <sub>3</sub> SEPT	"	23	0	Δ	-	-	0	-	

UREA PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FRCA-3-57-02	NH <sub>3</sub> LIQUID	0~10 m <sup>3</sup> /H	6.3 m <sup>3</sup> /H	50 %	0	+	0	0	0	x	TRANSMITTER "AP" CHECKED / GOOD RECORDER OVERHAULED / GOOD ALARM UNIT TO BE RENEWED
FR-3-57-03	CO <sub>2</sub> -COMP IN LET	0~3500 Nm <sup>3</sup> /H	1600 Nm <sup>3</sup> /H	-	0	-	-	0	-	-	"U" TUBE and RECORDER OVERHAULED / GOOD POSITION CHANGE FOR TRANSMITTER OK TRANSMITTER "AP" CHECKED / GOOD
FR-3-57-07	NH <sub>3</sub> STORAGE TANK	0~2 m <sup>3</sup> /H	2 m <sup>3</sup> /H	-	0	-	-	0	-	-	TRANSMITTER OVERHAULED / GOOD RECORDER OVERHAULED / GOOD
FR-3-57-08	NH <sub>3</sub> SCRUBBER	0~0.2 m <sup>3</sup> /H	0.2 m <sup>3</sup> /H	65 %	0	-	0	0	0	-	TRANSMITTER } OVERHAULED / GOOD RECORDER CONTROL VALVE OVERHAULED / GOOD
FR-2-81-01	UREA FILTER OUT	0~7x007 m <sup>3</sup> /H	2.66 m <sup>3</sup> /H	40 %	0	-	0	0	0	-	RECORDER OVERHAULED / GOOD

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PRC-2-81-04	EVAPORATOR	0~0.7 kp/cm <sup>2</sup>	0.38 kp/cm <sup>2</sup>	100%	0	-	0	0	Δ	-	CONTROL VALVE } OVERHAULED / GOOD RECORDER
PRC-2-81-07	SEPARATOR 2nd	9~9x10 <sup>3</sup> mm H <sub>2</sub> O	7.2 kg/cm <sup>2</sup>	-	0	-	x	0	0	-	CONTROLLER NOT GOOD RECORDER OVERHAULED / GOOD
PRC-2-81-11		0~6 kg/cm <sup>2</sup>			-	-	Δ	Δ	Δ	-	LOCAL CONTROL
PRCA-3-57-05	NH <sub>3</sub> STORAGE TANK	0~40 kp/cm <sup>2</sup>	21 kp/cm <sup>2</sup>	15%	0	-	0	0	0	OL	RECORDER OVERHAULED / GOOD L ALARM CONTACT OVERHAULED / GOOD
PRC-3-57-12	LIQ NH <sub>3</sub> to FIRST REACTOR	0~400 kp/cm <sup>2</sup>	190 kp/cm <sup>2</sup>	65%	0	-	0	0	0	-	TRANSMITTER } OVERHAULED / GOOD RECORDER
PRC-3-57-15	STEAM FIRST REACTOR	0~6 kp/cm <sup>2</sup>	4 kp/cm <sup>2</sup>	30%	0	-	0	0	0	-	RECORDER OVERHAULED / GOOD
PRC-3-57-16	STEAM	0~6 kp/cm <sup>2</sup>	3 kp/cm <sup>2</sup>	0	0	-	0	0	0	-	TRANSMITTER } OVERHAULED / GOOD RECORDER
PRC-3-57-17	CONDENSATE 1ST REACTOR	0~400 kp/cm <sup>2</sup>	200 kp/cm <sup>2</sup>	10%	-	-	0	0	0	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PRC-3-57-25	CARBAMATE GAS	0~4 kp/cm <sup>2</sup>	2.05 kp/cm <sup>2</sup>	60 %	0	—	0	0	0	—	RECORDER OVERHAULED / GOOD
PICA-3-57-32	N <sub>2</sub> GAS TANK	0~40 kp/cm <sup>2</sup>	25 kp/cm <sup>2</sup>	0	—	0	0	0	0	H O L	H.L ALARM CHECKED / GOOD
PIA-3-57-38	INST AIR	0~10 kp/cm <sup>2</sup>	38 kp/cm <sup>2</sup>	—	—	0	—	0	—	0	
PIA-3-57-08	CO <sub>2</sub> -GAS to CO <sub>2</sub> -COMP.	0~63 kp/cm <sup>2</sup>		—	—	0	—	0	—	0	
PIA-3-57-56	COOLING WATER	0~10 kp/cm <sup>2</sup>	2 kp/cm <sup>2</sup>	—	—	0	—	0	—	0	
PIA-3-57-58	OIL COMP	0~6 kp/cm <sup>2</sup>	3 kp/cm <sup>2</sup>	—	—	0	—	0	—	0	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LIA-3-57-01	NH <sub>3</sub> STORAGE TANK	0~100 mm	60 mm	0 %	—	0	0	0	0	0	CONTROL VALVE } OVERHAULED / GOOD INDICATOR } H.L ALARM CHECKED / GOOD
LICA-3-57-02	1st REACTOR	0~100 mm	30 mm	0 %	—	0	0	0	0	H O L	H.L ALARM CHECKED / GOOD
LIC-3-57-03	UREA SOLUTION 1st SEPOI	0~100 mm	42 mm	10 %	—	0	0	0	0	—	CONTROL VALVE OVERHAULED / GOOD
LICA-3-57-04	UREA SOLUTION 2nd SEPOI	0~100 mm	48 mm	0 %	—	0	0	0	0	—	CONTROL VALVE OVERHAULED / GOOD
LIC-3-57-05	WASHING COLUMN	0~100 mm	40 mm	20 %	—	0	0	0	0	—	
LICA-3-57-07	SEPARATION WATER TANK	0~100 mm	60 mm	10 %	—	0	0	0	0	H O L	CONTROL VALVE OVERHAULED / GOOD H.L ALARM CHECKED / GOOD
LICA-3-57-08	STEAM CONDENSATE TANK	0~100 mm	100 mm	75 %	—	0	x	0	0	H O L	TRANSMITTER } CHECKED / GOOD INDICATOR } H.L ALARM NEW WIRING
LICA-3-57-09	NH <sub>3</sub> CONDENSATE TANK	0~100 mm	53 mm	100 %	—	0	0	0	0	H O L	INDICATOR OVERHAULED / GOOD H.L ALARM CHECKED / GOOD

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LIA-2-81-01	UREA STORAGE TANK	0~100 mm	45 mm	-	-	0	-	0	-	H 0 L	INDICATOR CHECKED / GOOD H.L ALARM CHECKED / GOOD
LI-2-81-02	UREA MALTING	0~100 mm	0	-	-	0	-	X	-	-	
LIA-2-81-04	UREA TOWER TOP	0~100 mm	0	-	-	0	-	0	-	0 L	
LIA-3-52-	NH <sub>3</sub> SYNTHESIS	0~100 mm	0	-	-	0	-	0	-	H 0 L	



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
TRC-3-57-06	UREA SOLUTION 1st	0~200 °C	93°C	15%	0	—	0	0	0	—	RECORDER OVERHAULED / GOOD TRANSDUCER CHECKED / GOOD
TRC-3-57-	UREA SOLUTION 2nd	0~150 °C	72°C	100%	0	—	Δ	0	0	—	RECORDER OVERHAULED AND TRANSDUCER CHECKED / GOOD
TRC-3-57-10	WASHING COLUMN	0~150 °C	80°C	75%	0	—	0	0	0	—	CONTROL VALVE } OVERHAULED / GOOD RECORDER } TRANSDUCER }
TRC-2-81-05	SEPARATOR	50~150 °C	111°C	75%	0	—	0	0	0	—	CONTROL VALVE } OVERHAULED / GOOD RECORDER } TRANSDUCER }
TRC-2-81-07	STRAGE TANK	50~150 °C	130°C	75%	0	—	0	0	0	—	CONTROL VALVE } OVERHAULED / GOOD RECORDER } TRANSDUCER }
TIC-2-81-10	UREA MALT	0~150 °C	73°C	0	0	—	0	0	0	—	TRANSDUCER CHECKED / GOOD
TRC-3-57-02											CONTROL VALVE OVERHAULED / GOOD TRANSDUCER "
ARA-3-57-01	CO <sub>2</sub> -C INLET	0~1%	0.8%	—	—	×	Δ	—	Δ	×	RECORDER NOT GOOD } INDICATOR " } TO BE RENEWED ALARM " }

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-3-44B-01 /1	CO <sub>2</sub> -GAS DRYING	0-200 °C	X	X	X	Δ	X	-	-	
2	"	"	X	X	X	Δ	X	-	-	
3	"	"	X	X	X	Δ	X	-	-	
4	"	"	X	X	X	Δ	X	-	-	
5	"	"	X	X	X	Δ	X	-	-	
6	"	"	X	X	X	Δ	X	-	-	
7	"	"	X	X	X	Δ	X	-	-	
8	"	"	X	X	X	Δ	X	-	-	
9	"	"	X	X	X	Δ	X	-	-	
10	"	"	X	X	X	Δ	X	-	-	
11	"	"	X	X	X	Δ	X	-	-	
12	"	"	X	X	X	Δ	X	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-3-57-05 /1	1st REACTOR BOTTOM	0~250°C	72	Δ	Δ		X	-	-	
/2	"	"	113	Δ	Δ		X	-	-	
/3	1st REACTOR UPPER	"	-	Δ	Δ		X	-	-	
/4	2nd REACTOR INLET	"	172	Δ	Δ		X	-	-	
/5	" OUTLET	"	187	○	Δ	Δ	X	-	-	
/6	WASHING COLUMN IN	"	110	Δ	Δ		X	-	-	
/7	" BOTTOM	"	57	Δ	Δ		X	-	-	
/8	" UPPER	"	159	Δ	Δ		X	-	-	
/9	" OUTLET	"	50	Δ	Δ		X	-	-	
/10	UREA MALTING PUMP OUTLET	"		○	Δ		X	-	-	
/11	TR-3-57-05/5	"		Δ	Δ		X	-	-	
/12	TR-3-57-05/10	"		○	Δ		X	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TIA-3-57-02 / 1	AMMONIA TANK OUT	0~250°C	33°C	Δ	x	Δ	—	x	x L	
2	1st REACTOR INLET NH <sub>3</sub>		28°C	Δ	x	Δ	—	x	x L	
3	1st REACTOR INLET CO <sub>2</sub>		117°C	Δ	x	Δ	—	x	x L	
4	1st REACTOR BOTTOM		147°C	Δ	x	Δ	—	x	x L	
5	2nd "		159°C	Δ	x	Δ	—	x	x L	
6	2nd REACTOR MIDDLE		154°C	Δ	x	Δ	—	x	x L	
7	"		153°C	Δ	x	Δ	—	x	x L	
8	"		163°C	Δ	x	Δ	—	x	x L	
9	2nd REACTOR OUT		118°C	Δ	x	Δ	—	x	x L	
10	HEATOR INLET		62°C	Δ	x	Δ	—	x	x L	
11	WASHING COLMUN		74°C	Δ	x	Δ	—	x	x L	
12	WATER TANK		44°C	Δ	x	Δ	—	x	x L	
13	NH <sub>3</sub> SCRUBBER		49°C	Δ	x	Δ	—	x	x L	
14	NH <sub>3</sub> CONDENSATE TANK		38°C	Δ	x	Δ	—	x	x L	
.										
.										
.										
.										
.										
.										
40										

AMMONIA SULPHATE PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FR-2-51-01	CARBAMATE GAS	0~6000 kg/H	X	-	X	-	-	X	-	-	INSTRUMENT MISSED
FI-2-51-02	INLET SATURATOR	0~3000 kg/H	X	-	-	-	-	X	-	-	INSTRUMENT MISSED
" -03	"	"	X	-	-	-	-	X	-	-	INSTRUMENT MISSED
KrL-2-51-04	NH <sub>3</sub> WATER	0.3~3 m <sup>3</sup> /H	0	-	-	-	-	0	-	-	
" -05	"	"	X	-	-	-	-	X	-	-	INSTRUMENT MISSED
FR-2-51-06	SATURATOR STEAM	0~2000 kg/H	760 kg/H	-	0	-	-	0	-	-	
FI-2-51-07	"	0~1000 kg/H	450 kg/H	-	-	-	-	0	-	-	
" -08	"	"	0 kg/H	-	-	-	-	0	-	-	
FrL-2-51-09	HOT WATER	0.3~3 m <sup>3</sup> /H	0.5 m <sup>3</sup> /H	-	-	-	-	0	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FL-2-51-10	HOT WATER	0.3~3 m <sup>3</sup> /H	0 m <sup>3</sup> /H	-	-	-	-	0	-	-	
FR-2-51-11	H <sub>2</sub> SO <sub>4</sub> 98%	0.5~5 m <sup>3</sup> /H	2 m <sup>3</sup> /H	-	0	-	-	0	-	-	
FL-2-51-12	"	0.25~ 2.5 m <sup>3</sup> /H	x	-	-	-	-	x	-	-	INSTRUMENT MISSED
" -13	"	"	x	-	-	-	-	x	-	-	INSTRUMENT MISSED
FR-2-51-14	NH <sub>3</sub> WATER	0~6000 kg/H	0 kg/H	-	0	-	-	0	-	-	
FR-2-51-15	NH <sub>3</sub> GAS	0~3500 kg/H	x	-	x	-	-	0	-	-	RECORDER MISSED
FR-2-51-16	PROCESS WATER	0~10 m <sup>3</sup> /H	7.1 m <sup>3</sup> /H	-	0	-	-	0	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PIA-2-51-01	NH <sub>3</sub> GAS	0~16 kp/cm <sup>2</sup>	X	-	-	X	-	Δ	-	X	INSTRUMENT MISSED
PRC-2-51-02	"	0~6 kp/cm <sup>2</sup>	X	X	X	-	X	Δ	X	-	INSTRUMENT, CONTROLLER NOT GOOD
PRA-2-51-04	CARBANATE GAS	"	0 kp/cm <sup>2</sup>	-	Δ	Δ	-	Δ	-	X	
PRA-2-51-06	SATURATOR STEAM	0~16 kp/cm <sup>2</sup>	5 kp/cm <sup>2</sup>	-	0	Δ	-	Δ	-	X	
PRCA-2-51-09	COOLING WATER	"	3.5 kp/cm <sup>2</sup>	100%	Δ	Δ	X	Δ	0	X	CONTROL VALVE OVERHAULED / GOOD CONTROLLER OVERHAULED / GOOD
PIA-2-51-10	INST AIR	0~10 kp/cm <sup>2</sup>	3.5	-	-	0	-	-	-	X	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
LIA-2-51-0	H <sub>2</sub> SO <sub>4</sub> HEAD TANK	0~1800 mm	x	—	—	—	—	x	—	x	INSTRUMENT MISSED
LICA-2-51-02	NH <sub>3</sub> EVAPORATOR	0~750 mm	490 mm	250 mm	—	Δ	0	0	0	x	CONTROL VALVE OVERHAULED / CONTROL VALVE TO BE RENEWED
LIA-2-51-03	"	0~500 mm	x	—	—	—	—	x	—	x	INSTRUMENT MISSED
LIA-2-51-08	LYE-TANK	0~2900 mm	x	—	—	—	—	x	—	x	INSTRUMENT MISSED
LI-2-51-10	SULPHURIC ACID TANK	0~1200 mm	x	—	—	Δ	—	x	—	x	TRANSMITTER NOT GOOD
TIC-2-51-09	NH <sub>3</sub> SUPER HEATER	-10~0~ ~+50 °C	25 °C	90 %	—	Δ	x	—	Δ	—	PROTECTION TUBE TO BE CHANGED CONTROL VALVE OVERHAULED / GOOD



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-2-51-01 /1	CARBAMATE GAS	0~200°C	52°C	Δ	Δ	-	0	-	-	
"	STEAM	"	153.5	Δ	Δ	-	0	-	-	
"	NH <sub>3</sub> GAS	"	63	Δ	Δ	-	0	-	-	
"	H <sub>2</sub> SO <sub>4</sub> 98%	"	34	Δ	Δ	Δ	0	-	-	PROTECTION TUBE TO BE RENEWED
"	SPARE	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
"	"	"	-	-	-	-	-	-	-	
TI-2-51-06 /1	OUTLET LYE TANK	0~150°C	X	X	X	X	-	X	-	INSTRUMENT MISSED
"	AT DRYER HEATING ZONE	"	X	X	X	X	-	X	-	
"	AT DRYER COOLING ZONE	"	X	X	X	X	-	X	-	
"	AT TANK FOR SPRAYING AGENT	"	X	X	X	X	-	X	-	

H<sub>2</sub>SO<sub>4</sub> PLANT

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FR-861-1	DRYING TOWER OUT	0~26000 Nm <sup>3</sup> /h	X	—	X	—	—	X	—	—	
FI-868-1	INLET FURNACE	0~18000 Nm <sup>3</sup> /H	X	—	—	Δ	—	X	—	—	
TR-868-3-3	30K STEAM	250~500 °C	X	—	X	—	—	Δ	—	—	RECORDER TO BE CHANGED
FR-868-3-2	"	0~10 T/H	X	—	X	—	—	Δ	—	—	
PR-868-3-6	"	0~40 kg/cm <sup>2</sup>	X	—	X	—	—	X	—	—	
LRC-861-1	STEAM DRUM	0~400 mm	72 mm	65 %	0	—	0	Δ	0	—	CONTROLLER OVERHAULED CONTROL VALVE CHANGED TRANSMITTER TO BE RENEWED
DR-861-2	H <sub>2</sub> SO <sub>4</sub>	94~98.5 %	97 %	—	Δ	—	—	Δ	—	—	
DR-861-3	H <sub>2</sub> SO <sub>4</sub>	96.5~ 98.5%	99.2 %	—	Δ	—	—	Δ	—	—	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TI-861-1/1	BEFORE CONVERTER	0~900°C	280°C	0	Δ	0	-	0	-	PROTECTION TUBE INSPECTIONED / GOOD
2	BEFORE I RAY		402	0	Δ	0	-	0	-	PROTECTION TUBE INSPECTIONED / GOOD
3	I RAY		400	0	Δ	-	-	0	-	
4	OUTLET I RAY		570	0	Δ	-	-	0	-	
5	INLET II RAY		492	0	0	0	-	0	-	COMPENSATE WIRE CHANGED PROTECTION TUBE CHANGED
6	OUTLET II RAY		550	0	Δ	-	-	0	-	
7	INLET III RAY		410	0	Δ	0	-	0	-	PROTECTION TUBE INSPECTIONED / GOOD
8	OUTLET III RAY		410	0	Δ	-	-	0	-	
9	INLET IV RAY		392	0	Δ	-	-	0	-	
10	IV RAY		420	0	Δ	0	-	0	-	PROTECTION TUBE INSPECTIONED / GOOD
11	IV RAY		505	0	Δ	0	-	0	-	PROTECTION TUBE INSPECTIONED / GOOD
12	OUTLET III RAY		460	0	Δ	-	-	0	-	
13	AIR PREHEATER		160	0	Δ	-	-	0	-	
14	INTERMEDIATE COOLER		50	0	Δ	-	-	0	-	
15	"		270	0	Δ	-	-	0	-	
16	AIR PREHEATER		375	0	Δ	-	-	0	-	
17	ECO INLET		370	0	Δ	-	-	0	-	
18	ECO OUTLET		170	0	Δ	-	-	0	-	
19	STEAM		330	0	Δ	-	-	0	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TR-861-2.1	BEFORE CONVERTER	0~700°C	385°C	0	Δ	-	Δ	-	-	RECORDER OVERHAULED / TO BE RENEWED
"	BEFORE I RAY	"	400	0	Δ	-	Δ	-	-	
"	INLET II RAY	"	415	0	Δ	-	Δ	-	-	
"	OUTLET II RAY	"	495	0	Δ	-	Δ	-	-	
"	INLET III RAY	"	455	0	Δ	-	Δ	-	-	
"	IV RAY	"	445	0	Δ	-	Δ	-	-	
TR-868-2.1	OUTLET ECONOMIZER	0~600°C	209°C	0	Δ	-	Δ	-	-	RECORDER OVERHAULED / TO BE RENEWED
"	OUTLET FURNACE	50~1600°C	900	0	Δ	-	Δ	-	-	

EGAT BOILER

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
FI-	COMB AIR	0~100 %	25 %	-	-	0	-	0	-	-	
FI-	COAL RATE	0~100 %	18 %	-	-	0	-	0	-	-	
FI-	HP STEAM FLOW	0~40 T/H	x	-	-	x	-	x	-	-	
FI-	F.W FLOW	0~50 T/H	8 T/H	-	-	0	-	0	-	-	
FI-	STEAM TO FERTIZER PLANT	0~15 T/H	12 T/H	-	-	0	-	0	-	-	
LIA-	STEAM DRUM	~18~0 ~+22 mm	+0 mm	-	-	0	x	0	0	0 H.I.	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PI-	FD AIR PREHEATER IN	0~250 mmWG	30 mmWG	-	-	0	-	0	-	-	
PI-	FD AIR PREHEATER OUT	"	20 mmWG	-	-	0	-	0	-	-	
PI-	FLUE GAS ECO IN	0~200 mmWG	25 mmWG	-	-	0	-	0	-	-	
PI-	FLUE GAS ECO OUT	"	12 mmWG	-	-	0	-	0	-	-	
PI-	FLUE GAS PREHEATER OUT	"	0 mmWG	-	-	0	-	Δ	-	-	
PI-	STORAGE TANK I	0~40 CM.WG	13 CM.WG	-	-	0	-	0	-	-	
PI-	STORAGE TANK II	"	"	-	-	0	-	0	-	-	
PI-	SEC AIR	0~1000 mmWG	0 mmWG	-	-	Δ	-	Δ	-	-	
PI-	FD AIR	0~250 mmWG	20 mmWG	-	-	0	-	0	-	-	

TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
PI-	HP STEAM	0~100 kg/cm <sup>2</sup>	40 kg/cm <sup>2</sup>	-	-	0	-	0	-	-	
PI-	FURNACE DRAFT	-10~0 ~+5 mmWG	-3 mmWG	-	-	0	-	0	-	-	
PGA	STEAM	0~100 kg/cm <sup>2</sup>	40 kg/cm <sup>2</sup>	-	-	0	-	0	-	-	
PG	FEED WATER	"	63 kg/cm <sup>2</sup>	-	-	0	-	0	-	-	



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	ELEMENT	COMPENSATE WIRE	PROTECTION TUBE	RECORDER	INDICATOR	ALARM	REMARKS
TI-	ED ECO IN	0~300°C	90°C	0	0	-	-	0	-	
TI-	FD AIR PREHEATER OUT	"	104	0	0	0	-	0	-	PROTECTION TUBE INSPECTIONED / GOOD
TI-	FW FCO OUT	"	240	0	0	-	-	0	-	
TI-	DESUPER HEATER IN	200~550°C	330°C	0	0	-	-	0	-	
TI-	DESUPER HEATER OUT	"	460°C	0	0	-	-	0	-	
TI-	FLUE GAS ECO IN	0~700°C	230°C	0	0	-	-	0	-	
TI-	FLUE GAS ECO OUT	"	280	0	0	-	-	0	-	
TI-	FLUE-GAS PREHEATER OUT	"	520	0	0	0	-	0	-	PROTECTION TUBE INSPECTIONED / GOOD
TI	SUPER HEATER OUTLET	200~500°C	435°C	0	0	-	-	0	-	



TAG. NO.	SERVICE	RANGE	OPERATION VALVE	CONTROLLER OUTPUT	RECORDER	INDICATOR	CONTROLLER	TRANSMITTER	CONTROL VALVE	ALARM	REMARKS
CO <sub>2</sub>	INSIDE FURNACE	0 ~ 20 %	X	-	1	X	1	X	1	1	
CO + H <sub>2</sub>	"	0 ~ 20 %	X	-	1	X	1	X	1	1	

FCV-3-29-02 (AMMONIA PLANT STEAM)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION FLOW TEMP/ $\Delta P$	Single seat 40 K 80 A COMPLETE CONE/PARABOLIC Equal % 65 Spring close max. 6.8 t/H, standard 5.94 t/H 350°C/3.5 kg/cm <sup>2</sup> G
INSPC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 60 kg/cm <sup>2</sup> , 15 min Good Air 1 kg/cm <sup>2</sup> , 9.6 l/min Good Full stroke Good OK Changed, OK "

REMARKS	<div style="display: flex; align-items: flex-start;"> <div style="margin-right: 20px;">  <p>scratched 30 mm</p> </div> <div> <p>became slender about 0.5 mm</p> </div> </div> <div style="display: flex; align-items: flex-start;"> <div style="margin-right: 20px;">  </div> <div> <p>The lower cover of guide bush had been damaged and it was newly prepared and changed.</p> <p style="margin-left: 40px;">34 <math>\phi</math></p> <p style="margin-left: 40px;">25 <math>\phi</math></p> <p style="margin-left: 40px;">20 mm</p> </div> </div> <p>* Valve plug &amp; Seat ring should be replaced.</p>	
---------	---	--

FRC-3-29-02 (AMMONIA PLANT)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	Single seat 350°C/29 K 80 Complete cone/parabolic Equal % 65 Spring close
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	
REMARKS		

PCV-3-31-2 (AMMONIA PLANT FLASH VESSEL)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	Single seat 40 K  PARABOLIC Eq 2 MAX CV:20 NOR.OPERATION CV: 11.6 AIR to OPEN
INSPIC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	WATER 60 K, 15 min. Good Air 2K, 0.35 l/min. Good Full stroke Good OK Changed OK "
REMARKS		

LCV-3-52-01 (AMMONIA SEPARATOR)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION BODY MATERIAL	Angle 500 K 24 PARABOLIC LINEAR 1.33 AIR to OPEN WN 4580/VA
INSPEC. RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	WATER 600 kg/cm <sup>2</sup> , 15 min. Good AIR 4 kg/cm <sup>2</sup> , 0.8 l/min. Good Full stroke Good OK Change OK "
REMARKS	VALVE PLUG & SEAT RING changed	


LCV-3-29-02 (AMMONIA DEMOISTURE WATER)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION SERVO MOTOR	Double seat 40 K  PARABOLIC LINEAR max Cv 310, NOR OPERATION Cv 230.6 AIR to OPEN A300
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 60 kg/cm <sup>2</sup> , 15 Good Water 4 kg/cm <sup>2</sup> , 0 l/min Good Full stroke OK OK Changed OK "
REMARKS		

PCV-3-65-03 (FEED WATER MEDIUM STEAM)


SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	Double seat 16 80 PARABOLIC Eq % KV 76 AIR to OPEN
INSPC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 24 kg/cm <sup>2</sup> , 15 min Good Water 4 kg/cm <sup>2</sup> , 5.4 l/min. Good Full stroke OK OK Changed OK "
REMARKS	VALVE STEAM & PLUG are recommendable to be changed within 2 years.  	

PCV-3-65-02 (FEED WATER MEDIUM STEAM)


SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION MAX FLOW	Single seat 40 50 PARABOLIC Eq % KV: 40 AIR to OPEN 11 t/H
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 60 kg/cm <sup>2</sup> , 15 min Good AIR 2 kg/cm <sup>2</sup> , 4.2 l/min Good Full stroke good OK Changed OK "
REMARKS	Valve stem to be changed next occasion. Valve plug and seat ring were finished by the machining. Body inside has a hole by corrosion and seat ring damaged by the leakage. The troubles have been repaired by welding, yet it is recommendable to replace within 2 years.	
		



TCV-3-65-01 (FEED WATER INJECTION WATER)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	40 K
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 60 kg/cm <sup>2</sup> , 15 min. Good - Full stroke OK OK Changed OK "
REMARKS	<div style="display: flex; align-items: flex-start;"> <div style="flex: 1;">  <p style="margin-left: 20px;">← a little scratched</p> <p>valve plug</p> </div> <div style="flex: 2; padding-left: 20px;"> <p>Valve plug and Seat ring good</p> <p>Valve plug double seat face OK</p> </div> </div>	

TCV-3-65-02 (FEED WATER INJECTION WATER)


SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	20 K
INSPC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 30 kg/cm <sup>2</sup> , 15 min. Good - Full stroke OK OK Change OK "
REMARKS	<div style="text-align: center;">  <p>valve plug</p> </div>	


LCV-5 (GASIFICATION STEAM DRUM)


SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION FLOW $P_1, P_2$	Single seat  32 (1 1/2")  Eq 3  $Q_{max} 42 \text{ m}^3/\text{H}, Q_{normal} 8 \text{ m}^3/\text{H}$ 33.5 K, 12 K min.
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water $60 \text{ kg/cm}^2$ , 15 min. Good AIR $2 \text{ kg/cm}^2$ , 1 l/min. Good Full stroke OK OK Changed OK "

REMARKS

Connections of Valve plug and Stem were loosened and had been repaired.







Here was corroded, the damaged one was used in Urea plant and it is better to be renewed.

This was changed to UREA PLANT TCV-3-57-07.

The CV value of LCV is too large. It should be reduce to size of 1/3.

FCV-4-11-03 (ADIP OUTLET CONDENSATE REBOILER)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	Single seat 10 25 PARABOLIC Eq 8 13 AIR to OPEN
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 15 kg/cm <sup>2</sup> , 15 min. Good AIR 4 kg/cm <sup>2</sup> , 0 l/min. Good Full stroke OK OK Changed OK "
REMARKS	VALVE PLUG and Seat ring were finished.	


LCV-4 (AIR SEPARATION)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 15 kg/cm <sup>2</sup> , 15 min. Good  Full stroke Good  OK  Change OK  "
REMARKS	Good condition	

LCV-7 (AIR SEPARATION)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 10 kg/cm <sup>2</sup> , 15 min Good  Full stroke OK  OK  Change OK  "
REMARKS	Good condition	

LCV-861-1 (H<sub>2</sub>SO<sub>4</sub> PLANT STEAM DRUM)

SPECIFICATION	VALVE TYPE RATING SIZE TYPE OF PLUG CHARACTERISTIC CV VALVE ACTION	2B     KV: 20
INSPEC RESULT	TIGHT TEST LEKAGE TEST VALVE TRAVEL PAINTING OF BODY GLAND PACKING SEAT PACKING	Water 60 kg/cm <sup>2</sup> , 15 min. Good  AIR 2 kg/cm <sup>2</sup> , 0.6 l/min. Good  Full stroke Good  OK  Change OK  "
REMARKS	<div style="display: flex; align-items: flex-start;"> <div style="flex: 1;">  </div> <div style="flex: 2; padding-left: 20px;"> <p>The spare actuator of Ammonia FIC-3-65-03 was converted to this, because of the old actuator had not enough power to close the valve when the water pressure was over 40<sup>K</sup>.</p> <p>The body was change to new spare part, which was made in Bangkok.</p> <p>KV value of 20 is too large for this valve.</p> <p>Valve plug was machine and lapped to the seat.</p> </div> </div>	

GASIFICATION, FEED WATER, ADIP PLANT CONTROL VALVE O.H SCHEDULE

NO	DATE ITEM	JUL												RATING	TIGHT TEST	LEAKAGE TEST	TEST DATA (%)									
		11	12	13	14	15	16	17	18	19	20	21	22				23	24	25	26	27	28	0	25	50	75
1	LCV-5 (Gasification drum)	///																		60	AIR 2K 1 l/min.	0	25	50	75	100
2	PCV-3-65-02 (Feed water)						///					///								60	AIR 2K 4.2 l/min.	0	25	50	75	100
3	PCV-3-65-03 (Feed water)						///													24	WATER 4K 5.4 l/min.	0	25	50	75	100
4	TCV-3-65-01 (Feed water)							///												60	AIR 2K 3 l/min.	0	25	50	75	100
5	TCV-3-65-02 (Feed water)							///					///							30	WATER 4K 8.2 l/min.	0	25	50	75	100
6	FCV-4-11-03 (Adip)		///																	15	AIR 4K 0 l/min.	0	25	50	75	100







