

**PRELIMINARY DESIGNS OF
NAM GAM PROJECT**

- I. NAM PUNG HYDRO-ELECTRIC PROJECT**
- II. NAM PUNG IRRIGATION PROJECT**

DECEMBER 1962

**JAPANESE INVESTIGATION TEAM
ON THE NAM GAM PROJECT**

E 22

List of Errata (Preliminary Design)

Page	Line	Column	In the text	To be corrected as
I-2	8		2.75	2.62
"	9		Max. capacity	Max. output
"	10		Firm capacity	Firm output
"	11		Firm peak capacity 3,000 kW	Firm peak output 4,500 kW
"	12		Annual generation	Annual generating energy
I-5	26	10	oroginate	originate
I-7	6	1	gravel	pebbles
"	9	9	contains, granula	contains granula
"	12	9	cobbles	pebbles
"	12	8	shale	shaly
"	18	6	mm	1 m
"	22	2	boulder	nodules
I-9	8	11	intrusion	intercalation
"	14	6, 9	No. 2 and No. 5	No. 2' and No. 5'
I-10	11	1	erosion	weathering
I-12	20	6	No. 8	No. 8'
I-15	27		6 m	5 m
I-18	29		Revolutions	Revolving speed
I-19	9		Revolutions	Rcvolving speed
"	21		66 kV at an outdoor sub-station	66 kV at an outdoor switchyard
"	27		At the outdoor sub-station	At the outdoor switchyard
"	29		a lightning arrester	a lightning arrester
I-21	9		a lightning arrester	a lightning arrester
I-22	2		rated	nominal
I-23	11-12		wind pressure	wind pressure on conductor

Page	Line	Column	In the text	To be corrected as
I-25	6		690	650
"	15		performed	preformed
I-27	7	7	Dry	Wet
"	18		-	(1.2)
I-28	2		Pore water pressure	Up lift pressure
"	3		Pore water pressure acting	Load action
"	11		$(3.2 + 0.5)^2$	$(32 + 0.5)^2$
"	21	2	-	2
I-29	16		clip	slip
"	23		Safety factor	Safety factor =
"	24		ΣV_n	ΣU_n
"	24		$\tan \phi - \Sigma C$	$\tan \phi + \Sigma C$
I-32	5	6	1,965	1,960
I-33	19		track	rack
"	20		$U_1^2/2g$	$V_1^2/2g$
I-34	5		$122h^2/D^4/3$	$122n^2/D^4/3$
I-35	14-16		γT	γt
"	"		γG	γg
I-36	7-20		k_1, k_2, \dots, k_n	L_1, L_2, \dots, L_n
"	11		(kWh)	(kW)
I-37	23		6,529,740*	6,529,740
"	24		Note: * Interest	Interest
I-38	8	5	(Remarks of Direct Cost)	Refer to Table I-3
I-39	18	3	420,081	420,082
"	26	3	192,864	192,860
I-41	7	5	(Remarks of Diesel generator)	Include building
"	10		\$ 6,529,740	U.S.\$ 6,529,740

Page	Line	Column	In the text	To be corrected as
I-42	16	6	Crashed rock	
I-43	23	2	" 1 6,944	L _s 1 6,944
"	24	2	" 1 9,722	L _s 1 9,722
I-48	21		per annum	per annual
(II)				
i	6	Page	II-2	II-3
i	7	Page	II-3	II-4
iii	8		Weirs	Weir
II-1	18		Pumping Station	Pumping Stations
"	20		Non Han	Nong Han
II-2	2		Canal	Canals
"	7		Station	Stations
"	25		gates and	gates are
II-3	16, 17			(to be deleted)
II-4	25		L = 12 x 4.2 = 50 m	L = 12 x 4.2 ÷ 50 m
II-5	17		407 m ³ /s	407 m ³ /min
II-7			* Water diverged from	* Water diverged to
II-8	13		trapezoidal	trapezoidal
II-9	16		Top figure	Bottom figure
"	17		Bottom figure	Top figure
II-11	7		RHP = $\frac{SHP}{\eta_g} \times e_m$ 29 HP ÷ 21 kW	RHP = $\frac{SHP}{\eta_g} \times e_m$ = 29 HP ÷ 21 kW
II-14	5		400-voltage motor with	400-voltage motor

E 22/
54/
J

PRELIMINARY DESIGNS OF NAM GAM PROJECT

I. NAM PUNG HYDRO-ELECTRIC PROJECT

II. NAM PUNG IRRIGATION PROJECT

DECEMBER 1962

JICA LIBRARY



1050569[1]

JAPANESE INVESTIGATION TEAM
ON THE NAM GAM PROJECT

國際協力事業団		
受入 月日	'84. 5. 16	122
登録No.	04698	833
		SD

INTRODUCTION

The preliminary designs of the Nam Gam Project consists of the Nam Pung Hydro-electric Project and the Nam Pung Irrigation Project which are the two projects that are anticipated for early development among the several projects in the first stage development of the Nam Gam basin. The preliminary designs were prepared in accordance with the Plan of Operation which was signed in Bangkok in October 1961. It must be pointed out that field investigations and design work for the projects were completed in a very short period.

In this volume are included a general description of the designs and construction cost estimates of the Nam Pung Hydro-electric Project and the Nam Pung Irrigation Project. Therefore, detailed field surveys and investigations and detailed designs will be necessary before construction of the Projects may proceed. The time required to accomplish these work is estimated to be about 1 year for the power phase and about 1 1/2 years for the irrigation phase of the projects.

I. NAM PUNG HYDRO-ELECTRIC PROJECT

C O N T E N T S

	Page
A. SUMMARY	I-1
B. RESERVOIR PLAN	I-3
C. TOPOGRAPHY, GENERAL GEOLOGY AND STRUCTURES	I-5
(a) Topography and General Geology	I-5
(1) Topography	I-5
(2) General Geology and Rock Type	I-6
(3) Geologic Feature of the Dam Site	I-7
(4) Geology of the Powerhouse Site	I-11
(5) Rock and impervious Core Material	I-13
(6) Conclusion	I-14
(b) Description of Structures	I-14
(1) Dam	I-14
(2) Spillway	I-15
(3) Outlet	I-16
(4) Intake	I-16
(5) Pressure Conduit and Pressure Tunnel	I-17
(6) Surge Tank	I-17
(7) Penstock	I-18
(8) Power Plant	I-18
(9) Sub-stations	I-20
(10) Transmission Line	I-21
(11) Communication System	I-25

	Page
D. COMPUTATIONS	I-27
(a) Stability Calculations of Dam	I-27
(b) Calculation of Flood Discharge through Spillway	I-30
(c) Determination of Powerhouse Discharge	I-31
(d) Calculation of Head Losses and Powerhouse Output	I-32
(e) Calculation of Transmission Losses	I-35
E. ESTIMATED CONSTRUCTION COSTS	I-37
(a) Estimated Construction Costs	I-37
(b) Studies of Electric Service Rates	I-47

T A B L E S

	Page
I-1 Boring Result	I-14
I-2 Nam Pung Hydro-electric Project, Details of Construction Cost Estimates Based on Preliminary Designs	I-38
I-3 Breakdown of Direct Costs of Nam Pung Hydro-electric Project	I-42

F I G U R E S

	Page
I-1 Dam Standard Section	I-30
I-2 Diagram of Driving Forces Critical Slip Circle for Rapid Drawdown Condition	I-30
I-3 Diagram of Driving Forces Critical Slip Circle of Downstream Slope for Steady State Condition	I-30

D R A W I N G S

	Page
I-1 General Map	I-48
I-2 Geology and Location of Exploration (Dam)	"
I-3 Geology and Location of Exploration (Power Plant)	"
I-4 Geology Plan, Surge Tank Power Plant (Alternative Site)	"
I-5 Geologic Section (Dam) A-A, B-B, D-D, E-E	"
I-6 Geologic Section (Dam) C-C, F-F, G-G, H-H	"
I-7 Geologic Section, Surge Tank - Power Plant	"
I-8 Boring Profile (Dam) 1	"
I-9 Boring Profile (Dam) 2	"
I-10 Boring Profile (Surge Tank)	"
I-11 Boring Profile (Alternative Power Plant and Surge Tank)	"
I-12 Plan of Reservoir	"
I-13 General Plan	"
I-14 Typical Section and Upstream Elevation of Dam	"
I-15 Plan and Section of Spillway	"
I-16 Section of Spillway	"
I-17 Longitudinal Section (Head Race and Tail Race)	"
I-18 Section of Intake and Surge Tank	"
I-19 Sectional Profile of Penstock and Power Plant	"
I-20 Plan of Power Plant	"
I-21 Power Plant	"
I-22 System Diagram	"
I-23 Power Plant Connection Diagram	"
I-24 Substation Connection Diagram	"
I-25 Power Plant (Switch Yard)	"

	Page
I-26 Substation (Sakol Nakorn)	I-48
I-27 Substation (That Phanom)	"
I-28 Substation (Nam Pung Bridge, Nakorn Phanom, Mukdahan, Nam Pung)	"
I-29 Typical Wood Pole (69 kV)	"
I-30 Communication System Diagram	"

A. SUMMARY

The proposed site of the Nam Pung Hydro-electric Project is located on the Nam Pung, a tributary of the Nam Gam, approximately 30 km southwest of the city of Sakol Nakorn which is the center of activities of the area.

Near the proposed site there are several falls creating a developable head of about 60 m. A rock-fill dam 32 m high is to be constructed on exposed bedrock immediately upstream of the falls. The dam will impound 122,000,000 m³ of useful water from a catchment area of 296 km². The reservoir will regulate the flow of the river throughout a year, as well as, supplementing flow in dry seasons. Approximately 50% of the effective storage volume will be discharged during the dry seasons. The dam is to be utilized for power generation, irrigation and flood control.

The geology of the dam site consists mainly of sandstone and conglomerate with intrusion of mudstone and shale. The foundation rock is not sound, but will adequately sustain a fill type dam which is believed appropriate for the site in view of difficulties to obtain aggregates for concrete.

A general description of the Nam Pung Hydro-electric Project (the dam will be multi-purpose) is given in the following pages. It should be pointed out that the project was designed based on annual run-off estimated from analytical studies of 5 years rainfall records of Bang Srang Khor, recent 13 years rainfall records of Sakol Nakorn, and inflow and outflow from Lake Nong Han because available streamflow records of the dam site was for the year 1961 only. Therefore, when additional data become available, the estimated streamflow may be modified.

A rock-fill dam, 32 m high containing 764,000 m³ of embankment will create a reservoir with an effective storage capacity of 122,000,000 m³ which will regulate several years discharge of the Nam Pung. Water stored behind the dam is to be diverted to a power plant with a maximum output of

5,400 kW to be built about 1 km downstream of the dam.

Elevation at high water level	EL. 284 m
Elevation at low water level	EL. 270 m
Tailrace elevation	EL. 193.1 m
Gross head	90.9 m
Effective head (at normal water level)	78.5 m
Max. discharge of turbines	8.5 m ³ /s
Firm discharge of turbines	2.75 m ³ /s
Max. capacity	5,400 kW
Firm capacity	1,750 kW
Firm peak capacity	3,000 kW
Annual generation	15,000,000 kWh

The dam will have a spillway with a capacity of 300 m³/s. It will also have an outlet to lower the storage level to below EL. 270 m.

A reinforced concrete intake tower 22.5 m high and with a roller gate 25 m high and 3.0 m wide will be constructed on the right bank immediately upstream of the dam. The intake will connect to a pressure conduit, 2.0 m inside diameter and 439 m long and a pressure tunnel, 122 m long, and terminate at a simple surge tank, 6 m inside diameter and 34.0 m high. Connection from the surge tank to the powerhouse, to be located on the right bank about 2.5 river km downstream of the dam, will be by a penstock, 412 m long and 2.0 m inside diameter tapering down to 1.5 m.

The powerhouse will have 3 sets of turbine generators which will have a maximum output of 5,400 kW and produce 15,000,000 kWh annually. Water discharged from the powerhouse is to be released into the natural bed of the Nam Pung through a tailrace tunnel.

Adjoining the powerhouse, an outdoor switchyard is to be built. The switchyard will have 3 units of 2,200 kVA single phase transformers to step-

up the powerhouse output to 66 kV.

The following step-down sub-stations are to be built at the locations listed below.

Sakol Nakorn Sub-station	400 kVA single phase transformer x 6 units
Nam Pung Bridge Sub-station	400 kVA single phase transformer x 3 units
Na Kae Sub-station	50 kVA 3-phase transformer x 1 unit
That Phanom Sub-station	400 kVA single phase transformer x 3 units (1 unit is a reserve)
Nakorn Phanom Sub-station	400 kVA single phase transformer x 3 units
Mukdahan Sub-station	400 kVA single phase transformer x 3 units

The total length of transmission lines is approximately 200 km. In consideration of transmission capacity, voltage regulation and transmission loss, the most economical transmission line voltage determined as a result of studies is 66 kV (rated voltage 60 kV, maximum circuit voltage 69 kV) in one circuit of 58 mm² A.C.S.R. conductor.

Communication system will comprise of a power line carrier telephone between Nam Pung Power Plant and Sakol Nakorn Sub-station, and VHF (1 circuit) wireless telephone communication with sub-stations east of Sakol Nakorn.

B. RESERVOIR PLAN

The Nam Pong reservoir which will be created by the construction of a rock-fill dam, 32 m high, on the Nam Pung at a site about 30 km southwest of Sakol Nakorn city, will have an effective storage capacity of 122,000,000 m³ at a high water elevation of 284 m above sea level. The pondage area will be about 20 km².

With this storage capacity, water required in the first stage development of the Nam Gam basin may be secured. The general features of the reservoir are as follows. (see Drawing I-12)

Catchment area	296 km ²
Elevation at high water level	284 m
Elevation at low water level	270 m
Available drawdown	14 m
Gross storage capacity	133,000,000 m ³
Effective storage capacity	122,000,000 m ³
Pondage area	20 km ²
Elevation at design flood water level	285.5 m
Annual inflow	63,000,000 to 174,000,000 m ³

The operation of the reservoir, as a principle, in normal run-off year would be to store run-off during the wet season of June to July, fill the reservoir by the end of October, and discharge the stored water during the dry season of November to May. In a dry year, the reservoir may not fill up to capacity. However, adequate reserves are included in the capacity, and over-the-year supplementaing of flow is possible, as well as, the regulating of several years of run-off to enable the use of equalized flow throughout a year. The reservoir will not only serve the purpose of equalizing the flow of the Nam Pung, but storage is also included to generate necessary power during dry seasons to pump water from Lake Nong Han. The computation of this storage capacity is described hereinafter.

The monthly run-off at the Nam Pung dam site for the period 1952 to 1961 estimated from the analysis of streamflow at the dam site (Chapter II, C of the Report) was transcribed on a mass curve (see Fig. III-4 Nam Pung Reservoir Inflow Mass Curve in the Report). It was found that the least values

for 5 consecutive years were the period 1956 to 1960. In order to regulate the run-off during those years, an effective storage capacity of approximately 106,000,000 m³ is necessary. The required storage capacity to operate irrigation pumps for the Lake Nong Han pump-irrigation scheme, which was calculated separately is 16,000,000 m³. Therefore, the effective storage capacity of the reservoir was determined as: 106,000,000 m³ + 16,000,000 m³ = 122,000,000 m³.

With this reservoir, it will be also possible to regulate maximum flood discharges. The design high water level of the Nam Pung reservoir is EL. 284 m. During abnormal peak flood flows of 640 m³/s, which is a 1,000 year probability, the reservoir may be surcharged by 1.5 m to EL. 285.5 m which will provide a storage capacity of approximately 35,000,000 m³ to store the flood discharge. As a result, the peak flood run-off of 640 m³/s may be reduced to 281 m³/s and the peak flood discharge may be retarded. Thus, flood damages to the downstream area may be greatly alleviated. (see Chapter III, C. Flood Control Scheme in the Report)

C. TOPOGRAPHY, GENERAL GEOLOGY AND STRUCTURES

(a) Topography and General Geology

(1) Topography

The proposed project area is the north-eastern section of Korat Plateau in a hilly region in the southwest of the Nam Gam basin. The dam site is in the upper reaches of Nam Pung where the river makes a sharp bend to the west. The site of the power station is about 2.5 river km downstream of the dam on the right bank of the Nam Pung where it changes its course to the west. The Korat Plateau is a large land block gently sloping towards the southeast. The Nam Pung and other rivers which originate in the western edge of Nam Gam hills generally flow in a north-easterly direction according to the terrain of the region and drain into Lake Nong Han.

Upstream of the dam site is a continuous gently rolling hill which is dissected by the Nam Pung near the dam site, creating a boxed shaped valley 1 to 5 m deep and 40 m wide. The valley downstream of the dam site where the river makes a turn towards the west is almost V shaped. The Nam Pung has very little run-off during the dry seasons.

It will be seen from the geologic plan and section, attached herewith, that the topography of the Nam Pung is a valley in a valley. Near the dam axis there is visible a former river bed that has gone through 2 steps of river erosion cycle. The shoulder of the lower valley is EL. 265 m and the upper valley is EL. 275 m. The slope of the right valley at the dam site from the river bed to EL. 275 m is 6° on the average, while on the left bank it is 14° on the average up to EL. 275 m. Above that elevation, the valley walls have a gentle slope of 2 to 3° .

The river valley walls at the proposed powerhouse site and an alternative powerhouse site (400 m downstream of the former) have an average slope of 25° and 16° , respectively, from the river bed to EL. 260 m, and above this elevation, the valley walls are a gentle slope. The location of the surge tank is on a gentle rolling which is the hill that faces the dam site on one slope and the powerhouse site on the opposite slope. The top of the hill is flat and was a former river bed of cycle of erosion.

(2) General geology and rock type

The bedrock of Korat Plateau is triassic and/or jurassic of the Korat series.

In the proposed dam site area, the Korat series is mainly a thick layer of terrigenous deposits of sandstone and conglomerate with intercalation of thin layers of shale and mudstone. The bedrock of the dam site appears to belong to the younger geologic time of the Korat series. It is deposited almost horizontally with extremely gentle folding. Cross bedding has been

often recognized in the area.

The fresher of the sandstone at the proposed dam site is grayish or blue-grayish color, and those of arkose are white or milky colored, but the weathering surface has been changed to a yellowish brown color. Granularity of the rock is fine grained to medium or coarse grained with some small gravel or with intercalation of lamina of mudstone. Some have transformed into conglomerate described later, but are divided by clear bedding or by intercalation of a thin layer of shale or mudstone.

Conglomerate is composed of sandy matrix which contains, granula and small to medium size pebbles. In fresh rock, the matrix is similar to the color of sandstone. Pebbles are mostly silicious rock, and some of chert and slate. Besides these, small shale cobbles of greenish or chocolate color are found, though very little. Pebbles are generally well rounded and fresh.

Shale or mudstone in thin layers are found intercalated in sandstone, or have gradually interchanged with fine grained sandstone or are found between the border of conglomerate and sandstone. The color of this rock is black, dark green and chocolate, and they are generally compact rock with thickness of 10 cm up to m m at the most.

Covering this bedrock is a thin layer of sandy surface soil. Surface soil is yellow or yellowish-brown, relatively compacted and in some places well cemented with lime. In flat areas laterization has taken place and small boulders of laterite are found.

Results of microscopic observations of rocks and tests of physical qualities will not be described.

(3) Geologic feature of the dam site

In addition to surface geologic surveys of the dam site and vicinity, 19 diamond core drillings (7 drilling were made by NEA) and over 6 auger borings, shown on Table I-1, were made to confirm the bedrock condition.

No. 2 drill hole was used for permeability tests by the water lifting method.

In the geologic plans are shown the location of the diamond core drillings and geologic trial section prepared from geological data (Drawing I-5 and I-6). AA and BB on the geologic trial sections are respectively the dam center line of the alternative dam site and the proposed dam site.

The results and details of the diamond core drillings are given in Table I-1 and the outline and the relationship of the drill holes are shown on Drawing I-8 and I-9.

(i) Stratigraphical studies

The bedrock of the dam site is composed mainly of sandstone and conglomerate.

The conglomerate, as shown on Drawing I-2 and I-5, is found in the river bed and along the slopes of both banks, with considerable variation in the thickness and widely spread. Considering conglomerate as a key bed, the surface layer is almost horizontal, dipping 5° slightly to the north. According to the results of surface geologic methods and borings, there are at least 3 layers of conglomerate. The uppermost layer on the left bank is 1 to 2 meters thick, while on the right bank it is over 5 meters and the layer grows thicker and ultimately to 20 m as it recedes from the river. Bounding this bed and underlying sandstone interbeds a thin layer of mudstone. A mudstone layer exists under the conglomerate from near No. 3 drill hole on the right mountain slope and extending to the entire right bank. The layer thickness is about 2 m and immediately below the right abutment, the layer thickness decreases and forms a member of sandstone. Conglomerate in the intermediate zone is exposed near the dam axis line. The layer thickness is 2 to 3 m and the rock extends over a wide area. The very bottom layer of conglomerate, according to No. 9 drill hole, is about 8 m thick. From drill hole No.1,2

and 3, it was found that there are 2 to 3 thin layers extending from the river bed to the hill side of the right bank. Mudstone is found in the sandstone which is under the lowermost layer of conglomerate.

Sandstone is widely distributed on the surface, and its granulation is generally medium. However, granulation of a fineness close to mudstone and of a coarseness like conglomerate are found, and in most cases the granulation changes naturally. But, in some cases the granulation changes from fine to medium and coarse by the intrusion of mudstone 5 to 20 cm thick.

The foundation rock of the dam site is well compact, with little joints and cracks, and fault has not been recognized. Bedrock of former valley shoulder of cycle of erosion is somewhat loose, and the existence of creep phenomenon on a very small scale and cavities about 1 m wide, which were seen in No. 2 and No. 5 drill cores, have been recognized.

Overburden on the bedrock is very thin and in the river section there are places with deposits of large boulders.

(ii) Weathering and groundwater

The surface of the bedrock has been subject to weathering and the color of the rock is yellow or yellowish brown. Sandstone of fine to medium granulation are relatively strong against weathering, and it appears that the action of weathering has affected only the surface of the rock. Sandstone which has been affected by weathering is porous and light compared to fresh rock.

Conglomerate compared to sandstone is more easily affected by weathering and the weathering in conglomerate is more advanced towards the core. Weathering of shale and mudstone close to the surface have particularly advanced, and the valley floor of the cycle of erosion and slopes have ripped off rock which is believed to have accelerated the

loosening of rock on the valley shoulder.

Groundwater survey was made towards the end of the survey work after the core drillings were completed. This survey was made with a groundwater level indicator using an electric circuit. The results of this survey are shown on Drawing I-8, I-9 and Table I-1. The results shows that the ground water level is relatively close to the surface and in many cases water is stored in the conglomerate. It appears that there is a considerable fluctuation of water level between the dry and wet seasons. Because of this condition and as seen from the drill cores, it is believed that the conglomerate has been affected by deep seated erosion. Some groundwater were flowing out near a fall 220 m north of the Nam Pung Project Survey Office and at several places on the river bank which has been dissected.

In the riverbed, the bedding has eroded and water is infiltrating and numerous pot-holes were observed.

(iii) Permeability of bedrock

Permeability tests by the water lifting method were conducted in No. 2 drill hole. After the drilling of No. 2 core hole was completed, air was injected to force out water, and at given intervals (30 seconds to 1 minute) the restored water level was measured.

In 90 minutes of observation, the restored water level was 3.75 m. The test section below the groundwater level was 5.3 m and the diameter 3.2 cm. Therefore, the coefficient of permeability is believed to be in the range of 10^{-4} cm/s.

This test was made at one point in a small drill hole. However, the coefficient obtained is a small value for bedrock near the surface. It is believed that very little crack has developed and that the rock is compact. The test point was in the river bed where bedrock is most

stable, and that may be the reason for the small coefficient of permeability compared to the rock in the mountain slope.

(iv) Section of dam foundation

The dam site was selected after studies of several alternative sites. The geologic condition of the entire area is generally the same, and the proposed dam site was selected by mainly taking into account the land form, and the geologic conditions for constructing a dam with the least volume content.

These were:

1. that fresh bedrock is widely exposed on the riverbed and infiltration of river water is not taking place.
2. that loosening of former cycle of erosion and present valley shoulder bedrock is not taking place on an extensive scale.
3. that there is no outflow of groundwater.
4. that river bed has not formed a pool and that there are no deposits of large boulders.
5. that overburden is not heavy and that the bedrock is not loose.

The sites of the spillway and intake were selected after careful considerations of topographic and geologic conditions, in addition to engineering studies.

(4) Geology of the powerhouse site

Geologic surveys and core drillings were made of the proposed powerhouse site and an alternate site which is approximately 400 m downstream of the former.

For the proposed site, 1 hole was drilled at the powerhouse site and 1 hole at the surge tank site (drilling was executed by NEA at the location indicated by the Team), and for the alternative site, 1 hole was drilled at

the surge tank site and 2 holes at the powerhouse site.

The location of these core drillings are shown on the geologic plan (Drawing I-3 and I-4) and the general features on Drawing I-10 and I-11, and the results on Table I-1.

Comparative studies of the geologic conditions of both sites were made from the above mentioned data and geologic section (Drawing I-7).

Drill hole No. 8 reveals that the surge tank location of the alternative site is composed chiefly of conglomerate and sandstone, and deep seated weathering appears to have taken place. The 2 drill holes of the alternative powerhouse site indicate that the rock has been affected by the action of weathering from the surface to elevation 190 m. It was confirmed that clay seam of film exist between elevation 190 to 185 m.

Geologic survey of the alternative site showed that there is a relatively heavy (maximum about 5 m) talus deposit including angular block on the slopes, and that the rock on the shoulder of a former riverbed by cycle of erosion has loosened on an extensive scale.

At the proposed powerhouse site, bedrock in a small area is exposed on the riverbed, and compared with the alternative site, talus deposits on the slopes appear to be thin.

From drill hole No. 8, it was found that the bedrock from the surface to a depth of 7.90 m is sandstone, and that from the surface to a depth of 3.80 m the rock has been affected by weathering and around 3.50 m from the surface cracks were observed in the rock.

At depths over 7.90 m, there are places with concentration of hair cracks. Generally speaking, the rock is good quality siltstone. Core recovery rate at depths over 3.50 m was 100%. Drill hole No. 16 at the surge tank site revealed that, except for weathered conglomeratic rock between 4.6 m and 11.50 m, and badly weathered mudstone between 11.50 m and 12.20 m,

the geology is generally of good quality sandstone.

Comparative studies of both sites revealed that the proposed site is somewhat favorable from a geologic standpoint.

(5) Rock and impervious core material

The proposed sites to quarry rock are near the Nam Pung Streamflow Observation Office which is upstream of the dam site, and east of the Nam Pung Project Survey Office (downstream of dam site) where there is an extensive deposit of sandstone. The rock character of both sites are believed to be similar and core hole No. 10 was drilled near the Streamflow Observation Office.

The drilling was made to a depth of 20 m. Though rock near the surface is weathered, core of fresh sandy rock was recovered. Core specimens of the upper zone of the sandy rock showed a specific gravity of 2.07 (dry) and a water absorption rate of 7.16%. Weathered condition of the deeper zone rock was not as bad as the upper zone, and showed a much higher specific gravity (2.37 to 2.38) and much lower water absorption rate (2.44 to 2.45%).

Soil for core material was investigated by auger boring and test pits. The core material was divided into the following 4 zones by superficial observations. Upon return to Japan, samples of these 4 zones were tested in a laboratory.

No. 1 zone - Gray fine-grained sand (contains roots of vegetation)

No. 2 zone - Yellow or yellowish white fine sand and red lateritic fine sand bearing sandstone debris

No. 3 zone - Silty matrix of sandy soil with patches of completely weathered tinted brown sandstone

No. 4 zone - Clayey loam (including weathered sandstone)

The borrow areas for the impervious core which are zones No. 3 and No. 4 were determined by investigation of distribution with test pits and auger

drilling and at the same time ascertaining the groundwater level.

(6) Conclusion

It is believed that the bedrock of the proposed dam site is generally good. Rock in both slopes of the river bank which were a former valley shoulder are loose on a relatively extensive scale. In the excavation of the foundation for the impervious core zone, loose rock must be removed. In some sections, the existence of cavity has been recognized. In consideration of the fact that deep seated weathering has taken place in the conglomerate and conglomeratic stone and that the groundwater level is relatively high, it will be necessary to carefully execute grouting in the river bed, as well as, both abutments up to elevation 275 m in order to prevent percolation of water in the bedrock after completion of the dam.

It is believed that the foundation rock condition of the powerhouse and surge tank sites are generally good. Adequate care should be taken against fall in and seepage of water in the excavation of the headrace tunnel which will pass through weathered conglomerate deposits that are almost horizontal.

Rock for the dam are found widely distributed in the vicinity of the dam site. From laboratory tests, rock material for the dam are not of extremely hard quality. Therefore, careful attention should be paid in the method of quarrying rock and in the dumping of rock in the dam.

(b) Description of Structures

(1) Dam

Type:	Center core type rock-fill dam
Height:	32 m
Crest length:	1,719 m
Crest width:	14 m
Elevation of dam crest:	EL. 286.5 m
Volume content:	764,000 m ³

BORING	BORING MACHINE	BIT	DIAM. OF BORE HOLE	LOCATION	ELEVATION	DIRECTION OF HOLE	TOTAL DEPTH	DEPTH OF OVER-BURDEN	DRILLED LENGTH
1	SANDER	M C & D.C. *1	36 MM	DAM RIVER BED	254.6 M	90°	30.11 M	0 M	30.11 M
2	'	'	'	'	254.5	'	30.35	0	30.35
3	'	'	'	DAM, RIGHT BANK	267.5	'	20.00	0.70	19.30
4	'	'	'	'	288.5	'	30.23	2.00	28.23
5	'	'	'	'	279.8	'	21.14	0	21.14
6	'	'	'	ALTERNATIVE POWER PLANT	195.5	'	20.00	0.80	19.20
7	'	'	'	'	201.7	'	25.00	2.50	22.50
8	'	'	'	ALTERNATIVE SURGE TANK	289.0	'	20.00	1.80	18.20
9	'	'	'	DAM, LEFT BANK	259.2	'	20.80	0.30	20.50
10	'	'	'	QUARRY	272.8	'	20.02	0.20	19.82
11	'	'	'	DAM, LEFT BANK	276.1	'	20.23	0.50	19.73
12	'	'	'	"	274.6	'	20.00	0	20.00
13 *2	'	M.C	'	ALTERNATIVE SPILLWAY	274.2	'	6.68	3.45	3.23
14 *2	'	'	'	'	278.1	'	6.60	2.94	3.66
15 *2	'	'	'	'	277.5	'	6.74	2.12	4.62
16	'	MC & DC	'	SURGE TANK	281.1	'	28.70	0	28.70
1'	SANDER	DC	36 MM	DAM, LEFT BANK	285	90°	15.00	0	15.00
2'	'	'	'	'	278	'	15.00	3.15	11.85
3'	'	'	'	'	277.5	'	15.10	4.70	10.40
4'	'	'	'	'	270	'	20.00	0.20	19.80
5'	'	'	'	DAM, RIGHT BANK	262	'	25.00	2.35	22.65
6'	'	'	'	'	285	'	25.90	2.95	22.95
7'	'	'	'	INTAKE	267.5	'	15.00	4.97	10.03
8'	'	'	'	POWER PLANT	200	'	20.00	0	20.00
TOTAL				D A M	14	HOLES	308.86		292.01
				O T H E R S	: 10	HOLES	108.74		149.96
				T O T A L	: 24	HOLES	477.60		441.97
AVERAGE				D A M	: 14	HOLES			
				O T H E R S	7	HOLES *3			
				T O T A L	: 21	HOLES *3			

REMARKS ;

- *1, M.C. = METAL CROWN, DC = DIAMOND C
- *2, DRY DRILLING, CORE LIFTING BY ACTION BACUM
- *3, EXCEPT *2 BORINGS
- *4, GWL = GROUND WATER LEVEL MEASUREMENT ON 10TH MAR '62 BY JAP T
- *5, GWL = GROUND WATER LEVEL MEASUREMENT IN JULY - AUG '62 BY NE

BORING	BORING MACHINE	BIT	DIAM. OF BORE HOLE	LOCATION	ELEVATION	DIRECTION OF HOLE	TOTAL DEPTH	DEPTH OF OVER-BURDEN	R		O		C		K		FORMATION TYPE	REMARKS
									DRILLED LENGTH	TOTAL LENGTH OF CORE	CORE RECOVERY	TIME OF DRILLING	DRILLED LENGTH PER HOUR	IM PAR DRILL TIME				
1	SANDER	MC & DC #1	36 MM	DAM RIVER BED	254.6	90°	30.11	0	30.11	21.68	72%	12 - 05	2.48	0 - 24		SANDSTONE WITH MUDSTONE & SHALE.	*4 M GWL EL 250.60	
2	254.5	.	30.35	0	30.35	24.51	81	9 - 35	3.18	19		SANDSTONE WITH CONGLOMERATE & MUDSTONE	EL. 251.11	
3	.	.	.	DAM, RIGHT BANK	267.5	.	20.00	0.70	19.30	7.99	40	6 - 07	3.14	19		SURFACE SOIL & SANDSTONE WITH MUDSTONE	EL 260.60	
4	288.5	.	30.23	2.00	28.23	16.38	54	7 - 55	3.56	17		SURFACE SOIL & SANDSTONE	EL 269.35	
5	279.8	.	21.14	0	21.14	9.23	44	8 - 05	2.64	23		SANDSTONE WITH THIN MUDSTONE LAYERS	EL 266.80	
6	.	.	.	ALTERNATIVE POWER PLANT	195.5	.	20.00	0.80	19.20	10.82	54	7 - 50	2.45	25		SURFACE SOIL, SANDSTONE & MUDSTONE	EL 192.23	
7	201.7	.	25.00	2.50	22.50	13.13	53	12 - 10	1.78	34		.	EL 192.0	
8	.	.	.	ALTERNATIVE SURGE TANK	289.0	.	20.00	1.80	18.20	5.74	31	4 - 40	3.80	16		SANDSTONE	EL. 272.45	
9	.	.	.	DAM, LEFT BANK	259.2	.	20.80	0.30	20.50	12.16	58	6 - 25	3.19	18		.	EL 252.10	
10	.	.	.	QUARRY	272.8	.	20.02	0.20	19.82	18.07	91	6 - 10	3.22	18		SANDSTONE WITH MUDSTONE	EL 265.85	
11	.	.	.	DAM, LEFT BANK	276.1	.	20.23	0.50	19.73	16.62	82	6 - 15	3.15	19		SANDSTONE	EL 268.14	
12	274.6	.	20.00	0	20.00	19.39	97	8 - 15	2.42	25		SANDSTONE WITH MUDSTONE, CONGLOMERATE	EL 261.02	
13 *2	.	M.C	.	ALTERNATIVE SPILLWAY	274.2	.	6.68	3.45	3.23			2 - 31	1.28	47		SURFACE SOIL & SANDSTONE	EL 268.50	
14 *2	278.1	.	6.60	2.94	3.66			1 - 31	2.44	25		.		
15 *2	277.5	.	6.74	2.12	4.62			1 - 54	2.43	25		.	GWL EL 271.63	
16	.	MC & DC	.	SURGE TANK	281.1	.	28.70	0	28.70	17.22	60	8 - 48	3.23	19		SANDSTONE WITH THIN MUDSTONE LAYERS	NO MEASUREMENT	
1'	SANDER	D.C	36 MM	DAM, LEFT BANK	285	90°	15.00	0	15.00	15.00	100	3 - 21	4.48	13		SANDSTONE	GWL *5 EL 282.9	
2'	278	.	15.00	3.15	11.85	11.85	100	4 - 25	2.68	22		SURFACE SOIL, CAVES, SANDSTONE & CLAYSTONE	EL 275.4	
3'	277.5	.	15.10	4.70	10.40	10.27	99	3 - 30	2.97	21		SURFACE SOIL, SANDSTONE & CLAYSTONE	EL. 272.1	
4'	270	.	20.00	0.20	19.80	14.40	73	8 - 12	2.09	29		SANDSTONE, PEBBLY SANDSTONE & CLAYSTONE	EL 263.1	
5'	.	.	.	DAM, RIGHT BANK	262	.	25.00	2.35	22.65	17.10	75	6 - 01	1.98	30		SURFACE SOIL, CAVE, PEBBLY OR CLAY CEMENTED SANDST.	EL 255.9	
6'	285	.	25.90	2.95	22.95	12.17	53	6 - 20	1.07	56		SURFACE SOIL, SANDSTONE, & PEBBLY SANDSTONE	EL 282.8	
7'	.	.	.	INTAKE	267.5	.	15.00	4.97	10.03	6.75	67	4 - 42	3.94	15		SURFACE SOIL, SANDSTONE, & CLAYSTONE	EL 264.2	
8'	.	.	.	POWER PLANT	200	.	20.00	0	20.00	18.52	93	10 - 38	1.93	31		SANDSTONE & CLAYSTONE	EL 297.8	
TOTAL				D A M	: 14	HOLES	308.86		292.01	208.75		96 - 21						
				O T H E R S	: 10	HOLES	108.74		149.96	90.25		60 - 54						
				T O T A L	: 24	HOLES	477.60		441.97	299.00		157 - 15						
AVERAGE				D A M	: 14	HOLES					71		3.03	20				
				O T H E R S	: 7	HOLES *3					65		2.46	24				
				T O T A L	: 21	HOLES *3					69		2.81	21				

REMARKS ;
#1, MC = METAL CROWN, DC = DIAMOND CROWN.
#2, DRY DRILLING, CORE LIFTING BY ACTION OF BACUM.
#3, EXCEPT #2 BORINGS
#4, GWL = GROUND WATER LEVEL MEASURED ON 10TH MAR. '62 BY JAP TEAM
#5, GWL. = GROUND WATER LEVEL MEASURED IN JULY - AUG. '62 BY N.E.A.

TABLE I-1
BORING RESULT

The dam body will comprise of downstream rock zone and filter zone, impervious clay core, and downstream rock zone and filter zone. Stability against sliding, stability of the slopes against drawdown of reservoir and maintenance of the functions of the impervious core are duly taken into consideration in the design of the structure. The section of the bedrock, on which will rest the impervious core, shall be provided with a concrete pat to facilitate foundation grout and prevent percolation of water in the bedrock.

As a result of tests, it is believed that materials for the dam are qualitatively and quantitatively sufficient.

The proposed borrow and quarry sites are as follow:

Rock: mainly sandstone deposits found upstream and downstream of dam site.

Filter: crashed rock quarried from sites upstream and downstream of dam site, and sand near Ban Na (about 12 km southwest of Sakol Nakorn) and Na Kao.

Core: near the dam site and about 2 km from the dam site along a highway between Sakol Nakorn and Kalasin.

Stability calculations of the dam are given in section D (a). (see Drawing I-13 and I-14)

(2) Spillway

Type	overflow type chute spillway with gate controlled section
Width of chute:	20 m
Length of chute:	195 m
Elevation of flood water water level:	EL. 285.5 m
Design capacity:	30 m ³ /s
Gate:	2 sluice gates each 3 m high and 6 m wide

An overflow type chute spillway with gate controlled section is to be built on a saddle in the left bank about 154 m from the abutment. Two sluice gates, each 3.0 m high and 5.0 m wide, are to be installed in the spillway section 30 m long (elevation of overflow crest 284 m). The spillway is designed for a capacity of 300 m³/s at an overflow elevation of 285.5 m with the gates opened. The assumed probable maximum peak flood discharge (1000 years) is 640 m³/s. By surcharging the reservoir 1.5 m above the high water level of 284 m, the peak flood discharge may be reduced to 281 m³/s. Calculation of the spillway discharge capacity is given in section D, (b). (see Drawing I-13, I-15 and I-16)

(3) Outlet

Type:	Pressure conduit
Dimension:	Height - 2.5 m, Width - 2.0 m
Length:	190.0 m
Maximum capacity:	5 m ³ /s
Gate:	1 slide gate, 1 m diameter 1 Howell-Bunger valve, 1 m diameter

A reinforced concrete culvert, 2.5 m high and 2.0 m wide, is to be built in the center of the river channel to divert water during construction. Upon completion of the dam, this culvert will be converted into a permanent outlet by building a valve chamber, near the exit portal, in which will be installed a slide gate (1 m diameter) and a Howell-Bunger valve (1 m diameter) (see Drawing I-13 and I-14)

(4) Intake

Type:	Reinforced concrete tower
Width:	7.0 m
Height:	22.5 m
Gate:	1 roller gate, 2.5 m high and 3.0 wide

The intake structure is to be built near the right bank immediately upstream of the dam. The elevation of the structure will be EL. 286.5 m at the top and EL. 264 m at the foundation. River deposit in front of the intake will be excavated to permit the uninterrupted flow of water. The intake tower and dam will be bridged to permit access.

The center of the intake is EL. 265 m and the intake will connect to a pressure conduit 2.0 m diameter. The maximum intake is 8.5 m³/s. A roller gate, 2.5 m high and 3.0 m wide, will be installed in the intake structure. (see Drawing I-17 and I-18)

(5) Pressure conduit and pressure tunnel

Type:	horseshoe shape
Inside diameter:	2.0 m
Length:	pressure conduit - 439.0 m pressure tunnel - 122.0 m

The intake will connect to a horseshoe shape pressure conduit and a pressure tunnel which will terminate at a surge tank. (see Drawing I-13 and I-17)

(6) Surge tank

Type:	simple surge tank
Inside diameter:	6.0 m
Height:	34.0 m

A simple surge tank of reinforced concrete structure, 6 m inside diameter and 34.0 m high, is to be built at a site 564.0 m from the intake tower. The surge tank will absorb water surge caused by instantaneous fluctuation of loads on the power station. (see Drawing I-17 and I-18)

(7) Penstock

Tunnel section: inside diameter - 2.0 m
length - 242.0 m

Steel penstock: inside diameter 2.0 m tapering down to 1.5 m
from where it will bifurcate into 3 pipes that
will taper down to 0.8 m at the turbine inlet.

Length: 170.7 m

A section (39 m) of the penstock tunnel of reinforced concrete structure will be lined with welded steel plates and the lower section of the penstock will be of high tension welded steel pipes.

The penstock tunnel of reinforced concrete structure will adjoin the surge tank and 39.0 m of the tunnel will be lined with welded steel plates. The lower section will be welded high tension steel pipes.

The steel penstock will connect to the tunnel section which will be lined with steel plates. The steel penstock, 2 m inside diameter, will taper down to 1.5 m from where it will bifurcate into 3 pipes and connect to butterfly valves to be installed at the turbine inlet. (see Drawing I-13 and I-19)

(8) Power plant

Powerhouse: Width - 11.8 m
Length - 27.8 m

Switchyard: Width - 17.0 m
Length - 40.0 m

Equipment: Turbines - horizontal shaft, single runner, single
discharge, spiral type Francis turbines

Number of units - 3

Capacity - 1,900 kW per unit

Revolutions - 750 r.p.m.

Generators:

Type - Horizontal shaft, rotating-field, enclosed ventilated type, 3-phase synchronous generator

Number of units - 3

Frequency - 50 cycles

Capacity - 2,200 kVA per unit

Voltage - 3.3 kV

Revolutions - 750 r.p.m.

Power factor - 0.82 (lag)

Transformer:

Type - Outdoor, single-phase, oil immersed, self cooling type

Number of units - 3

Capacity - 2,200 kVA

Primary voltage - 3.3 kV

Secondary voltage - 66 kV

Frequency - 50 cycles

The powerhouse will have 3 sets of turbine-generator which will produce 5,400 kW (maximum). The output of the powerhouse will be stepped-up to 66 kV at an outdoor sub-station to be built on the hillside downstream of the powerhouse (EL. 207 m) and transmitted to Sakol Nakorn.

The turbines and generators will be of horizontal shaft and a valve will be installed at the turbine inlet. The draft tube will be "L" shaped and a gate will be installed at the outlet. For emergency use a 30 kVA diesel electric unit will be installed in the powerhouse.

At the outdoor sub-station will be installed necessary switching apparatus in addition to transformers. To protect the equipment from lightning shock, a lightning arrester, as well as, an overhead groundwire installed on the top of the outdoor steel structure shall be provided.

To haul the powerhouse equipment, an incline will be installed from a point downstream of the powerhouse (EL. 255 m) to the powerhouse machine floor (EL. 193.55 m) via the outdoor switchyard. (see Drawing I-19, I-20, I-21, I-22, I-23 and I-25)

(9) Sub-stations

The installations of step-down sub-stations on completion of the project will be as follow:

	<u>Sakol Nakorn</u>	<u>That Phanom</u>	<u>Mukdahan, Nakhon Phanom, Nam Pung Bridge</u>	<u>Na Kae</u>
Capacity	2,400 kVA	690 kVA	1,200 kVA	50 kVA
Transformers	Outdoor, oil Single phase	immersed self Single phase	cooling type Single phase	3 phase
Capacity	400 kVA	400 kVA	400 kVA	50 kVA
Primary voltage	66,000 V	66,000 V	66,000 V	66,000 V
Secondary voltage	6,600 V	6,600 V	6,600 V	6,600
Frequency	50 cycles	50 cycles	50 cycles	50 cycles
Number of banks	2	1	1	1
Number of units (normal use)	6	2	3	1
Spare unit	-	1	-	-
Number of circuits				
Transmission line	2	3	1	1
Distribution line	3	1	2	1

The output of the powerhouse stepped-up to 66 kV and transmitted to Sakol Nakorn, Nam Pung Bridge, Na Kae, That Phanom, Mukdahan and Nakorn Phanom sub-station (total capacity 6,850 kVA) will be stepped-down to 6.6 kV before distribution to consumers.

Except for Na Kae where demand is small, the other sub-stations will have 400 kVA single phase transformers in consideration of load growth and

interchangeability of equipment between the sub-stations. Wiring will be delta-delta to enable operation by V-V connection in case of outage of one phase. Consequently, one spare unit will be provided for common use for all the sub-stations. If necessary, operation may be possible by V-V connection, and corresponding with load growth additional units may be installed by delta-delta connection.

As a protective device for the transformer, a power fuse instead of an circuit breaker, will be installed on the high voltage side.

In addition to a lightning arrester, an overhead groundwire will be installed on the top of the outdoor steel structure to protect the sub-station equipment from lightning damages.

(10) Transmission line

	<u>Length</u>
Nam Pung Power Plant to Sakol Nakorn Sub-station	31 km
Sakol Nakorn Sub-station to Nam Pung Bridge Sub-station	18 km
Nam Pung Bridge Sub-station to Na Kae Sub-station	30 km
Na Kae Sub-station to That Phanom Sub-station	21 km
That Phanom Sub-station to Nakorn Phanom Sub-station	52 km
That Phanom Sub-station to Mukdahan Sub-station	48 km
Total approximately	200 km

The transmission lines will interconnect the aforementioned sub-stations to supply electricity to general consumers in the respective areas and to irrigation pumps.

The estimated loads of the respective areas are given in Chapter II, D, Fig. III-14 of the Report. The estimates show that in 10 years (1975) the peak load on the system will be about 5,700 kW. Consequently, the transmission system must be able to meet the estimated load conditions. Taking in

account transmission capacity, voltage regulation and transmission losses, it has been concluded that the most economical voltage is 66 kV (rated voltage 60 kV, maximum circuit voltage 69 kV) in one circuit of 58 mm² ACSR conductor. At this voltage, the estimated transmission loss in 1975 is 5.5% during peak loads and the voltage drop at Nakorn Phanom Sub-station is about 8.4%. (see Section D (c))

Non-ground neutral system has been adopted for the 66 kV system and insulation designs were made on this basis. This is the standard design method practiced in Japan.

The design has been based on the following conditions.

(i) Insulation design

Assuming a Feranty effect of 1.05, coefficient of critical impulse to switching surge of 1.10 and crest factor of 1.414 at an abnormal voltage 4 times in case of switching surge and 1.82 times in case of line fault surge of the earth potential, the abnormal voltage which will be created in the system will be 6.53 times in case of switching surge and 1.91 times in case of line fault surge of the earth potential. And, the coefficients of insulation drop are 1.10 for the ratio of 50% flashover voltage vs non-flashover voltage, 1.00 for the coefficient of insulation drop influenced by supports, and 1.10 for the coefficient of insulation drop influenced by altitude (1.10 times the inverse of relative atmospheric density).

Based on these criteria, the number of insulator discs, the minimum insulation spacing, the standard insulation spacing and the spacing between jumper and cross arm were determined as shown below.

Type of insulator:	Ball socket, NEMA type B outside diameter - 254 mm height - 146 mm
Number of discs:	4

Strength of complete set:	5,450 kg.
Minimum insulation spacing:	400 mm
Standard insulation spacing:	650 mm
Jumper spacing:	800 mm

The design of the insulator swing angle is 40° of the minimum insulation spacing and up to 30° of the standard insulation spacing.

(ii) Atmospheric condition

The following atmospheric conditions were assumed from atmospheric data of the area and the method adopted in Thailand.

That is, maximum, mean and minimum temperatures of 60° , 30° and 0° C, respectively, and maximum wind velocity of 25 m/s, mean wind pressure of 40 kg/m^2 and wind pressure on wooden pole of 32 kg/m^2 were assumed.

(iii) Conductor and support

Based on the above atmospheric conditions, the assumed worst condition on the conductor was taken as, in respect of temperature 15° C and wind pressure 40 kg/m^2 . And, for the conductor sag, a most logical span distance and maximum horizontal tension were determined from the strength and length of supports to be used, taking into account the required clearance to ground and every day stress. As stated in the preceding paragraph, wind loads are comparatively small in the area. Based on various studies, the maximum horizontal tension of conductor was taken as 600 kg and the ruling span 150 m.

With respect to line supports, it will be most economical to use wooden poles which can be obtained in Thailand. Four types of supports have been designed. These are: A type (suspension, triangular alignment, deviation angle up to 3°), B type (tension, horizontal alignment,

H poles, deviation angle up to 15°), C type (tension, horizontal alignment, H pole, deviation angle up to 30°), and D type (H pole for dead end). Special types of supports have been separately designed. Type B, C and D poles will be secured with stay wires if necessary. (see Drawing I-29)

Wooden poles will be treated and the assumed bending strength is 310 kg/cm². If wooden poles, such as, rang deng which have great bending strength and which may be used untreated, can be obtained locally, the B type support may be of single pole design for economic purposes. For cross arms, untreated square timber of high bending strength is believed to be adequate.

Clearance to ground of conductors is over 6 m which is the value adopted in Japan. In consideration of the route of the transmission line which crosses hills, forest, paddy fields and upland fields in the rural districts, this clearance is believed to be sufficient. For this clearance the required length of wooden poles will be 12 to 14 m.

The tension and sag of conductors for various temperatures calculated on the above design conditions are given below.

Conductor	58 mm ² , ACSR (aluminum 6/3.5 mm) (steel 1/3.5 mm)
Maximum horizontal tension	600 kg
Safety factor	3.3

	<u>Min. temperature</u>	<u>Mean temperature</u>	<u>Max. temperature</u>
Tension (kg)	525	343	248
Sag (m)	1.25	1.91	2.64
Every day stress (%)		17.3	

The specification of the conductor is as follows:

Conductor	58 mm ² ACSR (aluminum 6/3.5 mm) (steel 1/3.5 mm)
-----------	---

Calculated area (mm ²)	67.35 (aluminum 57.73, steel 9.621)
Diameter (mm)	10.5
Standard weight (kg/km)	233.1
Minimum breaking strength (kg)	1,980
Calculated resistance (Ω /kg)	0.593 (20°C)
Standard spacing (mm)	690
Minimum spacing (mm)	400

Supports - treated wooden poles

Type: Suspension - single pole, A type, deviation angle 3°

Tension - H pole, B, C, D type

deviation angle type B - 15°

" " type C - 30°

" " type D - dead end

Length of poles: 12 to 14 m

As vibration prevention, performed armour rod will be attached at the suspension point. (see Drawing I-1 and I-29)

(11) Communication system

The following communication circuits are to be provided for the operation and maintenance of the powerhouse and sub-stations, as well as, for load dispatching. This communication system in consideration of reliability and economy will consist of power line carrier telephone and VHF wireless telephone.

Communication between Nam Pung powerhouse and Sakol Nakorn will be by power line carrier telephone, and between Sakol Nakorn sub-station and sub-stations to its east will be by VHF telephone in consideration of the several branches in the transmission line. Economies have been made by the common utilization of the line maintenance base station at That Phanom sub-

station for telephone communication between That Phanom and Nakorn Phanom sub-station, and between That Phanom and Mukdahan sub-stations.

- (i) Power line carrier telephone between Nam Pung Power Station and Sakol Nakorn sub-station, duplex circuit - 1 circuit
- (ii) VHF wireless communication between Sakol Nakorn and That Phanom sub-stations, 150 MC or 60 MC band, duplex circuit - 1 circuit
- (iii) Communication between That Phanom sub-station, Nakorn Phanom sub-station, Mukdahan sub-station and line maintenance mobile station (jeep) will be by 1 circuit of simplex VHF telephone (150 MC band) from the base station at That Phanom sub-station.
- (iv) The VHF system described in (ii) and (iii) will be utilized for communication between Sakol Nakorn sub-station and Nakorn Phanom and Mukdahan sub-stations which will be by call through automatic repeating at That Phanom sub-station (base station).

Communication equipment will not be installed in Nam Pung Bridge and Na Kae sub-stations. Communication with That Phanom sub-station will be from a mobile station (jeep) that will visit the two sub-stations during line inspections. In this system Nam Pung Bridge sub-station and vicinity will be outside the range of communication with That Phanom base station. Therefore, a VHF antenna (20 m above ground level) will be installed at Nam Pung Bridge sub-station and communication between the sub-station and That Phanom sub-station will be made by connecting the mobile station to the antenna. Emergency power generating units for the communication system will be installed in Nam Pung Power Plant and Sakol Nakorn, That Phanom, Nakorn Phanom and Mukdahan sub-stations to maintain communication in the case of power failure or outage. (see Drawing I-30)

D. COMPUTATIONS

(a) Stability Calculations of Dam

(1) Design conditions

Computed Values of Dam Materials

Materials	Symbol	Unit weight T/m ³			Internal friction coefficient	Adhesive strength T/m ³	
		Dry	Wet	Saturated		Dry	Saturated
Core	1	1.6	1.9	2.0	0.4	8.0	2.0
Filter	2	1.8	1.9	2.1	0.5	0	0
Rock	3	1.75	1.8	2.0	0.65	0	0

Symbols:

h :	Water depth from high water level to arbitrary point	(m)
d :	Depth of sedimentary deposit from surface of deposit to arbitrary point	(m)
h_1 :	Depth from dam slope to arbitrary point above slip circle	(m)
W ₀ :	Unit weight of water	(T/m ³)
W _d :	Unit weight of sediment in water	(T/m ³)
C _s :	Coefficient of sedimentary pressure	(0.6)
K _a :	Rankin's coefficient of earth pressure	(principle dynamic coefficient of soil pressure)
r_3 :	Unit weight of rock	(T/m ³)
P _w :	Static pressure	(T)
P _s :	Sedimentary pressure	(T)
P _u :	Pore water pressure	(T)
P _d :	Earth pressure	(T)
W :	Vertical load	(T)
N :	Vertical load action on sliding slope	(T)

U : Up lift pressure (T)

Un: Pore water pressure acting vertically on slip circle (T)

T : Pore water pressure acting in the direction of slip circle (T)

$\tan\phi$: Internal friction coefficient of dam material

(2) Stability calculations against sliding of dam body

(i) Computations of slip circle at river bed line of standard section of dam (unit in per meter of width)

(ii) External force

1. Static pressure

$$P_w = 1/2 W_o (h + h_w)^2 = 1/2 \times 1.0 (3.2 + 0.5)^2 = 528.1 \text{ Tons}$$

2. Sedimentary pressure

$$P_s = 1/2 C_s W_d d^2 = 1/2 \times 0.6 \times 1.2 \times 13^2 = 60.8 \text{ Tons}$$

3. Pore water pressure (from line of flow diagram)

$$P_u = 256.4 \text{ Tons}$$

4. Earth pressure on impervious core

$$P_d = 1/2 K_a r_3 h_1^2 = 1/2 \times 0.3 \times 1.0 \times 34.5^2 = 178.5 \text{ Tons}$$

5. Dead load

	Material	Unit weight (T/m ³)	Area (m ²)	W (T)	$\tan\phi$	W x $\tan\phi$ (T)	Remarks
	2	1.1	65.5	72.1			
A	1	2.0	313.3	626.6			Top of im-
		1.9	59.5	113.1	0.4	324.7	pervious core
B	2	1.9	96.8	183.9			
	3	1.8	74.4	133.9	0.5	158.9	Top of filter
C	3	1.8	995.2	1791.4	0.65	1164.4	Top of rock
						1648.0	

(3) Stability studies against sliding of dam

	External force	Standard section
Horizontal load	Static pressure	528.1 Tons
	Sedimentary pressure	60.8
	Earth pressure	178.5
	Total	767.4
Vertical load	Pore water pressure	256.4
	Dead load	1,648.0
	Total	1,391.6
Safety factor		1.81

From the above studies, it is found that the dam is stable against sliding (see Fig. I-1)

(4) Stability calculation of slopes

Stability calculations of the slopes were made for the following conditions:

1. Critical slip circle when reservoir is full (upstream force)
2. Critical slip circle at rapid drawdown of reservoir (upstream force) (see Fig. I-2)
3. Critical slip circle at time of completion of dam (upstream force)
4. Critical slip circle when reservoir is full (downstream face) (see Fig. I-3)
5. Critical slip circle at time of completion of dam (downstream face)


Safety factor $\frac{\text{Friction and cohesive strength acting against sliding}}{\text{Driving force of sliding}} =$

$$\frac{(\sum N - \sum V_n) \tan \phi + \sum C}{\sum T}$$

Classification		Safety factor
Upstream face	At full water	1.62
	At rapid drawdown	1.81
	At completion of dam	1.83
Downstream face	At full water	1.36
	At completion of dam	1.48

From the above studies, it has been found that the dam is stable against the actions of sliding.

(b) Calculation of Flood Discharge through Spillway



(1) Calculations made at a maximum flood water level of EL. 285.5 m.

(2) Symbols

Q_g : Discharge through gates open full	m^3/s
Q_d : Discharge over spillway weir	m^3/s
q : Discharge over spillway weir in per unit of width	m^3/s
L : Elevation of spillway weir crest	30 m
B : Width of gate	5 m
C : Coefficient of run-off	
H : Overflow depth	m







FIG. I - I

DAM STANDARD SECTION



NORMAL COMPONENTS

TANGENTIAL COMPONENTS



PORE PRESSURE






FIG. I - 2


DIAGRAM OF DRIVING FORCES
CRITICAL SLIP CIRCLE FOR RAPID
DRAW DOWN CONDITION



NORMAL COMPONENTS


TANGENTIAL COMPONENTS

HEIGHT
LENGTH (m)



⊕
↑
⊖
↓

HEIGHT
LENGTH (m)



⊕
↑
⊖
↓




FIG. I - 3
DIAGRAM OF DRIVING FORCES
CRITICAL SLIP CIRCLE OF DOWNSTREAM
SLOPE FOR STEADY STATE CONDITION

(3) Calculation of volume of overflow

$$Q_g: CBH^{3/2} = 190.92 \text{ m}^3/\text{s}, \text{ where } H = 4.5 \text{ m}$$

$$q : CH^{3/2} = 3.67 \text{ m}^3/\text{s}, \text{ where } H = 1.5 \text{ m}$$

$$Q_d: qL = 110.1 \text{ m}^3/\text{s}$$

$$Q_g + Q_d = 301.02 \text{ m}^3/\text{s} > 281 \text{ m}^3/\text{s}$$

(c) Determination of Powerhouse Discharge

Determination of the powerhouse discharge is described in detail in Chapter III, D. Hydro-electric Power Development Scheme of the Report.

Therefore, a summary only will be given here.

From the annual inflow at the dam site which were estimated for the 10 years of 1952 to 1961 (refer to Chapter III, D of the Report) a mass curve was drawn, and in order to obtain the greatest possible discharge for power generation, the regulated flow for each year was computed by regulating flow in a reservoir with an effective storage capacity of 106,000,000 m³ (the effective storage capacity of the Nam Pung reservoir is 122,000,000 m³ including a storage of 16,000,000 m³ to generate power for the operation of irrigation pumps in dry seasons). From this regulated flow were deducted annual evaporation losses corresponding to the fluctuation of reservoir water level to arrive at the available discharge. And, the annual energy output computed from the annual average reservoir water level is shown in the table which follows.

Year	Annual inflow in m ³ /s	Regulated flow in m ³ /s	Available flow in m ³ /s	Average effective head in m	Average output in kW	Annual output in MWh
1952	4.45	4.68	4.32	82.48	2,890	25,400
1953	5.51	5.00	4.54	84.36	3,100	27,150
1954	3.21	3.29	2.91	83.63	1,970	17,250

Year	Annual inflow in m ³ /s	Regulated flow in m ³ /s	Available flow in m ³ /s	Average effective head in m	Average output in kW	Annual output in MWh
1955	2.01	3.30	2.97	82.62	1,985	17,400
1956	4.33	3.26	2.97	81.42	1,965	17,200
1957	2.38	2.98	<u>2.62</u>	83.20	<u>1,765</u>	<u>15,450</u>
1958	2.76	2.98	2.66	82.08	1,768	15,500
1959	2.35	2.98	2.73	80.68	1,785	15,640
1960	2.46	2.98	2.77	79.57	1,786	15,700
1961	4.66	3.17	2.85	81.87	1,880	16,450
Average	3.51	3.46	3.13	-	2,090	18,300

It will be noted from the foregoing table that the firm available energy is 15,450,000 kWh and the corresponding average output is 1,765 kW. Therefore, the firm output was taken at 1,750 kW. And, the average available flow of 2.62 m³/s was taken as the firm powerhouse discharge.

In determining the maximum discharge of the powerhouse, it was assumed that the annual load factor of general demands is about 30% and that the annual load factor of irrigation pump demands is also about 30%. Therefore, the maximum discharge was determined as 8.5 m³/s in order to generate 5,400 kW at the rated head and 4,500 kW at minimum water level.

(d) Calculation of Head Losses and Powerhouse Output

(1) Symbols

Head losses and powerhouse output calculated on a maximum discharge of $Q = 8.5 \text{ m}^3/\text{s}$ are as follows:

The symbols used in the calculations which are based on the formula given in the Theoretical Hydraulic formula published by the Japan Society of Civil Engineers are as follows:

h: head loss (m)

v: velocity in waterway m/s = Q/A

Q: volume of flow m³/s

A: cross-section area of flow m²

f: coefficient of loss

g: acceleration by gravity 9.8 m/s²

n: coefficient of coarseness concrete face 0.014

steel pipe face 0.012

P: wet perimeter m

R: hydraulic radius m

L: length of pipe m

θ: bend in pipe degree

P: theoretical water power kW

H: effective head m

E: output kW

γ_t: efficiency of turbine

γ_g: efficiency of generator

(2) Calculation of head losses

(i) Head loss by trash track

$$h_r' = \beta \sin \theta \left(\frac{t}{b}\right)^{4/3} \cdot \frac{u_1^2}{2g} = 0.0009 \text{ m,}$$

$$\text{where } \beta \sin \theta \left(\frac{t}{b}\right)^{4/3} = 0.0975$$

(ii) Head loss at intake (inside intake)

$$h_i = (1 + f_i) \cdot \frac{v^2}{2g} = 0.0111 \text{ m, where } f_i = 0.2$$

- (iii) Head loss at connection of intake and headrace (intake and culvert)

$$h_e' = f_i \cdot \frac{v_2^2}{2g} + \frac{v_2^2 - v_1^2}{2g} = 0.4389 \text{ m, where } f_i = 0.2$$

- (iv) Head loss by friction (culvert and tunnel) $n = 0.014$

$$h_{ft} = f \cdot L \cdot \frac{v^2}{2g} = \frac{122h^2}{\frac{4}{D^3}} \cdot L \cdot \frac{v^2}{2g} = 2.6927 \text{ m}$$

- (v) Head loss by friction (steel penstock) $n = 0.012$

$$\sum h_{fp} = f \cdot L \cdot \frac{v^2}{2g} = \frac{124.5 n^2}{\frac{4}{D^3}} \cdot L \cdot \frac{v^2}{2g} = 1.7387 \text{ m}$$

- (vi) Head loss in bend

$$\sum h_c = f_{b\theta} \cdot \frac{v^2}{2g} = 0.131 \cdot \frac{\theta}{180} \cdot \frac{v^2}{2g} = 0.2515 \text{ m}$$

- (vii) Head loss by tapering down of cross section area

(steel penstock) $n = 0.012$

$$\sum h_g = f_c \cdot \frac{v_2^2 - v_1^2}{2g} = 0.1686 \text{ m,}$$

$$\text{where, } f_c = \frac{0.025}{8 \sin \frac{\theta}{2}} = 0.000365$$

- (viii) Head loss by bifurcation

$$h_n = f_n \cdot \frac{v_1^2}{2g} = 1.534 \text{ m, where, } f_n = 1.3$$

- (ix) Surge tank, butterfly valve and other losses and margin

$$h_n = 0.8636$$

- (x) Total head losses

$$\begin{aligned} \sum h &= h_r' + h_i + h_e' + h_{ft} + h_{fp} + h_c + h_g + h_n = 0.0009 + 0.0111 \\ &0.4389 + 2.6927 + 1.7387 + 0.2515 + 0.1686 + 1.534 + 0.8636 = \\ &7.7 \text{ m} \end{aligned}$$

(3) Calculation of effective head

Reservoir water level at rated output	EL. 279.30 m
Tailrace elevation at maximum discharge	EL. 193.10 m
Head loss at maximum discharge	7.70 m
Effective head at maximum discharge	
= 279.30 - 193.10 - 7.70	78.50 m

(4) Calculation of theoretical water power and theoretical horse power

(i) Theoretical water power

$$P = 9.8 \cdot Q \cdot H = 6.539 \text{ kW}$$

where, H is the effective head at basic water level - 78.5 m

(ii) Theoretical horse power

$$HP = \frac{1000 QH}{75} = 13.33 QH = 8,894 \text{ HP}$$

(iii) Output

$$E = P \cdot \eta_T \cdot \eta_G = 5,400 \text{ kW,}$$


where, $\eta_T = 0.87$

$$\eta_G = 0.95$$

(e) Calculation of Transmission Losses

The estimated transmission losses of the Nam Pung power system are as follows:

Powerhouse



For simplicity of calculation, the instantaneous voltage (V) of the respective loads are assumed to be the same and the angles of phase difference of current in the respective sections were disregarded.

The respective load currents for 1 phase are as follows:

$$I_1 = P_1/V \cdot \cos \phi_1$$

$$I_2 = P_2/V \cdot \cos \phi_2$$

$$\vdots \quad \quad \quad \vdots$$

$$I_n = P_n/V \cos \phi_n$$

The total transmission losses are the sum of the losses of the respective line sections,

Therefore, $P_{\ell n} = 3 I_n^2 R_n$

$$P_{\ell n-1} = 3 (I_n + I_{n-1})^2 R_{n-1}$$

$$\vdots$$

$$P_{\ell 2} = 3 (I_n + I_{n-1} + \dots + I_2)^2 R_2$$

$$P_{\ell 1} = 3 (I_n + I_{n-1} + \dots + I_2 + I_1)^2 R_1$$

The total transmission losses P_{ℓ} (kWh) is

$$P_{\ell} + P_{\ell 1} + P_{\ell 2} + \dots + P_{\ell n-1} + P_{\ell n}$$

The total load capacity P (kW) is

$$P = P_1 \cos \phi_1 + P_2 \cos \phi_2 + \dots + P_n \cos \phi_n$$

Hence, the transmission loss Σ (%) is

$$= \frac{P_{\ell}}{P} \times 100$$

where: P_1, P_2, P_n , is size of load (kVA)

$\cos \phi_1, \cos \phi_2, \dots, \cos \phi_n$ are power factors of respective loads

$\ell_1, \ell_2, \dots, \ell_n$ are distance between points of loads (km)

R_1, R_2, \dots, R_n are the resistance of conductors (Ω) of line section $\ell_1, \ell_2, \dots, \ell_n$

V is instantaneous voltage at points of load (kV)

I_1, I_2, \dots, I_n are the load currents (A)

The transmission losses of the Nam Pung system under maximum loads for the 5 years between 1965 and 1975 calculated with the above formula are shown in the table which follows:

Year	Maximum load (kW)	Power loss (kW)	Rate of loss (%)
1965	1,430	23	1.6
1967	2,530	66	2.6
1968	3,000	87	2.9
1970	4,450	211	4.7
1975	5,670	316	5.5

E. ESTIMATED CONSTRUCTION COSTS

(a) Estimated Construction Costs

The estimated construction costs of Nam Pung Hydro-electric Development Project are summarized in the following table. The rates of conversion used in the costs estimates are 20.75 Bahts = 1 US\$ = 360 yen.

Total Construction Costs of Nam Pung Power Project

Classification	Total costs in US\$	Foreign currency requirements in US\$	Local currency requirements in Bahts
Civil Works	4,419,330	2,169,949	46,675,850
Dam	3,142,360	1,526,723	33,525,260
Waterways	1,276,970	643,226	13,150,590
Electrical Works	2,110,410	1,613,491	10,311,030
Powerhouse	1,254,990	1,143,104	2,321,440
Transmission line	855,420	470,387	7,989,590
Total	6,529,740*	3,783,440	56,986,880

Note: * Interest during construction is not included in the total costs.

In the following pages are given the details of the estimated costs.

Table I-2

Nam Pung Hydro-electric Project Details of Construction
Cost Estimates based on Preliminary Designs

Description	Unit Quantity	Total Costs		Remarks
		Foreign Currency US\$	Local Currency Baht	
<u>Civil Engineering Works</u>		<u>1,878,251</u>	<u>35,874,700</u>	
<u>Direct cost</u>	LS	<u>647,244</u>	<u>26,373,940</u>	
Dam	"	424,113	18,058,780	
Spillway	"	19,967	1,031,830	
Intake	"	33,312	720,910	
Pressure conduit	"	28,518	1,512,020	
Pressure tunnel	"	4,096	451,040	
Surge tank	"	5,018	322,400	
Penstock	"	62,422	1,217,830	
Power plant and substation	"	59,841	2,735,450	
Tailrace	"	9,957	323,680	
<u>Engineering fees</u>	LS	<u>125,790</u>	<u>409,000</u>	
<u>Temporary equipment</u>	LS	<u>31,557</u>	<u>2,619,000</u>	
<u>Penstock of machines and equipment</u>	LS	<u>635,620</u>	<u>1,749,000</u>	
<u>General expenses</u>	LS	<u>265,070</u>	<u>1,527,000</u>	
<u>Contingencies</u>	LS	<u>172,970</u>	<u>3,196,760</u>	

Description	Unit Quantity	Total Costs		Remarks
		Foreign Currency US\$	Local Currency Baht	
<u>Electrical Works</u>		<u>1,446,824</u>	<u>9,919,100</u>	
<u>Power plant</u>		<u>614,722</u>	<u>731,990</u>	
Water turbines	3	214,722	109,510	1,900 kW
Generators	3	148,889	80,690	2,200 kVA
Transformers	3	41,389	23,060	2,200 kVA/P
Switch board and others		128,889	95,100	
Outdoor structure		3,611	8,640	
Miscellaneous machines		41,389	63,400	
Miscellaneous equip- ment		8,611	109,510	
Fixtures		5,556	57,640	
Temporary equipment		13,333	40,350	
Installation of equipment		833	40,350	
Transportation costs		7,500	103,740	
<u>Sub-stations</u>		<u>420,081</u>	<u>1,550,450</u>	
Sakol Nakorn	400 x 6	125,338	432,280	
That Phanom	400 x 3	115,050	403,460	
Nakorn Phanom	400 x 3	53,671	213,260	
Mukdahan	400 x 3	53,671	213,260	
Nam Pung Bridge	400 x 3	53,671	213,260	
Na Kae	50 x 1	18,671	74,930	
<u>Transmission line (Nam Pung to Sakol Nakorn)</u>		<u>412,020</u>	<u>7,636,660</u>	
<u>Materials</u>		<u>192,864</u>	<u>3,434,160</u>	

Description	Unit Quantity	Total Costs		Remarks
		Foreign Currency US\$	Local Currency Baht	
Conductors		82,340		
Attachments of conductor		21,780		
Insulator		64,840		
Treated wooden poles and cross arm		940	3,283,770	
Attachments for poles		11,860	150,390	
Fixture		11,100		
<u>Transportation costs</u>			<u>1,875,570</u>	
<u>Bidding costs</u>		<u>145,640</u>	<u>1,886,450</u>	
Direct costs		65,920	955,010	
Temporary equipment costs			593,100	
Rentals of machinery and equipment		9,220		
General expense		70,500	338,340	
<u>Contingencies</u>		<u>20,720</u>	<u>440,480</u>	
<u>Communication system</u>		<u>52,800</u>		
<u>Overhead costs</u>		<u>458,365</u>	<u>11,193,080</u>	
<u>Administrative expenses</u>		<u>416,665</u>		
Detail surveys				
Detail designs & specifications		100,553		
Supervision fee		316,112		

Description	Unit Quantity	Total Costs		Remarks
		Foreign Currency US\$	Local Currency Baht	
Thai Government				
<u>Administrative expenses</u>		41,700	11,193,080	
Detail survey works			876,080	
Access roads			1,613,830	
Diesel generator		41,700	57,640	
Right-of-way costs			8,645,530	
<u>Total</u>		<u>3,783,440</u>	<u>56,986,880</u>	

\$6,529,740

Table I-3

Breakdown of Direct Costs of
Nam Pung Hydro-electric Project

Item	Unit	Quantity	Total Price		Remarks
			Foreign Currency US\$	Local Currency Baht	
<u>Dam</u>					
Excavation: dam foundation	m ³	105,500	14,665	912,050	
Excavation: river diversion	"	3,200	2,666	73,770	
Reinforced concrete for diversion work	"	1,100	1,528	614,980	
Concrete for plugging diversion work	"	130	181	67,430	
Upperstream rock embankment (quarried rock)	"	245,700	68,305	2,832,180	
Upperstream rock embankment (excavated rock)	"	15,500		89,330	
Downstream rock embankment	"	248,000	68,944	3,144,640	
Impervious clay core embankment	"	113,000	15,707	1,953,880	
Filter embankment (sand)	"	50,000	41,650	2,881,500	Crashed
" " (crashed rock)	"	91,500	25,437	1,054,720	rock
Fabrication and placing of reinforcing steel bar	t	60	10,020	17,290	
Coffer-dam	LS	1		230,550	
Outlet including one slide gate and one Howell-Bunger valve	LS	1	36,110	57,640	
Grout, dam foundation	"	1	138,900	3,919,300	
Others				209,520	
Sub Total			424,113	18,058,780	

Item	Unit	Quantity	Total Price		Remarks
			Foreign Currency US\$	Local Currency Baht	
<u>Spillway</u>					
Excavation, all classes	m ³	11,000	3,058	190,200	
Rock embankment	"	960	267	13,830	
Filter embankment	"	90	75	5,190	
Earth embankment	"	150	21	2,590	
Backfill	"	120		1,040	
Reinforced concrete	"	310	431	160,800	
Fabrication and placing of reinforcing steel bar	t	10	1,670	2,880	
Concrete	m ³	1,200	1,667	574,070	
Sluice gate, size 3m x 6m 2 gates, total weight 21 tons	LS	1	12,778	37,460	
Others	LS	1		43,770	
Sub Total			19,967	1,031,830	
<u>Intake</u>					
Excavation, all classes	m ³	5,900	1,310	74,810	
Reinforced concrete	"	600	833	328,530	
Fabrication and placing of reinforcing steel bar	t	12	2,004	3,460	
Screen, size 5m x 5m, 4 screens, total weight 18 tons	"	1	6,944	11,530	
Roller gate, size 2.5m x 3m, 1 gate, total weight 13 tons	"	1	9,722	23,050	
Bridge	LS	1	11,110	172,910	
Stoplog	"	1	1,389	86,460	

Item	Unit	Quantity	Total Price		Remarks
			Foreign Currency US\$	Local Currency Baht	
Others	LS	1		20,160	
Sub Total			33,312	720,910	
<u>Pressure Conduit</u>					
Excavation, all classes	m ³	9,000	5,004	155,620	
Reinforced concrete	m ³	2,300	3,195	1,285,880	
Fabrication and placing of reinforcing steel bar	t	117	19,539	33,720	
Fabrication and installa- tion of steel plates	"	4	780	3,460	
Backfill	m ³	3,000		25,930	
Others	LS	1		7,410	
Sub Total			28,518	1,512,020	
<u>Pressure Tunnel</u>					
Excavation, tunnel	m ³	760	1,267	105,130	
Reinforced concrete lining	"	370	514	206,850	
Fabrication and placing of reinforcing steel bar	t	8	1,335	2,300	
Excavation, adit, open cut	m ³	150	41	3,460	
Excavation, adit, tunnel	"	230	383	31,810	
Concrete plug	"	100	139	51,870	
Grouting	LS	1	417	37,460	
Others	LS	1		12,160	
Sub Total			4,096	451,040	
<u>Surge Tank</u>					
Excavation, rock	m ³	1,300	1,805	149,850	

Item	Unit	Quantity	Total Price		Remarks
			Foreign Currency US\$	Local Currency Baht	
Reinforced concrete	m ³	250	347	122,480	
Fabrication and placing of reinforcing steel bar	t	13	2,171	3,750	
Steel scaffold and ladder	LS	1	556	2,880	
Grouting	"	1	139	14,410	
Others	"	1		29,030	
Sub Total			5,018	322,400	
<u>Penstock</u>					
Excavation, all classes	m ³	3,200	1,334	55,330	
Excavation, tunnel	"	1,670	2,784	231,010	
Reinforced concrete lining	"	735	1,021	410,920	
Fabrication and placing of reinforcing steel bar	t	17	2,839	4,900	
Concrete plug	m ³	170	236	81,330	
Excavation (anchor block)	"	160	111	4,150	
Concrete (anchor block)	"	350	486	181,560	
Steel penstock, weight 100 tons	LS	1	52,778	115,270	
Mortar impregnation	LS	1	833	74,930	
Others	LS	1	2,839	4,900	
Sub Total			62,422	1,217,830	
<u>Power Plant and Sub-station</u>					
Open cut, all classes	m ³	2,700	1,501	38,910	
Excavation, rock	"	3,200	7,666	129,110	
Concrete retaining wall	"	500	695	253,600	

Item	Unit	Quantity	Total Price		Remarks
			Foreign Currency US\$	Local Currency Baht	
Reinforced concrete (powerhouse)	m ³	500	695	288,180	
Fabrication and placing of reinforcing steel bar	t	18	3,006	5,190	
Reinforced concrete (sub- station)	m ³	100	167	57,640	
Fabrication and placing of reinforcing bar	t	2	334	580	
Incline installation	LS	1	8,333	288,180	
Powerhouse building	"	1	42,444	1,321,040	
Appurtenant buildings	"	1		288,180	
Others				64,840	
Sub Total			59,841	2,735,450	
<u>Tailrace</u>					
Excavation (river training)	m ³	6,200	5,165	142,940	
Excavation, tunnel	"	240	400	33,200	
Concrete lining	"	90	125	51,870	
Concrete	"	50	69	23,050	
Draft gate, size 1.7m x 1.7m, number of gate 3	LS	1	3,333	17,290	
Diversion and core of run-off during construc- tion	LS	1	556	46,110	
Others		1	309	9,220	
Sub Total			9,957	323,680	

The principal construction equipment that will be required for the execution of the project are as follow:

Type of Equipment	Specification	Quantity
Power shovel	1.6 m ³	1
"	0.6 m ³	2
Bulldozer	D-80 class	10
Dump truck	13.5 t	18
"	6 t	10
Motor scraper	9.2 m ³	2
Water sprinkler truck	7 t	1
Motor grader	105 psi	2
Wagon drill		10
Concrete batching plant	12 m ³ /hr	1
Aggregate crushing and screeing plant		1
Concrete transit mixer		1
Concrete pump		1
Air compressor	100 HP	3
Portable air compressor	"	4
Utility truck	5 t	1
Tamping roller	9 t	2

(b) Studies of Electric Service Rates


The estimated total construction costs of the Nam Pung hydro-electric is arranged below for the purpose of estimating power costs.

<u>Item</u>	<u>Construction Costs</u>
Dam	US\$ 3,142,360
Waterways and powerhouse	1,981,140
Transmission lines and sub- stations (to Sakol Nakorn)	693,740
Transmission lines and sub- stations (to Nakorn Phanom and Mukdahan)	712,500
Total	6,529,740

Approximately 50% of the output of Nam Pung Power Plant is to be consumed in and around the city of Sakol Nakorn and the balance in areas along the main Mekong River. Consequently, the transmission lines east of Sakol Nakorn will be utilized at an extremely low factor in comparison with their transmission capacities. The capacities of these transmission lines were determined taking into account future load growths. In the calculating the cost of power, estimates were also made for the case of the national treasury bearing interest costs on the transmission lines east of Sakol Nakorn until interconnection is made with another power system.


Assuming an interest cost of 5% and operating costs of 2 to 5% per annum, including depreciation, the costs of power will be 3.56 cents per kWh if all costs are charged to power. If the operating costs only of the dam are charged to power until completion of the irrigation project (this cost is about equivalent to the cost of the dam allocable to power), then the cost of power is 2.48 cents per kWh. And, if interest costs of transmission lines east of Sakol Nakorn are not included, the cost of power is 2.24 cents per kWh.

Agricultural power will be consumed in and around Sakol Nakorn. Therefore, it is believed that the appropriate charge for agricultural power delivered at Sakol Nakorn would be 1.99 cents per kWh and for general demands about 2.5 cents per kWh.




NAM PUNG PROJECT	
GENERAL MAP	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC 1962	401

DRAWING. I - 1




1:2500



LEGEND


- SURFACE SOIL
- TALUS DEPOSITS
- BLOCK DEPOSITS
- FINE - MEDIUM GRAINED SANDSTONE
- COARSE GRAINED SANDSTONE
- CONGLOMERATE OR CONGLOMERATIC SANDSTONE
- LATERITE
- LOOSE EXPOSURE OR BLOCK
- BOUNDARY OF STRATA
- JOINT
- CREEPED - LOOSEND ROCK AREA
- SPRING WATER
- STRIKE & DIP OF STRATA
- STRIKE & DIP OF JOINT
- STRIKE & DIP OF OPEN JOINT
- STRIKE & DIP OF OPEN JOINT (DIP VERTICAL)


NO 12 (GH 2746) INDICATES BORING HOLE NO 12. GROUND HEIGHT 274 M 6.
















LINE OF GEOLOGIC SECTION

NAM PUNG PROJECT	
GEOLOGY AND LOCATION OF EXPLORATION (D A M)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TO KYO	
DEC. 1962	2 0 1







LEGEND


-  SURFACE SOIL
-  BLOCK DEPOSITS
-  FINE~MEDIUM GRAIN. SANDSTONE
-  COARSE GRAIN. SANDSTONE
-  CONGLOMERATIC SANDSTONE
-  EROSION CAVE
-  CREEPED~LOOSEND ROCK AREA
-  BOUNDARY OF STRATA
-  STRIKE & DIP OF STRATA
-  STRIKE & DIP OF JOINT
-  STRIKE N 50°W, VERTICAL DIPPED JOINT
-  INDICATES B.H. NO 8 BORING HOLE NO 8
-  LINE OF GEOLOGICAL SECTION



SCALE



NAM PUNG PROJECT	
GEOLOGIC PLAN ALTERNATIVE SITE (SURGE TANK - POWER PLANT)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT, TOKYO	
DEC. 1962	203












LEGEND

- SURFACE SOIL
- SANDSTONE
- CONGLOMERATIC SANDSTONE OR CONGLOMERATE
- SILTSTONE
- CLAY SEAM
- CAVITY
- INDICATES BORING HOLE NO 11
- INDICATES AUGER HOLE
- GROUND WATER LEVEL


REMARKS :
 DATE OF MEASUREMENT OF GROUND WATER LEVEL
 BH NO. 1 3 4 5 10 11 12 13 14 & 15. 10 - MAR. - 1962
 BH NO 1' 2' 3' 4' 5' & 6' JULY - 1962

NAM PUNG PROJECT	
GEOLOGIC SECTION (DAM)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC 1962	204






REMARK:
DATE OF MEASUREMENT
OF GROUND WATER LEVEL
B.H. NO 1 2 3 & 4 10 - MAR. - 1962
B.H. NO 7' 12 - JULY - 1962





REMARK:
 DATE OF MEASUREMENT
 OF GROUND WATER LEVEL
 BH NO.1, 2, 3, & 4 10 - MAR. - 1962
 BH NO 7' 12 - JULY - 1962

- LEGEND
- SURFACE SOIL
 - BLOCK DEPOSIT
 - SANDSTONE
 - CONGLOMERATIC SANDSTONE OR CONGLOMERATE
 - SILTSTONE
 - CLAY SEAM
 - B.H. NO 1 INDICATES BORING HOLE NO 1
 - INDICATES AUGER HOLE
 - GROUND WATER LEVEL
 - SPRING WATER



NAM PUNG PROJECT
 GEOLOGIC SECTION
 (D A M)
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC 1962 205






LEGEND

- SURFACE SOIL
- BLOCK DEPOSIT
- SANDSTONE
- CONGLOMERATIC SANDSTONE OR CONGLOMERATE
- SILTSTONE
- CLAY SEAM
- CLAYEY CORE IN BORING

BH NO.16
INDICATES BORING HOLE NO.16


GROUND WATER LEVEL




REMARK:
DATE OF MEASUREMENT
BH. NO 6B7 ; 10 - MAR - 1962
B.H NO 8' ; 28 - JULY - 1962



NAM PUNG PROJECT	
GEOLOGIC SECTION	
(SURGE TANK — POWER PLANT)	
JAPANESE GOVERNMENT INVESTIGATION	
TEAM ON THE NAM GAM PROJECT	
TOKYO	
DEC. 1962	206


FOLLOWING DAM AXIS








NAM PUNG PROJECT
BORING PROFIL (1)
(DAM)
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO
DEC 1962 207

FOLLOWING ALTERNATIVE DAM AXIS



POINT
G.H.

POINT
G.H.




LEGEND

- BH NO 10 INDICATES BORING HOLE NO 10 CASING
- BORING CORE RECOVERY (INDICATE % BY PAINTED PART)
- GROUND WATER LEVEL (MEASURED 10TH MAR '62)
- INDICATES AUGER HOLE & ITS DEPTH(m)
- WEATHERED ROCK
- SHALE
- SOIL & OVERBURDEN
- COARSE GRAINED SANDSTONE
- FINE GRAINED SANDSTONE
- CONGLOMERATIC OR PEBBLE BEARING SANDSTONE
- FINE-MEDIUM GRAINED SANDSTONE
- CONGLOMERATE
- MEDIUM GRAINED SANDSTONE
- CLAY-SILTSTONE
- MEDIUM COARSE GRAIN SANDSTONE
- CLAY SEAM
- CLAYEY ROCK


SCALE

0 50 100 m


NAM PUNG PROJECT
 BORING PROFIL (2)
 (D A M)
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC 1962 208





NAM PUNG PROJECT
 BORING PROFIL
 (SURGE TANK)
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC 1962 209




NAM PUNG PROJECT
 BORING PROFIL
 (ALTERNATIVE POWER P. & SURGE T.)
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC 1962 210






NAM PUNG PROJECT		
GENERAL PLAN		
JAPANESE TEAM	GOVERNMENT ON THE NAM PUNG	INVESTIGATION PROJECT TOKYO
DEC 1962	402	


DAM DEVELOPED ELEVATION




TYPICAL SECTION OF DAM




NAM PUNG PROJECT	
TYPICAL SECTION AND UP STREAM ELEVATION OF DAM	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC 1962	1102



SECTION SPILLWAY D-D



SECTIONAL PROFILE OF SPILLWAY




STATION	D.I.S.	T. DIS.	G. H.	F. H.
NO-2	-5.9 000	-7.5 500	280.500	280.500
NO-1	-16.500	-16.500	283.500	280.000
NO. 0	0	0	283.500	280.500
NO 1	5.000	5.000	282.900	277.500
NO 2	8.000	13.000	281.800	277.500
NO 3	7.000	20.000	280.800	277.500
NO. 4	30.000	50.000	278.500	277.000
NO. 5	145.000	195.000	275.000	275.000

NAM PUNG PROJECT




SECTION OF SPILLWAY

JAPANESE GOVERNMENT INVESTIGATION
TEAM ON THE NAM GAM PROJECT
TOKYO



DEC 1962 1602






NAM PUNG PROJECT
 LONGITUDINAL SECTION
 (HEAD RACE AND TAIL RACE)
 JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO
 DEC. 1962 501




DIS.	I.DIS.	G.H.	E.H.
0000	0000	281300	(Invert) 285500
3000	0000	281400	(Invert) 255500
203000	203000	268300	255094
39000	242000	263000	(Periback) 256016
3000	245000	262400	256010
6000	251000	261000	255998
6000	257000	259800	255986
6000	263000	259900	255974
6000	269000	259000	255962
6000	275000	257000	255950
57268	270726	256200	254160
5726	286453	254700	252370








NAM PUNG PROJECT
 SECTIONAL PROFIL
 OF PENSTOCK AND
 POWER PLANT
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC. 1962 | 2401




NAM PUNG PROJECT	
PLAN OF POWER PLANT	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC. 1962	3001


DRAWING. I-20




MAIN MACHINERY ROOM (EL. 193.55)





FIRST BASEMENT (EL. 196.90)




GROUND FLOOR (EL. 200.30)



FIRST FLOOR (EL. 203.10)




NAM PUNG PROJECT	
POWER PLANT	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC 1962	3401



NAM PUNG PROJECT	
SYSTEM DIAGRAM	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TO KYO	
DEC. 1962	3402

TO SAKOL NAKORN S.S.



Water Turbine	H.F. 1,900kW 750 rpm
Generator	2200 kVA 33kV 50 c/s 750 rpm


NAM PUNG PROJECT	
POWER PLANT	
CONNECTION DIAGRAM	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT T O K Y O	
DEC. 1962	3403

SAKOL NAKORN S.S.

THAT PHANOM S.S.


MUKDAHAN S.S.
NAKORN PHANOM S.S.
NAM PUNG BRIDGE S.S.

NA KAE S.S.




NAM PUNG PROJECT	
SUBSTATION CONNECTION DIAGRAM	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM PUNG PROJECT TOKYO	
DEC. 1962	3404



SECTION A - A




SECTION B - B




P L A N







NAM PUNG PROJECT	
POWER PLANT (SWITCH YARD)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC. 1962	3501




SECTION A - A




SECTION B - B




NAM PUNG PROJECT	
SUBSTATION (SAKOL NAKORN)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC. 1962	3502



SECTION A-A




SECTION B-B




SCALE
0 5 10m

NAM PUNG PROJECT	
SUBSTATION (THAT PHANOM)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC. 1962	3503





SECTION A-A




SECTION B-B


NAM PUNG BRIDGE S.S.
 NAKORN PHANOM S.S.
 MUKDAHAN S.S.






NA KAE S.S.



SECTION A-A



NAM PUNG PROJECT	
SUBSTATION (N.P.B.R., NA KAE,) (MUK. N.F.)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC. 1962	3504



() ; TYPE C ONLY


NUMBER OF GUY CABLE IN EACH TYPE



DESCRIPTION OF DETAILS

- | | |
|--|---|
| NO 1 TREATED POLE | NO. 9 1- BOLT |
| 2. LOG | 10 STAY HANGER. (STEEL) |
| 3. BIND WIRE (4mm STEEL) | 11 WIRE CLIP |
| 4. CROSS ARM (. 80 ^{mm} x 80 ^{mm} x L. WOOD) | 12 STAY WIRE (GALVANAIZED STRANDED STEEL WIRE) |
| 5 CAP (STEEL) | 13 PLATE (16mm ↑ STEEL) |
| 6. BOLT (19 ^{mm} - 300mm) | 14 BOLT (16 ^{mm} - 150mm) |
| 7. PLATE (6mm ↑ STEEL) | 15 CIRCULER SINBLE |
| 8. BOLT (16 ^{mm} - 150mm) | |

NAM PUNG PROJECT	
TYPICAL WOOD POLE (69 KV)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAN PROJECT TOKYO	
DEC. 1962	5002



II. NAM PUNG IRRIGATION PROJECT

C O N T E N T S

	Page
A. SUMMARY	II-1
B. GENERAL DESCRIPTION OF STRUCTURES	II-2
(a) Diversion Weir	II-2
(1) Design water level and controlled water level	II-2
(2) Method of intake	II-3
(3) Operation of gates	II-3
(4) Foundation	II-4
(5) Apron	II-4
(6) Consolidation work	II-5
(7) Retaining walls	II-5
(b) Pumping Stations	II-5
(1) Nong Hen No. 1 Pumping Station	II-5
(2) Ban Lat Du Pumping Station	II-6
(c) Canals	II-6
C. CALCULATIONS	II-10
(a) Calculation of Required Power for Pumping Stations	II-10
(1) Nong Hen No. 1 Pumping Station	II-10
(2) Ban Lat Du Pumping Station	II-11
(b) Example of Hydraulic Calculation of Siphon	II-11
D. CONSTRUCTION PLAN AND CONSTRUCTION COST ESTIMATES	II-12
(a) Construction Plan	II-12
(b) Number of Major Structures	II-13
(1) Diversion weir	II-13
(2) Pumping stations	II-13
(3) Canal works	II-14

	Page
(c) Quantities of Major Construction and Construction Schedule	II-15
(1) Quantities of construction	II-15
(2) Construction schedule	II-16
(d) Construction Cost Estimates	II-17

T A B L E S

		Page
II-1	Sectional Discharge by Canals	II-7
II-2	Dimensions of Canals	II-9
II-3	Estimated Total Construction Costs of Nam Pung Lower Basin Irrigation Project	II-17
II-4	Estimated Construction Costs of Main Canals, Structures, and Diversion Weir	II-18
II-5	Estimated Construction Costs of Pumping Stations	II-19
II-6	Estimated Construction Costs of Land Improvement Works	II-20

F I G U R E

II-1	Model Graph of Canals	II-6
------	-----------------------	------

D R A W I N G S

		Page
II-1	Nam Pung Lower Basin Area General Plan	II-20
II-2	Diversion Weir General Plan	II-20
II-3	" Plan	II-20
II-4	" Longitudinal Section	II-20
II-5	" Cross Section	II-20
II-6	" Pier	II-20
II-7	" Bridge	II-20
II-8	" Left Side Intake	II-20
II-9	" Right Side Intake	II-20
II-10	" Leading Canal Regulating Gate, Diversion & Direct Intake	II-20
II-11	" Leading Canal Drop	II-20
II-12	Nong Hcn No. 1 Pumping Station General Plan	II-20
II-13	" " Plan & Longitudinal Section	II-20
II-14	" " Pumping House Plan & Elevation	II-20
II-15	" " Pumping House Side View	II-20
II-16	" " Inlet Box Plan & Cross Section	II-20
II-17	Pumping Main Canal & 1st Main Canal (1) Profile & Standard Cross Section	II-20
II-18	1st Main Canal (2), (3) Profile & Standard Cross Section	II-20
II-19	2nd Main Canal & 3rd Main Canal Profile & Standard Cross Section	II-20
II-20	Related Structures of Canals Intake Gate	II-20
II-21	" " Turn Out	II-20
II-22	" " Regulating Gate Type (1)	II-20

			Page
II-23	Related Structures of Canals Regulating Gate Type (2)		II-20
II-24	"	"	Concrete Box Siphon & Pipe Siphon
			II-20
II-25	"	"	Canal Spillway & Box Culvert
			II-20

A. S U M M A R Y

The agricultural development plan for the proposed project area is described in the Report, III-E in connection with the development of other regions. In this preliminary designs emphasis will be placed on the design phase of facilities and structures for the Nam Pung Lower Basin Area.

The proposed project area in the Nam Pung lower basin area is 10,000 ha, comprising of 9,000 ha of existing paddy fields and 1,000 ha of upland fields reclaimed from forest land. Cultivated lands to be irrigated with water taken in from a diversion weir consist of paddy fields of 7,237.6 ha and upland fields of 785.2 ha, totaling 8,022.8 ha. And, cultivated lands, which will receive irrigation water from Lake Nong Han instead of through the diversion weir are 1,977.2 ha, comprising of 1,762.9 ha paddy fields and 214.8 ha of upland fields.

214.8 ha of upland field which is included in the area to be irrigated with taken from the diversion weir is located on high ground, and therefore. irrigation water to this area will be supplied from a pumping station to be constructed at Ban Lat Du.

The major structures in this area are a diversion weir, pumping station and canals. The diversion weir is to be built at a point about 700 m downstream of Nam Pung Bridge. Non Han No. 1 Pumping Station is to be installed on the southern shore of Lake Nong Han, at an intermediate point between Ban Tha Wat and Ban Yang At. A transition canal, 217 m long, from the right bank of the diversion weir will connect with the first main canal, 23 km long, the third main canal, 7 km long and the pumping main canal, 7.2 km long. The Ban Lat Du Pumping Station is to be constructed at the end of the third main irrigation canal. The second main canal, 15 km long, connects to the intake on the left bank of the diversion weir.

In addition to the construction of major structures, land improvement works, such as, the construction of branch irrigation and drainage canals,

construction and improvement of farm road, and reclamation of new upland fields are to be executed. The proposed routes of branch irrigation canal are shown provisionally on the general plan of the irrigation scheme. (see Drawing II-1) Their total length is about 67 km.

The designs of major structures are based on the water utilization program, and the respective dimensions and/or capacities of diversion weir, pumping station and canals have been determined so that the structures, either individually or as a component of the system, may function efficiently and to their fullest capacities.

Estimates of construction costs, were made separately for "canals, structures and diversion weir," "pumping stations" and "land improvement works," and to these estimates were added costs of temporary facilities (15% of direct construction costs and rentals of machines) and overhead (estimated at 20% of the total of direct construction costs, rentals of machines, and costs of temporary facilities).

Attached are drawings of typical structures for the Nam Pung lower basin area, including diversion weir, Lake Nong Han No. 1 Pumping Station, regulating gate, diversion gate, culvert and siphon, as well as, longitudinal section of main canals.


B. GENERAL DESCRIPTION OF STRUCTURES

(a) Diversion Weir

The site of the diversion weir has been selected where the river is stabilized in behavior, narrow in width and has sufficient drop in relation to the irrigation area. The length of the weir is 37.5 m. The weir pier is 10.0 m high and 2.5 m wide. Three spans of movable weir gates are to be installed. The required concrete volume is about 4,500 m³.

(1) Design water level and controlled water level

The diversion weir is of movable design in order to allow flood waters to flow without hindrance in the wet season. Fitted with three spans of oil-pressure type roller-gates, 10.0 m wide and 3.4 m high each, the weir will control water levels to the design intake water level (EL. 163.70 m). Also, by closing all the gates and raising the water level up to EL. 164.20 m, it will have a regulating capacity of 100,000 m³, and the water discharged from the powerhouse may be evenly utilized.



(2) Method of intake

From the river behavior at the proposed site of the diversion weir a method of taking in water on both banks is possible.

Left-bank Intake:

With one span of oil-pressure type sluice gate, 2.50 m wide and 1.80 m high a maximum of 2.66 m³/s of water may be taken in. The elevation of the intake sill is 162.20 m.

Right-bank Intake:

With three spans of oil-pressure type sluice gates, 2.40 m wide and

Right-bank Intake

With three spans of oil-pressure type sluice gates, 2.40 m wide and 1.80 m high each a maximum of 8.00 m³/s of water may be taken in. The elevation of the intake sill is similarly 162.20 m.

(3) Operation of gates

An operation room is to be built on the first pier of the diversion weir. From this room the gates of the main weir and the left-bank and the right bank intakes can be operated by oil-pressure type remote control method.

(4) Foundation

The foundation of weir piers will be reinforced with spiral steel piles, 300 mm in diameter and 9.00 m long each. In order to reduce permeability of the sandy foundation, sheet piles, 6.50 - 7.50 m long each, are to be driven in the foundation.

(5) Apron

The following method was adopted in determining the length of the apron.

$$L = CH$$

where, L = length of percolation line

C = coefficient by type of foundation;

In the case of the diversion weir, the foundation consists of coarse-grain sand, therefore, C = 12

H = difference between upstream and downstream water levels

$$H = 4.2 \text{ m}$$

Therefore,

$$L = 12 \times 4.2 = 50 \text{ m}$$

The upstream apron will be 7.40 m long and 0.5 m thick, while the downstream one will be 22.0 m long and 1.70 to 1.00 m thick. Both aprons will be

of concrete structure

(6) Consolidation work

Concrete-blocks will be placed on the river bed for a distance 48.00 m from the end of the downstream apron. From the end of the concrete block, rip-rap work, 60.35 m long, will be executed. Thus the total length of consolidation work will be 108.35 m.

(7) Retaining walls

Retaining walls, 122 m long on the left bank and 148 m long on the right bank downstream of the diversion weir will be built as measures against the river flow turning to the left.

(b) Pumping Stations

(1) Nong Han No. 1 Pumping Station

(i) Maximum discharge and operating time

The maximum required discharge is 1,954,000 m³/5 days, based on the irrigation scheme for the Nam Pung lower basin area. (see III-E-(d) of the Report). Based on this water requirement the operating time of pumps per day is 16 hours, and the maximum unit discharge (Q) is 407 m³/s.

(ii) Lift

The water level on the suction side is 155.50 m, which is the design lowest water level of Lake Nong Han. The water level on the discharge side must be 163.60 m according to the canal plan.

Therefore, the actual lift is 8.10 m. However, adding various head losses of about 1.60 m, the total lift (H) of the pump is 9.70 m.

(iii) Type and number of pumps

Two double suction type volute pumps, 1,200 mm in bore each are adopted, taking into consideration the problems of manufacturing and

advantages of use.

(iv) Prime movers and attachments

Two 6,000 voltage motors will be used as prime movers. Besides, a set of attachments, such as, starting vacuum pump and cooling pump will be installed.

(2) Ban Lat Du Pumping Station

(i) Maximum discharge and operating time

Maximum required discharge	74,000 m ³ /5 days
Maximum unit discharge (Q)	16 m ³ /min
Operating time per day	16 hours

(ii) Lift

Actual lift	8.0 m
Head loss	2.0 m
Total lift	10.0 m

(iii) Type and number of pumps

Type:	Double suction type volute pump
Bore:	250 mm
Number:	2 sets

(iv) Prime movers and attachments

Two 400-volts motors with complete sets of attachments.

(c) Canals

Based on the maximum water requirement (4,604,000 m³/5-days) for the basic year (October 1959) on which the irrigation scheme has been prepared, the calculated values of duty of water and sectional discharge relating to each main canal are shown on Fig. II-1 and Table II-1.

NOTE

- A IRRIGABLE AREA ha
- Q MAXMUM DISCHARGE m^3/s
- v VELOCITY m/s
- L DISTANCE m
- q CANAL LOSS m^3/s




FIG. II - 1

MODEL GRAPH OF CANAL SYSTEM

Table II-1

Sectional Discharge by Canals

First Main Canal				Second Main Canal			
Diverging Point	Controlled Area	Diverged Water	Discharge	Diverging Point	Controlled Area	Diverged Water	Discharge
	ha	m ³ /s	m ³ /s		ha	m ³ /s	m ³ /s
6			5.19	DIVER-SION WEIR			2.66
7	445.4	0.52	4.60	17	738.2	0.85	1.70
8	747.4	0.87	3.49	18	186.7	0.22	1.44
9	252.3	0.29	3.16	19	108.3	0.13	1.26
10	269.4	0.31	2.84	20	441.2	0.51	0.68
11	947.4	1.10	1.48	21	465.6	0.54	
12	387.7	0.45	0.98				
13	690.0	0.80					
Total	3,739.6			Total	1,940.0		

Third Main Canal				Pumping Main Canal			
Diverging Point	Controlled Area	Diverged Water	Discharge	Diverging Point	Controlled Area	Diverged Water	Discharge
	ha	m ³ /s	m ³ /s		ha	m ³ /s	m ³ /s
DIVER-SION WEIR			8.00	1ST PUMPING STATION			6.78
0	1,028.8	0.85	7.15	1	318.0	0.37	6.31
6 *	3,739.6	5.19	1.85	2	1,061.0	1.19	4.95
14	277.0	0.32	1.50	3	142.4	0.16	4.74
15	255.5	0.30	1.09	4	92.1	0.11	4.62
16	781.9	0.80		5	363.7	0.41	4.12
				6			
Total	6,082.8			Total	1,977.2		

* Water diverged from First Main Canal

If, in this case, they are calculated on the assumption that the daily duty of water for paddy and upland fields be 10.0 mm/day and 4.4 mm/day, respectively, and canal loss be proportionate to a product of the length of each section of a canal multiplied by the discharge, Fig. II-1 is obtained. The total canal losses are estimated at 20% of the total water requirements.

When the intake from the right-bank of the diversion weir is below 8.00 m³/s, land to be irrigated from the First and Third Main Canals may be supplied with 4.12 m³/s of water (maximum) from Lake Nong Han through the Pumping Main Canal.

As for each main canal, taking soil texture and the difficulty of execution into consideration, the embanked section will have a trapezoidal cross section with a side slope of 1:2.0, and lined with asphalt, while the open cut section will be unlined with asphalt and have a trapezoidal cross section with a side slope of 1:2.0. The ratio of the length of asphalt lining sections to the total length of main canals are given below:

First Main Canal	$\frac{7,680}{23,000}$,
Second Main Canal	$\frac{1,250}{15,000}$,
Third Main Canal	$\frac{4,300}{7,000}$,
Pumping Main Canal	$\frac{1,250}{7,200}$

Top figure: Total length of canal (m).

Bottom figure: Total length of asphalt lining section (m).

As shown in the attached drawings, each main canal will have diversion works, regulating gates, spillways, culverts and siphons.

For the velocity and the discharge in canals Manning Formula was used, and a coefficient of roughness of 0.015 for the asphalt-lined canal, and 0.030

for the earth canal were adopted.

The standard cross section of each canal is as shown in the attached drawings and Table II-2.

Table II-2

Dimensions of Canals

	Section	a ₁	a ₂	b	c	d	I	v	Q	Lining Type
		m	m	m	m	m		m/s	m ³ /s	
First Main Canal	⑥ — ⑦	3.00	2.00	1.00	0.30	2.16	1:5,500	0.47	5.19	Earth
	⑦ — ⑧	3.00	2.00	0.70	0.30	1.60	1:5,500	0.77	4.60	Asphalt
	⑩ — ⑪	3.00	2.00	0.70	0.30	1.33	1:5,500	0.73	2.84	Asphalt
	⑬	1.50	1.50	0.70	0.30	0.99	1:3,000	0.39	0.98	Earth
Second Main Canal	Div — ⑰	3.00	2.00	1.00	0.30	1.65	1:5,500	0.49	2.66	Earth
	⑲ — ⑳	1.50	1.50	0.70	0.30	0.87	1:4,000	0.62	1.20	Asphalt
Third Main Canal	⑥ — ⑭	2.00	1.50	1.00	0.30	1.28	1:4,000	0.52	1.85	Earth
	⑭ — ⑮	2.00	1.50	1.00	0.30	0.73	1:2,000	0.88	1.50	Asphalt
Pumping Main Canal	⑰ — ⑱	3.00	2.00	1.00	0.30	1.85	1:6,500	0.80	6.78	Asphalt
	⑵ — ⑶	3.00	2.00	1.00	0.30	2.00	1:6,500	0.42	4.12	Earth

Notes:

Manning Formula;


$$v = \frac{1}{n} \cdot R^{2/3} I^{1/2}$$

where, n = coefficient of roughness;

Asphalt part, n = 0.015
Earth part, n = 0.030

R = hydraulic mean depth

I = slope



- a_1, a_2 = width of left and right bank crest
- b = base width of canal
- c = freeboard
- d = waterdepth

C. CALCULATIONS

(a) Calculation of Required Power for Pumping Stations

(1) Nong Han No. 1 Pumping Station

$$\text{per pump } WHP = \frac{r \left(\frac{Q}{2}\right) H}{L,500} = 439 \text{ HP}$$

$$SHP = \frac{WHP}{\eta_p} = 549 \text{ HP}$$

$$RHP = \frac{SHP}{\eta_g} \times e_m = 665 \text{ HP} = 475 \text{ kW}$$

where, WHP = water horsepower

SHP = shaft horsepower

RHP = required horsepower

r = specific gravity of pumped water 1,000 kg/m³

η_p = efficiency of pump, 0.80

η_g = transmission efficiency of gear, 0.95

e_m = safety coefficient of motor, 1.15

Accordingly, the required power per pump including attachments is 500 kW, and the power for the total installations in Nong Han No. 1 Pumping Station is determined as 1,000 kW.

(2) Ban Lat Du Pumping Station

$$\text{Per pump WHP} = \frac{\gamma \left(\frac{Q}{2}\right) H}{4,500} = 18 \text{ HP}$$

$$\text{SHP} = \frac{\text{WHP}}{0.74} = 24 \text{ HP}$$

$$\text{RHP} = \frac{\text{SHP}}{\eta} \times \eta_m = 29 \text{ HP} \approx 21 \text{ kW} \quad 29 \text{ HP} \approx 21 \text{ kW}$$

The required power for the total installations in Ban Lat Du Pumping Station is determined as 50 kW.

(b) Example of Hydraulic Calculation of Siphon

First Main Canal siphon:

Length, $L = 900 \text{ m}$

Diameter, $D = 1,100 \text{ mm}$ (Hume pipe, $n = 0.012$)

Discharge, $Q = 0.98 \text{ m}^3/\text{s}$

Velocity inside Pipe, $V_2 = 1.03 \text{ m/s}$

1. Friction head loss, $h_f = f_o \cdot \frac{L}{D} \cdot \frac{V_2^2}{2g}, \quad f_o = 0.0174$

2. Head loss at entrance, $h_1 = f_1 \times \frac{V_2^2}{2g}, \quad f_1 = 0.5$

3. Head loss at outlet, $h_2 = f_2 \times \frac{V_2^2}{2g}, \quad f_2 = 1.0$

4. Head loss at bend, $h_3 = f_3 \times \frac{V_2^2}{2g}, \quad f_3 = 0.131$

5. Head loss at transition part:

Reduced section, $h_4 = f_4 \cdot \frac{V_2^2 - V_1^2}{2g}, \quad f_4 = 0.2$

$$\text{Extended section, } h_5 = f_5 \frac{V_2^2 - V_3^2}{2g}, f_5 = 0.3$$

$$V_1 = V_3 = 0.74 \text{ m/s}$$

6. Total required head (H)

$$H = h_f + h_1 + h_2 + 2h_3 + h_4 + h_5 = 0.877 \text{ m}$$

D. CONSTRUCTION PLAN AND CONSTRUCTION COST ESTIMATES

(a) Construction Plan

The construction works have been planned for completion in two years and a half in order that the benefits of the project may be realized as early as possible. For this purpose heavy construction machineries should be used to the fullest extent. The volume of embankment required to build canals is very large, as indicated later. Therefore, an important problem will be the selection of borrow pits. Generally speaking, the proposed project area is flat, and there are very few places suitable for borrow pits. Borrow pit sites selected on a map are as follows:

- First Main Canal Area: 2 places in the vicinity of Ban Na Mon and Ban Na Kung;
- Second Main Canal Area: 2 places in the vicinity of Ban Nong Mukula and Ban Phon Yang Kham;
- Third Main Canal Area: 1 place in the vicinity of Ban Hong I Kom;
- Pumping Main Canal Area: 1 place in the vicinity of Ban Phon Yang Kham.

Major construction machines required for the construction works are approximately as follows:

Bulldozer (10 tons)	23
Attachments (blade, plow, disc-harrow and rake)	10 sets
Bulldozer (17 tons)	6
Attachments (blade and rake)	6 sets

Carryall scraper (capacity: 6.1 m ³)	8
Power shovel and attachments (0.6 m ³)	7
Tamping roller (two-drum type)	6
Dump truck (capacity: 5 tons)	8
Dump truck (capacity: 7 tons)	68
Motor grader (6 tons)	2
Concrete batching plant	1 unit
Concrete transit mixing truck (capacity: 4 m ³)	5

(b) Number of Major Structures

The number of the major structures is as follows:

(1) Diversion weir:	1 place
Oil-pressure type roller gate (10 m wide and 3.4 m high)	3 spans
Right bank intake gate:	
Oil-pressure type sluice gate (2.4 m wide and 1.8 m high)	3 spans
Left bank intake gate:	
Oil-pressure type sluice gate (2.5 m wide and 1.8 m high)	1 span
Right-bank leading canal:	
(5 m wide and 2.3 m deep, concrete on three sides)	217 m long
Related structures of leading canal:	
Drop (1.0 m)	1 place
Diversion work	1 place

(2) Pumping stations

(i) Nong Han No. 1 Pump Station

1,200 mm-bore, double suction type volute pump	2
--	---

6,000-voltage motor 2
 Attachments 1 set

(ii) Ban Lat Du Pump Station

250 mm-bore, double suction type volute pump 2
 400-voltage motor with 2
 Attachments 1 set

(3) Canal works

N a m e		1st	2nd	3rd	Pumping	Total
		Main Canal	Main Canal	Main Canal	Main Canal	
Earth-lined Canal	m	15,320	13,750	2,700	5,950	37,720
Asphalt-lined Canal	m	7,680	1,250	4,300	1,250	14,480
Regulating Gate (large type)	place	6	0	0	1	7
Regulating Gate (small type)	place	0	4	0	0	4
Diversion Work	place	13	4	3	5	25
Direct Intake Work	place	20	10	7	7	44
Pipe Siphon Work D = 1,000mm, ℓ = 50m	place	1	0	0	0	1
" D = 1,100mm, ℓ = 50m	"	0	0	1	0	1
" D = 1,100mm, ℓ = 70m	"	1	0	0	0	1
" D = 1,100mm, ℓ = 900m	"	1	0	0	0	1
" D = 1,200mm, ℓ = 50m	"	0	1	2	0	3
" D = 1,300mm, ℓ = 50m	"	0	2	0	0	2
Box Siphon Work 2.2m x 2.0m, ℓ = 50	"	3	0	0	0	3
" 2.2m x 2.0m, ℓ = 200	"	2	0	0	0	2
" 2.2m x 2.2m, ℓ = 50	"	5	0	0	0	5
" 1.6m x 1.8m, ℓ = 50	"	0	1	0	0	1

N a m e	1st Main Canal	2nd Main Canal	3rd Main Canal	Pumping Main Canal	Total
Box Culvert					
1.8m x 2.0m, 2 spans, ℓ = 510m place	1	0	0	0	1
1.8m x 2.1m, 2 spans, ℓ = 200m "	1	0	0	0	1
1.7m x 1.4m, 1 span ℓ = 200m "	1	0	0	0	1
Canal Spillway "	6	4	3	1	14
Highway Bridge "	8	5	3	4	20
Turn Road Bridge "	22	4	6	10	42

) Quantities of Major Construction and Construction Schedule

(1) Quantities of construction

The quantities of earth-work and concrete for canals, structures, diversion weir and pumping stations are as follows (not including land improvement works):

1. Surface-soil removing	278,000 m ³
2. Excavation	245,000 m ³
3. Earth embankment	763,000 m ³
4. Reinforced concrete	12,000 m ³
5. Non-reinforced concrete	3,000 m ³

(2) Construction schedule

Year & Month	First Year												Second Year												Third Year						
	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5	6	7	8	9	10	11	12	1	2	3	4	5	6	
Diversion weir						18 months																									
Pumping stations												20 months																			
Canal works and others	Relating to 1st main canal																														
	Relating to 2nd main canal																														
	Relating to 3rd main canal																														
	Relating to pumping main canal																														

(d) Construction Cost Estimates

The estimated construction costs are as follows:

(\$1 = ¥360 = 20.75 Bahts)

Table II-3

Estimated Total Construction Costs of
Nam Pung Lower Basin Irrigation Project

I t e m	Construction Costs U.S.\$	Breakdown		Remarks
		Foreign Currency U.S.\$	Local Currency Baht	
Canals, Structures and Diversion Weir	4,178,222	2,563,000	33,515,856	See Table II-4
Pumping Station	947,888	713,305	4,867,597	See Table II-5
Land Improvement Works	1,739,944	582,472	24,017,543	See Table II-6
Total	6,866,054	3,858,777	62,400,996	
Contingencies	686,611	385,889	6,239,983	
Cumulative Total	7,552,665	4,244,666	68,640,979	
Total Expenditures	552,695	378,222	3,620,314	
a Surveying and Design work	271,166	271,166	0	
b Supervision of construction	107,056	107,056	0	
c Thai Government expenses	174,473	0	3,620,314	
Cumulative Total	8,105,360	4,622,888	72,261,293	
Construction Interest	650,670	371,077	5,801,534	
Grand Total	8,756,030	4,993,965	78,062,827	

Table II-4

Estimated Construction Costs of Main Canals,
Structures, and Diversion Weir

I t e m	Construction Costs U.S.\$	Breakdown		Remarks
		Foreign Currency U.S.\$	Local Currency Baht	
Direct Construction Costs	2,315,750	927,611	28,803,384	
1st Main Canal Work	1,064,028	396,917	13,842,553	
2nd Main Canal Work	316,056	129,083	3,879,690	
3rd Main Canal Work	179,972	74,472	2,189,125	
Pumping Main Canal Work	332,194	144,306	3,898,676	
Subtotal	1,892,250	744,778	23,810,044	
Intake Work	337,361	134,583	4,207,644	
Leading Canal Work	86,139	48,250	786,196	
Subtotal	423,500	182,833	4,993,840	
Rentals of Machines	711,944	711,944	0	
Temporary Facilities	454,166	227,083	4,711,972	
Overhead	696,362	696,362	0	
Grand Total	4,178,222	2,563,000	33,515,856	

Table II-5


Estimated Construction Costs of Pumping Stations

I t e m	Construction Costs U.S.\$	Breakdown		Remarks
		Foreign Currency U.S.\$	Local Currency Baht	
Direct Construction Cost	661,694	478,611	3,798,972	
Nong Han No. 1 Pump- ing Station	512,611	374,611	2,863,500	
Ban Lat Du Pumping Station	125,083	96,000	603,472	
Power-Transmission Line	24,000	8,000	332,000	
Rentals of Machines	25,194	25,194	0	
Temporary Facilities	103,028	51,528	1,068,625	
Overhead	157,972	157,972	0	
Grand Total	947,888	713,305	4,867,597	


Table II-6


Estimated Construction Costs of
Land Improvement Works

I t e m	Construction Costs U.S.\$	Breakdown		Remarks
		Foreign Currency U.S.\$	Local Currency Baht	
Direct Construction Cost	1,158,417	95,500	22,055,527	
o Branch Irrigation Canals, Branch Drainage Canals, Roads within Areas	1,000,000	0	20,750,000	
o Upland-Reclaiming Work	158,417	95,500	1,305,527	
Rentals of Machines	102,417	102,417	0	
Temporary Facilities	189,110	94,555	1,962,013	
Overhead	290,000	290,000	0	
Grand Total	1,739,944	582,472	24,017,543	




NAM PUNG PROJECT	
DIVERSION WEIR	
GENERAL PLAN	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC.	1962







NAM PUNG PROJECT	
DIVERSION WEIR PLAN	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC. 1962	




LONGITUDINAL SECTION






DETAIL A

DETAIL B




DETAIL C



RETAINING WALL


NAM PUNG PROJECT	
DIVERSION WEIR LONGITUDINAL SECTION	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAN PROJECT TOKYO	
D.E.C.	1962






0 10 20 30 40 50 100 m
SCALE

CROSS SECTION

NAM PUNG PROJECT
DIVERSION WEIR
CROSS SECTION
JAPANESE GOVERNMENT INVESTIGATION
TEAM ON THE NAM GAM PROJECT
DEC 1962




DRAWING II-6




NAM PUNG PROJECT	
DIVERSION WEIR BRIDGE	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962

DRAWING. II- 7




SCALE
0 10 20 30 40 50 100 mm

NAM PUNG PROJECT	
DIVERSION WEIR LEFT SIDE INTAKE	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM PUNG PROJECT TOKYO	
DEC	1962




PLAN

SCALE
0 10 20 30 40 50 100 mm




LONGITUDINAL SECTION




CROSS SECTION

SCALE
0 10 20 30 40 50 100 mm




ELEVATION







NAM PUNG PROJECT	
DIVERSION WEIR RIGHT SIDE INTAKE	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962




PLAN










LONGITUDINAL SECTION






CROSS SECTION




NAM PUNG PROJECT	
DIVERSION WEIR LEADING CANAL REGULATING GATE, DIVERSION & DIRECT INTAKE	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962





NAM PUNG PROJECT	
DIVERSION WEIR LEADING CANAL DROP	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962




NAM PUNG PROJECT	
NONG HAN NO.1 PUMPING STATION GENERAL PLAN	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962





LONGITUDINAL SECTION





PLAN




NAM PUNG PROJECT	
NONG HAN NO 1 PUMPING STATION PLAN & LONGITUDINAL SECTION	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962







ELEVATION



PLAN





NAM PUNG PROJECT	
NONG HAN NO.1 PUMPING STATION PUMPING HOUSE PLAN & ELEVATION	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC. 1962	




SIDE VIEW

Plan of in Side




NAM PUNG PROJECT	
NONG HAN NO.1 PUMPING STATION	
PUMPING HOUSE SIDE VIEW	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC.	1962


Section C-C



Section B-B





CROSS SECTION





PLAN


Section A-A



NAM PUNG PROJECT	
NONG HAN NO.1 PUMPING STATION	
INLET BOX PLAN & CROSS SECTION	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962





S.P. NO.	Dist.	G.H.	Grade	F.H.	W.S.
NO 0	0	154.17	○	154.000	(155.30)
	+61.30	155.06	○	154.500	(157.91)
	+100	155.51	○		
	NO 1	157.31	○	154.500	
	+227	159.73	○	154.500	
	+100	160.56	○	157.500	
	NO 2	160.56	○		
	+3	160.66	○	159.500	
	NO 3	161.33	○	161.717	163.600
	NO 4	161.33	○	161.686	163.567
	NO 5	161.67	○	161.656	163.506
	+63.4	163.34	○	161.646	
	NO 6	161.58	○	161.625	163.475
	+48.7	162.10	○	161.595	163.445
	NO 7	162.10	○	161.580	163.430
	+80	162.00	○	161.629	163.429
	+100	161.91	○	161.614	163.414
	NO 8	162.08	○	161.583	163.383
	NO 9	162.08	○	161.553	163.333
	NO 10	162.01	○	161.552	163.322
	NO 11	162.25	○	161.481	163.282
	NO 12	161.87	○	161.591	163.161
	+50	161.75	○	161.500	163.100
	+100	161.83	○	161.489	163.099
	NO 17	161.77	○	161.438	163.068
	+110	161.73	○	161.422	163.052
	NO 18	161.77	○	161.430	163.050
	+60	161.62	○	161.404	163.004
	+100	161.26	○	161.374	162.974
	NO 21	160.78	○	161.343	162.943
	NO 22	160.77	○	161.312	162.912
	NO 23	160.92	○	161.331	162.911
	NO 24	161.97	○	161.300	162.880
	+105	162.04	○	161.270	162.850
	NO 25	162.11	○	161.239	162.819
	NO 26	162.11	○	161.208	162.788
	NO 27	162.49	○	161.178	162.757
	NO 28	163.67	○	161.180	162.740
	+100	163.08	○	161.145	162.725
	+167	162.89	○	160.722	162.722
	NO 30	162.89	○	160.691	162.691
	NO 31	162.87	○	160.660	162.660
	NO 32	163.44	○		




S.P. NO.	Dist.	G.H.	Grade	F.H.	W.S.
NO 16	3200	161.87	○	161.591	163.161
	+50	161.75	○	161.500	163.100
	+100	161.83	○	161.489	163.099
	NO 17	161.83	○	161.438	163.068
	+60	161.62	○	161.422	163.052
	+100	161.26	○	161.430	163.050
	NO 21	160.78	○	161.404	163.004
	NO 22	160.77	○	161.374	162.974
	NO 23	160.92	○	161.343	162.943
	NO 24	161.97	○	161.312	162.912
	+105	162.04	○	161.331	162.911
	NO 25	162.11	○	161.300	162.880
	NO 26	162.11	○	161.270	162.850
	NO 27	162.49	○	161.239	162.819
	NO 28	163.67	○	161.208	162.788
	+100	163.08	○	161.178	162.757
	+167	162.89	○	161.180	162.740
	NO 30	162.89	○	161.145	162.725
	NO 31	162.87	○	160.722	162.722
	NO 32	163.44	○	160.691	162.691
	NO 32	164.00	○	160.660	162.660

PUMPING MAIN CANAL





S.P. NO.	Dist.	G.H.	Grade	F.H.	W.S.
NO 13	18	160.17	○	161.907	163.607
	+8	164.91	○		
	NO 14	164.27	○	160.337	163.587
	+50	163.95	○	160.329	162.489
	NO 15	163.58	○	160.312	162.472
	NO 16	163.26	○	160.294	162.454
	+250	162.81	○	160.278	162.438
	NO 17	162.85	○	160.258	162.418
	NO 18	162.85	○	160.240	162.400
	NO 19	163.09	○	160.222	162.382
	NO 20	163.47	○	160.204	162.364
	NO 21	163.91	○	160.186	162.346
	NO 22	163.94	○	160.168	162.328
	NO 23	163.94	○	160.150	162.320
	NO 24	163.61	○	160.132	162.291
	NO 25	163.51	○	160.098	162.256
	NO 26	163.08	○	160.059	162.219
	NO 27	162.54	○	160.023	162.183
	NO 28	162.30	○	159.998	162.148
	NO 29	162.24	○		
	NO 30	161.94	○		
	NO 31	161.36	○		
	NO 32	161.31	○		
	NO 33	161.20	○		




S.P. NO.	Dist.	G.H.	Grade	F.H.	W.S.
NO 34	3000	161.37	○	159.950	162.000
	NO 35	161.44	○	159.914	161.964
	NO 36	161.38	○	160.341	161.941
	NO 37	160.34	○	160.306	161.906
	NO 38	160.42	○	160.270	161.870
	NO 39	160.15	○	160.243	161.843
	NO 40	160.6	○	160.211	161.811
	NO 41	160.42	○	160.174	161.774
	NO 42	161.32	○	160.137	161.737
	NO 43	161.58	○	160.101	161.701
	NO 44	161.76	○	160.074	161.674
	NO 45	161.76	○	160.042	161.642
	NO 46	160.96	○	160.006	161.606
	NO 47	161.00	○	159.974	161.574
	NO 48	161.00	○	159.947	161.547
	NO 49	160.67	○	159.911	161.511
	NO 50	161.19	○	159.884	161.494
	NO 51	161.68	○	159.881	161.481
	NO 52	163.67	○	159.848	161.448
	NO 53	163.67	○	159.811	161.381
	NO 54	162.28	○	159.808	161.408
	NO 55	161.54	○	159.368	161.418
	NO 56	161.54	○	159.331	161.401
	NO 57	162.23	○	159.315	161.385
	NO 58	163.23	○	159.279	161.329
	NO 59	163.23	○	159.241	161.291

MAIN CANAL (1)


1st Main Irrigation Canal
S P 300 m




NAM PUNG PROJECT
PUMPING MAIN CANAL &
1st MAIN CANAL (I)
PROFILE & STANDARD CROSS SECTION
JAPANESE GOVERNMENT INVESTIGATION
TEAM ON THE NAM GAM PROJECT
TOKYO
DEC 1962




1st MAIN CANAL (2)



1st MAIN CANAL (3)




1st MAIN CANAL (2)




1st MAIN CANAL (3)

NAM PUNG PROJECT
 1st MAIN CANAL (2) (3)
 PROFILE & STANDARD CROSS SECTION
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC 1962




3rd MAIN CANAL




2nd MAIN CANAL

NAM PUNG PROJECT
 2nd MAIN CANAL & 3rd
 MAIN CANAL
 PROFILE & STANDARD
 CROSS SECTION
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC 1962




PLAN




ELEVATION


CROSS SECTION




LONGITUDINAL SECTION




NAM PUNG PROJECT	
RELATED STRUCTURES OF CANALS INTAKE GATE	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962




PLAN




LONGITUDINAL SECTION




NAM PUNG PROJECT	
RELATED STRUCTURES OF CANALS TURN OUT	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GÁM PROJECT TOKYO	
DEC 1962	




PLAN







LONGITUDINAL SECTION




CROSS SECTION





NAM PUNG PROJECT	
RELATED STRUCTURES OF CANALS REGULATING GATE TYPE (I)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC 1962	



NAM PUNG PROJECT	
RELATED STRUCTURES OF CANALS REGULATING GATE TYPE (2)	
JAPANESE GOVERNMENT INVESTIGATION TEAM ON THE NAM GAM PROJECT TOKYO	
DEC	1962



NAM PUNG PROJECT
 RELATED STRUCTURES OF CANALS
 CONCRETE BOX SIPHON &
 PIPE SIPHON
 JAPANESE GOVERNMENT INVESTIGATION
 TEAM ON THE NAM GAM PROJECT
 TOKYO
 DEC 1962



NAM PUNG PROJECT

RELATED STRUCTURES OF CANALS
CANAL SPILLWAY &
BOX CULVERT

JAPANESE GOVERNMENT INVESTIGATION
TEAM ON THE NAM GAM PROJECT


DEC. 1962


DRAWING II-1

NAM PUNG LOWER BASIN AREA GENERAL PLAN


(1: 50,000)

GENERAL PLAN OF NAM GAM IRRIGATION (Lower Nam Pung District)






TYPICAL CROSS SECTION













LEGEND


- Road
- River and Streamlet
- Crumbling earth
- Sand
- Rock
- Swamp
- Broad-leaved tree
- Coniferous tree
- Waste land
- Inclined plane
- Intermediate contour
- Index contour
- Main canal
- Lateral canal
- Paddy field
- Upland field

1:50,000
 m 0 1000 2000 3000 4000 5000



LEGEND

-  road and streamlet
-  embankment
-  leaved tree
-  round tree
-  land
-  d plane
-  diate contour
-  contour
-  canal
-  field
-  field



PLANNING ORGANIZATION : JAPANESE GOVERNMENT INVESTIGATION TEAM, TOKYO OFFICE
COMPILED BY : KOKUSAI AERIAL SURVEYS CO., LTD.

