


**VOLTAGE DROP OF TRANSMISSION AND
DISTRIBUTION LINE AT PEAK LOAD**

- Fig. III-3-12** Voltage drop of transmission and distribution line
at peak load – East Hai
- Fig. III-3-13** Ditto – Central Hai
- Fig. III-3-14** Ditto – West Hai
- Fig. III-3-15** Ditto – Rombo
- Fig. III-3-16** Ditto – North Pare
- Fig. III-3-17** Ditto – South Pare



Year	Volt
1	223
5	311
10	426
15	542

Year	Volt
1	254
5	354
10	485
15	617

Year	Volt
1	215
5	299
10	410
15	521

Year	Volt
1	174
5	242
10	332
15	422

Year	Volt
1	250
5	348
10	477
15	606

Year	Volt
1	254
5	353
10	484
15	615


EAST HAI

LEGEND ○ : Max. Demand (15 Year)

VOLTAGE DROP AT PEAK LOAD - EAST HAI

E.P.D.C. INTERNATIONAL LTD TOKYO, JAPAN	
Dr. No.	Sheet No. 1
T.A.L.	Approved By:
C.A.I.	Approved By:
LOCATION DATE DESCRIPTION REVISION	
	2
	3
	4

SHEET NO. OF



Year	Volt
1	295
5	411
10	563
15	717

Year	Volt
1	178
5	248
10	339
15	432

Year	Volt
1	102
5	142
10	195
15	248

Year	Volt
1	650
5	904
10	1240
15	1578

Year	Volt
1	335
5	466
10	638
15	813

Year	Volt
1	349
5	485
10	665
15	838

Year	Volt
1	349
5	485
10	665
15	838

Year	Volt
1	351
5	489
10	670
15	853


**VOLTAGE DROP AT PEAK LOAD
- CENTRAL HAI**

E.P.D.C. INTERNATIONAL LTD
TOKYO JAPAN

DATE: _____
 DRAWN BY: _____
 CHECKED BY: _____
 APPROVED BY: _____

LOCATION	DATE	DESCRIPTION	BY

LEGEND ○ Max. Demand (15 Year)



Year	Volt
1	41
5	57
10	78
15	98

Year	Volt
1	24
5	34
10	46
15	58

Year	Volt
1	25
5	35
10	48
15	61

Year	Volt
1	15
5	20
10	28
15	35

Year	Volt
1	24
5	34
10	47
15	110

**VOLTAGE DROP AT PEAK LOAD
- WEST HAI**

WEST HAI

LOCATION	DATE	DESCRIPTION	BY


LEGEND ○ ; Max. Demand (15 Year)

E.P.O.C. INTERNATIONAL LTD
TOKYO JAPAN


D.P.: SUBMITTED
T.P.: RECOMMENDED
C.A.: APPROVED

Fig. III-3-14

SHEET NO. 2 OF 4



SHEET NO. OF




**VOLTAGE DROP AT PEAK LOAD
-- NORTH PARE**

E.P.D.C. INTERNATIONAL LTD
TOKYO JAPAN

Submitted:
T.P.:
RECOMMENDED:
C.A.:
APPROVED:

LOCATION	DATE	DESCRIPTION	REVISION
			1
			2

SHEET NO. **16** OF **16**



Year	Volt
1	130
5	178
10	241
15	296

Year	Volt
1	100
5	138
10	187
15	230

Year	Volt
1	309
5	423
10	574
15	710

Year	Volt
1	208
5	285
10	386
15	478

Year	Volt
1	191
5	262
10	355
15	439

Year	Volt
1	122
5	168
10	227
15	253

Year	Volt
1	157
5	216
10	292
15	336

Year	Volt
1	195
5	267
10	362
15	448

VOLTAGE DROP AT PEAK LOAD
- SOUTH PARE

E.P.O.C. INTERNATIONAL LTD
TOKYO JAPAN

DATE: _____
DRAWN BY: _____
CHECKED BY: _____
APPROVED BY: _____

NO.	DATE	DESCRIPTION	BY

Fig. III-3-17
SHEET NO. _____ OF _____

A-7

VOLTAGE DROP OF LOW TENSION DISTRIBUTION LINE

A-7 VOLTAGE DROP OF LOW TENSION DISTRIBUTION LINE


The followings are examples of voltage drop calculations for the average models when distributed by 25 kVA and 50 kVA transformers.

(1) Conditions

- The voltage drop at the end of line to be below 16 V.
- The utilization factor of the transformer to be 100%.
- Assume that the load current is balanced and that the feeder length is half of the total line length.

(2) Calculations

(a) 25 kVA transformer



Conditions

- * HA 1 22 mm² (1φ 2W) : 1.530Ω/km
- * HA 1 30 mm² (3φ 4W) : 0.983Ω/km
- * Distribution of load points:
 - Uniform distribution (50%)
- * Power factor: 90%

Calculation

For 3 phase line portion

$$V1 = \sqrt{3} \times 0.983 \times 0.3 \times \frac{12.5}{\sqrt{3} \times 400 \times 0.9} \times 0.5$$

$$= 5V$$

For 1 phase line portion

$$V2 = 2 \times 1.530 \times 0.1 \times \frac{12.5}{\sqrt{3} \times 400 \times 0.9} \times 0.5$$

$$= 0.51V$$

Total voltage drop V_0

$$V_0 = \frac{5}{\sqrt{3}} + 0.51$$

$$= 3.4V$$

(For 230 V lighting)

(b) 50 kVA transformer

Conditions

* HA1 30 mm² (1 ϕ 2W) : 0.983 Ω /km

* HA1 55 mm² (3 ϕ 4W) : 0.507 Ω /km

* Distribution of load points:

Uniform distribution (50%)

* Power factor: 90%

Calculation

For 3 phase line portion

$$V1 = \sqrt{3} \times 0.507 \times 0.6 \times \frac{25}{\sqrt{3} \times 400 \times 0.9} \times 0.5$$
$$= 11V$$

For 1 phase line portion

$$V2 = 2 \times 0.983 \times 0.2 \times \frac{25}{\sqrt{3} \times 400 \times 0.9} \times 0.5 \times \frac{1}{3} \times 0.5$$
$$= 1.3V$$

Total voltage drop V_o




$$V_o = \frac{11}{\sqrt{3}} + 1.3$$
$$= 7.6V$$

(For 230 V lighting)

As shown in (a) and (b), the total voltage drop of a line is below 16 V (4%).

A-8

EXPLANATION OF SYMBOL AND ABBREVIATION

Symbol	Description
	Power transformer delta - star connection
	Power transformer star - star - delta connection
	Single phase transformer
	Oil circuit breaker
	Surge arrester
	Line switch
	Air breaker switch or Oil switch
	Power fuse
	Over current relay
	Over current grounding relay
	Over voltage grounding relay
	Under voltage relay
	Over voltage relay
	Compensating resistor
	Grounding potential transformer
	Current transformer
	Watt - meter

	Watt hour meter
	Var meter
	Voltmeter
	Ammeter
	Maximum voltmeter
	Maximum ammeter
	Ammeter change over switch
	Voltmeter change over switch or selector switch
	Molded-case air circuit breaker
	Rectifier
	Battery

A-9

CAPACITY AND LOCATION OF POLE MOUNTED TRANSFORMER

Table III-4-1 Capacity & Location of Pole Transformers
 For exclusive use transformer for Estate etc, diversity factor of 1.3 is not applicable.

1. Hai

Village & Estate intended for power supply	Load Forecast (kW)					Total	Calculation (kVA) = Forecast (kW) ÷ 0.9 ÷ 1.3 + 0.6"	Capacity (kVA) of Transformer	Location of Transformers
	T ₁	T ₂	T ₃	T ₄	T ₅				
Mwanza Estate			20.0			20.0	22.2	50	Mwanza Estate
Gararagua Estate			80.0			80.0	88.9	100	Gararagua Estate
Lelongo Estate			40.0			40.0	44.4	50	Lelongo Estate
Kifufu Estate				80.0		80.0	88.9	100	Kifufu Estate
Pongo Estate			20.0			20.0	22.2	50	Pongo Estate
Molomo Estate			40.0			40.0	44.4	50	Molomo Estate
Leoni Estate			20.0			20.0	22.2	50	Leoni Estate
Msingi Estate			20.0			20.0	22.2	50	Msingi Estate
Kifaru Estate			20.0			20.0	22.2	50	Kifaru Estate
Annahof Estate			20.0			20.0	22.2	50	Annahof Estate
Sanya Juu	16.6	15.7	-		0.8	31.1	44.3	50	Sanya Juu
Koboko, Nrao, Samaki, Maini	21.5	17.9	22.2		1.0	62.6	89.2	50 25	Koboko Siha
Pynta Estate				80.0		80.0	88.9	100	Pyrita Estate
Wandri	9.9	35.4	72.8		0.5	118.6	168.9	100 50	Fuka Fuka

Village & Estate intended for power supply	Load Forecast (kW)					Total	Calculation (kVA) = Forecast (kW) ÷ 0.9 ÷ 1.3 ÷ 0.6 = Transformer	Capacity (kVA) of Transformer	Location of Transformers
	T ₁	T ₂	T ₃	T ₄	T ₅				
Mac. Kyeungia	16.5	16.1	36.5	50.0	0.8	120.0	170.9	50 100	Mae Kibongto Hospital
Liwati	7.3	5.2	9.5		0.4	22.4	31.9	25	Liwati
Koshashi, Lukani	16.4	8.8	60.8		0.8	86.8	123.6	50x2	Suumu Lukani
Kyuu, Losaa, Ngumi	31.5	16.1	57.2		1.5	106.3	151.4	50x3	Kyuu, Losaa, Ngumi
Bondeni Estate				50.0		50.0	55.6	50	Bondeni Estate
Boloti Estate			30.0			30.0	33.3	50	Boloti Estate
Nkwansira Estate			80.0			80.0	88.9	100	Nkwansira Estate
Nkwansira	5.2	3.7	14.0		0.3	23.2	33.1	25	Nkwansira
Lemira, Kati, Isiki	8.9	15.4	32.5		0.4	57.2	81.5	25 50	Kati Lemira
Nroma, Mbwera	17.8	19.7	53.7		0.9	91.8	130.8	50x2	Nroma, Mbwera
Masama Hospital		20.0				20.0	22.2	25	Masama Hospital
Mudio	14.9	7.6	14.4		0.7	37.6	53.6	50	Mudio
Roo	11.2	4.9	38.2		0.5	54.8	78.1	25 50	Roo Roo
Kikafu Estate			40.0			40.0	44.4	50	Kikafu Estate
Kibo Estate				400.0		400.0	444.4	500	Kibo Estate
Uwau Estate			40.0			40.0	44.4	50	Uwau Estate
Kwate	7.9	4.4	18.7		0.4	31.4	44.7	50	Kwate

Village & Estate intended for power supply	Load Forecast (kW)					T _s	Total	Calculation (kVA) = forecast (kW) ÷ 0.9 ÷ 1.3 ÷ 0.6*	Capacity (kVA) of Transformer	Location of Transformers
	T ₁	T ₂	T ₃	T ₄	T ₅					
Mbosho Estate			50.0				50.0	55.6	50	Mbosho Estate
Mbosho	5.2	3.7	14.0		0.3	23.2	23.2	33.1	25	Mbosho
Salali, Sawe, Kyeeri	24.9	16.7	106.3		1.2	149.1	149.1	212.4	50x3 25	Salali, Uraa, Sawe, Kyeeri
Sonu, Ngira	13.3	12.1	31.7		0.6	57.7	57.7	82.0	25 50	Sonu Ngira
Nronga, Foo	22.0	14.7	48.2		1.1	86.0	86.0	122.5	50x2	Nronga Nkweseko
Boma La Ngombe	6.2	10.5			0.3	17.0	17.0	24.2	25	Boma La Ngombe
B. La Ngombe New Town									100	Boma La Ngombe
Mukufi Estate			20.0			20.0	20.0	22.2	50	Mukufi Estate
Mokoa			40.0			40.0	40.0	44.4	50	Mokoa Estate

Table III-4-2 Capacity & Location of Pole Transformers

Village & Estate intended for power supply	Load Forecast (KW)					Total	Calculation (KVA) = Forecast (KW) $\div 0.9 \div 1.3 \div 0.8$	Capacity (KVA) of Transformer	Location of Transformers
	T ₁	T ₂	T ₃	T ₄	T ₅				
2. Rombo Komakunai, Kotela, Kira Kimangara, Mkolowoni	24.8	18.6			1.6	45.0	64.1	25 50	Kinangaro Kisambo
	21.3	17.1	3.0		1.5	42.7	60.8	25 50	Lyakirini Nganyeni
Loie, Mareia, Maringa Minangaro, Mrimbo	29.2	17.7	6.0		1.8	54.7	77.9	50 25	Mwika Maringa
	28.3	11.2	9.6		1.2	50.9	72.5	25 50	Manda Mengwe
Kitasha, Mengeni Chini Aleni Chini, Machami Aleni	30.6	10.5	2.0		1.9	45.0	69.1	50 25	Keni Isia
	27.6	27.0	1.0		1.7	57.3	81.6	25 50	Mangulwa Mkuu

Village & Estate intended for power supply	Load Forecast (kW)					Total	Calculation (kW) = Forecast (kW) + 0.9 + 1.3 + 0.6*	Capacity (kVA) of Transformer	Location of Transformers
	T ₁	T ₂	T ₃	T ₄	T ₅				
Huruma New Twon								100x3	Huruma
Ubaa, Mokala Kolamfua, Ushiri	25.2	12.1	19.1		1.5	55.9	79.6	50 25	Ubaa Mrembe
Keryo, Miao, Kirwa Keni	29.2	12.0	12.8		1.8	55.8	79.5	50 25	Mroa Kirwa
Mreere, Karangara	20.3	16.0	25.9		1.3	63.5	90.5	50x2	Mreere
Kisare, Mahorosha Kilena, Kitowo	23.7	11.9	12.8		1.5	49.9	71.1	25 50	Mashati

Table III-4-3 Capacity & Location of Pole Transformers

3. North Pare

For exclusive use transformer for Estate etc, diversity factor of 1.3 is not applicable.

Village & Estate intended for power supply	Load Forecast (kW)					Total	Calculation (KVA) = Forecast (kW) ÷ 0.9 ÷ 1.3 ÷ 0.6*	Capacity (kVA) of Transformer	Location of Transformers
	T ₁	T ₂	T ₃	T ₄	T ₅				
Kisangara Sisal Estate				210.0		210.0	233.3	300	Kisangara Sisal Estate
Kisangara	8.1	18.3	14.1		0.5	41.0	58.4	50	Kisangara
Mwanga	5.1	27.4	6.4		0.4	39.3	56.0	50	Mwanga
Mwanga New Town								100	Mwanga New Town
Mruma								25	Mruma
Msangeni, Mamba	6.2	9.8	6.4		0.4	22.8	32.5	25x2	Msangeni Kikweni
Masanbeni, Kisanjuni Raa	14.8	21.7	19.0		0.5	56.0	80.0	25 50	Mbale Chogho
Shigatini, Ndinda, Kiriche	10.0	27.5	6.4		0.6	44.5	63.4	25x2	Shigatini, Ndinda
Kilaweni, Kighare, Vuanga	8.7	39.4	22.5		0.6	71.2	101.4	25 50	Kilaweni
Kirongaya, Chomuu Lomwe, Mshewa	11.8	8.5	40.0		0.8	61.1	87.0	25x2 50	Chomuu, Lome Sido

Table III-4-4 Capacity & Location of Pole Transformers
 For exclusive use transformer for Estate etc, diversity factor of 1.3 is not applicable.

4. South Pore

Village & Estate intended for power supply	Load Forecast (kW)				T ₅	Total	Calculation (kVA) = Forecast (kW) ÷ 0.9 ÷ 1.5 ÷ 0.6*	Capacity (kVA) of Transformer	Location of Transformers
	T ₁	T ₂	T ₃	T ₄					
Mwembe, Mreke, Mrunguja	12.7	15.9	18.8		0.8	48.2	68.7	25 50	Mwembe
Mukonga, Kisiwani	13.8	24.5	18.8		0.9	58.0	82.6	25 50	Mukonga Kisiwani
Kisiwani Estate				150.0		150.0	166.7	200	Kisiwani Estate
Maore	12.4	23.8	12.8		0.8	49.8	70.9	25 50	Maore Gonja
Gonja Estate				200.0		200.0	222.2	300	Gonja Estate
Mpirani	4.6	11.7			0.3	16.6	23.6	25	Mpirani
Mjema, Bombo, Mvaa	8.7	17.7		50.0	0.6	77.0	109.7	25 100	Mjema Bombo Hospital
Ndungu Estate				100.0		100.0	111.0	200	Ndungu Estate
Ndungu, Misufuni	18.3	24.3			1.2	45.8	62.4	25x2	Ndungu

A-10

SPARE PARTS

List of Spare Parts

Item	Specification	Q'ty
1. Line Post Insulator	33 kV LP-30	50 p.c.s
2. Pin Type Insulator	11 kV	50 p.c.s
3. Disc Insulator	254 mm x 146 mm	50 p.c.s
4. Transformer	11/4 kV 50 kVA	2 p.c.s
5. ditto	11/4 kV 25 kVA	2 p.c.s
6. ditto	33/4 kV 50 kVA	2 p.c.s
7. Primary cut-out switch	14.4 kV	20 p.c.s
8. ditto	24.5 kV	10 p.c.s
9. Surge arrester	14 kV	20 p.c.s
10. ditto	42 kV	10 p.c.s
11. Watt hour meter		20 p.c.s

JICA