

APPENDIX VIII

**PUMPING STATION
AND
DESILTING BASIN**

APPENDIX VIII

PUMPING STATION AND DESILTING STATION

CONTENTS

	PAGE
1. TYPE OF PUMPING STATION	VIII-1
1-1. TYPE OF PUMPING STATION	VIII-1
1-2. COMPARATIVE STUDY FOR THE PUMPING STATION	VIII-2
1-3. ALTERNATIVE STUDY FOR THE PUMPING STATION FOR BARIND AREA ..	VIII-24
1-3-1. Alternative Plan	VIII-24
1-3-2. Dimension of Pumping Facilities for Alternative Plan	VIII-25
1-3-3. Cost Estimate	VIII-29
1-3-4. Results of the Cost Estimate	VIII-29
2. TYPE OF PUMP	VIII-36
2-1. DECISION OF THE PUMP TYPE	VIII-36
3. DESIGN OF PROPOSED PUMPING STATION	VIII-38
3-1. DECISION OF BASIC FACTORS FOR THE PUMPING FACILITIES	VIII-38
3-1-1. Basic Factors for Design of Pumps	VIII-38
3-1-2. Type of Pumping Station and Pumping Facility	VIII-46
3-1-3. Diameter and Number of Pump	VIII-59
3-1-4. Selection of Total Head	VIII-59
3-1-5. Specific Dimension of Pumps	VIII-60
3-2. DESIGN OF PUMPING STATION	VIII-60
3-2-1. Design of intake canal	VIII-60
3-2-2. Design of Inlet on Pumping Station	VIII-63
3-2-3. Scale of Pumping Station	VIII-64
3-2-4. Foundation Treatment and Protection Dike	VIII-69
3-2-5. Design of Delivery Pond	VIII-72
3-2-6. Dual Purpose Pumps for Irrigation and Drainage at Kasba Pumping Station	VIII-74
3-2-7. Power Supply	VIII-78

LIST OF TABLES

	PAGE
TABLE VIII-1-1 TYPES OF PUMPING STATIONS	VIII-3
TABLE VIII-1-2 COMPARISON OF PUMPING STATION TYPE	VIII-7
TABLE VIII-1-3 COMPARISON OF COST FOR EACH TYPE	VIII-8
TABLE VIII-1-4 PUMP FACILITIES COST OF EACH TYPE	VIII-8
TABLE VIII-1-5 CONSTRUCTION COST PER 20 m ³ /sec	VIII-9
TABLE VIII-1-6 CONSTRUCTION COST OF PIPE LINE	VIII-11
TABLE VIII-1-7 OPERATION HOUR OF PUMP	VIII-15
TABLE VIII-1-8 DIMENSION OF PUMPING FACILITIES	VIII-26
TABLE VIII-1-9 COMPARISON OF COST FOR EACH CASE	VIII-30
TABLE VIII-1-10 COMPARISON OF COST FOR EACH CASE	VIII-31
TABLE VIII-1-11 PUMPING FACILITIES COST	VIII-32
TABLE VIII-1-12 CONSTRUCTION COST PER 20 m ³ /sec	VIII-33
TABLE VIII-1-13 OPERATION & MAINTENANCE FACILITIES COST	VIII-34
TABLE VIII-1-14 RUNNING COST	VIII-35
TABLE VIII-3-1 DIMENSION OF PUMP	VIII-39
TABLE VIII-3-2 MONTHLY MEAN WATER LEVEL	VIII-44
TABLE VIII-3-3 DIVERSION WATER REQUIREMENT	VIII-45
TABLE VIII-3-4 NUMBER OF PUMP UNIT (BARIND AREA)	VIII-47
TABLE VIII-3-5 NUMBER OF PUMP UNIT (FLOOD PLAIN AREA)	VIII-48
TABLE VIII-3-6 ANNUAL COST OF EACH CASE	VIII-49
TABLE VIII-3-7 PUMPING FACILITIES COST (BARAIPARA P.S)	VIII-51
TABLE VIII-3-8 PUMPING FACILITIES COST (KASBA P.S)	VIII-52
TABLE VIII-3-9 ELECTRICITY CHARGE	VIII-54

TABLE VIII-3-10	PUMP OPERATION UNITS OF EACH MONTH Actual Head 21.9 m	VIII-55
TABLE VIII-3-11	PUMP OPERATION UNITS OF EACH MONTH Actual Head 12.0m	VIII-57

LIST OF FIGURES

FIGURE VIII-1-1	DIMENSION OF DOUBLE VOLUTE PUMP	VIII-12
FIGURE VIII-1-2	DIMENSION OF INCLINED MIXED FLOW PUMP	VIII-13
FIGURE VIII-1-3	DIMENSION OF VERTICAL MIXED FLOW PUMP	VIII-14
FIGURE VIII-1-4	PUMP CHARACTERISTIC CURVE OF DOUBLE VOLUTE	VIII-17
FIGURE VIII-1-5	PUMP CHARACTERISTIC CURVE OF INCLINED PUMP	VIII-18
FIGURE VIII-1-6	PUMP CHARACTERISTIC CURVE OF VERTICAL MIXED FLOW PUMP	VIII-19
FIGURE VIII-1-7	PUMP CHARACTERISTIC CURVE OF VERTICAL MIXED FLOW PUMP	VIII-20
FIGURE VIII-1-8	AVERAGE IRRIGATION REQUIREMENT AND WATER LEVEL	VIII-21
FIGURE VIII-1-9	VERTICAL MIXED FLOW PUMP	VIII-22
FIGURE VIII-1-10	INCLINED PUMP	VIII-23
FIGURE VIII-1-11	LOCATION MAP OF CASE STUDY -CASE I ,III	VIII-27
FIGURE VIII-1-12	LOCATION MAP OF CASE STUDY -CASE II ,IV	VIII-28
FIGURE VIII-3-1	DIVERSION WATER REQUIREMENT (BARIND AREA)	VIII-40
FIGURE VIII-3-2	IRRIGATION REQUIREMENT AND WATER LEVEL (BARIND AREA)	..	VIII-41
FIGURE VIII-3-3	DIVERSION WATER REQUIREMENT (FLOOD PLAIN AREA)	VIII-42
FIGURE VIII-3-4	IRRIGATION REQUIREMENT AND WATER LEVEL (FLOOD PLAIN AREA)	VIII-43
FIGURE VIII-3-5	COST OF PUMP AND MOTOR	VIII-53
FIGURE VIII-3-6	PUMP CHARACTERISTIC CURVE (BARAIPARA P. S)	VIII-56
FIGURE VIII-3-7	PUMP CHARACTERISTIC CURVE (KASBA P. S)	VIII-58
FIGURE VIII-3-8	PARTICLE DISTRIBUTION OF BED MATERIAL OF THE GANGES RIVER	VIII-62

FIGURE VIII-3-9 PUMP SUCTION	VIII-65
FIGURE VIII-3-10 PUMP PIT	VIII-66
FIGURE VIII-3-11 BARAIPARA PUMPING STATION	VIII-67
FIGURE VIII-3-12 KASBA PUMPING STATION	VIII-68
FIGURE VIII-3-13 CHARACTERISTIC CURVE $124 \text{ m}^3/\text{m} \times 13 \text{ m} \times 1,000 \times 370 \text{ kw}$	VIII-76
FIGURE VIII-3-14 CHARACTERISTIC CURVE $247 \text{ m}^3/\text{m} \times 13 \text{ m} \times 1,350 \text{ mm} \times 720 \text{ kw}$..	VIII-77
FIGURE VIII-3-15 TRANSMISSION LINE	VIII-79

1. TYPE OF PUMPING STATION

1-1. Type of Pumping Station

The water required for the Project will be diverted directly from the Ganges rivers. In case the irrigation water is lifted from the rivers by pumps, the following three types of structure are generally put for comparative study :

(1) Floating type structure

All pump facilities are furnished on a floor of barge or pontoon in order to cope with the water stage fluctuation in the river and also river course shifting.

(2) Inclined Type Structure

The pump facilities are installed along the side slope of the river embankment. This type is applicable when the river course is stable.

(3) Fixed Type Structure

The pump facilities are installed inside the existing river bank with connection canals constructed to conduct water.

The above three types were carefully compared in due consideration of the adaptability with the sites, construction cost and operation and maintenance cost. The following definitions were employed in the study :

- Design Discharge	20m ³ /sec	
- Design Water Level	Low Water level	9.6 m
	High Water level	20.0 m
	Delivery Water level	30.5 m
- Existing Embankment height		20.0 m
- Actual Head	20.9 m	
- Total Head	26.0 m	

Based upon the above definitions, main facilities of the pumps systems are designed as in the following table :

Items	Floating Type	Inclined Type	Fixed Type	
Type	Horizontal Axis of Volute Type	Inclined Axis with mixed flow	Vertical Axis with mixed flow	
Design Discharge (m ³)	120	120	240	360
Diameter (mm)	1,000	1,000	1,350	1,650
P × r.p.m	14×420	10×593	16×370	20×290
Total Head (m)	26	26	26	26
Output (kw/unit)	670	670	1,430	2,120
No. of Pumps	10	10	2	2
Total Output (kw)	6,700	6,700	7,100	

In this connection, a submergible motor pump are also evaluated but finally excluded from the comparative study due to the following reasons :

- Cost of the motor is extremely high.
- Supply of spare parts is very difficult
- O & M cost shall be expensive

1-2. Comparative Study for the pumping station

Three types of pumping station were comparatively studied and summarized in TABLE VIII-1-1 — VIII-1-6.

Regarding general lay-out, these are prepared lay-out drawing in FIGURE VIII-1-1 — VIII-1-3.

As a results of comparative studies, the fixed type of pump station is recommendable for the project under the following reasons.

- The construction cost is cheaper than the other two types
- The operation and maintenance costs are less than the other two types

Concerning the sedimentation, countermeasures shall be required for all of the types of pumping station.

TABLE VIII-1-1 (1) TYPES OF PUMP STATIONS

Items	Type			Fixed Type
	Location	Floating Type		
	At main stream (A)	At intake canal (B)	At intake canal (Semi-Fixed Type)(C)	At intake canal (D)
1. Pump Equipment (1) Impeller	Pumps should lift up river water directly from main stream, which is inclusive of more sediments so that, the impeller should be taken the abrasion	The intake canal shall be taken off the sediment from the river water, so that abrasion of impeller should be less than(A) and the durable period shall be longer than (A)		
(2) Cavitation	The water elevation vary within 10 meter through a year. During the higher water level, the delivery discharge should be increased at about 150 percent, and these are occurrence of the cavitation in the pump equipment and control valve. In order to protect such phenomena, rotary valve shall be required to be installed in delivery pipes, and they are very costly.			In case of vertical type pumps and inclined type pumps, the following situation is keeping in any case of variation of suction head. $NBSH_{av} \geq NPSH_{re}$ NPSH ; Net positive Suction Head av ; Available re ; Required Accordingly, there are no occurrence of cavitation, and the discharge can be control with simple valve operation.

TABLE VIII-1-1 (2) TYPES OF PUMPING STATIONS

Items	Type Location	Floating Type			Fixed Type
		At main stream (A)	At intake canal (B)	At intake canal (Semi-Fixed Type)(C)	
2. Electric Power Cable		Electric power cable should be laid with floater in the river or intake canal. In this case, the low voltage cable shall be required to avoid the damage of electric leakage. If the Barges required to remove, it is necessary to prepare additional cables, and then its required additional labour cost and less time.		At intake canal No there are problem	At intake canal (D)
3. Barges		A part of joint between delivery pipes of pumps and the pipe line of land should be fixed with concrete anchors. On the other hands, the barges should be required to remove at any time, and it is not only up and down but also at front and rear. Accordingly, the adjustment in above case should be done with removal of Barges anchor.			No there are problem
4. Shifting of the river course		The Barges shall be removed as a counter measure for river shifting. However, the floating pipes and cable are required to be extension or reduction.		If the river course removed far away from existing embankment, a intake canal should be extended upto the necessary distance. On the other hand, the protection facilities should be constructed for the reverse phenomena.	

TABLE VII-1-1 (3) TYPES OF PUMPING STATIONS

Items	Type Location	Floating Type			Fixed Type
		At main stream (A)	At intake canal (B)	At intake canal (Semi-Fixed Type)(C)	
5. Sedimentation		<p>Barges should be removed to other point available. However, the floating pipes and cables are required to remove at the same time. Furthermore, fixed land structures should be necessary to have reconstructed after the removal</p>		<p>At intake canal</p>	<p>At intake canal (D)</p>
6. Operation and Maintenance		<p>As compared with fixed type pumping station, the barge, floating pipes and cables are required to have supporting facilities for operation and maintenance. Particularly, the space yards for the repairing should be required for barges.</p>			<p>Pumping facilities are necessary to have regular maintenance same as the floating pumps. Housing and supporting structure shall be required to have regular maintenance. However, they are not so difficult as compared with floating type pumping station.</p>

TABLE VII-1-1 (4) TYPES OF PUMPING STATIONS

Items	Floating Type			Fixed Type
	At main stream (A)	At intake canal (B)	At intake canal (Semi-Fixed Type)(C)	
7. Conclusion	<p>As mentioned above, the floating type has several kinds of problems in view point of technics. Furthermore, construction cost is the highest as compared with other three types. So that, this is not recommendable for the project.</p>	<p>There are no merits for the river shifting and sedimentation as compared with fixed type. Therefore, this not so recommendable.</p>	<p>As compared with the other two floating types, the structure of floating pipes and cables can be simplified because of semi-fixed anchor However, it is not so expected to have much merit.</p>	<p>At intake canal (D) As far as concerning the river shifting, and sedimentation, there are some weak point. Particularly, concerning the sedimentation, it can be solved by dredging system. As for operation and maintenance, this type is the most acceptable for the project. Taking into consideration aboved reasons, this type is the most recommendable for this project.</p>

TABLE VIII-1-2 COMPARISON OF PUMP STATION TYPE




Pump Station Type Item	Fixed Type			Floating Type
	Vertical Type	Inclined Type	Inclined Type	
Pump Type	 <p>Motor Vertical Mixed Flow Pump Suction Check Valve</p>	 <p>Motor Inclined Mixed Flow Pump Suction Check Valve</p>	 <p>Gate Valve Volute Pump Barge Suction Check Valve</p>	<p>1000 mm : 2.0 ~ 2.5 m³/s</p>
Maximum Pump Bore and Capacity	<p>2800 mm : 19.0 m³/s</p>	<p>1000 mm : 2.0 ~ 2.5 m³/s</p>	<p>1000 mm : 2.0 ~ 2.5 m³/s</p>	<p>1000 mm : 2.0 ~ 2.5 m³/s</p>

TABLE VIII-1-3 COMPARISON OF COST FOR EACH TYPE (1,000TK)

Item	Type	Fixed Type		Floating Type
		Vertical Type	Inclined Type	
Pump Facilities Cost *1		337,100	432,000	345,500
Pump House *2		10,120	16,230	300,000 (Barge)
Construction Cost *2		34,150	22,850	2,530
Initial Cost		381,370	471,080	648,030
Annual Repayment		×0.1714 65,366	×0.1714 80,743	×0.1714 111,072
Electric Charge *3		38,835	39,479	36,037
Total Annual Cost		104,201 (100%)	120,222 (115%)	147,109 (141%)

*1 Refer to TABLE VI-1-4

*2 Refer to TABLE VI-1-5

*3 Refer to TABLE VI-1-7

TABLE VIII-1-4 PUMPING FACILITIES COST OF EACH TYPE (1,000TK)

Item	Type	Fixed Type		Floating Type
		Vertical Type	Inclined Type	
[Per 20m ³ /s]		∅1,650, ∅1,350	∅1,000	∅1,000
Pump		95,500	143,600	79,600
Motor		2,150 ^{kw} , 1,430 ^{kw}	670 ^{kw}	670 ^{kw}
		103,800	98,500	110,800
Valve, Pipe		31,700	32,200	36,600
Crane		10,400	4,500	4,500
Electric Equipment		24,700	47,300	47,800
Equipment Work		51,100	75,000	41,700
Transportation		19,900	30,900	24,500
Total Cost		337,100	432,000	345,500

TABLE VII-1-5 CONSTRUCTION COST PER 20 %

(1000TK)

Item	Type	Unit	Floating Type		Inclined Type		Fixed Type	
			Quantity	Cost	Quantity	Cost	Quantity	Cost
1. Earth Work								
Excavation		TK/m ³ 31	m ³ 36,160	1,120	m ³ 96,891	3,003	m ³ 79,638	2,467
2. Concrete Work								
Reinforced concrete		TK/m ³ 2,181		—	m ³ 722	1,574	m ³ 1,844	4,021
Form Work		TK/m ² 175		—	m ² 923	161	m ² 3,856	674
Reinforcing bar Work		TK/t 20,360		—	t 28.9	588	t 147.5	3,003
3. Brick Work		TK/m ² 400	m ² 2,470	988	m ² 7,935	3,174	m ² 6,978	2,791
4. Steel pile 1 J		TK/Unit 155,000		—	Unit 68	10,540	Unit 100	15,500
5. Others		20%		422		3,810		5,694
Total		TK/m ³ 23,600		2,530		22,850		34,150
6. Building Works				—	m ² 688	16,230	m ² 429	10,120
7. Barge				300,000		—		—

1] Refer to unit cost of Steel pile

Unit Cost

Steel Pile $\phi 500\text{mm} \times 40\text{m}$ (t.9mm)

$$V = 60\text{min} \times 6.7\text{hr} / \text{TC min} = 402/273 = 1.5 \text{ set/day}$$

$$\text{TC} = (\text{Tp} + \text{Tb} + \text{Tw}) \times \alpha / \text{B}$$

$$= (36 + 40 + 88) \times 1.5 / 0.9 = 273\text{min}$$

$$\text{Tp} = 5 \cdot n + 11 = 5 \times 5 + 11 = 36\text{sec}$$

$$\text{Tb} = K \alpha L \beta = 1.0 \times 1.2 \times 40^{0.95} = 40\text{sec}$$

$$\text{Tw} = 22 \times 4 = 88\text{sec}$$

$$\text{B} = 0.9$$

$$\alpha = 1.5$$

Steel Pile $\phi 500\text{mm} \times 40\text{m}$

$$109\text{kg/m} \times 40\text{m} \cdot 97.060\text{TK/t} \times 1.3$$

$$\approx 153,000 \text{ TK}$$

$$(1,290 + 110) \times 2/1.5$$

$$\approx 2,000$$

$$155,000 \text{ TK}$$

TABLE VIII-1-6 CONSTRUCTION COST OF PIPE LINE
(1000TK)

Item	Diameter				
	2000 mm	1800 mm	1600 mm	1350 mm	1200 mm
6meterlong Pipe	242.3	194.4	151.5	111.5	92.7
Others	3.7	3.0	2.5	1.9	1.6
Sub - Total	246.0	197.4	154.0	113.4	94.3
(perday) Constraction	1.8	2.0	2.2	2.6	3.0
Labour	1.5	1.4	1.4	1.4	1.3
Crane	3.2	2.5	2.0	1.8	1.8
Sub - Total	2.6	2.0	1.5	1.2	1.0
Welding	76.4	64.5	61.4	46.7	42.0
(per6meter) Total	325.0	263.9	216.9	161.3	137.3
Per meter	54.2	44.0	36.2	26.9	22.9






FIGURE VII-1-1 DIMENSION OF DOUBLE VOLUTE PUMP

Main Dimension of Pump	
Type	Horizontal Double Volute Pump
Bore	1000 mm
Capacity	120 m ³ /min
Total Pumping lift	26 m
Pump Speed	420 rpm
Motor Power	670 kw
Units	10 #




DIMENSION OF INCLINED MIXED FLOW PUMP

FIGURE VII-1-2




Main Dimension of Pump	
Type	Inclined Mixed Flow Pump
Bore	1000 mm
Capacity	120 m ³ /min
Total Pumping Lift	26 m
Pump Speed	490 rpm
Motor Power	730 kw
Units	10 ty



DIMENSION OF VERTICAL MIXED FLOW PUMP

FIGURE VII-1-3



Main Dimension of Pump	
Type	Vertical Mixed Flow Pump
Bore	1350mm 1650mm
Capacity	240 ^{m³} /m 350 ^{m³} /m
Tidal Pumping Lift	26m 26m
Pump Speed	420rpm 330rpm
Motor Power	1430kw 2120kw
Units	2 ts 2 ts




TABLE VII-1-7 OPERATION HOUR OF PUMP

Date	Unit duty of Water	Irrigable Area	Irrigation Requirement	Water Level	Volute Pump		Inclined Pump		Vertical Mixed Flow Pump		
	I/S/ha				ha	Q ㎥	Hr	Q ㎥	Hr	Q ㎥	Hr
Mar	1	1.198	40.060×0.8	38.394	9.60	2.00	4.608	2.00	4.608	20.00	461
	2	1.198	"	38.394	"	"	"	"	4.608	"	461
	3	0.871	"	27.914	"	"	3.685	"	3.685	"	368
Apr	1	0.783	"	25.094	"	"	3.011	"	3.011	"	301
	2	0.612	"	19.613	"	"	2.354	"	2.354	"	235
	3	0.203	"	6.506	"	"	781	"	781	"	78
July	1	0.642	40.060	25.719	14.00	2.32	2.661	2.23	2.768	22.20	278
	2	0.929	"	37.216	17.00	2.52	3.544	2.37	3.769	23.16	386
	3	0.671	"	26.880	20.00	2.72	2.609	2.53	2.805	23.84	298
Aug	1	0.558	"	22.353	20.00	"	1.972	2.53	2.120	23.84	225
	2	0.532	"	14.101	20.00	"	1.244	2.53	1.338	23.84	142
Nov	1	0.067	40.060×0.8	2.147	14.00	2.32	222	2.23	231	22.20	23
	2	0.123	"	3.912	11.00	2.10	447	2.10	441	21.12	44
	3	0.884	"	28.330	"	"	3.238	"	3.192	"	322
Dec	1	1.026	"	32.881	"	"	3.758	"	3.705	"	374
	2	1.243	"	39.836	"	"	4.553	"	4.489	"	453
	3	1.300	"	41.662	"	"	5.238	"	5.163	"	521
Jan	1	0.422	"	13.524	9.60	2.00	1.623	2.00	1.623	20.00	162
	2	0.396	"	12.691	"	"	1.523	"	1.523	"	152
	3	0.437	"	13.128	"	"	1.733	"	1.733	"	173
Feb	1	0.746	"	23.908	"	"	2.869	"	2.869	"	287
	2	0.746	"	23.908	"	"	2.869	"	2.869	"	287
	3	0.746	"	23.908	"	"	2.295	"	2.295	"	230
Total	3.75TK/KWH						2.607		2.468		256
	1.65TK/KWH						58.838		59.512		6.005

1] Barind Area

2] Refer to FIGURE - VII-1-4 , VII-1-8

3] Refer to FIGURE - VII-1-5 , VII-1-8

4] Refer to FIGURE - VII-1-6, 7, 8

Estimation of Electric Charge.

Electric charge was estimated by the following procedure ;

- (1) Service charge for one pumping station 400 TK/month
- (2) Basic fixed charge 35 TK/year
- (3) Consumption cost
 - March - September PM 6:00 - PM 10:00 (4hr) 3.75 TK/kwh
 - October - February PM 5:00 - PM 9:00 (4hr)
 - Others 9.65 TK/kwh
- (4) Capacities of Pump $20 \text{ m}^3/\text{s} \times 2 \text{ set}$

Item	Type of Station	Floating Type × 1,000TK	Inclined Type × 1,000TK	Fixed Type × 1,000TK
(1) Service Charge 400TK/day/station		× 12 ^{month} × 2places = 9.6	× 12 ^{month} × 2places = 9.6	× 12 ^{month} × 2places = 9.6
(2) Basic Fixed Charge 35 TK/kw/year		× 670kw × 10unit × 2places = 469.0	× 730kw × 10unit × 2places = 511.0	× (1,430+2,120) × 2 × 2 = 497.0
(3) Consumption Cost 3.75 TK/kwh 1.65 TK/kwh		× 2,607Hr × 670kw = 6,550.0 × 58,838Hr × 670kw = 65,045.4	× 2,648Hr × 730kw = 6,756.1 × 59,512Hr × 730kw = 71,682.1	× 256Hr × 7,100kw = 6,816.0 × 6,005Hr × 7,100kw = 70,348.5
Total		72,074.0	78,958.9	77,671.1
1 set (Q = 20 m ³ /s)		36,037	39,479.4	38,835.5

Figure VIII-1-4




Figure VIII-1-5




Figure VIII-1-6




Figure VII-1-7




FIGURE - VIII-1-8 AVERAGE IRRIGATION REQUIREMENT AND WATER LEVEL




FIGURE VIII-1-9 VERTICAL MIXED FLOW PUMP







FIGURE VII-1-10 INCLINED PUMP



1-3. Alternative Study for the Pumping Station for Barind Area

1-3-1. Alternative Plan

The proposed site for pumping stations have been selected at Baraipara on the basis of the river bank shifting records and cross section survey results of the Ganges river.

Sultanganj is also suitable to propose for a pumping station but it should be limited to utilize during the wet season only due to the sand dune in the river mouth of the Mahananda river during the dry season.

Accordingly, the following three alternatives will be compared each other to select the most suitable pump site and pumping station type.

(1) Alternative 1.1' (See FIGURE VIII-1-11)

Revised plan of the selected plan No. 2 in the Interim Report ; i.e. since the Godagari site is not suitable for pumping stations as explained in Paragraph 2-2. The Baraipara site can be proposed for the pumping site for floating type for $34.0 \text{ m}^3/\text{sec}$ instead of the Godagari site. A connecting canal to the existing natural depression for about 2.2 km will be necessary to be added to convey the water from Baraipara to Sultanganj.

At Sultanganj, pumping equipment to lift up the water from the Mahananda river for $6.0 \text{ m}^3/\text{sec}$ together with the secondary lifting pumps of water from Baraipara for $34.0 \text{ m}^3/\text{sec}$ will be necessary to be facilitated in the pump stations. This total capacity of $40 \text{ m}^3/\text{sec}$ can also be utilized to lift the water from the Mahananda river during wet season.

(2) Alternative - 2 (See FIGURE VIII-1-12)

The Baraipara is the only site for pumping station where the water can be lifted up throughout a year.

Instead of floating type, the standard fixed type pumping station can be proposed at Baraipara.

(3) Alternative - 3 (See FIGURE VIII-1-11)

Alternative Plan 3 proposes a direct lifting up of the Ganges river water to the delivery pond at EL 30.5 m PWD by the floating pump with the capacity of 40 m³/sec.

(4) Alternative - 4 (See FIGURE VIII-1-12)

The fixed pumping station (Inclined Mixed Flow Pump) can be proposed at Baraipara instead of the floating pump.

1-3-2. Dimension of Pump Facilities on Alternative Plan

As mentioned above four kinds of alternative plans are considered. Necessary facilities for each plan are considered as in the following TABLE VIII-1-8.

TABLE - VIII-1-8 DIMENSION OF PUMP FACILITIES

Pump Station	Case I		Case II	Case III	Case IV
	Sultanganj P.S (Fixed)	Baraipara P.S (Float)	Baraipara P.S (Fixed)	Baraipara P.S (Float)	Baraipara P.S (Fixed)
Irrigation Requirement (m ³ /s)	6.0	34.0	40.0	40.0	40.0
Water Level H.W.L (m)	20.4	20.4	20.4	20.4	20.4
L.W.L (m)	9.9	9.6	9.6	9.6	9.6
Discharge Water Level (m)	30.5	30.5	30.5	30.5	30.5
Actual Head (m)	20.6	11.2	20.9	20.9	20.9
Loss Head (m)	3.5	3.5	5.0	5.0	5.0
Total Head (m)	24.1	14.7	25.9	25.9	25.9
Pump Type	Vertical Mixed Flow Pump	Volute Pump OR Inclined M.F.P	Vertical Mixed Flow Pump	Double Volute Pump	Inclined Mixed Flow Pump
Bore (mm)	1650	1650 1350	1650 1350	1000	1000
Capacity (m ³ /s)	6.0	4.0	6.0	4.0	2.0
Motor Power (kw)	2000	1220 830	2100 1400	670	670
Pump Efficiency (%)	84.5	84.5 83.5	84.5 83.5	85	85
Pump Unit	1	3 4	4 4	20	20
Pipe Line Diameter (mm)	2000	2000	2000	2000	2000
Length (km)	0.8	0.8	1.5	1.5	1.5
Unit	1	4, 3	2, 4	2, 4	2, 4

Figure VIII-1-11 CASE I AND III


Proposed Pump Station
at Sultanganj
(Fixed Type)

Delivery pipe 0.8 km

MAHANANDA RIVER

FLOW

FLOW



Connection Channel

0 = 100 m. 500 m.

GANGES RIVER

FLOW

National Road

Delivery pipe 1.5 km

Proposed Pump Station
at Baraipara (Floating Type)

FLOW





Figure VIII-1-12 CASE II AND IV



Proposed Pump Station
at Baraipara (Fixed Type)

1-3-3. Cost Estimate

The cost estimate was carried out for the construction cost of structures, facilities cost of the pumps, including the accessory and operation and maintenance cost based on semi-feasibility study level.

As for fixed type pumping station, the maintenance cost for sedimentation is the most important factor, particularly, estimation of the volume of sedimentation has been estimated in the basis of the observed suspended load discharge at Hardinge Bridge, and the dredging cost calculated under the consideration of using dredgers.

Regarding the maintenance cost for floating type pumping station, it has assumed to be utilize the Towing Boat (5t), Anchor Boat (3t), and Crane Boat (10t) for the transfer of the barges in the river.

1-3-4. Results of the Cost Estimate

The results of the cost estimate is tabulated in the TABLE VIII-1-9~VIII-1-14.

It is indicated that case II proposed plan (Fixed Type at Baraipara) is the most recommendable for the construction of pumping station at Barind Tract Area.

TABLE VII-1-9 COMPARISON OF COST FOR EACH CASE (1000TK)

Case Item	Case I (floating, Fixed) Mixed Flow, Volume	Case I' (floating, Fixed)	Case II (Fixed)	Case III (floating)	Case IV (Fixed)
1. Construction Cost	2,223,600	1,909,800	1,327,800	1,774,000	1,463,100
2. Operation & Maintenance	231,200	206,300	112,800	137,700	112,800
Total Cost (Cost Ratio)	2,454,800 (170%)	2,116,100 (147%)	1,440,600 (100%)	1,911,700 (133%)	1,575,900 (109%)
3. Running Cost (Cost Ratio)	129,200 (108%)	122,300 (102%)	120,000 (100%)	123,800 (103%)	117,000 (98%)

1] Refer to TABLE 1-3-3

TABLE VIII-I-10 COMPARISON OF COST FOR EACH CASE (1000TK)

Item	Case	Case I, I'				Case I' (Inclined) Baraipara-P-S	Case II (Fixed) Baraipara-P-S	Case III (floating) Baraipara-P-S	Case IV (Inclined) Baraipara-P-S
		Case I, I' Sultanganj-P-S (Fixed)		Case I (floating) Baraipara-P-S	Case I' (Inclined) Baraipara-P-S				
1. Construction Cost 1J									
Pump Facility Cost		660,600	525,600	659,700	690,200	710,000	835,900		
Pump Station & Pipe Barge		414,300	113,100	175,200	637,600	554,000	627,200		
			510,000			510,000			
Sub - Total		1,074,900	1,148,700	834,900	1,327,800	1,774,000	1,463,100		
2. Operation & Maintenance 2J									
Dredger Equipment Cost		112,800	93,500	93,500	112,800	112,800	112,800		
Maintenance Equipment (floating Pump)			24,900			24,900			
Sub - Total		112,800	118,400	93,500	112,800	137,700	112,800		
Total Cost (1+2)		1,187,700	1,267,100	928,400	1,440,600	1,911,700	1,575,900		
3. Running Cost 3J									
Electric Charge		66,800	32,400	32,400	104,500	100,100	100,100		
Fuel Charge		1,100	1,000	1,000	1,100	1,100	1,100		
Painting Charge			3,500			3,500			
Other		11,800	12,600	9,200	14,400	19,100	15,800		
Total Cost		79,700	49,500	42,600	120,000	123,800	117,000		

1J Refer to TABLE-I-3-4,5

3J Refer to TABLE-I-3-7

2J Refer to TABLE-I-3-6

TABLE VIII-1-11 PUMP FACILITIES COST (1000TK)

Item	Case I, I'		Case I, I' (inclined) Baraipara-P-S	Case II (Fixed) Baraipara-P-S	Case III (floating) Baraipara-P-S	Case IV (Inclined) Baraipara-P-S
	Sultanganj-P-S	(Fixed)				
Capacity X Total Head X Motor Power X Unit	6x24.1x 2000x1	6x14.7x 1220x3 4x14.7x 880x4	2x13x340 x17	6x25.9x2150 x4 6x25.9x1450 x4	6x25.9x670 x20	6x25.9x670 x20
Pump	28,000	84,000 78,800	244,100	291,200	159,100	287,200
Motor	36,500	46,000 72,900	108,800	207,600	221,600	197,000
Valve X Pipe	9,700	67,200	68,400	63,400	73,200	64,400
Crane		10,400	4,500	10,400	4,500	4,500
Electric Equipment		40,400	74,000	40,400	79,400	79,400
Equipment Work		126,300	99,900	126,300	107,600	126,500
Transportation		60,200	60,000	51,100	64,500	75,900
Total Cost	660,600		639,700	690,200	710,000	835,900

TABLE VIII-1-12 CONSTRUCTION COST PER 20% (1000TK)

Case Item	Unit Cost 10 ³ TK	Case I, I'		Case I (floating) Baraipara.P.S	Case I', (Inclined) Baraipara.P.S	Case II (Fixed) Baraipara.P.S	Case III (floating) Baraipara.P.S	Case IV (Inclined) Baraipara.P.S
		Sultanganj.P.S (Fixed)	Baraipara.P.S					
Barge	300,000/20%	—	—	510,000	—	—	510,000	—
Pump House	23.6/m ²	× 730m ² 17,200	—	—	× 1170m ² 27,600	× 860m ² 20,300	—	× 1380m ² 32,500
Intake Canal		× 34,150/20 × 40 68,300	—	× 2,530/20 × 34 4,300	× 22,850/20 × 34 38,800	× 34,150/20 × 40 68,300	× 2,530/20 × 40 5,000	× 22,850/20 × 40 45,700
Pipe Line	183/20 /m	× 800m 292,800	—	× 350m 108,800	× 350m 108,800	× 1500m 549,000	× 1500m 549,000	× 1500m 459,000
Regulator		36m 36,000	—	—	—	—	—	—
Total Cost		414,300	510,000	175,200	637,600	510,000	627,200	

TABLE VIII-1-13 OPERATION & MAINTENANCE FACILITIES COST
(1000TK)

Item	Cost		Case I (floating) Baraipara-P.S	Case I' (Inclined) Baraipara-P.S	Case II (Fixed) Baraipara-P.S	Case III (floating) Baraipara-P.S	Case IV (Inclined) Baraipara-P.S
	Case I, I'	Sultanganj-P.S (Fixed)					
Dredger Pump	$\phi 450 \times 320 \times 1$ $\phi 350 \times 230 \times 1$		$\phi 350 \times 230 \times 2$	$\phi 350 \times 230 \times 2$	$\phi 450 \times 320 \times 1$ $\phi 350 \times 230 \times 1$	$\phi 450 \times 320 \times 1$ $\phi 350 \times 230 \times 1$	$\phi 450 \times 320 \times 1$ $\phi 350 \times 230 \times 1$
Dredger Pump	38,000 27,600		55,200	55,200	38,000 27,600	65,900	65,900
Floating Pipe	20,700		16,000	16,000	20,700	20,700	20,700
Towing Boat	3,700		3,700	3,700	3,700	3,700	3,700
Assemblage	13,500		11,200	11,200	13,500	13,500	13,500
Transportation	9,000		7,400	7,400	9,000	9,000	9,000
Sub - Total	112,800		93,500	93,500	112,800	112,800	112,800
Maintenance Equipment							
Floating Pump			17,100			17,100	
Anchor Boat			7,800			7,800	
Crane Boat							
Sub - Total	112,800		24,900			24,900	
Total Cost	112,800		118,400	935,500	112,800	137,700	112,800

1] Length ; 500m (Steel Pipe, Rubber Joint, Floater) $72 \times (15.3+66.9)+71 \times 29.4 = 8,000 \times 10^3$
 $72 \times (18.3+103.0)+71 \times 56.6 = 12,700 \times 10^3$

TABLE VII-1-14 RUNNING COST (1000TK)

Item	Case I, I'		Case I' (inclined) Baraipara-P-S	Case II (Fixed) Baraipara-P-S	Case III (floating) Baraipara-P-S	Case IV (Inclined) Baraipara-P-S
	Sultanganj-P-S (Fixed)	I'				
Amount Motor Power (kw)	2,000	6,980	5,780	14,000	13,400	13,400
Operation Hour (hr)	4,000	4,000	3,000	4,000	4,000	4,000
Electric Charge						
Charge	3,000 11,800	10,400 41,400	6,500 23,700	21,000 83,100	20,100 79,600	20,100 79,600
Demand	—	200	200	400	400	400
Service	—	—	—	—	—	—
Sub - Total	66,800		32,400	104,500	100,100	100,100
Fuel Charge IJ	1,100		1,000	1,100	1,100	1,100
Painting Charge	—		3,500	—	3,500	—
Other	11,800		9,200	14,400	19,100	15,800
Sub - Total	12,900		10,200	15,500	23,700	16,900
Total Cost	79,700		42,600	120,000	123,800	117,000

IJ Dredger ; $\phi 450\text{mm} \times 320\text{kw}$, $\phi 350\text{mm} \times 230\text{kw}$

2. TYPE OF PUMP

2-1. Selection of the Pump types

Generally, the type of the pumps shall be decided based on the total head required at proposed site.

In general, the relation between the type of pumps and total head required is given as follows :

<u>Type</u>	<u>Horizontal Axis</u>	<u>Vertical Axis</u>
Volute Type	15.0 m more	15.0 m more
Mixed flow Type	2.0 m - 9.0 m	9.0 m - 20.0 m
Axial flow Type	1.5 m - 5.0 m	1.5 m - 5.0 m

Design water level of suction side is estimated based on computation of probability of exceedance at 100 years return period. Results of estimation is shown as follows ;

<u>Pumping station</u>	<u>KASBA</u>	<u>BARAIPARA</u>
Low water level	7.860 m	8.686 m
High water level	<u>20.325 m</u>	<u>21.826 m</u>
Deference	12.465 m	13.140 m

On the other hand, the actual pump head are estimated at each proposed pump site are as follows ;

KASBA	13.0 m approx
BARAIPARA	27.0 m approx

As for the selection of pump type from actual head, there are considered to be applied two type, namely, one is volute type, and other one is mixed flow type.

In case of volute type pump, there are some weak points in cavitation for variation of the water level at suction side. Accordingly, mixed flow type has been selected for both proposed sites. Comparatively, submergible motor pump is considered to be utilized at both proposed sites. However, the construction cost is excessively high for design capacity at both sites, thus, the idea has been canceled. As for

supporting structure of vertical mixed flow type pump, semi-two floor type is proposed for both stations as mentioned attached TABLE VIII-1-2.

3. DESIGN OF PROPOSED PUMPING STATION

According to the results studied for type of pump station, pump facilities and hydrological analysis, details lay-out has been carried out. They are as follows.

3-1. Selection of Basic Factors for the Pumping Facilities

3-1-1. Basic Factors for Design of Pumps

Design capacity of the pump has been decided under the consideration of water requirement and water level of the Ganges river at the proposed pumping site are as follows ;

Pumping station	Baraipara P.S.	Paba P.S.
Water Requirement *1	44.242 m ³ /s	9.436 m ³ /s
Pump Capacity *2	42.588 m ³ /s	8.247 m ³ /s

*1 Maximum water requirement 1978-1986

*2 Maximum W.R. in dry season 1978-1986

Regarding the difference between the water requirement and the pump capacity, there are some consideration on the water level of the Ganges river. Namely, the maximum water requirement appeared at third week of September, at the same time, the water level was higher than low water level and its about 6.0 m, so that, the pumping capacity could be reduced depending on said allowance of the head. Basic factor for the design and hydrological analysis are summarized in FIGURE VIII-3-1 — VIII-3-4 and TABLE VIII-3-1.

TABLE VII-3-1 DIMENSION OF PUMP

Pump Station Item	Baraipara Pump Station	Paba Pump Station	
(1) Irrigation Requirement ^{1J}			
Dry season (豊)	42.588	8.247	1980-Apr
Wet season (豊)	44.242	9.436	1982-Sep
(2) Water Level ^{2J}			
H. W. L (m)	21.826	20.325	1/100 Probability
L. W. L (m)	8.686	7.860	"
(3) Suction Water Level (m)	8.50	7.70	
(4) Discharge Water Level			
W. L (m)	30.50	19.80	

1J Refer to FIGURE VII-3-1~VII-3-4

2J Refer to 4-2

FIGURE - VII-3-1 DIVERSION WATER REQUIREMENT

(Barind Area)

m³/s
(42,588)

Mean Water Level

m
9,586

(UNIT: m³/s)

(UNIT: m)

JAN. FEB. MAR. APR. MAY JUNE JULY AUG. SEP. OCT. NOV. DEC.

YEAR - 1980

Water Requirement

Water Level

FIGURE - VIII-3-2 IRRIGATION REQUIREMENT AND WATER LEVEL
(BARIND AREA)





FIGURE - VIII-3-3 DIVERSION WATER REQUIREMENT



YEAR - 1980

FIGURE - VII-3-4 IRRIGATION REQUIREMENT AND WATER LEVEL
(Flood Plane Area)




TABLE VIII-3-2 Monthly Mean Water Level Rajshahi (1977. Apr ~ 1987. Mar)

Water Year	JAN.	FEB.	MAR.	APR.	MAY.	JUNE.	JULY.	AUG.	SEP.	OCT.	NOV.	DEC.
1 9 7 7				8.483	8.658	10.042	15.094	17.515	16.877	14.903	11.960	10.569
1 9 7 8	9.677	9.223	8.989	9.165	9.922	11.975	16.350	18.327	18.029	15.541	12.424	10.752
1 9 7 9	9.619	9.474	9.108	8.933	9.194	9.188	14.218	16.789	14.788	12.846	10.288	9.595
1 9 8 0	8.813	8.568	8.449	8.399	8.722	10.576	15.711	18.256	18.086	14.144	11.486	10.022
1 9 8 1	8.994	8.631	8.244	8.373	8.798	9.530	15.670	17.726	16.712	14.133	10.884	9.667
1 9 8 2	8.676	8.533	8.346	8.561	8.765	10.691	13.391	17.232	17.983	13.071	11.171	9.786
1 9 8 3	8.644	8.478	8.000	7.935	8.961	9.485	13.925	16.622	18.248	16.345	12.466	10.436
1 9 8 4	9.604	8.933	8.453	8.183	8.668	12.227	16.371	17.658	18.471	13.939	11.513	10.253
1 9 8 5	9.613	7.084	8.646	8.461	8.722	9.587	14.727	17.761	17.571	17.477	14.001	11.637
1 9 8 6	10.576	9.877	9.638	9.182	9.492	9.945	16.005	17.558	16.708	15.622	12.539	11.413
1 9 8 7	10.826	9.902	9.111									
LEVEL. W. L	9.504	9.070	8.698	8.568	8.990	10.325	15.148	17.544	17.347	14.802	11.882	10.413
Kasba	9.835	9.401	9.029	8.899	9.321	10.656	15.479	17.875	17.678	15.133	12.213	10.744
Baraipara	10.661	10.227	9.855	9.725	10.147	11.482	16.305	18.701	18.504	15.957	13.039	11.570
Sultanganj	10.813	10.379	10.007	9.877	10.299	11.634	16.457	18.853	18.656	16.111	13.191	11.722

TABLE VII-3-3 DIVERSION WATER REQUIREMENT

(噸)

Year	BARIND AREA			FLOOD PLAIN AREA		
	Dry Season	Wet Season	Total	Dry Season	Wet Season	Total
1977	—	—	—	—	—	—
78	3.326	1.753	5.080	646	372	1.018
79	Ⓜ 4.164	1.164	5.328	Ⓜ 794	248	1.042
80	Ⓐ 3.383	Ⓐ 1.469	Ⓐ 4.853	Ⓐ 661	Ⓐ 311	Ⓐ 972
81	2.682	1.685	4.367	522	358	880
82	3.018	Ⓜ 2.967	Ⓜ 5.986	577	Ⓜ 628	Ⓜ 1.205
83	3.782	802	4.585	727	169	896
84	3.452	837	4.290	668	178	846
85	3.338	1.039	4.377	649	222	871
86	3.435	1.370	4.805	664	291	955
	3.398	1.454	4.852	656	309	965

Dry Season ; JAN ~ JUNE

Wet Season ; JULY ~ DEC

Ⓜ ; Diversion Water Requirement ; Max

Ⓐ ; " ; Ave

3-1-2. Type of pumping station and pumping facility

On the basis of detail discussion in the previous chapter, it was decided that the pumps will be of fixed type, the pumping facilities will be of vertical mixed flow type at Baraipara & Kasba.

3-1-3. Diameter and Number of Pumps

(1) Selection of Diameter and Number of Pumps

As for mentioned subject, the following items were taken into consideration ;

- to get the most suitable combination of diameter and number for seasonal water requirement including the higher efficiency of operation.
- to consider the diversification of risks and exchangeable parts

The following combination has been studied to select the most suitable combination of pump capacity & number.

	Baraipara P.S.	Kasba P.S.
Case-1 1/3 division	14.20 m ³ /s = 852 m ³ /m	2.749 m ³ /s = 165 m ³ /m
Case-2 1/4 division	10.65 m ³ /s = 639 m ³ /m	2.062 m ³ /s = 124 m ³ /m
Case-3 1/5 division	8.52 m ³ /s = 511 m ³ /m	1.65 m ³ /s = 99 m ³ /m

The studies for these combination have been shown in TABLE VIII-3-4 and VIII-3-5, for Baraipara and Kasba stations, respectively.

The cost of the pumping facilities and the operation costs for each case have been estimated as shown in TABLE VIII-3-6.

As a result,

Baraipara P.S.	Case-2	Ø1,650 m/m × 4 unit
Kasba P.S.	Case 2-2	Ø1,350 m/m × 1 unit
		Ø1,000 m/m × 2 unit

The scale of mentioned facilities are considerable for this project from the view point of operation and maintenance.

TABLE VII-3-4 NUMBER OF PUMP UNIT

(Brind Area)

Item \ Case	Unit	1		2		3 - 1		3 - 2	
Pump Type		Vertical Mixed Flow Pump							
Irrigation Requirement	m ³ /m	42.588 (2.556m ³ /m)							
Pump Capacities	m ³ /m	552	300	399	240	331	180	318	240
Pump Bore	mm	2,000	1,500	1,650	1,350	1,650	1,200	1,500	1,350
Actual Head	m	21.90							
Total Head	m	27.00							
Pump Efficiency	%	85	84	84.5	83.5	84.5	83	84	83.5
Motor Power	kw	3,290	1,810	2,390	1,460	1,990	1,100	1,920	1,460
Pump Units		3	3	4	4	5	5	2	8
Total Motor Power	kw	15,300		15,400		15,450		15,520	

TABLE VIII-3-5 NUMBER OF PUMP UNIT

(Flood Plane Area)

Case \ Item	Unit	1	2 - 1	2 - 2	3
Pump Type		Vertical Mixed Flow Pump			
Irrigation Requirement	亩	8.247 (495m ² /m)			
Pump Capacities	m ³ /m	165	124	247 124	99
Pump Bore	mm	1.200	1.000	1.350 1.000	900
Actual Head	m		12.00		
Total Head	m		13.00		
Pump Efficiency	%	83	82	83.5 82	81
Motor Power	kw	490	370	720 370	300
Pump Units		3	4	1 2	5
Total Motor Power	kw	1.470	1.480	1.460	1.500

1] Motor Power ; $RHP = 0.163 \frac{Q \times H \times (1 + \alpha)}{n_p \times n_t}$

$n_p \times n_t$

TABLE VIII-3-6 ANNUAL COST OF EACH CASE

(1000TK)

Case \ Item	PUMP FACILITIES COST 1J		Electric Charge	Total Cost
	Initial Cost 1J	Annual Cost 3J		
1. Baraipara P.S				
1	646,100	110,700	92,500	203,200
2	633,400	① 108,500	① 87,800	① 196,300
3-1	701,500	120,200	88,800	208,200
3-2	651,500	111,600	88,700	200,300
2. Paba P.S				
1	230,300	39,400	12,900	52,300
2-1	250,200	42,800	11,000	53,800
2-2	216,100	① 37,000	① 10,400	① 47,400
3	274,300	47,000	10,400	57,400

1J Refer to TABLE VIII-3-7, 8

2J Refer to TABLE VIII-3-9

3J The formula of estimation on the capital recovery ratio is shown as following.

$$P = \frac{1 (1+i)^n}{(1+i)^n - 1} (1 + \text{Interest Ratio for Construction periods.})$$

$$\text{Interest Ratio} = \alpha \times f' \times t$$

Where : f = Interest 12%

α = Farmer's share 40%

f' = Interest of Farmer's share 14%

t = Periods 5 years

n = Durable Life

(2) Economical Study

As for the mentioned proposed plan in the previous section, the costs for the facilities are summarized in TABLE VIII-3-7 and VIII-3-8 and O & M costs are shown in TABLE VIII-3-9, furthermore, seasonal operation pumps number are shown in TABLE VIII-3-10 and VIII-3-11.

TABLE VIII-3-7 PUMP FACILITIES COST (Baraipara-P.S) (1000TK)

Item	Case 1		2		3-1		3-2	
	φ 2000	φ 1500	φ 1650	φ 1350	φ 1650	φ 1200	φ 1500	φ 1350
Pump 1J	@ 38,000	@ 23,500	@ 28,000	@ 20,000	@ 28,000	@ 17,500	@ 23,500	@ 20,000
Motor 2J	@ 47,000	@ 19,000	@ 27,500	@ 15,500	@ 21,000	@ 13,000	@ 20,000	@ 15,500
Valve & Pipe	@ 14,100	@ 8,200	@ 10,500	@ 7,000	@ 10,500	@ 5,800	@ 8,200	@ 7,000
Crane	14,100		11,700		11,700			8,200
Electric Equipment	40,000		48,200		56,400		56,400	
Equipment Work	85,600		83,700		92,700		86,100	
Transportation	57,000		55,800		61,700		57,400	
Total Cost	646,100		633,400		701,500		651,500	

IJ Refer to FIGURE VIII-3-5

TABLE VM-3-8 PUMP FACILITIES COST (Kasba P.S) (1000TK)

Item	Case 1 φ 1,200	2-1 φ 1,000	2-2 φ 1350	3 φ 900
Pump 1J	@ 20,000	@ 14,000	@ 25,000	@ 11,000
Motor 2J	@ 17,500	@ 17,000	@ 18,000	@ 17,000
Valve & Pipe	@ 11,200	@ 8,500	@ 12,500	@ 6,700
Crane	7,700	7,000	8,200	6,200
Electric Equipment	26,500	30,800	26,500	35,000
Equipment Work	30,000	32,700	28,100	35,800
Transportation	20,000	21,700	18,800	23,800
Total Cost	230,300	250,200	216,100	274,300

1J Refer to FIGURE VM-3-5

FIGURE - VIII-3-5 COST OF PUMP and MOTOR




TABLE VIII-3-9 ELECTRIC CHARGE

(1000TK)

Case \ Item	① kw	② kw	Demand Charge TK/kw/Y ② × 35	Pump Operation	Electric Charge ① × $\begin{cases} 3.75\text{TK/KWH} \\ 1.65 \end{cases}$
	Motor power × Pump Unit	Total Motor Power		Hour $\begin{cases} 4\text{hr/D} \\ 20\text{hr/D} \end{cases}$	
1. Baraipara P. S					
1	3,290 × 3	15,300	500	1,568	19,300
	1,810 × 3			7,840	42,500
2	2,390 × 4	15,400	500	1,416	9,600
	1,490 × 4			7,080	21,100
3-1	1,920 × 5	15,450	500	1,532	13,700
	1,100 × 5			7,660	30,200
3-2	1,920 × 2	15,520	500	2,460	13,700
	1,460 × 8			12,300	30,200
2. Paba P. S					
1	490 × 3	1,470	—	2,308	16,600
				11,540	36,500
2-1	370 × 4	1,480	—	2,644	10,900
				13,220	24,000
2-2	720 × 1	1,460	—	1,008	7,200
	370 × 2			5,040	15,900
3		1,500	—	3,748	20,500
	300 × 5			18,740	45,100

1] Refer to TABLE - VIII-3-10.11

TABLE VII-3-10 PUMP OPERATION UNITS OF EACH MONTH

Actual Head 21.9m

Date	Water Requirement %	%	Suction Water Level m	Actual Head m	Capacity %	1		2		3-1		3-2	
						2000×3 1500×3	1650×4 1350×4	1650×5 1000×5	1500×2 1350×2				
JAN 1 2 3	8.685 17.395 17.167		10.6	19.9	104	1 — 2 — 2 —	1 1 2 1 2 1	1 1 2 3 2 3	1 1 1 3 1 3				
FEB 1 2 3	21.269 " "		10.2	20.3	104	2 1 2 1 2 1	2 2 2 2 2 2	1 5 1 5 1 5	1 4 1 4 1 4				
MAR 1 2 3	29.523 " 34.385		9.8	20.7	102	3 1 3 1 2 3	2 4 2 4 3 4	5 1 5 1 5 3	1 6 1 6 2 6				
APR 1 2 3	42.685 17.395 17.167		9.7	20.8	102	3 3 3 2 2 2	4 4 3 4 3 2	5 5 5 3 4 3	2 8 1 8 — 7				
MAY 1 2 3	2.317 4.507 2.583		10.1	20.4	104	— 1 — 1 — 1	— 1 — 1 — 1	— 1 1 — — 1	— 1 1 — — 1				
JUN 1 2 3	0.646 2.194 16.070		11.4	19.1	108	— 1 — 1 1 1	— 1 — 1 1 2	— 1 — 1 2 2	— 1 — 1 2 1				
JUL 1 2 3	16.167 3.410 2.405		16.3	14.2	116	1 1 — 1 — 1	1 2 — 1 — 1	1 3 — 1 — 1	2 1 — 1 — 1				
AUG 1 2 3	1.553 3.199 0.945		18.7	11.8	118	— 1 — 1 — 1	— 1 — 1 — 1	— 1 — 1 — 1	— 1 — 1 — 1				
SEP 1 2 3	0.515 0.008 0.760		18.5	12.0	118	— 1 — 1 — 1	— 1 — 1 — 1	— 1 — 1 — 1	— 1 — 1 — 1				
OCT 1 2 3	22.401 30.240 —		15.9	14.6	116	2 2 3 — — —	2 3 2 3 — —	5 2 5 2 — —	1 6 2 4 — —				
NOV 1 2 3	9.326 8.398 5.705		13.0	17.5	110	1 — 1 — 1 —	— 2 — 2 1 —	1 1 1 1 1 —	— 2 — 2 1 —				
DEC 1 2 3	2.540 10.044 17.251		11.5	19.8	108	— 1 — 2 2 —	— 1 1 1 2 1	— 1 1- 2 2 2	— 1 1 1 1 3				
Total						392 354	383 615	577 661	252 937				

1/ Refer to Figure VII-3-6

FIGURE - VII-3-6 PUMP CHARACTERISTIC CURVE
 (Baraipara P. S)





TABLE VII-3-11 PUMP OPERATION UNITS OF EACH MONTH

Actual Head 12.0m

Date	Water Requirement %	%	Suction Water Levelm	Actual Head m	Capacity % /	1	2	3-1 1350×1 1000×2		3-2
						1200×3	1000×4	1000×2	900×5	
JAN 1	1.729					1	1	—	1	1
JAN 2	3.462		9.8	10.0	112	2	2	1	—	2
JAN 3	3.417					2	2	1	—	2
FEB 1	4.234					2	2	1	—	3
FEB 2	"		9.4	10.4	110	2	2	1	—	3
FEB 3	"					2	2	1	—	3
MAR 1	5.877					2	3	1	1	4
MAR 2	"		9.0	10.8	109	2	3	1	1	4
MAR 3	6.298					3	4	1	1	4
APR 1	8.247					3	4	1	2	5
APR 2	6.779		8.8	11.0	107	3	4	1	1	4
APR 3	4.941					2	3	1	1	3
MAY 1	0.395					1	1	—	1	1
MAY 2	0.769		9.3	10.5	110	1	1	—	1	1
MAY 3	0.441					1	1	—	1	1
JUN 1	0.110					1	1	—	1	1
JUN 2	0.468		10.6	9.2	116	1	1	—	1	1
JUN 3	3.427					2	2	1	—	2
JUL 1	3.311					2	2	1	—	2
JUL 2	0.727		15.4	4.4	120	1	1	—	1	1
JUL 3	0.410					1	1	—	1	1
AUG 1	0.331					1	1	—	1	1
AUG 2	0.682		17.8	2.0	120	1	1	—	1	1
AUG 3	0.202					1	1	—	1	1
SEP 1	0.110					1	1	—	1	1
SEP 2	0.002		17.6	2.2	120	1	1	—	1	1
SEP 3	0.162					1	1	—	1	1
OCT 1	6.910					3	3	1	1	4
OCT 2	6.449		15.1	4.7	120	2	3	1	1	4
OCT 3	—					—	—	—	—	—
NOV 1	1.989					1	1	—	1	2
NOV 2	1.791		12.2	7.6	120	1	1	—	1	1
NOV 3	1.217					1	1	—	1	1
DEC 1	0.542					1	1	—	1	1
DEC 2	2.142		10.7	9.1	116	1	1	—	1	2
DEC 3	3.679					2	2	1	—	2
Total						556	627	161	284	725

1/ Refer to Figure VII-3-7

FIGURE - VII-3-7 PUMP CHARACTERISTIC CURVE
(Kasba P. S)



3-1-4. Selection of Total Head

The pipe line should be prepared from the pumping station to delivery ponds at Baraipara and Kasba. The steel pipe is the most suitable under the consideration of strength, and availabilities for construction.

In this case, the diameter of the pipes are decided based on the average velocity of 2.0 m per second. The head loss in the pipe line is computed as follows.

Station	Q m ³ /s	Diameter mm	Velocity m/s	Loss Head m/m	Hf *1	hf *2	
Baraipara	6.92	1,800	2.719	0.00268	ℓ=1,400m 4.5	0.4	
	4.17	1,500	2.360	0.00256		4.3	0.3
	8.34	2,000	2.655	0.00226		3.8	0.4
Kasba	4.72	1,500	2.671	0.00322	ℓ=50m 0.2	0.4	
	2.37	1,200	2.096	0.00267		0.2	0.3

*1 Hf = Loss Head/m × 1.2 × ℓ

*2 hf = Loss Head inside of pump facilities

From the above computation, total head estimated at Baraipara and Kasba are as follows ;

$$\text{Baraipara ; } 30.50 - 8.50 + 4.50 + 0.40 = 26.9 \approx 27.0 \text{ m}$$

$$\text{Kasba ; } 19.80 - 7.70 + 0.20 + 0.40 = 12.7 \approx 13.0 \text{ m}$$

3-1-5. Special Dimension of Pumps

Station	Baraipara P.S.		Kasba P.S.	
Items				
Pump Facilities	Vertical Mixed Flow		Vertical Mixed Flow	
Capacity (m ³ /s)	399	240	247	124
Diameter (m·m)	1,650	1,350	1,350	1,000
Max. Actual Head (m)	22.0	22.0	12.0	12.0
Max. Total Head (m)	27.0	27.0	13.0	13.0
Power Source	Electric motor		Electric motor	
Output (kw)	2,390	1,460	720	370
Number of Pump	4	4	1	2
Max. Discharge	415	250	283	142
W.L. of Suction pipe (m)	8.5		7.70	
W.L. of Suction pipe (m)	30.50		19.80	

Note ; The variation of actual head is 9.0 m is average year

3-2. Design of Pumping Station

3-2-1. Design of Intake Canal

The water of the Ganges river consists of sediment, and its contents vary throughout the year, and the most high value appeared at end of flood season. In order to protect the damage to the pump facilities and canals function, it is proposed to construct a silting basin in front of suction tank of the pumping station.

As a basic criterion for design, average water velocity decided to have 0.15 m/s to 0.30 m/s in the canal, and the retarding period assumed to be 30-60 seconds in the basin.

Based on the intake discharge and depth of water, the width of canal estimated as follows ;

	<u>Baraipara</u>		<u>Kasba</u>
Width of Canal	$\frac{42.588 \text{ m}^3/\text{s}}{2.0 \times 0.20} \cong 100 \text{ m}$		$\frac{8.247 \text{ m}^3/\text{s}}{1.50 \times 0.20} \cong 30 \text{ m}$

On the other hand, the length of silting basin is calculated by the following formula,

$$L = K \frac{Q}{B \cdot Vg}$$

L ; Length of silting basin

K ; Safety factor (1.5 - 2.0)

Q ; Discharge (m³/s)

B ; Width of Basin (m)

Vg ; Silting velocity on sediment of minimum size (m/s)

where ; Vg = 0.003 m/s (Grain size 0.1 mm S.G.S.S. = 1.10)

S.G.S.S; Specific Gravity of soil suspension. (See FIGURE VIII-3-8)


<u>Baraipara</u>	<u>Kasba</u>	<u>Remarks</u>
$L = 2.0 \times \frac{42.588}{100 \times 0.003} \cong 300 \text{ m}$	$L = 2.0 \times \frac{8.247}{30 \times 0.003} \cong 200 \text{ m}$	

Main items of silting basin are summarized as follows ;

Items	Baraipara	Kasba	Remarks
- Pump Capacity	42.588 m ³ /s	8.247 m ³ /s	The water depth is decided based on water level in dry season.
- Depth of water in the canal	2.10 m	1.50 m	
- Velocity of discharge	0.20 m/s	0.20 m/s	
- Width of Basin	100 m	30 m	
- Length of Basin	300 m	200 m	

FIGURE - VIII-3-8

PARTICLE DISTRIBUTION OF BED MATERIAL
OF GANGES RIVER



3-2-2. Design of Inlet of Pumping Station

(1) Height of sill at Inlet structure

Basically, the velocity of inlet is assumed to have 0.5 m/s below.

The results of the computation for the height of the sill are shown as follows;

	Baraipara P.S.	Kasba P.S.
Design discharge at Lowest Water Level	42.588 m ³ /s	8,247 m ³ /s
Width of inlet (B) *1	8.686 m	7.860 m
Water Depth (H) *2	40.20 m	11.20 m
Elevation of sill	6.5 m	6.30 m

*1 See (3)

*2 $Q/0.5 \times H \leq H$

(2) Height of bottom at Suction Pump


At first, the head loss should be decided at the screen, after that, necessary water depth, and the height of bottom shall be determined. The procedure and the results are shown as follows ;

- Screen loss : $\Delta h_{r1} \doteq 0.10$ m


	Baraipara P.S.	Kasba P.S.
Suction Water level	$8.686 - 0.10 \doteq 8.50$ m	$7.86 - 0.10 \doteq 7.70$ m
Height of bottom at Suction pit	$8.50 - 4.35^{*3} \doteq 4.10$ m	$7.70 - 3.65^{*4} \doteq 4.0$ m

*3 $\varnothing 1,650$ mm E+F = 4.25 m

*4 $\varnothing 1,350$ mm E+F = 3.65 m



At Baraipara



At Kasba

3-2-3. Scale of Pumping Station

(1) Lay-out of supporting structure for pumps

Taking into consideration of the following factors, the scale of structures is decided are shown below.

- Diameter of the pumps
- Size of power equipment
- Distribution of the valves and pipe
- Scale of overhead travelling crane

	<u>Width</u>	<u>Length</u>	<u>Height</u>
Baraipara P.S.	15.80 m	40.80 m	13.0 m
Kasba P.S.	14.30 m	11.80 m	12.0 m

The allowance space for installation of the equipment and the space of operation are as follows;

	Width	Length	Height
Baraipara P.S.	15.80 m	5.60×2 m	13.0 m
Kasba P.S.	14.30 m	4.60×7.20 m	12.0 m


Finally, the shapes of the planes for supporting structures are shown as follows ;

	Width	Length	Spaces
Baraipara P.S.	15.80 m	52.00 m	≅ 830 m ²
Kasba P.S.	14.30 m	23.60 m	≅ 350 m ²

(2) Dimension of suction pump and space of pumps


There are some design criteria for the suction pit and space for the pump equipments. Based on the criteria, the lay-out of the structures are shown in the following figures.

FIGURE VII-3-9 PUMP SUCTION




D	B=L	E	F	G
1650	5000	2700	1650	1800
1350	4000	2300	1350	1500
1000	3000	1700	1000	1100

FIGURE- VII-3-10 PUMP PIT



ϕD	$B \approx 3D$	A	ϕC	l^a	b	X	Y
1650	5000	5500	2900	3300	2600	6000	9000
1350	4000	5000	2300	2900	2200	5500	8000
1000	3000	4500	1750	2400	1800	5000	7000

FIGURE - VII-3-11 BARAIPARA PUMPING STATION



$$\begin{aligned}
 H &= K + A + F + J \\
 &= 1.7 + 2.9 + 1.1 + 6.6 \\
 &= 12.3 \approx 13.0\text{m}
 \end{aligned}$$







FIGURE - VIII-3-12 KASBA PUMPING STATION



$$\begin{aligned}
 H &= K + A + F + J \\
 &= 1.5 + 2.6 + 0.9 + 6.2 \\
 &= 11.2 \approx 12.0\text{m}
 \end{aligned}$$

3-2-4. Foundation Treatment and Protection Dike

(1) Foundation Structures

According to the test boring data at proposed pump site, shallow layer is covered with very hard clay, and deep layer consist of the sand with high degree of consolidation.

The value of N of standard penetration tests at an elevation of -3.0 m to -4.0 m is expected to be more than 30. So that, this layer can be considered as the bearing zone for the structures.

The concrete pile foundation should be provided for foundation treatment at the proposed site.

The bearing capacity of pile shall be estimated from the following formula.

$$R_a = 1/3 \left\{ 30N \cdot A_p + \left(\frac{N_s L_s}{5} + \frac{N_c L_c}{2} \right) \psi \right\}$$

where ;

R_a ; Long term allowable bearing capacity

N ; N value at the top of pile under the ground

A_p ; Cross section of top of the pile (m^2 or cm^2)

N_s ; Average N value in sandy layer


L_s ; Length of the pile in sandy layer

N_c ; Average N value in clayey layer

L_c ; Length of the pile in clayey layer

ψ ; Length of circumference of the pile

(a) Bearing capacity of the pile at Baraipara P.S.




□400

$$R_a = \frac{1}{3} \left[30 \times 29 + 0.4 \times 0.4 + \frac{22 \times 8}{5} \times 1.6 \right]$$

$$= 65t < 0.075 \times 40^2 = 120t$$

(b) Bearing capacity of the pile at Kasba




$$\square 400 \quad R_a = \frac{1}{3} \left[30 \times 29 + 0.4 \times 0.4 + \left(\frac{23 \times 7}{5} + \frac{16 \times 5}{2} \right) \times 1.6 \right]$$

$$= 84t < 120t$$

(2) Flood Protection Structure

The flood protection structure is required to install for the protection of the erosion in the river bed at the conjunction of the Ganges river and intake canal.

A typical section of the structure is shown as follows ;



3-2-5. Design of Discharge Pond


(1) Shape of the discharge pond

1) Barind Tract Area

Discharge pond should be connected with the main canal directly. Therefore, the lay-out was carried out considering the following items.

- flow velocity inside of the pond should be within 0.5 m/sec.
- the location of outlet of the pipe line should serve as a wave protector
- sedimentation in the pond

As a result of the analysis and under the consideration of the said items, the typical section of the structure is shown as follows ;



The width of discharge pond was computed by the following formula

$$B = \frac{Q}{\text{hr} \times v} = \frac{44.242}{3.30\text{m} \times 0.3} = 45 \text{ m}$$

This width could cover outlet of the pipe line ($B \approx 23.0\text{m}$) sufficiently. Necessary length of the pond was calculated by the following formula.

$$L = K \frac{Q}{B \cdot Vg} \approx 80 \text{ m}$$

$$Q ; 44.242 \text{ m}^3/\text{x}$$

$$B ; 45$$

$$Vg ; 0.025 \text{ m/s}$$


$$K ; 2$$

Therefore, dimensions of the discharge pond are as follows ;

$$\begin{array}{l} \text{Width} \times \text{Length} \times \text{Depth} \\ 45 \text{ m} \times 80 \text{ m} \quad 3.30 \text{ m} \end{array}$$

2) Paba Flood Plain Area

The same approaches and considerations were applied for this area also. Typical shape is shown as below ;



$$B = \frac{Q}{h_i \times v} \approx 15.0 \text{ m}$$


$$L = 2 \times Q / B \cdot V_g \approx 50 \text{ m}$$

Width × Length × Depth
 45 m × 80 m 3.30 m

(2) Construction materials

It should be considered to protect the leakage of costly water.

Main dike shall be made by clayey materials with sufficient compaction and also inside surface of pond should be covered by concrete pavement.



3-2-6. Dual Purpose Pumps for Irrigation and Drainage at Kasba Pump Station

It has been proposed to review the possibility of dual purpose pumps for irrigation and drainage at Kasba Pump station. Terms to be considered for drainage plan at Kasba pump station are shown below, particularly, on the water level at the site.

- Inside water level 13.70 m
- Outside water level 20.325 m
- Actual Head 6.700 m
- Total Head 7.700 m

Pump capability has been evaluated from the pump characteristic curve considering the above mentioned points (FIGURE VIII-3-13 and FIGURE VIII-3-13).

From the evaluated result it is clear that the discharge should be controlled by the valves to avoid cavitation.

The recommended capacities are as follows.

$$\text{Ø } 1,000 \text{ mm } A = 160 \text{ m}^3/\text{m} = 2.7 \text{ m}^3/\text{s}$$

$$\text{Ø } 1,350 \text{ mm } Q = 300 \text{ m}^3/\text{s} = 5.0 \text{ m}^3/\text{s}$$

Therefore, total capacity shall be at about $10.0 \text{ m}^3/\text{s}$.

For dual purpose application, some additional facilities shall be required. The development plan including additional facilities are shown in the following illustration.




FIGURE - VIII-3-13 CHARACTERISTIC CURVE

124 $\frac{m^3}{m}$ x 13 m x 1000 mm x 370 kw





FIGURE - VIII-3-14 CHARACTERISTIC CURVE



3-2-7. Power Supply

Total demand of electricity at Baraipara and Kasba pumping stations is about 17,000 kw.

Electric supply systems in the project area are described as follows, according to the information obtained from the Bangladesh Power Development Board.

<u>Area</u>	<u>Existing transmission line</u>	<u>Planning transmission line</u>
	kv line(s)	kv line(s)
Natore	132 × 2	- -
Rajshahi	132 × 1 66 × 1	- -
Godagari	33 × 1	132 × 1
Sultanganj	33 × 1	132 × 1


Therefore, pumping stations at Godagari and Sultanganj, total demand of electricity can not be supplied by existing 33 kv transmission line.

However, in 1990 132 kv transmission line will be constructed and will be able to operate the pumping stations.

Transmission line in this project area is shown in FIGURE VIII-3-15.

FIGURE VIII-3-15

TRANSMISSION LINE



TRANSMISSION LINE		LEGEND		
		EXISTING	UNDER CONSTRUCTION	PLANNED
230 KV				
132 KV				
66 KV				
33 KV				
33 KV	LINE ENERGISED AT 11 KV			
POWER PLANT				
GRID SUB-STATION				
DIESEL POWER STATION				
REB 33/11 KV SUB STN				
PDB 33 KV SUB STN				

APPENDIX IX

ORGANIZATION AND MANAGEMENT

APPENDIX IX

ORGANIZATION AND MANAGEMENT

CONTENTS


	PAGE
1. ORGANIZATION OF BWDB	IX-1
2. ORGANIZATION FOR PROJECT IMPLEMENTATION	IX-3
3. IMPLEMENTATION SCHEDULE	IX-7
4. ORGANIZATION FOR OPERATION AND MAINTENANCE	IX-8

LIST OF FIGURE

FIGURE IX-1-1 ORGANIZATION CHART OF MINISTRY SECRETARY OFFICE	IX-1
FIGURE IX-1-2 ORGANIZATION CHART OF BANGLADESH WATER DEVELOPMENT BOARD	IX-2
FIGURE IX-2-1 STRUCTURE OF BWDB FOR NRIP	IX-3
FIGURE IX-2-2 PROPOSED ORGANIZATION CHART FOR IMPLEMENTATION OF THE NRIP	IX-4
FIGURE IX-2-3 CENTRAL COORDINATION COMMITTEE	IX-5
FIGURE IX-2-4 LOCAL COORDINATION COMMITTEE	IX-6
FIGURE IX-3-1 THE PROJECT IMPLEMENTATION SCHEDULE	IX-7
FIGURE IX-4-1 PROPOSED ORGANIZATION CHART FOR OPERATION AND MAINTENANCE OF THE PROJECT	IX-8

ORGANIZATION CHART OF MINISTRY SECRETARY OFFICE

FIGURE IX-1-1



ORGANIZATION CHART OF MINISTRY OF IRRIGATION,
WATER DEVELOPMENT AND FLOOD CONTROL




FIGURE IX-1-2 ORGANIZATION CHART OF BANGLADESH WATER DEVELOPMENT BOARD





FIGURE IX-2-1



NOTE ; S. E. ----- SUPERINTENDING ENGINEER
XEN ----- EXECUTIVE ENGINEER
SDE ----- SUB-DIVISIONAL ENGINEER

FIGURE IX-2-2 PROPOSED ORGANIZATION CHART FOR IMPLEMENTATION OF THE NORTH RAJSHAHI IRRIGATION PROJECT




FIGURE IX-2-3

CENTRAL COORDINATION COMMITTEE




FIGURE I X-2-4 LOCAL COORDINATION COMMITTEE





FIGURE IX-3-1 The Project Implementation Schedule

	1st Year			2nd Year			3rd Year			4th Year			5th Year			6th Year			7th Year			
	I	II	III	I	II	III	I	II	III	I	II	III	I	II	III	I	II	III	I	II	III	
I. Detailed Design																						
II. Tendering																						
III. Loan Procedure																						
IV. Construction																						
1. Land Acquisition																						
2. Procurement of Equipment																						
3. Preparation Works																						
4. Flood Plain Area																						
a. Pumping Station																						
b. Irrigation Canal																						
c. Irrigation Facilities																						
d. Drainage Facilities																						
e. Road and Bridge																						
f. On-farm																						
g. Transmission Line																						
h. Telephone Line																						
5. Barind Area																						
a. Pumping Station																						
b. Irrigation Canal																						
c. Irrigation Facilities																						
d. Road and Bridge																						
e. On-farm																						
f. Transmission Line																						
g. Telephone Line																						
6. Agricultural Extension																						
V. Consulting Service																						

FIGURE IX 4-1 PROPOSED ORGANIZATION CHART FOR OPERATION AND MAINTENANCE OF THE PROJECT



NOTE ; S. E. ----- SUPERINTENDING ENGINEER
 XEN ----- EXECUTIVE ENGINEER
 SDE ----- SUB-DIVISIONAL ENGINEER