

## 1. Introduction

The study team employed a local subcontractor to carry out the leveling survey in the four cities, namely Zagazig, Bilbeis, Faqus and Minyet El Qamh. They started the field work on 23rd January and finished it on 10th February, 1988. During the field survey, confirmation of the official bench marks were carried out by them under the supervision of the team's engineers. Also seven temporary bench marks to be used for sewerage planning, two in Zagazig, Bilbeis and Minyet El Qamh and one in Faqus, were established.

Leveling survey was carried out along the proposed gravity trunk sewers. The routes of the leveling survey are illustrated on Figures XIX-1 through XIX-4. Ground levels usually at 80 m intervals were measured. Levels of such mian features as curves, crossings of main roads, canals, drains and railways were also measured. Accuracy of the leveling survey is within 20 mm S (where S is one way distance of the survey in km). The results of the leveling survey are plotted on the drawings as longitudinal sections with scales 1:100 vertical, and 1:5,000 horizontal. Drawings are included in Volume Four of the current report.

Locations of the official and temporary bench marks are shown on Figures XIX-1 through XIX-4. Sketches and photographs of the temporary bench marks in the four cities are shown in Figures XIX-5 through XIX-11 and Photos XIX-1 through XIX-7.





Figure XIX-1 Routes of Leveling Survey in Zagazig City






Figure XIX-2 Routes of Leveling Survey in Bilbeis City



Scale : 1/25,000  
 0 500 m 1 km

- LEGEND**
- : Survey Route
  - ▲** : Official Bench Mark
  - : Temporary Bench Mark

Figure XIX-3 Routes of Leveling Survey in Minyet El Qamh City





Figure XIX-4 Routes of Leveling Survey in Faqus City




Figure XIX-5 Sketch of Temporary Bench Mark (A) in Zagazig City



Photo XIX-1 Temporary Bench Mark (A) in Zagazig City




Figure XIX-6 Sketch of Temporary Bench Mark (B) in Zagazig City




Photo XIX-2 Temporary Bench Mark (B) in Zagazig City




Figure XIX-7 Sketch of Temporary Bench Mark (A) in Bilbeis City



Photo XIX-3 Temporary Bench Mark (A) in Bilbeis City






Figure XIX-8 Sketch of Temporary Bench Mark (B) in Bilbeis City



Photo XIX-4 Temporary Bench Mark (B) in Bilbeis City




Figure XIX-9 Sketch of Temporary Bench Mark (A) in Minyet El Qamh City



Photo XIX-5 Temporary Bench Mark (A) in Minyet El Qamh City




Figure XIX-10 Sketch of Temporary Bench Mark (B) in Minyet El Qamh City



Photo XIX-6 Temporary Bench Mark (B) in Minyet El Qamh City




Figure XIX-11 Sketch of Temporary Bench Mark in Faqus City



Photo XIX-7 Temporary Bench Mark in Faqus City

APPENDIX - XX

DESIGN AND HYDRAULIC CALCULATIONS OF SEWERAGE FACILITIES

APPENDIX - XX

DESIGN AND HYDRAULIC CALCULATIONS OF SEWERAGE FACILITIES

Table of Contents

	<u>Page</u>
1. <u>Introduction</u> .....	XX-1

List of Tables

Table XX-1	Sewerage Computation Sheet for Zagazig .....	XX-5
Table XX-2	Calculation Sheet of Pumping Station for Zagazig .....	XX-9
Table XX-3	Sewerage Computation Sheet for Faqus .....	XX-13
Table XX-4	Calculation Sheet of Pumping Station for Faqus .....	XX-16
Table XX-5	Process Design of STP for Faqus .....	XX-17
Table XX-6	Hydraulic Calculation Sheet of STP for Faqus .....	XX-20
Table XX-7	Sewerage Computation Sheet for Bilbeis .....	XX-27
Table XX-8	Calculation Sheet of Pumping Station for Bilbeis .....	XX-30
Table XX-9	Process Design of STP for Bilbeis .....	XX-31
Table XX-10	Hydraulic Calculation Sheet of STP for Bilbeis .....	XX-34
Table XX-11	Sewerage Computation Sheet for Minyet El Qamh .....	XX-41
Table XX-12	Calculation Sheet of Pumping Station for Minyet El Qamh .....	XX-43
Table XX-13	Process Design of STP for Minyet El Qamh .....	XX-44
Table XX-14	Hydraulic Calculation Sheet of STP for Minyet El Qamh .....	XX-47

## 1. Introduction

Design and hydraulic calculations of the sewerage facilities in the four cities, namely Zagazig, Faqus, Bilbeis and Minyet El Qamh, are presented in this Appendix. For each city, a set of tables consisting of four categories, i.e. 1) hydraulic calculations of trunk sewers, 2) design and hydraulic calculations of pumping stations, 3) process design of treatment plants, and 4) hydraulic calculations of treatment plants are prepared. Process design and hydraulic calculations of Zagazig STP by NOPWASD are included in Appendix VI and not presented here.

Hydraulic calculations of trunk sewers are based on the Manning Formula, using a roughness coefficient of 0.012. For gravity sewers, peak flows in the year 2040 are used. For force mains, double lines, one for the peak flows in 2005 and another for the incremental flows from 2005 to 2040 are designed. All pumping stations are designed for flows in 2005. Capacities of pumping stations, i.e. diameters and number of pumps, total heads, and motor powers are calculated based on peak flows in 2005.

Capacities of major process units of treatment plants for three cities together with dimensions of the facilities are calculated. All treatment plants are designed as conventional activated sludge process. Hydraulic calculations are carried out on the basis of assumed water levels of the receiving drains. It should be noted that water levels of the drains should be confirmed with the authority concerned at a later stage.

All of the design drawings presented in Volume Four are completed based on the calculations in this Appendix. Therefore, tables here should be viewed in conjunction with those drawings.





Zagazig



FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-1 Sewerage Computation Sheet For Zagazig (1 of 4)

NO of Sewer	Sewerage Area		Sewer Length		Unit Sewage Flow Per ha			Sewer Invert Elevation		Ground Elevation		Earth Cover		NO of MH	Remark		
	Incremental Area	Cumulated Area	Incremental Length	Cumulated Length	Design Flow	Sewer Diameter	Slope	Velocity	Capacity	Begin	End	Begin	End				
																ha	ha
<b>ZONE-8</b>																	
1	43.8	43.8	860	860	0.059	Ø350	1.8	0.70	0.067	7.233	5.405	8.60	8.70	1.00	2.93	14	
2	57.9	101.7	1,110	1,970	0.137	Ø500	1.3	0.75	0.147	5.255	3.432	8.70	8.85	2.90	4.88	19	
3	34.0	135.7	430	2,400	0.182	Ø600	1.1	0.78	0.221	3.332	2.719	8.85	11.96	4.87	8.59	7	
Flow to No.1 Pumping Station (A8=135.7 ha)																	
4	-	135.7	980	3,380	0.083	Ø300	6.3	1.18	0.083	10.645	7.285	11.96	8.60	1.00	1.00	-	Force Main
<b>ZONE-7</b>																	
5	44.4	44.4	860	860	0.060	Ø350	1.8	0.70	0.067	7.533	5.705	8.90	8.80	1.00	2.73	14	
6	45.1	89.5	920	1,780	0.120	Ø500	1.3	0.75	0.147	5.555	4.059	8.80	8.70	2.70	4.10	15	
7	65.9	155.4	1,070	2,850	0.209	Ø600	1.1	0.78	0.221	3.959	2.422	8.70	8.60	4.09	5.53	18	
Flow to No.2 Pumping Station																	
8	55.9	55.9	440	440	0.075	Ø400	1.5	0.70	0.087	6.981	6.181	8.40	8.40	1.00	1.80	7	
9	42.0	97.9	600	1,040	0.132	Ø500	1.3	0.75	0.147	6.081	5.101	8.40	8.60	1.78	2.96	10	
10	59.0	156.9	620	1,660	0.211	Ø600	1.1	0.78	0.221	5.001	4.119	8.60	8.60	2.95	3.83	10	
11	63.8	63.8	790	790	0.086	Ø400	1.6	0.72	0.090	7.181	5.657	8.60	8.60	1.00	2.52	13	
12	64.7	285.4	900	2,560	0.384	Ø900	0.7	0.82	0.519	3.819	2.889	8.60	8.60	3.79	4.72	15	
Flow to No.2 Pumping Station (A7=440.8 ha)																	
13	-	440.8	770	3,620	0.271	Ø450	7.7	1.70	0.271	7.112	7.112	8.60	8.60	1.00	1.00	-	Force Main
<b>ZONE-4</b>																	
14	-	578.5	2,240	5,860	0.354	Ø500	7.5	1.80	0.354	7.058	8.568	8.60	10.11	1.00	1.00	-	Force Main

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-1 Sewerage Computation Sheet For Zagazig (2 of 4)

NO of Sewer	Sewerage Area		Sewer Length		Unit Sewerage Flow Per ha		Sewer Diameter		Sewer Velocity		Sewer Capacity		Sewer Invert Elevation		Ground Elevation		Earth Cover		NO of MH	Remark
	ha	Incremental	ha	Incremental	m	Cumulated	mm	Design	m/s	%	m <sup>3</sup> /s	m <sup>3</sup> /s	Begin	End	m	Begin	End	m		
<b>ZONE-4</b>																				
15	28.4	28.4	430	430	0.038	0.038	250	3.5	0.78	0.038	11.168	9.523	12.43	11.44	1.00	1.66	7			
16	53.7	82.1	280	710	0.110	0.110	450	1.4	0.73	0.116	9.323	8.831	11.44	10.51	1.63	1.19	5			
17	73.2	155.3	320	1,030	0.209	0.209	600	1.1	0.78	0.221	8.681	8.229	10.51	10.77	1.18	1.89	5			
18	86.1	241.4	720	1,750	0.324	0.324	750	0.8	0.77	0.341	8.079	7.263	10.77	10.11	1.88	2.04	12			
19	56.3	297.7	640	2,390	0.400	0.400	900	0.7	0.82	0.519	7.113	6.445	10.11	10.11	2.01	2.68	11			
Flow to No.3 Pumping Station																				
20	73.7	73.7	720	720	0.099	0.099	450	1.4	0.73	0.116	8.782	7.534	10.27	9.97	1.00	1.95	12			
21	43.5	117.2	720	1,440	0.158	0.158	600	1.1	0.78	0.221	7.384	6.352	9.97	10.11	1.94	3.11	12			
Flow to No.3 Pumping Station																				
22	24.0	24	370	370	0.032	0.032	250	2.6	0.67	0.033	7.968	6.906	9.25	9.50	1.00	2.33	8			
23	58.5	82.5	530	900	0.111	0.111	450	1.4	0.73	0.116	6.706	5.784	9.50	10.11	2.31	3.84	9			
Flow to No.3 Pumping Station (A4=497.4 ha)																				
24	36	1073.9	1,650	7,510	0.659	0.659	700	4.4	1.73	0.666	8.360	8.570	10.11	10.32	1.00	1.00	-	Force Main		
<b>ZONE-2</b>																				
25	194.8	194.8	750	750	0.262	0.262	750	0.8	0.77	0.341	6.190	5.330	8.00	8.10	1.00	1.96	13			
26	95.0	289.8	770	1,520	0.389	0.389	900	0.7	0.82	0.519	5.180	4.381	8.10	8.20	1.93	2.83	13			
Flow to No.4 Pumping Station																				
27	98.9	98.9	460	460	0.133	0.133	500	1.3	0.75	0.147	6.858	6.100	8.40	8.20	1.00	1.56	8			
Flow to No.4 Pumping Station (A2=388.7 ha)																				
28	35	388.7	2,660	4,160	0.239	0.239	450	6.0	1.50	0.239	6.712	7.422	8.20	8.91	1.00	1.00	-	Force Main		

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-1 Sewerage Computation Sheet For Zagazig (3 of 4)

NO of Sewer	Sewerage Area		Sewer Length	Unit Sewage Flow Per ha		Design Sewer		Sewer Invert Elevation		Ground Elevation		Earth Cover		NO of MII	Remark	
	Increment Area	Cumulated Area		ha	ha	m <sup>3</sup> /s	mm	Diameter	Slope	Velocity	Capacity	Begin	End			Begin
29	43.3	43.3	610	0.058	350	1.8	0.70	0.067	7.133	5.835	8.50	9.00	1.00	2.80	10	
30	90.1	133.4	1,200	0.179	600	1.1	0.78	0.221	5.585	3.865	9.00	9.44	2.77	4.92	20	
31	96.1	229.5	240	0.308	750	0.8	0.77	0.341	3.715	3.443	9.44	8.91	4.92	4.66	4	
32	105.3	105.3	560	0.142	450	2.1	0.89	0.142	8.602	7.246	10.09	8.91	1.00	1.18	9	
33	-	334.8	200	0.450	900	0.7	0.82	0.519	3.293	3.093	8.91	9.00	4.63	4.92	3	
Flow to No.5 Pumping Station (A3=334.8 ha)																
34	-	334.8	200	0.206	400	8.3	1.64	0.206	7.581	7.491	9.00	8.91	1.00	1.00	-	Force Main
35	-	723.5	660	0.444	600	4.5	1.58	0.446	7.260	8.670	8.91	10.32	1.00	1.00	-	Force Main
36	-	1,797.4	710	1.104	900	3.2	1.74	1.109	8.330	8.000	10.32	9.99	1.00	1.00	-	Force Main
Flow to STP																
ZONE-1	(A1=220.0 ha)															
ZONE-5	(A5=325.0 ha)															
ZONE-6	(A6=383.6 ha)															
Total	2,726.0															

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-1 Sewerage Computation Sheet For Zagazig (4 of 4)

NO of Sewer	Flow to Sewer	Sewerage Area		Sewer Length		Unit Sewage Flow Per ha		Sewer Invert Elevation		Ground Elevation		Earth Cover		NO of MH	Remark
		Incremental Area ha	Cumulative Area ha	Incremental Length m	Cumulative Length m	Design Flow m <sup>3</sup> /s	Design Flow m <sup>3</sup> /ha	Velocity m/s	Capacity m <sup>3</sup> /s	Begin m	End m	Begin m	End m		
	Design Flow of No.1 Pumping Station					0.088	0.001344					0.000614			
	Design Flow of No.2 Pumping Station					0.271									
	Design Flow of No.3 Pumping Station					0.305									
	Design Flow of No.4 Pumping Station					0.239									
	Design Flow of No.5 Pumping Station					0.206									

Table XX-2 Calculation Sheet of Pumping Station for Zagazig

City Name	Items	Unit	Pump No													
			1	2	3	4	5	6	7	8	9					
ZAGAZIG	Wastewater	m <sup>3</sup> /sec	0.083	0.271	0.305	0.239	0.206	0.488								
		m <sup>3</sup> /min	5.0	16.3	18.3	14.3	12.4	29.3								
	Inlet Diameter	m	0.6	0.6	0.6	0.5	0.9	1.2								
	Pipe Elevation	m	2.72	2.42	6.35	6.10	3.08	5.00								
	Ground Elevation	m	9.99	9.99	9.99	9.99	9.99	9.99								
	Pump															
	Mos.	N	2	3	3	3	3	3								
	Q/Unit	Qp=Qm/N	2.5	5.4	6.1	4.8	4.1	9.8								
	Dia. in need	D=146*(Qp/2.0) <sup>(1/2)</sup>	162.9	240.3	255.0	225.7	209.5	322.4								
Diameter	Dp	150	250	250	200	200	300									
Pump																
Force Main Length	L	5.580	5.370	2.360	4.030	1.370	2.000									
Loss in Pipe	H1=L*.01	56.8	53.7	23.6	40.3	13.7	20.0									
Water Head	H2=Et-Ep	7.3	7.6	3.6	3.9	6.9	5.0									
Loss	H3=4.0(2.0)	4.0	4.0	4.0	4.0	4.0	4.0									
Total Loss	H=H1+H2+H3	67.1	65.3	31.2	48.2	24.6	29.0									
Pump Capacity	KW	Ps=0.163*H*Qp/0.6	45.4	96.1	51.8	62.6	27.5	76.8								
Motor Capacity	KW	P=Ps*(1+0.1)	49.9	105.7	56.9	68.8	30.3	84.5								
Pump																
Diameter	mm	150	250	250	200	200	300									
Quantity	m <sup>3</sup> /min	2.5	5.4	6.1	4.8	4.1	9.8									
Spec	m	67.1	65.3	31.2	48.2	24.6	29.0									
Motor Capacity	KW	55	90	55	75	30	90									
Nos.		3	4	4	4	4	4									
	I Standby															





## FAQs



FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-3 Sewerage Computation Sheet For Faqus (1 of 3)

NO of Sewer to Flow	Sewerage Area		Sewer Length		Unit Sewerage Flow Per ha		Sewer Invert Elevation		Ground Elevation		Earth Cover		NO of MH	Remark			
	Increment	Cumulated	Increment	Cumulated	Design Flow	Sewer Diameter	Slope	Velocity	Capacity	Begin	End	Begin			End	Begin	End
	ha	ha	m	m	m <sup>3</sup> /s	mm	%	m/s	m <sup>3</sup> /s	m	m	m			m	m	m
ZONE-1																	
1	20.9	20.9	320	320	0.027	250	2.6	0.67	0.033	4.008	3.048	7.27	7.46	3.00	4.15	6	
2	10.6	31.5	320	640	0.040	300	2.2	0.70	0.049	2.998	2.166	7.46	7.38	4.15	4.90	6	
3	14.9	46.4	400	1,040	0.059	350	1.8	0.70	0.067	2.116	1.236	7.38	9.23	4.90	7.63	8	
4	26.2	26.2	200	200	0.033	250	2.6	0.67	0.033	6.008	5.408	7.27	7.30	1.00	1.63	4	
5	12.8	39.0	380	580	0.050	350	1.8	0.70	0.067	5.308	4.472	7.30	7.40	1.63	2.56	8	
6	8.9	47.9	460	1,040	0.061	350	1.8	0.70	0.067	4.472	3.460	7.40	9.23	2.56	5.40	9	
7	2.7	97.0	250	1,290	0.123	500	1.3	0.75	0.147	1.086	0.661	9.23	9.74	7.60	8.54	5	
8	16.0	16.0	290	290	0.020	200	3.2	0.64	0.020	5.020	3.976	6.23	6.86	1.00	2.67	6	
9	15.0	31.0	350	640	0.039	300	2.2	0.70	0.049	3.876	2.966	6.86	6.32	2.67	3.04	7	
10	20.3	51.3	350	990	0.065	350	1.8	0.70	0.067	2.916	2.146	6.32	7.37	3.04	4.86	7	
11	7.9	59.2	300	1,290	0.075	400	1.6	0.72	0.090	2.096	1.496	7.37	9.74	4.86	7.83	6	
12	2.2	158.4	200	1,490	0.201	600	1.1	0.78	0.221	0.561	0.261	9.74	7.00	8.53	6.09	4	
13	18.2	18.2	210	210	0.023	250	2.6	0.67	0.033	4.238	3.608	5.50	6.00	1.00	2.13	4	
14	13.9	32.1	250	460	0.041	300	2.2	0.70	0.049	3.558	2.908	6.00	6.30	2.13	3.08	5	
15	14.3	46.4	560	1,020	0.059	350	1.8	0.70	0.067	2.858	1.626	6.30	7.00	3.08	5.01	11	
16	8.3	213.1	580	2,020	0.271	750	0.8	0.77	0.341	0.111	-0.525	7.00	6.25	6.08	5.97	11	
17	12.7	225.6	290	2,310	0.287	750	0.8	0.77	0.341	-0.525	-0.873	6.25	5.70	5.97	5.76	6	

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-3 Sewerage Computation Sheet For Faqus (2 of 3)

NO of Sewer	Flow to	Sewerage Area		Sewer Length		Unit Sewerage Flow Per ha		0.001271 m <sup>3</sup> /sec/ha (in 2040)		0.000608 m <sup>3</sup> /sec/ha (in 2005)		N <sub>0</sub> of MFI	Remark						
		Increment Area	Cumulated Area	Length	Increment Length	Design Flow	Sewer Diameter	Slope	Velocity	Capacity	Sewer Elevation			Ground Elevation	Earth Cover				
		ha	ha	m	m	m <sup>3</sup> /s	mm	%	m/s	m <sup>3</sup> /s	m	m	Begin	End	Begin	End	m	m	
18	19	13.1	238.9	200	2,510	0.304	750	0.8	0.77	0.341	-0.873	-1.113	5.70	5.50	5.76	5.80			4
19	24	-	238.9	700	3,210	0.145	350	8.4	1.51	0.145	4.081	4.871	5.50	6.29	1.00	1.00			Force Main
ZONE-3																			
20		10.0	10.0	150	150	0.013	200	3.2	0.64	0.020	4.790	4.250	6.00	6.25	1.00	1.79			3
21		13.3	23.3	190	340	0.030	250	2.6	0.67	0.033	4.200	3.630	6.25	6.50	1.79	2.61			4
22		20.9	44.2	140	480	0.056	350	1.8	0.70	0.067	3.530	3.222	6.50	6.76	2.60	3.17			3
23		6.6	50.8	330	810	0.065	350	1.8	0.70	0.067	3.222	2.496	6.76	6.29	3.17	3.43			7
24	28	4.0	293.7	340	3,550	0.373	900	0.7	0.82	0.519	1.948	1.572	6.29	6.18	3.35	3.62			7
25		15.1	15.1	310	310	0.019	200	3.2	0.64	0.020	6.790	5.674	8.00	7.40	1.00	1.52			6
26		14.5	29.6	400	710	0.038	300	2.2	0.70	0.049	5.574	4.534	7.40	6.80	1.51	1.95			8
27		9.6	39.2	420	1,130	0.050	350	1.8	0.70	0.067	4.484	3.560	6.80	6.18	1.95	2.25			8
28	38	3.9	336.8	260	3,810	0.428	900	0.7	0.82	0.519	1.572	1.286	6.18	5.56	3.62	3.28			5
ZONE-2																			
29		33.8	33.8	410	410	0.043	300	2.2	0.70	0.049	4.685	3.619	6.00	5.80	1.00	1.87			8
30	33	11.2	45.0	310	720	0.057	350	1.8	0.70	0.067	3.569	2.887	5.80	5.60	1.86	2.35			6
31		37.1	37.1	230	230	0.047	300	2.2	0.70	0.049	4.685	4.087	6.00	5.80	1.00	1.40			5
32	33	17.4	54.5	320	550	0.069	400	1.6	0.72	0.090	3.987	3.347	5.80	5.60	1.39	1.83			6

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-3 Sewerage Computation Sheet For Faqus (3 of 3)

NO of Sewer	Sewerage Area		Sewer Length		Unit Sewerage Flow Per ha		0.001271 m <sup>3</sup> /sec/ha (in 2040)		0.000608 m <sup>3</sup> /sec/ha (in 2005)		NO of MH	Remark
	Increment	Cumulated	Increment	Cumulated	Design Flow	Design Velocity	Capacity	Elevation	Elevation	Earth Cover		
	ha	ha	m	m	m <sup>3</sup> /s	m/s	m <sup>3</sup> /s	Begin	End	Begin	End	
Flow to No.2 Pumping Station												
ZONE-3				(A2=99.5 ha)								
33	10.6	110.1	240		0.140	0.500	0.147	4.058	3.650	5.60	5.60	1.41
34	12.7	122.8	250		0.156	0.600	0.221	3.550	3.175	5.60	5.60	1.78
35	10.7	10.7	260		0.014	0.200	0.021	6.790	5.789	8.00	7.00	1.00
36	7.3	18.0	660		0.023	0.250	0.033	5.739	3.759	7.00	5.60	1.58
37	15.9	156.7	390		0.199	0.600	0.221	3.175	2.590	5.60	5.56	2.32
38	-	493.5	50		0.627	1.000	0.87	1.186	1.131	5.56	5.56	3.33
Flow to No.3 Pumping Station				(A3=176.6 ha)								
39	-	515.0	2,400		0.313	0.450	1.97	3.910	2.850	5.56	4.50	1.00
Flow to STP												
Design Sewerage Flow of No.1 Pumping Station					0.145	m <sup>3</sup> /sec						
Design Sewerage Flow of No.2 Pumping Station					0.060	m <sup>3</sup> /sec						
Design Sewerage Flow of No.3 Pumping Station					0.313	m <sup>3</sup> /sec						

Table XX-4 Calculation Sheet of Pumping Station for Faqus

City Name	Items	Unit	Pump No											
			1	2	3	4	5	6	7	8	9			
FAQUS	Wastewater	m <sup>3</sup> /sec	0.145	0.060	0.313									
		m <sup>3</sup> /min	8.7	3.6	18.8									
	Inlet Pipe	m	0.75	0.35	1.00									
	Elevation	m	-1.11	-2.88	-1.33									
	Ground Elevation	m	6.29	5.60	5.00									
	Pump	Nos.	2	2	2									
		Q/Unit	Q <sub>p</sub> =Q <sub>m</sub> /N	4.4	1.8	9.4								
		Dia. in need	D=146*(Q <sub>p</sub> /2.0) <sup>(1/2)</sup>	215.3	138.5	316.4								
		Diameter	D <sub>p</sub>	200	150	300								
	Pump	Force Main Length	m	700	-	2,400								
	Loss	Loss in Pipe	m	7.0		24.0								
		Water Head	m	7.4	8.5	6.3								
		+a	m	2.0	2.0	4.0								
	Total Loss	m	16.4	10.5	34.3									
Pump Capacity	KW	Ps=0.163*H*Q <sub>p</sub> /0.6	19.4	5.1	87.6									
Motor Capacity	KW	P=Ps*(1+0.1)	21.3	5.6	96.3									
Pump Spec	Diameter	mm	200	150	300									
	Quantity	m <sup>3</sup> /min	4.4	1.8	9.4									
	Loss	m	16.4	10.5	34.3									
	Motor Capacity	KW	22	5.5	110									
	Nos.	I Standby	3	3	3									

Table XX-5 Process Design of STP for Faqus (1 of 3)

Facility	Items	Unit	
Condition	Daily Max	m <sup>3</sup> /day	Qd 20,481
	Hourly Max	m <sup>3</sup> /day	Qh 27,052
Grit Chamber	Surface Load(1,800)	m <sup>3</sup> /m <sup>2</sup> /day	A (1,800)
	Area in Need	m <sup>2</sup>	Qh/A (15.0)
	Width	m	W 1.0
	Length	m	L 7.5
	Depth	m	H 1.0
	Nos.	N	N 2
	Area	m <sup>2</sup>	A=W*L*N 15.0
	Volume	m <sup>3</sup>	V=W*L*H*N 15.0
	Surface Load	m <sup>3</sup> /m <sup>2</sup> /day	Qh/A 1,803.5
	Retention Time	sec	V*86400/Qh 47.9
Primary Sedimentation Tank	Surface Load(25-50)	m <sup>3</sup> /m <sup>2</sup> /day	A (40)
	Area in Need	m <sup>2</sup>	Qd/A (512.0)
	Diameter	m	D 18.0
	Depth	m	H 3.5
	Nos.	N	N 2
	Area	m <sup>2</sup>	A=3.14*D*D/4*N 508.7
	Volume	m <sup>3</sup>	V=A*H 1,780.4
	Surface Load	m <sup>3</sup> /m <sup>2</sup> /day	Qd/A 40.3
	Retention Time	hours	V*24/Qh 1.6

Note: Figures in parentheses are guidelines for calculation of capacities.

Table XX-5 Process Design of STP for Faqus (2 of 3)

Facility	Items	Unit	
Aeration Tank	BOD-SS Load(0.2-0.4)	kg/kg/day	B0
	Aeration Time(6-12)	hours	T
	Return Sludge Ratio	%	a
	MLSS	mg/l	$ML=(152 \times 1.0 + 8,000 \times 0.25) / 1.25$
	BOD Removed	kg/day	$BR=(315-30) \times 10(-3) \times Qd$
	Volume in Need	m <sup>3</sup>	$V=Qd \times T / 24$
	Width	m	W
	Length	m	L
	Depth	m	H
	Nos.		N
	Tank Volume	m <sup>3</sup>	$V=W \times L \times H \times N$
	SS in Tank	kg	$SS=V \times 1722 \times 10(-3)$
	BOD-SS Load	kg/kg/day	BR/SS
	Sludge Age	days	$V \times 1722 / Qd / 152$
	Aeration Time	hours	$V \times 24 / Qd$
Final Sedimentation Tank	Surface Load(20-30)	m <sup>3</sup> /m <sup>2</sup> /day	A
	Area in Need	m <sup>2</sup>	$Qd/A$
	Diameter	m	D
	Depth	m	H
	Nos.		N
	Area	m <sup>2</sup>	$A=3.14 \times D^2 / 4 \times N$
	Volume	m <sup>3</sup>	$V=A \times H$
	Surface Load	m <sup>3</sup> /m <sup>2</sup> /day	$Qh/A$
	Retention Time	hours	$V \times 24 / Qh$
Chlorine Contact Tank	Contact Time(15)	min	
	Width	m	W
	Length	m	L
	Depth	m	H
	Channel		N
	Tank Volume	m <sup>3</sup>	$V=W \times L \times H \times N$
	Contact Time	min	$T=V \times 1440 / Qd$

Note: Figures in parentheses are guidelines for calculation of capacities.



Table XX-5 Process Design of STP for Faqus (3 of 3)

Facility	Items	Unit			
Sludge	Dry Solid	kg/day	$DS = (460 - 30) * 10^{(-3)} * Qd$	8,808.8	
	Sludge Volume	m <sup>3</sup>	$Q = DS / 0.01 * .001$	880.7	
Sludge Thickner	Solid Load(60)	m <sup>2</sup> /kg/day	SL	(60.0)	
	Area in Need	m <sup>2</sup>	DS/SL	(146.8)	
	Diameter	m	D	10.0	
	Depth	m	H	4.0	
	Nos.		N	2	
	Area	m <sup>2</sup>	$A = 3.14 * D * D / 4 * N$	157.0	
	Volume	m <sup>3</sup>	$V = A * H$	628.0	
	Sludge Load	m <sup>2</sup> /kg/day	DS/A	56.1	
	Retention Time	hours	$V * 24 / Q$	4.3	
Drying Bed	Sludge Volume	m <sup>3</sup>	$Q = DS / 0.05 * .001$	178.1	
	Retention Time	day	RT	(5.0)	
	Thickness	m	TH	(.5)	
	Volume in Need	m <sup>3</sup>	$V = Q * RT$	(880.7)	
	Area in Need	m <sup>2</sup>	$A = V / TH$	(1,761.4)	
	Width	m	W	10.0	
	Length	m	L	10.0	
	Depth	m	H	.5	
	Nos.		N	20	
	Tank Volume	m <sup>3</sup>	$V = W * L * H * N$	1,000.0	
	Retention Time	day	$V / Q$	5.7	

Note: Figures in parentheses are guidelines for calculation of capacities.

Table XX-6 Fagus City Hydraulic Calculation Sheet of STP for Faqus (1 of 5)

Facility	Items	Unit	Daily Max	Hourly Max	
Initial Condition	Ground Level of STP	m	5.5	5.5	
	Water Level of Drain	m	3.5	3.5	
Chlorine Contact Tank	Wastewater	m <sup>3</sup> /day	20,481	27,052	
		m <sup>3</sup> /sec	0.237	0.313	
Chlorine Contact Tank	Wastewater	m <sup>3</sup> /sec	0.237	0.313	
	Pipe	Diameter	m	0.5	0.5
		Length	m	25	25
		Cross Area	m <sup>2</sup>	$A=3.14 \cdot D(2)/4$	0.196
	Velocity		m	0.125	0.125
			m/sec	$V=Qs/A$	1.209
				$I=V(2) \cdot 0.012(2)/R(4/3)$	0.003368
	Loss of Pipe		m	0.084	0.147
			m	$H1=L \cdot I$	0.112
	Total Loss		m	0.196	0.196
			m	$H=H1+H2$	3.842
	Barrage	Width	m	3.0	3.0
		Height	m	3.8	3.8
	Height of Overflow		m	$H3=(Qs/1.84/B)(2/3)$	0.123
			m	$WLc2=GH+H3$	3.923
	Water Level	m	3.923	3.918	

Table XX-6 Hydraulic Calculation Sheet of STP for Faqus (2 of 5)  
 Faqus City

Facility	Items	Unit	Equation	Daily Max	Hourly Max
Final Sedimentation Tank	Wastewater	m <sup>3</sup> /sec	Qs	0.237	0.313
	Pipe	m	D	0.5	0.5
		m	L	25.0	25.0
	No.1	m <sup>2</sup>	$A=3.14*(D/2)^2/4$	0.196	0.196
		m	R=D/4	0.125	0.125
	Velocity	m/sec	V=Qs/A	1.209	1.597
	Loss of Pipe	m	$I=V(2)*0.012(2)/R(4/3)$	0.003368	0.005376
	Loss of out	m	H1=L*I	0.084	0.147
		m	H2=1.0*V(2)/19.6	0.075	0.130
	Wastewater	m <sup>3</sup> /sec	Q=Qs/2	0.119	0.157
	Pipe	m	D	0.4	0.4
		m	L	86	86
	No.2	m <sup>2</sup>	$A=3.14*(D/2)^2/4$	0.126	0.126
		m	R=D/4	0.100	0.100
	Velocity	m/sec	V=Q/A	0.940	1.242
	Loss of Pipe	m	$I=V(2)*0.012(2)/R(4/3)$	0.002744	0.004786
	Loss of in	m	H3=L*I	0.236	0.412
Total Loss	m	H4=0.5*V(2)/19.6	0.023	0.039	
out of PST	m	H=H1+H2+H3+H4	0.418	0.728	
	m	Wf1=Wf2+H	4.341	4.676	
Notch	m	Dia	21.0	21.0	
	per	N=3.14*Dia/0.15	440	440	
Height of Overflow	m	NH	4.800	4.800	
Water Level	m	H3=(Q/1.55N)(2/5)	0.031	0.035	
	m	Wf2=NH+H3	4.831	4.835	

Table XX-6 Hydraulic Calculation Sheet of STP for Faqus (3 of 5)  
 Facility Faqus City

Facility	Items	Unit	Daily Max	Hourly Max
Aeration Tank	Wastewater	m <sup>3</sup> /sec	0.119	0.157
	Pipe	m	0.4	0.4
	Diameter	m	25.0	25.0
	Length	m	0.126	0.126
	No.1	m <sup>2</sup>	0.100	0.100
	Cross Area	m	1.242	1.242
	Velocity	m/sec	0.002741	0.004786
	Loss of Pipe	m	0.069	0.120
	Loss of in & out	m	0.068	0.118
	Total Loss	m	0.137	0.238
	out of Distribution Tank	m	4.988	5.073
	Distribu. Well	m	1.0	1.0
	Width	m	5.1	5.1
	Height	m	0.161	0.193
	Height of Overflow	m	5.261	5.293
	Water Level of Dist.Well	m		
	Wastewater	m <sup>3</sup> /sec	0.237	0.313
	Pipe	m	0.5	0.5
	Diameter	m	25.0	25.0
	Length	m	0.196	0.196
	No.1	m <sup>2</sup>	0.125	0.125
	Cross Area	m	1.209	1.597
	Velocity	m/sec	0.003368	0.005876
Loss of Pipe	m	0.084	0.147	
Loss of in & out	m	0.112	0.195	
Total Loss	m	0.196	0.342	
out of Aeration Tank	m	5.457	5.635	
Wastewater	m <sup>3</sup> /sec	0.059	0.078	
Barrage	m	10.0	10.0	
Width	m	5.7	5.7	
Height	m			
Height of Overflow	m	0.022	0.026	
Water Level of AT	m	5.722	5.726	

Table XX-6 Hydraulic Calculation Sheet of STP for Faqus (4 of 5)  
 Faqus City  
 Primary Sedimentation Tank

Facility	Items	Unit	Daily Max	Hourly Max	
Primary Sedimentation Tank	Wastewater	m <sup>3</sup> /sec	Q=Qs/8	0.030	
	Barrage	Width	m	B	0.4
		Height	m	G/H	5.4
	Water Depth	h=WLd-GH	m	0.324	0.326
		A=B*h	m <sup>2</sup>	0.129	0.130
	Velocity	V=Q/A	m/sec	0.233	0.300
		H1=1.5*V(2)	m	0.081	0.135
	Water Level of AT inflow	WLP1=WLd+H1	m	5.803	5.861
	Wastewater	m <sup>3</sup> /sec	Q=Qs	0.237	0.313
	Pipe No.1	Diameter	m	D	0.5
		Length	m	L	10
		Gross Area	m <sup>2</sup>	A=3.14*D(2)/4	0.196
	Velocity	R=D/4	m	0.125	0.125
		V=Q/A	m/sec	1.208	1.595
	Loss of Pipe	I=V(2)*0.012(2)/R(4/3)	m	0.00386	0.00386
Loss of out	H1=L*I	m	0.034	0.059	
	H2=1.0*V(2)/19.6	m	0.074	0.130	
Wastewater	m <sup>3</sup> /sec	Q=Qs/2	0.119	0.157	
Pipe No.2	Diameter	m	D	0.4	
	Length	m	L	86	
	Gross Area	m <sup>2</sup>	A=3.14*D(2)/4	0.126	
Velocity	R=D/4	m	0.100	0.100	
	V=Q/A	m/sec	0.940	1.242	
Loss of Pipe	I=V(2)*0.012(2)/R(4/3)	m	0.002744	0.004786	
Loss of in	H3=L*I	m	0.236	0.412	
	H4=0.5*V(2)/19.6	m	0.023	0.039	
Total Loss out of PST	H=H1+H2+H3+H4	m	0.367	0.639	
	WLP2=WLP1+H	m	6.170	6.500	
Notch	Dia. of Notch	m	Dia.	17.0	
	Num. of Notch	per	N=3.14*Dia/0.15	356.0	
Height of Overflow	Height	m	NH	6.7	
	H3=(Q/1.55/N)(2/5)	m	0.034	0.038	
Water Level of PST	WLP3=NH+H3	m	6.734	6.738	

Table XX-6 Hydraulic Calculation Sheet of STP for Faqus (5 of 5)  
 Facility Faqus City

Facility	Items	Unit	Daily Max	Hourly Max	
Grit Chamber	Wastewater	m <sup>3</sup> /sec	0.119	0.157	
	Pipe No.1	m	0.4	0.4	
	Diameter	m	30	30	
	Length	m <sup>2</sup>	A=3.14*D(2)/4	0.126	
	Cross Area	m	R=D/4	0.100	
	Velocity	m/sec	V=Q/A	0.943	
	Loss of Pipe	m	I=V(2)*0.012(2)/R(4/3)	0.002762	
	Loss of in & out	m	H1=L*I	0.083	
	Total Loss	m	H2=1.5*V(2)/19.6	0.023	
	Water Level of Dist. Well	m	H=H1+H2	0.106	
	Water Level of out of Distribution Well	m	WLG1=WLG3+H	6.840	
	Water Level of Distrib. Well	m	WLG1=WLG3+H	6.922	
	Distrib. Well	m	B	I	
	Width	m	GH	7.000	
	Height	m	H3=(Q/1.847B)(2/3)	0.161	
	Height of Overflow	m	WLG2=GH+H3	7.161	
	Water Level of Dist. Well	m		7.193	
	Wastewater	m <sup>3</sup> /sec	Q=Qs	0.237	0.313
	Pipe No.1	m	D	0.5	0.5
	Diameter	m	L	30	30
Length	m <sup>2</sup>	A=3.14*D(2)/4	0.196	0.196	
Cross Area	m	R=D/4	0.125	0.125	
Velocity	m/sec	V=Q/A	1.208	1.595	
Loss of Pipe	m	I=V(2)*0.012(2)/R(4/3)	0.00385	0.003861	
Loss of in & out	m	H4=L*I	0.101	0.176	
Total Loss	m	H5=1.5*V(2)/19.6	0.037	0.065	
Water Level of out of GT	m	H=H4+H5	0.138	0.241	
Water Level of out of GT	m	WLG3=WLG2+H	7.299	7.434	
Loss of Screen	m	H6	0.1	0.1	
Water Level of GT Inflow	m	WLG4=WLG3+H6	7.399	7.534	

**Bilbeis**





FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-7 Sewerage Computation Sheet For Bilbeis City (1 of 3)

NO of Flow Sewer to	Sewerage Area		Sewer Length		Unit Sewerage Flow Per ha			Sewer Invert Elevation			Ground Elevation			Earth Cover		Remark	
	Increment Area ha	Cumulated Area ha	Increment Length m	Cumulated Length m	Design Flow m <sup>3</sup> /s	Sewer Diameter mm	Slope %	Velocity m/s	Capacity m <sup>3</sup> /s	Begin m	End m	Begin m	End m	Begin m	End m		NO of MH
ZONE-1																	
1	33.6	33.6	460	460	0.115	Ø450	2.0	0.87	0.138	16.512	15.412	19.00	17.00	2.00	1.10	9	
2	30.4	64.0	440	900	0.219	Ø600	1.1	0.78	0.221	14.350	13.706	17.00	16.00	2.00	1.64	8	
3	23.6	87.6	400	1,300	0.300	Ø750	0.8	0.77	0.341	13.190	12.710	16.00	15.00	2.00	1.48	8	
4	7.8	95.4	480	1,780	0.327	Ø750	0.8	0.77	0.341	12.190	11.626	15.00	14.10	2.00	1.66	9	
	Flow to No.1 Pumping Station																
5	13.8	13.8	270	270	0.086	Ø350	4.0	1.04	0.100	17.605	16.425	19.92	17.99	2.00	1.25	5	From Army Camp 0.039(0.032)
6	15.2	29.0	240	510	0.138	Ø450	2.0	0.87	0.138	15.502	14.942	17.99	17.23	2.00	1.80	4	
7	27.1	56.1	450	960	0.231	Ø600	1.5	0.91	0.258	14.580	13.725	17.23	15.66	2.00	1.28	9	
8	8.0	8.0	500	500	0.027	Ø250	2.6	0.67	0.033	13.738	12.238	15.00	15.66	1.00	3.16	10	
9	10.4	74.5	450	1,410	0.294	Ø750	0.8	0.77	0.341	11.738	11.198	15.66	14.28	3.11	2.27	9	
10	5.1	5.1	180	180	0.017	Ø200	3.0	0.62	0.019	12.230	11.630	13.44	13.78	1.00	1.94	3	
11	8.2	13.3	250	430	0.046	Ø300	2.2	0.70	0.049	11.530	10.880	13.78	13.03	1.94	1.84	5	
12	5.9	19.2	300	730	0.066	Ø350	1.8	0.70	0.067	10.830	10.170	13.03	13.59	1.81	3.03	6	
13	11.3	11.3	380	380	0.039	Ø300	2.2	0.70	0.049	12.685	11.709	14.00	13.59	1.00	1.57	7	
14	3.5	34.0	240	970	0.117	Ø450	1.5	0.75	0.120	10.070	9.630	13.59	14.28	3.03	4.16	4	
15	6.6	115.1	350	1,760	0.433	Ø900	0.7	0.82	0.519	9.180	8.795	14.28	14.10	4.11	4.32	7	

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-7 Sewerage Computation Sheet For Bilbeis City (2 of 3)

NO of Sewer	Sewerage Area		Sewer Length	Unit Sewerage Flow Per ha		Sewer Invert. Elevation		Ground Elevation		Earth Cover	NO of MH	Remark				
	Increment Area	Cumulated Area		Flow m <sup>3</sup> /s	Designated Sewer Diameter mm	Slope %	Velocity m/s	Capacity m <sup>3</sup> /s	Begin m				End m	Begin m	End m	
	Flow to No.1 Pumping Station (A1=210.5 ha)															
16	-	210.5	500	2,260	0.244	11.7	1.94	0.244	12.681	8.581	14.10	10.00	1.00	1.00	10	Force Main
17	40.5	251.0	440	2,700	0.285	8.5	1.79	0.285	8.512	7.972	10.00	9.46	1.00	1.00	8	From No.2 P/S
18	79.1	330.1	650	3,350	0.364	7.9	1.85	0.364	7.918	8.688	9.46	10.21	1.00	1.00	13	Force Main
19	97.0	427.1	100	3,450	0.462	12.8	2.36	0.462	8.668	8.708	10.21	10.25	1.00	1.00	2	From No.3 P/S
20	41.6	41.6	1,000	1,000	0.042	14.0	1.34	0.042	7.290	9.040	8.50	10.25	1.00	1.00	20	Force Main
21	-	468.7	330	3,780	0.504	5.8	1.79	0.507	8.600	8.300	10.25	9.95	1.00	1.00	6	From No.5 P/S
22	28.5	497.2	550	4,330	0.533	6.5	1.90	0.536	8.300	7.200	9.95	8.85	1.00	1.00	11	Force Main
23	55.9	55.9	650	650	0.056	7.6	1.14	0.056	7.238	7.588	8.50	8.85	1.00	1.00	13	From No.6 P/S
24	48.3	48.3	950	950	0.049	5.8	1.00	0.049	7.238	7.588	8.50	8.85	1.00	1.00	19	Force Main
25	-	601.4	160	4,490	0.638	9.2	2.26	0.638	7.200	7.490	8.85	9.14	1.00	1.00	3	From No.7 P/S
26	65.6	667.0	350	4,840	0.704	11.2	2.49	0.704	7.490	7.650	9.14	9.30	1.00	1.00	7	Force Main
	Flow to Treatment Plant															

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM

Table XX-7 Sewerage Computation Sheet For Bilbeis City (3 of 3)

NO of Sewer	Sewerage Area		Sewer Length		Design Flow m <sup>3</sup> /s	Sewer Diameter mm	Sewer Velocity m/s	Sewer Invert Elevation		Ground Elevation		m <sup>3</sup> /sec/ha (in 2040)	m <sup>3</sup> /sec/ha (in 2005)	Earth Cover Begin	Earth Cover End	NO of MH	Remark
	ha	ha	m	m				Begin	End	Begin	End						
	Increment	Cumulated	Increment	Cumulated				Capacity	Slope %	Begin	End						
Design Sewerage Flow of No.1			Pumping Station		0.212	m <sup>3</sup> /sec											
Design Sewerage Flow of No.2			Pumping Station		0.041	m <sup>3</sup> /sec											
Design Sewerage Flow of No.3			Pumping Station		0.080	m <sup>3</sup> /sec											
Design Sewerage Flow of No.4			Pumping Station		0.098	m <sup>3</sup> /sec											
Design Sewerage Flow of No.5			Pumping Station		0.042	m <sup>3</sup> /sec											
Design Sewerage Flow of No.6			Pumping Station		0.029	m <sup>3</sup> /sec											
Design Sewerage Flow of No.7			Pumping Station		0.058	m <sup>3</sup> /sec											
Design Sewerage Flow of No.8			Pumping Station		0.049	m <sup>3</sup> /sec											
Design Sewerage Flow of No.9			Pumping Station		0.066	m <sup>3</sup> /sec											

Table XX-8 Calculation Sheet of Pumping Station for Bilbeis

City Name	Items	Unit	Pump No								
			1	2	3	4	5	6	7	8	9
BILBEIS	Wastewater	m <sup>3</sup> /sec	0.212	0.041	0.080	0.098	0.042	0.029	0.056	0.049	0.066
		m <sup>3</sup> /min	12.7	2.5	4.8	5.9	2.5	1.7	3.4	2.9	4.0
	Inlet Pipe	m	0.90	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25
		Ep	8.80	7.00	6.46	7.21	5.50	6.95	5.50	5.50	6.14
	Ground Elevation	m	8.80	8.80	8.80	8.80	8.80	8.80	8.80	8.80	8.80
	Pump	Nos.	2	1	2	2	1	1	1	1	1
		Q/Unit	6.4	2.5	2.4	2.9	2.5	1.7	3.4	2.9	4.0
		Dia. in need	mm	260.4	161.9	159.9	177.0	163.9	136.2	189.2	177.0
		Diameter	mm	250	150	150	200	150	200	200	200
	Pump Loss	Force Main Length	m	3.080	2.580	2.140	1.490	2.390	1.060	1.160	1.460
	Loss in Pipe	m	30.8	25.8	21.4	14.9	23.9	10.6	11.6	14.6	
	Water Head	m	0.0	1.8	2.3	1.6	3.3	1.9	3.3	3.3	
	+a	m	4.0	4.0	4.0	4.0	4.0	4.0	4.0	4.0	
	Total Loss	m	34.8	31.6	27.7	20.5	31.2	16.5	18.9	21.9	
Pump Capacity	KW		60.1	21.1	18.1	16.4	21.4	7.8	17.3	17.5	
Motor Capacity	KW		66.1	23.2	19.9	18.0	23.5	8.6	19.0	19.2	
Pump Spec	Diameter	mm	250	150	150	200	150	200	200	200	
	Quantity	m <sup>3</sup> /min	6.4	2.5	2.4	2.9	2.5	1.7	3.4	2.9	
	Loss	m	34.8	31.6	27.7	20.5	31.2	16.5	18.9	21.9	
	Motor Capacity	KW	75	30	22	22	30	11	22	22	
	Nos.		3	2	3	3	2	2	2	2	

Table XX-9 Process Design of STP for Bilbeis (1 of 3)

Facility	Items	Unit	
Condition	Daily Max	m3/day	Qd 44,606
	Hourly Max	m3/day	Qh 60,864
Grit Chamber	Surface Load(1,800)	m3/m2/day	A (1,800)
	Area in Need	m2	Qh/A (33.8)
	Width	m	W 1.2
	Length	m	L 7.5
	Depth	m	H 1.0
	Nos.		N 4
	Area	m2	A=W*L*N 36.0
	Volume	m3	V=W*L*H*N 36.0
	Surface Load	m3/m2/day	Qh/A 1,800.7
	Retention Time	sec	V*86400/Qh 51.1
Primary Sedimentation Tank	Surface Load(25-50)	m3/m2/day	A (40)
	Area in Need	m2	Qd/A (1,115.2)
	Diameter	m	D 19.0
	Depth	m	H 3.5
	Nos.		N 4
	Area	m2	A=3.14*D*D/4*N 1,133.5
	Volume	m3	V=A*H 3,967.4
	Surface Load	m3/m2/day	Qd/A 39.4
	Retention Time	hours	V*24/Qh 1.6

Note: Figures in parentheses are guidelines for calculation of capacities.

Table XX-9 Process Design of STP for Bilbeis (2 of 3)

Facility	Items	Unit	
Aeration Tank	BOD-SS Load(0.2-0.4)	kg/kg/day	B0 (0.4)
	Aeration Time(6-12)	hours	T (10.0)
	Return Sludge Ratio	%	a 25.0
	MLSS	mg/l	$ML = (152 * 1.0 + 8,000 * 0.25) / 1.25$ 1,722.0
	BOD Removed	kg/day	$BR = (315 - 30) * 10 (-3) * Qd$ 12,712.7
	Volume in Need	m <sup>3</sup>	$V = Qd * T / 24$ (18,585.8)
	Width	m	W 12.0
	Length	m	L 12.0
	Depth	m	H 5.0
	Nos.	N	N 28
	Tank Volume	m <sup>3</sup>	$V = W * L * H * N$ 20,160.0
	SS in Tank	kg	$SS = V * 1722 * 10 (-3)$ 34,715.5
	BOD-SS Load	kg/kg/day	BR/SS .37
	Sludge Age	days	$V * 1722 / Qd / 152$ 5.1
	Aeration Time	hours	V*24/Qd 10.8
Final Sedimentation Tank	Surface Load(20-30)	m <sup>3</sup> /m <sup>2</sup> /day	A (30.0)
	Area in Need	m <sup>2</sup>	$Qd / A$ (1,486.9)
	Diameter	m	D 22.0
	Depth	m	H 3.5
	Nos.	N	N 4
	Area	m <sup>2</sup>	$A = 3.14 * D^2 * N / 4$ 1,519.8
	Volume	m <sup>3</sup>	$V = A * H$ 5,319.2
	Surface Load	m <sup>3</sup> /m <sup>2</sup> /day	$Qh / A$ 29.4
	Retention Time	hours	$V * 24 / Qh$ 2.9
Chlorine Contact Tank	Contact Time(15)	min	(15.0)
	Width	m	W 3.0
	Length	m	L 20.0
	Depth	m	H 2.0
	Channel	N	N 4
	Tank Volume	m <sup>3</sup>	$V = W * L * H * N$ 480.0
	Contact Time	min	$T = V * 1440 / Qd$ 15.5

Note: Figures in parentheses are guidelines for calculation of capacities.

Table XX-9 Process Design of STP for Bilbeis (3 of 3)

Facility	Items	Unit			
Sludge	Dry Solid	kg/day	$DS=(460-30)*10^{(-3)}*Qd$	19,180.6	
	Sludge Volume	m <sup>3</sup>	$Q=DS/0.01*0.001$	1,918.1	
Sludge Thickner	Solid Load(60)	m <sup>2</sup> /kg/day	SL	(60.0)	
	Area in Need	m <sup>2</sup>	DS/SL	(319.7)	
	Diameter	m	D	10.0	
	Depth	m	H	4.0	
	Nos.		N	4	
	Area	m <sup>2</sup>	$A=3.14*D*D/4*N$	314.0	
	Volume	m <sup>3</sup>	$V=A*H$	1,256.0	
	Sludge Load	m <sup>2</sup> /kg/day	DS/A	61.1	
	Retention Time	hours	$v*24/Q$	3.9	
Drying Bed	Sludge Volume	m <sup>3</sup>	$Q=DS/0.05*0.001$	383.6	
	Retention Time	day	RT	(5.0)	
	Thickness	m	TH	(.5)	
	Volume in Need	m <sup>3</sup>	$V=Q*RT$	(1,918.1)	
	Area in Need	m <sup>2</sup>	$A=V/TH$	(3,836.1)	
	Width	m	W	10.0	
	Length	m	L	10.0	
	Depth	m	H	.5	
	Nos.		N	40	
	Tank Volume	m <sup>3</sup>	$V=W*L*H*N$	2,000.0	
	Retention Time	day	V/Q	5.2	

Note: Figures in parentheses are guidelines for calculation of capacities.

Table XX-10 Bilbeis City Hydraulic Calculation Sheet of STP for Bilbeis (1 of 5)

Facility	Items	Unit	Daily Max	Hourly Max
Initial Condition	Ground level of STP	m	9.3	9.3
	Water Level of Drain	m	7.3	7.3
Wastewater	$Q_d$	m <sup>3</sup> /day	44,806	60,864
	$Q_s = Q_d / 86,400$	m <sup>3</sup> /sec	0.516	0.704
Chlorine Contact Tank	Wastewater	m <sup>3</sup> /sec	0.516	0.704
	Pipe	m		
	Diameter	m	0.8	0.8
	Length	m	20	20
	Cross Area	m <sup>2</sup>	$A = 3.14 \cdot D(2) / 4$	0.502
		m	0.200	0.200
	$R = D / 4$	m		
	Velocity	m/sec	$V = Q_s / A$	1.402
		m	0.001301	0.00242
	Loss of Pipe	m	$H_1 = L \cdot K_1$	0.048
	Loss of in & out	m	$H_2 = 1.5 \cdot V(2) / 19.6$	0.15
	Total Loss	m	$H = H_1 + H_2$	0.198
	out well	m	$WL_1 = WL + H$	7.488
Barrage	Width	m	3.0	3.0
	Height	m	7.4	7.4
	Height of Overflow	m	$H_3 = (Q_s / 1.84 \cdot B)(2/3)$	0.206
	Water Level	m	$WL_2 = GH + H_3$	7.653



Table XX-10 Bilbeis City Hydraulic Calculation Sheet of STP for Bilbeis (2 of 5)

Facility	Items	Unit	Items	Daily Max	Hourly Max
Final Sedimentation Tank	Wastewater	m3/sec	Qs	0.516	0.704
	Pipe	m	D	0.8	0.8
		m	L	10.0	10.0
	No.1	m2	A=3.14*D(2)/4	0.502	0.502
		m	R=D/4	0.200	0.200
	Velocity	m/sec	V=Qs/A	1.028	1.402
			I=V(2)*0.012(2)/R(4/3)	0.001301	0.00242
	Loss of Pipe	m	H1=L*I	0.013	0.024
	Loss of out	m	H2=1.0*V(2)/19.6	0.054	0.100
	Wastewater	m3/sec	Q=Qs/2	0.258	0.352
	Pipe	m	D	0.6	0.6
		m	L	90	90
	No.2	m2	A=3.14*D(2)/4	0.283	0.283
		m	R=D/4	0.150	0.150
	Velocity	m/sec	V=Q/A	0.912	1.244
			I=V(2)*0.012(2)/R(4/3)	0.001502	0.002795
	Loss of Pipe	m	H3=L*I	0.135	0.252
	Wastewater	m3/sec	Q=Qs/4	0.129	0.176
	Pipe	m	D	0.4	0.4
		m	L	45	45
	No.3	m2	A=3.14*D(2)/4	0.126	0.126
		m	R=D/4	0.100	0.100
	Velocity	m/sec	V=Q/A	1.024	1.397
			I=V(2)*0.012(2)/R(4/3)	0.003252	0.006053
	Loss of Pipe	m	H4=L*I	0.146	0.272
Loss of in	m	H5=0.5*V(2)/19.6	0.027	0.050	
Total Loss	m	H=H1+H2+H3+H4+H5	0.375	0.698	
out of FST	m	WLF1=WLC2+H	7.981	8.351	
Notch	m	Dia	21.0	21.0	
	per	N=3.14*Dia/0.15	440	440	
		NH	8.600	8.600	
Height of Overflow	m	H3=(Q/1.55/N)(2/5)	0.032	0.037	
Water Level	m	WLF2=NH+H3	8.632	8.637	

Table XX-10 Hydraulic Calculation Sheet of STP for Bilbeis (3 of 5)

Facility	Items	Unit	Equation	Daily Max	Hourly Max	
Aeration Tank	Wastewater	m <sup>3</sup> /sec	$Q=Qs/4$	0.129	0.176	
	Pipe	m	D	0.4	0.4	
	Length	m	L	25.0	25.0	
	No.1	Cross Area	m <sup>2</sup>	$A=3.14*D(2)/4$	0.126	0.126
		Velocity	m/sec	$V=Qs/A$	1.024	1.397
	Loss of Pipe	m	$H1=L*1$	0.081	0.151	
	Loss of in & out	m	$H2=1.5*V(2)/19.6$	0.080	0.149	
	Total Loss	m	$H=H1+H2$	0.161	0.300	
	out of Distribution Tank	m	$WL1=WL2+H$	8.793	8.937	
	Distribu. Well	m	B	1.0	1.0	
	Height	m	GH	8.900	8.900	
	Height of Overflow	m	$H3=(Q/1.84/B)(2/3)$	0.170	0.209	
	Water Level of Dist. Well	m	$WL2=GH+H3$	9.070	9.109	
	Wastewater	m <sup>3</sup> /sec	$Q=Qs$	0.516	0.704	
	Pipe	m	D	0.8	0.8	
No.1	Length	m	L	25.0	25.0	
	Cross Area	m <sup>2</sup>	$A=3.14*D(2)/4$	0.502	0.502	
Velocity	m/sec	$V=Qs/A$	1.028	1.402		
Loss of Pipe	m	$H1=L*1$	0.001301	0.00242		
Loss of in & out	m	$H5=1.5*V(2)/19.6$	0.033	0.061		
Total Loss	m	$H=H4+H5$	0.114	0.211		
out of Aeration Tank	m	$WL3=WL2+H$	9.184	9.320		
Wastewater	m <sup>3</sup> /sec	$Q=Qs/4$	0.129	0.176		
Barrage	Width	m	B	12.0	12.0	
	Height	m	GH	9.400	9.400	
Height of Overflow	m	$H6=(Qs/1.84/B)(2/3)$	0.032	0.04		
Water Level of AT	m	$WL4=GH+H6$	9.432	9.440		

Table XX-10 Hydraulic Calculation Sheet of STP for Bilbeis (4 of 5)

Facility	Items	Unit	Daily Max	Hourly Max
Primary Sedimentation Tank	Wastewater Barrage	$Q=Qs/8$	0.065	0.083
	Width	m	0.4	0.4
	Height	m	5.5	5.5
	Water Depth	m	3.932	3.940
	Cross Area	m <sup>2</sup>	1.578	1.578
	Velocity	m/sec	0.041	0.056
	Loss of in & out	m	0.003	0.005
	Water Level of AI inflow	m	9.435	9.445
	Wastewater Pipe No.1	$Q=Qs$	0.516	0.704
	Diameter	m	0.8	0.8
Length	m	10	10	
Cross Area	m <sup>2</sup>	0.502	0.502	
Velocity	m/sec	0.200	0.200	
Loss of Pipe	m	0.001299	0.002418	
Loss of out	m	0.013	0.024	
Wastewater Pipe No.2	$Q=Qs/2$	0.258	0.352	
Diameter	m	0.6	0.6	
Length	m	50	50	
Cross Area	m <sup>2</sup>	0.283	0.283	
Velocity	m/sec	0.150	0.150	
Loss of Pipe	m	0.001502	0.002795	
Wastewater Pipe No.3	$Q=Qs/4$	0.129	0.176	
Diameter	m	0.4	0.4	
Length	m	35	35	
Cross Area	m <sup>2</sup>	0.128	0.128	
Velocity	m/sec	0.100	0.100	
Loss of Pipe	m	0.003252	0.006053	
Loss of in	m	0.114	0.212	
Total Loss out of PSI	m	0.053	0.100	
Notch	Di. of Notch	m	18.000	18.000
	Num. of Notch	per	377	377
Height of Overflow	Height	m	10.100	10.100
Water Level of PSI	H3=(Q/1.55(N)) <sup>2/5</sup>	m	0.045	0.052
	$Wp3=NH+H3$	m	10.145	10.152

Table XX-10 Bilbeis City Hydraulic Calculation Sheet of STP for Bilbeis (5 of 5)

Facility	Items	Unit	Daily Max	Hourly Max	
Grit Chamber	Wastewater	m <sup>3</sup> /sec	Q=Qs/2	0.258	
	Pipe No.1	m	D	0.8	
		m	L	30	
	Cross Area	m <sup>2</sup>	A=3.14*(D/2) <sup>2</sup> /4	0.502	
		m	R=D/4	0.200	
	Velocity	m/sec	V=Q/A	0.514	
			I=V(2)*0.012(2)/R(4/3)	0.000325	
	Loss of Pipe	m	H1=L*I	0.010	
	Loss of in & out	m	H2=1.5*V(2)/19.6	0.018	
	Total Loss	m	H=H1+H2	0.031	
	out of Distribution Well	m	WLg1=WLp3+H	10.161	
	Distribu. Well	m	B	1	
	Height	m	GH	10.200	
	Height of Overflow	m	H3=(Q/1.84/B) <sup>2</sup> /3	0.27	
	Water Level of Dist. Well	m	WLg2=GH+H3	10.470	
	10.532				
	Wastewater	m <sup>3</sup> /sec	Q=Qs	0.516	
	0.704				
	Grit Chamber	Pipe No.1	m	D	0.8
			m	L	30
Cross Area		m <sup>2</sup>	A=3.14*(D/2) <sup>2</sup> /4	0.502	
		m	R=D/4	0.200	
Velocity		m/sec	V=Q/A	1.027	
			I=V(2)*0.012(2)/R(4/3)	0.002418	
Loss of Pipe		m	H1=L*I	0.039	
Loss of in & out		m	H5=1.5*V(2)/19.6	0.027	
Total Loss		m	H=H4+H5	0.066	
0.123					
Water Level of out of GI	m	WLg3=WLg2+H	10.536		
10.655					
Loss of Screen	m	H6	0.1		
0.1					
Water Level of GI Inflow	m	WLg4=WLg3+H6	10.636		
10.755					

Minyet El Qamh



FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM  
 Table XX-11 Sewerage Computation Sheet For Minyet El Qamh (1 of 2)

NO of Sewer	Sewerage Area		Sewer Length		Unit Sewage Flow Per ha		Designed Sewer		Sewer Invert Elevation		Ground Elevation		Earth Cover		NO of MH	Remark		
	Increment	Cumulated	Increment	Cumulated	Flow	Design	Diameter	Slope	Velocity	Capacity	Begin	End	Begin	End			Begin	End
	ha	ha	m	m	m <sup>3</sup> /s	m <sup>3</sup> /s	mm	%	m/s	m <sup>3</sup> /s	m	m	m	m			m	m
<b>ZONE-1</b>																		
1	9.7	9.7	280	280	0.031	0.031	Ø250	2.3	0.63	0.031	9.738	8.974	11.00	12.00	1.00	2.76	6	
2	11.9	21.6	360	640	0.070	0.070	Ø350	2.0	0.73	0.071	8.874	8.014	12.00	13.00	2.76	4.62	7	
3	13.4	13.4	330	330	0.043	0.043	Ø300	2.0	0.66	0.047	10.685	9.885	12.00	13.00	1.00	2.80	7	
4	18.7	53.7	360	1,000	0.174	0.174	Ø500	1.8	0.88	0.174	7.864	7.076	13.00	11.13	4.59	3.51	7	
5	15.2	68.9	320	1,320	0.224	0.224	Ø600	1.2	0.81	0.230	6.976	6.472	11.13	10.95	3.50	3.83	6	
6	10.3	10.3	240	240	0.033	0.033	Ø250	2.6	0.67	0.033	9.628	8.904	10.89	10.87	1.00	1.70	5	
7	10.9	21.2	240	480	0.069	0.069	Ø350	1.9	0.72	0.069	8.804	8.248	10.87	10.95	1.70	2.33	5	
8	-	90.1	50	1,370	0.292	0.292	Ø750	0.8	0.77	0.341	6.322	6.262	10.95	10.50	3.82	3.43	1	
<b>ZONE-2</b>																		
9	-	90.1	1,150	2,520	0.090	0.090	Ø300	7.3	1.27	0.090	9.185	9.265	10.50	10.58	1.00	1.00	23	Force Main
10	30.3	30.3	230	230	0.030	0.030	Ø200	7.0	0.95	0.030	9.470	9.370	10.68	10.58	1.00	1.00	5	From No.2 P/S Force Main
11	-	120.4	190	2,710	0.121	0.121	Ø350	5.9	1.26	0.121	9.213	9.733	10.58	11.10	1.00	1.00	4	Force Main
<b>ZONE-3</b>																		
12	20.7	20.7	350	350	0.067	0.067	Ø350	1.8	0.70	0.067	10.033	9.263	11.40	11.40	1.00	1.77	7	
13	14.5	35.2	350	700	0.114	0.114	Ø450	1.4	0.73	0.116	9.163	8.533	11.40	11.47	1.75	2.45	7	
14	5.4	40.6	80	780	0.132	0.132	Ø500	1.3	0.75	0.147	8.483	8.339	11.47	11.40	2.45	2.52	2	
<b>Flow to No.3 Pumping Station</b>																		

FEASIBILITY STUDY ON SHARQIYA SEWERAGE SYSTEM  
 Sewerage Computation Sheet For Minyot El Qamh (2 of 2)

NO of Sewer	Sewerage Area		Sewer Length		Unit Sewerage Flow Per ha			Sewer Invert Elevation		Ground Elevation		Earth Cover		NO of MH	Remark		
	Increment	Cumulated	Increment	Cumulated	Design Flow	Sewer Diameter	Slope	Velocity	Capacity	Begin	End	Begin	End			Begin	End
ha	ha	ha	m	m	m <sup>3</sup> /s	mm	%	m/s	m <sup>3</sup> /s	m	m	m	m	m	m		
15	19.9	19.9	270	270	0.065	Ø350	1.8	0.70	0.067	10.033	9.447	11.40	11.40	1.00	1.59	5	
16	6.9	26.8	300	570	0.087	Ø400	1.6	0.72	0.090	9.397	8.797	11.40	11.40	1.58	2.18	6	
	Flow to NO.3 Pumping Station (A3=67.4 ha)																
17	-	67.4	280	1,060	0.088	Ø250	11.0	1.38	0.068	10.138	9.838	11.40	11.10	1.00	1.00	6	Force Main
18	-	187.8	860	3,570	0.189	Ø400	7.0	1.50	0.189	9.681	8.401	11.10	9.82	1.00	1.00	17	Force Main
	Flow to STP																
	ZONE-4																
19	24.0	24.0	290	290	0.078	Ø400	1.6	0.72	0.090	10.021	9.437	11.44	11.00	1.00	1.14	6	
20	11.8	35.8	350	640	0.118	Ø450	1.4	0.73	0.116	9.387	8.757	11.00	10.50	1.13	1.26	7	
21	12.1	47.9	240	880	0.155	Ø600	1.0	0.74	0.210	8.607	8.267	10.50	10.00	1.24	1.08	5	
22	13.9	61.8	300	1,180	0.200	Ø600	1.0	0.74	0.210	8.267	7.847	10.00	9.77	1.08	1.27	6	
	Flow to STP																
23	13.2	13.2	280	280	0.043	Ø300	2.2	0.70	0.049	9.235	8.499	10.55	10.25	1.00	1.44	8	
24	12.3	25.5	390	670	0.083	Ø400	1.6	0.72	0.090	8.399	7.615	10.25	9.77	1.43	1.74	8	
25	-	87.3	80	1,260	0.283	Ø750	0.8	0.77	0.341	7.265	7.161	9.77	9.82	1.68	1.85	2	
	Flow to STP (A4=87.3 ha, A5=24.9 ha)																
	Total Area 300.0 ha																
	Design Flow Rate of STP Pumping Station 0.113 m <sup>3</sup> /sec																
	Design Flow Rate of NO.1 Pumping Station 0.090 m <sup>3</sup> /sec																
	Design Flow Rate of NO.2 Pumping Station 0.030 m <sup>3</sup> /sec																
	Design Flow Rate of NO.3 Pumping Station 0.068 m <sup>3</sup> /sec																



Table XX-12 Calculation Sheet of Pumping Station for Minyet El Qamh

City Name	Items	Unit	Pump No															
			1	2	3	4	5	6	7	8	9							
MINYET EL QAMH	Wastewater	m <sup>3</sup> /sec	0.030	0.030	0.068	0.113												
		m <sup>3</sup> /min	5.4	1.8	4.1	6.8												
	Inlet Pipe Diameter	m	0.75	0.25	0.50	0.75												
	Elevation	m	6.26	7.68	8.34	6.16												
	Ground Elevation	m	10.3	10.3	10.3	10.3												
	Pump Nos.	N	2	1	2	2												
	Q/Unit	Qp=Qm/N	2.7	1.8	2.0	3.4												
	Dia. in need	D=146*(Qp/2.0) <sup>(1/2)</sup>	169.6	138.5	147.5	190.1												
	Diameter	Dp	150	150	150	200												
	Pump Loss	Force Main Length	m	2,200	1,280	1,140	-											
	Loss in Pipe	m	22.0	12.8	11.4	-												
	Water Head		4.0	2.6	2.0	4.1												
	+a	m	4.0	4.0	4.0	4.0												
	Total Loss	m	30.0	19.4	17.4	8.1												
Pump Capacity		KW	Ps=0.163*H*Qp/0.6	22.0	9.5	9.6	7.5											
Motor Capacity		KW	P=Ps*(1+0.1)	24.2	10.4	10.6	8.2											
Pump Spec	Diameter	mm	150	150	150	200												
	Quantity	m <sup>3</sup> /min	2.7	1.8	2.0	3.4												
	Loss	m	30.0	19.4	17.4	8.1												
	Motor Capacity	KW	30	11	11	11												
	Nos.		3	2	3	3												
	1 Standby																	

Table XX-13 Process Design of STP for Minyet El Qamh (1 of 3)

Facility	Items	Unit		
Condition	Daily Max	m <sup>3</sup> /day	Qd 19,118	
	Hourly Max	m <sup>3</sup> /day	Qh 26,026	
Grit Chamber	Surface Load(1,800)	m <sup>3</sup> /m <sup>2</sup> /day	A (1,800)	
	Area in Need	m <sup>2</sup>	Qh/A (14.5)	
	Shape	Width	m	W 1.0
		Length	m	L 7.5
		Depth	m	H 1.0
	Area	Nos.	N	N 2
			m <sup>2</sup>	A=W*L*N 15.0
		Volume	m <sup>3</sup>	V=W*L*H*N 15.0
	Surface Load	m <sup>3</sup> /m <sup>2</sup> /day	Qh/A 1,735.1	
	Retention Time	sec	V*86400/Qh 48.8	
Primary Sedimentation Tank	Surface Load(25-50)	m <sup>3</sup> /m <sup>2</sup> /day	A (40)	
	Area in Need	m <sup>2</sup>	Qd/A (478.0)	
	Shape	Diameter	m	D 18.0
		Depth	m	H 3.5
		Nos.	N	N 2
	Area		m <sup>2</sup>	A=3.14*D*D/4*N 508.7
		Volume	m <sup>3</sup>	V=A*H 1,780.4
		Surface Load	m <sup>3</sup> /m <sup>2</sup> /day	Qd/A 37.6
	Retention Time	hours	V*24/Qh 1.8	

Note: Figures in parentheses are guidelines for calculation of capacities.

Table XX-13 Process Design of STP for Minyot El Qamh (2 of 3)

Facility	Items	Unit	
Aeration Tank	BOD-SS Load(0.2-0.4)	kg/kg/day	B0
	Aeration Time(6-12)	hours	T
	Return Sludge Ratio	%	a
	MLSS	mg/l	ML=(152*1.0+8.000*0.25)/1.25
	BOD Removed	kg/day	BR=(315-30)*10(-3)*Qd
	Volume in Need	m3	V=Qd*T/24
	Width	m	W
	Length	m	L
	Depth	m	H
	Nos.		N
	Tank Volume	m3	V=W*L*H*N
	SS in Tank	kg	SS=W*1722*10(-3)
	BOD-SS Load	kg/kg/day	BR/SS
	Sludge Age	days	V*1722/Qd/152
Aeration Time	hours	V*24/Qd	
Final Sedimentation Tank	Surface Load(20-30)	m3/m2/day	A
	Area in Need	m2	Qd/A
	Diameter	m	D
	Depth	m	H
	Nos.		N
	Area	m2	A=3.14*D*D/4*N
	Volume	m3	V=A*H
	Surface Load	m3/m2/day	Qh/A
	Retention Time	hours	V*24/Qh
Chlorine Contact Tank	Contact Time(15)	min	
	Width	m	W
	Length	m	L
	Depth	m	H
	Channel		N
	Tank Volume	m3	V=W*L*H*N
	Contact Time	min	T=V*1440/Qd

Note: Figures in parentheses are guidelines for calculation of capacities.

Table XX-13 Process Design of STP for Minyet El Qamh (3 of 3)

Facility	Items	Unit	
Sludge Thickner	Dry Solid	kg/day	$DS=(460-30)*10(-3)*QD$ 8,220.7
	Sludge Volume	m <sup>3</sup>	$Q=DS/0.01*0.001$ 822.1
	Solid Load(60)	m <sup>2</sup> /kg/day	SL (60.0)
	Area in Need	m <sup>2</sup>	$DS/SL$ (137.0)
	Diameter	m	D 10.0
	Depth	m	H 4.0
	Nos.	N	N 2
	Area	m <sup>2</sup>	$A=3.14*D*D/4*N$ 157.0
	Volume	m <sup>3</sup>	$V=A*H$ 628.0
	Sludge Load	m <sup>2</sup> /kg/day	$DS/A$ 52.4
Retention Time	hours	$V*24/Q$ 4.6	
Drying Bed	Sludge Volume	m <sup>3</sup>	$Q=DS/0.05*0.001$ 164.4
	Retention Time	day	RI (5.0)
	Thickness	m	TH (.5)
	Volume in Need	m <sup>3</sup>	$V=Q*RI$ (822.1)
	Area in Need	m <sup>2</sup>	$A=V/TH$ (1,644.1)
	Width	m	W 10.0
	Length	m	L 10.0
	Depth	m	H .5
	Nos.	N	N 20
	Tank Volume	m <sup>3</sup>	$V=W*L*H*N$ 1,000.0
Retention Time	day	V/Q 6.1	

Note: Figures in parentheses are guidelines for calculation of capacities.



Table XX-14 Hydraulic Calculation Sheet of STP for Minyot El Qamh (2 of 5)

Facility	Items	Unit	Daily Max	Hourly Max	
Final Sedimentation Tank	Wastewater	m <sup>3</sup> /sec	0.221	0.301	
	Pipe No.1	Diameter	D	0.5	0.5
		Length	L	25.0	25.0
	Cross Area	$A=3.14*D(2)/4$	m <sup>2</sup>	0.196	0.196
		$R=D/4$	m	0.125	0.125
	Velocity	$V=Qs/A$	m/sec	1.128	1.536
		$I=V(2)*0.012(2)/R(4/3)$	m	0.002632	0.005436
	Loss of Pipe	$H1=L*I$	m	0.073	0.136
	Loss of out	$H2=1.0*V(2)/19.6$	m	0.065	0.120
	Wastewater	$Q=Qs/2$	m <sup>3</sup> /sec	0.111	0.151
	Pipe No.2	Diameter	D	0.4	0.4
		Length	L	86	86
	Cross Area	$A=3.14*D(2)/4$	m <sup>2</sup>	0.126	0.126
		$R=D/4$	m	0.100	0.100
	Velocity	$V=Q/A$	m/sec	0.877	1.194
		$I=V(2)*0.012(2)/R(4/3)$	m	0.002386	0.004428
	Loss of Pipe	$H3=L*I$	m	0.205	0.381
	Loss of in	$H4=0.5*V(2)/19.6$	m	0.020	0.036
Total Loss	$H=H1+H2+H3+H4$	m	0.363	0.673	
out of FST	$WLF1=W/Lc2*H$	m	9.980	10.317	
Notch	Dia. of Notch	m	21.0	21.0	
	Num. of Notch	per	440	440	
Height of Overflow Water Level	$NH$	m	10.400	10.400	
	$H3=(Q/1.55/N)(2/5)$ $WLF2=NH+H3$	m	0.030	0.034	
			10.430	10.434	

Table XX-14 Hydraulic Calculation Sheet of STP for Minyret El Qamh (3 of 5)  
 Minyret El Qamh City

Facility	Items	Unit	Items	Daily Max	Hourly Max	
Aeration Tank	Wastewater	m <sup>3</sup> /sec	$Q=Qs/2$	0.111	0.151	
	Pipe	Diameter	m	D	0.4	0.4
		Length	m	L	25.0	25.0
	No.1	Cross Area	m <sup>2</sup>	$A=3.14*D(2)/4$	0.126	0.126
			m	$R=D/4$	0.100	0.100
	Velocity	m/sec	$V=Qs/A$	0.877	1.194	
	Loss of Pipe	m	$I=V(2)*0.012(2)/R(4/3)$	0.002386	0.004423	
	Loss of in & out		m	$H1=L*1$	0.060	0.111
			m	$H2=1.5*V(2)/19.6$	0.059	0.109
	Total Loss	m	$H=H1+H2$	0.119	0.220	
	out of Distribution Tank	m	$WLa1=WLa2+H$	10.549	10.654	
	Distribu. Well	Width	m	B	1.0	1.0
		Height	m	GH	10.7	10.7
	Height of Overflow	m	$H3=(Q/1.84/B)(2/3)$	0.153	0.188	
	Water Level of Dist.Well	m	$WLa2=GH+H3$	10.853	10.888	
Wastewater	m <sup>3</sup> /sec	$Q=Qs$	0.221	0.301		
Pipe	Diameter	m	D	0.5	0.5	
	Length	m	L	25.0	25.0	
No.1	Cross Area	m <sup>2</sup>	$A=3.14*D(2)/4$	0.196	0.196	
		m	$R=D/4$	0.125	0.125	
Velocity	m/sec	$V=Qs/A$	1.128	1.536		
Loss of Pipe	m	$I=V(2)*0.012(2)/R(4/3)$	0.002332	0.005436		
Loss of in & out		m	$H4=L*1$	0.073	0.136	
		m	$H5=1.5*V(2)/19.6$	0.097	0.181	
Total Loss	m	$H=H4+H5$	0.170	0.317		
out of Aeration Tank	m	$WLa3=WLa2+H$	11.023	11.205		
Wastewater	m <sup>3</sup> /sec	$Q=Qs/4$	0.055	0.075		
Barrage	Width	m	B	10.0	10.0	
	Height	m	GH	11.300	11.300	
Height of Overflow*	m	$H6=(Qs/1.84/B)(2/3)$	0.021	0.026		
Water Level of AT	m	$WLa4=GH+H6$	11.321	11.326		

Table XX-14 Hydraulic Calculation Sheet of SIP for Minyret El Qamh (4 of 5)  
 Facility: Minyret El Qamh City

Items	Unit	Daily Max	Hourly Max
Wastewater	m <sup>3</sup> /sec	Q=Qs/8	0.028
Barrage	m	B	0.4
Height	m	GH	9.2
Water Depth	m	h=WL4-GH	2.121
Cross Area	m <sup>2</sup>	A=0.5*h	0.848
Verocity	m/sec	V=Q/A	0.033
Loss of in & out	m	H1=1.5*V(2)	0.002
Water Level of AI inflow	m	WLP1=WL4+H1	11.323
Wastewater	m <sup>3</sup> /sec	Q=Qs	0.301
Pipe No.1	m	D	0.5
Length	m	L	10
Cross Area	m <sup>2</sup>	A=3.14*D(2)/4	0.196
Velocity	m/sec	R=D/4	0.125
Loss of Pipe	m	V=Q/A	1.126
Loss of out	m	I=V(2)*0.012(2)/R(4/3)	0.002922
	m	H1=L*I	0.029
	m	H2=1.0*V(2)/19.6	0.065
Wastewater	m <sup>3</sup> /sec	Q=Qs/2	0.151
Pipe No.2	m	D	0.4
Length	m	L	86
Cross Area	m <sup>2</sup>	A=3.14*D(2)/4	0.126
Velocity	m/sec	R=D/4	0.100
Loss of Pipe	m	V=Q/A	0.877
Loss of in	m	I=V(2)*0.012(2)/R(4/3)	0.002386
Total Loss out of PST	m	H3=L*I	0.205
	m	H4=0.5*V(2)/19.6	0.020
	m	H=H1+H2+H3+H4	0.319
	m	WLP2=WL1+H	11.642
Notch	m	Dia.	17.0
Num. of Notch	per	N=3.14*Dia/0.15	356
Height of Overflow	m	NH	12.200
Water Level of PST	m	H3=(Q/1.55/N)(2/5)	0.038
	m	WLP3=NH+H3	12.238



Table XX-14 Hydraulic Calculation Sheet of STP for Minyet El Qamh (5 of 5)  
 Minyet El Qamh City

Facility	Items	Unit	Daily Max	Hourly Max	
Grit Chamber	Wastewater	m <sup>3</sup> /sec	Q=Qs/2	0.111	
	Pipe No.1	m	D	0.4	
		m	L	30	
		m <sup>2</sup>	A=3.14*D(2)/4	0.126	
		m	R=D/4	0.100	
	Velocity	m/sec	V=Q/A	0.880	
			I=V(2)*0.012(2)/R(4/3)	0.002401	
	Loss of Pipe	m	H1=L*I	0.072	
	Loss of in & out	m	H2=1.5*V(2)/19.6	0.020	
	Total Loss	m	H=H1+H2	0.092	
	out of Distribution Well	m	WLg1=WLp3+H	12.325	
	Distribu. Well	m	B	1	
	Height	m	GH	12.400	
	Height of Overflow	m	H3=(Q/1.84/B)(2/3)	0.153	
	Water Level of Dist. Well	m	WLg2=GH+H3	12.553	
	Wastewater	m <sup>3</sup> /sec	Q=Qs	0.221	
	Hourly Max			0.301	
	Pipe No.1	Diameter	m	D	0.5
		Length	m	L	30
		Cross Area	m <sup>2</sup>	A=3.14*D(2)/4	0.196
		m	R=D/4	0.125	
Velocity		m/sec	V=Q/A	1.126	
			I=V(2)*0.012(2)/R(4/3)	0.002922	
Loss of Pipe		m	H4=L*I	0.088	
Loss of in & out		m	H5=1.5*V(2)/19.6	0.032	
Total Loss		m	H=H4+H5	0.120	
Water Level of out of GT		m	WLg3=WLg2+H	12.673	
Loss of Screen		m	H6	0.1	
Water Level of GT Inflow		m	WLg4=WLg3+H6	12.773	
			12.911		



APPENDIX - XXI

STUDY ORGANIZATION AND MINUTES OF THE OFFICIAL MEETINGS

APPENDIX - XXI

STUDY ORGANIZATION AND MINUTES OF THE OFFICIAL MEETINGS

Table of Contents

	<u>Page</u>
1. <u>Government of Egypt</u> .....	XXI-1
2. <u>Advisory Committee</u> .....	XXI-1
3. <u>JICA Study Team</u> .....	XXI-2
4. <u>Minutes of the Official Meetings</u> .....	XXI-3

List of Figures

Figure XIII-1 Organization Chart .....	XXI-2
--	-------