



4. SCHEDULE



RUN	/7 TII COAL GASIFICATION TEST RUN	RUN No.	CG017
-----	-----------------------------------	---------	-------

DATE	1987.11.5 (Thu.)
------	------------------

1. PURPOSE of RUN

- INVESTIGATIONS of GASIFICATION-CHARACTERISTIC for CBAZ, SJEZ and CBAI coal.

2. COAL SAMPLE and OPERATION CONDITION
COAL SAMPLE - A

Sample number		CBAZ	
Proximate analysis		Ultimate analysis	Ash components
Ash	10.94 %	71.56 %	SiO2
V.M.	45.01 %	5.73 %	Al2O3
F.C.	44.05 %	1.16 %	CaO
		21.20 %	K2O
		0.35 %	Na2O
			%
			%
			%
			%
			%
			%

(DRY BASE) (D.A.F.)

OPERATION CONDITION - A

Weight of molten iron	300	Kg
Flow rate of Oxygen	13.3	Nm ³ /hr
Flow rate of carrier gas	10.0	Nm ³ /hr
Flow rate of pulverized coal	35.0	Kg/hr
Position of main-lance over bath surface	200	mm
Molten iron temperature on discharge to gasifier on coal gasification	1550	°C
on discharge to pot car	1500	°C
Basicity of slag	1.5	
Weight of coal	-	wet Kg
Weight of burnt lime	0	Kg

COAL SAMPLE - B

Sample number		SJEZ	
Proximate analysis		Ultimate analysis	Ash components
Ash	2.68 %	70.41 %	SiO2
V.M.	50.15 %	5.48 %	Al2O3
F.C.	47.17 %	1.10 %	CaO
		22.84 %	K2O
		0.17 %	Na2O
			%
			%
			%
			%
			%
			%

(DRY BASE) (D.A.F.)

OPERATION CONDITION - B

Weight of molten iron	300	Kg
Flow rate of Oxygen	14.0	Nm ³ /hr
Flow rate of carrier gas	10.0	Nm ³ /hr
Flow rate of pulverized coal	35.0	Kg/hr
Position of main-lance over bath surface	200	mm
Molten iron temperature on discharge to gasifier on coal gasification	--	°C
on discharge to pot car	1500	°C
Basicity of slag	1.5	
Weight of coal	22	wet Kg
Weight of burnt lime	0	Kg

RUN	RUN No.	CG017
-----	---------	-------

COAL SAMPLE - C



Sample number		CEA1	
Proximate analysis		Ultimate analysis	
Ash	17.03 %	C	69.60 %
V.M.	42.73 %	H	5.76 %
F.C.	40.24 %	N	1.12 %
		O	21.81 %
		S	1.71 %
		Ash components	
		SiO ₂	%
		Al ₂ O ₃	%
		CaO	%
		K ₂ O	%
		Na ₂ O	%

(DRY BASE) (D.A.F)

OPERATION CONDITION - C

Weight of molten iron	300	Kg
Flow rate of Oxygen	11.8	Nm ³ /hr
Flow rate of carrier gas	10.0	Nm ³ /hr
Flow rate of pulverized coal	35.0	Kg/hr
Position of main lance over bath surface	200	mm
Molten iron temperature on discharge to gasifier on coal gasification	1550	°C
on discharge to pot car	1500	°C
Basicity of slag	1.5	
Weight of coal	21	wet Kg
Weight of burnt lime	0	Kg

4. SCHEDULE



RUN	18 TH COAL GASIFICATION TEST RUN	RUN No.	CG018
-----	----------------------------------	---------	-------

DATE	1987.11.12 . (Thu.)
------	---------------------

1. PURPOSE of RUN
 1) INVESTIGATIONS of GASIFICATION-CHARACTERISTIC for
 BJS and BUICI coal.

2. COAL SAMPLE and OPERATION CONDITION
 COAL SAMPLE - A

Sample number	BJS		Ash components	
Proximate analysis	Ultimate analysis			
Ash	4.24 %	C	68.52 %	SI02
V.M.	49.97 %	H	5.68 %	Al2O3
F.C.	45.79 %	N	1.15 %	CaO
		O	24.13 %	K2O
		S	0.52 %	Na2O

(DRY BASE) (D.A.F.)

OPERATION CONDITION - A

Weight of molten iron	300	Kg
Flow rate of Oxygen	73.3	Nm ³ /hr
Flow rate of carrier gas	10.0	Nm ³ /hr
Flow rate of pulverized coal	35.0	Kg/hr
Position of main-lance over bath surface	200	mm
Molten iron temperature on discharge to gasifier	1550	°C
on coal gasification	1500	°C
on discharge to pot car	-	°C
Basicity of slag	1.5	
Weight of coal	28	wet Kg
Weight of burnt lime	0	Kg

COAL SAMPLE - B

Sample number	BUICI		Ash components	
Proximate analysis	Ultimate analysis			
Ash	1.90 %	C	74.50 %	SI02
V.M.	46.04 %	H	5.43 %	Al2O3
F.C.	52.06 %	N	1.36 %	CaO
		O	18.26 %	K2O
		S	0.45 %	Na2O


(DRY BASE) (D.A.F.)

OPERATION CONDITION - B

Weight of molten iron	300	Kg
Flow rate of Oxygen	72.6	Nm ³ /hr
Flow rate of carrier gas	10.0	Nm ³ /hr
Flow rate of pulverized coal	35.0	Kg/hr
Position of main-lance over bath surface	200	mm
Molten iron temperature on discharge to gasifier	--	°C
on coal gasification	1500	°C
on discharge to pot car	1350	°C
Basicity of slag	1.5	
Weight of coal	27.	wet Kg
Weight of burnt lime	0	Kg

4. SCHEDULE

Time	5	6	7	8	9	10	11	12	13	14	15	16	17
Meeting Operating utility-equipments													
Heating up: Gasifier													
Runner													
Pot car													
Emergency pot													
Pulverizing coal													
Melting iron													
Discharging molten iron to gasifier													
Coal gasification													
Discharging molten iron to pot car													



RUN	/9 TH COAL GASIFICATION TEST RUN	RUN No.	CG019
-----	----------------------------------	---------	-------

DATE	1987.11. 18 . (Wed.)
------	----------------------

1. PURPOSE of RUN
 1) INVESTIGATIONS of GASIFICATION-CHARACTERISTIC for
 BJS and BSIA1 coal

2. COAL SAMPLE and OPERATION CONDITION
 COAL SAMPLE - A

Sample number		BJS	
Proximate analysis		Ultimate analysis	
Ash		Ash components	
V.M.	4.24 %	C	68.52 %
F.C.	49.97 %	H	5.68 %
	45.79 %	N	1.15 %
		O	24.13 %
		S	0.52 %

(DRY BASE) (D.A.F.)

OPERATION CONDITION - A

Weight of molten iron	300 Kg
Flow rate of Oxygen	Nm ³ /hr
Flow rate of carrier gas	Nm ³ /hr
Flow rate of pulverized coal	35.0 Kg/hr
Position of main-lance over bath surface	200 mm
Molten iron temperature on discharge to gasifier	1550 °C
on coal gasification	1500 °C
on discharge to pot car	— °C
Basicity of slag	1.5
Weight of coal	22 wet Kg
Weight of burnt lime	0 Kg

COAL SAMPLE - B



Sample number		BSIA1	
Proximate analysis		Ultimate analysis	
Ash		Ash components	
V.M.	4.29 %	C	73.15 %
F.C.	46.63 %	H	5.72 %
	49.08 %	N	1.14 %
		O	19.30 %
		S	0.71 %

(DRY BASE) (D.A.F.)

OPERATION CONDITION - B

Weight of molten iron	300 Kg
Flow rate of Oxygen	15.8 Nm ³ /hr
Flow rate of carrier gas	10.0 Nm ³ /hr
Flow rate of pulverized coal	35.0 Kg/hr
Position of main-lance over bath surface	200 mm
Molten iron temperature on discharge to gasifier	— °C
on coal gasification	1500 °C
on discharge to pot car	1550 °C
Basicity of slag	1.5
Weight of coal	21 wet Kg
Weight of burnt lime	0 Kg

4. SCHEDULE



DATE	1987.10. ()
TH COAL GASIFICATION TEST RUN	RUN No. CG01 - 20

26. Nov. 87

1. PURPOSE of RUN
 1) INVESTIGATIONS of GASIFICATION-CHARACTERISTIC for

2. COAL SAMPLE and OPERATION CONDITION
 COAL SAMPLE - A

Sample number BS4B		Ash components	
Proximate analysis	Ultimate analysis	SiO2	
Ash 4.49 %	C 73.12 %	Al2O3	**
V.M. 47.25 %	H 5.74 %	CaO	%
F.C. 48.26 %	N 1.13 %	K2O	**
	O 19.74 %	Na2O	**
	S 0.27 %		%

(DRY BASE) (D.A.F.)

OPERATION CONDITION - A

Weight of molten iron	300 Kg
Flow rate of Oxygen	15.0 Nm ³ /hr
Flow rate of carrier gas	10.0 Nm ³ /hr
Flow rate of pulverized coal	35.0 Kg/hr
Position of main-lance over bath surface	200 mm
Molten iron temperature on discharge to gasifier on coal gasification	1550 °C
on discharge to pot car	1500 °C
Basicity of slag	1.5
Weight of coal	2.0 wet Kg
Weight of burnt lime	0 Kg

COAL SAMPLE - B

Sample number B42B2		Ash components	
Proximate analysis	Ultimate analysis	SiO2	
Ash 2.29 %	C 73.10 %	Al2O3	**
V.M. 47.38 %	H 5.80 %	CaO	**
F.C. 50.16 %	N 1.25 %	K2O	**
	O 18.15 %	Na2O	**
	S 1.70 %		**

(DRY BASE) (D.A.F.)

OPERATION CONDITION - B

Weight of molten iron	300 Kg
Flow rate of Oxygen	15.7 Nm ³ /hr
Flow rate of carrier gas	10.0 Nm ³ /hr
Flow rate of pulverized coal	35.0 Kg/hr
Position of main-lance over bath surface	200 mm
Molten iron temperature on discharge to gasifier on coal gasification	-- °C
on discharge to pot car	1500 °C
Basicity of slag	1.5
Weight of coal	2.0 wet Kg
Weight of burnt lime	0 Kg

TEST000-1

DATE 1987.10.26 - (Thu.)

COAL SAMPLE--C

Sample number BU 2 A 1		Ash components	
Proximate analysis	Ultimate analysis		
Ash 7.06 %	C 76.73 %	SiO2	%%
V.M. 44.92 %	H 5.97 %	Al2O3	%%
F.C. 48.02 %	N 1.28 %	CaO	%%
	O 15.48 %	K2O	%%
	S 0.50 %	Na2O	%%

(DRY BASE) (D.A.F.)

OPERATION CONDITION--B

Weight of molten iron	300 Kg
Flow rate of Oxygen	16.1 Nm ³ /hr
Flow rate of carrier gas	10.0 Nm ³ /hr
Flow rate of pulverized coal	35.0 Kg/hr
Position of main-lance over bath surface	200 mm
Molten iron temperature on discharge to gasifier	°C
on coal gasification	1500 °C
on discharge to pot car	1350 °C
Basicity of slag	1.5
Weight of coal	2/ wet Kg
Weight of burnt lime	0 Kg

4-SCHEDULE

Time	5	6	7	8	9	10	11	12	13	14	15	16	17
Meeting operating utility equipments													
Heating up: Gasifier													
Rummer													
Pot car													
Emergency pot													
Pulverizing coal													
Melting iron													
Discharging molten iron to gasifier													
Coal gasification													
Discharging molten iron to pot car													

Time	11	12	13	14
Power of melting furnace & gasifier (KW)	250 150 50	150 150 150	150 150 150	150 150 150
Molten iron temperature (°C)	1550 1550 1550	1550 1550 1550	1550 1550 1550	1550 1550 1550
Flow rate of pulverized coal (Kg/hr)	350 10 20	350 10 20	350 10 20	350 10 20
Flow rate of oxygen & carrier gas (Nm ³ /hr)	20 10	20 10	20 10	20 10
Position of main-lance (mm)	200 100	200 100	200 100	200 100
Pressure in gasifier (mmAq)	+5 0 -5	+5 0 -5	+5 0 -5	+5 0 -5
Operating immersion probe	Δ	Δ	Δ	Δ
sub-lance MT	▲	▲	▲	▲
sub-lance CD	▼	▼	▼	▼
burnt lime	▽	▽	▽	▽

Mean bed depth
Sampling m-2
Sampling slag
Discharging

Discharging

RUN	TH COAL GASIFICATION TEST RUN	RUN No.	CG01 021
-----	-------------------------------	---------	----------

DATE	1987-12-2 - ()
------	-----------------

1. PURPOSE of RUN
 1) INVESTIGATIONS of GASIFICATION-CHARACTERISTIC for BSIC1

2. COAL SAMPLE and OPERATION CONDITION
 COAL SAMPLE - A

Sample number BSIC1		
Proximate analysis	Ultimate analysis	Ash components
Ash	76.4 %	SiO2
V.M.	46.95 %	Al2O3
F.C.	50.40 %	CaO
		K2O
		Na2O
		%
		%
		%
		%
		%
		%

(DRY BASE) (D.A.F.)

OPERATION CONDITION - A

Weight of molten iron	300	Kg
Flow rate of Oxygen	13.4	Nm3/hr
Flow rate of carrier gas	10.0	Nm3/hr
Flow rate of pulverized coal	35	Kg/hr
Position of main-lance	200	mm
over bath surface		
Molten iron temperature		°C
on discharge to gasifier	1550	°C
on coal gasification	1500	°C
on discharge to pot car	1.5	wet Kg
Basicity of slag	2.0	Kg
Weight of coal	0	
Weight of burnt lime		

COAL SAMPLE - B

Sample number BUIC1		
Proximate analysis	Ultimate analysis	Ash components
Ash	74.50 %	SiO2
V.M.	5.45 %	Al2O3
F.C.	1.36 %	CaO
	18.26 %	K2O
	0.45 %	Na2O
		%
		%
		%
		%
		%
		%

(DRY BASE) (D.A.F.)

OPERATION CONDITION - B

Weight of molten iron	300	Kg
Flow rate of Oxygen	12.6	Nm3/hr
Flow rate of carrier gas	10.0	Nm3/hr
Flow rate of pulverized coal	35	Kg/hr
Position of main-lance	200	mm
over bath surface		
Molten iron temperature		°C
on discharge to gasifier	1500	°C
on coal gasification		°C
on discharge to pot car	1.5	wet Kg
Basicity of slag	2.0	Kg
Weight of coal	0	
Weight of burnt lime		

TH COAL GASIFICATION TEST RUN	RUN No.	00021
-------------------------------	---------	-------

DATE	1987-12-2 . ()
------	-----------------

1. PURPOSE of RUN
 1) INVESTIGATIONS of GASIFICATION-CHARACTERISTIC for

2. COAL SAMPLE and OPERATION CONDITION
 COAL SAMPLE - A

Sample number			Ash components		
Proximate analysis	Ultimate analysis		SiO2		
Ash	%	C	%	H	%
V.M.	%	H	%	N	%
F.C.	%	N	%	O	%
	%	O	%	S	%
	%	S	%		%

(DRY BASE) (D.A.F.)

OPERATION CONDITION - A

Weight of molten iron	Kg	300
Flow rate of Oxygen	Nm3/hr	10.0
Flow rate of carrier gas	Nm3/hr	200
Flow rate of pulverized coal	Kg/hr	
Position of main-lance over bath surface	mm	
Molten iron temperature on discharge to gasifier	°C	1550
on coal gasification	°C	1500
on discharge to pot car	°C	1.5
Basicity of slag		
Weight of coal	wet Kg	
Weight of burnt lime	Kg	0

COAL SAMPLE - C

Sample number			Ash components		
Proximate analysis	Ultimate analysis		SiO2		
Ash	%	C	%	H	%
V.M.	%	H	%	N	%
F.C.	%	N	%	O	%
	%	O	%	S	%
	%	S	%		%

(DRY BASE) (D.A.F.)

OPERATION CONDITION - B

Weight of molten iron	Kg	300
Flow rate of Oxygen	Nm3/hr	14.5
Flow rate of carrier gas	Nm3/hr	10.0
Flow rate of pulverized coal	Kg/hr	35
Position of main-lance over bath surface	mm	200
Molten iron temperature on discharge to gasifier	°C	--
on coal gasification	°C	1500
on discharge to pot car	°C	1350
Basicity of slag		1.5
Weight of coal	wet Kg	2.0
Weight of burnt lime	Kg	0

4-SCHEDULE

Time	5	6	7	8	9	10	11	12	13	14	15	16	17
Meeting Operating utility-equipments heating up: Gasifier Runner Pot car Emergency pot Pulverizing coal Melting iron Discharging molten iron to gasifier													
Coal gasification													
Discharging molten iron to pot car													


Time	11	12	13	14
Power of melting furnace & gasifier (KW)	250	150	50	
Molten iron temperature (°C)	1500	1500	1500	1500
Flow rate of pulverized coal (kg/hr)	40	35.0	35.0	35.0
Flow rate of oxygen & carrier gas (Nm ³ /hr)	20	10.0	10.0	10.0
Position of main lance (mm)	200	200	200	200
Pressure in gasifier (mmHg)	+ 5	0	- 5	
Operating immersion probe	▲	▲	▲	▲
sub-lance MT	▲	▲	▲	▲
sub-lance CD	▼	▼	▼	▼
burnt line	▽	▽	▽	▽

Measuring bath depth
Sampling
Sampling slag
Discharging


2. Test Results

Operation Result on 8th, Sept, 1987


CG004




Operation Results on 11th, Sept, 1987




Operation Results on 16th, Sept. (CG006)




Operation Results on 22nd Oct. (CG007)




Operation Results, 25th. Sept. 1987.




Operation Results on 30th. Sept. '87




OPERATION RESULTS (1987.10.6)




OPERATION RESULTS (1987, 10.9)




OPERATION RESULTS (1987.10.15)




OPERATION RESULTS (1987.10.20.)




OPERATION RESULTS (1987.10.23.)




OPERATION RESULTS (1987.10.27.)




OPERATION RESULTS (1987.10.手.)




OPERATION RESULTS (1987.11.05.)




OPERATION RESULTS (1987.11.18.)



OPERATION RESULTS (1987.11.26.)



OPERATION RESULTS (1987.12.02)




ATTACHMENT 8-3

1. Material Balance Based on Gas Sampled from Inside to Gasifier
2. Material Balance Based on Gas Sampled from Position just before IDF

1. Material Balance Based on Gas Sampled from Inside to Gasifier

1. Material Flow



As shown in material flow, coal, N₂ and O₂ become generated gas by gasification. We want to know an information of generated gas, however air from the atmosphere mixes and reacts with generated gas before we get gas sample.

Furthermore we analyzed gas component as dry.

Therefore we should estimate real gas component by material balance calculation.

2. Assumption

- 1 Oxygen in the air from the atmosphere reacts with CO and H₂ in the generated gas, generating CO₂ and H₂O.
- 2 If summation of each content of gas components such as CO, CO₂, H₂, H₂O, N₂ and so on would not be 100%, N₂ content would be modified to make the summation 100%.

3. Calculation Method

By making material balance for H₂, O₂ and N₂ around gasifier we can know the following unknown values.

Unknown values: 1) gas components in generated gas (CO, CO₂, H₂, O₂, N₂, H₂O, H₂S, COS)
 2) amount of generated gas
 3) amount of air from the atmosphere
 4) H₂O content in sampled gas

Known values: 1) property of coal (ash, moisture, C, H, O, N, S)
 2) operation conditions (coal feed rate, carrier gas flow rate, oxygen flow rate)
 3) gas components in sampled gas (CO, CO₂, H₂, O₂, N₂, H₂S, COS)

(1) Hydrogen balance

$$HSUI + HGEN = HGAS + HJO$$

$$HSUI = \frac{22.4}{18} \times CFR \times Moi / 100$$

$$HGEN = \frac{22.4}{2} \times CFR \times (100 - Ash - Moi) / 100 \times H / 100$$

$$HGAS = (Y + 0.79Z - X) \times (H_2GS + H_2SGS) / 100$$

$$HJO = X$$

(2) Nitrogen balance

$$NGEN + 0.79Z + CGFR = NGAS$$

$$NGEN = \frac{22.4}{28} \times CFR \times (100 - Ash - Moi) / 100 \times N / 100$$

$$NGAS = (Y + 0.79Z - X) \times N_2GSD / 100$$

(3) Oxygen balance

$$OSUI + OGEN + OFR + 0.21Z = OGAS + OJO$$

$$OSUI = \frac{11.2}{18} \times CFR \times Moi / 100$$

$$OGEN = \frac{22.4}{32} \times CFR \times (100 - Ash - Moi) / 100 \times O / 100$$

$$OGAS = (Y + 0.79Z - X) \times (COGS/2 + CO_2GS + O_2GS + COSGS/2) / 100$$

$$OJO = X/2$$

(4) Gas compositions in generated gas

$$\begin{aligned} \text{CO} &: Y \times \text{CO}/100 - 0.21Z \times \eta_{\text{CO}} \times 2 = (Y + 0.79Z - X) \times \text{COGS}/100 \\ \text{CO}_2 &: Y \times \text{CO}_2/100 + 0.21Z \times \eta_{\text{CO}} \times 2 = (Y + 0.79Z - X) \times \text{CO}_2\text{GS}/100 \\ \text{H}_2 &: Y \times \text{H}_2/100 - 0.21Z \times (1 - \eta_{\text{CO}}) \times 2 = (Y + 0.79Z - X) \times \text{H}_2\text{GS}/100 \\ \text{O}_2 &: Y \times \text{O}_2/100 = (Y + 0.79Z - X) \times \text{O}_2\text{GS}/100 \\ \text{N}_2 &: Y \times \text{N}_2/100 + 0.79Z = (Y + 0.79Z - X) \times \text{N}_2\text{GS}/100 \\ \text{H}_2\text{S} &: Y \times \text{H}_2\text{S}/100 = (Y + 0.79Z - X) \times \text{H}_2\text{SGS}/100 \\ \text{COS} &: Y \times \text{COS}/100 = (Y + 0.79Z - X) \times \text{COSGS}/100 \\ \text{H}_2\text{O} &: Y \times \text{H}_2\text{O}/100 + 0.21Z \times (1 - \eta_{\text{CO}}) \times 2 = X \end{aligned}$$

Assumption: η_{CO} is given under the following assumption

$$K = \frac{\text{CO} \times \text{H}_2\text{O}}{\text{CO}_2 \times \text{H}_2} = \frac{\text{COGS} \times X}{\text{CO}_2\text{GS} \times (Y + 0.79Z - X) \times \text{H}_2\text{GS}/100}$$

X, Y and Z can be calculated by three simultaneous equations of (1), (2) and (3).


Therefore gas composition in generated gas can be also calculated by the upper equation (4).

Ash	Ash in coal (%)
Moi	Moisture in coal (%)
C	Carbon in coal (%) (d.a.f.)
H	Hydrogen in coal (%) (d.a.f.)
O	Oxygen in coal (%) (d.a.f.)
N	Nitrogen in coal (%) (d.a.f.)
S	Sulfur in coal (%) (d.a.f.)
CFR	Coal feed rate (kg/h)
CGFR	Carrier gas flow rate (Nm ³ /h)
OFR	Oxygen flow rate (Nm ³ /h)
COGS	CO content in sampled gas (%)
CO ₂ GS	CO ₂ content in sampled gas (%)
H ₂ GS	H ₂ content in sampled gas (%)
O ₂ GS	O ₂ content in sampled gas (%)
N ₂ GS	N ₂ content in sampled gas (%)
H ₂ SGS	H ₂ S content in sampled gas (%)
COSGS	COS content in sampled gas (%)

CO	CO content in generated gas (%)
CO ₂	CO ₂ content in generated gas (%)
H ₂	H ₂ content in generated gas (%)
O ₂	O ₂ content in generated gas (%)
N ₂	N ₂ content in generated gas (%)
H ₂ S	H ₂ S content in generated gas (%)
COS	COS content in generated gas (%)
H ₂ O	H ₂ O content in generated gas (%)
Y	Amount of generated gas (Nm ³ /h)
Z	Amount of air (Nm ³ /h)
X	Amount of H ₂ O in sampled gas (Nm ³ /h)
AA	Summation of gas components in sampled gas (%)
N ₂ GSD	N ₂ content in sampled gas after modification (N ₂ GSD = N ₂ GS + 100 - AA)
Y ₂	Amount of leakage gas (Nm ³ /h)
N ₂ P	Amount of purge N ₂ (Nm ³ /h)
HSUI	Hydrogen amount in moisture in coal (Nm ³ /h)
HGEN	Hydrogen amount in coal (Nm ³ /h)
HGAS	Hydrogen amount in sampled gas (Nm ³ /h)
HJO	Hydrogen amount in H ₂ O in sampled gas (Nm ³ /h)
NGEN	Nitrogen amount in coal (Nm ³ /h)
NGAS	Nitrogen amount in sampled gas (Nm ³ /h)
OSUI	Oxygen amount in moisture in coal (Nm ³ /h)
OGEN	Oxygen amount in coal (Nm ³ /h)
OGAS	Oxygen amount in sampled gas (Nm ³ /h)
OJO	Oxygen amount in H ₂ O in sampled gas (Nm ³ /h)
neo	Utilization ratio of oxygen in air to burn CO
FI	Recovering gas flow rate (m ³ /h)
ρ _o	Design value of density of recovering gas (kg/m ³)
ρ	Actual density of recovering gas (kg/m ³)
To	Design value of temperature of recovering gas (°C)
T	Actual temperature of recovering gas (°C)
PPI	Pressure difference in bag filter (mmH ₂ O)
P _o	Design value of pressure of recovering gas (mmH ₂ O)

**2. Material Balance Based on Gas Sampled from Position
just before IDF**

1. Material Flow



As shown in material flow, coal, N₂ and O₂ become generated gas by gasification. After that, air from the atmosphere mixes and reacts with generated gas and then a part of gas leaks from the space between hood and gasifier. Furthermore purge N₂ comes in from main lance hole and bag filter. After taking these change, gas passes through gas flow meter and is sampled at the position just before IDF in gas recovering duct.

In this material flow, we would know about an information of real generated gas.

2. Assumption

- (1) Oxygen in the air from the atmosphere reacts with CO and H₂ in the generated gas, generating CO₂ and H₂O.
- (2) If summation of each content of gas components such as CO, CO₂, H₂, H₂O, N₂ and so on would not be 100%, N₂ content would be modified to make the summation 100%.

3. Calculation Method

By making material balance for H₂, O₂ and N₂ around gasifier we can know the following unknown values.

- Unknown values:
- 1) gas components in generated gas (CO, CO₂, H₂, O₂, N₂, H₂O, H₂S, COS)
 - 2) amount of generated gas
 - 3) amount of air from the atmosphere
 - 4) amount of leakage gas
 - 5) H₂O content in sampled gas

- Known values:
- 1) property of coal (ash, moisture, C, H, O, N, S)
 - 2) operation conditions (coal feed rate, carrier gas flow rate, oxygen flow rate, recovering gas flow rate)
 - 3) gas components in sampled gas (CO, CO₂, H₂, O₂, N₂, H₂S, COS)

	Generated gas	After gasifier	Gas flow meter	Gas sampled
Gas amount (Nm ³ /h)	Y	Y+0.79Z	Y+0.79Z-Y ₂ +N ₂ P	/
CO (%)	CO	COI	COII	COGS
CO ₂ (%)	CO ₂	CO ₂ I	CO ₂ II	CO ₂ GS
H ₂ (%)	H ₂	H ₂ I	H ₂ II	H ₂ GS
H ₂ O (%)	H ₂ O	H ₂ OI	H ₂ OII	/
O ₂ (%)	O ₂	O ₂ I	O ₂ II	O ₂ GS
N ₂ (%)	N ₂	N ₂ I	N ₂ II	N ₂ GS
H ₂ S (%)	N ₂ S	H ₂ SI	H ₂ SII	H ₂ SGS
COS (%)	COS	COSI	COSII	COSGS
	↑ Air Z Nm ³ /h	↓ Leakage Y ₂ Nm ³ /h	↑ Purge N ₂ N ₂ P Nm ³ /h	

(1) Hydrogen balance

$$\begin{aligned}
 \text{HSUI} + \text{HGEN} &= Y \times (\text{H}_2 + \text{H}_2\text{O} + \text{H}_2\text{S})/100 \\
 &= (Y + 0.79Z) \times (\text{H}_{2I} + \text{H}_2\text{OI} + \text{H}_2\text{SI})/100 \\
 &= Y_2 \times (\text{H}_{2I} + \text{H}_2\text{OI} + \text{H}_2\text{SI})/100 \\
 &\quad + (Y + 0.79Z - Y_2 + N_2P) \times (\text{H}_{2II} + \text{H}_2\text{OII} + \text{H}_2\text{SII})/100 \\
 \text{H}_2 &: Y \times \text{H}_2/100 - Z \times 0.21 \times 2 \times (1 - \eta_{\text{CO}}) = (Y + 0.79Z) \times \text{H}_2\text{GS} \times A \times B/100 \\
 \text{H}_2\text{O} &: Y \times \text{H}_2\text{O}/100 + Z \times 0.21 \times 2 \times (1 - \eta_{\text{CO}}) = (Y + 0.79Z) \times \text{H}_2\text{OII} \times B/100 \\
 \text{H}_2\text{S} &: Y \times \text{H}_2\text{S}/100 = (Y + 0.79Z) \times \text{H}_2\text{SGS} \times A \times B/100 \\
 Y \times (\text{H}_2 + \text{H}_2\text{O} + \text{H}_2\text{S})/100 &= (Y + 0.79Z) \times B \times (\text{H}_2\text{OII} + A \times (\text{H}_2\text{GS} + \text{H}_2\text{SGS}))/100 \\
 &\dots (1)
 \end{aligned}$$

$$\begin{aligned}
 Y + 0.79Z - Y_2 + N_2P &= F_I \times D \\
 D &= \text{SQRT} \left(\frac{\rho_0}{\rho} \right) \times \left(\frac{T_0 + 273}{T + 273} \right) \times \left(\frac{10^4 - \text{PDI}}{P_0} \right) \\
 A &= (100 - \text{H}_2\text{OII})/100 \\
 B &= (Y + 0.79Z - Y_2 + N_2P)/(Y + 0.79Z - Y_2)
 \end{aligned}$$

(2) Oxygen balance

$$\begin{aligned}
 \text{OSUI} + \text{OGEN} + \text{OFR} &= Y \times (\text{CO}/2 + \text{CO}_2 + \text{H}_2\text{O}/2 + \text{O}_2 + \text{COS}/2)/100 \\
 \text{OSUI} + \text{OGEN} + \text{OFR} + 0.21Z &= (Y + 0.79Z) \times (\text{COI}/2 + \text{CO}_2\text{I} + \text{H}_2\text{OI}/2 \\
 &\quad + \text{O}_2\text{I} + \text{COSI}/2) \\
 &= Y_2 \times (\text{COI}/2 + \text{CO}_2\text{I} + \text{H}_2\text{OI}/2 + \text{O}_2\text{I} + \text{COSI}/2, \\
 &\quad + (Y + 0.79Z - Y_2 + N_2P) \times (\text{COII}/2 + \text{CO}_2\text{II} \\
 &\quad + \text{H}_2\text{OII}/2 + \text{O}_2\text{II} + \text{COSII}/2)/100 \\
 \text{CO} &: \text{COI} = \text{COGS} \times A \times B \\
 \text{CO}_2 &: \text{CO}_2\text{I} = \text{CO}_2\text{GS} \times A \times B \\
 \text{H}_2\text{O} &: \text{H}_2\text{OI} = \text{H}_2\text{OII} \times B \\
 \text{O}_2 &: \text{O}_2\text{I} = \text{O}_2\text{GS} \times A \times B \\
 \text{COS} &: \text{COSI} = \text{COSGS} \times A \times B \\
 \times \text{OSUI} + \text{OGEN} + \text{OFR} + 0.21Z &= (Y + 0.79Z) \times B \times (A \times (\text{COS}/2 + \text{CO}_2\text{GS} \\
 &\quad + \text{O}_2\text{GS} + \text{COSGS}/2) + \text{H}_2\text{OII}/2)/100 \\
 &\dots (2)
 \end{aligned}$$

(3) Nitrogen balance

$$\text{NGEN} + \text{CGFR} = Y \times N_2 / 100$$

$$\text{NGEN} + \text{CGFR} + 0.79Z = (Y + 0.79Z) \times N_2 I / 100$$

$$\text{NGEN} + \text{CGFR} + 0.79Z - Y_2 \times N_2 I / 100 + N_2 P = (Y + 0.79Z - Y_2 + N_2 P) \times N_2 II / 100$$

$$(Y + 0.79Z - Y_2) \times N_2 I / 100 = (Y + 0.79Z - Y_2 + N_2 P) \times N_2 II / 100 - N_2 P$$

$$N_2 II = N_2 GS \times A$$

$$\text{NGEN} + \text{CGFR} + 0.79Z = (Y + 0.79Z) \times B \times (A \times N_2 GS / 100 - N_2 P / (Y + 0.79Z - Y_2 + N_2 P))$$

..... (3)

From equation (1) and (2), Y and Z can be calculated, if H₂OII could be assumed a certain value.

After that we check whether both sides in equation (3) are equal or not, if they are OK, we can have all components in generated gas.

Ash	Ash in coal (%)
Moi	Moisture in coal (%)
C	Carbon in coal (%) (d.a.f.)
H	Hydrogen in coal (%) (d.a.f.)
O	Oxygen in coal (%) (d.a.f.)
N	Nitrogen in coal (%) (d.a.f.)
S	Sulfur in coal (%) (d.a.f.)
CFR	Coal feed rate (kg/h)
CGFR	Carrier gas flow rate (Nm ³ /h)
OFR	Oxygen flow rate (Nm ³ /h)
COGS	CO content in sampled gas (%)
CO ₂ GS	CO ₂ content in sampled gas (%)
H ₂ GS	H ₂ content in sampled gas (%)
O ₂ GS	O ₂ content in sampled gas (%)
N ₂ GS	N ₂ content in sampled gas (%)
H ₂ SGS	H ₂ S content in sampled gas (%)
COSGS	COS content in sampled gas (%)
CO	CO content in generated gas (%)

CO ₂	CO ₂ content in generated gas (%)
H ₂	H ₂ content in generated gas (%)
O ₂	O ₂ content in generated gas (%)
N ₂	N ₂ content in generated gas (%)
H ₂ S	H ₂ S content in generated gas (%)
COS	COS content in generated gas (%)
H ₂ O	H ₂ O content in generated gas (%)
Y	Amount of generated gas (Nm ³ /h)
Z	Amount of air (Nm ³ /h)
X	Amount of H ₂ O in sampled gas (Nm ³ /h)
AA	Summation of gas components in sampled gas (%)
N ₂ GSD	N ₂ content in sampled gas after modification (N ₂ GSD = N ₂ GS + 100 - AA)
Y ₂	Amount of leakage gas (Nm ³ /h)
N ₂ P	Amount of purge N ₂ (Nm ³ /h)
HSUI	Hydrogen amount in moisture in coal (Nm ³ /h)
HGEN	Hydrogen amount in coal (Nm ³ /h)
HGAS	Hydrogen amount in sampled gas (Nm ³ /h)
HJO	Hydrogen amount in H ₂ O in sampled gas (Nm ³ /h)
NGEN	Nitrogen amount in coal (Nm ³ /h)
NGAS	Nitrogen amount in sampled gas (Nm ³ /h)
OSUI	Oxygen amount in moisture in coal (Nm ³ /h)
OGEN	Oxygen amount in coal (Nm ³ /h)
OGAS	Oxygen amount in sampled gas (Nm ³ /h)
OJO	Oxygen amount in H ₂ O in sampled gas (Nm ³ /h)
η _{co}	Utilization ratio of oxygen in air to burn CO
FI	Recovering gas flow rate (Nm ³ /h)
ρ _o	Design value of density of recovering gas (kg/m ³)
ρ	Actual density of recovering gas (kg/m ³)
To	Design value of temperature of recovering gas (°C)
T	Actual temperature of recovering gas (°C)
PPI	Pressure difference in bag filter (mmH ₂ O)
Po	Design value of pressure of recovering gas (mmH ₂ O)

ATTACHMENT 9-2

1. Production Cost Comparison between Methanol and Methanol/Urea Co-products
2. Comparison of Electricity Generation Cost

- 1. Production Cost Comparison between Methanol and Methanol/Urea Co-products**

Production Cost Comparison between Methanol and Methanol/Urea Co-products

1. Objective of the Study

This study has been carried out to grasp the cost comparison between methanol production and methanol/urea co-production from Banko coal on the basis of the master plan established in the 2nd stage.

(Note): The results of the study is cited from the Interim Report (Stage II), March 1988.

2. Outline of the Case Study

Fuel methanol production and fuel methanol/urea co-production are taken up out of possible products for the Proposed Project and the following two cases have been set up.

Case 1 is to produce only fuel methanol of which total plant capacity is 5,000 t/d and can be defined as a base case, since fuel methanol is expected as the most prospective derivatives of coal in Indonesia.

Master plan and overall block flow diagram of Case 1 are shown in Fig. 1 and 2.

Case 2 is to produce 4,060 t/d of methanol as well as 1,750 t/d of urea through ammonia. Since a demand of urea in Indonesia will still grow up, this case is selected. However, a viability of this case will mainly depend on a sales price of urea after a decade and possibility of natural gas supply for a new project in Indonesia, since PUSRI has urea production facilities starting from natural gas in Palembang and there is enough amount of natural gas resources to produce urea but not enough for export.

Master plan and overall block flow diagram of Case 2 are shown in Fig. 3 and 4.

3. Assumptions for Financial Analysis

3-1 Master Plan Case 1

3-1-1 Production Schedule

(1) Annual Production; 1,600,000 t of chemical grade methanol

(2) Plant Construction Period; 1990 - 1993 (4 years)

where 30% completion at the end of 1990

60% completion at the end of 1991

80% completion at the end of 1992

100% completion at the end of 1993

(Note); In this financial study, it is assumed that escalation factor is out of considerations. Therefore, time schedule such as 1990 - 1993 is assumed only for reference.

(3) Project Life; 1994 - 2023 (30 years)

where 70% of full operation in 1994

85% of full operation in 1995

100% of full operation in 1996 and after

(4) Annual Operation Days; 320 days

3-1-2 Finance

(1) Debt/Equity Ratio; 75/25

(2) Currency

For Annual Revenue/Expenditure; Rupiah

For Capital Investment; Yen

Exchange Rate; 0.18 Yen/Rupiah

Accordingly, debt is repayed by exchanging Rupiah for yen at the above exchange rate.

(3) Debt Repayment Schedule

Terms of 12 years after commitment, including 4 years of grace period with 8 years equal payments of principal.




Fig. 1 Master Plan for Feasibility Study on Effective Utilization of Banko Coal Case 1




Fig. 2 Overall Block Flow Diagram (Case 1)




Fig. 3 Master Plan for Feasibility Study on Effective Utilization of Banko Coal Case 2




Fig. 4 Overall Block Flow Diagram (Case 2)

(4) Interest

- 1) Long-term Loan; 8% per annum

Assumed supplier's credit (7.2% p.a.) plus bank loan and project risk premium.

- 2) Short-term Loan; 8% per annum

A short term loan would be raised commensurate with annual cash deficiency and would be repayed after development loan.

- 3) Interest during Construction Period

In accordance with a general rule in similar projects, interest paid or accrued during construction period is capitalized and amortized over a 10-year period from 1994.

3-1-3 Escalation

No escalation is assumed.

3-1-4 Price and Costs

- (1) Sales Price of Methanol at Plant Gate; 194 Rp/kg (35 ¥/kg, 175 \$/t)

- (2) Capital Investment Costs

- 1) Fixed-capital Investment;

	<u>10⁶ Rupiah</u>	<u>(10⁶ Yen)</u>
Coal Gasification	301,900	(54,500)
Coal Transportation	43,800	(7,900)
Methanol Synthesis	188,400	(34,000)
Air Separation	89,200	(16,100)
Power Generation	99,700	(18,000)
Support Facilities	159,600	(28,800)
Equipment Transportation	63,700	(11,500)
Contingency	47,600	(8,600)
Total	<u>993,900</u>	<u>(179,400)</u>

(Note); Construction cost of each plant was reviewed based on the revised master plan. As the result, total fixed-capital

investment cost was slightly increased in comparison with that of previous estimation in the study of FY1985.

	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
2) Working Capital;	50,216	(9,064)
(Note); Working capital is added as cash-flow at the end of the project.		
3) Start-up Expense;	6,882	(1,242)
4) Operator Training Cost;	2,598	(469)
5) Investment Schedule;	Shown in Table 1	

Table 1 Investment Schedule

	1990	1991	1992	1993
Fixed Capital	30%	30%	20%	20%
Working Capital	-	-	-	100%
Start-up Expense	-	-	-	100%
Operator Training	-	-	-	100%

(3) Annual Expense

1) Fixed Costs

i) Depreciation and Amortization

	<u>Period</u>	<u>Amount</u>	
	<u>Years</u>	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
- Boiler, Power Plant, Cooling Tower, Buildings	15	13,702	(2,473)
- Others	10	94,296	(17,020)
ii) Maintenance		23,172	(4,182)
iii) Insurance		9,269	(1,673)

(Note); Capital investment for the plant construction including expense and interests during construction period is depreciated and amortized based on straight line method.

	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
2) Variable Costs		
i) Raw Materials ¹⁾		
- Coal	67,895	(12,255)
- CaCO ₃	665	(120)
ii) Supervisor and Operating Labor		
- Foreign Staff ²⁾		
- Local Labor	2,715	(490)
iii) Catalysts and Chemicals	3,413	(616)

(Note); 1) In the study of preliminary evaluation of economic feasibility in FY1985 and FY1986, \$14.85/t-coal was assumed as raw material cost. In this study, coal cost was assumed to be \$14.48/t on the basis of the study on coal mining cost in FY1986 (for details, see the Interim Report III, page 71 -102). Cost of lime stone consumed in gasification plant and fluidized-bed boiler was estimated to be \$4.83/t assuming that it was one-third of coal cost.

2) Foreign staff decrease in number as the project proceeds.

Table 2 Costs for Foreign Staffs

Op. Year	1st	2nd	3rd	4th	5th	6th-30th
Year	1994	1995	1996	1997	1998	1999-2023
% on 1st year	100	70	50	30	10	0
Cost, 10 ⁶ Rp/y	7,900	5,530	3,950	2,370	790	0
(Cost, 10 ⁶ ¥/y)	(1,426)	(998)	(713)	(428)	(143)	(0)

	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
iii) Plant Overhead Costs	10,615	(1,916)
iv) Administration Expenses	5,307	(958)

3-1-5 Evaluation Criteria

(1) Financial Statement

- 1) Profit and Loss Statement
- 2) Cash Flow Statement
- 3) Balance Sheet

(2) IRR on Total Project Cost before Tax

In accordance with the following equation, cash flow is discounted to the present value as of 1985.

$$\sum_{i=0}^n \frac{(C_{in, i} - C_{out, i})}{(1+r)^i} = 0$$

where,

- C_{in, i}; cash-inflow at ith year from 1985
- C_{out, i}; cash-outflow at ith year from 1985
- r; discount rate (=IRR)
- n; project life (1990-2023)
- i = 0 at 1985

Cash-inflow	Cash-outflow
• Sales Proceeds	• Investment excluding interest during construction period.
• Residual value of investment	• Total operating expenditure excluding depreciation and interest

3-2 Master Plan Case 2

3-2-1 Production Schedule

(1) Annual Production;

Methanol 1,300,000 t (Chemical grade)
 Urea 560,000 t (Ditto)

(2) Plant Construction Period; Same as with Case 1

(3) Project Life; Same as with Case 1

(4) Annual Operation Days; Same as with Case 1

3-2-2 Finance

Same as with Case 1.

3-2-3 Escalation

Same as with Case 1.

3-2-4 Price and Costs

(1) Sales Price of Products at Plant Gate;

Methanol 194 Rp/kg (35 ¥/kg, 175 \$/t)

Urea 166 Rp/kg (30 ¥/kg, 150 \$/t)

(Note); Sales price of methanol is same as that in Case 1. Sales price of urea at plant gate was assumed referring to the preliminary evaluation study on urea production cost executed in FY1986 in which international FOB price and transportation cost of urea from plant to Palembang were estimated to be 170-180 \$/t and 25 \$/t respectively.

(2) Capital Investment Costs

1) Fixed-capital investment;

	<u>10⁶ Rupiah</u>	<u>(10⁶ Yen)</u>
Coal Gasification	301,900	(54,500)
Coal Transportation	45,400	(8,200)
Methanol Synthesis	162,900	(29,400)
Ammonia/Urea Synthesis	154,000	(27,800)
Air Separation	89,200	(16,100)
Power Generation	139,600	(25,200)
Support Facilities	164,600	(29,700)
Equipment Transportation	63,700	(11,500)
Contingency	56,600	(10,200)
Total	1,177,800	(212,600)

(Note); Construction cost of each plant was reviewed based on the

information in FY 1987. As the result, total fixed-capital investment cost was almost same as that of estimation in FY1986.

	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
2) Working Capital;	57,839	(10,440)
(Note); Working capital is added as cash-flow at the end of the project.		
3) Start-up Expense;	7,490	(1,352)
4) Operator Training Cost;	3,202	(578)
5) Investment Schedule;	Same as with Case 1	

(3) Annual Expense

1) Fixed Costs

i) Depreciation and Amortization

	<u>Period</u>	<u>Amount</u>	
	<u>Years</u>	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
- Boiler, Power Plant, Cooling Tower, Buildings	15	16,952	(3,060)
- Others	10	110,614	(19,966)
ii) Maintenance		27,770	(5,012)
iii) Insurance		11,108	(2,005)

(Note); See the relevant note in 3-1-4 (3).

	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
2) Variable Costs		
i) Raw Materials ¹⁾		
- Coal	72,825	(13,145)
- CaCO ₃	715	(129)
ii) Supervisor and Operating Labor		
- Foreign Staff ²⁾		
- Local Labor	3,346	(604)
iii) Catalysts and Chemicals	3,324	(600)

(Note); 1) See the relevant note in 3-1-4 (3).

2) Foreign staff decrease in number as the project proceeds.

Table 3 Costs for Foreign Staff

Op. Year	1st	2nd	3rd	4th	5th	6th-30th
Year	1994	1995	1996	1997	1998	1999-2023
% on 1st year	100	70	50	30	10	0
Cost, 10 ⁶ Rp/y	9,651	6,756	4,825	2,895	965	0
(Cost, 10 ⁶ ¥/y)	(1,742)	(1,219)	(871)	(523)	(174)	(0)

	<u>10⁶ Rp/y</u>	<u>(10⁶ ¥/y)</u>
3) Plant Overhead Costs	12,997	(2,346)
4) Administration Expenses	6,499	(1,173)

3-2-5 Evaluation Criteria

Same as with Case 1

4. Results and Evaluation

4-1 Results

Results are summarized in Table 4.

Profit and loss statement and cash flow statement are shown in Table 5 to Table 8.

Table 4 Results of Financial Analysis

Case	Case 1 (Methanol Production)	Case 2 (Methanol/Urea Co-production)
IRR on Total Investment	13.0%	12.2%
First Year to Have Profit before Tax (Year from Operation Starts)	3rd	3rd
Clear off of Accumulated Loss (Year from Operation Starts)	6th	7th
Pay off of All the Debts (Year from Loan Raised)	12th	12th
Minimum Sales Price (IRR=Interest Rate (8%))	Methanol 148 Rp/kg (26.7 ¥/kg) (175 \$/t)	Methanol 194 Rp/kg (35 ¥/kg) Urea 37 Rp/kg (6.7 ¥/kg) (33.4 \$/t)

(Note); Minimum sales price of urea are calculated under fixed price of methanol.

Table 5 Profit and Loss Statement of Case 1

(Unit: 10⁹ Rupiah)

Year	OP Year	Revenue	Expenditure				Profit				
			Variable Cost	Fixed Cost	General	Interest Paid	Total	Before Tax	(Tax)	Net Profit	Retained Earning
1994	1	217.2	61.0	140.4	15.9	70.4	287.8	-70.6	0	-70.6	-70.6
1995	2	263.7	69.4	140.4	15.9	65.7	291.5	-27.8	0	-27.8	-98.4
1996	3	310.2	78.6	140.4	15.9	57.5	292.5	17.8	0	17.8	-80.6
1997	4	310.2	77.1	140.4	15.9	46.9	280.4	29.9	0	29.9	-50.7
1998	5	310.2	75.5	140.4	15.9	35.4	267.2	43.0	0	43.0	-7.7
1999	6	310.2	74.7	140.4	15.9	23.7	254.7	55.5	22.0	33.5	25.8
2000	7	310.2	74.7	140.4	15.9	13.5	244.6	56.7	30.2	35.5	61.3
2001	8	310.2	74.7	140.4	15.9	4.5	235.5	74.7	34.4	40.3	101.6
2002	9	310.2	74.7	140.4	15.9	0	231.0	79.2	36.4	42.8	144.4
2003	10	310.2	74.7	140.4	15.9	0	231.0	79.2	36.4	42.8	187.2
2004	11	310.2	74.7	46.1	15.9	0	136.8	173.5	79.8	93.7	280.9
2005	12	310.2	74.7	46.1	15.9	0	136.8	173.5	79.8	93.7	374.5
2006	13	310.2	74.7	46.1	15.9	0	136.8	173.5	79.8	93.7	468.2
2007	14	310.2	74.7	46.1	15.9	0	136.8	173.5	79.8	93.7	561.9
2008	15	310.2	74.7	46.1	15.9	0	136.8	173.5	79.8	93.7	655.6
2009	16	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	756.7
2010	17	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	857.8
2011	18	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	958.9
2012	19	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,060.0
2013	20	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,161.1
2014	21	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,262.1
2015	22	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,363.2
2016	23	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,464.3
2017	24	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,565.4
2018	25	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,666.5
2019	26	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,767.6
2020	27	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,868.7
2021	28	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	1,969.8
2022	29	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	2,070.8
2023	30	310.2	74.7	32.4	15.9	0	123.1	187.2	86.1	101.1	2,171.9
	Total	9,167.9	2,228.8	2,121.7	477.7	317.6	5,145.8	4,022.1	1,850.2	2,171.9	

Table 6 Cash Flow Statement of Case 1

(Unit: 10⁹ Rupiah)

(IRR: 13.0%)

Year	OP Year	Investment	Profit Before Tax	Depreciation/Amortization	Interest Paid	Cash Flow	DCF (Base; 1985)
1990		-298.2	-	-	-	-298.2	-161.6
1991		-298.2	-	-	-	-298.2	-143.0
1992		-198.8	-	-	-	-198.8	-84.4
1993		-258.5	-	-	-	-258.5	-97.0
1994	1	-	-70.6	108.0	70.4	107.8	35.8
1995	2	-	-27.8	108.0	65.7	145.9	42.9
1996	3	-	17.8	108.0	57.5	183.2	47.6
1997	4	-	29.9	108.0	46.9	184.8	42.5
1998	5	-	43.0	108.0	35.4	186.4	37.9
1999	6	-	55.5	108.0	23.7	187.2	33.7
2000	7	-	56.7	108.0	13.5	187.2	29.8
2001	8	-	74.7	108.0	4.5	187.2	26.4
2002	9	-	79.2	108.0	0	187.2	23.3
2003	10	-	79.2	108.0	0	187.2	20.7
2004	11	-	173.5	13.7	0	187.2	18.3
2005	12	-	173.5	13.7	0	187.2	16.2
2006	13	-	173.5	13.7	0	187.2	14.3
2007	14	-	173.5	13.7	0	187.2	12.7
2008	15	-	173.5	13.7	0	187.2	11.2
2009	16	-	187.2	0	0	187.2	9.9
2010	17	-	187.2	0	0	187.2	8.8
2011	18	-	187.2	0	0	187.2	7.8
2012	19	-	187.2	0	0	187.2	6.9
2013	20	-	187.2	0	0	187.2	6.1
2014	21	-	187.2	0	0	187.2	5.3
2015	22	-	187.2	0	0	187.2	4.8
2016	23	-	187.2	0	0	187.2	4.2
2017	24	-	187.2	0	0	187.2	3.7
2018	25	-	187.2	0	0	187.2	3.3
2019	26	-	187.2	0	0	187.2	2.9
2020	27	-	187.2	0	0	187.2	2.6
2021	28	-	187.2	0	0	187.2	2.3
2022	29	-	187.2	0	0	187.2	2.0
2023	30	-	187.2	0	0	237.4	2.3
	Total	-1,053.7	4,022.1	1,148.5	317.6	4,484.8	0.0

Table 7 Profit and Loss Statement of Case 2

(Unit: 10⁹ Rupiah)

Year	OP Year	Revenue	Expenditure				Profit			Retained Earning	
			Variable Cost	Fixed Cost	General	Interest Paid	Total	Before Tax	(Tax)		Net Profit
1994	1	241.6	66.8	166.4	19.5	83.8	336.5	-94.9	0	-94.9	-94.9
1995	2	293.4	75.4	166.4	19.5	79.3	340.6	-47.3	0	-47.3	-142.2
1996	3	345.2	85.0	166.4	19.5	70.8	341.8	3.4	0	3.4	-138.8
1997	4	345.2	83.1	166.4	19.5	59.8	328.9	16.3	0	16.3	-122.6
1998	5	345.2	81.2	166.4	19.5	47.8	314.9	30.3	0	30.3	-92.3
1999	6	345.2	80.2	166.4	19.5	34.6	300.7	44.4	0	44.4	-47.9
2000	7	345.2	80.2	166.4	19.5	20.5	286.6	58.5	5.2	53.4	5.5
2001	8	345.2	80.2	166.4	19.5	6.6	272.8	72.4	33.3	39.1	44.6
2002	9	345.2	80.2	166.4	19.5	0	266.2	79.0	36.3	42.7	87.2
2003	10	345.2	80.2	166.4	19.5	0	266.2	79.0	36.3	42.7	129.9
2004	11	345.2	80.2	55.8	19.5	0	155.5	189.6	87.2	102.4	232.3
2005	12	345.2	80.2	55.8	19.5	0	155.5	189.6	87.2	102.4	334.7
2006	13	345.2	80.2	55.8	19.5	0	155.5	189.6	87.2	102.4	437.1
2007	14	345.2	80.2	55.8	19.5	0	155.5	189.6	87.2	102.4	539.5
2008	15	345.2	80.2	55.8	19.5	0	155.5	189.6	87.2	102.4	641.9
2009	16	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	753.4
2010	17	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	865.0
2011	18	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	976.5
2012	19	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,088.0
2013	20	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,199.6
2014	21	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,311.1
2015	22	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,422.7
2016	23	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,534.2
2017	24	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,645.8
2018	25	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,757.3
2019	26	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,868.9
2020	27	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	1,980.4
2021	28	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	2,092.0
2022	29	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	2,203.5
2023	30	345.2	80.2	38.9	19.5	0	138.6	206.6	95.0	111.5	2,315.1
Total		10,199.3	2,396.8	2,526.8	584.9	403.1	5,911.6	4,287.7	1,972.6	2,315.1	

Table 8 Cash Flow Statement of Case 2

(Unit: 10⁹ Rupiah)

(IRR: 12.2%)

Year	OP Year	Investment	Profit Before Tax	Depreciation/ Amortization	Interest Paid	Cash Flow	DCF (Base; 1985)
1990		-353.4	-	-	-	-353.4	-198.4
1991		-353.4	-	-	-	-353.4	-176.7
1992		-235.5	-	-	-	-235.5	-105.0
1993		-304.1	-	-	-	-304.1	-120.7
1994	1	-	-94.9	127.6	83.8	116.4	41.2
1995	2	-	-47.3	127.6	79.3	159.6	50.3
1996	3	-	3.4	127.6	70.8	201.7	56.6
1997	4	-	16.3	127.6	59.8	203.7	51.0
1998	5	-	30.3	127.6	47.8	205.6	45.8
1999	6	-	44.4	127.6	34.6	206.6	41.0
2000	7	-	58.5	127.6	20.5	206.6	36.5
2001	8	-	72.4	127.6	6.6	206.6	32.6
2002	9	-	79.0	127.6	0	206.6	29.0
2003	10	-	79.0	127.6	0	206.6	25.8
2004	11	-	189.6	16.9	0	206.6	23.0
2005	12	-	189.6	16.9	0	206.6	20.5
2006	13	-	189.6	16.9	0	206.6	18.3
2007	14	-	189.6	16.9	0	206.6	16.3
2008	15	-	189.6	16.9	0	206.6	14.5
2009	16	-	206.6	0	0	206.6	12.9
2010	17	-	206.6	0	0	206.6	11.5
2011	18	-	206.6	0	0	206.6	10.3
2012	19	-	206.6	0	0	206.6	9.1
2013	20	-	206.6	0	0	206.6	8.1
2014	21	-	206.6	0	0	206.6	7.3
2015	22	-	206.6	0	0	206.6	6.5
2016	23	-	206.6	0	0	206.6	5.8
2017	24	-	206.6	0	0	206.6	5.1
2018	25	-	206.6	0	0	206.6	4.6
2019	26	-	206.6	0	0	206.6	4.1
2020	27	-	206.6	0	0	206.6	3.6
2021	28	-	206.6	0	0	206.6	3.2
2022	29	-	206.6	0	0	206.6	2.9
2023	30	-	206.6	0	0	264.4	3.3
	Total	-1,246.4	4,287.7	1,360.4	403.1	4,862.7	0.0

4-2 Evaluation

(1) Profit and Loss

From the viewpoint of profitability, both projects of Case 1 and Case 2 are financially viable. After the projects record deficit for the first two years, they record surplus from the third year onward.

The cumulative deficit of Case 1 is cleared off in the 6th year but that of Case 2 is in the 7th year.

(2) Internal Rate of Return before Tax

As far as IRR is concerned, the resulting 13.0% of IRR on Case 1 and 12.2% on Case 2 cannot be considered as a high rate in general standard due to large investment costs. However, if low cost funds such as the interest rate of 8% assumed in this study is arranged, both cases are considered to be viable.

(3) Debt Repayment

Debt repayment is accomplished in eight years from start of plant operation in both cases. This period is not so long term in consideration of thirty years of project life.

(4) Evaluation

Profitability of Case 1 is superior to that of Case 2 from the viewpoint of IRR. Provided that the crude oil price rises higher than 30\$/bbl which corresponds to 35¥/kg of methanol price at plant gate, the viability of the project Case 1 would be enhanced because the noncommercial Banko coal is not affected by oil.

2. Comparison of Electricity Generation Cost

1. Objective of the Study

This study has been carried out for the purpose of preliminary evaluation of economic feasibility on the case of electricity generation from Banko coal by using the fluidized-bed boiler (FBB) in order to compare with the economic evaluation of coal gasification combined-cycle (CGCC) power generation.

As a matter of convenience for cost comparison between this plant and CGCC power plant, the same gross generating capacity (900 MW), and assumptions of economic factors such as electricity generation schedule, finance, sales price and raw material cost were selected in this study.

Note): These results are abstracted and compiled from the Interim Report III (FY 1986) and the Interim Report, Stage II (March, 1988) on the Feasibility Study on Effective Utilization of Banko Coal in the Republic of Indonesia. For details, refer to these reports.

2. Outline of Power Plants

2-1 Coal Gasification Combined-cycle Plant (CGCC)

2-1-1 Design Basis

- | | | |
|------------------------------|---|---------------------------|
| (1) Type of Power Plant | : | Combined Cycle Generation |
| (2) Generating Power | | |
| Gross Generating Power | : | 900 MW |
| Available Generating Power | : | 855 MW |
| Net Generating Power | : | 835 MW |
| (Power to Gasification Plant | : | 20 MW) |
| (3) Annual Operation Days | : | 320 d/y |
| (4) Plant Location | : | Tanjung Priok |
| (5) Electricity Transmission | : | Switchyard of Power Plant |

Note*): Electricity will be sold to PLN.

(6) Feed Coal Specification :

C, %	:	27.4
V.M., %	:	32.8
Ash, %	:	4.8
Mo., %	:	35.0
Total, %	:	100.0
HV, Kcal/kg	:	4,430

(7) Coal Receiving : Bunker Hopper at Mine Site


(8) Utilities : All the utilities except raw water and coal are generated inside the plant

Conditions:

HP St'm	:	480°C, 65 kg/cm ² G
MP St'm	:	250°C, 40 kg/cm ² G
LP St'm	:	155°C, 3.5 kg/cm ² G
BFW (I)	:	110°C, 5 kg/cm ² G
BFW (II)	:	110°C, 55 kg/cm ² G
C. Water	:	30°C (Supply)/37°C (Return)

2-1-2 Plant Configuration

Fig. 1 shows the scope of coal gasification and electricity generation complex divided into seven blocks each of which has its individual function. The component facilities in each block are listed in Table 1.



* Component facilities consisting each block are listed in Table 1.

Fig. 1 Overall Block Flow Diagram

Table 1 Plant Configuration

- 1) **Belt Conveyor System**
Primary Crusher/Feeder
Overland Coal Conveyor

- 2) **Coal Gasification**
Coal Storage and Handling
Coal Pretreatment
Coal Gasification
Gas Cooling/Dedusting
Calcination

- 3) **Air Separation Plant**
Air Separation
Liquid Oxygen Tank
Liquid Nitrogen Tank

- 4) **Power Plant & Utility System**
Gas Turbine/Generator
Steam Turbine/Generator
Heat Recovery Steam Generator (HRSG)
HP & LP Steam Circuit
Power Distribution
Water Cooling
Raw Water Intake/Pretreatment
Instrument/Plant Air Supply

- 5) **Pollution Control/Safety System**
Waste Water Treatment
Solid Waste Disposal
Flare/Blowdown
Fire Fighting

6) Service Facilities

Administration Office

Laboratory

Warehouse

Accommodation

Canteen

Cafeteria

Leisure Center

Mosque

Communication System

Maintenance Shop

Potable Water Supply

2-1-3 Electricity Generation

(1) Process Flow Diagram

See Fig. 2.

(2) Process Description

- 1) The plant comprises three combined cycle blocks. Each consists of two 100 MW class gas turbines, two heat recovery steam generators (HRSG) and a steam turbine.
- 2) The gas turbine/generator packages convert about 31% of the fuel energy into electric power and release almost all the remainder as waste heat in the exhaust gas at about 530°C. This wasted energy is recovered for use as heat. The heat recovery steam generator (HRSG) positioned on the exhaust paths reduce the exhaust temperature to about 130°C and recover the gas turbine losses by converting them into steam. The steam is used to drive steam turbines to generate additional power and process steam. Thus the gross efficiency of power plant becomes about 45%.
- 3) The HRSG is of dual pressure system and produces two different pressure steams.

HP steam: 65 kg/cm²G x 480°C

LP steam: 3.5 kg/cm²G x 155°C

The feedwater is first heated in feedwater tank and then in the LP economizer. Evaporation takes place in forced circulation LP evaporator and transferred to the process. HP part of the HRSG has the same system as that of LP part, though superheater is furnished in this case, and is placed in series in the exhaust gas stream. A part of HP steam is transferred to the process and the remainder is used to drive steam turbine. MP steam (40 kg/cm²G x 250°C) is input to the intermediate stage of the steam turbine.

(3) Major Equipment

Specifications and the number of units of major equipment are listed in Table 2.




Fig. 2 Simplified Process Flow Diagram (CGCC)

Table 2 Major Equipment (CGCC)

Description	Q'ty	Specification
Gas turbine/generator package	6	100 MW
Heat recovery steam generator	6	HP: 65 kg/cm ² G x 480°C x 168 t/h LP: 3.5 kg/cm ² G x 156°C x 46 t/h
Steam turbine/generator unit	3	100 MW
Steam condenser	3	390 t/h x 722 mmHgV
Vacuum pump	3	722 mmHgV
Condensate pump	9 (3 standby)	215 m ³ /h x 100m
Feedwater tank	3	10 m ³
HP feedwater pump	9 (3 standby)	200 m ³ /h x 750 m
LP feedwater pump	9 (3 standby)	250 m ³ /h x 75m
Cooling tower	1	100,000 t/h
Fuel gas compressor unit	6	115,000 Nm ³ /h x 17 kg/cm ²
Demineralized water plant	1	100 t/h
Raw water pump	3 (1 standby)	1,630 t/h x 30m
Feed water pump for gasification	2 (1 standby)	640 t/h x 550 m

2-1-4 Utility Requirement

See Table 3 and Fig. 3.

Table 3 Utility Requirement

Coal	495 t/h (external supply)
Raw Water	2,960 t/h (ditto)
Electricity	835,000 kW (outside supply)
ditto	20,000 kW (internal supply)
Cooling Water	119,100 t/h (ditto)
BFW	1,703 t/h (ditto)
HP Steam	189 t/h (ditto)
LP Steam	273 t/h (ditto)




Fig. 3 Utility Flow Diagram (CGCC)

2-2 Fluidized-bed Boiler Plant (FBB)

2-2-1 Design Basis

- (1) Type of Power Plant : Thermal Power Plant with Fluidized-bed Boiler
- (2) Generating Power
 - Gross Generating Power : 900 MW
 - Net Generating Power : 818 MW
 - (For Home Consumption : 82 MW)
- (3) Annual Operation Days : 320 d/y
- (4) Plant Location : Tanjung Priok
- (5) Electricity Transmission : Switchyard of Power Plant
(Note): Electricity will be sold to PLN.
- (6) Feed Coal Specification : Same to the coal for CGCC Plant
- (7) Coal Receiving : Bunker Hopper at Mine Site
- (8) Utilities

All the utilities except raw water and coal are generated inside the plant.


Drying of coal is carried out by utilizing the heat of boiler flue gas.

Cooling water for main condenser is supplied at 30°C and returned at 37°C.

2-2-2 Plant Configuration

Fig 4 shows the scope of power plant divided into five blocks each of which has its individual function.

The component facilities in each block are listed in Table 4.



* Component facilities consisting each block are listed in Table 4.

Fig. 4 Overall Block Flow diagram

Table 4 Plant Configuration

- 1) **Belt Conveyor System**
 - Primary Crusher/Feeder
 - Overland Coal Conveyor
- 2) **Coal and Limestone Handling**
 - Coal Storage and Handling
 - Coal Pretreatment
 - Limestone Storage and Handling
- 3) **Power Plant & Utility System**
 - Gas Turbine/Generator
 - Steam Turbine/Generator
 - Coal Fired Fluidized Bed Boiler
 - Power Distribution
 - Water Cooling
 - Raw Water Intake/Pretreatment
 - Instrument/Plant Air Supply
- 4) **Pollution Control/Safety System**
 - Waste Water Treatment
 - Solid Waste Disposal
 - Flare/Blowdown
 - Fire Fighting
- 5) **Service Facilities**
 - Administration Office
 - Laboratory
 - Warehouse
 - Accommodation
 - Canteen
 - Cafeteria
 - Leisure Center
 - Mosque
 - Communication System
 - Maintenance Shop
 - Potable Water Supply

2-2-3 Electricity Generation

(1) Process Flow Diagram

See Fig. 5.

(2) Process Description (Fig. 5 & Fig. 6)

- 1) The plant comprises of three trains. Each train consists of 300 MW single reheat steam turbine generator set and 3 units of fluidized bed boiler.
- 2) The fluidized bed boiler is especially suitable for burning the difficult-burn coal such as lignite with high water content and anthracite.
- 3) The feedwater is heated by 3 units of LP feedwater heaters, deaerator, and 4 units of HP feedwater heaters. The steam for heating of each feedwater is extracted from the respective steam turbine bleeding point.

(3) Major Equipment

Specifications and the number of units of major equipment are listed in Table 5.

2-5 Utility Requirement

See Table 6 and Fig. 7.

Table 6 Utility Requirement

Coal	478 t/h (external supply)
Raw Water	1,680 t/h (ditto)
Electricity	818,000 kW (outside supply)
ditto	82,000 kW (internal supply)
Cooling Water	155,000 t/h (ditto)
CaCO ₃	15 t/h





Fig. 5 Power Plant Flow Diagram (FBB)



- | | | | |
|--------------------|-------------------|------------------|--------------------|
| 1 Coal Crusher | 6 Primary Air | 11 Air Preheater | 16 FDF |
| 2 Coal Bunker | 7 Secondary Air | 12 Bag Filter | 17 Bed Ash |
| 3 Limestone Bunker | 8 Tertiary Air | 13 IDF | 18 Fly Ash |
| 4 Coal Feed | 9 Steam Generator | 14 Stack | 19 Fly Ash Recycle |
| 5 Fluidized Bed | 10 Cyclone | 15 Ash Siphon | 20 Fly Ash Silo |
| | | | 21 Bed Ash Silo |

Fig. 6 Scheme of Fluidized Bed Boiler

Table 5 Major Equipment (FBB)

Description	Q'ty	Capacity
1. Coal Handling Section		
1.1 Primary Crusher	3	200 t/h
1.2 Dewatering Drum	3	160 t/h
2. Thermal Power Plant Section		
Fluidized bed boiler	9	310 t/h
Steam turbine/generator unit	3	300 MW
Steam condenser	3	603 t/h x 700 mmHgV
Vacuum pump	3	700 mmHgV
Condensate pump	9 (3 standby)	360 m ³ /h x 200 m
Feedwater tank	3	10 m ³
HP feedwater heaters	12	928 t/h
Deaerators	3	928 t/h
LP feedwater heaters	9	702 t/h
Boiler feed pumps	9 (3 standby)	510 t/h x 198 at
Cooling tower	1	155,000 t/h
Demineralized water plant	3	35 t/h
Raw water pump	2 (1 standby)	1,900 t/h x 30m




Fig. 7 Utility Flow Diagram (FBB)

3. Financial Analysis

Financial viability and profitability of the Project was evaluated by means of financial statements* and internal rate of return (hereafter referred to as IRR) on total project investment.

- * Projected Profit and Loss Statement
- Projected Cash Flow Statement
- Projected Balance Sheet

3-1 Assumptions

(1) Electricity Generation Schedule

- 1) Net Generating Power : 835 MW (CGCC), 818 MW (FBB)
- 2) Average Load Factor : 66%
- 3) Plant Construction Period : 1990 - 1993 (4 years)
 - where 30% Completion at the end of 1990
 - 60% Completion at the end of 1991
 - 80% Completion at the end of 1992
 - 100% Completion at the end of 1993
- 4) Project Life : 1994 - 2023 (30 years)
 - where 70% of full operation in 1994
 - 85% of full operation in 1995
 - 100% of full operation in 1996 and after
- 5) Annual Operation Days : 320 days

(2) Finance

- 1) Debt/Equity Ratio : 75/25
- 2) Currency
 - For Annual Revenue/Expenditure ; Rupiah
 - For Capital Investment ; Yen
 - Exchange Rate ; 0.18 Yen/Rupiah

Accordingly, debt is repayed by exchanging Rupiah for yen at the above exchange rate.

3) Debt Repayment Schedule

Terms of 12 years after commitment, including 4 years of grace period with 8 years equal payments of principal.

4) Interest

i) Long-term Loan ; 8% per annum

Assumed supplier's credit (7.2% p.a.) plus bank loan and project risk premium.

ii) Short-term Loan ; 8% per annum

A short term loan would be raised commensurate with annual cash deficiency and would be repayed after development loan.

iii) Interest during Construction Period

In accordance with a general rule in similar projects, interest paid or accrued during construction period is capitalized and amortized over a 10-year period from 1994.

(3) Escalation

No escalation is assumed.

(4) Ex-Power Plant Price of Electricity

Supply to Jakarta:

Case E-5,7 : 43 Rp/kWh (7.76 ¥/kWh)

Case E-6,8 : 53 Rp/kWh (9.57 ¥/kWh)

Supply to Adjacent Area:

Case E-4,9 : 64 Rp/kWh (11.55 ¥/kWh)

Case E-1,10 : 78 Rp/kWh (14.08 ¥/kWh)

Note*) Ex-Power Plant Price was assumed referring to the electric rate in Indonesia as of April 1984 and estimated sales cost. Estimation of price in each case is shown in Table 7.

Table 7 Sales Price and Cost Estimation of Electricity

(Unit: Rp/kWh)

Case	Case E-5,7	Case E-6,8	Case E-4,9	Case E-1,10
Average Sales Price of PLN ①	98			
Administration and Distribution Cost of PLN	30%	20%	20%	20%
Transmission Loss	15%	15%	15%	0%
Sub-total ②	45% 44	35% 34	35% 34	20% 20
Transmission Cost to Java ③	11	11	-	-
Total ② + ③ = ④	55	45	34	20
Ex-Power Plant Price ① - ④	43	53	64	78

3-2 Capital Investment Costs

3-2-1 CGCC Plant Case

(1) Fixed-capital Investment:

	<u>10⁶ Rupiah</u>	<u>(10⁶ Yen)</u>
Coal Gasification	461,500	(83,300)
Coal Transportation	41,000	(7,400)
Power Plant/Support Facilities	304,200	(54,900)
Equipment Transportation	89,200	(16,100)
Contingency	<u>44,300</u>	<u>(8,000)</u>
Total	940,200	(169,700)

(2) Working capital 39,100 (7,058)

Note): Working capital is added as cash-inflow at the end of the project.

(3) Start-up Expense: 4,300 (777)

(4) Operator Training Cost: 2,400 (430)

Note): Table 8 shows the investment schedule.

Table 8 Investment Schedule

	1990	1991	1992	1993
Fixed Capital	30%	30%	20%	20%
Working Capital	-	-	-	100%
Start-up Expense	-	-	-	100%
Operator Training	-	-	-	100%

3-2-2 FBB Plant Case

(1) Fixed-capital Investment:

	<u>10⁶ Rupiah</u>	<u>(10⁶ Yen)</u>
Coal Transportation	39,900	(7,200)
Power Plant/Support Facilities	736,800	(133,000)
Equipment Transportation	74,200	(13,400)
Contingency	42,700	(7,700)
Total	893,600	(161,300)

(2) Working capital: 33,820 (6,105)

Note): Working capital is added as cash-inflow at the end of the project.

(3) Start-up Expense: 4,160 (750)

(4) Operator Training Cost: 2,070 (374)

Note): Investment schedule is same as the CGCC Plant Case.

3-3 Annual Expense

3-3-1 CGCC Plant Case

(1) Fixed Costs

1) Depreciation and Amortization¹⁾*

	<u>Period</u>	<u>Amount</u>	
	<u>Year</u>	<u>10⁶ Rupia/Year</u>	<u>(10⁶ Yen/Year)</u>
• Boiler, Power Plant, Cooling Tower, Buildings	15	18,986	(3,427)
• Others	10	79,900	(14,422)
2) Maintenance		21,163	(3,820)
3) Insurance		8,465	(1,528)
(2) Variable Costs			
1) Raw Material (Coal) ²⁾ *		41,285	(7,452)
2) Supervisor & Operating Labor			
• Foreign Staff ³⁾ *			
• Local Labor		2,476	(447)
3) Chemicals		404	(73)
(3) Plant Overhead Costs		9,934	(1,793)
(4) Administration Expenses		4,970	(897)

Note): 1) Capital investment for the plant construction including expenses and interests during construction period is depreciated and a amortized based on straight line method.

2) In the strategic study in FY1984, mining cost was estimated at \$13.88/ton-coal. In this study \$14.85/ton-coal is assumed as raw material costs by adding 7% to the mining cost as overhead.

3) Foreign staff decrease in number as the project proceeds. (See Table 9)

Table 9 Costs for Foreign Staff

Op. Year	1st	2nd	3rd	4th	5th	6th-30th
Year	1994	1995	1996	1997	1998	1999-2023
% on 1st year	100	70	50	30	10	0
Cost, 10 ⁶ rupiah/year	7,457	5,220	3,729	2,237	746	0
(Cost, 10 ⁶ yen/year)	(1,346)	(942)	(673)	(404)	(135)	(0)

3-3-2 FBB Plant Case

(1) Fixed Costs

1) Depreciation and Amortization¹⁾*

	<u>Period</u>	<u>Amount</u>	
	<u>Year</u>	<u>10⁶ Rupia/Year</u>	<u>(10⁶ Yen/Year)</u>
• Boiler, Power Plant, Cooling Tower, Buildings	15	49,269	(8,893)
• Others	10	29,086	(5,250)
2) Maintenance		20,388	(3,680)
3) Insurance		8,155	(1,472)

(2) Variable Costs

1) Raw Material (Coal) ²⁾ *		39,867	(7,196)
2) Supervisor & Operating Labor			
• Foreign Staff ³⁾ *			
• Local Labor		2,166	(391)
3) Chemicals		1,224	(221)
(3) Plant Overhead Costs		8,748	(1,579)
(4) Administration Expenses		4,377	(790)

Note): 1 - 3: Same as the CGCC Plant Case.

3-4 Evaluation Criteria

- 1) Financial Statement
 - a) Profit and Loss Statement
 - b) Cash Flow Statement
 - c) Balance Sheet
- 2) IRR on Total Project Cost before Tax
(For details, see the Interim Report II (FY 1985), page 218 - 219.)

3-5 Results and Evaluation

3-5-1 Results

Results of the financial analysis for CGCC Plant Case and FBB Plant Case are summarized in Tables 10 and 11 respectively. Profit and loss statements and cash flow statements for Case E-4 and E-9 are shown in Table 12 through 15.

Table 10 Results of Financial Analysis (CGCC Plant)

Case	Supply to Jakarta		Supply to Adjacent Area	
	E-5	E-6	E-4	E-1
Ex-plant Price of Electricity	43 Rp/ kWh (7.76 ¥ /kWh)	53 Rp/ kWh (9.57 ¥ /kWh)	64 Rp/ kWh (11.55 ¥ /kWh)	78 Rp/ kWh (14.08 ¥ /kWh)
IRR on Total Investment	6.9 %	10.3 %	13.5 %	17.0 %
First Year to Have Profit before Tax (Year from Operation Starts)	11th	7th	3rd	2nd
Clear off of Accumulated Loss (Year from Operation Starts)	28th	13th	5th	2nd
Pay off of All the Debts (Year from Loan Raised)	28th	15th	12th	12th
Minimum Sales Price (IRR = Interest Rate)	46 Rp/kWh (8.31 ¥/kWh)			

Table 11 Results of Financial Analysis (FBB Plant)

Case	Supply to Jakarta		Supply to Adjacent Area	
	E-7	E-8	E-9	E-10
Ex-plant Price of Electricity	43 Rp/kWh (7.76 ¥/kWh)	53 Rp/kWh (9.57 ¥/kWh)	64 Rp/kWh (11.55 ¥/kWh)	78 Rp/kWh (14.08 ¥/kWh)
IRR on total Investment	7.4 %	10.8 %	14.0 %	17.5 %
First Year to Have Profit before Tax (Year from Operation Starts)	11th	4th	2nd	1st
Clean off of Accumulated Loss (Year from Operation Starts)	24th	9th	3rd	1st
Pay off of All the Debts (Year from Loan Raised)	23th	14th	12th	12th
Minimum Sales Price (IRR = Interest Rate)	44.7 Rp/kWh (8.08 ¥/kWh)			

3-5-2 Evaluation

As for economic comparison for power generation, generating system by fluidized-bed coal-fired steam cycle is slightly superior to that by CGCC though the difference in IRR between two systems is narrow.

Table 12 Profit and Loss Statement of Case E-4

(Unit: 10⁶ Rupiah)

Year	OP Year	REVENUE	EXPENDITURE				Total	Before Tax	PROFIT		Retained Earning
			Variable Cost	Fixed Cost	General	Interest Paid			(Tax)	Net Profit	
1994	1	189.6	39.1	128.5	14.9	65.8	248.3	- 58.7	0	- 58.7	- 58.7
1995	2	230.3	43.1			60.9	247.4	- 17.2	0	- 17.2	- 75.8
1996	3	270.9	47.9			52.6	243.9	27.0	0	27.0	- 48.8
1997	4		46.4			42.0	231.8	39.1	0	39.1	- 9.7
1998	5		44.9			31.3	219.6	51.3	18.1	32.2	22.5
1999	6		44.2			21.4	209.0	61.9	28.5	33.4	55.9
2000	7					12.6	200.2	70.7	32.5	38.2	94.1
2001	8					4.2	191.8	79.1	36.4	42.7	136.8
2002	9					0	187.6	83.3	38.3	45.0	181.8
2003	10						187.6	83.3	38.3	45.0	226.8
2004	11					128.5	107.7	163.2	75.1	88.1	314.9
2005	12					48.6	107.7	163.2	75.1	88.1	403.1
2006	13						107.7	163.2	75.1	88.1	491.2
2007	14						107.7	163.2	75.1	88.1	579.3
2008	15					48.6	107.7	163.2	75.1	88.1	667.5
2009	16					29.6	88.7	182.2	83.8	98.4	755.9
2010	17										864.3
2011	18										962.7
2012	19										1,061.1
2013	20										1,159.5
2014	21										1,257.9
2015	22										1,356.3
2016	23										1,454.6
2017	24										1,553.0
2018	25										1,651.4
2019	26										1,749.8
2020	27										1,848.2
2021	28										1,946.6
2022	29										2,045.0
2023	30	270.9	44.2	29.6	14.9	0	88.7	182.2	83.8	98.4	2,143.4
Total		8,005.5	1,325.6	1,972.7	447.1	290.8	4,036.2	3,969.3	1,825.9	2,143.4	

Table 13 Cash Flow Statement of Case E-4

(Unit: 10⁹ Rupiah)

Year	OP Year	INVESTMENT	Profit Before TAX	Depreciation/ Amortization	Interest Paid	CASH FLOW	DCF (Base; 1985)
1990		- 282.1	-	-	-	- 282.1	- 150.0
1991		- 282.1	-	-	-	- 282.1	- 132.2
1992		- 188.0	-	-	-	- 188.0	- 77.7
1993		- 233.8	-	-	-	- 233.8	- 85.2
1994	1	-	- 58.7	98.9	65.8	106.0	34.0
1995	2	-	- 17.2		60.9	142.6	40.4
1996	3	-	27.0		52.6	178.5	44.5
1997	4	-	39.1		42.0	180.0	39.6
1998	5	-	51.3		31.3	181.5	35.2
1999	6	-	61.9		21.4	182.2	31.1
2000	7	-	70.7		12.6		27.4
2001	8	-	79.1		4.2		24.2
2002	9	-	83.3		0		21.3
2003	10	-	83.3	98.9			18.8
2004	11	-	163.2	19.0			16.6
2005	12	-	163.2				14.6
2006	13	-	163.2				12.9
2007	14	-	163.2				11.3
2008	15	-	163.2	19.0			10.0
2009	16	-	182.2	0			8.8
2010	17	-					7.8
2011	18	-					6.8
2012	19	-					6.0
2013	20	-					5.3
2014	21	-					4.7
2015	22	-					4.1
2016	23	-					3.6
2017	24	-					3.2
2018	25	-					2.8
2019	26	-					2.5
2020	27	-					2.2
2021	28	-					1.9
2022	29	-				182.2	1.7
2023	30	-	182.2	0	0	221.3	1.8
	Total	- 986.0	3,969.3	1,083.8	290.8	4,397.0	0

Table 14 Profit and Loss Statement of Case E-9

(Unit: 10⁹ Rupiah)

Year	OP Year	Revenue	Expenditure				Total	Before Tax	Profit		Retained Earning
			Variable Cost	Fixed Cost	General	Interest Paid			(Tax)	Net Profit	
1994	1	185.7	37.5	106.9	13.1	62.0	219.6	-33.8	0	-33.8	-33.8
1995	2	225.5	41.7	106.9	13.1	56.8	218.6	7.0	0	7.0	-26.9
1996	3	265.3	46.5	106.9	13.1	48.7	215.3	50.0	10.7	39.4	12.5
1997	4	265.3	45.2	106.9	13.1	39.6	204.8	60.5	27.8	32.7	45.2
1998	5	265.3	43.9	106.9	13.1	30.5	194.4	70.9	32.6	38.3	83.5
1999	6	265.3	43.3	106.9	13.1	20.9	184.2	81.1	37.3	43.8	127.3
2000	7	265.3	43.3	106.9	13.1	12.0	175.3	90.1	41.4	48.6	175.9
2001	8	265.3	43.3	106.9	13.1	4.0	167.3	98.1	45.1	53.0	228.9
2002	9	265.3	43.3	106.9	13.1	0	163.3	102.1	47.0	55.1	284.0
2003	10	265.3	43.3	106.9	13.1	0	163.3	102.1	47.0	55.1	339.1
2004	11	265.3	43.3	77.8	13.1	0	134.2	131.1	60.3	70.8	409.9
2005	12	265.3	43.3	77.8	13.1	0	134.2	131.1	60.3	70.8	480.8
2006	13	265.3	43.3	77.8	13.1	0	134.2	131.1	60.3	70.8	551.6
2007	14	265.3	43.3	77.8	13.1	0	134.2	131.1	60.3	70.8	622.4
2008	15	265.3	43.3	77.8	13.1	0	134.2	131.1	60.3	70.8	693.2
2009	16	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	790.7
2010	17	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	888.1
2011	18	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	985.5
2012	19	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,082.9
2013	20	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,180.4
2014	21	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,277.8
2015	22	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,375.2
2016	23	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,472.7
2017	24	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,570.1
2018	25	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,667.5
2019	26	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,764.9
2020	27	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,862.4
2021	28	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	1,959.8
2022	29	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	2,057.2
2023	30	265.3	43.3	28.5	13.1	0	84.9	180.4	83.0	97.4	2,154.6
Total		7,840.9	1,296.4	1,886.2	393.7	274.6	3,850.8	3,990.1	1,835.5	2,154.6	

Table 15 Cash Flow Statement of Case E-9

(Unit: 10⁹ Rupiah)


Year	OP Year	Investment	Profit Before Tax	Depreciation/ Amortization	Interest Paid	Cash Flow	DCF (Base; 1985)
1990		-268.1	-	-	-	-268.1	-139.4
1991		-268.1	-	-	-	-268.1	-122.3
1992		-178.7	-	-	-	-178.7	-71.5
1993		-218.8	-	-	-	-218.8	-76.8
1994	1	-	-33.8	78.4	62.0	106.6	32.8
1995	2	-	7.0	78.4	56.8	142.2	38.4
1996	3	-	50.0	78.4	48.7	177.1	42.0
1997	4	-	60.5	78.4	39.6	178.4	37.1
1998	5	-	70.9	78.4	30.5	179.8	32.8
1999	6	-	81.1	78.4	20.9	180.4	28.9
2000	7	-	90.1	78.4	12.0	180.4	25.3
2001	8	-	98.1	78.4	4.0	180.4	22.2
2002	9	-	102.1	78.4	0	180.4	19.5
2003	10	-	102.1	78.4	0	180.4	17.1
2004	11	-	131.1	49.3	0	180.4	15.0
2005	12	-	131.1	49.3	0	180.4	13.2
2006	13	-	131.1	49.3	0	180.4	11.6
2007	14	-	131.1	49.3	0	180.4	10.1
2008	15	-	131.1	49.3	0	180.4	8.9
2009	16	-	180.4	0	0	180.4	7.8
2010	17	-	180.4	0	0	180.4	6.8
2011	18	-	180.4	0	0	180.4	6.0
2012	19	-	180.4	0	0	180.4	5.3
2013	20	-	180.4	0	0	180.4	4.6
2014	21	-	180.4	0	0	180.4	4.1
2015	22	-	180.4	0	0	180.4	3.6
2016	23	-	180.4	0	0	180.4	3.1
2017	24	-	180.4	0	0	180.4	2.7
2018	25	-	180.4	0	0	180.4	2.4
2019	26	-	180.4	0	0	180.4	2.1
2020	27	-	180.4	0	0	180.4	1.9
2021	28	-	180.4	0	0	180.4	1.6
2022	29	-	180.4	0	0	180.4	1.4
2023	30	-	180.4	0	0	214.2	1.5
	Total	-933.7	3,990.1	1,029.9	274.6	4,394.7	0

ATTACHMENT 11-1

1. Figures for Conceptual Design of On-site Facilities
2. Equipment List (Gasification Plant)


1. Figures for Conceptual Design of On-site Facilities

- Fig. 11-1-4 Banko Coal Gasification Plant, Top View of Gasifier Building
- Fig. 11-1-6 Banko Coal Gasification Plant, Cross Section Vies of Gasifier Building (Section B-B)
- Fig. 11-1-7 Banko Coal Gasification Plant, Layout of Electric Room
- Fig. 11-1-8 Banko Coal Gasification Plant, Single Line Diagram
- Fig. 11-1-9 Banko Coal Gasification Plant, Piping and Instrumentation Diagram
- Fig. 11-1-10 Banko Coal Gasification Plant, Process Building (Elevation)
- Fig. 11-1-34 Administration Office
- Fig. 11-1-35 Dining Building
- Fig. 11-1-35 Dining Building
- Fig. 11-1-37 Gate House
- Fig. 11-1-38 Maintenance Office
- Fig. 11-1-39 Warehouse & Workshop (Mechanical)
- Fig. 11-1-40 Warehouse & Workshop (Electrical & Instrument)





COMPUTER AIDED DESIGN

DATE Oct. 1988	MANAGER OF DEP. <i>S. Imai</i>	Banko Coal Gasification Plant	WORK NO P3066
SCALE 1:300	MANAGER <i>S. Imai</i>	Top View Of Gasifier Building	DRAWING NO Fig. 11-1-4
	CHECKED BY <i>H. Kusaka</i>	JAPAN INTERNATIONAL COOPERATION AGENCY	
	DRAWN BY <i>Y. J.</i>		



∇ GL+59000
 ∇ GL+50000
 ∇ GL+45000
 ∇ GL+40000
 ∇ GL+35000
 ∇ GL+30000
 ∇ GL+25000
 ∇ GL+20000
 ∇ GL+15000
 ∇ GL+10000
 ∇ GL+ 8000
 ∇ GL±0




Key Plan

Area of Plant


SECTION B-B

COMPUTER AIDED DESIGN

DATE Oct. 1988	MANAGER OF DEP. <i>[Signature]</i>	Banko Coal Gasification Plant	WORK NO P3066
SCALE 1:300	MANAGER <i>[Signature]</i>	Cross Section View Of Gasifier Building (Section B-B)	DRAWING NO Fig. 11-1-6
	CHECKER BY <i>[Signature]</i>	JAPAN INTERNATIONAL COOPERATION AGENCY	
	DRAWN BY <i>[Signature]</i>		




DATE	MANAGER OF DEP.	BANKO COAL GASIFICATION PLANT	WORK NO.
Oct. 1988	<i>G. Saito</i>		P3066
SCALE	CHIEF	LAYOUT OF ELECTRIC ROOM	DRAWING NO.
1:150	<i>K. Morita</i>		FIG. 11-1-7
	CHECKED BY	JAPAN INTERNATIONAL COOPERATION AGENCY	
	<i>T. Takasaki</i>		
	DRAWN BY		
	<i>T. E. J. Kuroki</i>		






EXPLANATORY NOTES


TR:Transformer
 DS:Disconnection Switch
 CB:Circuit Breaker
 CT:Current Transformer
 PF:Power Fuse
 HMctt:High Speed Magnetic Contactor
 ZCT:Zero Current Transformer
 ELB:Earth Leakage Breaker
 GPT:Ground Potential Transformer
 MCB:Motor Circuit Breaker
 LBS:Load Breaker Switch
 VVF:Variable Voltage Variable Frequency Device


DATE	MANAGER OF DEP.	BANKO COAL GASIFICATION PLANT	WORK NO.
Oct. 1988	<i>[Signature]</i>		P3066
SCALE	CHIEF	SINGLE LINE DIAGRAM	DRAWING NO.
	<i>[Signature]</i>		Fig. 11-1-8
CHECKED BY		JAPAN INTERNATIONAL COOPERATION AGENCY	
DRAWN BY			
















DATE
Oct. 19
SCALE




COMPUTER AIDED DESIGN

DATE Oct. 1988	MANAGER OF DEP. <i>Y. Iwano</i>	Banko Coal Gasification Plant	WORK NO P3066
SCALE	MANAGER <i>T. Hatada</i>	Piping And Instrumentation Diagram	DRAWING NO Fig. 11-1-9
	CHECKED BY <i>P. Yamamoto</i>	JAPAN INTERNATIONAL COOPERATION AGENCY	
	DRAWN BY <i>J.Y.</i>		




ELEVATION "A"


ELEVATION "C"



ELEVATION "B"




ELEVATION "D"




REVISION		DATE	MANAGER OF DEP.	WORK NO.
NO	DATE			

SCALE	MANAGER	Banko Coal Gasification Plant	P 3066
1/500	<i>Ameyama</i>	Process Building (Elevation)	DRAWING NO
CHECKED BY	<i>J. Brode</i>	JAPAN INTERNATIONAL CORPORATION AGENCY	FIG-11-1-10
DRAWN BY			




1ST FLOOR PLAN SCALE 1:200




2ND FLOOR PLAN SCALE 1:200

JAPAN INTERNATIONAL COOPERATION AGENCY
Fig. 11-1-34 Administration Office




1ST FLOOR PLAN SCALE 1:200




ELEVATION SCALE 1:200


JAPAN INTERNATIONAL COOPERATION AGENCY
 Fig. 11-1-35 Dining Building



1ST FLOOR PLAN SCALE 1:200




2ND FLOOR PLAN SCALE 1:200




FLOOR PLAN SCALE 1:200

JAPAN INTERNATIONAL COOPERATION AGENCY
 Fig. 11-1-36 Gate House


2. Equipment List (Gasification Plant)



1ST FLOOR PLAN SCALE 1:200




2ND FLOOR PLAN SCALE 1:200




ELEVATION SCALE 1:200


JAPAN INTERNATIONAL COOPERATION AGENCY
 Fig. 11-1-37 Laboratory



FLOOR PLAN SCALE 1:200




FLOOR PLAN SCALE 1:200




FLOOR PLAN SCALE 1:200


JAPAN INTERNATIONAL COOPERATION AGENCY
 Fig. 11-1-38 Maintenance Office




1ST FLOOR PLAN SCALE 1:300



2ND FLOOR PLAN SCALE 1:300




ELEVATION SCALE 1:300




ELEVATION SCALE 1:300


JAPAN INTERNATIONAL COOPERATION AGENCY
 Fig. 11-1-39 Warehouse & Workshop (Mechanical)



FLOOR PLAN SCALE 1:200



ELEVATION SCALE 1:200



ELEVATION SCALE 1:200

JAPAN INTERNATIONAL COOPERATION AGENCY
 Fig. 11-1-40 Warehouse & Workshop (Electrical & Instrument)

PROJECT BANKO PROJECT
TITLE COAL DEWATERING EQUIPMENT

EQUIPMENT LIST (Gasification Plant)

EQUIPMENT ITEM NUMBER	SERVICE	No REQD	TYPE	SPECIFICATION	WEIGHT (ton)			DESIGN		REMARKS
					EREC	TEST	OPN	PRESS Kg/cm ²	TEMP °C	
1-1	No.1 Belt Feeder	2	Belt Conveyor	Belt Width : 1,800 Capacity : 290 t/hr Motor	62 \$			0	50	Out of supply
1-2	Magnetic Separator	2	Magnet Type	Capacity : 290 t/hr Magnet : 11.7 KW (DC) Motor (Traverse) : 5 KW	7.4 \$			0	50	
1-3	Bucket Elevator	2	Belt Type	Capacity : 290 t/hr Motor : 50 KW	90 \$			0	100	
1-4	Coal Hopper	2	Cylindrical Cone Type Steel Plate	14,500 ø x 25,200 H (Cylinder Height 13,000 H) Cone Height 12,200 H Volume : 2,820 m ³	214 \$			0	80	
1-5	Coal Feeder	2	Closed Type Chain Feeder	Capacity : 240 t/hr Motor : 25 KW	12 \$			0	80	
1-6	Primary Crusher	2	Hammer Mill	Capacity : 240 t/hr Grain Size : 40 m/m → 2-3 m/m Motor : 400 KW	216 \$			0	100	

PROJECT BANKO PROJECT
TITLE COAL DEWATERING EQUIPMENT

EQUIPMENT LIST (Gasification Plant)

EQUIPMENT ITEM NUMBER	SERVICE	No REQD	TYPE	SPECIFICATION	WEIGHT (ton)			DESIGN		REMARKS
					EREC	TEST	OPN	PRESS Kg/cm ²	TEMP °C	
1-7	No.2 Belt Feeder	2	Belt Conveyor	Belt Width : 900 mm Capacity : 240 t/hr Motor : 80 KW	140			0	50	
1-8	Dewatering Drum	2	Steam Tube Dryer	Capacity : 240 t/hr Water Content : 23.1% → 15% Motor : 490 KW	4200			5	200	
1-9	Dust Collector	2	Suction Type Bag Filter	7400 W x 26.3m L x 19m H Capacity : 6,300 m ³ /min With Discharge Feeder Motor : 2.2 KW x 8	370			0	100	
1-10	Dust Collector Exhaust Fan	2	Single Suction Turbo Type	Capacity : 6,300 m ³ /min Pressure Head : 450 mm Aq Motor : 1,000 KW	51			0.2	80	
1-11	Exhaust Stack	2	Steel Plate	3,000 ø x 10,000	14			0	80	

PROJECT BANKO PROJECT
TITLE COAL PULVERIZER AND DRYING EQUIPMENT

EQUIPMENT LIST (Gasification Plant)

EQUIPMENT ITEM NUMBER	SERVICE	No REQD	TYPE	SPECIFICATION	WEIGHT (ton)			DESIGN		REMARKS
					EREC	TEST	OPN	PRESS Kg/cm ²	TEMP °C	
2-1	Coal Feeder	2	Closed Type Chain Feeder	Capacity : 220 t/hr Motor : 140 KW	140			0	80	
2-2	Distributor	2	Dumper Adjust	Square Dumper Distributor Approximate Dimension 5m x 5m x 5m	17.8			0	80	
2-3	Coal Feeder	2	Closed Type Chain Feeder	Capacity : 150 t/hr x 30m Motor : 15 KW	65			0	80	
2-4	Coal Pulverizer	2	Vertical Roller Mill	7,000 W x 7,000 L x 12,200 H Capacity : 150 t/hr Product Particle Size : 74 μm X 70% Up Product Water Content : 10% under Motor : 1,600 KW	450			0.1	300	
2-5	Pulverized Coal Collector	2	Suction Type Bag Filter	14.8m W x 26.3m L x 19m H Capacity : 600,000 m ³ /hr With Discharge Feeder	1000			0.1	120	
2-6	Exhaust Fan	2	Single Suction Turbo Type	Capacity : 10,000 m ³ /min Pressure Head : 500 mm Aq Motor : 1,700 KW	56			0.2	80	
2-7	Exhaust Stack	2	Steel Plate	4,000 φ X 10,000	19			0	80	
2-8	Belt Conveyor	2	Belt Type	Capacity : 150 S/hr Motor : 80 KW	15			0	80	

PROJECT BANKO PROJECT
TITLE COAL PULVERIZER AND DRYING EQUIPMENT

EQUIPMENT LIST (Gasification Plant)

EQUIPMENT ITEM NUMBER	SERVICE	No REQD	TYPE	SPECIFICATION	WEIGHT (ton)			DESIGN		REMARKS
					EREC	TEST	OPN	PRESS Kg/cm ²	TEMP °C	
2-9	Bucket Elevator	2	Belt Type	Capacity : 150 t/hr Motor : 80 KW	40			0	80	
2-10	No.1 Pulverized Coal Surge Hopper	2	Steel Plate Cylindrical Type	6,000 ϕ x 10,900 H (Cylindrical Height 5.7m) Conical Height 5.2m Volume : 210 m ³	13.5			0	80	
2-11	Pulverized Coal Feed Tank	2	Steel Plate Pressure Vessel	6,000 ϕ x 10,900 H (Cylindrical Height 5.7m) Cone Height 5.2m Volume : 210 m ³	54.3			5	80	
2-12	Pulverized Coal Discharge Feeder	2	Rotary Feeder	Capacity : 210 t/hr Motor : 10 KW Speed Reducer : 25 rpm	0.6			5	80	
2-50	Pulverized Coal Discharge Feeder	2	Rotary Feeder	Capacity : 0.61 t/hr Motor : 0.2 KW	0.1			5	50	
2-51	Pulverized Coal Collector	1	Suction Type Bag Filter	Capacity : 6,000 Nm ³ /hr Discharge Feeder Motor : 0.4 KW x 2 Unit	35			0.1	50	
2-52	Exhaust Fan	1	Single Suction Turbo Type	Capacity : 6,000 Nm ³ /hr Pressure Head : 500 mm Aq Motor : 22 KW	0.4			0.1	50	
2-53	Pulverized Coal Conveyor	1	Snake Conveyor	Capacity : 1.4 m^3 /hr Motor : 0.75 KW	5.8			0.1	50	