

estate and large factory are determined individually at their respective locations.

Location, wastewater discharge and pollution load generation of each housing estate and large factory are given in Data Book.

The regional distributions of total wastewater discharge in 1986 and 2000 are shown in Fig. C.10. The regional distribution of total pollution load generation in 1986 and 2000 are shown in Fig. C.11.

5. Pollution Load Runoff

5.1 Pollution Load Runoff Coefficient

The pollution load runoff coefficient is defined as the ratio of the pollution load entering the klongs to the pollution load generated at the sources.

The JICA Study Team made pollution load runoff observations at seven (7) sites for a continuous 24 hour period. The observation sites were selected from various land use pattern areas.

Suriwong Rd, Krung Kasem Rd, and Sukhumvit Rd Soi 40 were selected as representative residential and commercial areas. As the representative high density residential area, Pathumwan was selected.

Siam Jasco, Wipawadi Rangsit 1 and Wipawadi Rangsit 2 were selected as the representative low density residential areas.

Observation dates of pollution load runoff survey are shown in Table C.18.

The outline of the observation sites are listed in Table C.19. The locations of the sites are shown in Fig. C.12. The pollution load runoff coefficients determined are shown in Tables C.20 and C.21, respectively for BOD and SS.

5.2 Pollution Load Runoff in the Study Area

The pollution load runoff coefficient in the Study Area was determined based on the following consideration: The weighted average hourly pollution load runoff coefficient at each survey site that was obtained from the field surveys was used as the pollution load runoff coefficient of the area.

For the evaluation of the pollution load runoff coefficient, the following parameters must be taken into consideration:

- (a) Discharge: In general, when discharge becomes large, velocity becomes high. As a result, sedimentation of pollutant decreases and the pollution load runoff coefficient tends to increase.
- (b) Catchment area: If a catchment area is large, it requires longer time to wash down the pollutant and the pollution load runoff coefficient tends to decrease.
- (c) Urban development: If sewerage and drainage ditches are improved, the sewage runoff and drainage become easier. Thus, the pollution load runoff coefficient tends to increase.

Considering the above-mentioned characteristics, the pollution load run-off coefficient of an area is estimated with respect to the specific discharge of the area ($\text{m}^3/\text{day}/\text{km}^2$).

Since the specific discharge of an area consists of sewage and rainfall, it was considered that the difference in the pollution load runoff coefficient during dry and rainy seasons will be reflected by the difference in specific discharge.

As for urbanization, a well developed area produces a large amount of sewage and drainage. Since such an area has a well developed drainage pipe system, it can be considered that the area's pollution load runoff coefficient is high.

Based on the above considerations, the relationship between the specific discharge and BOD runoff coefficient was obtained as follows (see Fig. C.13).

$$y = 1.625x + 37.6 \quad (\gamma = 0.734)$$

where, y: runoff coefficient
 x: specific discharge
 γ : correlation coefficient

The BOD run-off coefficients for the Study are assumed to be constant average values based on the range of specific discharge, as an approximation to the above formula, and is illustrated in Fig. C.13.

Specific Discharge ($10^3 \text{ m}^3/\text{day}/\text{km}^2$)	BOD Runoff Coefficient (%)
0 - 10	50
10 - 20	60
20 - 30	80
> 30	90

The runoff coefficient of SS was also determined as shown in Fig. C.13.

Table C.1 Population Growth in BMA and Whole Thailand

Year	Population in BMA	Population in Whole Country
1978	4,870,509	10,121,921
1979	4,999,515	10,388,095
1980	5,153,903	10,585,050
1981	5,331,402	10,856,057
1982	5,468,286	11,122,666
1983	5,018,327	10,797,324
1984	5,174,682	11,067,125
1985	5,363,378	11,423,946
1986	5,468,915	11,670,900

Source : National Statistical Office.

Table C.2 Current Population and Population Density in Each District of the Study Area

District Name	Population (1986 Year)	Area (km ²)	Population Density (person/ha)
Phra Nakhon	111,875	5.54	202
Pom Prab Sattru Pai	87,955	1.93	455
Sampan Thawong	51,121	1.42	360
Pathumwan	143,199	8.37	171
Phya Thai	359,604	21.11	170
Huai Khwang	255,774	9.50	269
Phra Khanong	629,386	143.56	44
Bang Kapi	409,785	158.78	26
Bang Khen	548,078	169.31	36
Bang Rak	90,672	5.54	164
Dusit	562,990	22.21	253
Yan Nawa	415,703	36.91	133
Total	3,666,142	584.18	63

Ref: Bangkok 1986
 Statistical Profile of the Bangkok Metropolitan Administration
 Department of Policy and Planning

Table C.3 Land Use in 1980

Unit: km²

Land Use Classification	City Core Area	Eastern Suburbans	Total
Residential	37	97	134
Commercial	10	6	16
Industrial	3	3	6
Institution	15	22	37
Park, Sport, Ground, etc.	5	6	11
Agricultural and Open Space	27	149	176
Total	97	283	380

- Ref: (1) Flood Protection/Drainage Project in Eastern Suburban Bangkok
 JAPAN INTERNATIONAL COOPERATION AGENCY
 (2) Bangkok Flood Control and Drainage Project (City Core)
 NEDECO

Table C.4 Present and Future District Population in the Study Area

	Present Population (1986)	Future Population (2000)
Phra Nakhon	111,875	112,000
Pom Prab Sattru Pai	87,955	88,000
Sampanthawong	51,121	51,000
Pathumwan	143,199	143,000
Phya Thai	359,604	360,000
Huai Khwang	255,774	359,000
Phra Khanong	629,386	840,000
Bang Kapi	409,785	710,000
Bang Khen	548,078	809,000
Bang Rak	90,672	91,000
Dusit	562,990	772,000
Yan Nawa	415,703	416,000
Total	3,666,142	4,751,000

Table C.5 Future Land Use (2000)

Land Use Classification	City Core Area (km ²)	Eastern Suburbs Area (km ²)	Total Area (km ²)
Residential	37	185	222
Commercial	10	14	24
Industrial	3	3	6
Institutional	15	-	15
Park, Sport Ground etc.	5	14	19
Agricultural & Open Space	27	67	94
Total	97	283	380

Table C.6 Existing Water Supply by MWA (1986)

Service Area	Supply Connection	Supply Population	Daily Water Supply (m ³ /d) 1)			Per Capita Water Supply (lcd) 1)				
			Residential	Government	Comm-Ent.	Total	Residential	Government	Comm-Ent.	
Nonthaburi	66,613	339,726	79,018	155	22,485	101,658	233	0.5	66	330
Bang Khen	47,322	241,342	57,557	8	17,451	75,016	238	-	72	310
Phya Thai	56,188	398,934	93,816	497	42,784	137,097	235	1.2	107	343
Thung Mahamek	35,071	206,919	50,498	119	37,502	88,119	244	0.6	181	426
Man Sri	37,976	265,832	74,048	30	129,183	203,261	279	0.1	486	765
Phra Khanong	39,936	207,667	77,868	109	46,708	124,685	375	0.5	225	601
Samut Prakarn	36,891	177,077	50,082	87	18,221	68,390	283	0.5	103	387
Total	319,997	1,837,497	482,887	1,005	314,334	798,226	263	0.5	171	435

1) Include Unaccounted Water

Table C.7 Existing Unit Water Consumption (1986)

(Unit: lcd)

Service Area	Residential	Government	Commercial & Enterprise	Total
Nonthaburi	137	0.3	39	176
Bang Khen	140	-	42	182
Phya Thai	139	0.7	63	203
Thung Mahamek	144	0.4	107	251
Man Sri	165	-	287	452
Phra Khanong	221	0.3	133	354
Samut Prakarn	167	0.3	61	228

Table C.8 Served Population Ratio of Water Supply System

Service Area	a. Served Population	b. Total Population	Service Ratio (a/b)
Thung Mahamek	206,919	415,703	50%
Man Sri Phya Thai	664,765	1,559,550	43%
Bang Khen Phra Khanong	449,009	1,299,026	35%
Total	1,320,693	3,274,279	40%

Table C.9 Existing Unit Water Consumption of Total Water Sources

(Unit: lcd)

District	Category	Water Supply		Groundwater		Water Supply + Groundwater
		(lcd)	Ratio ¹⁾	(lcd)	Ratio ¹⁾	
Dusit Phra Nakhon Pom Prab Sattru Pai Sampanthawong Pathumwan Bang Rak	Residen.	165	(43%)	152	(57%)	158
	Commer.	287		264		274
	Total	452		416		432
Phya Thai Huai Khwang	Residen.	139	(43%)	128	(57%)	133
	Commer.	64		59		61
	Total	203		187		194
Phra Khanong	Residen.	221	(35%)	203	(65%)	209
	Commer.	133		122		126
	Total	354		325		335
Bang Kapi Bang Khen	Residen.	140	(35%)	129	(65%)	133
	Commer.	42		39		40
	Total	182		169		173
Yan Nawa	Residen.	144	(50%)	132	(50%)	138
	Commer.	107		98		103
	Total	251		230		241

1) Ratio of served population

Residen.: Residential

Comemr.: Government + Commercial/Enterprise

Table C.10 Present and Future Unit Water Consumption

Unit: lcd

Districts	Category	Present	Future
Dusit Phra Nakhon Pom Prab Sattru Pai Sampanthawong Pathumwan Bang Rak	Residen.	158	215
	Commer.	274	297
	Total	432	512
Phya Thai Huai Khwang	Residen.	133	215
	Commer.	61	146
	Total	194	361
Phra Khanong	Residen.	209	21
	Commer.	126	146
	Total	335	367
Bang Kapi Bang Khen	Residen.	133	215
	Commer.	40	146
	Total	173	361
Yan Nawa	Residen.	138	215
	Commer.	103	146
	Total	241	361

Residen.: Residential

Commer.: Government+Commercial/Enterprise

Table C.11 Present and Future Water Consumption in the Study Area

(Unit: m³ /day)

District	Present (Year 1986)						Future (Year 2000)						
	Population		Residential		Commercial & Others		Total	Popula- tion	Residential		Commercial & Others		Total
			led	Consump- tion	led	Consump- tion			led	Consump- tion	led	Consump- tion	
Phra Nakhon	111,875	158	17,676	274	30,654	48,330	112,000	215	24,080	297	33,264	57,344	
Pom Prab Sauru Pai	87,955	158	13,897	274	24,100	37,997	88,000	215	18,920	297	26,136	45,056	
Sampanthawong	51,121	158	8,077	274	14,007	22,084	51,000	215	10,965	297	15,147	26,112	
Pathumwan	143,199	158	22,625	274	39,237	61,862	143,000	215	30,745	297	42,471	73,216	
Phya Thai	359,604	133	47,827	61	21,936	69,763	360,000	215	77,400	146	52,560	129,960	
Huai Khwang	255,774	133	34,018	61	15,602	49,620	359,000	215	77,185	146	52,414	129,599	
Phra Khanong	629,386	209	131,542	126	79,303	210,845	840,000	221	185,640	146	122,640	308,280	
Bang Kapi	409,785	133	54,501	40	16,391	70,892	710,000	215	152,650	146	103,660	256,310	
Bang Khen	548,078	133	72,894	40	21,923	94,817	809,000	215	173,935	146	118,114	292,049	
Bang Rak	90,672	158	14,326	274	24,844	39,170	91,000	215	19,565	297	27,027	46,592	
Dusit	562,990	158	88,952	274	154,259	243,211	772,000	215	165,980	297	229,284	395,264	
Yan Nawa	415,703	138	57,367	103	42,817	100,184	416,000	215	89,440	146	60,736	150,176	
Total	3,666,142	154	563,702	132	485,073	1,048,775	4,751,000	216	1,026,505	186	883,453	1,909,958	

Table C.12 Unit Pollution Load in Previous Studies

Agency	Year	Pollution Load (BOD-gcd)	Wastewater (lcd)	Remarks
JICA/L	1981	61	234	Residential 48 gcd Commercial 13 gcd
WHO	1980	54	-	
STRIT	1980	20	138	Science and Technical Research, Institute of Thailand
MR. THONGCHAI	1979	35	390	Mr. Thongchai Pansawad
AIT	1978	45	-	
NEB	1987	48	-	Sanitary Engineering Dept., Faculty of Engineering Chulalongkorn Univ.

Source: National Seminar
Technology of Water & Wastewater, March 1988

Table C.13 Unit Pollution Load in Previous Studies (STRIT Study)

Observation Site	Number of Household	Person per Household	Population	Flow		BOD ₅		COD _{cr}	
				m ³ /d	lcd	mg/l	gcd	mg/l	gcd
Din Daeng 3-1	330	4.14	1,366	272.3	199.4	118.5	23.6	226.2	45.1
Din Daeng 3-3	330	4.14	1,366	260.0	190.4	106.9	20.4	223.0	42.5
Bang Buo	1,214	3.95	4,796	476.5	99.4	184.7	18.4	310.9	30.9
Bang Na	1,654	3.12	5,167	602.0	116.5	152.8	17.8	235.1	27.4
Bon Kai	308	4.16	1,282	208.4	162.6	124.6	20.3	275.9	44.9
Huai Khwang	3,360	5.15	17,304	2698.4	155.9	114.3	17.8	222.6	34.7

Ref.: Thailand Institute of Science and Technical Research
 "Project Study for Evaluation of Waste Water Treatment
 of the National Housing Authority"
 Bangkok, 1980

Table C.14 Survey Results of Unit Pollution Load Generation from Resident

Site	Date	Flow (m ³ /d)	Quality (mg/l)			Pollution Load (kg/d)			Popula- tion	Per Capita Flow (l/cd)	Per Capita Pollution Load (gcd)		
			BOD	COD	SS	BOD	COD	SS			BOD	COD	SS
Din Daeng	Feb. 24-25	267	99	273	91	26.4	73.0	24.2	1320	202	20.0	55.3	18.3
Din Daeng	Jul. 21-22	175	80	187	77	14.0	32.7	13.5	1320	133	10.6	24.8	10.2
Din Daeng	Sep. 7-8	190	132	308	120	25.0	58.6	22.8	1320	144	18.9	44.4	17.3
Bon Kai	Aug. 10-11	266	109	192	98	28.9	51.0	26.1	1900	140	15.2	26.8	13.7
Bon Kai	Sep. 7-8	315	220	385	154	69.5	121.5	48.5	1900	165	36.6	63.9	25.5
Total	-	1213	*128	*269	*108	163.8	336.8	135.1	7760	*157	*20.3	*43.0	*17.0

* Average

Table C.15 Survey Results of Unit Pollution Load Generation from Commercial Enterprise

Name	Flow m ³ /d	Water Quality (mg/l)			Pollution Load (kg/d)		
		BOD	COD	SS	BOD	COD	SS
Suriwong Rd.	5108	74	137	30	375.6	698.0	153.4
Silom Rd.	15064	60	115	75	905.5	1725.3	1134.6
Siam Square	-	305	457	133	-	-	-
Average	-	146	236	79	-	-	-

Table C.16 Pollution Load of Commercial Wastewater

Item	Wastewater (Ratio)	Quality (mg/l)		
		BOD	COD	SS
Restaurant	31,000 m ³ /d (33%)	305 ²⁾	457 ²⁾	133 ²⁾
Other 1)	63,000 m ³ /d (67%)	67 ³⁾	126 ³⁾	53 ³⁾
Average	94,000 m ³ /d (100%) *	145	235	80

- 1) Hotel, Theater, Market, Department Store, Office, Hospital, etc.
- 2) Quality of Wastewater: Siam Square
- 3) Quality of Wastewater: Average of Suriwong Rd. and Silom Rd.

* : Total

Table C.17 (1) Present and Future Estimated Unit Pollution Load Generation (BOD)

Districts	Item	Present (1986 Year)			Future (2000 Year)			Remarks
		Residen.	Commer. Gover.	Total	Residen.	Commer. Gover.	Total	
	Quality	130 mg/l	145 mg/l	-	130 mg/l	145 mg/l	-	
Dusit Phra Nakhon Pom Prab Sattru Pai Sampanthawong	Discharge	158 lcd	274 lcd	432 lcd	215 lcd	297 lcd	512 lcd	
Pathmwan Bang Rak	Pollution Load	20.5 gcd	39.7 gcd	60.2 gcd	28.0 gcd	43.1 gcd	71.1 gcd	
Phya Thai Huai Khwang	Discharge Load	133 lcd 17.3 gcd	61 lcd 8.8 gcd	194 lcd 26.1 gcd	215 lcd 28.0 gcd	146 lcd 21.2 gcd	361 lcd 49.2 gcd	
Phra Khanong	Discharge Load	209 lcd 27.2 gcd	126 lcd 18.3 gcd	335 lcd 45.5 gcd	221 lcd 28.7 gcd	146 lcd 21.2 gcd	367 lcd 49.9 gcd	
Bang Kapi Bang Khen	Discharge Load	133 lcd 17.3 gcd	40 lcd 5.8 gcd	173 lcd 23.1 gcd	215 lcd 28.0 gcd	146 lcd 21.2 gcd	361 lcd 49.2 gcd	
Yan Nawa	Discharge Load	138 lcd 17.9 gcd	103 lcd 14.9 gcd	241 lcd 32.8 gcd	215 lcd 28.0 gcd	146 lcd 21.2 gcd	361 lcd 49.2 gcd	

* Growth rate: Residen. = 0.6 g/year Total = 1.2 g/year

Table C.17 (2) Present and Future Estimated Unit Pollution Load Generation (COD)

Districts	Item	Present (1986 Year)			Future (2000 Year)			Remarks
		Residen.	Commer. Gover.	Total	Residen.	Commer. Gover.	Total	
	Quality	270 mg/l	235 mg/l	-	270 mg/l	235 mg/l	-	
Dusit Phra Nakhon Pom Prab Sattru Pai Sampanthawong	Discharge	158 lcd	274 lcd	432 lcd	215 lcd	297 lcd	512 lcd	
Pathmwan Bang Rak	Pollution Load	42.7 gcd	64.4 gcd	107.1 gcd	58.1 gcd	69.8 gcd	127.9 gcd	
Phya Thai Huai Khwang	Discharge	133 lcd	61 lcd	194 lcd	215 lcd	146 lcd	361 lcd	
	Load	35.9 gcd	14.3 gcd	50.2 gcd	58.1 gcd	34.3 gcd	92.4 gcd	
Phra Khanong	Discharge	209 lcd	126 lcd	335 lcd	221 lcd	146 lcd	367 lcd	
	Load	56.4 gcd	29.6 gcd	86.0 gcd	59.7 gcd	34.3 gcd	94.0 gcd	
Bang Kapi Bang Khen	Discharge	133 lcd	40 lcd	173 lcd	215 lcd	146 lcd	361 lcd	
	Load	35.9 gcd	9.4 gcd	45.3 gcd	58.1 gcd	34.3 gcd	92.4 gcd	
Yan Nawa	Discharge	138 lcd	103 lcd	241 lcd	215 lcd	146 lcd	361 lcd	
	Load	37.3 gcd	24.2 gcd	61.5 gcd	58.1 gcd	34.3 gcd	92.4 gcd	

* Growth rate: Residen. = 1.2 g/year Residen. = 1.2 g/year Total = 2.1 g/year

Table C.17 (3) Present and Future Estimated Unit Pollution Load Generation (SS)

Districts	Item	Present (1986 Year)			Future (2000 Year)			Remarks
		Residen.	Commer. Gover.	Total	Residen.	Commer. Gover.	Total	
	Quality	110 mg/l	80 mg/l	-	110 mg/l	80 mg/l	-	
Dusit Phra Nakhon Pom Prab Satiru Pai Sampanthawong Pathmwan Bang Rak	Discharge	158 lcd	274 lcd	432 lcd	215 lcd	297 lcd	512 lcd	
	Pollution Load	17.4 gcd	21.9 gcd	39.3 gcd	23.7 gcd	23.8 gcd	47.5 gcd	
Phya Thai Huai Khwang	Discharge Load	133 lcd 14.6 gcd	61 lcd 4.9 gcd	194 lcd 19.5 gcd	215 lcd 23.7 gcd	146 lcd 11.7 gcd	361 lcd 35.4 gcd	
Phra Khanong	Discharge Load	209 lcd 23.0 gcd	126 lcd 10.1 gcd	335 lcd 33.1 gcd	221 lcd 24.3 gcd	146 lcd 11.7 gcd	367 lcd 36.0 gcd	
Bang Kapi Bang Khen	Discharge Load	133 lcd 14.6 gcd	40 lcd 3.2 gcd	173 lcd 17.8 gcd	215 lcd 23.7 gcd	146 lcd 11.7 gcd	361 lcd 35.4 gcd	
Yan Nawa	Discharge Load	138 lcd 15.2 gcd	103 lcd 8.2 gcd	241 lcd 23.4 gcd	215 lcd 23.7 gcd	146 lcd 11.7 gcd	361 lcd 35.4 gcd	

* Growth rate: Residen. = 0.5 g/year Total = 0.8 g/year

Table C.18 Observation Date of Pollution Load Run-off

Land Use Pattern	Name	Observation Date
Commercial and Residential Area	Suriwong Rd.	Aug. 3-4, 1988 Aug. 10-11, 1988
	Krung Kasem Rd.	Aug. 3-4, 1988 Aug. 17-18, 1988
	Sukhumvit Rd.	Feb. 18-19, 1988 Jul. 21-22, 1988 Aug. 17-18, 1988
High Density Residential Area	Pathumwan	Aug. 17-18, 1988
Low Density Residential Area	Siam Jasco Wipawadi Rangsit 1 Wipawadi Rangsit 2	Aug. 10-11, 1988 Aug. 10-11, 1988 Aug. 10-11, 1988

Table C.19 Conditions of Survey Areas for Pollution Load Runoff

	Population	Area km ²	Population Density (Person/ha)	Conditions of Survey Areas
Suriwong Rd.	2,773	0.090	308	In Suriwong Rd., there are many large company offices, banks, hotels and stores. The survey area is located in the residential area behind the main streets.
Krung Kasem Rd.	11,886	0.340	349	Unlike Suriwong Rd. and Silom Rd. that have many large company offices, banks, hotels, and stores, there are many small and medium sized stores in the survey areas. These stores are located on the ground floors of buildings that have residential units above the second floor.
Sukhumvit Rd. Soi 40	66,000	6.150	107	The survey area is a large area between Sukhumvit Street and the K. Saen Saep. The area facing the street is a commercial zone. The area behind the commercial zone is a high class residential area having many condominiums.
Pathumwan	2,777	0.050	555	Relatively low income families live in this area. About one half of the area is occupied by congested low houses and is heavily populated.
Siam Jasco	9,072	0.220	412	The roadsides in the survey area are occupied by open weather restaurants and stores. However, more than 90% of the area is residential.
Wipawadi Rangsit 1	2,943	1.140	25	The area is located to the north of Bangkok City. It is a high class residential area that faces the highway connecting Bangkok City to the airport. Most of the houses face the paved roads that have nice side ditches.
Wipawadi Rangsit 2	4,577	0.560	82	Pollution load in the area is discharged from a large complex of police flats and scattered houses. Except for the police flat area, the area is densely populated. The pollution load from the police flats flows into one spot of the upper part of the areas.

Table C.20 BOD Run-off Coefficient

Name	Date	Discharge m ³ /d	Average Quality mg/l	Run-off Load kg/d	Popula- tion	Per Capita Load Generation g _{cd}	Generated Load kg/d	Run-off Coefficient %	Area km ²	Population Density person/ha	Specific Discharge 10 ³ m ³ /d/km ²
Suriwong Rd.	Aug. 3-4	4311	54	231.4	2773	60.2	166.9	139	0.090	308	47.9
Suriwong Rd.	Aug.17-18	4251	54	230.9	2773	60.2	166.9	138	0.090	308	47.2
Krung Kasem Rd.	Aug. 3-4	10710	65	694.3	11886	60.2	715.5	97	0.340	349	31.5
Krung Kasem Rd.	Aug.17-18	7360	40	297.9	11886	60.2	715.5	42	0.340	349	21.6
Sukhumvit soi 40	Feb.18-19	33800	42	1419.3	66000	45.5	3003.0	47	6.150	107	5.5
Sukhumvit soi 40	Jul. 21-22	72538	19	1363.4	66000	45.5	3003.0	45	6.150	107	11.8
Sukhumvit soi 40	Aug.17-18	44278	49	2171.9	66000	45.5	3003.0	72	6.150	107	7.2
Pathumwan	Aug.17-18	1757	45	78.6	2777	60.2	167.2	47	0.050	555	35.1
JASCO	Aug.10-11	2399	43	102.7	9072	26.1	236.8	43	0.220	412	10.9
Wipawadi Rangsit-1	Aug.10-11	1542	32	48.7	2943	23.1	68.0	72	1.140	25	1.4
Wipawadi Rangsit-2	Aug.10-11	3600	29	103.0	4577	23.1	105.7	97	0.560	82	6.4

Table C.21 SS Run-off Coefficient

Name	Date	Discharge m ³ /d	Average Quality mg/l	Run-off Load kg/d	Popula- tion	Per Capita Load Generation g _{cd}	Generated Load kg/d	Run-off Coefficient %	Area km ²	Population Density person/ha	Specific Discharge 10 ³ m ³ /d/km ²
Suriwong Rd.	Aug. 3-4	4311	25	108.8	2773	39.3	109.0	100	0.090	308	47.9
Suriwong Rd.	Aug.17-18	4251	123	524.1	2773	39.3	109.0	481	0.090	308	47.2
Krung Kasem Rd.	Aug. 3-4	10710	46	490.0	11886	39.3	467.1	105	0.340	349	31.5
Krung Kasem Rd.	Aug.17-18	7360	32	235.5	11886	39.3	467.1	50	0.340	349	21.6
Sukhumvit soi 40	Feb.18-19	33800	35	1198.6	66000	33.1	2184.6	55	6.150	107	5.5
Sukhumvit soi 40	Jul. 21-22	72538	39	2824.4	66000	33.1	2184.6	129	6.150	107	11.8
Sukhumvit soi 40	Aug.17-18	44278	90	3965.3	66000	33.1	2184.6	182	6.150	107	7.2
Pathumwan	Aug.17-18	1757	64	111.6	2777	39.3	109.1	102	0.050	555	35.1
JASCO	Aug.10-11	2399	13	30.2	9072	19.5	176.9	17	0.220	412	10.9
Wipawadi Rangsit-1	Aug.10-11	1542	21	32.9	2943	17.8	52.4	63	1.140	25	1.4
Wipawadi Rangsit-2	Aug.10-11	3600	12	43.5	4577	17.8	81.5	53	0.560	82	6.4




FIG. C. 1

EXPANSION OF URBANIZED AREA IN THE STUDY AREA

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK

Bangkok	Metropolis
1980	5,070,000
1990	6,400,000
2000	7,700,000

Urban	Core Area
1980	390,000
1990	320,000
2000	270,000

Core	Fringe Area
1980	2,580,000
1990	2,840,000
2000	3,070,000

Suburban Area	
Eastern Suburban Area	Remaining Area
1980	940,000
1990	1,450,000
2000	1,860,000

District Name

- * Phra Nakhon
- * Pom Prap Sattru Pai
- * Samphanthawong

District Name

- * Pathumwan
- * Bang Rak
- * Yan Nawa
- * Dusit
- * Phya Thai
- Thonburi
- Klong San
- Bangkok Noi
- Bangkok Yai

District Name

- * Hual Khwang
- * Phra Khanong
- * Bang Khen
- * Bang Kapi

District Name

- Phra Khanong
- Bang Khen
- Bang Kapi
- Min Buri
- Nong Chok
- Lad Krabang
- Rat Burana
- Bang Khun Thian
- Phasi Charoen
- Taling Chan
- Nong Khaem


Note : Districts marked by * are included in the Study Area.

Ref. : Report of Flood Protection / Drainage in Eastern Suburban Bangkok, JICA

FIG. C.3

PROJECTED POPULATION OF URBAN CORE, CORE FRINGE AND SUBURBAN AREAS

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK




LEGEND

- Residential Area
- Residential and Commercial Area
- Institutional Area
- Commercial Area

FIG. C. 4

FUTURE LAND USE

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK



No.	Districts
1	Dusit
2	Phra Nakhon
3	Pom Prab Sattru Pai
4	SamPanthawong
5	Pathumwan
6	Bang Rak
7	Phya Thai
8	Huai Khwang
9	Phra Khanong
10	Bang Kapi
11	Bang Khen
12	Yan Nawa

LEGEND

- Districts
- - - - Service Area
- Study Area

FIG. C.5

MWA SERVICE AREA

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK




FIG. C. 6

RESULTS OF SAMPLING SURVEY ON UNIT WATER CONSUMPTION

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK





FIG. C. 7

CONCEPT OF POLLUTION LOAD GENERATION

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK



NO.	NAME
1	DIN DAENG (NHA)
2	BON KAI (NHA)
3	SURIWONG ROAD
4	SILOM ROAD
5	SIAM SQUARE

FIG. C.8

LOCATION OF UNIT POLLUTION LOAD GENERATION SURVEY

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK




NO	NAME
1	SURIWONG
2	KRUNG KASEN
3	SUKHUMVIT SOI 40
4	PATHUMWAN
5	SIAM JASCO
6	WIPAWADI RANGSIT - 1
7	WIPAWADI RANGSIT - 2


FIG. C.12

LOCATION OF POLLUTION LOAD RUN-OFF OBSERVATION

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK



Correlation Between Run - off Coefficient of BOD and Specific Discharge



Correlation Between Run - off Coefficient of SS and Specific Discharge

FIG. C.13

CORRELATION BETWEEN RUN-OFF COEFFICIENT AND UNIT DISCHARGE

THE FEASIBILITY STUDY ON PURIFICATION OF KLONG WATER IN BANGKOK


APPENDIX D.
AERATED LAGOON TREATMENT

APPENDIX D. AERATED LAGOON TREATMENT

1. Wastewater Treatment Alternatives

1.1 Comparison of Treatment Methods

There are many treatment methods available for wastewater treatment, consisting of physical, chemical and biological processes as shown in the following flow chart.



The choice of the best method of treatment will depend on the following considerations:

- (1) The required treatment level
- (2) Economic considerations
- (3) Local and environmental conditions

An important characteristics peculiar to the klong wastewater is that, it is of large quantity with relatively low concentration of BOD, in comparison to conventional sewer domestic wastewater.

Also the treatment method shall be low in cost and simple to operate and maintain, from the view point of large quantity of wastewater as well.

To treat the klong water directly, it is necessary to obtain the land for treatment facilities near the klongs. In Bangkok city, there exists many ponds in the vicinity of klongs and consequently, lagoon systems appears to be the obvious means of simple treatment.

Table D.1 gives a comparison of various options of biological treatment systems, their advantages and disadvantages.

1.2 Selection of Treatment Method

The characteristic features of aerated lagoon system is that it is a biological treatment process utilizing aerobic microbial oxidation with no sludge recycle, hence the hydraulic and solids retention times being the same. As a result, the main disadvantage of this process in the high capacity requirement and in turn large area of land. However, it is simple and can achieve a high treatment efficiency with relatively low construction and operation and maintenance cost (Refer to Table D.1).

By assuming evaluation points, to qualitatively compare the alternative treatment methods of Table D.1, as shown below, aerated lagoon and waste stabilization system (with/without anaerobic unit) gain the highest rankings.

- * (poor) : 1 point
- ** (fair) : 2 points
- *** (good) : 3 points

In this study, as existing ponds should be utilized for klong water treatment, the available pond capacity would limit the lagoon treatment options. As such it is decided to experimentally evaluate a combined lagoon system, which will while optimising land requirement would also achieve high treatment efficiency, including removal of pathogens in final maturation pond.

Aerated Lagoon → Facultative Pond → Maturation Pond

2. Experimental Plan


2.1 General

Rama IX pond was used in this Study to investigate the feasibility of klong water treatment by lagoon methods as a low cost option and to collect the necessary basic data for the klong water purification plan. Location of the Rama IX Pond is shown in Fig.D.1.

Experiments were performed during both dry and rainy seasons, as these two seasons represent very different hydraulic conditions in the kolngs. During each season, a number of alternatives with various pond detention times were studied to understand the effects of different detention times on treatment efficiencies and hence the water quality improvement of the kolngs.

2.2 Overview of the Plan

The processes used in this study are as shown below.



The klong water is treated in each pond, which have different biological and ecological conditions.

In the Aerated Lagoon, as will be described later, 3 floating type aerators will be used. Under normal operation, aerobic conditions will prevail, and pollutants in the water, especially organic matter as BOD or COD, will be biodegraded by aerobic microorganisms biologically utilizing oxygen.

The Facultative Pond receives the effluent from the Aerated Lagoon. The upper layer of the Facultative Pond is aerobic, where the wastewater undergo aerobic treatment, while the lower layer is anaerobic, where the wastewater will undergo anaerobic treatment. Symbiosis between algae and bacteria, and the resultant

photosynthetic oxygen is a prime source of day time DO for microbial oxidation.

The Maturation Pond is the last stage in the treatment scheme and acts to polish the treated water, including the removal of pathogenic organisms which is in effect equivalent to disinfection.

2.3 Overview of Treatment Facilities

The pond used for the experiments is the Rama IX Pond, which draws polluted water from Klong Lad Phrao and discharges the treated water into the same klong, as shown in Fig. D.2.

The important characteristic features/specification of all facilities and equipment are as shown below.

- | | |
|----------------------------|--|
| (1) Inlet Facility | Pump 20 m ³ /min. x 2 units |
| (2) Aerator | Floating type 11 Kw x 3 units |
| (3) Aerated Lagoon | Capacity 19,200 m ³
(Depth 3 m, Surface Area 6,400 m ²) |
| (4) Open Channel | Length 120 m, Depth 3 m |
| (5) Facultative Pond | Capacity 49,700 m ³
(Depth 2.5 m, Surface Area 19,900 m ²) |
| (6) Maturation Pond | Capacity 45,900 m ³
(Depth 2.5 m, Surface Area 18,400 m ²) |
| (7) Outlet Facility | Stop Log Width 2 m |

2.4 Experimental Method

(1) Experimental Conditions

As it will be difficult to obtain new land for lagoons to be used for klong water quality improvement, it is decided, in principle, that only the existing ponds could be used.

The hydraulic conditions and water quality of these klongs and the ponds of their vicinity vary according to their locality.

In this experiment using Rama IX Pond, several cases, obtained by varying detention time, were studied. These cases of experiment are described in Table D.2. Accordingly, four (4) number of cases with varying detention times of aerated lagoon, facultative pond and maturation pond were investigated (Case 1 ~ Case 4). Of these Case-1 and Case-3 consisted respectively of three (3), Case 1-1 ~ Case 1-3, and two (2), Case 3-1 ~ Case 3-2, experimental phases, whereas Case 2 and Case 4 consisted of one single phase for each.

(2) Experimental Schedule

The experimental work was conducted from the beginning of February to the middle of August. The schedule of the experimental work is shown in Fig. D.3.

(3) Water Quality Analysis

1) Sampling Points

To evaluate the effectiveness of the lagoon treatment, mass balance analysis was performed across all three (3) ponds. For this purpose, water sampling and the subsequent analysis of water quality parameters were carried from samples taken at the following locations (Refer to Fig. D.2):

Point ① Inlet of the Aerated Lagoon

Point ② Outlet of the Aerated Lagoon

Point ③ Outlet of the Open Channel (Inlet of Facultative Pond)

Point ④ Outlet of the Facultative Pond

Point ⑤ Outlet of the Maturation Pond

As the Open Channel connecting the Aerated Lagoon and the Facultative Pond is rather long (120 m), and considerable sedimentation occurs in this section, and it is likely that this would affect the water quality. Therefore sampling was conducted at the outlet of the Open Channel as well to

evaluate its influence, and to be representative location of facultative pond inlet.

2) Sampling Frequency and Time

As the minimum detention time used in this study, even in the Aerated Lagoon, is at least 8 hours, the daily variation in the influent water quality could possibly be averaged. Hence it was decided that frequency of sampling and analysis should, in principle, be done only once a day. Also the water quality observation in klongs was carried out between January and July in 1988. Fig. D.4 shows the hourly variation of BOD observed in Klong Lad Phrao near the inlet of the Aerated Lagoon. From Fig. D.4, it can be seen that the BOD value around 10 a.m. is quite representative to the average for the whole day. Hence, 10 a.m. was selected as the daily sampling time.

3) Water Quality Parameter

To get a comprehensive understanding for the specific features of each pond, treatment conditions, etc., the water quality parameters, given in Table D.3, were analyzed.

3. Results of Water Quality Observations

3.1 Water Quality of Wastewater Source

The wastewater in this study is from Klong Lad Phrao. DDS has maintained records of water quality in klongs in Bangkok city for many years. Judging from the data of the 6 year period, 1981 - 1986, the average BOD value in Klong Lad Phrao is approximately 14 mg/l. Other klongs in the study area have BOD values ranging from 5 - 54 mg/l. Therefore, the average BOD of Klong Lad Phrao falls under lower range in comparison to other klongs.

However, Klong Lad Phrao is black in color, very malodorous, and compared to its water quality measurements, it presents an image of being highly polluted based on observation (visual, smell).

The results of the water quality of wastewater source at the inlet of aerated lagoon are given in Table D.4, and the variation of BOD and COD are given in Fig. D.5.

As shown in Table D.4, the influent DO is practically 0 mg/l, total BOD (henceforth referred to as T-BOD) and soluble BOD (S-BOD) are approximately 20 mg/l and 8 mg/l, respectively. T-COD and S-COD (T and S as in the case of BOD) are approximately 45 mg/l and 30 mg/l, respectively.

In the rainy season, rainwater flows into klongs and dilutes the pollutant concentration of klongs. As Table D.4 indicates, during rainy season the black color of the klong water turned to gray or brown color, and the value of BOD and COD concentration and Coliform count decreased slightly compared to that of dry season.

The BOD load of influent to the Aerated Lagoon in Case-1 is

$$28,800 \text{ m}^3/\text{d} \times 20 \text{ mg/l} \div 19,200 \text{ m}^3 = 0.03 \text{ kg/d/m}^3$$

This is extremely low, about one-tenth that in conventional activated sludge systems.

In the Aerated Lagoon, as already emphasized there is no recycling of settled sludge, and the effect of BOD loading on the process was also investigated in this study.

Fig. D.5 shows the variation of influent BOD (T-BOD and S-BOD) and COD (T-COD and S-COD). Although neither of these values have good correlation, the value of T-COD is approximately three (3) times that of T-BOD and the value S-COD is four (4) times that of S-BOD, in general.

3.2 Experimental Results of All Cases

The experiments were conducted as per the experimental schedule shown in Fig. D.3 from February 6 to August 28 of 1989. The daily experimental data obtained are given in Data Book.

(1) Case-1

All three (3) phases of the experiments were conducted during dry season.

The experimental results obtained have been averaged over the whole experimental period for each sampling point and are organized as given in Table D.5 to Table D.7, for all 3 phases. The corresponding longitudinal variation of the measured water quality parameters from influent (Point ①) to effluent (Point ⑤) of the whole system is shown in Fig. D.7 to Fig. D.9.

Table D.8 shows the pollutant removal efficiencies in each pond for the three (3) phases (Case-1-1, Case-1-2 and Case-1-3) under similar experimental conditions.

The removal efficiencies in Case-1-1 (Phase 1) differ markedly from those observed in other two (2) cases, especially, BOD and COD removal efficiencies.

This may be attributed to the fact that at the start of Case-1-1, the Rama IX Pond, which was previously filled with rainwater, was gradually replaced by polluted influent water from Klong Lad Phrao, and consequently, the microbial phase in the Facultative and Maturation ponds was not, as yet, fully developed and acclimated. In other words, steady state condition was not reached.

Considering the results of Case-1-2 and Case-1-3, which were performed in about one (1) month and two (2) months, respectively, after the start of the pond operation, it can firstly be seen that the DO of the effluent from the Aerated Lagoon

increased up to 58% and 72% of the saturation DO value of 7.6 mg/l and 7.5 mg/l, respectively, based on the respective temperatures of the lagoon mixed liquor (Refer to Table D.6 and Table D.7).

The average removal efficiency of T-BOD for Case 1-2 and Case 1-3 in the Aerated Lagoon is approximately 50%, while that of S-BOD is 30%. The average T-COD and S-COD removal efficiencies for the same phases are 40% and 30%, respectively (Refer to Table D.8).

The $\text{NH}_4\text{-N}$ and coliform count reduction is not very significant. Due to the short detention and no sludge recycling, the VS content in the Aerated Lagoon did not increase sufficiently. High water temperature and the DO concentration in the Aerated Lagoon resulted in significant reduction of organic matter represented as BOD.

Further, in the Aerated Lagoon, there is considerable reduction in the color and odor, with the black color being replaced by a brown color and odor becoming almost undetectable.

Because the Open Channel connecting the Aerated Lagoon and the Facultative Pond is about 120 m long, it is possible that sedimentation could occur in this channel. But as can be seen from Table D.6 and Table D.7 sedimentation is not very significant. As there is an increase in pH value, rather than sedimentation, the Open Channel appear to act rather as a portion of the Facultative Pond.

In the Facultative and Maturation Ponds, good $\text{NH}_4\text{-N}$ and coliform reductions were observed. However, the effluent BOD, COD and other parameters from these ponds were higher than that of effluent from the Aerated Lagoon. This seemingly reverse phenomenon can be attributed to the fact that the BOD of the source is 17 mg/l, which is relatively low, and algal growth and the resultant carbon fixing which results from treatment in ponds, increases the value of BOD in these ponds.

The diurnal variation of DO profiles in facultative and maturation ponds were determined on 14 February 1989 at 1 hour interval, and are shown in Fig. D.10. The temperature is around 29 - 30°C, at which the DO saturation concentration is about 7.6 mg/l. The DO profile indicates approximately three (3) times this value at its maximum, which occurred around 4:00 p.m., is the typical profile around which time the maximum super saturated DO levels occur due to (day time) photosynthetic activity in oxidation ponds.

The chlorophyll-a concentration, however, was 0.06 - 0.08 µg/l in the Facultative and Maturation Ponds. Compared to values reported in literature, this concentration is very low, which is attributable to the low influent concentration of wastewater and the respective nutrients (N, P).

(2) Case-2

The experiments were conducted during dry season (Refer to Fig. D.3).

The experimental results obtained have been averaged over the whole experimental period for each sampling point and are organized as given in Table D.9. Fig. D.11 shows the corresponding longitudinal variation of all the measured water quality parameters from influent (Point ①) to effluent (Point ⑤) of the whole system.

In Case-2, the detention time in the Aerated Lagoon was 32 hours. Consequently, the influent pollutant load was approximately half of that in Case-1 (Refer to Table D.2).

Compared to Case-1, the DO concentration in the Aerated Lagoon was about 30% higher and was 86% of its saturation level of 7.8 mg/l at the water temperature of 27.7°C.

The removal efficiencies of BOD, COD and other parameters given in Table D.10 were generally higher than those observed in Case-

1 (Refer to Table D.8). This is attributed to the fact that the detention time was twice that in Case-1.

Similar to that observed in Case-1, there was significant improvement in color and odor level in the Aerated Lagoon. Furthermore, in the Maturation Pond, the $\text{NH}_4\text{-N}$ concentration and coliform count reduced, with the former dropping to insignificant level, and the latter dropping to about one-thousandth of its level in the Aerated Lagoon.

It therefore appears that the Maturation Pond with at least five (5) days detention time serves well in producing a good quality polished effluent.

(3) Case-3

The experiments of Case-3 were started from June 7, 1989 (Refer to Fig. D.3). In this case, one (1) aerator was stopped, as the DO concentration in the Aerated Lagoon was too high in Case-1 and Case-2, where three (3) aerators were operated for 24 hours.

Case-3 was divided into two (2) phases. Case-3-1 (Phase 1) was conducted in the dry season, whereas Case-3-2 (Phase 2) was conducted in the rainy season.

The experimental results obtained have been averaged over the whole experimental period for each sampling point and are organized as given in Table D.11 and Table D.12, respectively for Case 3-1 and Case 3-2. Fig. D.12 and Fig. D.13 show the corresponding longitudinal variation of all the measured water quality parameters from influent (Point ①) to effluent (Point ③) of the whole system, respectively for Case 3-1 and Case 3-2.

Reducing the magnitude of aeration in the Aerated Lagoon resulted in a drop in the DO value to about 80% of the value when all three (3) aerators were operated, corresponding to 59% of the

saturation DO value of 7.6 mg/l at the average water temperature of 29.4°C.

Based on the BOD and COD removal efficiencies shown in Table D.13, it is evident that the overall removal efficiencies of Case-3-1 and Case-3-2 are almost equivalent. The BOD removal efficiency was, similar to that observed in Case-1 or Case-2, approximately from 50% to 60% through the Aerated Lagoon and the Open Channel, in spite of the decrease in the DO concentration.

However, compared to the results obtained in Case-1 or Case-2, the COD removal in the Aerated Lagoon was slightly low, and in the Facultative and Maturation Pond, and also no significant reduction in $\text{NH}_4\text{-N}$ was observed in the ponds.

The Chlorophyll-a concentration observed in Case-3-2 during rainy season decreased to approximately half of that observed in Case-1 during dry season. This may be attributed to the fact that the influent load was less than that in the dry season and that, the algal photosynthesis decreased in the rainy season.

The latter is in part due to decrease in depth of penetration of solar radiation into the pond by the high turbidity of the incoming rainwater runoff and in part due to reduced solar radiation by cloudiness and an overall decrease in day time, typical to rainy seasons.

(4) Case-4

The experiment in Case-4 was carried out by operating two (2) pumps in addition to the two (2) aerators as per Case-3.

The experimental results obtained have been averaged over the whole experimental period for each sampling point and are organized as given in Table D.14. Fig. D.14 shows the corresponding longitudinal variation of all the measured water

quality parameters from influent (Point ①) to effluent (Point ⑥) of the whole system.

By means of operating the two (2) pumps, the detention time in the Aerated Lagoon was reduced to 8 hours and the BOD loading to the Aerated Lagoon was increased to more than twice that in any other cases, Case 1 and Case 3. The DO concentration profile observed in the Aerated Lagoon decreased to 75% of that observed in Case-3.

The removal efficiencies of the water quality parameters, BOD and COD, are shown in Table D.15, which are nearly equal to those observed in Case-3. Although the T-COD removal efficiency was less than 20% in the Aerated Lagoon, it appears to increase in the following ponds in contrast to the results in the other cases.

Due to the reduced detention time, the Chlorophyll-a concentration also dropped to approximately one-third the level observed in Case-3.

(5) Correlation of Removal Efficiency

Fig. D.15 shows the correlation between the removal efficiencies of T-BOD and T-COD and the detention time in the Aerated Lagoon for all 4 cases. In this figure, the value of each removal efficiency was averaged over for all phases of Case 1 and Case 3 where the same operational conditions prevailed. As such, each case is represented only by a single point.

While T-BOD removal efficiency remained practically unchanged over all the detention times studied, the T-COD removal is related to the detention time and/or the magnitude of aeration. Therefore, from the point of view of COD removal, it seems about one day detention time of Aerated Lagoon is required for the satisfactory treatment of klong water.

Fig. D.16 shows the correlation between the BOD removal efficiency and the influent BOD loading with respect to both the T-BOD and S-BOD for all cases of experiments. The similar removal efficiencies, but with respect to both the T-COD and S-COD are shown in Fig. D.17.

No discernable relationship or trend between removal efficiency and BOD loading (for both the T-BOD and S-BOD) is observed in the range of BOD loading used in the experiments (Refer to Fig. D.16). However a general trend of decrease in efficiency of COD removal, with increasing COD loading (for both the T-COD and S-COD), from Case 2 to Case 4, is discernable (Refer to Fig. D.17)

In all cases, the DO level, which is almost zero in the influent klong water, increased in the effluent of Aerated Lagoon. T-BOD and S-BOD removal efficiencies observed in the Aerated Lagoon as a function of effluent DO is shown in Fig. D.18. Fig. D.19 shows similar results of COD removal efficiencies. Though no discernable relationship between removal efficiency and DO is observed in case of BOD removal (both T-BOD and S-BOD), an increasing trend in removal efficiency with increasing DO is discernable in case of COD removal. with respect to both the T - COD and S - COD.

(6) Supplemental Observation of Heavy Metals

Heavy metal concentrations were also observed as a supplement to the general water quality parameters, and the results are shown in Table D.16.

The heavy metal levels in Table D.16 are within the allowable limits set in the river water quality standards of Japan. But, since some heavy metals get adsorbed to the settled sludge in the lagoons and ponds and accumulate in benthic deposits, further consideration may be required into this matter.

4. Conclusion

The experimental study in the Rama IX Pond for the klong water quality improvement project had been carried out from the beginning of February to the end of August in 1989 with the cooperation of DDS.

The purpose of this study is to get basic data for the Aerated Lagoon process. Based on the results, it is to be decided whether the Aerated Lagoon process should be used as a supplementary method for klong water treatment.

The results of all cases were discussed in the foregone sections, and based on these, the following conclusions were made.

- (1) From the experimental results obtained using the lagoon system it is clear that the variation in detention time and magnitude of aeration of the Aerated Lagoon, did not exert any significant influence on the overall treatment efficiency. This may be attributed to low pollution load of influent wastewater and the effects of algal growth in facultative and maturation ponds.
- (2) A very significant improvement in color and odor is attained in the three (3) ponds. Black color in klong water changed to brown color in the Aerated Lagoon and to green color in the Facultative and Maturation Ponds, respectively. Odor was almost undetectable in any ponds.
- (3) The Aerated Lagoon is effective with respect to BOD and COD removals. The removal efficiencies of T-BOD and T-COD in the Aerated Lagoon are approximately 50% and 30%, respectively, when the detention time is almost one (1) day under aerobic conditions.
- (4) Algal growth in facultative and maturation ponds affect the overall removal efficiencies of T-BOD and T-COD. However, if some method of algal harvesting at the outlet of the Maturation Pond can be considered, it can be inferred that these removal efficiencies be increased.