



[換配筋リスト(平面形式)]

<R.FL層>




<G.FL層>



[柱配筋リスト(平面形式)]

< 1 層 R.FL-G.FL >



937

AR-6 屋外機器の基礎

構造計算書

目 次

6.1	一般事項	1
6.2	煙道サポート	4
6.3	タービン油貯蔵タンク	7
6.4	燃料油サービスタンク	9

()

○

938

6.1 一般事項

6.1.1 APPLICABLE CODES AND STANDARDS

- 1) For design and allowable stress of structural materials

Reinforced concrete structure

AIJ : "Standards for calculation of reinforced
concrete structures"

Foundation

AIJ : "Standards for structural design of building
foundation"

* AIJ : Architectural Institute of Japan

6.1.2 STRUCTURAL MATERIALS TO BE USED AND ALLOWABLE UNIT STRESS

- 1) Qualities of materials

Concrete ; Comperressive strength of 28 days

$$F_c' = 210 \text{ kg/cm}^2$$

Reinforcement ; Deformed reinforcement

ASTM A615 Grade 40

$$f_y = 2,812 \text{ kg/cm}^2$$

- 2) Physical constants for structural materials

Modulus of elasticity

Concrete 210 t/cm²

Reinforcement 2100 t/cm²

3) ALLOWABLE UNIT STRESS

i) Allowable Unit Stress of Concrete (kg/cm²)

stresses		Permanent Stresses					Temporary Stresses		
		Compress	Shear	Bond			Compress	shear	Bond
				A	B	C			
Materials									
Normal concrete Fc-210	Plain bar Deformed bar	70	7.0	8.4 14.0	12.6 21.0	8.4 14.0	Permanent Stresses x 2.0	Permanent Stresses x 1.5	

- * Remarks A : Top bar of flexural members
- B : Bar, except "Item A", of flexural members
- C : Anchors and lap splices

ii) Allowable Unit Stress of Reinforcing Bars (kg/cm²)

Stresses	Permanent Stresses		Temporary Stresses	
	Tension Compression	Shear Reinforcement	Tension Compression	shear Reinforcement
Deformed bar ASTM A615 Grade 40	1,870	1,870	2,812	2,812

6.1.3 LOAD COMBINATION

1) Load combination for steel and concrete structure

Long term loading

i) $D.L+L.L+M.L+C.L$

Short term loading

i) $D.L+L.L+M.L+C.D+W.L$



ii) $D.L+L.L+M.L+C.D+S.L$

where;


D.L ; Dead load
L.L ; Live load and over burden load
M.L ; Machine load
C.L ; Crane operation load
C.D.L ; Crane dead load
W.L ; Wind load
S.L ; Seismic load

942

§1. GENERAL DRAWING



S2. LOADING DATA



SEISMIC FORCE


$$H_1 = 0.1 \times 2.5 \times 15.0 = 3.75 \text{ t}$$

WIND FORCE

$$H_1 = 0.15 \times (0.8 + 0.4) \times 15.0 \times 2.6 = 7.02 \text{ t}$$


$$P_1 = 0.15 \times 0.7 \times 15.0 \times 4.8 = 7.56 \text{ t}$$

D.L



$$P_1 = 2.50 \times 15.0 = 37.5 \text{ t}$$

E.L




$$H_1 = 3.75 \text{ t}$$

$$M_1 = 3.75 \times (8.50 + 2.60/2) = 36.75 \text{ t-m}$$

9.80

W.L



$$H_1 = 7.02 \text{ t}$$


$$P_1 = 7.56 \text{ t}$$

$$M_1 = 7.02 \times 9.80 = 68.80 \text{ t-m}$$

DESIGN OF FOUNDATION

OUTLINE OF FOUNDATION

RC - Pile
4 - 450



Foundation weight

$$N_f = 2.4 \cdot (36 \cdot 36 \cdot 1.7 + 10 \cdot 10 \cdot \pi \cdot 0.7) + 1.8 \cdot (36 \cdot 36 - 10 \cdot 10 \cdot \pi) \cdot 0.5 = 45.22 \text{ t}$$

LOADING

	N (t)	Hx (t)	Hy (t)
D.L	37.50		
L.L			
S.Lx	0	3.75	
S.Ly	0		3.75
W.Lx	-7.56	7.02	
W.Ly			

Stress at bottom of foundation

$$N = 37.50 - 7.56 + 45.22 = 75.16 \text{ t}$$

$$M = 68.80 + 7.02 \cdot 1.70 = 80.73 \text{ t}\cdot\text{m}$$

CHECK OF BEARING PRESSURE


Check of Pile Reaction

$$P_1 = 75.16/4 + 80.73/(2 \cdot 2 \cdot 2) = 37.14 \text{ t/pile} < 35.0 \cdot 1.5$$

$$P_1' = 29.94/4 + 80.73/(2 \cdot 2 \cdot 2) = 25.83 \text{ t/pile}$$

DESIGN OF FOOTING

Load case	Factored Load		Pile Reaction	
	ΣN (t)	ΣM (t,m)	P1 (t/n)	P1' (t/n)
D.L + L.L	37.50			
D.L + L.L + W.L				
D.L + L.L + S.L				
D.L + W.L	29.94	80.73	37.14	25.83



Stress

$$QF = 25.83 \text{ t}$$

$$MF = 25.83 \cdot 0.1 = 2.58 \text{ t}\cdot\text{m}$$

Reinforcement

$$D = 100 \text{ cm}, \quad d = 85 \text{ cm}, \quad j = 7/8d = 74.38 \text{ cm}$$





$$\text{neq } A_t = \frac{MF}{f_t \cdot j} = 1.23 \text{ cm}^2 \quad \left. \begin{array}{l} 19 - \#5 \\ (A_t = 38 \text{ cm}^2) \\ (\phi = 95 \text{ cm}) \end{array} \right\}$$

$$\phi = \frac{Q}{f_a \cdot j} = 11.02 \text{ cm}$$

$$\tau = \frac{Q}{b \cdot j} = 0.96 < 7.0 \text{ kg/cm}^2$$

9/45

§1 FOUNDATION PLAN AND SECTION



945

§ 2. DESIGN OF FOUNDATION

8

2-1. DESIGN OF CONCRETE PILE

Foundation weight

$$N_f = 2.4 \cdot \{0.5 \times 5.0 \times 8.0 + 0.2 \times 0.5 \times (8.0 + 5.0) \times 2\}$$

$$= 54.24 \text{ t}$$

LOADING

$$\text{D.L. } N = 80.0 + 0.5 \times 2 = 81.0 \text{ t}$$

Stress at bottom of foundation


$$N = 81.0 + 54.24 = 135.24 \text{ t}$$

$$M = \text{---}$$

Check of Pile Reaction

$$P_i = 135.24 / 6 = 22.54 \text{ t/pile} < 35 \text{ t/pile OK}$$


2-2. DESIGN OF FOOTING




$$w_1 = 2.4 \times 0.5 \times 2.5 = 3.00 \text{ t/m (Footing weight)}$$

$$P_1 = 80.0 / 2 = 40.0 + 2.4 \times 0.2 \times 0.5 \times 2.2 / 2 = 20.26 \text{ t}$$

$$P_2 = 0.5 + 2.4 \times 0.2 \times 1.0 \times 1.5 = 1.22 \text{ t}$$



$$M = 23.3 \text{ t}$$



$$D = 50 \text{ cm} \quad d = 40 \text{ cm} \quad j = 35.0 \text{ cm}$$

$$A_t = \frac{M}{f_c \cdot j} = \frac{6.88 \times 10^5}{1870 \times 35} = 10.51 \text{ cm}^2$$

$$\phi = \frac{Q}{f_a \cdot j} = \frac{23.3 \times 10^3}{21 \times 35} = 31.70 \text{ cm}$$

$$(l = 145 \text{ cm})$$

$$\#5 - \text{Ø} 200$$


$$(A_s = 16.92)$$

$$(\phi = 40.0 \text{ cm})$$

$$T = \frac{Q}{b \cdot j} = \frac{23.3 \times 10^3}{145 \times 35} = 4.59 < 7.0$$

977

§1. FOUNDATION PLAN AND SECTION



§2. DESIGN OF FOUNDATION

2-1 DESIGN OF CONCRETE PILE

Foundation weight

$$N_f = 24 \times \left(\frac{8.9}{2} \times \frac{8.9}{2} \times \pi \times 0.5 + 3.9 \times 3.9 \times \pi \times 0.2 \right)$$

$$= 97.59 \text{ t}$$

Seismic force

$$H = 0.1 \times 298.0 = 29.8 \text{ t}$$

STRESS at bottom of foundation

LONG TERM

$$N = 298.0 + 97.59 = 395.59 \text{ t}$$

$$M = \text{---}$$

SHORT TERM

$$N = 395.59 \text{ t}$$

$$M = 29.8 \times \left(\frac{6.1}{2} + 0.7 \right) = 111.75 \text{ t-m}$$

BTH

Check of Pile Reaction

LONG TERM

$$P_1 = 395.59 / 9 = 43.95 \text{ t/pile} < 45 \text{ t/pile}$$

SHORT TERM


$$Z = \frac{(3.9^2 + 2.76^2 \cdot 2) \times 2}{3.9} = 15.61$$

$$P_1 = \frac{395.59}{9} \pm \frac{111.75}{15.61} = 51.11 \text{ t/pile} < 45 \times 2, \quad 36.80 \text{ t/pile} > 0$$

OK.

2-2. DESIGN OF FOOTING

LONG TERM



$$W = \frac{298.0}{(8.9/2 \times 8.9/2 \times \pi)} \times 2.76 = 13.22 \text{ t/m}$$

$L = 4.79$


SHORT TERM

$$W = (4.79 + \frac{111.75}{46.59}) \times 2.76 = 19.84 \text{ t/m}$$

$$Z = \frac{\pi \times 7.8^2}{32} = 46.59$$

LONG TERM

$$D = 50.0 \text{ cm} \quad d = 40.0 \text{ cm} \quad j = 35.0 \text{ cm}$$




$$A_t = \frac{M}{f_c \cdot j} = 36.89 \text{ cm}^2$$

$$\phi = \frac{Q}{f_a \cdot j} = 42.86 \text{ cm}$$

$$Z = \frac{Q}{b \cdot j} = 3.26 < 7.0$$

$l = 276 \text{ cm}$
 $\#6 @ 200$
 $(A_s = 39.76 \text{ cm}^2)$
 $\phi = 84.00 \text{ cm}$

SHORT TERM



$$A_t = 36.80 \text{ cm}^2$$

$$\phi = 42.81 \text{ cm}$$

$$Z = 4.89 < 7.0 \times 1.5$$

$\#6 @ 200$
 $(A_s = 39.76 \text{ cm}^2)$
 $\phi = 84.00 \text{ cm}$

AR-7 空 調 設 備 (本館)

目 次

7. 1	設計条件	1
7. 2	データ	2
7. 3	熱貫流計算	4
7. 4	空調負荷	7
7. 5	設備負荷	21
7. 6	冷却設備の選定	29
7. 7	換 気	39

7. 1 設計条件

1. DESIGN CRITERIA

1 - 1 DESIGN CONDITION

1) For air conditioning system

(a) Outdoor air

Summer : 42.2°C DB, 28.6°C WB, 37%RH

(b) Room

Summer : 24°C+2°C DB, 50%RH

Winter : Not more than the condition in summer

2) Minimum ventilation air vol.

For Control Room 25 m³/Hr person

3) Lighting

20 W/m²

4) People

Refer to "Cooling and dehumidifying estimate sheets"

5) Location

25.4°(N), 68.3°(E)

952

2. DATA

Data used for load estimation is based on Carrier,s Design Manual of the newest condition.

2- 1 Outdoor air

1) Dry Bulb

Time	8	9	10	11	12	13	14	15	16	17	18
Dry Bulb											
°C	28.2	30.3	32.8	35.7	38.4	40.4	41.7	42.2	41.7	40.5	38.7

2) Humidity Ratio

Time	8	9	10	11	12	13	14	15	16	17	18
Humidity Ratio											
g/Kg	19.1	19.0	19.0	19.2	18.9	19.0	18.8	19.0	18.8	18.9	18.8

2- 2 Solar heat gain

1) Peak solar heat gain thru ordinary glass

EXPOSURE	NL	NE	SE	SW	NW	HORIZONTAL	SHADE
HEAT							
Kcal/h m ²		366	252	252	366	674	47

2) Solar gain correction factors

for steel sash : 1/0.85
for dew point : 0.94

3) Load storage factors , solar heat gain thru ordinary glass

TIME	8	9	10	11	12	13	14	15	16	17	18
EXPOSURE											
NE	0.57	0.46	0.30	0.24	0.20	0.19	0.17	0.16	0.15	0.13	0.11
SE	0.47	0.61	0.67	0.65	0.57	0.44	0.29	0.24	0.21	0.18	0.15
SW	0.08	0.08	0.10	0.24	0.40	0.55	0.66	0.70	0.64	0.50	0.26
NW	0.09	0.09	0.10	0.10	0.10	0.10	0.16	0.34	0.52	0.65	0.64

NOTE : Venetian blind to be located on the inside of glass.

(Overall factor is 0.65)

2 - 3 Equivalent temperature difference

1) For wall

EXPOSURE	TIME	8	9	10	11	12	13	14	15	16	17	18
NE		4.6	7.9	16.8	16.0	15.3	13.3	11.3	11.9	12.6	13.0	13.5
SE		5.4	8.6	11.1	12.4	13.6	13.8	13.9	12.9	12.4	11.8	11.5
SW		2.6	3.1	3.7	5.0	5.9	9.8	12.1	15.8	18.6	19.2	19.5
NW		3.7	4.5	5.3	6.6	7.9	10.1	11.3	13.5	15.4	19.5	23.2

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 200Kg/m².

2) For wall

EXPOSURE	TIME	8	9	10	11	12	13	14	15	16	17	18
NE		15.7	16.2	16.8	14.8	12.8	12.7	12.4	13.0	13.7	13.6	13.5
SE		7.4	9.6	12.1	13.1	14.1	14.4	14.2	13.1	12.6	12.0	11.5
SW		1.9	2.8	3.7	5.7	7.0	12.2	14.9	17.9	20.3	20.4	20.5
NW		3.7	4.7	5.7	7.4	9.1	11.3	12.4	15.8	18.3	22.4	25.5

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 100Kg/m².

3) For roof





FOR ROOF	TIME	8	9	10	11	12	13	14	15	16	17	18
°C		10.3	10.2	10.8	12.4	14.9	18.0	21.2	24.0	26.2	27.8	28.5

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 300Kg/m².

72/2






7.3 熱貫流計算

3 HEAT TRANSMISSION : K-Value

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE ($m^2H^{\circ}C/Kcal$)	AIR FILM ($m^2H^{\circ}C/Kcal$)	K-Value ($Kcal/m^2H^{\circ}C$)
ROOF 1. 	① CONCRETE BLOCK	30	0.067	$\gamma_0 = 0.05$	0.46
	② SAND	10	0.015		
	③ ASPHALT ROOFING	10	0.108		
	④ CONCRETE	100	0.071		
	⑤ DECK PLATE	1.2	-		
	⑥ AIR SPACE			0.2	
	⑦ GLASS WOOL	50	1.36		
	⑧ CEILING	25	0.132		
				$\gamma'_i = 0.189$ (2.192)	
CEILING 1 FLOOR 1. 	① CEMENT MORTAL	30	0.023	$\gamma'_i = 0.125$	1.16
	② CINDER CONCRETE	60	0.084		
	③ ASPHALT WATER PROOF	10	0.108		
	④ CONCRETE	100	0.071		
	⑤ DECK PLATE	1.2	-		
	⑥ AIR SPACE			0.2	
	⑦ CEILING	25.0	0.132		
				$\gamma'_i = 0.125$ (0.868)	
FLOOR 2 CEILING 2. 	① VINYL ASBESTOS TILE	2	0.054	$\gamma_i = 0.125$	2.52
	② CEMENT MORTAL	28	0.022		
	③ CONCRETE	100	0.071		
	④ DECK PLATE	1.2	-		
				$\gamma_i = 0.125$ (0.397)	
FLOOR 3. 	① FLOORING	12	0.086	$\gamma_i = 0.125$	1.59
	② AIR SPACE			0.2	
	③ CONCRETE	130	0.093		
	④ DECK PLATE	1.2	-		
				$\gamma_i = 0.125$ (0.629)	

255

HEAT TRANSMISSION : K-Value

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE (m ² H°C/Kcal)	AIR FILM (m ² H°C/Kcal)	K-Value (Kcal/m ² H°C)	
WALL 1 				$\gamma_o = 0.05$		
	① PRECAST CONCRETE	120	0.086			
	② GLASS WOOL	50	1.36			
	③ AIR SPACE			0.2		
	④ PLASTER BOARD	12	0.064			
				$\gamma_i = 0.133$ (1.893)	0.53	
WALL 2 				$\gamma_o = 0.05$		
	① CONCRETE BLOCK	150	0.334			
	② AIR SPACE			0.2		
	③ PLASTER BOARD	12	0.064			
					$\gamma_i = 0.133$ (0.781)	1.29
WALL 3 				$\gamma_o = 0.05$		
	① STEEL	—	—			
	② GLASS WOOL	50	1.36			
	③ AIR SPACE			0.2		
	④ PLASTER BOARD	12	0.064			
				$\gamma_i = 0.133$ (1.807)	0.56	
PARTITION 1 				$\gamma_i = 0.133$		
	① CONCRETE BLOCK	150	0.334			
	② PLASTER BOARD	12	0.064			
					$\gamma_i = 0.133$ (0.664)	1.51
PARTITION 2 				$\gamma_i = 0.133$		
	① PLASTER BOARD	12	0.064			
	② AIR SPACE			0.2		
	③ PLASTER BOARD	12	0.064			
					$\gamma_i = 0.133$ (0.594)	1.69

956

4. ROOM LOAD SUMMARY

4-1. AC-Z

1) ROOM PEAK LOAD

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(%)	DEHUM AIR (m ³ /H)	OUT AIR (m ³ /H)
					R.S.H (Kcal/H)	R.T.H (Kcal/H)			
OPER. FLOOR 0-2	CENTRAL CONTROL ROOM	328. ²⁹	978. ⁸⁷	5	42.936	43.656	12.9		650
	SUB TOTAL.				42.936	43.656	12.6	14,500	650
FORTH FLOOR F-1	SHIFT ROOM	56.0	156. ⁸	6	4.365	4.791	12.2	1470	150
F-2	REST ROOM	19.6	54. ⁸⁸	2	1.273	1.415	12.1	450	50
F-3	CONFERENCE RM.	88.0	246. ⁴	10	5.358	6.169	11.8	1,850	400
F-4	ELECTRICAL & INSTRUMENT REPAIR ROOM	198.0	554.4	6	10.023	10.551	12.5	3,400	300
F-5	PABX ROOM	67. ⁶⁸	189. ⁵	4	3.938	4.223	12.4	1,330	100
	SUB TOTAL				24.957	27.149		8,500	1000
	TOTAL				67.893	70.805	12.6	23,000	1,650
					SHF = 0.96				

958

2). LOAD SUMMARY (TIME)

NO.	ROOM NAME	3:00		4:00		5:00	
		E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)
OPER 0-2	CENTRAL CONTROL ROOM	* 42.936	* 43.656	42.568	43.278	41.670	42.380
	SUB TOTAL	42.936	43.656	42.568	43.278	41.670	42.380
4F							
F-1	SHIFT ROOM	4.358	4.786	* 4.365	* 4.791	4.215	4.641
F-2	REST ROOM	1.175	1.318	* 1.273	* 1.415	1.166	1.308
F-3	CONFERENCE ROOM	5.331	6.159	* 5.358	* 6.169	5.307	6.118
F-4	ELECTRICAL & INSTRUMENT REPAIR ROOM	9.905	10.437	* 10.023	* 10.551	10.013	10.541
F-5	PABX ROOM	3.811	4.096	3.926	4.220	* 3.938	* 4.223
	SUB TOTAL	24.580	26.796	24.945	27.146	24.639	26.831
AC-2	TOTAL	* 67.516	* 70.452	67.513	70.424	66.309	69.211

RSP

4-2 AC-1

3100

9

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	R. S. H (Kcal/h)	R. T. H (Kcal/h)	INDICATED A.D.P.(°C)	DEHUM.AIR (m ³ /h)	OUT.AIR (m ³ /h)
OPER. FLOOR 0-1	COMPUTER ROOM UNIT NO. 2	84.0	252	4	23.754	24.040	13.0	8.400	100
0-3	COMPUTER ROOM UNIT NO. 1	127.21	381.63	6	35.257	35.685	13.0	12.300	150
TOTAL		211.21	633.63	10	59.011	59.725	13.0	20.700	250

SHF=0.99

4-3 AC-3

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	R. S. H (Kcal/h)	R. T. H (Kcal/h)	INDICATED A.D.P.(°C)	DEHUM.AIR (m ³ /h)	OUT.AIR (m ³ /h)
MEZZ. FLOOR M-1	UNIT NO. 1 & NO. 2 CONTROL EQUIPMENT ROOM	216.33	605.73	6	41.732	42.160	13	14.600	150
TOTAL		216.33	605.73	6	41.732	42.160	13	14.600	150

SHF=0.99

4-4 AC-4

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	R. S. H (Kcal/h)	R. T. H (Kcal/h)	INDICATED A.D.P.(°C)	DEHUM.AIR (m ³ /h)	OUT.AIR (m ³ /h)
MEZZ FLOOR M-1	FUEL LABORATORY	65.57	183.60	4	6.265	6.605	12.5	2.200	100
M-2	WATER ANALYTICAL INSTRUMENT ROOM	134.75	377.3	7	12.970	13.464	12.6	4.400	210
TOTAL				11	19.235	20.069	12.6	6.600	310

SHF=0.96

096

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **CENTRAL CONTROL ROOM (0-2)** SYSTEM _____
 SIZE m x m = **328.29** m² x **3** m(H) = **978.87** m³

SHEET No. **10**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP DIFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				3:00	CORRECTION	5:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)			
(SE)	3.0 m ²	252.074/28.5 x 0.94 x 0.65		131	115	98	OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
	m ²	x					CONDITIONS	DB C	WB C	%RH
	m ²	x					OUTSIDE	42.2	28.6	37
	m ²	x					ROOM	24.0		50
	m ²	x					DIFFERENCE	18.2	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D			
WALL (SE)	132.0 m ²	13.1 x 0.56		969	932	887	GLASS	ORDINARY, THICK, ABSORBENT.	%	DOUBLE
	m ²	x					COLOR	LIGHT, MEDIUM, DARK.		
	m ²	x					WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)	
	m ²	x					INTERNAL HEAT	W/m ²	m ² /PEOPLE	
ROOF - SUN	m ²	x					INFILTRATION			
ROOF - SHADED	m ²	x					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.			
GLASS	3.0 m ²	18.2 x 5.1		279	271	258	OPEN DOORS	DOORSX	CMH/DOOR	
CEILING	75.04 m ²	9.1 x 1.16		793	771	719	EXHAUST AIR			
FLOOR	328.29 m ²	9.1 x 2.52		7529	7322	6826	CRACK	m X	CMH/m	
PARTITION (1)	93.74 m ²	9.1 x 1.51		1014	986	919	INFILTRATION	CMH		
	(2) 2.7 m ²	9.1 x 1.69		42	41	38	VENTILATION			
DOOR (IN)	5.4 m ²	9.1 x 2.15		106	103	96	5 PEOPLEX	25	CMH/PER.	125
GLASS (IN)	3.66 m ²	9.1 x 5.8		127	123	115	m ²	CMH/m ²		↓
INTERNAL HEAT							VENTILATION			
PEOPLE	5 PEOPLEX	41		205	205	205	SENSIBLE HEAT FACTOR			
Kw	29.7 Kw X	0.8 x	860	20434	20430	20434	E.S.H.F. = $\frac{42.936}{43.656}$ (ERSH) = 0.98 (12.9°C)			
LIGHTS	328.29 x 20 W X	1.08		7091	7091	7091	TERTH) =			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE							APPARATUS DEWPOINT 12.6 °C			
	m ²	deg X					$\frac{42.936}{12.6 \text{ (LADP)} (1 - BF) \times 0.29} = 14.500 \text{ CMH}$			
SUB TOTAL										
SAFETY FACTOR		%					NOTES			
ROOM SENSIBLE HEAT SUB TOTAL				38720	38794	37887	SR = $23.0 \times 13.15 + 6.0 + \frac{(3.05 + 5.0) \times 1.5}{2} = 328.29$			
SUPPLY DUCT	SUPPLY DUCT	FAN					GLASS (SE): $1.5 \times 1.0 \times 2 = 3.0$			
HEAT GAIN	- LEAK LOSS	- HP	= 10%	3872	386	379	WALL (SE): $27.0 \times 5.0 - 3.0 = 132.0$			
BYPASS OUTSIDE AIR	650 CMH X	18.2 deg. C	0.1 BF x 0.29	344	334	215	PARTITION (1): $27.0 \times 3.0 - (3.66 + 3.6) = 73.74$			
EFFECTIVE ROOM SENSIBLE HEAT				42936	42568	41670	(2): $1.5 \times 3.0 - 1.3 = 2.7$			
ROOM LATENT HEAT							DOOR (IN): $0.9 \times 2.0 \times 3 = 5.4$			
INFILTRATION	CMH X	e/kg X	0.72				GLASS (IN): $3.05 \times 1.2 = 3.66$			
PEOPLE	5 PEOPLE X	49		245			CEILING: $23.0 \times 3.0 + \frac{(3.05 + 5.0) \times 1.5}{2} = 75.04$			
STEAM	kg/h X	540					FLOOR: SR			
APPLIANCES ETC.										
VAPOR TRANS.										
SUB TOTAL										
SAFETY FACTOR		%								
ROOM LATENT HEAT SUB TOTAL				245	245	245				
SUPPLY DUCT LEAKAGE LOSS		10%		25	25	25				
BYPASS OUTSIDE AIR	650 CMH X	9.6 e/kg X	0.1 BF X 0.72	450	440	440				
EFFECTIVE ROOM LATENT HEAT				720	710	710				
EFFECTIVE ROOM TOTAL HEAT				43656	42778	42380				
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29								
LATENT:	CMH X	e/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT SUB TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	- H.P.	- GAIN	= %						
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **SHIFT ROOM (E-1)** SYSTEM _____
 SIZE $m \times m \times 56.0 \text{ m}$ $\times 2.8 \text{ m(H)}$ $= 156.8 \text{ m}^3$

SHEET NO. **11**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP DIFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 4	
				4:00	5:00	3:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)				
(SE)	3.0	$m^2 \times 253 \times 0.2 / 0.85 \times 0.94 \times 0.65$		115	98	131	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
(NE)	1.5	$m^2 \times 266 \times 0.15 / 0.85 \times 0.94 \times 0.65$		60	52	64	CONDITIONS DB C WB C %RH DP C g/kg				
	$m^2 \times$	\times					OUTSIDE	21.7	28.4	38	18.8
	$m^2 \times$	\times					ROOM	24.0	50		94
	$m^2 \times$	\times					DIFFERENCE	17.7	X X X	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L M D				
WALL (SE)	32.48	$m^2 \times 12.6$	$\times 0.56$	230	219	239	GLASS (ORDINARY, THICK, ABSORBENT, % DOUBLE				
(NE)	32.52	$m^2 \times 13.7$	$\times 0.56$	250	248	237	COLOR (LIGHT, MEDIUM, DARK.				
	$m^2 \times$	\times					WEIGHT		kg/m^2 (FLOOR)		kg/m^2 (WALL)
	$m^2 \times$	\times					INTERNAL HEAT		W/m^2		m^2 /PEOPLE
ROOF - SUN	56.0	$m^2 \times 26.2$	$\times 0.46$	675	717	619	INFILTRATION				
ROOF - SHADED	$m^2 \times$	\times					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.				
GLASS	4.5	$m^2 \times 17.7$	$\times 5.1$	407	379	418	OPEN DOORS DOORS X CMH/DOOR				
CEILING	$m^2 \times$	\times					EXHAUST AIR				
FLOOR	25.65	$m^2 \times 8.85$	$\times 1.16$	264	246	271	CRACK $m \times$ CMH/m				
PARTITION (1)	12.76	$m^2 \times 8.85$	$\times 1.51$	171	123	176	INFILTRATION CMH				
(2)	15.68	$m^2 \times 8.85$	$\times 1.69$	235	196	242	VENTILATION				
DOOR (IN)	1.8	$m^2 \times 8.85$	$\times 2.15$	35	32	36	6 PEOPLE X	25	CMH/PER.	150	
INFILTRATION	CMH X	deg X	0.29				$m^2 \times$	CMH/m ²			
INTERNAL HEAT							VENTILATION CMH				
PEOPLE	6	PEOPLE X	41	246	246	246	SENSIBLE HEAT FACTOR				
Kw	Kw X	\times	860				E.S.H.F. = $\frac{4365}{4791}$ (ERSH) = 0.91 (12.2)				
LIGHTS	56.0×20	WX	1.08	1210	1210	1210	DEHUMIDIFIED AIR				
APPLIANCES ETC.							APPARATUS DEWPOINT 12.6 C				
CREDIT FOR THERMAL STORAGE	$m^2 \times$	deg X	-1	(-)	(-)		$\frac{4365}{(24 \text{ RM} - 126 \text{ ADP}) (1 - BF) \times 0.29} = 1470 \text{ CMH}$				
Sub TOTAL											
SAFETY FACTOR %											
ROOM SENSIBLE HEAT Sub TOTAL				3898	3766	3889	NOTES				
SUPPLY DUCT	SUPPLY DUCT	FAN					GLASS (SE) : $1.0 \times 1.5 \times 2 = 3.0$				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	390	377	389	(NE) : $1.0 \times 1.5 = 1.5$				
BYPASS OUTSIDE AIR 150 CMH X 19.7 deg X 0.1 BF X 0.29				77	72	80	WALL (SE) : $7.3 \times 4.86 - 3.0 = 32.48$				
EFFECTIVE ROOM SENSIBLE HEAT				4365	4715	4358	(NE) : $7.0 \times 4.86 - 1.5 = 32.52$				
ROOM LATENT HEAT							PARTITION (1) : $5.2 \times 2.8 - 1.8 = 12.76$				
INFILTRATION	CMH X	g/kg X	0.72				(2) : $5.6 \times 2.8 = 15.68$				
PEOPLE	6 PEOPLE X	49		294		294	DOOR (IN) : $0.9 \times 2.0 = 1.8$				
STEAM	kg/h X	540					FLOOR : $3.3 \times 7.0 + 1.7 \times 1.5 = 25.65$				
APPLIANCES ETC.							ROOF : SR				
VAPOR TRANS.							SR = $7.3 \times 7.0 + 1.4 \times 3.5 = 56.0$				
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL				294	294	294					
SUPPLY DUCT LEAKAGE LOSS (10 %)				30	30	30					
BYPASS OUTSIDE AIR $150 \text{ CMH} \times 9.4 \text{ g/kg} \times 0.1 \text{ BF} \times 0.72$				102	102	104					
EFFECTIVE ROOM LATENT HEAT				426	426	428					
EFFECTIVE ROOM TOTAL HEAT				4791	4641	4786					
OUTSIDE AIR HEAT											
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29									
LATENT:	CMH X	g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	- H.P.	- GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR REST ROOM (F-2) SYSTEM _____
 SIZE 5.6 m x 3.5 m = 19.6 m² x 2.8 m(H) = 54.88 m³

SHEET NO. 12
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR:	AM PM	PEAK LOAD	AM PM		
				4:00	5:00	3:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
(SE)	1.5	m ² x 252 x 0.71 / 0.85 x 0.94 x 0.65		58	49	66	OUTSIDE DESIGN CONDITIONS: CDB CWB %RH					
	m ² x	X					CONDITIONS:	DB °C	WB °C	%RH	DP °C	g/kg
	m ² x	X					OUTSIDE	41.7	28.4	38		18.8
	m ² x	X					ROOM	24.0		50		9.4
	m ² x	X					DIFFERENCE	17.7	X X X	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D					
WALL (SE)	15.51	m ² x 12.6 x 0.56		196	105	114	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² x	X					COLOR LIGHT, MEDIUM, DARK.					
	m ² x	X					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)					
	m ² x	X					INTERNAL HEAT W/m ² m ² /PEOPLE					
ROOF - SUN	19.6	m ² x 26.2 x 0.46		237	251	217	INFILTRATION					
ROOF - SHADED		m ² x X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.					
GLASS	1.5	m ² x 17.7 x 5.1		136	127	140	OPEN DOORS DOORS X CMH/DOOR					
CEILING		m ² x X					EXHAUST AIR					
FLOOR		m ² x X					CRACK m x CMH/m					
PARTITION		m ² x X					INFILTRATION CMH					
INTERNAL HEAT							VENTILATION					
PEOPLE	2	PEOPLE X 41		82	82	82	2 PEOPLE X 25 CMH/PER. 50					
KW		KW X X	860				m ² x CMH/m ²					
LIGHTS	19.6	x 20 WX	1.08	424	424	424	VENTILATION CMH 50					
APPLIANCES ETC.							SENSIBLE HEAT FACTOR					
CREDIT FOR THERMAL STORAGE							E.S.H.F. = $\frac{1.273}{14.15} \left(\frac{IERSH}{IERTH} \right) = 0.9 (12.1)$					
DEHUMIDIFIED AIR							APPARATUS DEWPOINT 12.6 °C					
SUB TOTAL							$\frac{1.273}{14.15} \left(\frac{IERSH}{IERTH} \right) \times 4.30 \text{ CMH}$					
SAFETY FACTOR							NOTES					
ROOM SENSIBLE HEAT SUB TOTAL							GLASS (SE): 1.0 x 1.5 = 1.5					
SUPPLY DUCT		SUPPLY DUCT FAN		114	104	105	WALL (SE): 3.5 x 4.86 x 1.5 = 15.51					
HEAT GAIN		+ LEAK LOSS - HP = 10%		26	24	27						
BYPASS OUTSIDE AIR	50	CMH x 17.7 deg x 0.1 BF x 0.29		1273	1166	1175						
EFFECTIVE ROOM SENSIBLE HEAT												
ROOM LATENT HEAT												
INFILTRATION		CMH x g/kg x 0.72		98	98	98						
PEOPLE	2	PEOPLE x 49										
STEAM		kg/h x 540										
APPLIANCES ETC.												
VAPOR TRANS.												
SUB TOTAL												
SAFETY FACTOR												
ROOM LATENT HEAT SUB TOTAL												
SUPPLY DUCT		LEAKAGE LOSS 10%		10	10	10						
BYPASS OUTSIDE AIR	25	CMH x 9.4 g/kg x 0.1 BF x 0.72		34	34	35						
EFFECTIVE ROOM LATENT HEAT												
EFFECTIVE ROOM TOTAL HEAT												
OUTSIDE AIR HEAT												
SENSIBLE:		CMH x deg x (1 - BF) x 0.29										
LATENT:		CMH x g/kg x (1 - BF) x 0.72										
GRAND TOTAL HEAT SUB TOTAL												
RETURN DUCT		RETURN DUCT PUMP PIPE = %										
HEAT GAIN		+ LEAK GAIN H.P. + GAIN										
(U.S.R.T.) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY No. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **CONFERENCE ROOM** (F-3) SYSTEM _____
 SIZE **8.0** m² x **11** m² x **88** m³ x **2.8** m/H = **216.4** m³

SHEET No. **13**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 4
					CORRECTION					
SOLAR GAIN - GLASS				4100	5:00	3:00	HOURS OF OPERATION Hour (-)			
(SE) GLASS	4.5 m ² x 252 x 0.216 x 0.94 x 0.65			172	147	196	OUTSIDE DESIGN CONDITIONS °C DB °C WB °C %RH DP °C g/kg			
	m ² x x						CONDITIONS OUTSIDE 41.7 22.9 38 ROOM 24.0 50 DIFFERENCE 17.7 x x x x x x x 9.4			
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE (OUTSIDE, INSIDE) L M D)			
WALL (SE)	34.38 m ² x 12.6 x 0.56			243	231	253	GLASS ORDINARY THICK. ABSORBENT. % DOUBLE			
	m ² x x						COLOR LIGHT. MEDIUM. DARK.			
	m ² x x						WEIGHT kg/m² (FLOOR) kg/m² (WALL)			
	m ² x x						INTERNAL HEAT W m² m²/PEOPLE			
ROOF - SUN	88 m ² x 26.2 x 0.46			1061	1126	972	INFILTRATION			
ROOF - SHADED	m ² x x						SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.			
GLASS	4.5 m ² x 17.7 x 5.1			407	379	418	OPEN DOORS DOORS X CMH/DOOR			
CEILING	m ² x x						EXHAUST AIR			
FLOOR	m ² x x						CRACK m x CMH/m			
PARTITION (1)	18.8 m ² x 8.85 x 1.51			252	235	259	INFILTRATION CMH			
(2)	11.2 m ² x 8.85 x 1.69			168	157	173	VENTILATION			
DOOR	3.6 m ² x 8.85 x 2.15			69	64	71	10 PEOPLE X 25 CMH/PER. 250			
INFILTRATION	CMH x deg x 0.29						m² x CMH/m² 400			
INTERNAL HEAT							VENTILATION CMH 400			
PEOPLE	10 PEOPLE x 41			410	410	410	SENSIBLE HEAT FACTOR			
KW	KW x x 860						E.S.H.F. = 5.358 (ERSH) = 0.87 (11.8°C)			
LIGHTS	88.0 x 20 W x 1.08			1901	1901	1901	6.169 (ERTH)			
APPLIANCES ETC.							DERHUMIDIFIED AIR			
							APPARATUS DEWPOINT 12.6 °C			
							5358 (ERSH)			
CREDIT FOR THERMAL STORAGE	m ² x deg x						12 ARM. 12.6 ADP (1 - BF) x 0.29 = 1800 CMH			
Sub TOTAL										
SAFETY FACTOR %							NOTES			
ROOM SENSIBLE HEAT Sub TOTAL				4683	4650	4653	GLASS (SE): 1.0 x 1.5 x 3 = 4.5			
SUPPLY DUCT	SUPPLY DUCT FAN						WALL (SE): 8.0 x 4.86 - 4.5 = 34.38			
HEAT GAIN	- LEAK LOSS + HP = 10%			469	465	466	PARTITION (1): 8.0 x 2.8 - 3.6 = 18.8			
BYPASS OUTSIDE AIR	400 CMH x 17.7 deg x 0.1 BF x 0.29			206	192	212	(2): 4.0 x 2.8 = 11.2			
EFFECTIVE ROOM SENSIBLE HEAT				5358	5307	5351	ROOF: SR			
ROOM LATENT HEAT							DOOR (IN): 1.8 x 2.0 = 3.6			
INFILTRATION	CMH x g/kg x 0.72									
PEOPLE	10 PEOPLE x 49			490		490				
STEAM	kg/h x 540									
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL				490	490	490				
SUPPLY DUCT	LEAKAGE LOSS 10%			50	50	50				
BYPASS OUTSIDE AIR	400 CMH x 9.4 g/kg x 0.1 BF x 0.72			271	271	288				
EFFECTIVE ROOM LATENT HEAT				811	811	828				
EFFECTIVE ROOM TOTAL HEAT				6169	6118	6159				
OUTSIDE AIR HEAT										
SENSIBLE:	CMH x deg x (1 - BF) x 0.29									
LATENT:	CMH x g/kg x (1 - BF) x 0.72									
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT PUMP PIPE = %									
HEAT GAIN	LEAK GAIN H.P. GAIN									
(U.S.R.T) GRAND TOTAL HEAT										

196

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.	INQUIRED BY	SHEET NO. 14
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR ELECTRICAL & INSTRUMENT REPAIR ROOM (F-4)	SYSTEM	REVISION
SIZE 18.0 m x 11.0 m = 198.0 m²	x 2.8 m(H) = 554.4 m³	PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
				4:00	5:00	3:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION				
(SE)	6.0 m ²	252 x 0.21 / 0.85 x 0.94 x 0.65		229	196	261	OUTSIDE DESIGN CONDITIONS				
	m ²	x					DB °C	WB °C	%RH	DP °C	g/kg
	m ²	x					41.7	28.4	38		18.8
	m ²	x					ROOM	24.0	50		9.4
	m ²	x					DIFFERENCE	17.7	x x x	x x x	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND				
WALL (SE)	81.48 m ²	12.0 x 0.56		575	548	598	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.				
	m ²	x					GLASS				
	m ²	x					ORDINARY THICK. ABSORBENT. % DOUBLE				
	m ²	x					COLOR				
	m ²	x					LIGHT. MEDIUM. DARK.				
	m ²	x					WEIGHT				
	m ²	x					kg/m ² (FLOOR) kg/m ² (WALL)				
	m ²	x					INTERNAL HEAT				
	m ²	x					W/m ² m ² /PEOPLE				
ROOF - SUN	198.0 m ²	26.2 x 0.46		2387	2532	2186	INFILTRATION				
ROOF - SHADED	m ²	x					SWINGING				
	m ²	x					REVOLVING DOORS PEOPLE X CMH/PER				
	m ²	x					OPEN DOORS DOORS X CMH/DOOR				
	m ²	x					EXHAUST AIR				
	m ²	x					CRACK m x CMH/m				
	m ²	x					INFILTRATION CMH				
	m ²	x					VENTILATION				
	m ²	x					6 PEOPLE X 25 CMH/PER. 150				
	m ²	x					m ² CMH/m ² ↓				
	m ²	x					VENTILATION				
	m ²	x					CMH 300				
	m ²	x					INTERNAL HEAT				
	m ²	x					PEOPLE 6 PEOPLE X 41				
	m ²	x					Kw Kw X 860				
	m ²	x					LIGHTS 198.0 x 20 W X 1.08				
	m ²	x					APPLIANCES ETC.				
	m ²	x					DEHUMIDIFIED AIR				
	m ²	x					APPARATUS DEWPOINT 12.6 °C				
	m ²	x					10023 (ERSH)				
	m ²	x					(24 RM - 12.6 ADP) (1 - BF) X 0.29 = 3.400 CMH				
	m ²	x					NOTES				
	m ²	x					GLASS (SE): 1.0 x 1.5 x 4 = 6.0				
	m ²	x					WALL (SE): 18.0 x 4.86 - 6.0 = 81.48				
	m ²	x					PARTITION: 18.0 x 2.8 - 7.2 = 43.2				
	m ²	x					DOOR (IN): 1.8 x 2.0 x 2 = 7.2				
	m ²	x					ROOF : SR				
	m ²	x					ROOM SENSIBLE HEAT SUB TOTAL				
	m ²	x					8977 8977 8860				
	m ²	x					SUPPLY DUCT SUPPLY DUCT FAN				
	m ²	x					HEAT GAIN - LEAK LOSS +HP = 10%				
	m ²	x					898 898 886				
	m ²	x					BYPASS OUTSIDE AIR				
	m ²	x					300 CMH x 17.7 deg x 0.1 BF x 0.29				
	m ²	x					154 144 159				
	m ²	x					EFFECTIVE ROOM SENSIBLE HEAT				
	m ²	x					10023 10023 9905				
	m ²	x					ROOM LATENT HEAT				
	m ²	x					INFILTRATION CMH X g/kg X 0.72				
	m ²	x					PEOPLE 6 PEOPLE X 49				
	m ²	x					294 294				
	m ²	x					STEAM kg/h X 540				
	m ²	x					APPLIANCES ETC.				
	m ²	x					VAPOR TRANS.				
	m ²	x					Sub Total				
	m ²	x					SAFETY FACTOR				
	m ²	x					%				
	m ²	x					ROOM LATENT HEAT SUB TOTAL				
	m ²	x					294 294 294				
	m ²	x					SUPPLY DUCT LEAKAGE LOSS				
	m ²	x					10 %				
	m ²	x					30 30 30				
	m ²	x					BYPASS OUTSIDE AIR				
	m ²	x					300 CMH X 9.4 g/kg X 0.1 BF X 0.72				
	m ²	x					204 204 208				
	m ²	x					EFFECTIVE ROOM LATENT HEAT				
	m ²	x					528 528 532				
	m ²	x					EFFECTIVE ROOM TOTAL HEAT				
	m ²	x					10551 10541 10437				
	m ²	x					OUTSIDE AIR HEAT				
	m ²	x					SENSIBLE: CMH X deg X (1 - BF) X 0.29				
	m ²	x					LATENT: CMH X g/kg X (1 - BF) X 0.72				
	m ²	x					GRAND TOTAL HEAT SUB TOTAL				
	m ²	x					RETURN DUCT + RETURN DUCT - PUMP PIPE				
	m ²	x					HEAT GAIN - LEAK GAIN H.P. - GAIN = %				
	m ²	x					(U.S.R.T) GRAND TOTAL HEAT				

965

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO.	INQUIRED BY	SHEET NO. 15
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR PBX ROOM (F-5)	SYSTEM	REVISION
SIZE $m \times m = 67.68 m^2$	x $2.8 m(H) = 189.50 m^3$	PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				5:00	CORRECTION	4:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION	Hour (-)		
	$m^2 \times$	x					OUTSIDE DESIGN CONDITIONS	'CDB	'CWB	%RH
	$m^2 \times$	x					CONDITIONS: DB °C	WB °C	%RH	DP °C
	$m^2 \times$	x					OUTSIDE	40.5	28.2	79
	$m^2 \times$	x					ROOM	24.0		50
	$m^2 \times$	x					DIFFERENCE	16.5	xxx	xxx
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.		
WALL (SE)	33.05 $m^2 \times$	12.0 x	0.56	222	243	234	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
(SW)	41.80 $m^2 \times$	20.4 x	0.56	478	419	476	COLOR	LIGHT, MEDIUM, DARK.		
	$m^2 \times$	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)
	$m^2 \times$	x					INTERNAL HEAT	W/m ² m ² /PEOPLE		
ROOF - SUN	67.68 $m^2 \times$	27.8 x	0.46	866	748	816	INFILTRATION			
ROOF - SHADED	$m^2 \times$	x					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER			
GLASS	$m^2 \times$	x					OPEN DOORS DOORS X CMH/DOOR			
CEILING	$m^2 \times$	x					EXHAUST AIR			
FLOOR	$m^2 \times$	x					CRACK m x CMH/m			
PARTITION	22.40 $m^2 \times$	8.25 x	1.51	280	309	300	INFILTRATION CMH			
DOOR (IN)	36 $m^2 \times$	8.25 x	2.15	64	91	69	VENTILATION			
INFILTRATION	CMH X	deg X	0.29				4 PEOPLE X 25 CMH/PER. 100			
INTERNAL HEAT							VENTILATION CMH			
PEOPLE	4 PEOPLE X	41		164	164	164	SENSIBLE HEAT FACTOR			
Kw	Kw X	x	860				E.S.H.F. = 3938 (ERSH) = 0.93 (12.4)			
LIGHTS	67.68 x 20 W X		1.08	1462	1462	1462	4223 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE							APPARATUS DEWPOINT 12.6 °C			
Sub TOTAL							3938 (ERSH)			
SAFETY FACTOR %							(24 RM - 12.6 ADP) (1 - BF) X 0.29 = 1330 CMH			
ROOM SENSIBLE HEAT Sub TOTAL				3536	3410	3521	NOTES			
SUPPLY DUCT	SUPPLY DUCT	FAN					SR = 68 x 11.0 - 285 x 2.5 = 67.68			
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	354	342	353	WALL (SE): 6.8 x 4.86 = 33.05			
BYPASS OUTSIDE AIR 100 CMH x 16.5 deg x 0.1 BF x 0.29				48	53	52	(SW): 8.6 x 4.86 = 41.80			
EFFECTIVE ROOM SENSIBLE HEAT				2938	3811	3926	PARTITION: 9.3 x 2.8 - 3.6 = 22.94			
ROOM LATENT HEAT							DOOR (IN): 1.8 x 2.0 = 3.6			
INFILTRATION	CMH X	g/kg X	0.72				ROOF: SR			
PEOPLE	4 PEOPLE X	49		196	196	196				
STEAM		kg/h X	540							
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL				196	196	196				
SUPPLY DUCT	LEAKAGE LOSS		10%	20	20	20				
BYPASS OUTSIDE AIR 100 CMH x 9.5 g/kg x 0.1 BF x 0.72				69	69	68				
EFFECTIVE ROOM LATENT HEAT				285	285	284				
EFFECTIVE ROOM TOTAL HEAT				4223	4096	4220				
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29								
LATENT:	CMH X	g/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	- H.P.	- GAIN	= %						
(U.S.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INSURING No. _____ INSURED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR COMPUTER RM. UNIT No. 2 (0-1) SYSTEM _____
 SIZE 12.0 m x 7.0 m = 84 m² x 3.0 m H = 252 m³

SHEET No. 16
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h	
				3:00	CORRECTION
SOLAR GAIN -- GLASS					
m ² X		X			
m ² X		X			
m ² X		X			
m ² X		X			
m ² X		X			
SOLAR & TRANS GAIN--WALLS & ROOF					
WALL	m ² X	X			
m ² X		X			
m ² X		X			
m ² X		X			
ROOF--SUN	m ² X	X			
ROOF--SHADED	m ² X	X			
TRANS. GAIN--EXCEPT WALLS & ROOF					
GLASS	m ² X	X			
CEILING	49.0 m ² X	9.1 X	1.16	518	
FLOOR	84.0 m ² X	9.1 X	1.59	1216	
PARTITION(1)	13.5 m ² X	9.1 X	1.51	186	
(2)	50.0 m ² X	9.1 X	1.69	776	
DOOR(IN)	3.6 m ² X	9.1 X	2.15	71	
INFILTRATION	CMHX	deg X	0.29		
INTERNAL HEAT					
PEOPLE	4 PEOPLE X 41			164	
Kw	Kw X	X	860	16800	
LIGHTS	84.0 x 20 W X		1.08	1815	
APPLIANCES ETC.					
CREDIT FOR THERMAL STORAGE					
	m ² X	deg X			
Sub TOTAL					
SAFETY FACTOR					
ROOM SENSIBLE HEAT SUB TOTAL				21546	
SUPPLY DUCT	SUPPLY DUCT	FAN			
HEAT GAIN	+LEAK LOSS	-HP	=10%	2155	
BYPASS OUTSIDE AIR	100 CMH X 18.2 deg X 0.1 BF X 0.29			53	
EFFECTIVE ROOM SENSIBLE HEAT				23754	
ROOM LATENT HEAT					
INFILTRATION	CMHX	g/kg X	0.72		
PEOPLE	4 PEOPLE X 49			196	
STEAM	kg/h X		540		
APPLIANCES ETC.					
VAPOR TRANS.					
Sub TOTAL					
SAFETY FACTOR					
ROOM LATENT HEAT SUB TOTAL				196	
SUPPLY DUCT	LEAKAGE LOSS		10%	20	
BYPASS OUTSIDE AIR	100 CMH X 9.6 g/kg X 0.1 BF X 0.72			70	
EFFECTIVE ROOM LATENT HEAT				286	
EFFECTIVE ROOM TOTAL HEAT				24040	
OUTSIDE AIR HEAT					
SENSIBLE:	CMHX	deg X (1 - BF) X 0.29			
LATENT:	CMHX	g/kg X (1 - BF) X 0.72			
GRAND TOTAL HEAT SUB TOTAL					
RETURN DUCT	RETURN DUCT	PUMP	PIPE		
HEAT GAIN	LEAK GAIN	H.P	GAIN	= %	
(U.S.R.T) GRAND TOTAL HEAT					

ESTIMATE FOR:	AM PM	PEAK LOAD	AM PM3
HOURS OF OPERATION	Hour (
OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
CONDITIONS	DB C	WB C	%RH DP C g/kg
OUTSIDE	42.2	28.6	37 19.0
ROOM	24.0	50	9.4
DIFFERENCE	18.2	X X X	X X X X X 9.6
BLIND	(NON-EXISTENCE) (OUTSIDE, INSIDE) L M D		
GLASS	ORDINARY, THICK, ABSORBENT, % DOUBLE		
COLOR	LIGHT, MEDIUM, DARK		
WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)	
INTERNAL HEAT	W/m ²	m ² /PEOPLE	
INFILTRATION			
SWINGING			
REVOLVING DOORS	PEOPLES	CMH/PER	
OPEN DOORS	DOORS	CMH/DOOR	
EXHAUST AIR			
CRACK	m X	CMH/m	
INFILTRATION	CMH		
VENTILATION			
4 PEOPLES X	25 CMH/PER	100	
m ² X	CMH/m ²		
VENTILATION	CMH		100
SENSIBLE HEAT FACTOR			
E.S.H.F =	23754 (ERSH)	= 0.99 (13°C)	
	24040 (ERTH)		
DEHUMIDIFIED AIR			
APPARATUS DEWPOINT		13°C	
	23754 (ERSH)		
24 RM - 13 ADP (1 - BF) X 0.29		= 8400 CMH	

NOTES

PARTITION(1) : 4.5 x 3.0 = 13.5
 (2) : 18.0 x 3.0 - 3.6 = 50.4

DOOR(IN) : 1.8 x 2.0 = 3.6
 CEILING : 7.0 x 7.0 = 49.0
 FLOOR : SR

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **COMPUTER ROOM UNIT NO.1 (0-3)** SYSTEM _____
 SIZE m x m = **127.21 m²** x **3.0 m** H = **381.63 m³**

SHEET NO **17**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3	
				3:00	CORRECTION					
SOLAR GAIN - GLASS						HOURS OF OPERATION Hour (-)				
	m ²	X				OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH				
	m ²	X				CONDITIONS DB °C WB °C %RH DP °C E/KG				
	m ²	X				OUTSIDE	42.2	28.6	37	19.0
	m ²	X				ROOM	24.0	50		9.4
	m ²	X				DIFFERENCE	18.2	X X X	X X X	9.6
SOLAR & TRANS GAIN - WALLS & ROOF						BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L. M. D				
WALL (SE)	51.5 m ²	13.1 X	0.56	378		GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
(SW)	43.0 m ²	17.9 X	0.56	431		COLOR LIGHT, MEDIUM, DARK.				
	m ²	X				WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)				
	m ²	X				INTERNAL HEAT W/m ² m ² /PEOPLE				
ROOF - SUN	m ²	X				INFILTRATION				
ROOF - SHADED	m ²	X				SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF						REVOLVING DOORS PEOPLE X CMH/PER.				
GLASS	m ²	X				OPEN DOORS DOORS X CMH/DOOR				
CEILING	22.35 m ²	9.1 X	1.16	236		EXHAUST AIR				
FLOOR	127.21 m ²	9.1 X	1.59	1841		CRACK m X CMH/m				
PARTITION	42.75 m ²	9.1 X	1.51	588		INFILTRATION CMH				
DOOR	3.6 m ²	9.1 X	2.15	71		VENTILATION				
INFILTRATION	CMH X	deg X	0.29			6 PEOPLE X 25 CMH/PER. 150				
INTERNAL HEAT						VENTILATION CMH 150				
PEOPLE	6 PEOPLE X	41		246		SENSIBLE HEAT FACTOR				
KW	KW X	X	860	25440		E.S.H.F. = $\frac{35257 \text{ (ERSH)}}{35685 \text{ (ERTH)}} = 0.99 (13^{\circ}\text{C})$				
LIGHTS	127.21 X 20 W X	1.08		2748		DEHUMIDIFIED AIR				
APPLIANCES ETC.						APPARATUS DEWPOINT 13.0 °C				
CREDIT FOR THERMAL STORAGE	m ²	deg X				35.257 (ERSH)				
						$(24 \text{ RM} - 13 \text{ ADP}) (1 - \text{BF}) \times 0.29 = 12.300 \text{ CMH}$				
SUB TOTAL						NOTES				
SAFETY FACTOR		%				SR = $10.3 \times 8.6 + 5.15 \times 7.5 = 127.21$				
ROOM SENSIBLE HEAT SUB TOTAL				31979		WALL (SE): $10.3 \times 5.0 = 51.5$				
SUPPLY DUCT SUPPLY DUCT FAN						(SW): $8.6 \times 5.0 = 43.0$				
HEAT GAIN - LEAK LOSS - HP = 10%				3198		PARTITION: $15.45 \times 3.0 - 3.6 = 42.75$				
BYPASS OUTSIDE AIR 150 CMH (18.2 deg. 0.1 BF) 0.25				80		DOOR (IN): $1.8 \times 2.0 = 3.6$				
EFFECTIVE ROOM SENSIBLE HEAT				35257		CEILING: $7.45 \times 3.0 = 22.35$				
ROOM LATENT HEAT						FLOOR: SR				
INFILTRATION CMH X E/KG X 0.72										
PEOPLE 6 PEOPLE X 49				294						
STEAM kg/h X 540										
APPLIANCES ETC.										
VAPOR TRANS.										
SUB TOTAL										
SAFETY FACTOR		%								
ROOM LATENT HEAT SUB TOTAL				294						
SUPPLY DUCT LEAKAGE LOSS				30						
BYPASS OUTSIDE AIR 150 CMH X 9.6 g/kg X BF X 0.72				104						
EFFECTIVE ROOM LATENT HEAT				428						
EFFECTIVE ROOM TOTAL HEAT				35685						
OUTSIDE AIR HEAT										
SENSIBLE: CMH X deg X (1 - BF) X 0.29										
LATENT: CMH X g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT SUB TOTAL										
RETURN DUCT + RETURN DUCT - PUMP PIPE										
HEAT GAIN - LEAK GAIN - H.P. - PIPE GAIN = %										
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET NO. 18
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR UNITS NO. 1 & NO. 2 CONTROL EQUIPMENT ROOM (M-3) SYSTEM
 SIZE m x m = 216.33 m² x 2.8 m (H) = 605.73 m³

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM 3
				9:00	CORRECTION				
SOLAR GAIN - GLASS						HOURS OF OPERATION	Hour (-)		
	m ² X	X				OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
	m ² X	X				CONDITIONS	DB C	WB C	%RH
	m ² X	X				OUTSIDE	42.2	28.6	37
	m ² X	X				ROOM	24.0		50
	m ² X	X				DIFFERENCE	18.2	X X X	X X X
									9.6
SOLAR & TRANS GAIN - WALLS & ROOF						BLIND	(NON-EXISTENCE) (OUTSIDE, INSIDE) L. M. D.		
WALL (SE)	51.24 m ² X	12.9 X	0.53	351		GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
(SW)	26.23 m ² X	15.8 X	0.53	220		COLOR	LIGHT, MEDIUM, DARK.		
	m ² X	X				WEIGHT	kg/m ² (FLOOR) kg/m ² (WALL)		
	m ² X	X				INTERNAL HEAT	W m ² m ² /PEOPLE		
ROOF - SUN	m ² X	X				INFILTRATION			
ROOF - SHADED	m ² X	X				SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF						REVOLVING DOORS	PEOPLEX CMH/PER.		
GLASS	m ² X	X				OPEN DOORS	DOOREX CMH/DOOR		
CEILING	216.33 m ² X	9.1 X	2.52	4961		EXHAUST AIR			
FLOOR	216.33 m ² X	9.1 X	2.52	4961		CRACK	m X CMH/m		
PARTITION (1)	51.06 m ² X	9.1 X	1.51	771		INFILTRATION	CMH		
(2)	38.5 m ² X	9.1 X	1.69	592		VENTILATION			
DOOR (IN)	5.9 m ² X	9.1 X	2.15	106		6 PEOPLEX	25 CMH/PER.	150	
INFILTRATION	CMH X	deg X	0.29			m ² X	CMH/m ²		
INTERNAL HEAT						VENTILATION	CMH	150	
PEOPLE	6 PEOPLEX	41		246		SENSIBLE HEAT FACTOR			
Kw	36.5 Kw X	0.8 X	860	20.984		E.S.H.F. =	41.732 (ERSH)	0.99 (13.0 C)	
LIGHTS	216.33 X 20 W X		1.08	4.673			42.160 (ERTH)		
APPLIANCES ETC.						DEHUMIDIFIED AIR			
						APPARATUS DEWPOINT	13.0 C		
CREDIT FOR THERMAL STORAGE	m ² X	deg X				41.732 (ERSH)			
						(24 RM - 13 ADP) (1 - BF) X 0.29	14.600 CMH		
SUB TOTAL						NOTES			
SAFETY FACTOR			%			WALL (SE): 16.8 x 3.05 = 51.24			
ROOM SENSIBLE HEAT SUB TOTAL				37 865		(SW): 8.6 x 3.05 = 26.23			
SUPPLY DUCT SUPPLY DUCT FAN						CEILING: SR			
HEAT GAIN + LEAK LOSS - HP = 10%				3 787		FLOOR: SR			
BYPASS OUTSIDE AIR 150 CMH X 18.2 deg X 0.1 BF X 0.29				80		PARTITION (1): 21.95 x 2.8 - 5.4 = 56.06			
EFFECTIVE ROOM SENSIBLE HEAT				41 932		(2): 13.75 x 2.8 = 38.5			
ROOM LATENT HEAT						DOOR (IN): (1.8 + 0.9) x 2.0 = 5.4			
INFILTRATION	CMH X	g/kg X	0.72			SR = 16.8 x 13.75 - 2.85 x 5.15 = 216.33			
PEOPLE	6 PEOPLEX	4.9		294					
STEAM	kg/h X		540						
APPLIANCES ETC.									
VAPOR TRANS.									
SUB TOTAL									
SAFETY FACTOR			%						
ROOM LATENT HEAT SUB TOTAL				294					
SUPPLY DUCT LEAKAGE LOSS 10%				30					
BYPASS OUTSIDE AIR 150 CMH X 9.6 g/kg X BF X 0.72				104					
EFFECTIVE ROOM LATENT HEAT				428					
EFFECTIVE ROOM TOTAL HEAT				42 160					
OUTSIDE AIR HEAT									
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29							
LATENT:	CMH X	g/kg X (1 - BF) X 0.72							
GRAND TOTAL HEAT SUB TOTAL									
RETURN DUCT RETURN DUCT PUMP PIPE									
HEAT GAIN + LEAK GAIN - H.P. - GAIN = %									
(U.S.R.T) GRAND TOTAL HEAT									

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____ SHEET NO. 19
 JOB NAME _____ ADDRESS _____ DATE ORIGINAL _____
 SPACE USED FOR FUEL LABORATORY (M-1.) SYSTEM _____ REVISION _____
 SIZE 8.3 m x 7.9 m = 65.57 m² x 2.8 m(H) = 183.60 m³ PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3		
				3:00	CORRECTION						
SOLAR GAIN - GLASS											
(SE)	3.0 m ²	252 x 0.24 x 0.94 x 0.65		131		HOURS OF OPERATION Hour (-)					
	m ²	x				OUTSIDE DESIGN CONDITIONS °C DB °C WB °C %RH DP °C g/kg					
	m ²	x				CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ²	x				OUTSIDE	42.3	28.6	37		19.0
	m ²	x				ROOM	24.0		50		9.4
	m ²	x				DIFFERENCE	18.3	x x x	x x x	x x x	9.6
SOLAR & TRANS GAIN - WALLS & ROOF											
WALL (SE)	22.32 m ²	12.9 x	0.53	153		BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D				
(NE)	24.10 m ²	11.9 x	0.53	152		GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m ²	x				COLOR	LIGHT, MEDIUM, DARK.				
	m ²	x				WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ²	x				INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN	m ²	x				INFILTRATION					
ROOF - SHADED	m ²	x				SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF											
GLASS	3.0 m ²	18.2 x	5.1	279		REVOLVING DOORS	PEOPLE X CMH/PER				
CEILING	65.57 m ²	9.1 x	2.52	1504		OPEN DOORS	DOORS X CMH/DOOR				
FLOOR	65.57 m ²	9.1 x	2.52	1504		EXHAUST AIR					
PARTITION (1)	7.98 m ²	9.1 x	1.51	110		CRACK	m X		CMH/m		
(2)	15.12 m ²	9.1 x	1.69	233		INFILTRATION	CMH		■		
INFILTRATION											
INFILTRATION	CMH X	deg X	0.29			VENTILATION		CMH		■	
INTERNAL HEAT											
PEOPLE	4 PEOPLE X	41		164		4 PEOPLE X		25 CMH/PER.		100	
Kw	Kw X	x	860			1 m ² X		CMH/m ²			
LIGHTS	65.57 x 20 W X		1.08	1417		SENSIBLE HEAT FACTOR					
APPLIANCES ETC.						E.S.H.F. = $\frac{6.265}{6.605}$ (ERSH) = 0.95 (12.5°C)					
CREDIT FOR THERMAL STORAGE											
CREDIT FOR THERMAL STORAGE	m ² X	deg X				DEHUMIDIFIED AIR					
SAFETY FACTOR											
SAFETY FACTOR	%					APPARATUS DEWPOINT 12.6 °C					
ROOM SENSIBLE HEAT SUB TOTAL											
ROOM SENSIBLE HEAT SUB TOTAL				5647		6.265 (ERSH)					
SUPPLY DUCT	SUPPLY DUCT	FAN				(24 RM - 12.6 DP) (1 - BF) X 0.29 = 2.200 CMH					
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	565		NOTES					
GLASS (SE): 1.0 x 1.5 x 2 = 3.0											
WALL (SE): 8.3 x 3.05 - 3.0 = 22.32											
(NE): 7.9 x 3.05 = 24.1											
CEILING: SR											
FLOOR: SR											
PARTITION (1) 2.85 x 2.8 = 7.98											
(2) 5.4 x 2.8 = 15.12											
BYPASS OUTSIDE AIR											
BYPASS OUTSIDE AIR	100 CMH X	18.2 deg X	0.1 BF X 0.29	53							
EFFECTIVE ROOM SENSIBLE HEAT											
EFFECTIVE ROOM SENSIBLE HEAT				6265							
ROOM LATENT HEAT											
INFILTRATION	CMH X	g/kg X	0.72								
PEOPLE	5 PEOPLE X	49		245							
STEAM	kg/h X	540									
APPLIANCES ETC.											
VAPOR TRANS.											
SAFETY FACTOR											
SAFETY FACTOR	%										
ROOM LATENT HEAT SUB TOTAL											
ROOM LATENT HEAT SUB TOTAL				245							
SUPPLY DUCT LEAKAGE LOSS	%			25							
BYPASS OUTSIDE AIR	100 CMH X	9.6 g/kg X	0.1 BF X 0.72	70							
EFFECTIVE ROOM LATENT HEAT											
EFFECTIVE ROOM LATENT HEAT				340							
EFFECTIVE ROOM TOTAL HEAT											
EFFECTIVE ROOM TOTAL HEAT				6605							
OUTSIDE AIR HEAT											
SENSIBLE:	CMH X	deg X	(1 - BF) X 0.29								
LATENT:	CMH X	g/kg X	(1 - BF) X 0.72								
GRAND TOTAL HEAT SUB TOTAL											
GRAND TOTAL HEAT SUB TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	P/W								
HEAT GAIN	+ LEAK GAIN	+ H.P.	+ GAIN	= %							
(U.S.T) GRAND TOTAL HEAT											
(U.S.T) GRAND TOTAL HEAT											

970

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____ (M-2)
 SPACE USED FOR WATER ANALYSIS & ANALYTICAL INSTRUMENT ROOM SYSTEM
 SIZE m² x m = 134.75 m² x 2.8 m(H) = 377.3 m³

SHEET NO. 20
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR	AM PM	PEAK LOAD	AM PM3
				3100	CORRECTION				
SOLAR GAIN - GLASS									
(SE)	3.0 m ²	252 x 0.24 x 0.85 x 0.94 x 0.65		131					
	m ²	x							
	m ²	x							
	m ²	x							
SOLAR & TRANS GAIN - WALLS & ROOF									
WALL (SE)	23.23 m ²	12.9 x 0.53		159					
	m ²	x							
	m ²	x							
	m ²	x							
ROOF - SUN	m ²	x							
ROOF - SHADED	m ²	x							
TRANS. GAIN - EXCEPT WALLS & ROOF									
GLASS	3.0 m ²	18.2 x 5.1		279					
CEILING	134.75 m ²	9.1 x 2.52		3090					
FLOOR	134.75 m ²	9.1 x 2.52		3090					
PARTITION (1)	20.88 m ²	9.1 x 1.51		688					
	(2) 20.88 m ²	9.1 x 1.69		322					
	(3) 38.5 m ²	9.1 x 1.69		592					
DOOR (IN)	7.2 m ²	9.1 x 2.15		101					
INTERNAL HEAT									
PEOPLE	7 PEOPLE	x 41		287					
Kw	KwX	x	860						
LIGHTS	134.75 x 20 W	x	1.08	2911					
APPLIANCES ETC.									
CREDIT FOR THERMAL STORAGE									
SAFETY FACTOR %									
ROOM SENSIBLE HEAT SUB TOTAL				11690					
SUPPLY DUCT	SUPPLY DUCT	FAN							
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	1169					
BYPASS OUTSIDE AIR 210 CMH x 18.2 deg x 0.1 BF x 0.29				111					
EFFECTIVE ROOM SENSIBLE HEAT				12970					
ROOM LATENT HEAT									
INFILTRATION	CMH x	g/kg x	0.72						
PEOPLE	7 PEOPLE	x 49		343					
STEAM		kg/h x	540						
APPLIANCES ETC.									
VAPOR TRANS.									
ROOM LATENT HEAT SUB TOTAL				343					
SUPPLY DUCT LEAKAGE LOSS 10%				35					
BYPASS OUTSIDE AIR 210 CMH x 9.6 g/kg x 0.1 BF x 0.72				146					
EFFECTIVE ROOM LATENT HEAT				524					
EFFECTIVE ROOM TOTAL HEAT				13494					
OUTSIDE AIR HEAT									
SENSIBLE:	CMH x	deg x (1 - BF) x 0.29							
LATENT:	CMH x	g/kg x (1 - BF) x 0.72							
GRAND TOTAL HEAT SUB TOTAL									
RETURN DUCT	RETURN DUCT	PUMP PIPE	= %						
HEAT GAIN	LEAK GAIN	H.P.	GAIN						
(U.S.R.T.) GRAND TOTAL HEAT									

HOURS OF OPERATION HOUR (-)			
OUTSIDE DESIGN CONDITIONS CDB CWB %RH			
CONDITIONS DB C	WB C	%RH	DP C
OUTSIDE 42.2	28.6	37	19.0
ROOM 24.0		50	9.4
DIFFERENCE 18.2	x x x	x x x	x x x
BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.		
GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
COLOR	LIGHT, MEDIUM, DARK		
WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)	
INTERNAL HEAT	W/m ²	m ² /PEOPLE	
INFILTRATION			
SWINGING			
REVOLVING DOORS	PEOPLE	CMH/PER.	
OPEN DOORS	DOORS	x CMH/DOOR	
EXHAUST AIR			
CRACK	m x	CMH/m	
INFILTRATION CMH			
VENTILATION			
7 PEOPLE	x	25 CMH/PER.	175
m ²	x	CMH/m ²	
VENTILATION CMH			
210			
SENSIBLE HEAT FACTOR			
E.S.H.F.	12.970 (ERSH)	0.96 (12.6 C)	
	13494 (ERTH)		
DEHUMIDIFIED AIR			
APPARATUS DEWPOINT 12.6 C			
12.970 (ERSH)			
(24RM - 12.6 ADP) / (1 - BF) x 0.29 = 4400 CMH			

NOTES
 SR = 13.75 x 8.6 + 55 x 3.0 = 134.75
 GLASS (SE): 1.0 x 1.5 x 2 = 3.0
 WALL (SE): 8.6 x 3.05 - 3.0 = 23.23
 CEILING: SR
 FLOOR: SR
 PARTITION (1): 19.8 x 2.8 - 5.4 = 50.04
 (2): 8.1 x 2.8 - 1.8 = 20.88
 (3): 13.75 x 2.8 = 38.5
 DOOR (IN): 1.8 x 2.0 + 0.9 x 2.0 x 2 = 7.2

5. EQUIPMENT LOAD

5-1 AHU-1

x 2ea (100% STANBY)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	: 24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE	: 42.2°C	28.6°C	22.0 kcal/kg
R.S.H	: 59.011	kcal/h	
S.H.F	: 0.99		
DEHUMIDIFIED AIR	: 20.700	m ³ /h	
OUT AIR	: 250	m ³ /h	
RETURN AIR	: 20.450		

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{250 \frac{\text{m}^3}{\text{h}} \times 22.0 \frac{\text{kcal}}{\text{kg}} + 20450 \frac{\text{m}^3}{\text{h}} \times 11.5 \frac{\text{kcal}}{\text{kg}}}{20700 \frac{\text{m}^3}{\text{h}}} = 11.6 \frac{\text{kcal}}{\text{kg}}$$

$$\therefore \left[20.700 \frac{\text{m}^3}{\text{h}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (11.6 - 8.7) \frac{\text{kcal}}{\text{kg}} \right] \times (1 - 0.1) \times 1.05 = 68.000 \frac{\text{kcal}}{\text{h}}$$

① PEAK LOAD (PM 3:00)

$$\text{E.R.T.H} : 59.725 \frac{\text{kcal}}{\text{h}}$$

$$\text{OUTSIDE AIR HEAT} : 250 \frac{\text{m}^3}{\text{h}} \times 18.2 \times (1 - 0.1) \times 0.29 = 1.188 \frac{\text{kcal}}{\text{h}} \dots \textcircled{2}$$

$$250 \frac{\text{m}^3}{\text{h}} \times 9.6 \times (1 - 0.1) \times 0.72 = 1.556 \frac{\text{kcal}}{\text{h}} \dots \textcircled{3}$$

$$\text{TOTAL} = \textcircled{1} + \textcircled{2} + \textcircled{3} = (59.725 + 1.188 + 1.556) \times 1.05 = 66.000 \frac{\text{kcal}}{\text{h}}$$

226

PSYCHROMETRIC CHART

ZONE NAME: COMPUTER ROOM (AC-1)

SA : 20.700 CMH


CA : 25.0 CMH

RA : 20.450 CMH

MIX POINT = $\frac{250 \times 42.2 + 20450 \times 24.0}{20700}$

≈ 24.2

SHE = 0.91



5 - 2 AHU - 2

x 2 ea (50% x 2)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM :	24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE :	42.2°C	28.6°C	22.0 kcal/kg
R.S.H :	67.893	kcal/h / 2 = 33.947 kcal/h	
S.H.F :	0.9		
DEHUMIDIFIED AIR :	23000 m ³ /h / 2 = 11500 m ³ /h		
OUT AIR :	1.650 m ³ /h / 2 = 825		
RETURN AIR :	21.350 m ³ /h / 2 = 10675		

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{825 \frac{\text{m}^3}{\text{h}} \times 22.0 \frac{\text{kcal}}{\text{kg}} + 10675 \frac{\text{m}^3}{\text{h}} \times 11.5 \frac{\text{kcal}}{\text{kg}}}{11500}$$

$$= 12.3 \text{ kcal/kg}$$

$$\therefore \left[11500 \frac{\text{m}^3}{\text{h}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (12.3 - 8.6) \frac{\text{kcal}}{\text{kg}} \times (1 - 0.1) \times 1.05 \right]$$

$$= 48.000 \text{ kcal/h}$$

⊙ PEAK LOAD (PM 3:00)

$$\text{E.R.T.H} = 70452 \text{ kcal/h} \quad \text{--- ①}$$

$$\text{OUTSIDE AIR HEAT: } 1650 \frac{\text{m}^3}{\text{h}} \times 18.2 \times (1 - 0.1) \times 0.29 = 7.838 \text{ kcal/h} \quad \text{--- ②}$$

$$1650 \frac{\text{m}^3}{\text{h}} \times 9.6 \times (1 - 0.1) \times 0.72 = 10.265 \text{ kcal/h} \quad \text{--- ③}$$

$$\text{TOTAL} = \text{①} + \text{②} + \text{③}$$

$$= (70452 + 7838 + 10265) \times 1.05 / 2 = 47.000 \text{ kcal/h}$$

766

PSYCHROMETRIC CHART

ZONE NAME: CENTRAL CONTROL ROOM etc
(AC-2 x 2)


SA: 11,500 CMH

OA: 835 CMH

RA: 10,675 CMH

MIX POINT = $\frac{825 \times 42.2 + 10,675 \times 24.0}{11,500} = 25.3$

SHE = 0.97



S - 3 AHU - 3

x 2 ea (50% x 2)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	: 24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE	: 42.2°C	28.6°C	22.0 kcal/kg
R.S.H	: 41.733	kcal/h / 2 = 20.867 kcal/h	
S.H.F	: 0.99		
DEHUMIDIFIED AIR	: 14.600 m ³ /h	/ 2 = 7300 m ³ /h	
OUT AIR	: 150 m ³ /h	/ 2 = 75	
RETURN AIR	: 14.450 m ³ /h	/ 2 = 7.225	

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{75 \frac{\text{m}^3/\text{h}}{\text{kg}} \times 22.0 \frac{\text{kcal}}{\text{kg}} + 7.225 \frac{\text{m}^3/\text{h}}{\text{kg}} \times 11.5 \frac{\text{kcal}}{\text{kg}}}{7.300}$$

$$= 11.6 \text{ kcal/kg}$$

$$\therefore \left[7.300 \frac{\text{m}^3/\text{h}}{\text{kg}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (11.6 - 8.7) \frac{\text{kcal}}{\text{kg}} \times (1 - 0.1) \times 1.05 \right]$$

$$= 24.000 \text{ kcal/h}$$

⊙ PEAK LOAD (PM 3:00)

$$\text{E.R.T.H} = 42.160 \frac{\text{kcal}}{\text{h}} \dots \text{①}$$

$$\text{OUTSIDE AIR HEAT} : 150 \frac{\text{m}^3/\text{h}}{\text{kg}} \times 18.2 \times (1 - 0.1) \times 0.29 = 713 \text{ kcal/h} \dots \text{②}$$

$$150 \frac{\text{m}^3/\text{h}}{\text{kg}} \times 9.6 \times (1 - 0.1) \times 0.72 = 934 \text{ kcal/h} \dots \text{③}$$

$$\text{TOTAL} = \text{①} + \text{②} + \text{③}$$

$$= (42.160 + 713 + 934) \times 1.05 / 2 = 23.000 \text{ kcal/h}$$


PSYCHROMETRIC CHART

ZONE NAME: UNIT No. 1 & No. 2 CONTROL EQUIPMENT ROOM (AC-3x2)

S.A. : 7.300 CMH
O.A. : 75 CMH
R.A. : 7.225 CMH

MIX POINT = $75 \times 42.2 + 7.225 \times 24.0 = 24.2$
7.300

S.H.F. = 0.99



5 - 4 AHU - 4 x 2 ea (50% x 2)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM :	24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE :	42.2°C	28.6°C	22.0 kcal/kg
R.S.H. :	19.235	kcal/h/2 = 9.618 kcal/h	
S.H.F. :	0.96		
DEHUMIDIFIED AIR :	6.600 m ³ /h / 2 = 3.300		
OUT AIR :	310 m ³ /h / 2 = 155		
RETURN AIR :	6.290 m ³ /h / 2 = 3.145		

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{155 \text{ m}^3/\text{h} \times 22.0 \text{ kcal/kg} + 3.145 \text{ m}^3/\text{h} \times 11.5 \text{ kcal/kg}}{3.300}$$

$$= 12.0 \text{ kcal/kg}$$

$$\therefore \left[3.300 \text{ m}^3/\text{h} \times 1.2 \text{ kg/m}^3 \times (12.0 - 8.5) \text{ kcal/kg} \right] \times (1 - 0.1) \times 1.05$$

$$= 13.000 \text{ kcal/h}$$

① PEAK LOAD (PM 3:00)

$$\text{E.R.T.H} = 20.069 \text{ kcal/h} \dots \text{①}$$

$$\text{OUTSIDE AIR HEAT} : 310 \text{ m}^3/\text{h} \times 18.2 \times (1 - 0.1) \times 0.29 = 1.473 \text{ kcal/h} \dots \text{②}$$

$$310 \text{ m}^3/\text{h} \times 9.6 \times (1 - 0.1) \times 0.72 = 1.929 \text{ kcal/h} \dots \text{③}$$

$$\text{TOTAL} = \text{①} + \text{②} + \text{③}$$

$$= (20.069 + 1.473 + 1.929) \times 1.05 / 2 = 13.000 \text{ kcal/h}$$

PSYCHROMETRIC CHART

FUEL LABORATORY
 ZONE NAME : WATER ANALYSIS & ANALYTICAL INSTRUMENT RM

(AC-4)


SA : 3,300 CMH

OA : 155 CMH

RA : 3,145 CMH

MIX POINT = $\frac{155 \times 42^2 + 3,145 \times 74^2}{3,300} = 24.9$

S.H.F. = 0.96



6. SELECTION OF COOLING EQUIPMENT

6-1. TOTAL LOAD SUMMARY

AHU-1	66.000 kcal/h/2 (REHEAT 20.000 kcal/h)
AHU-2	94.000 kcal/h/2
AHU-3	46.000 kcal/h/2
AHU-4	26.000 kcal/h/2

TOTAL 116.000 kcal/h RT-2 (50% x 2 ea)

CAPACITY, CHILLED WATER.

RT-1. FOR AHU-1

$$66.000 \text{ kcal/h} / 3024 = 22 \text{ RT}$$

$$66.000 \text{ kcal/h} / 5 \times 60 = 220 \text{ l/min}$$

RT-2. FOR AHU-1 ~ 4.

$$116.000 \text{ kcal/h} / 3024 = 39 \text{ RT}$$

$$116.000 \text{ kcal/h} / 5 \times 60 = 387 \text{ l/min}$$

6-2 EQUIPMENT.

(1) AIR COOLED
PACKAGED LIQUID CHILLER UNIT

R-1
 COOLING LOAD CAPACITY : 66,000 Kcal/Hr (22 RT)
 CHILLED WATER
 WATER TEMP. : IN 12 - OUT 7 °C
 WATER FLOW RATE : 220 lit/min
 WATER FRICTION LOSS : 0.8 m (COIL SECTION)
 CONNECTION PIPE DIA. : φ 65 (GAS STEEL PIPE)

REFRIGERANT TYPE : R- 22

ELECTRIC POWER(OUTPUT)
 COMPRESSOR : 30 Kw (3φ - V)
 FAN : 0.75x3 Kw (-do-)
 : Kw (-do-)
 : Kw (-do-)

DIMENSION : W 3,300 x D 1,200 x H 2000 (mm)
 WEIGHT : Kg (OPERATING 1.8¹⁰ Kg)
 Mfr. MODEL NO : 30AE040 (or equal)
 (CARRIER)

NOTE : TON IS REFGIGERATION(U.S) IS 3,024 Kcal/Hr.

181

AIR COOLED

PACKAGED LIQUID CHILLER UNIT

R - 2 x 2 ea

COOLING LOAD CAPACITY : 116,000 Kcal/Hr (39 RT)

CHILLED WATER

WATER TEMP. : IN 12 - OUT 7 °C

WATER FLOW RATE : 387 lit/min

WATER FRICTION LOSS : 2.1 m (COIL SECTION)

CONNECTION PIPE DIA. : ϕ 80 (GAS STEEL PIPE)

REFRIGERANT TYPE : R- 22

ELECTRIC POWER(OUTPUT)

COMPRESSOR : 30 x 2 Kw (3 ϕ - 380 V)

FAN : 0.75 x 6 Kw (-do-)

: Kw (-do-)

: Kw (-do-)

DIMENSION : W 3,690 x D 2,000 x H 2,300 (mm)

WEIGHT : Kg (OPERATING 2,810 Kg)

Mfr. MODEL NO : 30AE 080 (or equal)

(CARRIER)

NOTE : TON IS REFRIGERATION(U.S) IS 3,024 Kcal/Hr.

982

(2) PUMP

PUMP / VOLUTE CWP - 1 x 20%

WATER RATE FLOW : 220 lit/min
 WATER FLOW PIPE DIA. : ϕ 65
 WATER FLOW SPEED : 1.1 m/sec
 PIPE FRICTION LOSS (R) : 40 mmAq/m
 PIPE EQUIVALENT LENGTH (Le)

STRAIGHT PIPE : 150 m
 ELBOW : ea x m/ea = 150 m
 GATE VALVE : ea x m/ea = x m
 CHECK VALVE : ea x m/ea = 0.5 m
 OTHERS : = 25 m

TOTAL (Le) 225 m

PIPE HEAD LOSS (*1) : (Le) 225 m x (R) 0.04 = 9 m
 LIFT HEAD (*2) : 5 m

EQUIPMENT or OTHERS HEAD LOSS

- 1. R-1 Coil : 0.8 m
- 2. AHU coil : 2 m
- 3. Reheater : 2 m
- 4. : m

TOTAL (*3) 4.8 m

TOTAL PIPE HEAD LOSS : (*1) + (*2) + (*3) = 18.8 m x 10%
 = 20 m

SELECTION OF PUMP

TYPE : VOLUTE / TURBINE / IN_LINE
 DIA. : ϕ 50x40
 WATER FLOW RATE : 220 lit/min
 POWER OUTPUT : 2.2 Kw (ϕ 3 - 380 V)
 NUMBER : 2 ea
 WEIGHT : 81 Kg
 Mfr. MODEL NO. : 50x40FS4J52.2 or equal
 (EBARA)

NOTE :

283

PUMP / VOLUTE CWP-2 X2EQ

WATER RATE FLOW	:	387	lit/min
WATER FLOW PIPE DIA.	:	φ 80	
WATER FLOW SPEED	:	1.2	m/sec
PIPE FRICTION LOSS (R)	:	40	mmAq/m
PIPE EQUIVALENT LENGTH (Le)			
STRAIGHT PIPE	:	160	m
ELBOW	:	ea x m/ea =	m
GATE VALVE	:	ea x m/ea =	160 m
CHECK VALVE	:	ea x m/ea =	0.5 m
OTHERS	:	=	80 m
TOTAL (Le)		240	m
PIPE HEAD LOSS (*1)	:	(Le) 240 m x (R) 0.04 =	9.6 m
LIFT HEAD (*2)	:	5	m
EQUIPMENT or OTHERS HEAD LOSS			
1. R-1 Coil	:	2.1	m
2. AHU Coil	:	2	m
3.	:		m
4.	:		m
TOTAL (*3)		4.1	m
TOTAL PIPE HEAD LOSS : (*1)+(*2)+(*3) =		18.7	m x 10%
		= 20	m

SELECTION OF PUMP

TYPE	:	<u>VOLUTE</u> / TURBINE / IN_LINE
DIA.	:	φ 65x50
WATER FLOW RATE	:	387 lit/min
POWER OUTPUT	:	3.7 Kw (φ 3 - 380 V)
NUMBER	:	2 ea
WEIGHT	:	130 Kg
Mfr. MODEL NO.	:	65x50FS4J53.7 or equal (EBARA)


NOTE :

* EQUIVALENT LENGTH OF PIPE FITTINGS & VALVES

DIA	90° ELBOW	90° TEE	GATE VALVE	GLOVE VALVE	CHECK VALVE
20	0.75	1.2	0.15	6.0	1.6
25	0.9	1.5	0.18	7.5	2.0
32	1.2	1.8	0.24	10.5	2.5
40	1.5	2.1	0.3	13.5	3.1
50	2.1	3.0	0.39	16.5	4.0
65	2.4	3.6	0.48	19.5	4.6
80	3.0	4.5	0.63	24.0	5.7
100	4.2	6.3	0.81	37.5	7.6
125	5.1	7.5	0.99	42.0	10.0
150	6.0	9.0	1.20	49.5	12.0
200	6.5	14.0	1.40	70.0	15.0
250	8.0	20.0	1.70	90.0	19.0

* FRICTIONAL RESISTANCE CHART OF PIPING

(at GALVANIZED STEEL PIPE)



2025

(3) AIR HANDLING UNIT

AHU-1 x 2 ea (one for stand by)

AIR FLOW RATE : 20.700 m³/H (345 m³/min)

COOLING LOAD : 66.000 Kcal/H (REHEAT LOAD : 20.000 Kcal/H)

FAN MOTOR : 11 KW

EXTERNAL STATIC PRES.: 70 mmAq

AIR INLET : 24.2°C DB, 17.2°C WB, 11.6 Kcal/Kg

OUTLET : 14.1°C DB, 13.4°C WB, 9.0 Kcal/Kg

CHILLED WATER : 270 lit/min (66.000 / 5x60)

TYPE	: VERTICAL
AIR FLOW RATE	: 20.700 m ³ /H
COOLING COIL	: 1 x 26
FAN MOTOR	: 11 Kw, REHEATER : 24 KW
POWER	: Ø3-380 ^V , 50Hz
TAPPING SIZE	: CHILLED WATER 65Ax2, DRAIN 20A
DIMENSION	: 3000 x 845 x 1.930 ^H (mm)
WEIGHT	: 1.660 Kg

MODEL : 39 ACJ 11 (CARRIER)

AIR HANDLING UNIT

AHU-2 x 2 ea

AIR FLOW RATE : 11.500 m³/H (192 m³/min)
 COOLING LOAD : 47.000 Kcal/H
 FAN MOTOR : 3.7 KW
 EXTERNAL STATIC PRES.: 60 mmAq
 AIR INLET : 25.3°C DB , 17.3°C WB , 12.3 Kcal/Kg
 OUTLET : 13.9°C DB , 13.4°C WB , 9.° Kcal/Kg
 CHILLED WATER : 157 lit/min (47.000/5x60)

TYPE	:	VERTICAL
AIR FLOW RATE	:	11.500 m ³ /H
COOLING COIL	:	1x22
FAN MOTOR	:	3.7 Kw
POWER	:	Ø3-380 ^V , 50Hz
TAPPING SIZE	:	CHILLED WATER 40 Ax2, DRAIN 20 A
DIMENSION	:	2090 x 780 x 1.790 ^H (mm)
WEIGHT	:	1.060 Kg

MODEL : 39ACT 9 (CARRIER)

AIR HANDLING UNIT

AHU-3 x 2 ea

AIR FLOW RATE : 7.300 m³/H (122 m³/min)
 COOLING LOAD : 23.000 Kcal/H
 FAN MOTOR : 2.2 KW
 EXTERNAL STATIC PRES.: 60 mmAq
 AIR INLET : 24.2°C DB , 17.2°C WB , 11.6 Kcal/Kg
 OUTLET : 14.1°C DB , 13.4°C WB , 9.0 Kcal/Kg
 CHILLED WATER : 77 lit/min (23.000 / 5 x 60)

TYPE	: VERTICAL
AIR FLOW RATE	: 7.300 m ³ /H
COOLING COIL	: 1 x 22
FAN MOTOR	: 2.2 Kw
POWER	: 03-380 ^V , 50Hz
TAPPING SIZE	: CHILLED WATER 40 Ax2, DRAIN 20 A
DIMENSION	: 1.580 x 780 x 1.740 ^m (mm)
WEIGHT	: 810 Kg

MODEL : 39 ACJ 8 (CARRIER)

AIR HANDLING UNIT

AHU - 4 x 2ea

AIR FLOW RATE : 3.300 m³/H (55 m³/min)
 COOLING LOAD : 13.000 Kcal/H.
 FAN MOTOR : 1.5 kW
 EXTERNAL STATIC PRES.: 60 mmHg
 AIR INLET : 24.9°C DB, 17.7°C WB, 12.0 Kcal/Kg
 OUTLET : 13.8°C DB, 13.1°C WB, 8.8 Kcal/Kg
 CHILLED WATER : 44 lit/min (13.000/5x60)

TYPE	: VERTICAL
AIR FLOW RATE	: 3.300 m ³ /H
COOLING COIL	: 1 x 16
FAN MOTOR	: 1.5 Kw
POWER	: Ø3-380 ^V , 50Hz
TAPPING SIZE	: CHILLED WATER 32 Ax2, DRAIN 20 A
DIMENSION	: 1.125 x 670 x 1.550 ^H (mm)
WEIGHT	: 360 Kg

MODEL : 39ACJ 6 (CARRIER)

PSP

7.7 換 気

7. VENTILATION SYSTEM

7-1. ESTIMATE OF VENTILATION AIR VOLUME

FLOOR	ROOM NAME	AREA (m ²)	VOL. (m ³)	AIR CHANGE (T/Hr)	AIR FLOW (m ³ /Hr)	EXHAUST AIR (m ³ /Hr)	SUPPLY AIR (m ³ /Hr)	
MEZZANINE FLOOR	STORAGE ROOM	14.6	40.9	5	205	210 *	-	(III) VF-4
	BATTERY ROOM	144.5	404.6	10	4046	-		(I)
				35 m ³ /m ²	5058 *	5060	5060	OAG EF-3
	SUB TOTAL					5.270	5060	
CABLE TREATMENT FLOOR	CABLE TREATMENT AREA	628.9	1509	10	15090	15100	15100	OF-1 (I) EF-1
	SUB TOTAL					15.100		
OPERATING FLOOR	KITCHEN	5.4	16.2	10	162	170		(III) VF-5
	LAVATORY	19.1	57.3	10	573	600 *	650	(III) VF-2
	JAN	2.3	6.9	5	35	50 *		(III) VF-7
	SUB TOTAL					820		
FOURTH FLOOR	LOCKER ROOM	22.4	62.7	10	627	630 *	1000	(III) VF-1
	KITCHEN	5.3	148	10	148	150		(III) VF-6
	JAN	2.3	6.4	5	32	50 *		(III) VF-7
	LAVATORY	11.5	32.2	10	322	320 *		(III) VF-3
	AIR CONDITIONING MACHINE ROOM	310	1500	10	15000	15000		(III) EF-2
	SUB TOTAL					16.150		
ROOF	TURBINE ROOM							(III) RF-1
		$\frac{200.000 \text{ kW} \times 0.003 \times 860 \text{ kcal/kWh}}{0.29 \times 5}$						
		$= 355.862$						
		$= 356.000 / 16 = 22.300 / \text{EA}$						
		$VR = 22 \times 111.6 \times 155$						
		$+ 110.0 \times 111.6 \times 5$						
		$= 43,435 \text{ m}^3$			7	305.450		

ppp

7-2 SELECTION OF VENTILATION EQUIPMENT

V - 1

MEZZANINE FLOOR STORAGE ROOM

MACHINE NO VF-4			
TYPE OF VENTILATOR	: CEILING	x 1	ea
AIR FLOW RATE	:	210 m ³ /Hr	x 8 mm ²
FAN MOTOR	:	1/2 or 35 w	
POWER	:	1 ϕ 220v / 3ϕ (50/ 60 Hz)	
SIZE	:	308 x 308 x 226 ^H	(mm)
ACCESSORY	:	150 ϕ VENT CAP	

V - 2

MEZZANINE FLOOR BATTERY ROOM

MACHINE NO EF-2	SS # 2 1/2		
TYPE OF VENTILATOR	: CENTRIFUGAL MULTI-BANE	x 1	ea
AIR FLOW RATE	:	5060 m ³ /Hr	x 25 mm ²
FAN MOTOR	:	1.5 KW or	w
POWER	:	1ϕ 220v / 3 ϕ 380v	(50/ 60 Hz)
SIZE	:	960 ^L x 360 ^W x 805 ^H	(mm)
ACCESSORY	:		

V - 3

CABLE TREATMENT AREA

MACHINE NO EF-1 (OF-1) SS #4			
TYPE OF VENTILATOR	: DITTO	x 1	ea
AIR FLOW RATE	:	15100 m ³ /Hr	x 25 mm ²
FAN MOTOR	:	3.7 KW or	w
POWER	:	1ϕ 220v / 3 ϕ 380v	(50/ 60 Hz)
SIZE	:	1540 ^L x 545 ^W x 1.140 ^H	(mm)
ACCESSORY	:		

V - 4

OPERATING FLOOR : KITCHEN

MACHINE NO	VF-5
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 170 m ³ /Hr x 8 mm ⁴ g
FAN MOTOR	: 35 or 35 w
POWER	: 1ϕ 220v / 3ϕ (50/60 Hz)
SIZE	: 308 x 308 x 226 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

V - 5

OPERATING FLOOR LAVATORY

MACHINE NO	VF-2
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 600 m ³ /Hr x 8 mm ⁴ g
FAN MOTOR	: 95 or 95 w
POWER	: 1ϕ 220v / 3ϕ (50/60 Hz)
SIZE	: 464 x 464 x 278 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

V - 6

OPERATING FLOOR JAN (= FORTH FLOOR JAN)

MACHINE NO	VF-7
TYPE OF VENTILATOR	: CEILING x 2 ea
AIR FLOW RATE	: 50 m ³ /Hr x 6 mm ⁴ g
FAN MOTOR	: 18 or 18 w
POWER	: 1ϕ 220v / 3ϕ (50/60 Hz)
SIZE	: 223 x 223 x 165 ^H (mm)
ACCESSORY	: 100 ⁺ VENT CAP

992

V - 7

FORTH FLOOR LOCKER ROOM

MACHINE NO VF - 1	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 630 m ³ /Hr x 8 mmHg
FAN MOTOR	: 75 or 95 w
POWER	: 1ϕ 220v / 3ϕ (50/60 Hz)
SIZE	: 464 x 464 x 278 ^H (mm)
ACCESSORY	: 150ϕ VENT CAP

V - 8

FORTH FLOOR KITCHEN

MACHINE NO VF - 6	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 150 m ³ /Hr x 8 mmHg
FAN MOTOR	: 75 or 35 w
POWER	: 1ϕ 220v / 3ϕ (50/60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150ϕ VENT CAP

V - 9

FORTH FLOOR LAVATORY

MACHINE NO VF - 3	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 320 m ³ /Hr x 7 mmHg
FAN MOTOR	: 75 or 46 w
POWER	: 1ϕ 220v / 3ϕ (50/60 Hz)
SIZE	: 345 x 345 x 243 ^H (mm)
ACCESSORY	: 150ϕ VENT CAP

9/3

V - 10

FORTH FLOOR AIR CONDITIONING MACHINE ROOM

MACHINE NO	EF-3			
TYPE OF VENTILATOR	: AXIAL.		x 1 ea	
AIR FLOW RATE	: 15.000 m ³ /Hr	x 15	mmA ₈	
FAN MOTOR	: 2.2 KW or		w	
POWER	: 1φ 220v / 3φ 380v		(50/60 Hz)	
SIZE	: x	x	(mm)	
ACCESSORY	:			

V - 11

ROOF TURBINE ROOM.

MACHINE NO	RF-1			
TYPE OF VENTILATOR	: ROOF VENTILATOR		x 16 ea	
AIR FLOW RATE	: 22.300 m ³ /Hr	x 10	mmA ₈ (41200)	
FAN MOTOR	: 3.7 KW or		w	
POWER	: 1φ 220v / 3φ 380v		(50/60 Hz)	
SIZE	: 2.250 x 2.250 x 1520H.		(mm)	
ACCESSORY	:			

V - 1

MACHINE NO				
TYPE OF VENTILATOR	:		x ea	
AIR FLOW RATE	:	m ³ /Hr		
FAN MOTOR	:	KW or	w	
POWER	:	1φ 220v / 3φ	v (50/60 Hz)	
SIZE	:	x	x (mm)	
ACCESSORY	:			

994

V - 12.

FORTH FLOOR: AIR CONDITIONING MACHINE ROOM

MACHINE NO EF-4	< FOR AHU-1 >
TYPE OF VENTILATOR	: AXIAL x 1 ea
AIR FLOW RATE	: 250 m ³ /Hr x 10 ^{mmA⁸}
FAN MOTOR	: 75 or 80 W
POWER	: 1ø 220v / 3ø (50/60 Hz)
SIZE	: 375 ^ø x 320 ^L x (mm)
ACCESSORY	:

V - 13

MACHINE NO EF-5	< FOR AHU-3 >
TYPE OF VENTILATOR	: AXIAL x 1 ea
AIR FLOW RATE	: 150 m ³ /Hr x 10 ^{mmA⁸}
FAN MOTOR	: 75 or 12 W
POWER	: 1ø 220v / 3ø (50/60 Hz)
SIZE	: 250 ^ø x 220 ^L x 274 ^H (mm)
ACCESSORY	:

V - 14

MACHINE NO EF-6	< FOR AHU-4 >
TYPE OF VENTILATOR	: AXIAL x 1 ea
AIR FLOW RATE	: 100 m ³ /Hr x 7 ^{mmA⁸}
FAN MOTOR	: 75 or 12 W
POWER	: 1ø 220v / 3ø (50/60 Hz)
SIZE	: 250 ^ø x 220 ^L x 274 ^H (mm)
ACCESSORY	:

9/5

AR-8 空 調 設 備 (事務建屋)

目 次

8.1	設計条件	1
8.2	データ	2
8.3	熱貫流計算	3
8.4	空調負荷	6
8.5	設備負荷	43
8.6	冷却設備の選定	47
8.7	換 気	49

8.1 設計条件

1. DESIGN CRITERIA

1 - 1 DESIGN CONDITION

1) For air conditioning system

(a) Outdoor air

Summer : 42.2°C DB, 28.6°C WB, 37%RH

(b) Room

Summer : 24°C+2°C DB, 50%RH

Winter : Not more than the condition in summer

2) Minimum ventilation air vol.

For Control Room 25 m³/Hr person

3) Lighting

20 W/m²

4) People

Refer to "Cooling and dehumidifying estimate sheets"

5) Location

25.4°(N), 68.3°(E)

866.

8.2 データ

2. DATA

Data used for load estimation is based on Carrier,s Design Manual of the newest condition.

2- 1 Outdoor air

1) Dry Bulb

Time	8	9	10	11	12	13	14	15	16	17	18
Dry Bulb											
°C	28.2	30.3	32.8	35.7	38.4	40.4	41.7	42.2	41.7	40.5	38.7

2) HUmidity Ratio

Time	8	9	10	11	12	13	14	15	16	17	18
Humidity Ratio											
g/Kg	19.1	19.0	19.0	19.2	18.9	19.0	18.8	19.0	18.8	18.9	18.8

2- 2 Solar heat gain

1) Peak solar heat gain thru ordinary glass

EXPOSURE	NL	NE	SE	SW	NW	HORIZONTAL	SHADE
HEAT							
Kcal/h m ²		366	252	252	366	674	47

2) Solar gain correction factors

- for steel sash : 1/0.85
- for dew point : 0.94

9/9/9

3) Load storage factors , solar heat gain thru ordinary glass

EXPOSURE	TIME	8	9	10	11	12	13	14	15	16	17	18
NE		0.57	0.46	0.30	0.24	0.20	0.19	0.17	0.16	0.15	0.13	0.11
SE		0.47	0.61	0.67	0.65	0.57	0.44	0.29	0.24	0.21	0.18	0.15
SW		0.08	0.08	0.10	0.24	0.40	0.55	0.66	0.70	0.64	0.50	0.26
NW		0.09	0.09	0.10	0.10	0.10	0.10	0.16	0.34	0.52	0.65	0.64

NOTE : Venetian blind to be located on the inside of glass.
 (Overall factor is 0.65)

2 - 3 Equivalent temperature difference

1) For wall

EXPOSURE	TIME	8	9	10	11	12	13	14	15	16	17	18
NE		4.6	7.9	16.8	16.0	15.3	13.3	11.3	11.9	12.6	13.0	13.5
SE		5.4	8.6	11.1	12.4	13.6	13.8	13.9	12.9	12.4	11.8	11.5
SW		2.6	3.1	3.7	5.0	5.9	9.8	12.1	15.8	18.6	19.2	19.5
NW		3.7	4.5	5.3	6.6	7.9	10.1	11.3	13.5	15.4	19.5	23.2

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 200Kg/m².

2) For roof




For roof	TIME	8	9	10	11	12	13	14	15	16	17	18
°C		10.3	10.2	10.8	12.4	14.9	18.0	21.2	24.0	26.2	27.8	28.5

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 300Kg/m².

2021





8.3 熱貫流計算

3. HEAT TRANSMISSION : K-Value

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE ($m^2H^{\circ}C/Kcal$)	AIR FILM ($m^2H^{\circ}C/Kcal$)	K-Value ($Kcal/m^2H^{\circ}C$)
WALL 				$\gamma_0 = 0.05$	
	① CEMENT PLASTER	10	0.016		
	② BRICK	150	0.283		
	③ CEMENT PLASTER	10	0.016		
				$\gamma_i = 0.133$ (0.498)	2.008 \Rightarrow 2.1
PARTITION 1. DITTO				$\gamma_i = 0.133$	
	① CEMENT PLASTER	10	0.016		
	② BRICK	150	0.283		
	③ CEMENT PLASTER	10	0.016		
				$\gamma_i = 0.133$ (0.581)	1.722 \Rightarrow 1.8
PARTITION 2 				$\gamma_i = 0.133$	
	① CEMENT PLASTER	10	0.016		
	② CONCRETE	150	0.107		
	③ CEMENT PLASTER	10	0.016		
				$\gamma_i = 0.133$ (0.405)	2.47 \Rightarrow 2.5
DOOR (IN) 				$\gamma_i = 0.133$	
	① WOOD	12	0.092		
	② AIR SPACE		0.200		
	③ WOOD	12	0.092		
				$\gamma_i = 0.133$ (0.650)	1.539 \Rightarrow 1.6
WINDOW (OUT)	ORDINARY GLASS	3			5.1
WINDOW (IN)	ORDINARY GLASS	3			3.8

1001

ADMINISTRATION BUILDING

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE ($m^2H^{\circ}C/Kcal$)	AIR FILM ($m^2H^{\circ}C/Kcal$)	K-Value ($Kcal/m^2H^{\circ}C$)
ROOF 1 	① BLACK TILE ② SAND ③ POLYETHYLENE FILM ④ ROOFING ⑤ CONCRETE ⑥ CEMENT PLASTER	10 30 1 10 150 25	0.019 0.057 0.034 0.112 0.107 0.040	$\gamma_0 = 0.05$ $\gamma_i = 0.189$ (0.608)	 1.645 \Rightarrow 1.7
ROOF 2 	① BLACK TILE ② SAND ③ POLYETHYLENE FILM ④ ROOFING ⑤ CONCRETE ⑥ AIR SPACE ⑦ ACOUSTICAL TILE BOARD	10 30 1 10 150 12	0.019 0.057 0.034 0.112 0.107 0.200 0.187	$\gamma_0 = 0.05$ $\gamma_i = 0.189$ (0.955)	 1.048 \Rightarrow 1.1
CEILING 1 	① TERRAZZO ② MORTAR ③ CONCRETE ④ AIR SPACE ⑤ ALUM SHEET	30 40 150 2	0.070 0.031 0.107 0.200 -	$\gamma_i = 0.189$ $\gamma_i = 0.189$ (0.736)	 1.359 \Rightarrow 1.4
FLOOR 1 DITTO	DITTO	DITTO	DITTO	$\gamma_i = 0.125$ (0.608)	1.645 \Rightarrow 1.7
CEILING 2 	① TERRAZZO ② MORTAR ③ CONCRETE	30 40 150	0.020 0.031 0.107	$\gamma_i = 0.189$ $\gamma_i = 0.189$ (0.536)	 1.866 \Rightarrow 1.9
FLOOR 2 DITTO	DITTO	DITTO	DITTO	$\gamma_i = 0.125$ (0.403)	2.482 \Rightarrow 2.5

1002

4. ROOM LOAD SUMMARY
 4-1. PAC-1 (NW-SYSTEM)
 1) ROOM PEAK LOAD (1)

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(%)	DEHUM AIR (m ³ /H)	OUT AIR (m ³ /H)
					R.S.H (Kcal/H)	R.T.H (Kcal/H)			
1F G02	ENTRANCE & ENTRANCE HALL	84.0	240.6 ³	-	4967	5285	12.5	1.660	460
	SUB TOTAL	84.0	240.6 ³	-	4967	5.285		1.660	460
2F F02	SECRETARY ROOM ASSISTANT SUPERINTENDENT RM.	16.0	40.0	2	1.593	1.736	12.3	530	50
F02	SUPERINTENDENT RM.	42.25	126.75	4	6.610	6.895	12.6	2.210	100
F01	SUPERINTENDENT RM	84.5	253.5	8	10.716	11.285	12.5	3.580	200
F01	SECRETARY ROOM	24.0	60.0	4	1.856	2.142	11.8	620	100
F07	TELCOMUNICATION ROOM	52.25	156.75	5	4.872	5.228	12.4	1.630	125
F04	CANTEEN	78.5	251.8	15	14.403	16.360	11.9	4.810	1.695
	SUB TOTAL	297.5	888.18	38	40.050	43.645		13.380	2270
3F S02	SECRETARY ROOM ASSISTANT SUPERINTENDENT RM.	16.0	40.0	2	927	1070	11.8	310	50
S02	SUPERINTENDENT RM.	42.25	160.55	4	5.306	5.591	12.5	1.770	100
S01	SECRETARY ROOM	16.0	40.0	2	1.130	1.273	12.0	380	50
S01	ASSISTANT SUPERINTENDENT RM	42.25	160.55	4	4.239	4.523	12.5	1.420	100
S03C	JUNIOR ENGINEER ROOM	68.25	225.55	6	4.976	5.402	12.3	1.660	150
S03b	DITTO	68.25	225.55	6	5.196	5.622	12.3	1.740	150
S03a	DITTO	62.25	200.55	6	7.970	8.397	12.5	2.660	150
	SUB TOTAL	315.25	1052.75	30	29.744	31.878		9.940	750

1) ROOM PEAK LOAD (z)

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(%)	DEHUM AIR (m ³ /H)	OUT AIR (m ³ /H)
					R.S.H (Kcal/H)	R.T.H (Kcal/H)			
4F	JUNIOR ENGINEER ROOM	68.25	225.55	6	9.579	10.005	12.6	3.200	150
To1d	DITTO	68.25	225.55	6	8.116	8.542	12.6	2.710	150
To1c	DITTO	68.25	225.55	6	7.979	8.405	12.6	2.660	150
To1b	DITTO	68.25	225.55	6	8.125	8.551	12.6	2.710	150
To1a	DITTO	60.25	205.55	6	10.916	11.343	12.6	3.640	150
	SUB TOTAL	333.25	1107.75	30	44.715	46.846		14.920	750
PAC-1	TOTAL	1030	3289.31	98	119.476	127.654	12.5	39.900	4.230
					SHF = 0.94				

2). PEAK LOAD TIME (1)

NO.	ROOM NAME	3:00		5:00		6:00	
		E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)
1F. G02	ENTRANCE & ENTRANCE HALL	*	*				
		4.967	5.285	4706	5.021	4.428	4.740
	SUB TOTAL	4.967	5.285	4706	5.021	4.428	4.740
2F F02	SECRETARY ROOM	*	*				
		1.593	1.736	1.520	1.663	1.336	1.478
F02	ASSISTANT SUPERINTENDENT RM			*	*		
		6.184	6.968	6.610	6.895	6.417	6.700
F01	SUPERINTENDENT RM.			*	*		
		9.598	10.169	10.716	11.285	10.417	10.985
F01	SECRETARY ROOM	*	*				
		1.856	2.142	1.723	2.008	1.581	1.865
F07	TELCOMUNICATION ROOM			*	*		
		4.277	4.634	4.872	5.228	4.843	5.198
F04	CANTEEN <small>PEAK 4:00</small>						
		14.152	16.133	13.964	15.921	12.738	14.395
	SUB TOTAL	37.660	41.282	39.405	43.000	37.332	40.621
3F S02	SECRETARY ROOM	*	*				
		927	1.070	884	1.027	840	982
S02	ASSISTANT SUPERINTENDENT RM.			*	*		
		4.687	4.971	5.306	5.591	5.304	5.587
S01	SECRETARY ROOM	*	*				
		1.130	1.273	1.067	1.210	1.003	1.145
S01	ASSISTANT SUPERINTENDENT RM.					*	*
		3.078	3.363	4.187	4.470	4.239	4.523
S03C	JUNIOR ENGINEER ROOM					*	*
		3.823	4.251	4.928	5.355	4.976	5.402
S03b	DITTO					*	*
		4.095	4.523	4.807	5.234	5.196	5.622
S03a	DITTO			*	*		
		7.013	7.441	7.970	8.397	7.559	7.985
	SUB TOTAL	24.753	26.892	29.149	31.284	29.117	31.246

2). PEAK LOAD TIME (2)

No.	ROOM NAME	3:00		5:00		6:00	
		E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)
4F	JUNIOR					*	*
To1e	ENGINEER ROOM	8083	8511	9.541	9.968	9.579	10.005
To1d	DITTO	6.465	6.893	7.990	8.417	8.116	8.542
To1c	DITTO	6.294	6.722	7.835	8.262	7.979	8.405
To1b	DITTO	6.475	6.903	7.999	8.426	8.125	8.551
To1a	DITTO	9.576	10.004	* 10.916	* 11.343	10.575	11.001
	SUB TOTAL	36.893	39.033	44.281	46.416	44.374	46.504
PAC-1	TOTAL	104.273	112.492	* 117.541	* 125.721	115.251	123.111

10001

4-2 PAC-2 (SE-SYSTEM)
1) ROOM PEAK LOAD

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(%)	DEHUM AIR (m ³ /H)	OUT AIR (m ³ /H)
					R.S.H (Kcal/H)	R.T.H (Kcal/H)			
ZF F03	CONFERENCE ROOM	84.5	253.5	16	9658	10.792	12.1	3,220	400
F09	CORRIDOR	87.25	218.13	-	6.523	6.523	13.2	2180	-
	SUB TOTAL	171.75	471.63	16	16.181	17.315		5400	400
3F S05d	EXECUTIVE ENGINEER ROOM	21.13	80.29	2	1.926	2.069	12.3	640	50
S05c	DITTO	21.13	80.29	2	1.709	1.852	12.3	570	50
S05b	DITTO	21.13	80.29	2	1.709	1.852	12.3	570	50
S05a	DITTO	21.13	80.29	2	2.010	2.153	12.3	670	50
S04	PRAY ROOM	42.25	160.55	12	5809	6.664	11.8	1940	300
S06	CORRIDOR	101.5	253.75	-	5.102	5.102	13.2	1700	-
	SUB TOTAL	228.27	735.46	20	18.265	19.692		6090	500
4F T03d	EXECUTIVE ENGINEER ROOM	21.13	80.29	2	2.770	2.912	12.5	920	50
T03c	DITTO	21.13	80.29	2	2.503	2.646	12.5	840	50
T03b	DITTO	21.13	80.29	2	2.503	2.646	12.5	840	50
T03a	DITTO	21.13	80.29	2	2.873	3.015	12.5	960	50
T02	LIBRARY & STRAGE ROOM	42.25	160.55	4	7009	7.293	12.6	2340	100
T04	CORRIDOR	101.5	253.75	-	7.963	7.963	13.2	2.660	-
	SUB TOTAL	228.27	735.46	12	25.621	26.475		8560	300
PAC-2 TOTAL		628.29	1942.55	48	60.067	63.482	SELECTED 12.5°C	26.650	1,200

SHP=0.95

1001

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR ENTRANCE - ENTRANCE HALL (602) PAC-1 SYSTEM
 SIZE m x m = 84.0 m² x m(H) = 240.63 m³

SHEET No. 12
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM
				MAX	3:00	5:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)			
	m ²	X					OUTSIDE DESIGN CONDITIONS °C DB °C WB °C %RH			
	m ²	X					CONDITIONS: DB °C WB °C %RH DP °C g/kg			
	m ²	X					OUTSIDE 47.2 28.6 37 19.0			
	m ²	X					ROOM 24.0 17.1 50 9.4			
	m ²	X					DIFFERENCE 18.2 X X X X X X X X X X 9.6			
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D			
WALL	m ²	X					GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE			
	m ²	X					COLOR LIGHT, MEDIUM, DARK.			
	m ²	X					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)			
	m ²	X					INTERNAL HEAT W/m ² m ² /PEOPLE			
ROOF - SUN	m ²	X					INFILTRATION			
ROOF - SHADED	m ²	X					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.			
GLASS	15.5 m ²	9.1 X	3.8	536	486	433	OPEN DOORS DOORS X CMH/DOOR			
CEILING	16.0 m ²	9.1 X	1.4	204	185	165	EXHAUST AIR			
DOOR	6.8 m ²	18.2 X	1.6	198	180	160	CRACK m X CMH/m			
PARTITION (1)	21.6 m ²	18.2 X	1.8	708	642	572	INFILTRATION CMH			
(2)	3.2 m ²	26.0 X	1.8	150	150	150	VENTILATION			
(3)	30.0 m ²	9.1 X	2.5	683	619	552	PEOPLE X CMH/PER.			
INFILTRATION	CMH X deg X		0.29				J m ² X CMH/m ²			
INTERNAL HEAT							VENTILATION CMH			
PEOPLE	PEOPLE X						SENSIBLE HEAT FACTOR			
Kw	Kw X	X	860				E.S.H.F. = 496.7 (ERSH) = 0.94 (12.5°C)			
LIGHTS	84.0 X 20 W X		1.08	1815	1815	1815	5285 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE m ² X deg X (-)							APPARATUS DEWPOINT 12.5 °C			
Sub TOTAL							496.7 (ERSH)			
Safety Factor %							(20RM - (25ADP) (1 - BF) X 0.29) = 1.660 CMH			
ROOM SENSIBLE HEAT Sub TOTAL							NOTES			
SUPPLY DUCT	SUPPLY DUCT	FAN		430	408	385	PARTITION			
HEAT GAIN	+ LEAK LOSS	+ HP	= 16%				(1): 10.0 x 2.5 - 1.7 x 2.0 = 21.6			
BYPASS OUTSIDE AIR 460 CMH X 18.2 X 0.1 BF X 0.29							(2): 2.0 x 2.5 - 0.9 x 2.0 = 3.2			
EFFECTIVE ROOM SENSIBLE HEAT							(3): 12.0 x 2.5 = 30.0			
ROOM LATENT HEAT							GLASS (IN): 6.2 x 2.5 = 15.5			
INFILTRATION	CMH X g/kg X		0.72				DOOR (IN): 1.7 x 2.0 x 2 = 6.8			
PEOPLE	PEOPLE X						CEILING: 4.0 x 4.0 + 6.0 = 22.0			
STEAM	kg/h X		540				SR: 12.0 x 6.5 + 2.0 x 3.0 = 84.0			
APPLIANCES ETC.							VR: 6.5 x 3.5 x 2.5 + (8.5 x 6.5 + 2.0 x 3.0) x 3.0 = 240.63			
VAPOR TRANS.										
Sub TOTAL										
Safety Factor %										
ROOM LATENT HEAT Sub TOTAL										
SUPPLY DUCT	LEAKAGE LOSS									
BYPASS OUTSIDE AIR 460 CMH X 9.6 g/kg X 0.1 BF X 0.72										
EFFECTIVE ROOM LATENT HEAT										
EFFECTIVE ROOM TOTAL HEAT										
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X deg X (1 - BF) X 0.29									
LATENT:	CMH X g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	LEAK GAIN	H.P.	GAIN							
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **SECRETARY ROOM (FO2)** **PAC-1 SYSTEM**
 SIZE **4.0 m x 4.0 m = 16.0 m²** x **2.5 m(H) = 40 m³**

SHEET No. 13
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3
				MAX	3:00	5:00				
SOLAR GAIN - GLASS										
	m ² X	X								
	m ² X	X								
	m ² X	X								
	m ² X	X								
	m ² X	X								
SOLAR & TRANS GAIN - WALLS & ROOF										
WALL	m ² X	X								
	m ² X	X								
	m ² X	X								
	m ² X	X								
	m ² X	X								
ROOF - SUN	m ² X	X								
ROOF - SHADED	m ² X	X								
TRANS. GAIN - EXCEPT WALLS & ROOF										
GLASS	m ² X	X								
CEILING	m ² X	X								
FLOOR	16.0 m ² X	13.2	X 2.5	528	508	388				
PARTITION (1)	10.2 m ² X	9.1	X 1.8	167	152	135				
(2)	12.0 m ² X	9.1	X 2.5	273	248	221				
DOOR	1.8 m ² X	9.1	X 1.6	27	24	22				
INFILTRATION	CMHX	degX	0.29							
INTERNAL HEAT										
PEOPLE	2 PEOPLEX	41		82	82	82				
KW	KWX	X	860							
LIGHTS	16.0 x 20 WX		1.08	346	346	346				
APPLIANCES ETC.										
CREDIT FOR THERMAL STORAGE	m ² X	degX								
Sub TOTAL										
SAFETY FACTOR %										
ROOM SENSIBLE HEAT Sub TOTAL				1423	1360	1194				
SUPPLY DUCT	SUPPLY DUCT	FAN								
HEAT GAIN	+LEAK LOSS	+HP	=10%	143	136	120				
BYPASS OUTSIDE AIR	50 CMHX	18.2 degX	0.1 BF x 0.29	27	24	22				
EFFECTIVE ROOM SENSIBLE HEAT				1593	1520	1336				
ROOM LATENT HEAT										
INFILTRATION	CMHX	g/KGX	0.72							
PEOPLE	2 PEOPLEX	44		98	98	98				
STEAM	kg/hX	540								
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL				98	98	98				
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL										
SUPPLY DUCT LEAKAGE LOSS			10%	10	10	10				
BYPASS OUTSIDE AIR	50 CMHX	9.6 g/kgX	0.1 BF x 0.72	35	35	34				
EFFECTIVE ROOM LATENT HEAT				143	143	142				
EFFECTIVE ROOM TOTAL HEAT				1736	1663	1478				
OUTSIDE AIR HEAT				(109)						
SENSIBLE:	CMHX	degX	(1 - BF) x 0.29							
LATENT:	CMHX	g/kgX	(1 - BF) x 0.72							
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	LEAK GAIN	H.P.	GAIN							
(U.S.R.T) GRAND TOTAL HEAT										

HOURS OF OPERATION	Hour			
OUTSIDE DESIGN CONDITIONS	COB	CWB	%RH	
CONDITIONS:	DB °C	WB °C	%RH	DP °C
OUTSIDE	47.2	28.6	37	19.0
ROOM	24.0	17.1	50	9.0
DIFFERENCE	18.2	X X X	X X X	X X X
BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L M D			
GLASS	ORDINARY, THICK, ABSORBENT, % DOUBLE			
COLOR	LIGHT, MEDIUM, DARK			
WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
INTERNAL HEAT	W/m ²		m ² /PEOPLE	
INFILTRATION				
SWINGING				
REVOLVING DOORS	PEOPLEX CMH/PER.			
OPEN DOORS	DOORSX CMH/DOOR			
EXHAUST AIR				
CRACK	mX	CMH/m		
INFILTRATION	CMH			
VENTILATION				
2 PEOPLEX	25 CMH/PER.		50	
1 m ² X	CMH/m ²			
VENTILATION	CMH			
SENSIBLE HEAT FACTOR				
E.S.H.F. =	1.593 (ERSH)	= 0.92 (12.3°C)		
	1736 (ERTH)			
DEHUMIDIFIED AIR				
APPARATUS DEWPOINT	12.5 °C			
	1.593 (ERSH)			
(24 RM - 12.5 ADP) (1 - BF) x 0.29	= 530 CMH			

NOTES
 • PARTITION:
 (1) : 4.0 x 3.0 - 1.8 = 10.2
 (2) : 4.0 x 3.0 = 12.0
 • FLOOR : 4.0 x 4.0 = 16.0
 • DOOR : 0.9 x 2.0 = 1.8

1010

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR ASSISTANT SUPERINTENDENT ROOM (FOZ) PAC-1 SYSTEM
 SIZE 6.5 m x 6.5 m = 42.25 m² x 9.0 m H = 126.75 m³

SHEET No. 4
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX 5:00	3:00	6:00				
SOLAR GAIN — GLASS							HOURS OF OPERATION	Hour (-)		
NE)	6.9 m ² x 3.6 x 0.13 x 1/0.85 x 0.94 x 0.65			236	291	200	OUTSIDE DESIGN CONDITIONS	°CDB	°CWB	%RH
NW)	5.4 m ² x 3.6 x 0.45 x 1/0.85 x 0.94 x 0.65			924	483	923	CONDITIONS	DB °C	WB °C	%RH
	m ² x	X					OUTSIDE	40.5	28.2	99
	m ² x	X					ROOM	24.0	17.1	50
	m ² x	X					DIFFERENCE	16.5	X X X	X X X
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.H.D.		
WALL (NE)	19.1 m ² x 13.0 x 2.1	X	2.1	522	478	542	GLASS	ORDINARY, THICK, ABSORBENT, % DOUBLE		
(NW)	20.6 m ² x 19.5 x 2.1	X	2.1	844	584	1004	COLOR	LIGHT, MEDIUM, DARK.		
	m ² x	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)
	m ² x	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE
ROOF—SUN	m ² x	X					INFILTRATION			
ROOF—SHADED	m ² x	X					SWINGING			
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.			
GLASS	12.3 m ² x 16.5 x 5.1	X	5.1	1035	1142	923	OPEN DOORS DOORS X CMH/DOOR			
CEILING	m ² x	X					EXHAUST AIR			
FLOOR	42.25 m ² x 11.5 x 2.5	X	2.5	1215	1395	1025	CRACK m x CMH/m			
PARTITION	7.6 m ² x 8.25 x 1.8	X	1.8	112	123	100	INFILTRATION CMH			
INFILTRATION CMH x deg x 0.29							VENTILATION			
INTERNAL HEAT							4 PEOPLE X 25 CMH/PER. 100			
PEOPLE	4 PEOPLE X 41			164	164	164	VENTILATION CMH			
Kw	Kw x X 860						SENSIBLE HEAT FACTOR			
LIGHTS	42.25 x 20 W x 1.08			913	913	913	E.S.H.F = $\frac{6610}{6895}$ (ERSH) = 0.96 (12.0°)			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE m ² x deg x (-) (-)							APPARATUS DEWPOINT 12.5 °C			
Sub TOTAL							$\frac{6610}{6895}$ (ERSH) = 2210 CMH			
SAFETY FACTOR %							NOTES			
ROOM SENSIBLE HEAT Sub TOTAL				5965	5573	5194	GLASS (NE) : 15 x 1.8 + 1.5 x 2.8 = 6.9			
SUPPLY DUCT	SUPPLY DUCT FAN						(NW) : 1.5 x 1.8 x 2 = 5.4			
HEAT GAIN	-LEAK LOSS -HP = 10%			597	558	520	WALL (NE) : 6.5 x 4.0 = 6.9 = 19.1			
BYPASS OUTSIDE AIR 100 CMH x 16.5 deg x 0.1 BF x 0.29				48	53	43	(NW) : 6.5 x 4.0 - 5.4 = 20.6			
EFFECTIVE ROOM SENSIBLE HEAT				6610	6184	6417	PARTITION : 25 x 3.0 = 7.5			
ROOM LATENT HEAT							FLOOR : SR			
INFILTRATION	CMH x g/kg x 0.72									
PEOPLE	4 PEOPLE X 49			196	196	196				
STEAM	kg/h x 540									
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR *										
ROOM LATENT HEAT Sub TOTAL										
SUPPLY DUCT	LEAKAGE LOSS 10%			20	20	20				
BYPASS OUTSIDE AIR 100 CMH x 9.5 g/kg x 0.1 BF x 0.72				69	70	68				
EFFECTIVE ROOM LATENT HEAT				285	284	283				
EFFECTIVE ROOM TOTAL HEAT				6895	6468	6700				
OUTSIDE AIR HEAT (164)										
SENSIBLE:	CMH x deg x (1 - BF) x 0.29									
LATENT:	CMH x g/kg x (1 - BF) x 0.72									
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT - PUMP - PIPE = %									
HEAT GAIN	LEAK GAIN H.P. - GAIN = %									
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INSURING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR SUPERINTENDENT ROOM (FOI) PAC-1 SYSTEM
 SIZE 13.0 m x 6.5 m = 84.5 m² x 3.0 m H = 253.5 m³

SHEET NO. 15
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM 5		
				MAX	5:00	CORRECTION						
SOLAR GAIN - GLASS							HOURS OF OPERATION		Hour (-)			
(NW)	12.3	m ² x 366 x 0.65 / 0.95 x 0.94 x 6.65		2104	1101	2072	OUTSIDE DESIGN CONDITIONS		CDB	CWB	%RH	
	m ² x	X					CONDITIONS	DB °C	WB °C	%RH	DP °C	E/KE
	m ² x	X					OUTSIDE	40.5	28.2	39		18.9
	m ² x	X					ROOM	24.0	17.1	50		9.4
	m ² x	X					DIFFERENCE	16.5	X X X	X X X	X X X	9.5
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND		[NON-EXISTENCE (OUTSIDE, INSIDE) L. M. D			
WALL (NW)	39.7	m ² x 195	X 2.1	1626	1126	1935	GLASS		ORDINARY, THICK, ABSORBENT. % DOUBLE			
	m ² x	X					COLOR		LIGHT, MEDIUM, DARK.			
	m ² x	X					WEIGHT		kg/m ² (FLOOR) kg/m ² (WALL)			
	m ² x	X					INTERNAL HEAT		W/m ² m ² /PEOPLE			
ROOF - SUN	m ² x	X					INFILTRATION					
ROOF - SHADED	m ² x	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS		PEOPLES CMH/PER.			
GLASS	12.3	m ² x 16.5	X 5.1	1053	1142	923	OPEN DOORS		DOORS X CMH/DOOR			
CEILING	m ² x	X					EXHAUST AIR					
FLOOR	84.5	m ² x 11.5	X 2.5	2430	2789	2050	CRACK		m x CMH/m			
PARTITION	17.7	m ² x 8.25	X 1.8	263	270	235	INFILTRATION CMH					
DOOR	1.8	m ² x 8.25	X 1.6	24	27	22	VENTILATION					
							8 PEOPLES		25 CMH/PER.		200	
INFILTRATION	CMH X	deg X	0.29				1' m ² X		CMH/m ²			
INTERNAL HEAT							VENTILATION		CMH			
PEOPLE	8	PEOPLES	41	328	328	328	SENSIBLE HEAT FACTOR					
Kw	X	X	B60				E.S.H.F. =		10716 (ERSH) = 0.95 (12.5°C)			
LIGHTS	845	X 20 W X	1.08	826	1826	1826			11285 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT		12.5 °C			
CREDIT FOR THERMAL STORAGE	m ² X	deg X	(-)	(-)	(-)	(-)	10716 (ERSH)					
							(24 RM - 12.5 ADP) (1 - BF) X 0.29		= 3580 CMH			
Sub Total												
SAFETY FACTOR %												
ROOM SENSIBLE HEAT Sub Total				9654	8629	9391	NOTES • GLASS (NW) : 15 x 1.8 x 3 + 1.5 x 2.8 = 12.3 • WALL (NW) : 13.0 x 4.0 - 12.3 = 39.7 • PARTITION : 6.5 x 3.0 - 1.8 = 17.7 • DOOR : 0.9 x 2.0 = 1.8 • FLOOR : SR					
SUPPLY DUCT	SUPPLY DUCT	FAN										
HEAT GAIN	- LEAK LOSS	- HP	= 10%	966	863	940						
BYPASS OUTSIDE AIR	200 CMH x 16.5 deg x 0.1 BF x 0.29			96	106	86						
EFFECTIVE ROOM SENSIBLE HEAT				10716	9598	10417						
ROOM LATENT HEAT												
INFILTRATION	CMH X	E/KE X	0.72									
PEOPLE	8	PEOPLES	49	392								
STEAM		kg/h X	540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub Total												
SAFETY FACTOR %												
ROOM LATENT HEAT Sub Total				392	392	392						
SUPPLY DUCT LEAKAGE LOSS			10%	40	40	40						
BYPASS OUTSIDE AIR	200 CMH x 9.5 E/KE x 0.1 BF x 0.72			137	139	136						
EFFECTIVE ROOM LATENT HEAT				569	571	568						
EFFECTIVE ROOM TOTAL HEAT				11285	10169	10985						
				(134)								
OUTSIDE AIR HEAT												
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29										
LATENT:	CMH X	E/KE X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub Total												
RETURN DUCT	RETURN DUCT	PUMP	PIPE				= %					
HEAT GAIN	LEAK GAIN	H.P	GAIN									
(U.S.R.T) GRAND TOTAL HEAT												

1012

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No.	INQUIRED BY	SHEET No. 16
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR SECRETARY ROOM (F01)	PAC-1 SYSTEM	REVISION
SIZE $m \times m = 24.0 \text{ m}^2$	$\times 2.5 \text{ m H.F.} = 60 \text{ m}^2$	PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX	3:00	5:00				
SOLAR GAIN -- GLASS										
	$m^2 \times$	X								
	$m^2 \times$	X								
	$m^2 \times$	X								
	$m^2 \times$	X								
	$m^2 \times$	X								
SOLAR & TRANS GAIN--WALLS & ROOF										
WALL	$m^2 \times$	X								
	$m^2 \times$	X								
	$m^2 \times$	X								
	$m^2 \times$	X								
ROOF--SUN	$m^2 \times$	X								
ROOF--SHADED	$m^2 \times$	X								
TRANS. GAIN--EXCEPT WALLS & ROOF										
GLASS	$m^2 \times$	X								
CEILING	$m^2 \times$	X								
FLOOR	$24.0 \text{ m}^2 \times$	13.2 X	2.5	792	690	582				
PARTITION	$10.0 \text{ m}^2 \times$	9.1 X	1.8	164	149	133				
INFILTRATION										
CMH X deg X 0.29										
INTERNAL HEAT										
PEOPLE	4 PEOPLE X	41		164	164	164				
Kw	Kw X	X	860							
LIGHTS	$24.0 \times 20 \text{ W X}$		1.08	519	519	519				
APPLIANCES ETC.										
CREDIT FOR THERMAL STORAGE										
Sub TOTAL										
SAFETY FACTOR %										
ROOM SENSIBLE HEAT Sub TOTAL				1639	1522	1398				
SUPPLY DUCT	SUPPLY DUCT	FAN								
HEAT GAIN	+LEAK LOSS	-HP	=10%	164	153	140				
BYPASS OUTSIDE AIR $100 \text{ CMH} \times 18.2 \text{ deg} \times 0.1 \text{ BF} \times 0.29$				53	48	43				
EFFECTIVE ROOM SENSIBLE HEAT				1856	1723	1581				
ROOM LATENT HEAT										
INFILTRATION	CMH X	g/kg X	0.72							
PEOPLE	4 PEOPLE X	49		196						
STEAM	kg/h X	540								
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL				196	196	196				
SUPPLY DUCT	LEAKAGE LOSS	10 %		20	20	20				
BYPASS OUTSIDE AIR $100 \text{ CMH} \times 9.6 \text{ g/kg} \times 0.1 \text{ BF} \times 0.72$				70	67	68				
EFFECTIVE ROOM LATENT HEAT				286	285	284				
EFFECTIVE ROOM TOTAL HEAT				2142	2008	1865				
OUTSIDE AIR HEAT				(89)						
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29								
LATENT:	CMH X	g/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+LEAK GAIN	-HP	+GAIN	= %						
(U.S.R.T) GRAND TOTAL HEAT										

HOURS OF OPERATION	Hour (-)
OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
CONDITIONS	DB C	WB C	%RH DP C
OUTSIDE	42.2	28.6	39
ROOM	24.0	17.1	50
DIFFERENCE	18.2	X X X	X X X
BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L M D		
GLASS	ORDINARY, THICK, ABSORBENT, % DOUBLE		
COLOR	LIGHT, MEDIUM, DARK		
WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)	
INTERNAL HEAT	W/m ²	m ² /PEOPLE	
INFILTRATION			
SWINGING			
REVOLVING DOORS PEOPLE X CMH/PER.			
OPEN DOORS DOORS X CMH/DOOR			
EXHAUST AIR			
CRACK	m X	CMH/m	
INFILTRATION CMH			
VENTILATION			
4 PEOPLE X	25	CMH/PER. 100	
1 m ² X	CMH/m ²		
VENTILATION CMH 100			
SENSIBLE HEAT FACTOR			
E.S.H.F. =	1.856	(ERSH) = $0.87 (11.8^\circ C)$	
	2142	(ERTH)	
DEHUMIDIFIED AIR			
APPARATUS DEWPOINT	12.5	C	
	1856	(ERSH)	
(24RM - 12 ADP) (1 - BF) X 0.29	620	CMH	

NOTES

SR: $6.5 \times 4.0 - 2.0 = 24.0$

PARTITION: $4.0 \times 2.5 = 10.0$

FLOOR: SR

10/13

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **TELECOMMUNICATION ROOM (F07)** PAC-1 SYSTEM
 SIZE m² x m = **57.25** m² x **3** m(H) = **156.75** m³

SHEET No. 17
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM5	
				MAX	CORRECTION						
SOLAR GAIN - GLASS							HOURS OF OPERATION		Hour (-)		
(NW)	5.4 m ²	366 x 0.65 x 0.85	0.94 x 0.65	925	484	910	OUTSIDE DESIGN CONDITIONS		CDB CWB %RH		
	m ²	X					CONDITIONS	DB C	WB C	%RH	
	m ²	X					OUTSIDE	40.5	28.7	39	
	m ²	X					ROOM	24.0	17.1	50	
	m ²	X					DIFFERENCE	16.5	X X X	X X X	
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND		NON-EXISTENCE (OUTSIDE, INSIDE) L M D		
WALL (NW)	20.6 m ²	19.5	X 2.1	844	584	1004	GLASS	ORDINARY, THICK, ABSORBENT, % DOUBLE			
	m ²	X					COLOR	LIGHT, MEDIUM, DARK			
	m ²	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ²	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE	
ROOF - SUN	m ²	X					INFILTRATION				
ROOF - SHADED	m ²	X					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS		PEOPLEX CMH/PER.		
GLASS	m ²	X					OPEN DOORS	DOORS X CMH/DOOR			
CEILING	m ²	X					EXHAUST AIR				
FLOOR	19.5 m ²	11.5	X 2.5	561	644	473	CRACK	m X		CMH/m	
PARTITION	45.9 m ²	8.25	X 1.8	675	744	601	INFILTRATION CMH				
DOOR	2.6 m ²	8.25	X 1.6	35	38	31	VENTILATION				
INFILTRATION CMH X deg X 0.29							5 PEOPLEX		25 CMH/PER.		125
INTERNAL HEAT							1' m ²		CMH/m ²		
PEOPLE	5 PEOPLEX	41		205	205	205	VENTRATION		CMH		
KW	KWX	X	860				SENSIBLE HEAT FACTOR				
LIGHTS	5725 X 20 WX	X	1.08	1129	1129	1129	E.S.H.F =		4.872 (ERSH) = 0.93 (124°C)		
APPLIANCES ETC.							5 228		(ERTH)		
CREDIT FOR THERMAL STORAGE m ² X deg X							DEHUMIDIFIED AIR				
Sub TOTAL							APPARATUS DEWPOINT		12.5 C		
SAFETY FACTOR %							4.872 (ERSH)				
ROOM SENSIBLE HEAT Sub TOTAL							24 RM - (25 ADP) (1 - BF) X 0.29		= 1.630 CMH		
SUPPLY DUCT	SUPPLY DUCT	FAN		438	383	436	NOTES				
HEAT GAIN	+ LEAK LOSS	- HP	40 %				SR : 10.5 x 6.5 - 4.0 x 4.0 = 57.25				
BYPASS OUTSIDE AIR 125 CMH X 16 F.O.E. X 0.1 BF X 0.29							GLASS (NW) : 1.5 x 1.8 x 2 = 5.4				
EFFECTIVE ROOM SENSIBLE HEAT							WALL (NW) : 6.5 x 4.0 - 5.4 = 20.6				
ROOM LATENT HEAT							PARTITION : 16.0 x 3.0 - 2.6 = 45.4				
INFILTRATION	CMH X	g/kg X	0.72				FLOOR : 3.0 x 6.5 = 19.5				
PEOPLE	5 PEOPLEX	49		245	245	245	DOOR : 1.3 x 2.0 = 2.6				
STEAM		kg/h X	540								
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL											
SUPPLY DUCT	LEAKAGE LOSS		10 %	25	25	25					
BYPASS OUTSIDE AIR 125 CMH X 9.5 g/kg X 0.1 BF X 0.72											
EFFECTIVE ROOM LATENT HEAT											
EFFECTIVE ROOM TOTAL HEAT							5228 4634 6198				
OUTSIDE AIR HEAT (101)											
SENSIBLE: CMH X deg X (1 - BF) X 0.29											
LATENT: CMH X g/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	- H.P.	- GAIN								
(U.S.R.T) GRAND TOTAL HEAT											

10/10

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **CANTEEN (FO4)** PAC-1 SYSTEM
 SIZE $m \times m = 78.5 \text{ m}^2$ $\times 3.8, 2.5 \text{ m(H)} = 251.18 \text{ m}^3$

SHEET No. **18**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
				4:00	3:00	5:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour ()				
(NW)	5.4	$m^2 \times 366 \times 0.52 / 685 \times 0.94 \times 0.65$		1739	484	925	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
(SW)	12.3	$m^2 \times 252 \times 0.64 / 685 \times 0.94 \times 0.65$		1476	1560	1115	CONDITIONS DB°C WB°C %RH DPC g/kg				
	$m^2 \times$	\times					OUTSIDE	41.7	28.4	38	18.8
	$m^2 \times$	\times					ROOM	24.0	17.1	50	9.4
	$m^2 \times$	\times					DIFFERENCE	17.7	X X X	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D				
WALL (NW)	20.6	$m^2 \times 15.4 \times 2.1$		667	584	844	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
(SW)	39.7	$m^2 \times 18.6 \times 2.1$		1551	1318	1601	COLOR LIGHT, MEDIUM, DARK.				
	$m^2 \times$	\times					WEIGHT		kg/m ² (FLOOR)	kg/m ² (WALL)	
	$m^2 \times$	\times					INTERNAL HEAT		W/m ²	m ² /PEOPLE	
ROOF - SUN	$m^2 \times$	\times					INFILTRATION				
ROOF - SHADED	$m^2 \times$	\times					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER				
GLASS	17.7	$m^2 \times 17.7 \times 5.1$		1598	1643	1490	OPEN DOORS DOORS X CMH/DOOR				
CEILING	$m^2 \times$	\times					EXHAUST AIR				
FLOOR	78.5	$m^2 \times 12.7 \times 2.5$		2493	2591	2257	CRACK		m X	CMH/m	
PARTITION (1)	26.6	$m^2 \times 8.85 \times 1.8$		424	436	395	INFILTRATION CMH				
(2)	24.7	$m^2 \times 17.7 \times 2.5$		1093	1124	1019	VENTILATION				
							15 PEOPLE X		2.5	CMH/PER.	
INFILTRATION	CMH X	deg X	0.29				i		m ³ /m ²		
INTERNAL HEAT							VENTILATION CMH				
PEOPLE	15	PEOPLE X	41	615	615	615	SENSIBLE HEAT FACTOR				
Kw	Kw X	X	860				E.S.H.F. = $\frac{14403 \text{ (ERSH)}}{16360 \text{ (ERTH)}} = 0.88 (11.9^\circ\text{C})$				
LIGHTS	78.5 X 20	W X	1.08	1676	1676	1676	DEHUMIDIFIED AIR				
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C				
CREDIT FOR THERMAL STORAGE	$m^2 \times$	deg X	(-)				14.403 (ERSH)				
		Sub TOTAL					24 RM - (2.5 ADP) (1 - BF) X 0.29 = 481.0 CMH				
SAFETY FACTOR							NOTES				
ROOM SENSIBLE HEAT Sub TOTAL				12302	12051	11957	SR: $13.0 \times 6.5 - 1.5 \times 4.0 = 78.5$				
SUPPLY DUCT	SUPPLY DUCT	FAN					• GLASS (NW): $1.5 \times 1.8 \times 2 = 5.4$				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	1231	1206	1196	(SW): $1.5 \times 1.8 \times 3 + 1.5 \times 2.8 = 12.3$				
BYPASS OUTSIDE AIR	1695 CMH X 17.7 deg X 0.1 BF X 0.29			870	875	811	• WALL (NW): $6.5 \times 4.0 - 5.4 = 20.6$				
EFFECTIVE ROOM SENSIBLE HEAT				14403	14152	13964	(SW): $13.0 \times 4.0 - 12.3 = 39.7$				
ROOM LATENT HEAT							• PARTITION				
INFILTRATION	CMH X	g/kg X	0.72				(1): $7.0 \times 3.8 = 26.6$				
PEOPLE	15	PEOPLE X	49	735			(2): $6.5 \times 3.8 = 24.7$				
STEAM		kg/h X	540				• FLOOR: SR				
APPLIANCES ETC.							VR = $6.5 \times 6.5 \times 3.8 + (6.5 \times 6.5 - 1.5 \times 4) \times 2.5$				
VAPOR TRANS.							= 251.18				
SAFETY FACTOR							(6:00): 14,395				
ROOM LATENT HEAT Sub TOTAL				735	735	735					
SUPPLY DUCT LEAKAGE LOSS		10%		74	74	74					
BYPASS OUTSIDE AIR	1695 CMH X 9.4 g/kg X 0.1 BF X 0.72			1148	1172	1148					
EFFECTIVE ROOM LATENT HEAT				1957	1981	1957					
EFFECTIVE ROOM TOTAL HEAT				16360	16133	15921					
OUTSIDE AIR HEAT											
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29									
LATENT:	CMH X	g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	LEAK GAIN	H.P.	GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **SECRETARY ROOM (502)** PAC-1 SYSTEM
 SIZE **4.0 m x 4.0 m = 16.0 m²** x **2.5 m H = 4.0 m³**

SHEET No. **19**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3		
				MAX	3:00	5:00					6:00	
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
	m ² X	X					OUTSIDE DESIGN CONDITIONS 'CDB' 'CWB' %RH					
	m ² X	X					CONDITIONS DB °C WB °C %RH DP °C g/kg					
	m ² X	X					OUTSIDE	42.2	28.6	37	19.0	
	m ² X	X					ROOM	24.0	17.1	50	9.4	
	m ² X	X					DIFFERENCE	X X X	X X X	X X X	9.6	
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L. M. D					
WALL	m ² X	X					GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² X	X					COLOR LGHT. MEDIUM. DARK.					
	m ² X	X					WEIGHT		kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² X	X					INTERNAL HEAT		W. m ²		m ² /PEOPLE	
ROOF - SUN	m ² X	X					INFILTRATION					
ROOF - SHADED	m ² X	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.					
GLASS	m ² X	X					OPEN DOORS DOORS X CMH/DOOR					
CEILING	m ² X	X					EXHAUST AIR					
FLOOR	m ² X	X					CRACK m X CMH/m					
PARTITION (1)	8.2 m ² X	9.1 X	1.8	135	122	109	INFILTRATION CMH					
(2)	10.0 m ² X	9.1 X	2.5	228	207	184	VENTILATION					
DOOR	1.8 m ² X	9.1 X	1.6	27	24	22	Z PEOPLE X		25 CMH/PER.		50	
INFILTRATION	CMHX	deg X	0.29				f' m ² X		CMH/m ²			
INTERNAL HEAT							VENTILATION CMH					
PEOPLE	Z PEOPLE X	41		82	82	82	SENSIBLE HEAT FACTOR					
Kw	Kw X	X	860				E.S.H.F. = $\frac{927}{1070}$ (ERSH) = 0.87 (11.8°C)					
LIGHTS	16.0 X 20 W X		1.08	346	346	346	DEHUMIDIFIED AIR					
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C					
CREDIT FOR THERMAL STORAGE	m ² X	deg X	(-)	(-)	(-)	(-)	$\frac{927}{(24 \text{ RM} - 12.5 \text{ ADP}) (1 - BF) \times 0.29} = 310 \text{ CMH}$					
Sub TOTAL												
SAFETY FACTOR				%			NOTES					
ROOM SENSIBLE HEAT Sub TOTAL					818	781	743	PARTITION				
SUPPLY DUCT	SUPPLY DUCT	FAN					(1) 4.0 x 2.5 - 1.8 = 8.2					
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	82	79	75	(2) 4.0 x 2.5 = 10.0					
BYPASS OUTSIDE AIR 50 CMH X 18.2 deg X 0.1 BF X 0.29					27	24	22	DOOR : 0.9 x 2.0 = 1.8				
EFFECTIVE ROOM SENSIBLE HEAT					927	884	840					
ROOM LATENT HEAT												
INFILTRATION	CMHX	g/kg X	0.72									
PEOPLE	Z PEOPLE X	49		98								
STEAM		kg/h X	540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub TOTAL												
SAFETY FACTOR				%								
ROOM LATENT HEAT Sub TOTAL					98	98	98					
SUPPLY DUCT	LEAKAGE LOSS		10 %	10	10	10						
BYPASS OUTSIDE AIR 50 CMH X 9.6 g/kg X 0.1 BF X 0.72					35	35	34					
EFFECTIVE ROOM LATENT HEAT					143	143	142					
EFFECTIVE ROOM TOTAL HEAT					1070	1027	982					
OUTSIDE AIR HEAT					(67)							
SENSIBLE:	CMHX	deg X (1 - BF) X 0.29										
LATENT:	CMHX	g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE				= %					
HEAT GAIN	LEAK GAIN	H.P.	GAIN									
(U.S.R.T.) GRAND TOTAL HEAT												

9101

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **ASSISTANT SUPERINTENDENT ROOM (502) PAC-1 SYSTEM**
 SIZE **6.5 m x 6.5 m = 42.25 m²** x **3.8 m(H) = 160.5 m³**

SHEET No. **20**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM P.M.	
				MAX	3:00	6:00					
SOLAR GAIN - GLASS				MAX	5:00	3:00	6:00	HOURS OF OPERATION HOUR ()			
(NE)	6.9 m ²	366 x 0.13 / 0.85 x 0.94 x 0.65		236	291	200	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
(NW)	5.4 m ²	366 x 0.65 / 0.85 x 0.94 x 0.65		925	484	910	CONDITIONS DB°C WB°C %RH DPC e/kg				
	m ²	x					OUTSIDE	40.5	28.2	39	19.0
	m ²	x					ROOM	24.0	17.1	50	9.4
	m ²	x					DIFFERENCE	16.5	x x x	x x x	9.6
SOLAR & TRANS GAIN - WALLS & ROOF											
WALL (NE)	19.1 m ²	13.0 x 2.1		522	478	542	BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.			
(NW)	20.6 m ²	19.5 x 2.1		844	584	1004	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE			
	m ²	x					COLOR	LGHT. MEDIUM, DARK.			
	m ²	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ²	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE	
ROOF - SUN	m ²	x					INFILTRATION				
ROOF - SHADED	m ²	x					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER				
GLASS	12.3 m ²	16.5 x 5.1		1035	1102	923	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m ²	x					EXHAUST AIR				
FLOOR	m ²	x					CRACK m X CMH/m				
PARTITION	9.5 m ²	825 x 1.8		141	156	126	INFILTRATION CMH				
INFILTRATION							VENTILATION				
	CMH X	deg X	0.29				4 PEOPLE X 25 CMH/PER 100				
							1 m ³ X CMH/m ³				
INTERNAL HEAT							VENTILATION CMH 100				
PEOPLE	4 PEOPLE X	41		164	164	164	SENSIBLE HEAT FACTOR				
Kw	Kw X	x	860				E.S.H.F. = 5306 (ERSH) = 0.95 (12.5°C)				
LIGHTS	42.25 X 20 W X		1.08	913	913	913	5591 (ERTH)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE							APPARATUS DEWPOINT 12.5 °C				
	m ²	deg X					5306 (ERSH)				
							24 RM - 12.5 ADP (1 - BF) X 0.29 = 1770 CMH				
SUB TOTAL							NOTES				
SAFETY FACTOR							GLASS (NE): 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
ROOM SENSIBLE HEAT SUB TOTAL							(NW): 1.5 x 1.8 x 2 = 5.4				
SUPPLY DUCT	SUPPLY DUCT	FAN		478	422	479	WALL (NE): 6.5 x 4.0 - 6.9 = 19.1				
HEAT GAIN	+ LEAK LOSS	- HP	= 10%				(NW): 6.5 x 4.0 - 5.4 = 20.6				
BYPASS OUTSIDE AIR							PARTITION: 2.5 x 3.8 = 9.5				
	100 CMH X	16.5 deg X	0.1 BF X 0.29	48	53	43					
EFFECTIVE ROOM SENSIBLE HEAT											
				5306	4687	5304					
ROOM LATENT HEAT											
INFILTRATION	CMH X	e/kg X	0.72								
PEOPLE	4 PEOPLE X	49		196							
STEAM		kg/h X	540								
APPLIANCES ETC.											
VAPOR TRANS.											
SUB TOTAL											
SAFETY FACTOR											
ROOM LATENT HEAT SUB TOTAL											
SUPPLY DUCT	LEAKAGE LOSS		10%	20	20	20					
BYPASS OUTSIDE AIR											
	100 CMH X	9.5 e/kg X	0.1 BF X 0.72	69	70	68					
EFFECTIVE ROOM LATENT HEAT											
				285	284	283					
EFFECTIVE ROOM TOTAL HEAT											
				5591	4971	5587					
OUTSIDE AIR HEAT											
							(133)				
SENSIBLE:	CMH X	deg X	(1 - BF) X 0.29								
LATENT:	CMH X	e/kg X	(1 - BF) X 0.72								
GRAND TOTAL HEAT SUB TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	LEAK GAIN	H.P.	GAIN								
(U.S.T) GRAND TOTAL HEAT											

10/1

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____ SHEET No. 21
 JOB NAME _____ ADDRESS _____ DATE ORIGINAL _____
 SPACE USED FOR SECRETARY ROOM (SO1) PAC-1 SYSTEM REVISION _____
 SIZE 4.0 m x 4.0 m = 16.0 m² x 2.5 m H = 4.0 m³ PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM
				MAX	3:00	6:00				
SOLAR GAIN - GLASS				MAX	3:00	5:00	6:00	HOURS OF OPERATION Hour ()		
m ² X		X						OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH		
m ² X		X						CONDITIONS DB°C WB°C %RH DPC g/kg		
m ² X		X						OUTSIDE 42.2 28.6 37 19.0		
m ² X		X						ROOM 24.0 17.1 50 9.4		
m ² X		X						DIFFERENCE 18.2 X X X X X X X X X 9.6		
SOLAR & TRANS GAIN - WALLS & ROOF								BLIND (NON-EXISTENCE/OUTSIDE, INSIDE) L M D		
WALL	m ² X	X						GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE		
	m ² X	X						COLOR LIGHT, MEDIUM, DARK.		
	m ² X	X						WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)		
	m ² X	X						INTERNAL HEAT W/m ² m ² /PEOPLE		
ROOF - SUN	m ² X	X						INFILTRATION		
ROOF - SHADED	m ² X	X						SWINGING		
TRANS. GAIN - EXCEPT WALLS & ROOF								REVOLVING DOORS PEOPLE X CMH/PER		
GLASS	m ² X	X						OPEN DOORS DOORS X CMH/DOOR		
CEILING	m ² X	X						EXHAUST AIR		
FLOOR	16.0 m ² X	9.1 X	1.7	248	225	200		CRACK m X CMH/m		
PARTITION	18.2 m ² X	9.1 X	1.8	299	271	241		INFILTRATION CMH		
DOOR	1.8 m ² X	9.1 X	1.6	27	24	22		VENTILATION		
INFILTRATION CMH X deg X 0.29								2 PEOPLE X 25 CMH/PER 50		
INTERNAL HEAT								VENTILATION CMH 50		
PEOPLE	2 PEOPLE X	41		82	82	82		SENSIBLE HEAT FACTOR		
Kw	Kw X	X	860					E.S.H.F. = $\frac{1.130 \text{ (ERSH)}}{1.273 \text{ (ERTH)}} = 0.89 (12.0)$		
LIGHTS	16.0 X 20 W X	1.08		346	346	346		DEHUMIDIFIED AIR		
APPLIANCES ETC.								APPARATUS DEWPOINT 12.5 °C		
CREDIT FOR THERMAL STORAGE m ² X deg X								1130 (ERSH)		
Sub Total								$(24RM \cdot (2.5ADP)(1 - BF) \times 0.29 = 380 \text{ CMH}$		
SAFETY FACTOR %								NOTES		
ROOM SENSIBLE HEAT Sub Total				1002	948	891		PARTITION: $8.0 \times 2.5 \cdot 1.8 = 18.2$		
SUPPLY DUCT	SUPPLY DUCT	FAN						DOOR: $0.9 \times 2.0 = 1.8$		
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	101	95	90		FLOOR: SR.		
BYPASS OUTSIDE AIR	50 CMH X 18.2 deg X 0.1 BF X 0.29			27	24	22				
EFFECTIVE ROOM SENSIBLE HEAT				1130	1067	1003				
ROOM LATENT HEAT										
INFILTRATION	CMH X	g/kg X	0.72							
PEOPLE	2 PEOPLE X	49		98						
STEAM	kg/h X	540								
APPLIANCES ETC.										
VAPOR TRANS.										
Sub Total										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub Total				98	98	98				
SUPPLY DUCT	LEAKAGE LOSS	10 %		10	10	10				
BYPASS OUTSIDE AIR	50 CMH X 9.6 g/kg X 0.1 BF X 0.72			35	35	34				
EFFECTIVE ROOM LATENT HEAT				143	143	142				
EFFECTIVE ROOM TOTAL HEAT				1273	1210	1145				
OUTSIDE AIR HEAT				(80)						
SENSIBLE:	CMH X deg X (1 - BF) X 0.29									
LATENT:	CMH X g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub Total										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	H.P.	- GAIN							
(U.S.R.T) GRAND TOTAL HEAT										

8/10

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **ASSISTANT SUPERINTENDENT ROOM (501) PAC-1 SYSTEM**
 SIZE **6.5 m x 6.5 m = 42.25 m²** x **3.8 m H = 160.55 m³**

SHEET No. **22**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX 6:00	3:00	5:00				
SOLAR GAIN - GLASS										
(NW) GLASS	6.9 m ²	366 x 0.85 x 0.94 x 0.65	X	1162	618	1180	HOURS OF OPERATION	Hour (-)
	m ²	X	X				OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
	m ²	X	X				CONDITIONS	DB C	WB C	%RH
	m ²	X	X				OUTSIDE	38.7	27.6	43
	m ²	X	X				ROOM	24.0	17.1	50
	m ²	X	X				DIFFERENCE	14.7	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF										
WALL (NW)	19.1 m ²	23.2	X 2.1	931	258	783	BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L. M. D		
	m ²	X	X				GLASS	ORDINARY, THICK, ABSORBENT, % DOUBLE		
	m ²	X	X				COLOR	LIGHT, MEDIUM, DARK.		
	m ²	X	X				WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)
	m ²	X	X				INTERNAL HEAT	W/m ²		m ² /PEOPLE
ROOF - SUN	m ²	X	X				INFILTRATION			
ROOF - SHADED	m ²	X	X				SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF										
GLASS	6.9 m ²	14.7	X 5.1	518	641	581	REVOLVING DOORS	PEOPLEX CMH/PER		
CEILING	m ²	X	X				OPEN DOORS	DOORS X CMH/DOOR		
FLOOR	m ²	X	X				EXHAUST AIR			
PARTITION	9.5 m ²	7.35	X 1.0	126	156	141	CRACK	m X		CMH/m
							INFILTRATION	CMH		■
VENTILATION										
							4 PEOPLEX	25 CMH/PER		100
							i	m ² X		CMH/m ²
							VENTILATION	CMH		■
										100
INTERNAL HEAT										
PEOPLE	4 PEOPLEX	41		164	164	164	SENSIBLE HEAT FACTOR			
Kw	Kw X	X	860				E.S.H.F =	4.239 (ERSH)		0.94 (12.5°C)
LIGHTS	42.25 X 20	WX	1.08	913	913	913		4.523 (ERTH)		
APPLIANCES ETC.							DEHUMIDIFIED AIR			
							APPARATUS DEWPOINT	12.5 °C		
								4.239 (ERSH)		
							24 RM-12.5ADP(1-0.2BF) X 0.29	1420 CMH		
CREDIT FOR THERMAL STORAGE										
SAFETY FACTOR										
							NOTES			
							GLASS (NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9			
							WALL (NW): 6.5 x 4.0 - 6.9 = 19.1			
							PARTITION: 2.5 x 3.8 = 9.5			
ROOM SENSIBLE HEAT Sub Total										
							3814	2750	3762	
SUPPLY DUCT	SUPPLY DUCT	FAN								
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	382	275	377				
BYPASS OUTSIDE AIR	100 CMH X 14.7	0.1 BF X 0.29		43	53	48				
EFFECTIVE ROOM SENSIBLE HEAT										
							41239	3078	4187	
ROOM LATENT HEAT										
INFILTRATION	CMH X	g/kg X	0.72							
PEOPLE	4 PEOPLEX	4.9		196						
STEAM		kg/h X	540							
APPLIANCES ETC.										
VAPOR TRANS.										
SAFETY FACTOR										
ROOM LATENT HEAT Sub Total										
							196	196	196	
SUPPLY DUCT	LEAKAGE LOSS		10%	26	20	20				
BYPASS OUTSIDE AIR	100 CMH X 9.4	0.1 BF X 0.72		68	70	69				
EFFECTIVE ROOM LATENT HEAT										
							284	285	283	
EFFECTIVE ROOM TOTAL HEAT										
							4523	3363	4470	
OUTSIDE AIR HEAT										
							(107)			
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29								
LATENT:	CMH X	g/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT Sub Total										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	+ H.P.	- PIPE GAIN	=	%					
(U.S.R.T) GRAND TOTAL HEAT										

101P

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET No. 23

INSURING No.	INSURED BY
JOB NAME	ADDRESS
SPACE USED FOR <u>JUNIOR ENGINEER ROOM (503c)</u> PAC-1 SYSTEM	
SIZE <u>10.5 m x 6.5 m = 68.25 m²</u>	<u>x 3.8, 2.5 m H = 225.55 m³</u>

DATE ORIGINAL
REVISION
PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX	CORRECTION	5:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION		Hour (-)	
(NW) 6.9	m ² x 366 x 0.64	0.85 x 0.94 x 0.65		1162	618	1180	OUTSIDE DESIGN CONDITIONS		°C DB °C WB °C %RH	
	m ² x	X					CONDITIONS		DB °C WB °C %RH DP °C E/kg	
	m ² x	X					OUTSIDE	38.7	27.6	43
	m ² x	X					ROOM	24.0	17.1	50
	m ² x	X					DIFFERENCE	14.7	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND		(NON-EXISTENCE) (OUTSIDE, INSIDE) L M D	
WALL (NW) 19.1	m ² x	23.2	X 2.1	931	258	783	GLASS		(ORDINARY, THICK, ABSORBENT, % DOUBLE	
	m ² x	X					COLOR		(LIGHT, MEDIUM, DARK.	
	m ² x	X					WEIGHT		kg/m ² (FLOOR) kg/m ² (WALL)	
	m ² x	X					INTERNAL HEAT		W/m ² m ² /PEOPLE	
ROOF - SUN	m ² x	X					INFILTRATION			
ROOF - SHADED	m ² x	X					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.			
GLASS 6.9	m ² x	14.7	X 5.1	518	641	581	OPEN DOORS DOORSX CMH/DOOR			
CEILING	m ² x	X					EXHAUST AIR			
FLOOR	m ² x	X					CRACK m x CMH/m			
PARTITION 10.0	m ² x	7.35	X 1.8	133	164	149	INFILTRATION CMH			
INFILTRATION							VENTILATION			
	CMHX	degX	0.29				6 PEOPLEX		25 CMH/PER. 150	
							7 m ² x		CMH/m ²	
INTERNAL HEAT							VENTILATION CMH 150			
PEOPLE	6 PEOPLEX	41		246	246	246	SENSIBLE HEAT FACTOR			
Kw	Kwx	X	860				E.S.H.F. = 4.976 (ERSH) = 0.92 (123°C)			
LIGHTS	68.25 x 20 Wx	1.08		1475	1475	1475	5402 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE							APPARATUS DEWPOINT 12.5 °C			
	m ² x	degX					4.977 (ERSH)			
							(24RM-12.5ADP)(1-BF)X0.29 = 1.660 CMH			
Sub TOTAL							NOTES			
SAFETY FACTOR %							VR = 6.5 x 6.5 x 3.8 + 6.5 x 4.0 x 2.5 = 225.55			
ROOM SENSIBLE HEAT Sub TOTAL							GLASS (NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9			
SUPPLY DUCT	SUPPLY DUCT	FAN		447	341	442	WALL (NW): 6.5 x 4.0 = 6.9			
HEAT GAIN	-LEAK LOSS	-HP	=10%				PARTITION: 4.0 x 2.5 = 10.0			
BYPASS OUTSIDE AIR 150 CMH x 9.4 g/kg x 0.1 BF x 0.29										
EFFECTIVE ROOM SENSIBLE HEAT										
ROOM LATENT HEAT										
INFILTRATION	CMHX	g/kgX	0.72							
PEOPLE	6 PEOPLEX	49		294						
STEAM		kg/hX	540							
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL										
SUPPLY DUCT LEAKAGE LOSS		10%		30	30	30				
BYPASS OUTSIDE AIR 150 CMH x 9.4 g/kg x 0.1 BF x 0.72										
EFFECTIVE ROOM LATENT HEAT										
EFFECTIVE ROOM TOTAL HEAT										
OUTSIDE AIR HEAT										
SENSIBLE: CMHX degX (1-BF)X0.29										
LATENT: CMHX g/kgX (1-BF)X0.72										
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	LEAK GAIN	H.P	GAIN							
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO.	INSURED BY	SHEET NO. 24
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR JUNIOR ENGINEER ROOM (503 b)	PAC-1 SYSTEM	REVISION
SIZE $m \times m = 6.25 \times 3.8 = 23.95 \text{ m}^2$	$m \times m \times m = 6.25 \times 3.8 \times 2.5 = 47.9 \text{ m}^3$	PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM 6		
				MAX	3:00	5:00						
SOLAR GAIN - GLASS				MAX 6:00	3:00	5:00	HOURS OF OPERATION Hour (- -)					
(NW) 6.9	$m^2 \times 3.66 \times 0.64 / 4.5 \times 0.94 \times 0.65$			1162	618	1180	OUTSIDE DESIGN CONDITIONS °C DB °C CWB °C %RH					
	$m^2 \times$	X					CONDITIONS	DB °C	WBC	%RH	DP °C	g/kg
	$m^2 \times$	X					OUTSIDE	38.7	27.6	43		18.8
	$m^2 \times$	X					ROOM	24.0	17.1	50		9.4
	$m^2 \times$	X					DIFFERENCE	14.7	X X X	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L M D				
WALL (NW) 19.1	$m^2 \times 23.2$	X	2.1	931	258	783	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE				
	$m^2 \times$	X					COLOR	LIGHT, MEDIUM, DARK.				
	$m^2 \times$	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	$m^2 \times$	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN	$m^2 \times$	X					INFILTRATION					
ROOF - SHADED	$m^2 \times$	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER					
GLASS 6.9	$m^2 \times 14.7$	X	5.1	518	641	246	OPEN DOORS DOORS X CMH/DOOR					
CEILING	$m^2 \times$	X					EXHAUST AIR					
FLOOR 16.0	$m^2 \times 7.35$	X	1.7	200	248	225	CRACK m X CMH/m					
PARTITION 10.0	$m^2 \times 7.35$	X	1.8	133	164	149	INFILTRATION CMH					
							VENTILATION					
							6 PEOPLE X 25 CMH/PER.		150			
INFILTRATION	CMH X	deg X	0.29				1 m ² X CMH/m ²					
INTERNAL HEAT							VENTILATION CMH					
PEOPLE 6	6 PEOPLE X 41			246	246	246	SENSIBLE HEAT FACTOR					
KW	KW X	X	860				E.S.H.F. = $\frac{5196 \text{ (ERSH)}}{5622 \text{ (ERTH)}} = 0.92 \text{ (12.3°C)}$					
LIGHTS	$68.25 \times 20 \text{ WX}$		1.08	1475	1475	1475	DEHUMIDIFIED AIR					
APPLIANCES ETC.							APPARATUS DEWPOINT		12.5 °C			
CREDIT FOR THERMAL STORAGE	$m^2 \times \text{deg X}$						5196 (ERSH)		1740 CMH			
							(24RM-12.5ADP)(1 - BF) X 0.29					
SAFETY FACTOR %							NOTES • $VR = 6.5 \times 6.5 \times 3.8 + 6.5 \times 4.0 \times 2.5 = 225.55$ • GLASS (NW): $1.5 \times 1.8 + 1.5 \times 2.8 = 6.9$ • WALL (NW): $6.5 \times 4.0 - 6.9 = 19.1$ • PARTITION: $4.0 \times 2.5 = 10.0$ • FLOOR: $4.0 \times 4.0 = 16.0$					
ROOM SENSIBLE HEAT Sub Total				4665	3650	4304						
SUPPLY DUCT	SUPPLY DUCT	FAN		467	365	431						
HEAT GAIN	+ LEAK LOSS	- HP = 10%		64	80	72						
BYPASS OUTSIDE AIR	$150 \text{ CMH} \times 14.7 \text{ deg} \times 0.1 \text{ BF} \times 0.29$			5196	4075	4807						
EFFECTIVE ROOM SENSIBLE HEAT				5196	4075	4807						
ROOM LATENT HEAT												
INFILTRATION	CMH X	g/kg X	0.72									
PEOPLE	6 PEOPLE X 49			294								
STEAM	kg/h X		540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub Total												
SAFETY FACTOR %												
ROOM LATENT HEAT Sub Total				294	294	294						
SUPPLY DUCT LEAKAGE LOSS		10 %		30	30	30						
BYPASS OUTSIDE AIR	$150 \text{ CMH} \times 9.4 \text{ g/kg} \times 0.1 \text{ BF} \times 0.72$			102	104	103						
EFFECTIVE ROOM LATENT HEAT				426	428	427						
EFFECTIVE ROOM TOTAL HEAT				5622	4523	5234						
OUTSIDE AIR HEAT												
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29										
LATENT:	CMH X	g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub Total												
RETURN DUCT	RETURN DUCT	PUMP PIPE										
HEAT GAIN	LEAK GAIN	H.P. GAIN										
(U.S.R.T) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.	INQUIRED BY	SHEET NO. 25
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR JUNIOR ENGINEER ROOM (503a)	PAC-1 SYSTEM	REVISION
SIZE mX m = 62.25 m' X 3.8, 2.5 m(H) = 200.55 m'		PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM5	
					CORRECTION						
SOLAR GAIN - GLASS				MAX 5:00	3:00	6:00	HOURS OF OPERATION Hour (-)				
(NW) 6.9	m² x 3.66 x 0.65	0.85 x 0.94 x 0.65		1180	618	112	OUTSIDE DESIGN CONDITION °CDB °CWB %RH				
(SW) 8.1	m² x 2.52 x 0.50	0.85 x 0.94 x 0.65		1734	1028	382	CONDITIONS DB °C WB °C %RH DP °C E/kg				
	m² x	X					OUTSIDE	40.5	28.2	39	18.9
	m² x	X					ROOM	24.0	17.1	50	9.4
	m² x	X					DIFFERENCE	16.5	X X X	X X X	9.5
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L.M.D				
WALL (NW) 19.1	m² x	19.5 X	2.1	783	258	931	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
(SW) 33.9	m² x	19.2 X	2.1	1267	1125	1389	COLOR LIGHT, MEDIUM, DARK.				
	m² x	X					WEIGHT		kg/m² (FLOOR) kg/m² (WALL)		
	m² x	X					INTERNAL HEAT		W/m² m²/PEOPLE		
ROOF - SUN	m² x	X					INFILTRATION				
ROOF - SHADED	m² x	X					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.				
GLASS 15.0	m² x	16.5 X	5.1	1263	1393	1125	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m² x	X					EXHAUST AIR				
FLOOR	m² x	X					CRACK m X CMH/m				
PARTITION 17.6	m² x	8.25 X	1.8	262	289	233	INFILTRATION CMH				
							VENTILATION				
							6 PEOPLE X		25 CMH/PER 150		
INFILTRATION	CMH X	deg X	0.29				i' m² X		CMH/m²		
							VENTILATION		CMH 150		
INTERNAL HEAT							SENSIBLE HEAT FACTOR				
PEOPLE	6 PEOPLE X 41			246	246	246	E.S.H.F. = 7970 (ERSH) = 0.95 (12.5°C)				
KW	KWX X 860						8397 (ERTH)				
LIGHTS	62.25 X 20 WX 1.08			1345	1345	1345					
APPLIANCES ETC.							DEHUMIDIFIED AIR				
							APPARATUS DEWPOINT 12.5 °C				
							7.970 (ERSH)				
CREDIT FOR THERMAL STORAGE	m² X	deg X					(24RM - 12.5ADP) (1 - BF) X 0.29 = 2.660 CMH				
							Sub TOTAL				
SAFETY FACTOR %							NOTES				
ROOM SENSIBLE HEAT Sub TOTAL				7180	6302	6813	SR = 6.5 x 10.5 - 1.5 x 4 = 62.25				
SUPPLY DUCT	SUPPLY DUCT	FAN					VR = 6.5 x 6.5 x 3.8 + 4.0 x 4.0 x 2.5 = 200.55				
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	718	631	682	GLASS				
BYPASS OUTSIDE AIR 150 CMH x 16.5 deg x 0.1 BF x 0.29				72	80	64	(NW) = 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
EFFECTIVE ROOM SENSIBLE HEAT				7.970	7083	7559	(SW) = 1.5 x 1.8 x 3 = 8.1				
ROOM LATENT HEAT							WALL				
INFILTRATION	CMH X	E/kg X	0.72				(NW) = 6.5 x 4.0 - 6.9 = 19.1				
PEOPLE	6 PEOPLE X 49			294			(SW) = 10.5 x 4.0 - 8.1 = 33.9				
STEAM	kg/h X 540						PARTITION : 4.0 x 2.5 + 2.0 x 3.8 = 17.6				
APPLIANCES ETC.											
VAPOR TRANS.											
							Sub TOTAL				
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL				294	294	294					
SUPPLY DUCT LEAKAGE LOSS	10%			30	30	30					
BYPASS OUTSIDE AIR 150 CMH x 9.5 E/kg x 0.1 BF x 0.72				103	104	102					
EFFECTIVE ROOM LATENT HEAT				427	428	426					
EFFECTIVE ROOM TOTAL HEAT				8397	7441	7985					
OUTSIDE AIR HEAT				(135)							
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29									
LATENT:	CMH X	E/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	- H.P.	- GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (Tolr)** PAC - 1 SYSTEM
 SIZE 10.5 m x 6.5 m = 68.25 m² x 2.5, 3.8 m(H) = 225.55 m³

SHEET No. 26
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX	3:00	5:00				
SOLAR GAIN - GLASS				MAX 6:00	3:00	5:00	HOURS OF OPERATION Hour (-)			
(NE)	6.4 m ²	366 x 0.11 / 0.85 x 0.94 x 0.65		157	228	185	OUTSIDE DESIGN CONDITIONS °C DB °C WB °C %RH DP °C g/kg			
(NW)	6.9 m ²	366 x 0.14 / 0.85 x 0.94 x 0.65		162	618	1180	ROOM 24.0 17.1 50 9.4			
	m ²	x					DIFFERENCE 14.7 x x x x x x x 9.4			
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.			
WALL (NE)	20.6 m ²	13.5 x 2.1		584	515	563	GLASS ORDINARY, THICK, ABSORBENT, % DOUBLE			
(NW)	19.1 m ²	23.2 x 2.1		431	258	783	COLOR LIGHT, MEDIUM, DARK			
	m ²	x					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)			
	m ²	x					INTERNAL HEAT W/m ² m ² /PEOPLE			
ROOF - SUN	42.25 m ²	28.5 x 1.1		2047	1724	1997	INFILTRATION			
ROOF - SHAD	26.9 m ²	28.5 x 1.1		816	687	795	SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER			
GLASS	12.3 m ²	14.7 x 5.1		923	1142	1036	OPEN DOORS DOORSX CMH/DOOR			
CEILING	m ²	x					EXHAUST AIR			
FLOOR	10.0 m ²	7.35 x 1.7		125	155	141	CRACK mX CMH/m			
PARTITION	10.0 m ²	7.35 x 2.5		184	228	207	INFILTRATION CMH			
							VENTILATION			
							6 PEOPLEX 25 CMH/PER 150			
INFILTRATION	CMHX	degX	0.29				VENTILATION CMH 150			
INTERNAL HEAT							SENSIBLE HEAT FACTOR			
PEOPLE	6 PEOPLEX	41		246	246	246	E.S.H.F. = 9579 (ERSH) = 0.96 (12.6°C)			
KW	KwX	x	860				10.005 (ERTH)			
LIGHTS	68.25 x 20 Wx		1.08	1475	1475	1475	DEHUMIDIFIED AIR			
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C			
							9579 (ERSH)			
CREDIT FOR THERMAL STORAGE	m ²	degX					(24RM - 12.5ADP) (1 - BF) x 0.29 = 3200 CMH			
Sub TOTAL										
SAFETY FACTOR		%					NOTES			
ROOM SENSIBLE HEAT Sub TOTAL				8650	7275	8608	GLASS (NE): 1.5 x 1.8 x 2 = 5.4			
SUPPLY DUCT	SUPPLY DUCT	FAN					(NW): 1.5 x 1.8 x 1.5 x 2.8 = 6.9			
HEAT GAIN	-LEAK LOSS	-HP	=10%	865	728	861	WALL (NE): 6.5 x 4.0 - 5.4 = 20.6			
BYPASS OUTSIDE AIR	150 CMH x 14.7 deg x 0.1 BF x 0.29			64	80	72	(NW): 6.5 x 4.0 - 6.9 = 19.1			
EFFECTIVE ROOM SENSIBLE HEAT				9579	8083	9541	PARTITION: 4.0 x 2.5 = 10.0			
ROOM LATENT HEAT							FLOOR: 4.0 x 2.5 = 10.0			
INFILTRATION	CMHX	g/kgX	0.72				ROOF (1): 4.0 x 6.5 = 26.0			
PEOPLE	6 PEOPLEX	49		294			(2): 6.5 x 6.5 = 42.25			
STEAM		kg/hX	540				VR: 6.5 x 4.0 x 2.5 + 6.5 x 6.5 x 3.8 = 225.55			
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR		%								
ROOM LATENT HEAT Sub TOTAL				294	294	294				
SUPPLY DUCT LEAKAGE LOSS		10%		30	30	30				
BYPASS OUTSIDE AIR	150 CMH x 9.4 g/kg x 0.1 BF x 0.72			102	104	103				
EFFECTIVE ROOM LATENT HEAT				426	428	427				
EFFECTIVE ROOM TOTAL HEAT				10005	8511	9968				
OUTSIDE AIR HEAT				(147)						
SENSIBLE:	CMHX	degX (1 - BF) x 0.29								
LATENT:	CMHX	g/kgX (1 - BF) x 0.72								
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	LEAK GAIN	H.P.	GAIN	=	%					
(U.S.R.T) GRAND TOTAL HEAT										