

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.

INQUIRED BY

SHEET NO. 27

JOB NAME

ADDRESS

DATE ORIGINAL

SPACE USED FOR

JUNIOR ENGINEER ROOM (TO 1d)

PAC - 1 SYSTEM

REVISION

SIZE

10.5 m x

6.5 m =

 68.25 m²

x

m/H = 225.55

 m³

PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 6	
SOLAR GAIN — GLASS				MAX 6:00	3:00	5:00	HOURS OF OPERATION		Hour (	—)	
(NW)	6.9 m ²	366 x 0.94 x 0.65		1162	618	1180	OUTSIDE DESIGN CONDITIONS		'CDB	'CWB	
	m ²	x					CONDITIONS	DB °C	WB °C	%RH	
	m ²	x					OUTSIDE	38.7	27.6	43	
	m ²	x					ROOM	24.0	17.1	50	
	m ²	x					DIFFERENCE	14.7	x x x	x x x	
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.			
WALL (NW)	19.1 m ²	23.2 x 2.1		931	258	783	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE			
	m ²	x					COLOR	LIGHT, MEDIUM, DARK.			
	m ²	x					WEIGHT	kg/m ² (FLOOR) kg/m ² (WALL)			
	m ²	x					INTERNAL HEAT	W/m ² m ³ /PEOPLE			
ROOF—SUN	42.25 m ²	28.5 x 1.7		2047	1724	1997	INFILTRATION				
ROOF—SHADE	26.0 m ²	28.5 x 1.1		816	687	795	SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.				
GLASS	6.9 m ²	14.7 x 5.1		510	641	581	OPEN DOORS DOORSX CMH/DOOR				
CEILING	m ²	x					EXHAUST AIR				
FLOOR	10.0 m ²	7.35 x 1.7		125	155	141	CRACK m x CMH/m				
PARTITION	m ²	x					INFILTRATION CMH				
INFILTRATION CMH x deg x 0.29							VENTILATION				
INTERNAL HEAT							6 PEOPLEX 25 CMH/PER. 150				
PEOPLE	6 PEOPLEX	41		246	246	246	VENTILATION CMH 150				
Kw	Kw x	x	860				SENSIBLE HEAT FACTOR				
LIGHTS	68.25 x 20 W x	1.08		1475	1475	1475	E.S.H.F. = $\frac{8116}{8542}$ (ERSH) = 0.95 (12.6°C)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE m ² x deg x							APPARATUS DEWPOINT 12.5 °C				
Sub Total							8.116 (ERSH)				
SAFETY FACTOR %							(24 RM - 12.5 ADP) (1 - BF) x 0.29 = 2710 CMH				
ROOM SENSIBLE HEAT Sub Total				7320	5804	7198	NOTES				
SUPPLY DUCT	SUPPLY DUCT	FAN		732	581	720	GLASS (NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%				WALL (NW): 6.5 x 4.0 = 6.9 = 19.1				
BYPASS OUTSIDE AIR	150 CMH x 14.7 deg x 0.1 BF x 0.29			64	80	72	FLOOR : 4.0 x 2.5 = 10.0				
EFFECTIVE ROOM SENSIBLE HEAT				8116	6465	7190	ROOF (1): 4.0 x 6.5 = 26.0				
ROOM LATENT HEAT							(2): 6.5 x 6.5 = 42.25				
INFILTRATION	CMH x	g/kg x	0.72								
PEOPLE	6 PEOPLE x	49		294	294	294					
STEAM	kg/h x	540									
APPLIANCES ETC.											
VAPOR TRANS.											
Sub Total											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub Total				294	294	294					
SUPPLY DUCT	LEAKAGE LOSS	10 %		30	30	30					
BYPASS OUTSIDE AIR	150 CMH x 9.4 g/kg x 0.1 BF x 0.72			102	104	103					
EFFECTIVE ROOM LATENT HEAT				426	428	427					
EFFECTIVE ROOM TOTAL HEAT				8542	6893	8417					
OUTSIDE AIR HEAT											
SENSIBLE:	CMH x	deg x (1 - BF) x 0.29									
LATENT:	CMH x	g/kg x (1 - BF) x 0.72									
GRAND TOTAL HEAT Sub Total											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	LEAK GAIN	H.P.	GAIN	= %							
(U.S.R.T.) GRAND TOTAL HEAT											

FORM E-20E

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No.

INQUIRED By

SHEET No.

28

JOB NAME

ADDRESS

DATE ORIGINAL

REVISION

PERSON IN CHARGE

SPACE USED FOR JUNIOR ENGINEER ROOM (TO 10) PAC-1 SYSTEM

 SIZE 10.5 m x 6.5 m = 68.25 m² x m(H) = 225.55 m³

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DEF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 6		
					CORRECTION							
SOLAR GAIN — GLASS				MAX 6:00	3:00	5:00	HOURS OF OPERATION Hour (~)					
(NW)	6.9 m ² x 366 x 0.64 x 0.85 x 0.94 x 0.65			1162	618	1180	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ² x	x					CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ² x	x					OUTSIDE	38.7	27.6	43		18.8
	m ² x	x					ROOM	24.0	17.1	50		9.4
	m ² x	x					DIFFERENCE	14.7	x x x	x x x	x x x	9.4
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.				
WALL (NW)	19.1 m ² x 23.2 x 2.1			931	258	783	GLASS	ORDINARY, THICK, ABSORBENT: % DOUBLE				
	m ² x	x					COLOR	LIGHT, MEDIUM, DARK.				
	m ² x	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ² x	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF—SUN	42.25 m ² x 28.5 x 1.7			2047	1724	1997	INFILTRATION					
ROOF—SHADE	26.0 m ² x 28.5 x 1.1			816	687	795	SWINGING					
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER					
GLASS	6.9 m ² x 14.7 x 5.1			518	601	581	OPEN DOORS DOOREX CMH/DOOR					
CEILING	m ² x	x					EXHAUST AIR					
FLOOR	m ² x	x					CRACK m x CMH/m					
PARTITION	m ² x	x					INFILTRATION CMH					
							VENTILATION					
							6 PEOPLEX 25 CMH/PER. 150					
INFILTRATION	CMH x deg x	0.29					m ² x CMH/m ²					
INTERNAL HEAT							VENTILATION CMH 150					
PEOPLE	6 PEOPLEX 41			246	246	246	SENSIBLE HEAT FACTOR					
Kw	Kw x x	860					E.S.H.F. = 7.979 (IERSH) = 0.95 (12.6°C)					
LIGHTS	68.25 x 20 W x	1.08		1475	1475	1475	8405 (ERTH)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT 12.5 °C					
CREDIT FOR THERMAL STORAGE m ² x deg x (-) (-)							(IERSH) = 2.670 CMH					
Sub Total							24 RM-12.5 ADF (12.5 BF) x 0.29					
SAFETY FACTOR %							NOTES					
ROOM SENSIBLE HEAT Sub Total				7195	5449	7057	VR = 4.0 x 6.5 x 2.5 + 6.5 x 6.5 x 3.8 = 225.55					
SUPPLY DUCT	SUPPLY DUCT	FAN										
HEAT GAIN	+ LEAK LOSS	+ HP	70%	720	565	706						
BYPASS OUTSIDE AIR	6 CMH x 14.7 deg x 0.1 BF x 0.29			64	80	72	GLASS (NW) : 1.5 x 1.8 + 1.5 x 2.8 = 6.9					
EFFECTIVE ROOM SENSIBLE HEAT				7979	6294	7835	WALL (NW) : 6.5 x 4.0 - 6.9 = 19.1					
ROOM LATENT HEAT							ROOF (1) : 4.0 x 6.5 = 26.0					
INFILTRATION	CMH x g/kg x	0.72					(2) : 6.5 x 6.5 = 42.25					
PEOPLE	6 PEOPLEX 49											
STEAM	kg/h x	540		294								
APPLIANCES ETC.												
VAPOR TRANS.												
Sub Total												
SAFETY FACTOR %												
ROOM LATENT HEAT Sub Total				294	294	294						
SUPPLY DUCT	LEAKAGE LOSS	10 %		30	30	30						
BYPASS OUTSIDE AIR	15 CMH x 9.4 g/kg x 0.1 BF x 0.72			102	104	103						
EFFECTIVE ROOM LATENT HEAT				426	428	427						
EFFECTIVE ROOM TOTAL HEAT				8405	6722	8262						
OUTSIDE AIR HEAT				(124)								
SENSIBLE:	CMH x deg x (1 - BF) x 0.29											
LATENT:	CMH x g/kg x (1 - BF) x 0.72											
GRAND TOTAL HEAT Sub Total												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	+ LEAK GAIN	H.P.	+ GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

FORM E-20E

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (TOILET)** PAC-1 SYSTEM
 SIZE 10.5 m x 6.5 m = 68.25 m² x 2.5 m H = 225.55 m³

SHEET No. **29**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
					CORRECTION					
SOLAR GAIN — GLASS				MAX 6:00	3:00	5:00	HOURS OF OPERATION			
(NW) 6.9	m ² x 366 x 0.65 x 0.94 x 0.65			1162	118	1180	OUTSIDE DESIGN CONDITIONS			
	m ² x	X					CONDITIONS	DB °C	WB °C	% RH
	m ² x	X					OUTSIDE	32.7	27.6	43
	m ² x	X					ROOM	24.0	17.1	50
	m ² x	X					DIFFERENCE	14.7	X X X	X X X
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.		
WALL (NW) 19.1	m ² x 23.2 x 2.1			931	258	783	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
	m ² x	X					COLOR	LIGHT, MEDIUM, DARK		
	m ² x	X					WEIGHT	kg/m ² (FLOOR) kg/m ² (WALL)		
	m ² x	X					INTERNAL HEAT	W/m ² m ² /PEOPLE		
ROOF—SUN 42.25	m ² x 28.5 x 1.7			2047	1724	1997	INFILTRATION			
ROOF—SHADE 26.0	m ² x 28.5 x 1.1			816	687	795	SWINGING			
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER			
GLASS 6.9	m ² x 14.7 x 5.1			518	641	581	OPEN DOORS DOORSX CMH/DOOR			
CEILING	m ² x	X					EXHAUST AIR			
FLOOR	m ² x	X					CRACK m x CMH/m			
PARTITION 10.0	m ² x 7.35 x 1.8			133	164	149	INFILTRATION CMH			
							VENTILATION			
INFILTRATION CMH x deg x 0.29							6 PEOPLEX 25 CMH/PER 150			
INTERNAL HEAT							1' m ² x CMH/m ²			
PEOPLE 6	PEOPLEX 41			246	246	246	VENTILATION CMH 150			
KW KW x X 860							SENSIBLE HEAT FACTOR			
LIGHTS 68.25 x 20 WX 1.08				1475	1475	1475	E.S.H.F. = $\frac{8125}{8551}$ (ERSH) = 0.95 (12.6°C)			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE m ² x deg x							APPARATUS DEWPOINT 12.5 °C			
Sub Total							$\frac{8125}{(24RM \cdot 12.5ADP)(1 - 0.8BF) \times 0.29} = 2.710$ CMH			
SAFETY FACTOR %							NOTES			
ROOM SENSIBLE HEAT Sub Total				7328	5813	7206	GLASS (NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9			
SUPPLY DUCT	SUPPLY DUCT	FAN					WALL (NW): 6.5 x 4.0 = 6.9 = 19.1			
HEAT GAIN	+ LEAK LOSS	+ HP	10 %	733	582	721	ROOF (1): 4.0 x 6.5 = 26.0			
BYPASS OUTSIDE AIR 150 CMH x 14.7 deg x 0.1 BF x 0.29				64	80	72	(2): 6.5 x 6.5 = 42.25			
EFFECTIVE ROOM SENSIBLE HEAT				8125	6475	7994	PARTITION: 4.0 x 2.5 = 10.0			
ROOM LATENT HEAT							VR = 4.0 x 6.5 x 2.5 + 6.5 x 6.5 x 3.8 = 225.55			
INFILTRATION	CMH x	g/kg x	0.72							
PEOPLE	6 PEOPLEX	49		294						
STEAM		kg/h x	540							
APPLIANCES ETC.										
VAPOR TRANS.										
Sub Total										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub Total				294	294	294				
SUPPLY DUCT	LEAKAGE LOSS		10 %	30	30	30				
BYPASS OUTSIDE AIR 150 CMH x 9.4 g/kg x 0.1 BF x 0.72				102	104	103				
EFFECTIVE ROOM LATENT HEAT				426	428	427				
EFFECTIVE ROOM TOTAL HEAT				8551	6903	8426				
OUTSIDE AIR HEAT				(126)						
SENSIBLE:	CMH x deg x (1 - BF) x 0.29									
LATENT:	CMH x g/kg x (1 - BF) x 0.72									
GRAND TOTAL HEAT Sub Total										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	M.P.	- GAIN							
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (To 1 a)** **PAC-1** SYSTEM
 SIZE $m \times m = 60.25 \text{ m}^2 \times 2.5, 3.8 \text{ m} \text{ H.I.} = 205.55 \text{ m}^3$

SHEET No. **30**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
					CORRECTION						
SOLAR GAIN — GLASS				MAX 5100	3100	6100	HOURS OF OPERATION Hour ()				
(NW) 6.9	$m^2 \times 766 \times 0.65 / 0.85 \times 0.94 \times 0.65$			1180	618	1162	OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH				
(SW) 8.1	$m^2 \times 752 \times 0.65 / 0.85 \times 0.94 \times 0.65$			734	1028	982	CONDITIONS DB °C WB °C %RH DP °C e/kg				
	$m^2 \times$	X					OUTSIDE 40.5 28.2 39 18.9				
	$m^2 \times$	X					ROOM 24.0 17.1 50 9.4				
	$m^2 \times$	X					DIFFERENCE 16.5 XXX XXX XXX 9.5				
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L.M.D				
WALL (NW) 19.1	$m^2 \times$	19.5 X 2.1		783	258	931	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
(SW) 33.9	$m^2 \times$	19.2 X 2.1		1367	1125	1389	COLOR LIGHT, MEDIUM, DARK.				
	$m^2 \times$	X					WEIGHT kg/m² (FLOOR) kg/m² (WALL)				
	$m^2 \times$	X					INTERNAL HEAT W/m² m²/PEOPLE				
ROOF—SUN 42.25	$m^2 \times$	27.8 X 1.7		1997	1724	2047	INFILTRATION				
ROOF—SHADE 18.0	$m^2 \times$	27.8 X 1.1		551	476	565	SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER				
GLASS 15.0	$m^2 \times$	16.5 X 5.1		1263	1393	1125	OPEN DOORS DOORS X CMH/DOOR				
CEILING	$m^2 \times$	X					EXHAUST AIR				
FLOOR	$m^2 \times$	X					CRACK m X CMH/m				
PARTITION 17.6	$m^2 \times$	8.25 X 1.8		262	289	233	INFILTRATION CMH				
							VENTILATION				
							PEOPLE X 25 CMH/PER. 150				
INFILTRATION CMH X deg X 0.29							VENTILATION CMH 150				
INTERNAL HEAT							SENSIBLE HEAT FACTOR				
PEOPLE	6 PEOPLE X	41		246	246	246	E.S.H.F. 10.916 (ERSH) = 0.96 (12.6°C)				
KW	KWX	X 860					11.343 (ERTH)				
LIGHTS	60.25 X 20 WX	1.08		1475	1475	1475	DEHUMIDIFIED AIR				
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C				
CREDIT FOR THERMAL STORAGE $m^2 \times$ deg X							10.916 (ERSH)				
Sub Total							(24 RM - 12 ADP) (1 - BF) X 0.29 = 3.640 CMH				
Safety Factor %							NOTES				
Room Sensible Heat Sub Total				9858	8632	9555	$SR = 10.5 \times 6.5 - 2.0 \times 4.0 = 60.25$				
SUPPLY DUCT	SUPPLY DUCT	FAN					$GLASS (NW): 1.5 \times 1.8 + 1.5 \times 2.8 = 6.9$				
HEAT GAIN	+ LEAK LOSS	- HP	= 16%	986	864	956	$(SW): 1.5 \times 1.8 \times 3 = 8.1$				
BYPASS OUTSIDE AIR 150 CMH X 16.5 deg X 0.1 BF X 0.29				72	80	64	$WALL (NW): 6.5 \times 4.0 - 6.9 = 19.1$				
EFFECTIVE ROOM SENSIBLE HEAT				10916	9576	10575	$(SW): 10.5 \times 4.0 - 8.1 = 33.9$				
ROOM LATENT HEAT							$ROOF (1): 4.0 \times 4.5 = 18.0$				
INFILTRATION	CMH X	e/kg X	0.72				$(2): 6.5 \times 6.5 = 42.25$				
PEOPLE	6 PEOPLE X	49		294			$PARTITION: 4.0 \times 2.5 + 2.0 \times 3.8 = 17.6$				
STEAM	kg/h X	540					$VR = 4.0 \times 4.5 \times 2.5 + 6.5 \times 6.5 \times 3.8$				
APPLIANCES ETC.							$= 205.55$				
VAPOR TRANS.											
Sub Total											
Safety Factor %											
Room Latent Heat Sub Total				294	294	294					
SUPPLY DUCT	LEAKAGE LOSS	10%		30	30	30					
BYPASS OUTSIDE AIR 150 CMH X 9.5 e/kg X 0.1 BF X 0.72				103	104	102					
EFFECTIVE ROOM LATENT HEAT				427	428	426					
EFFECTIVE ROOM TOTAL HEAT				11343	10004	11001					
OUTSIDE AIR HEAT (189)											
SENSIBLE: CMH X deg X (1 - BF) X 0.29											
LATENT: CMH X e/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT Sub Total											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	H.P.	+ GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRED BY

DATE ORIGINAL _____

REVISION

PERSON IN CHARGE

JOO NAME

ADDRESS

SPACE USED FOR CONFERENCE ROOM (E03) PAC-2 SYSTEM

SIZE 13.0 m x 6.5 m = 84.5 m' x 3.0 m (H) = 253.5 m'

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM 2
SOLAR GAIN — GLASS										
(SE) 12.3	m ² × 252 × 0.79 / 85 × 0.94 × 0.65			MAX 2:00	3:00	4:00	HOURS OF OPERATION		Hour (	~)
	m ² ×	X		647	535	418	OUTSIDE DESIGN CONDITIONS		CDB	CWB %RH
	m ² ×	X					CONDITIONS	DB °C	WB °C	%RH DP °C g/kg
	m ² ×	X					OUTSIDE	41.7	28.4	38 18.8
	m ² ×	X					ROOM	24.0	17.1	50 9.4
	m ² ×	X					DIFFERENCE	17.7	X X X	X X X X X X 9.4
SOLAR & TRANS GAIN—WALLS & ROOF										
WALL (SE) 39.7	m ² × 13.9	X	2.1	1159	1076	777	BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.		
	m ² ×	X					GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
	m ² ×	X					COLOR	LIGHT, MEDIUM, DARK.		
	m ² ×	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)
	m ² ×	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE
ROOF—SUN	m ² ×	X					INFILTRATION			
ROOF—SHADED	m ² ×	X					SWINGING			
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER			
GLASS 12.78	m ² × 17.7	X	5.1	1154	1187	1154	OPEN DOORS DOORSX CMH/DOOR			
CEILING	m ² ×	X					EXHAUST AIR			
FLOOR 84.5	m ² × 12.7	X	2.5	2683	2789	2683	CRACK	m X		CMH/m
PARTITION(1) 12.6	m ² × 8.85	X	1.8	201	207	201	INFILTRATION		CMH	
(2) 12.0	m ² × 8.85	X	2.5	266	273	266	VENTILATION			
INFILTRATION CMHX degX 0.29							16 PEOPLEX		25 CMH/PER.	400
INTERNAL HEAT							1 m ² X		CMH/m ²	
PEOPLE 16	PEOPLEX 41			656	656	656	VENTILATION		CMH	400
KW KWX	X	860					SENSIBLE HEAT FACTOR			
LIGHTS 84.5	X 20 WX	1.08		1826	1826	1826	E.S.H.F. = $\frac{9.658}{10.792} \left(\frac{IERSH}{IERTH} \right) = 0.91 (17.1^\circ C)$			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE m ² X degX							APPARATUS DEWPOINT 12.5 °C			
Sub TOTAL							$\frac{9.658}{(24RM-12.5ADP)(1-1BF) \times 0.29} = 3.220 \text{ CMH}$			
SAFETY FACTOR %							NOTES			
ROOM SENSIBLE HEAT Sub TOTAL				8592	8541	8031	GLASS (SE): $1.5 \times 1.8 \times 3 + 1.5 \times 2.8 = 12.3$			
SUPPLY DUCT	SUPPLY DUCT	FAN					WALL (SE): $13.0 \times 4.0 - 12.3 = 39.7$			
HEAT GAIN	+ LEAK LOSS	+ HP	= 0%	860	855	804	PARTITION			
BYPASS OUTSIDE AIR 400 CMH (17.7 degX 0.1 BF) X 0.29				206	212	212	(1): $4.2 \times 3.0 = 12.6$			
EFFECTIVE ROOM SENSIBLE HEAT				9658	9616	9047	(2): $4.0 \times 3.0 = 12.0$			
ROOM LATENT HEAT							FLOOR: SR			
INFILTRATION	CMHX	g/kgX	0.72							
PEOPLE 16	PEOPLEX 49			784	784	784				
STEAM	kg/hX	540								
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL				784	780					
SUPPLY DUCT	LEAKAGE LOSS	10 %		79	79					
BYPASS OUTSIDE AIR 400 CMH X 9.4 g/kg X 0.1 BF X 0.72				271	277	274				
EFFECTIVE ROOM LATENT HEAT				1134	1136	1133				
EFFECTIVE ROOM TOTAL HEAT				10792	10752	10280				
OUTSIDE AIR HEAT (128)										
SENSIBLE:	CMHX	degX (1 - BF) X 0.29								

FORM E-201

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.

INQUIRED BY

SHEET NO. 32

JOB NAME

ADDRESS

DATE ORIGINAL

SPACE USED FOR CORRIDOR (F09)

PAC-2 SYSTEM

REVISION

 SIZE m x m = 87.25 m² x 2.5 m H = 218.13 m³

PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3
					CORRECTION				
SOLAR GAIN — GLASS				MAX 3:00	2:00 4:00	HOURS OF OPERATION HOUR (~)			
	m ² X	X				OUTSIDE DESIGN CONDITIONS CDB CWB %RH			
	m ² X	X				CONDITIONS DB °C WB °C %RH DP °C g/kg			
	m ² X	X				OUTSIDE 42.2 28.6 37 19.0			
	m ² X	X				ROOM 24.0 17.1 50 9.0			
	m ² X	X				DIFFERENCE 18.2 X X X X X X X 9.6			
SOLAR & TRANS. GAIN—WALLS & ROOF						BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L.M.D			
WALL	m ² X	X				GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE			
	m ² X	X				COLOR LIGHT, MEDIUM, DARK			
	m ² X	X				WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)			
	m ² X	X				INTERNAL HEAT W/m ² m ² /PEOPLE			
ROOF—SUN	m ² X	X				INFILTRATION			
ROOF—SHADED	m ² X	X				SWINGING			
TRANS. GAIN—EXCEPT WALLS & ROOF						REVOLVING DOORS PEOPLE X CMH/PER			
GLASS	m ² X	X				OPEN DOORS DOOREX CMH/DOOR			
CEILING	m ² X	X				EXHAUST AIR			
FLOOR 56.25	m ² X	13.2 X 2.5		1857	1786	CRACK m X CMH/m			
PARTITION (12) 8.55	m ² X	9.1 X 1.6		1336	1299	INFILTRATION CMH			
	(2) 30.15	m ² X 9.1 X 2.5		686	667	VENTILATION			
DOOR 11.34	m ² X	9.1 X 1.6		166	161	PEOPLEX CMH/PER			
INFILTRATION	CMH X	deg X	0.29			m ² X CMH/m ²			
INTERNAL HEAT						VENTILATION CMH			
PEOPLE	PEOPLEX					SENSIBLE HEAT FACTOR			
Kw	Kw X	X	860			E.S.H.F. = 6523 (ERSH) = 1.0 (13.2°C)			
LIGHTS	87.25 X 20 W X		1.08	1885	1885	6523 (ERTH)			
APPLIANCES ETC.						DEHUMIDIFIED AIR			
						APPARATUS DEWPOINT 12.5 °C			
CREDIT FOR THERMAL STORAGE m ² X deg X						6523 (ERSH)			
Sub Total						24 RM. (2.5 ADP) (1 - BF) X 0.29 = 2180 CMH			
SAFETY FACTOR %						NOTES			
ROOM SENSIBLE HEAT Sub Total				5930	5798	SR = 26.0 x 2.5 + 2.0 x 2.0 + 4.5 x 2.5 + 2.0 = 87.25			
SUPPLY DUCT	SUPPLY DUCT	FAN				PARTITION			
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	593	580	(1) 8.55 x 2.5 - 0.9 x 2.0 x 4 = 81.55			
BYPASS OUTSIDE AIR	CMH X	deg X	B.F. X 0.29			(2) 13.5 x 2.5 - 0.9 x 2.0 x 2 = 30.15			
EFFECTIVE ROOM SENSIBLE HEAT				6523	6378	DOOR: 0.9 x 2.0 x 6 = 10.8			
ROOM LATENT HEAT						FLOOR: 2.5 x 22.5 = 56.25			
INFILTRATION	CMH X	g/kg X	0.72						
PEOPLE	PEOPLEX								
STEAM	kg/h X		540						
APPLIANCES ETC.									
VAPOR TRANS.									
Sub Total									
SAFETY FACTOR %									
ROOM LATENT HEAT Sub Total									
SUPPLY DUCT	LEAKAGE LOSS		%						
BYPASS OUTSIDE AIR	CMH X	g/kg X	B.F. X 0.72						
EFFECTIVE ROOM LATENT HEAT									
EFFECTIVE ROOM TOTAL HEAT				61523	6378				
OUTSIDE AIR HEAT									
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29							
LATENT:	CMH X	g/kg X (1 - BF) X 0.72							
GRAND TOTAL HEAT Sub Total									
RETURN DUCT	RETURN DUCT	PUMP	PIPE						
HEAT GAIN	LEAK GAIN	H.P.	GAIN	= %					
(U.S.R.T) GRAND TOTAL HEAT									

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRYING NO.

INQUIRED BY

SHEET No 23

JOB NAME

ADDRESS

DATE ORIGINAL

SPACE USED FOR EXECUTIVE ENGINEER ROOM (505 d) PAC-2 SYSTEM

REVISION

 SIZE 3.25 m x 6.5 m = 21.13 m² x 3.8 m(H) = 80.29 m³

PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
					CORRECTION						
SOLAR GAIN — GLASS				MAX: 12:00	3:00	4:00	HOURS OF OPERATION Hour ()				
(SE) 4.2	m ² x 252	1.57/0.85 x 0.94 x 0.65		434	183	160	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
	m ² x	X					CONDITIONS DB C WB C %RH DP C E/kg				
	m ² x	X			(22)		OUTSIDE 38.4 27.6 43				
	m ² x	X					ROOM 24.0 17.1 50				
	m ² x	X					DIFFERENCE 14.4 X X X X X X X X X X X X 9.5				
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L.M.D				
WALL (SE) 8.8	m ² x 13.6	X 2.1		252	239	230	GLASS (ORDINARY, THICK, ABSORBENT, % DOUBLE				
	m ² x	X					COLOR (LIGHT, MEDIUM, DARK,				
	m ² x	X			(25)		WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)				
	m ² x	X					INTERNAL HEAT W/m ² m ² /PEOPLE				
ROOF—SUN	m ² x	X					INFILTRATION				
ROOF—SHADED	m ² x	X					SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER				
GLASS 4.2	m ² x 14.4	X 5.1		309	393	354	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m ² x	X				(354)	EXHAUST AIR				
FLOOR	m ² x	X					CRACK m x CMH/m				
PARTITION 15.7	m ² x 7.2	X 1.8		197	249	243	INFILTRATION CMH				
						(243)	VENTILATION				
							Z PEOPLE X 25 CMH/PER 50				
INFILTRATION	CMH X	deg X	0.29				I' m ² X CMH/m ²				
INTERNAL HEAT							VENTILATION CMH 50				
PEOPLE	2 PEOPLE X	41		82	82	82	SENSIBLE HEAT FACTOR				
Kw	Kw X	X	860				E.S.H.F. = 1.926 (ERSH) = 0.93 (12.3°C)				
LIGHTS	21.13 X 20 W X	1.08		457	457	457	2.069 (ERTH)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
							APPARATUS DEWPOINT 12.5 °C				
CREDIT FOR THERMAL STORAGE	m ² X	deg X					1926 (ERSH)				
							(24RM-12.5ADP)(1-0.1BF)X0.29 = 620 CMH				
Sub TOTAL											
SAFETY FACTOR %						(164)	NOTES				
ROOM SENSIBLE HEAT Sub TOTAL				1731	1603	1526	GLASS (SE): 1.5 x 2.8 = 4.2				
SUPPLY DUCT	SUPPLY DUCT	FAN				(162)	WALL (SE): 3.25 x 4.0 - 4.2 = 8.8				
HEAT GAIN	- LEAK LOSS	- HP	= 10%	174	161	153	PARTITION: 4.0 x 3.8 = 15.2				
BYPASS OUTSIDE AIR 50 CMH X 4.9 deg X 0.1 BF X 0.29				21	27	24					
EFFECTIVE ROOM SENSIBLE HEAT				1926	1791	1703					
ROOM LATENT HEAT						(1800)					
INFILTRATION	CMH X	g/kg X	0.72								
PEOPLE	2 PEOPLE X	49		98							
STEAM		kg/h X	540								
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL				98	98	98					
SUPPLY DUCT LEAKAGE LOSS		10 %		10	10	10					
BYPASS OUTSIDE AIR 50 CMH X 9.5 g/kg X 0.1 BF X 0.72				35	35	34					
EFFECTIVE ROOM LATENT HEAT				143	143	142					
EFFECTIVE ROOM TOTAL HEAT				2069	1934	1845	(2:00): 1942				
OUTSIDE AIR HEAT				(98)							
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29									
LATENT:	CMH X	g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	LEAK GAIN	H.P.	GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **EXECUTIVE ENGINEER ROOM (505b, 505c) PAC-Z SYSTEM**
 SIZE **6.5** m x **9.25** m = **21.13** m² x **3.8** m/H = **80.29** m³

SHEET NO. **34**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
				MAX	CORRECTION	12:00					
SOLAR GAIN — GLASS				MAX 12:00	3:00	4:00	HOURS OF OPERATION Hour ()				
(SE) 4.2	m ² x 252 x 0.57 x 0.85 x 0.94 x 0.65			434	183	160	OUTSIDE DESIGN CONDITIONS				
	m ² x	X					DB °C	WB °C	% RH	DP °C	g/kg
	m ² x	X			(22)		OUTSIDE	38.4	27.6	43	18.9
	m ² x	X					ROOM	24.0	17.1	50	9.4
	m ² x	X					DIFFERENCE	14.4	X X X	X X X	9.5
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D				
WALL (SE) 8.8	m ² x 13.6 x 2.1	X		252	239	230	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m ² x	X					COLOR LIGHT, MEDIUM, DARK				
	m ² x	X			(257)		WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)				
	m ² x	X					INTERNAL HEAT W/m ² m ² /PEOPLE				
ROOF—SUN	m ² x	X					INFILTRATION				
ROOF—SHADED	m ² x	X					SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE CMH/PER				
GLASS 4.2	m ² x 14.4 x 5.1	X		309	393	354	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m ² x	X					EXHAUST AIR				
FLOOR	m ² x	X			(354)		CRACK m x CMH/m				
PARTITION	m ² x	X					INFILTRATION CMH				
INTERNAL HEAT							VENTILATION				
INFILTRATION	CMH x deg x 0.29						Z PEOPLE X 25 CMH/PER. 50				
PEOPLE	2 PEOPLE X 41			82	82	82	VENTILATION CMH 50				
KW	KW x X 860						SENSIBLE HEAT FACTOR				
LIGHTS	21.13 x 20 WX 1.08			457	457	457	E.S.H.F. = 1.709 (ERSH) = 0.92 (12.3°C) 1.852 (ERTH)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE	m ² x deg x						APPARATUS DEWPOINT 12.5 °C				
							1.709 (ERSH)				
							(24 RM x 12.5 ADP) (1 - BF) x 0.29 = 550 CMH				
Sub Total							NOTES				
Safety Factor	%				(131)		GLASS (SE) : 4.2				
Room Sensible Heat Sub Total				1534	1354	1283	WALL (SE) : 8.8				
SUPPLY DUCT	SUPPLY DUCT FAN					(138)					
HEAT GAIN	+ LEAK LOSS - HP = 10%			154	136	129					
BYPASS OUTSIDE AIR	50 CMH x 1.49 deg x 0.1 BF x 0.29			21	27	26					
EFFECTIVE ROOM SENSIBLE HEAT				1709	1517	1438					
ROOM LATENT HEAT						(1673)					
INFILTRATION	CMH x g/kg x 0.72										
PEOPLE	2 PEOPLE x 49			98							
STEAM	kg/h x 540										
APPLIANCES ETC.											
VAPOR TRANS.											
Sub Total											
Safety Factor	%										
Room Latent Heat Sub Total				98	98	98					
SUPPLY DUCT LEAKAGE LOSS	10 %			10	10	10					
BYPASS OUTSIDE AIR	50 CMH x 1.5 g/kg x 0.1 BF x 0.72			35	35	34					
EFFECTIVE ROOM LATENT HEAT				143	143	142					
EFFECTIVE ROOM TOTAL HEAT				1852	1660	1580					
OUTSIDE AIR HEAT						(88)					
SENSIBLE:	CMH x deg x (1 - BF) x 0.29										
LATENT:	CMH x g/kg x (1 - BF) x 0.72										
GRAND TOTAL HEAT Sub Total											
RETURN DUCT	RETURN DUCT PUMP PIPE = %										
HEAT GAIN	+ LEAK GAIN - H.P. - GAIN										
(U.S.R.T.) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO. _____ INQUIRED BY _____ SHEET No. **35**
 JOB NAME _____ ADDRESS _____ DATE ORIGINAL _____
 SPACE USED FOR **EXECUTIVE ENGINEER ROOM (505 a)** PAC-2 SYSTEM REVISION _____
 SIZE **3.25 m x 6.5 m = 21.13 m²** x **3.8 m H = 80.29 m³** PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
					CORRECTION						
SOLAR GAIN — GLASS				MAX	12:00	3:00	4:00	HOURS OF OPERATION			Hour ()
(SE) 42	m ² x 252	0.57	0.85 x 0.94 x 0.65	434	183	160	OUTSIDE DESIGN CONDITIONS				CDB CWB %RH
	m ² x	X					CONDITIONS	DB C	WB C	%RH	DP C
	m ² x	X					OUTSIDE	38.4	27.6	43	18.9
	m ² x	X					ROOM	24.0	17.1	50	9.4
	m ² x	X					DIFFERENCE	14.4	X X X	X X X	9.5
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.			
WALL (SE) 8.8	m ² x 13.6	X	2.1	252	239	230	GLASS	ORDINARY, THICK, ABSORBENT % DOUBLE			
	m ² x	X					COLOR	LIGHT, MEDIUM, DARK			
	m ² x	X					(257) WEIGHT	kg/m² (FLOOR) kg/m² (WALL)			
	m ² x	X					INTERNAL HEAT	W/m² m²/PEOPLE			
ROOF—SUN	m ² x	X					INFILTRATION				
ROOF—SHADED	m ² x	X					SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER				
GLASS 42	m ² x 14.4	X	5.1	309	393	354	OPEN DOORS DOORSX CMH/DOOR				
CEILING	m ² x	X					(354) EXHAUST AIR				
FLOOR	m ² x	X					CRACK	m x	CMH/m		
PARTITION 15.2	m ² x 17.2	X	2.5	274	346	337	INFILTRATION CMH				
							(337) VENTILATION				
INFILTRATION				CMHX	deg X	0.29	2 PEOPLEX 25 CMH/PER. 50				
INTERNAL HEAT							VENTILATION CMH 50				
PEOPLE	2 PEOPLEX	4		82	82	82	SENSIBLE HEAT FACTOR				
KW	KWX	X	860				E.S.H.F. = 2010 (ERSH) = 0.93 (12.3°C)				
LIGHTS	21.13 x 20 WX	1.08		457	457	457	2153 (ERTH)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE				m² x	deg X	(-)	APPARATUS DEWPOINT 12.5 C				
Sub Total							2010 (ERSH)				
SAFETY FACTOR				%			(24 RM - 12 (ADP) (1 - BF) x 0.29 = 2.7 CMH				
Room Sensible Heat Sub Total							NOTES				
SUPPLY DUCT	SUPPLY DUCT	FAN		1808	1700	1620	GLASS (SE): 1.5 x 2.8 = 4.2				
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	181	170	162	WALL (SE): 3.25 x 4 = 4.2 = 8.8				
BYPASS OUTSIDE AIR 50 CMH x 14.4 deg x 0.1 BF x 0.29				21	27	26	PARTITION: 4.0 x 3.8 = 15.2				
EFFECTIVE ROOM SENSIBLE HEAT				2010	1897	1808					
ROOM LATENT HEAT											
INFILTRATION	CMHX	g/kg X	0.72								
PEOPLE	2 PEOPLEX	49		98							
STEAM	kg/h X	540									
APPLIANCES ETC.											
VAPOR TRANS.											
Sub Total											
SAFETY FACTOR				%							
Room Latent Heat Sub Total				98							
SUPPLY DUCT	LEAKAGE LOSS		10 %	10							
BYPASS OUTSIDE AIR CMH x 9.5 g/kg x 0.1 BF x 0.72				35	35	34					
EFFECTIVE ROOM LATENT HEAT				143	143	142					
EFFECTIVE ROOM TOTAL HEAT				2153	2040	1950					
OUTSIDE AIR HEAT											
SENSIBLE:	CMHX	deg X (1 - BF) x 0.29									
LATENT:	CMHX	g/kg X (1 - BF) x 0.72									
GRAND TOTAL HEAT Sub Total											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	LEAK GAIN	H.P.	GAIN								
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.

INQUIRED BY

SHEET NO. 36

JOB NAME

ADDRESS

DATE ORIGINAL

SPACE USED FOR PRAY ROOM (504)

PAC-2 SYSTEM

REVISION

 SIZE 6.5 m x 6.5 m = 42.25 m² x 3.8 m H = 160.55 m³

PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h	CORRECTION	ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3
SOLAR GAIN — GLASS				MAX 3100	7:00 4:00	HOURS OF OPERATION	Hour ()		
(SE) 6.9	m ² x 252 x 0.74 x 0.85 x 0.94 x 0.65			300	363	263	OUTSIDE DESIGN CONDITION CDB CWB %RH		
(SW) 5.4	m ² x 252 x 0.74 x 0.85 x 0.94 x 0.65			185	646	627	CONDITIONS DB °C WB °C %RH DP °C E/KE		
	m ² x	x					OUTSIDE 42.2 28.6 37 19.0		
	m ² x	x					ROOM 24.0 17.1 50 9.4		
	m ² x	x					DIFFERENCE 18.2 x x x x x x x x x x 9.6		
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.		
WALL (SE) 19.1	m ² x 12.9 x 2.1			518	558	498	GLASS ORDINARY, THICK, ABSORBENT, % DOUBLE		
(SW) 20.6	m ² x 15.8 x 2.1			684	524	805	COLOR LIGHT, MEDIUM, DARK		
	m ² x	x					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)		
	m ² x	x					INTERNAL HEAT W/m ² m ² /PEOPLE		
ROOF—SUN	m ² x	x					INFILTRATION		
ROOF—SHADED	m ² x	x					SWINGING		
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER		
GLASS 6.9	m ² x 18.2 x 5.1			641	623	623	OPEN DOORS DOORSX CMH/DOOR		
CEILING	m ² x	x					EXHAUST AIR		
FLOOR 42.25	m ² x 9.1 x 1.7			654	636	636	CRACK m x CMH/m		
PARTITION 15.2	m ² x 9.1 x 1.8			249	243	243	INFILTRATION CMH		
							VENTILATION		
							12 PEOPLEX 25 CMH/PER. 300		
							m ² x CMH/m ²		
							VENTILATION CMH 300		
INTERNAL HEAT							SENSIBLE HEAT FACTOR		
PEOPLE 12	PEOPLEX 41			492	492	492	E.S.H.F. = 5.809 (ERSH) = 0.87 (11.8°C)		
KW	Kw x	x	860				6.664 (ERTH)		
LIGHTS 42.25 x 20	W x		1.08	913	913	913	DEHUMIDIFIED AIR		
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C		
							5.809 (ERSH)		
CREDIT FOR THERMAL STORAGE m ² x deg x							(24 RM. 12.5 ADP) (1 - BF) x 0.29 = 1.940 CMH		
Sub Total									
SAFETY FACTOR %				5136	4998	5100	NOTES		
ROOM SENSIBLE HEAT Sub Total							GLASS (SE): 1.5 x 1.8 + 1.5 x 2.8 = 6.9		
SUPPLY DUCT	SUPPLY DUCT FAN			514	500	510	WALL (SE): 6.5 x 4.0 - 6.9 = 19.1		
HEAT GAIN	+ LEAK LOSS + HP = 10%			159	154	154	PARTITION: 4.0 x 3.8 = 15.2		
BYPASS OUTSIDE AIR 300 CMH x 18.2 deg x 0.18 BF x 0.29							GLASS (SW): 1.5 x 1.8 x 2 = 5.4		
EFFECTIVE ROOM SENSIBLE HEAT				5809	5652	5764	WALL (SW): 6.5 x 4.0 - 5.4 = 20.6		
ROOM LATENT HEAT									
INFILTRATION	CMH x g/kg x 0.72			588					
PEOPLE	12 PEOPLE x 49								
STEAM	kg/h x 540								
APPLIANCES ETC.									
VAPOR TRANS.									
Sub Total									
SAFETY FACTOR %									
ROOM LATENT HEAT Sub Total				588	588	588			
SUPPLY DUCT	LEAKAGE LOSS 10 %			59	59	59			
BYPASS OUTSIDE AIR 300 CMH x 9.6 g/kg x 0.1 BF x 0.72				208	203	203			
EFFECTIVE ROOM LATENT HEAT				855	850	850			
EFFECTIVE ROOM TOTAL HEAT				6664	6502	6614			
OUTSIDE AIR HEAT									
SENSIBLE:	CMH x deg x (1 - BF) x 0.29								
LATENT:	CMH x g/kg x (1 - BF) x 0.72								
GRAND TOTAL HEAT Sub Total									
RETURN DUCT	RETURN DUCT PUMP PIPE								
HEAT GAIN	+ LEAK GAIN H.P. - GAIN = %								
(U.S.R.T.) GRAND TOTAL HEAT									

FORM E-20

1033

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.		INSURED BY		SHEET NO. 37	
JOB NAME		ADDRESS		DATE ORIGINAL	
SPACE USED FOR CORRIDOR (Sd6)		AC-2 SYSTEM		REVISION	
SIZE m x m = 101.5 m ² x 2.5 m (H) = 253.75 m ³				PERSON IN CHARGE	

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3	
				MAX	2:00	4:00					
SOLAR GAIN — GLASS							HOURS OF OPERATION Hour 1				
(SW) 4.2	m ² x 252 x 0.7 / 0.85 x 0.94 x 0.65			533	503	487	OUTSIDE DESIGN CONDITIONS				
	m ² x	X					CONDITONS	DB C	WB C	%RH	DP C
	m ² x	X					OUTSIDE	42.2	28.6	37	
	m ² x	X					ROOM	24.0	17.1	50	
	m ² x	X					DIFFERENCE	18.2	X X X	X X X	9.6
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND				
WALL (SW) 5.8	m ² x 15.8	X	2.1	193	148	227	GLASS				
	m ² x	X					NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D				
	m ² x	X					ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m ² x	X					COLOR				
	m ² x	X					WEIGHT				
	m ² x	X					INTERNAL HEAT				
ROOF—SUN	m ² x	X					INFILTRATION				
ROOF—SHADED	m ² x	X					SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS				
GLASS 4.2	m ² x 18.2	X	5.1	390	380	380	PEOPLEX CMH/PER.				
CEILING	m ² x	X					OPEN DOORS				
FLOOR	m ² x	X					DOORSX CMH/DOOR				
PARTITION (1) 30.5	m ² x 9.1	X	1.8	494	481	481	EXHAUST AIR				
(2) 33.2	m ² x 9.1	X	2.5	756	735	735	CRACK				
DOOR 5.4	m ² x 9.1	X	1.6	79	77	77	INFILTRATION CMH				
INFILTRATION	CMHX	degX	0.29				VENTILATION				
INTERNAL HEAT							PEOPLEX CMH/PER.				
PEOPLE	PEOPLEX						VENTILATION CMH				
Kw	KwX	X	860				SENSIBLE HEAT FACTOR				
LIGHTS	101.5 x 20 Wx		1.08	2193	2193	2193	E.S.H.F. = 5.102 (ERSH) = 1.0 (13.2)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE	m ² x	degX					APPARATUS DEWPOINT 12.5 C				
Sub TOTAL							5.102 (ERSH)				
Safety Factor	%						24 RM-12.5ADP(1-1, BF) x 0.29 = 1680 CMH				
ROOM SENSIBLE HEAT Sub TOTAL							NOTES				
SUPPLY DUCT	SUPPLY DUCT	FAN		4638	4571	4580	SR = 32.5 x 2.5 + 2.0 x 2.0 + 6.5 x 2.5 = 101.5				
HEAT GAIN	—LEAK LOSS	—HP	=10%	464	452	458	GLASS (SW) : 1.5 x 2.8 = 4.2				
BYPASS OUTSIDE AIR	CMHX	degX	BF x 0.29				WALL (SW) : 2.5 x 4.0 = 4.2 = 5.8				
EFFECTIVE ROOM SENSIBLE HEAT							PARTITION				
ROOM LATENT HEAT							(1) : 13.5 x 2.5 = 30.15				
INFILTRATION	CMHX	g/kgX	0.72				(2) : 14.0 x 2.5 = 33.2				
PEOPLE	PEOPLEX						DOOR : 0.9 x 2.0 x 3 = 5.4				
STEAM	kg/hX		540								
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
Safety Factor	%										
ROOM LATENT HEAT Sub TOTAL											
SUPPLY DUCT LEAKAGE LOSS			%								
BYPASS OUTSIDE AIR	CMHX	g/kgX	BF x 0.72								
EFFECTIVE ROOM LATENT HEAT											
EFFECTIVE ROOM TOTAL HEAT											
OUTSIDE AIR HEAT											
SENSIBLE:	CMHX	degX(1 - BF) x 0.29									
LATENT:	CMHX	g/kgX(1 - BF) x 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	—LEAK GAIN	—H.P	—GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR EXECUTIVE ENGINEER ROOM (to 3d) PAC-2 SYSTEM
 SIZE 3.25 m x 6.5 m = 21.13 m² x 3.8 m (H) = 80.29 m³

SHEET No. 38
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM4	
					CORRECTION						
SOLAR GAIN — GLASS				HAX 4:00	2:00	3:00	HOURS OF OPERATION Hour 1 - 1				
(SE) 4.2	m ² x 2.52 x 0.21 / 0.85 x 0.94 x 0.65			160	221	183	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
	m ² x	x					CONDITIONS DB °C WB °C %RH DP °C g/kg				
	m ² x	x					OUTSIDE 41.7 28.4 38 18.8				
	m ² x	x					ROOM 24.0 17.1 50 9.4				
	m ² x	x					DIFFERENCE 17.7 x x x x x x 9.4				
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L, M, D				
WALL (SE) 8.8	m ² x 12.4 x 2.1			230	257	239	GLASS ORDINARY, THICK, ABSORBENT, % DOUBLE				
	m ² x	x					COLOR LIGHT, MEDIUM, DARK				
	m ² x	x					WEIGHT kg/m² (FLOOR) kg/m² (WALL)				
	m ² x	x					INTERNAL HEAT W/m² m²/PEOPLE				
ROOF—SUN 21.13	m ² x 26.2 x 1.7			942	762	863	INFILTRATION				
ROOF—SHADED	m ² x	x					SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.				
GLASS 4.2	m ² x 17.7 x 5.1			380	380	390	OPEN DOORS DOORSX CMH/DOOR				
CEILING	m ² x	x					EXHAUST AIR				
FLOOR	m ² x	x					CRACK m x CMH/m				
PARTITION 15.2	m ² x 8.85 x 1.8			243	243	249	INFILTRATION CMH				
							VENTILATION				
							Z PEOPLEX 2.5 CMH/PER. 50				
							Z m² CMH/m²				
INFILTRATION CMHX degX 0.29							VENTILATION CMH 50				
INTERNAL HEAT							SENSIBLE HEAT FACTOR				
PEOPLE	2 PEOPLEX 41			82	82	82	E.S.H.F. = 2.770 (ERSH) = 0.95 (12.5°C)				
Kw	KwX x 860						2.912 (ERTH)				
LIGHTS	21.13 x 20 Wx 1.08			457	457	457					
APPLIANCES ETC.							DEHUMIDIFIED AIR				
							APPARATUS DEWPOINT 12.5 °C				
CREDIT FOR THERMAL STORAGE m² x degX (-) (-)							2.770 (ERSH)				
Sub TOTAL							(24RM-12.5ADP)(1-BF)X0.29 = 920 CMH				
SAFETY FACTOR %							NOTES				
ROOM SENSIBLE HEAT Sub TOTAL				2494	2402	2463	GLASS (SE) : 1.5 x 2.8 = 4.2				
SUPPLY DUCT	SUPPLY DUCT FAN						WALL (SE) : 3.25 x 4.0 - 4.2 = 8.8				
HEAT GAIN	- LEAK LOSS -HP = 10%			250	241	247	PARTITION : 4.0 x 3.8 = 15.2				
BYPASS OUTSIDE AIR 50 CMH x 17.7 deg x 0.1 BF x 0.29				26	26	27	ROOF : 15R				
EFFECTIVE ROOM SENSIBLE HEAT				2770	2629	2737					
ROOM LATENT HEAT											
INFILTRATION	CMHX g/kgX 0.72										
PEOPLE	2 PEOPLEX 49			98							
STEAM	kg/hX 540										
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL				98	98	98					
SUPPLY DUCT	LEAKAGE LOSS 10%			10	10	10					
BYPASS OUTSIDE AIR 50 CMH x 9.4 g/kg x 0.1 BF x 0.72				34	34	35					
EFFECTIVE ROOM LATENT HEAT				142	142	143					
EFFECTIVE ROOM TOTAL HEAT				2912	2811	2880					
OUTSIDE AIR HEAT (138)											
SENSIBLE: CMHX degX (1-BF)X0.29											
LATENT: CMHX g/kgX (1-BF)X0.72											
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT PUMP PIPE										
HEAT GAIN	LEAK GAIN H.P. + GAIN										
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRED BY

SHEET No. 39

ADDRESS

DATE ORIGINAL

REVISION

$$\text{SIZE } 3,25 \text{ m} \times 6,5 \text{ m} = 21,13 \text{ m}^2 \times 3,8 \text{ m(H)} = 80,29 \text{ m}^3$$

PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM 4
					CORRECTION					
SOLAR GAIN — GLASS				MAX 4:00	2:00	3:00	HOURS OF OPERATION		Hour (	-)
(SE) 4.7	m ² × 2.52 × 0.21	0.85 × 0.94 × 0.65		160	221	183	OUTSIDE DESIGN CONDITIONS		CDB	CWB %RH
	m ² ×	X					CONDITIONS	DB °C	WB °C	%RH DP °C g/kg
	m ² ×	X					OUTSIDE	41.7	28.4	38 188
	m ² ×	X					ROOM	24.0	17.1	50 9.4
	m ² ×	X					DIFFERENCE	17.7	X X X	X X X X X X 9.4
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D		
WALL (SE) 8.8	m ² × 12.4	X 2.1		230	257	239	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
	m ² ×	X					COLOR	LIGHT, MEDIUM, DARK.		
	m ² ×	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)
	m ² ×	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE
ROOF—SUN 21.13	m ² × 26.2	X 1.7		942	762	863	INFILTRATION			
ROOF—SHADED	m ² ×	X					SWINGING			
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.			
GLASS 4.2	m ² × 17.7	X 5.1		380	380	390	OPEN DOORS DOOREX CMH/DOOR			
CEILING	m ² ×	X					EXHAUST AIR			
FLOOR	m ² ×	X					CRACK m X CMH/m			
PARTITION	m ² ×	X					INFILTRATION CMH			
							VENTILATION			
							2 PEOPLEX 25 CMH/PER. 50			
INFILTRATION CMH X deg X 0.29							1' m ² X CMH/m ²			
INTERNAL HEAT							VENTILATION CMH 50			
PEOPLE 2	PEOPLEX 41			82	82	82	SENSIBLE HEAT FACTOR			
KW KW X X 860							E.S.H.F. = 2.503 (ERSH) = 0.95 (12.5°C)			
LIGHTS 21.13 X 20 WX 1.08				457	457	457	2.646 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
							APPARATUS DEWPOINT 12.5 °C			
CREDIT FOR THERMAL STORAGE m ² X deg X							2.503 (ERSH)			
Sub TOTAL							24 RM-12.5ADP(1-BF) X 0.29 = 830 CMH			
SAFETY FACTOR %							NOTES			
ROOM SENSIBLE HEAT Sub TOTAL				2251	2159	2214	GLASS (SE): 1.5 × 2.8 = 4.2			
SUPPLY DUCT SUPPLY DUCT FAN							WALL (SE): 3.25 × 4.0 - 4.2 = 8.8			
HEAT GAIN - LEAK LOSS + HP = 1 %				226	216	222	ROOF : SR			
BYPASS OUTSIDE AIR 50 CMH X 17.7 deg X 0.1 BF X 0.29				26	26	27				
EFFECTIVE ROOM SENSIBLE HEAT				2503	2401	2463				
ROOM LATENT HEAT										
INFILTRATION CMH X g/kg X 0.72										
PEOPLE 2 PEOPLEX 44				98						
STEAM kg/h X 540										
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL				98	98	98				
SUPPLY DUCT LEAKAGE LOSS 10 %				10	10	10				
BYPASS OUTSIDE AIR 50 CMH X 9.4 g/kg X 0.1 BF X 0.72				34	34	35				
EFFECTIVE ROOM LATENT HEAT				143	142	143				
EFFECTIVE ROOM TOTAL HEAT				2164.6	2543	2606				
OUTSIDE AIR HEAT										
SENSIBLE: CMH X deg X (1 - BF) X 0.29										
LATENT: CMH X g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT RETURN DUCT PUMP PIPE										
HEAT GAIN LEAK GAIN H.P. GAIN = %										
(U.S.R.T) GRAND TOTAL HEAT										

FORM E-20E

1036

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR EXECUTIVE ENGINEER ROOM (T03A) PAC-2 SYSTEM
 SIZE 3.25 m x 6.5 m = 21.13 m² x 3.8 m H = 80.29 m³

SHEET No. 40
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 4	
				MAX	2:00	3:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour () ~ ()				
(SE) 4.2	m ² x 252	0.85 x 0.94 x 0.65		160	221	183	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
	m ² x	x					CONDITIONS DB °C WB °C %RH DP °C g/kg				
	m ² x	x					OUTSIDE 41.7 28.4 38 18.8				
	m ² x	x					ROOM 24.0 17.1 50 9.9				
	m ² x	x					DIFFERENCE 17.7 x x x x x x x 9.4				
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L.M.D				
WALL (SE) 8.8	m ² x 12.4	x 2.1		230	257	239	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m ² x	x					COLOR LIGHT, MEDIUM, DARK.				
	m ² x	x					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)				
	m ² x	x					INTERNAL HEAT W/m ² m ² /PEOPLE				
Roof - SUN 21.13	m ² x 26.2	x 1.7		942	762	863	INFILTRATION				
Roof - SHADED	m ² x	x					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE CMH/PER				
GLASS 4.2	m ² x 17.7	x 5.1		380	380	390	OPEN DOORS DOORS x CMH/DOOR				
CEILING	m ² x	x					EXHAUST AIR				
FLOOR	m ² x	x					CRACK m x CMH/m				
PARTITION 15.2	m ² x 8.85	x 2.5		337	337	346	INFILTRATION CMH				
INFILTRATION CMH x deg x 0.29							VENTILATION				
INTERNAL HEAT							2 PEOPLE x 25 CMH/PER. 50				
PEOPLE 2 PEOPLE x 41				82	82	82	SENSIBLE HEAT FACTOR				
KW KW x 860							E.S.H.F. = 2.873 (ERSH) = 0.95 (12.5°C)				
LIGHTS 21.13 x 20 W x 1.08				457	457	457	3.015 (ERTH)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE m ² x deg x							APPARATUS DEWPOINT 12.5 °C				
Sub Total							2873 (ERSH)				
Safety Factor %							(24RM - 12.5 ADP) (1 - BF) x 0.29 = 960 CMH				
Room Sensible Heat Sub Total							NOTES				
SUPPLY DUCT SUPPLY DUCT FAN				259	250	256	GLASS (SE): 1.5 x 2.8 = 4.2				
HEAT GAIN - LEAK LOSS - HP = 10%							WALL (SE): 3.25 x 4.0 - 4.2 = 8.8				
BYPASS OUTSIDE AIR 50 CMH x 17.7 deg x 0.1 BF x 0.29				26	26	27	PARTITION: 4.0 x 3.8 = 15.2				
EFFECTIVE ROOM SENSIBLE HEAT							ROOF: SR				
ROOM LATENT HEAT											
INFILTRATION CMH x g/kg x 0.72											
PEOPLE 2 PEOPLE x 49				98							
STEAM kg/h x 540											
APPLIANCES ETC.											
VAPOR TRANS.											
Sub Total											
Safety Factor %											
Room Latent Heat Sub Total											
SUPPLY DUCT LEAKAGE LOSS 10%				10	10	10					
BYPASS OUTSIDE AIR CMH x 9.4 g/kg x 0.1 BF x 0.72				34	34	35					
EFFECTIVE ROOM LATENT HEAT											
EFFECTIVE ROOM TOTAL HEAT											
OUTSIDE AIR HEAT (143)											
SENSIBLE: CMH x deg x (1 - BF) x 0.29											
LATENT: CMH x g/kg x (1 - BF) x 0.72											
GRAND TOTAL HEAT Sub Total											
RETURN DUCT + RETURN DUCT + PUMP + PIPE											
HEAT GAIN + LEAK GAIN + H.P. + GAIN = %											
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR LIBRARY & STORAGE ROOM (TOZ) PAC - 2 SYSTEM
 SIZE 6.5 m x 6.5 m = 42.25 m² x 3.8 m H = 160.55 m³

SHEET NO. 41
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
				MAX	CORRECTION						
SOLAR GAIN - GLASS							HOURS OF OPERATION		Hour (-)		
(SW) 5.4	m ² x 2.52 x 0.64	685 x 0.94 x 0.65		1627	646	685	OUTSIDE DESIGN CONDITIONS		CDB	CWB	%RH
(SE) 6.9	m ² x 2.52 x 0.21	685 x 0.94 x 0.65		263	263	300	CONDITIONS	DB °C	WB °C	%RH	DP °C
	m ² x	x					OUTSIDE	41.7	28.4	38	18.8
	m ² x	x					ROOM	24.0	17.1	50	9.4
	m ² x	x					DIFFERENCE	17.7	x x x	x x x	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE)			L M. D
WALL (SW) 21.6	m ² x	18.6 x	2.1	805	524	684	GLASS	ORDINARY, THICK, ABSORBENT.			% DOUBLE
(SE) 19.1	m ² x	12.4 x	2.1	498	558	518	COLOR	LIGHT, MEDIUM, DARK.			
	m ² x	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² x	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE	
ROOF - SUN 36.25	m ² x	26.2 x	1.7	1625	1367	1479	INFILTRATION				
ROOF - SHADED	m ² x	x					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.				
GLASS 12.3	m ² x	17.7 x	5.1	1111	1111	1142	OPEN DOORS DOORSX CMH/DOOR				
CEILING 6.0	m ² x	8.85 x	1.4	75	75	77	EXHAUST AIR				
FLOOR	m ² x	x					CRACK m x CMH/m				
PARTITION 15.2	m ² x	8.85 x	1.8	243	243	249	INFILTRATION CMH				
							VENTILATION				
							4 PEOPLEX 25 CMH/PER. 100				
							m ² x CMH/m ²				
							VENTILATION CMH 100				
INFILTRATION CMH x deg x 0.29							SENSIBLE HEAT FACTOR				
INTERNAL HEAT							E.S.H.F. = $\frac{7009}{7293}$ (ERSH) = 0.96 (12.6°C)				
PEOPLE 4	PEOPLEX	41		164	164	164	DEHUMIDIFIED AIR				
KW	KW x	x	860				APPARATUS DEWPOINT 12.5 °C				
LIGHTS 42.25 x 20	WX	1.08		913	913	913	$\frac{7009}{7293}$ (ERSH) = 2.340 CMH				
APPLIANCES ETC.											
CREDIT FOR THERMAL STORAGE m² x deg x											
Sub TOTAL											
SAFETY FACTOR %							NOTES				
ROOM SENSIBLE HEAT Sub TOTAL				6324	4904	6211	GLASS (SW): 1.5 x 1.8 x 2 = 5.4				
SUPPLY DUCT	SUPPLY DUCT	FAN					(SE): 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
HEAT GAIN	- LEAK LOSS	+ HP	= 10%	633	491	622	WALL (SW): 6.5 x 4.0 x 5.4 = 20.6				
BYPASS OUTSIDE AIR 100 CMH x 17.7 deg x 0.1 BF x 0.29				52	52	53	(SE): 6.5 x 4.0 = 6.9 = 19.1				
EFFECTIVE ROOM SENSIBLE HEAT				7009	5447	6886	PARTITION: 4.0 x 3.8 = 15.2				
ROOM LATENT HEAT							ROOF: SR - 6.0 = 36.25				
INFILTRATION	CMH x	g/kg x	0.72				CEILING: 3.0 x 2.0 = 6.0				
PEOPLE 4	PEOPLEX	49		196							
STEAM		kg/h x	540								
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL				196	196	196					
SUPPLY DUCT LEAKAGE LOSS		10 %		20	20	20					
BYPASS OUTSIDE AIR 100 CMH x 9.4 g/kg x 0.1 BF x 0.72				68	68	70					
EFFECTIVE ROOM LATENT HEAT				284	284	286					
EFFECTIVE ROOM TOTAL HEAT				7293	5731	7172					
OUTSIDE AIR HEAT (173)											
SENSIBLE: CMH x deg x (1 - BF) x 0.29											
LATENT: CMH x g/kg x (1 - BF) x 0.72											
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE = %								
HEAT GAIN	LEAK GAIN	H.P.	GAIN								
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY No.

INQUIRED BY

SHEET No. 47

JOB NAME

ADDRESS

DATE ORIGINAL

SPACE USED FOR CORRIDOR (TO 4)

PAC-2 SYSTEM

REVISION

 SIZE m x m = 101.5 m² x 2.5 m (H) = 253.75 m³

PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM4
				MAX 4:00	CORRECTION					
SOLAR GAIN — GLASS										
(SW) 4.2	m ² x 253 x 0.14 / 0.85 x 0.94 x 0.65			1487	503	533	HOURS OF OPERATION Hour 1 - 1			
m ² x	X						OUTSIDE DESIGN CONDITIONS CDB CWB %RH			
m ² x	X						CONDITIONS DB °C WB °C %RH DP °C E/kWh			
m ² x	X						OUTSIDE 41.7 28.6 38 18.8			
m ² x	X						ROOM 24.0 17.1 50 9.4			
m ² x	X						DIFFERENCE 17.7 X X X X X X X 9.4			
SOLAR & TRANS GAIN—WALLS & ROOF										
WALL (SW) 5.8	m ² x 18.6 x 2.1			227	148	193	BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L.M.D			
m ² x	X						GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE			
m ² x	X						COLOR LIGHT, MEDIUM, DARK.			
m ² x	X						WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)			
ROOF—SUN 85.25	m ² x 26.2 x 1.1			2457	1488	2251	INTERNAL HEAT W/m ² m ² /PEOPLE			
ROOF—SHADED	m ² x	X					INFILTRATION			
TRANS. GAIN—EXCEPT WALLS & ROOF										
GLASS 4.2	m ² x 17.7 x 5.1			380	380	390	SWINGING			
CEILING 16.25	m ² x 8.85 x 1.4			202	202	207	REVOLVING DOORS PEOPLEX CMH/PER.			
FLOOR	m ² x	X					OPEN DOORS DOORSX CMH/DOOR			
PARTITION (1) 30.15	m ² x 8.85 x 1.8			481	481	494	EXHAUST AIR			
(2) 33.2	m ² x 8.85 x 2.5			735	735	756	CRACK m x CMH/m			
DOOR 5.4	m ² x 8.85 x 1.6			77	77	79	INFILTRATION CMH			
INFILTRATION	CMHX deg X 0.29						VENTILATION			
INTERNAL HEAT										
PEOPLE	PEOPLEX						PEOPLEX CMH/PER.			
Kw	KwX X 860						m ² x CMH/m ²			
LIGHTS	101.5 x 20 Wx 1.08			2193	2193	2193	VENTILATION CMH			
APPLIANCES ETC.							SENSIBLE HEAT FACTOR			
E.S.H.F. = 7966 (ERSH) 1.0										
7966 (ERTH)										
DEHUMIDIFIED AIR										
APPARATUS DEWPOINT 12.5 °C										
7966 (ERSH)										
(24 RM - 12.5 ADP) (1 - BF) x 0.29 CMH										
NOTES										
SR = 2.5 x 32.5 + 2.0 x 2.0 + 6.5 x 2.5 = 101.5										
GLASS (SW) : 1.5 x 2.8 = 4.2										
WALL (SW) : 2.5 x 4.0 - 4.2 = 5.8										
PARTITION										
(1) : 13.5 x 2.5 - 3.6 = 30.15										
(2) : 14.0 x 2.5 - 1.8 = 33.2										
DOOR : 0.9 x 2.0 x 3 = 5.4										
ROOF : SR - 2.5 x 6.5 = 85.25										
CEILING : 2.5 x 6.5 = 16.25										
CREDIT FOR THERMAL STORAGE										
CREDIT FOR THERMAL STORAGE m ² x deg X (1 - BF) x 0.29										
Sub Total										
SAFETY FACTOR										
ROOM SENSIBLE HEAT Sub Total										
7239 6707 7096										
SUPPLY DUCT SUPPLY DUCT FAN										
HEAT GAIN + LEAK LOSS + HP = 10%										
724 671 710										
BYPASS OUTSIDE AIR CMHX deg X BF x 0.29										
EFFECTIVE ROOM SENSIBLE HEAT										
71963 7378 7806										
ROOM LATENT HEAT										
INFILTRATION CMHX g/kg X 0.72										
PEOPLE PEOPLEX										
STEAM kg/h X 540										
APPLIANCES ETC.										
VAPOR TRANS.										
Sub Total										
SAFETY FACTOR										
ROOM LATENT HEAT Sub Total										
SUPPLY DUCT LEAKAGE LOSS										
BYPASS OUTSIDE AIR CMHX g/kg X BF x 0.72										
EFFECTIVE ROOM LATENT HEAT										
EFFECTIVE ROOM TOTAL HEAT										
71963 7378 7806										
OUTSIDE AIR HEAT										
SENSIBLE: CMHX deg X (1 - BF) x 0.29										
LATENT: CMHX g/kg X (1 - BF) x 0.72										
GRAND TOTAL HEAT Sub Total										
RETURN DUCT RETURN DUCT PUMP PIPE										
HEAT GAIN + LEAK GAIN H.P. + GAIN = %										
(U.S.R.T) GRAND TOTAL HEAT										

FORM E-20E

8.5 設備負荷

5. EQUIPMENT LOAD

5-1 PAC-1

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	: 24.0°C	17.1°C	11.5 Kcal/kg
OUTSIDE	: 42.2°C	28.6°C	22.0 Kcal/kg
R.S.H	: 119.476	Kcal/h	
S.H.F	: 0.94		
DEHUMIDIFIED AIR	: 39.900	m ³ /h	
OUT AIR	: 4.230	m ³ /h	
RETURN AIR	: 35670	m ³ /h	

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{4230 \frac{\text{m}^3}{\text{h}} \times 22.0 \frac{\text{Kcal}}{\text{kg}} + 35670 \frac{\text{m}^3}{\text{h}} \times 11.5 \frac{\text{Kcal}}{\text{kg}}}{39.900 \frac{\text{m}^3}{\text{h}}} \\ = 12.6 \frac{\text{Kcal}}{\text{kg}}$$

$$\therefore \left[39.900 \frac{\text{m}^3}{\text{h}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (12.6 - 8.5) \frac{\text{Kcal}}{\text{kg}} \times (1 - 0.1) \times 1.05 \right] \\ = 185.000 \text{ Kcal/h}$$

③ PEAK LOAD (PM. 5:00)

$$\text{E.R.T.H} : 125.721 \frac{\text{Kcal}}{\text{h}} \dots \text{①}$$

$$\text{OUT SIDE AIR HEAT} : 4.230 \frac{\text{m}^3}{\text{h}} \times 165 \times (1 - 0.1) \times 0.29 = 18.217 \frac{\text{Kcal}}{\text{h}} \dots \text{②}$$

$$4.230 \times 95 \times (1 - 0.1) \times 0.72 = 26.040 \frac{\text{Kcal}}{\text{h}} \dots \text{③}$$

$$\text{TOTAL } \text{①} + \text{②} + \text{③} = (125.721 + 18.217 + 26.040) \times 1.05 = 179.000 \frac{\text{Kcal}}{\text{h}}$$

PSYCHROMETRIC CHART

ZONE NAME :


SA = 39.900 CMH

OA = 4.230 CMH

RA = 35.670 CMH

MIX POINT = $\frac{4.230 \times 42.2 + 35.670 \times 24.0}{39.900} = 25.9$

SHE = 0.94



S - 2 PAC - 2

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	24.0°C	17.1°C	11.5 Kcal/kg
OUTSIDE	42.2°C	28.6°C	22.0 Kcal/kg
R.S.H	60.067	Kcal/h	
S.H.F	0.95		
DEHUMIDIFIED AIR		20.050 m ³ /h	
OUT AIR		1.200 m ³ /h	
RETURN AIR		18.850 m ³ /h	

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{1200 \frac{\text{m}^3}{\text{h}} \times 22.0 \frac{\text{Kcal}}{\text{kg}} + 18.850 \frac{\text{m}^3}{\text{h}} \times 11.5 \frac{\text{Kcal}}{\text{kg}}}{20.050 \frac{\text{m}^3}{\text{h}}}$$

$$= 12.1 \text{ Kcal/kg}$$

$$\therefore \left[20.050 \frac{\text{m}^3}{\text{h}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (12.1 - 8.5) \frac{\text{Kcal}}{\text{kg}} \right] \times (1 - 0.1) \times 1.05$$

$$= 82.000 \text{ Kcal/h}$$

① PEAK LOAD CPM

$$\text{E.R.T.H} : 62.391 \text{ Kcal/h} \dots \text{①}$$

$$\text{OUT SIDE AIR HEAT} : 1200 \frac{\text{m}^3}{\text{h}} \times 18.2 \times (1 - 0.1) \times 0.29 = 5.701 \text{ Kcal/h} \dots \text{②}$$

$$: 1200 \times 9.6 \times (1 - 0.1) \times 0.72 = 7.465 \text{ Kcal/h} \dots \text{③}$$

$$\text{TOTAL} = \text{①} + \text{②} + \text{③} = (62.391 + 5.701 + 7.465) \times 1.05 = 80.000 \text{ Kcal/h}$$

1042

PSYCHROMETRIC CHART

ZONE NAME:


SA = 20,050 C.M.H.

QA = 1,200 C.M.H.

RA = 18,850 C.M.H.

$$\text{MIX-POINT} = \frac{1700 \times 42 + 18850 \times 24.0}{20050}$$

$$= 25.1$$



6. SELECTION OF COOLING EQUIPMENT

6-1 EQUIPMENT PAC-1 x 1ea

AIR-COOLED PACKAGED AIR CONDITIONER

AIR FLOW RATE : 39.900 m³/H (665 m³/min)

COOLING LOAD (T.H.R.) : 179,000 KCAL/H

(SHC) : 119,476

EXTERNAL STATIC PRES. : 70 mmA_g

AIR INLET : 25.9°C DB , 18.4°C WB , 12.6 Kcal/Kg

OUTLET : 13.8°C DB , 13.2°C WB , 8.9 Kcal/Kg

CONDENSING TEMPERATURE : 50°C DB

TEMPERATURE DIFFERENCE : 15°C

TYPE : FLOOR (DUCT TYPE)

AIR FLOW RATE : 39.900 m³/H

COMPRESSOR (3ea) : 83.5 KW (INPUT)

FAN MOTOR : 18.5 KW (IN) , 0.75^{KW} x 3 x 3 (OUT)

POWER : Ø3-380 V, 50Hz

TAPPING SIZE : (1-3/8" + 7/8") x 3 , DRAIN 40A

DIMENSION (INDOOR): 3.700 x 1.600 x 2.130^H (mm)(OUTDOOR): 2.922 x 1.204 x 1.126^H x 3

WEIGHT : (IN) 2.660 Kg, (OUT) 4.10 Kg x 3

MODEL INDOOR UNIT : 50BM100 x 1ea (CARRIER)

OUTDOOR UNIT : 09DC024 x 3ea

$$SHC = 151,000 + 665 \times 17.4 \times (1 - 0.17) \times (24 - 27) = 122,000 \text{ kcal/h}$$

6-2EQUIPMENT PAC-Z x 1ea
AIR-COOLED PACKAGED AIR CONDITIONER

AIR FLOW RATE : 20050 m³/H (345 m³/min)

COOLING LOAD (T.H.R) : 80.000 Kcal/H
(S.H.C) : 60.067 Kcal/H

EXTERNAL STATIC PRES.: 65 mmA₈

AIR INLET : 25.1°C DB , 18.1°C WB , 12.1 Kcal/Kg

OUTLET : 13.8°C DB , 13.2°C WB , 8.9 Kcal/Kg

CONDENSING TEMPERATURE : 50°C DB

TEMPERATURE DIFFERENCE : 15°C

TYPE	: FLOOR (DUCT TYPE)
AIR FLOW RATE	: 20.050 m ³ /H
COMPRESSOR (2ea)	: 45.0 Kw (INPUT)
FAN MOTOR	: 7.5 Kw (IN) , 0.3 Kw x 2 x 2 (OUT)
POWER	: Ø3-380 V, 50Hz
TAPPING SIZE	: (1-1/8" + 1-3/8") x 2 DRAIN 40 A
DIMENSION (INDOOR):	2.600 x 1.600 x 1.900 ^H (mm)
(OUTDOOR)	1.900 x 1.118 x 1.028 ^H x 2
WEIGHT	: (IN) 1.550 Kg (OUT) 180 Kg x 2

MODEL INDOOR UNIT : 50BM 054 x 1ea (CARRIER)

OUTDOOR UNIT : 09DE012 x 2ea

$$SHC' = 79.000 + 345 \times 17.4 \times (1 - 0.2) \times (24 - 27) = 64.600 \text{ Kcal/H}$$

1045

8.7 換 氣

7. VENTILATION SYSTEM

7-1 ESTIMATE OF VENTILATION AIR VOLUME

ADMINISTRATION BUILDING (1)

49

FLOOR	ROOM NAME	AREA (m ²)	VOL. (m ³)	AIR CHANGE (T/Hr)	AIR FLOW (m ³ /Hr)	EXHAUST AIR (m ³ /Hr)	SUPPLY AIR (m ³ /Hr)	
GROUND FLOOR	(G04) MACHINE SHOP	310.	1488	10	14,880	15,000	15,000	OF-1×4 (I) PF-1×4
	(G05) WELDING ROOM	22.8	109.4	5	547	550	550	OF-3 (I) PF-5
	(G06) TOOL & SPARE PARTS STORAGE ROOM	35.0	168.0	5	840	840	DG: 840	(III) PF-4
	(G07) AIR CONDITIONING MACHINE ROOM	84.5	405.6	5	2028	2100	2100	OF-2 (I) PF-2
	(G08) ELECTRIC ROOM	21.1	101.3	20	2026	2100	2100	OF-2 (I) PF-2
	(G09) LAVATORY	18.4	46	10	460	460 *	-	(III) VF-4
	SUB TOTAL					21,050	20590	SA: 1660 RA: 1200 GA: 460
FIRST FLOOR	(F15) LAVATORY (MALE)	27.0	67.5	10	675	680 *	2670	(III) VF-2
	(F16) LAVATORY (FEMALE)	9.0	22.5	10	225	230 *	-	(II) VF-6
	(F18b) LAVATORY	6.8	17.0	10	170	170 *	-	(II) VF-9
	(F14b) SHOWER BOOTH	3.2	8	10	80	80	-	(III) VF-11
	(F14a) SHOWER BOOTH	3.0	7.5	10	75	80	-	(III) VF-11
	(F12) DRESSING RM.	7.0	17.5	10	175	180 *	-	(III) VF-8
	(F18a) LAVATORY	3.0	7.5	10	75	80 *	-	(III) VF-11
	(F13) KITCHENETTE	6.0	15.0	10	150	150	-	(III) VF-10
	(F17) LAVATORY	7.0	17.5	10	175	180 *	-	(III) VF-8
	(F06) PANTRY	9.0	22.5	10	225	250 *	-	(III) PF-6
	(F08) BATTERY ROOM	16.0	60.8	10	608	610	610	OF-4 (I) VF-3
	(F05) KITCHEN	33.3	83.25	10	833	900 *	700 200 -	PF-1 (III) VF-7
	SUB TOTAL					3,590		(13380+5400) SA: 18,780 RA: 16,110 GA: 2670

(2270+400)

946

ESTIMATE OF VENTILATION AIR VOLUME

ADMINISTRATION BUILDING (2)

50

FLOOR	ROOM NAME	AREA (m ²)	VOL. (m ³)	AIR CHANGE (T/Hr)	AIR FLOW (m ³ /Hr)	EXHAUST AIR (m ³ /Hr)	SUPPLY AIR (m ³ /Hr)	
SECOND FLOOR	(S09) LAVATORY (MALE)	27.0	67.5	10	675	680	1250	(III) VF-2
	(S10) LAVATORY (FEMALE)	9.0	22.5	10	225	230	-	(III) VF-6
	(S11b) LAVATORY	6.8	17.0	10	170	170	-	(III) VF-9
	(S12b) SHOWER BOOTH	3.2	8	10	80	80	-	(III) VF-11
	(S11a) LAVATORY	6.8	17.0	10	170	170	-	(III) VF-9
	(S12a) SHOWER BOOTH	3.2	8	10	80	80	-	(III) VF-11
	SUB TOTAL					1.410	-	SA = 16030 RA = 14780 OA = 1250
THIRD FLOOR	(T07) LAVATORY (MALE)	27.0	67.5	10	675	750	1050	(III) VF-1
	(T08) LAVATORY (FEMALE)	9.0	22.5	10	225	300	-	(III) VF-5
	SUB TOTAL					1050		SA = 23480 RA = 22430 OA = 1050
								TSA = 59950 TRA = 54520 TEA/OA = 5430
ROOF	(R01) ELEVATOR MACHINE ROOM	27.7	85.9	20	1.718	1800		(III) PF-3
	G. TOTAL							

1047

7-2. SELECTION OF VENTILATION EQUIPMENT

V - 1. MACHINE SHOP (GROUND FLOOR)

MACHINE NO PF-1 (=OF-1 x 4 ea)

TYPE OF VENTILATOR	:	PROPELLER	x 4 ea
AIR FLOW RATE	:	3750 m ³ /Hr	4500 x 5 mm/hg
FAN MOTOR	:	0.4 KW or	w
POWER	:	10-220v / 30 380 v	(50/60 Hz)
SIZE	:	620 x 620 x 332	(mm)
ACCESSORY	:	SUS WEATHER COVER, SHUTTER	

V - 2 ELECTRIC ROOM. (GROUND FLOOR)

MACHINE NO PF-2 (=OF-2 x 1 ea)

TYPE OF VENTILATOR	:	PROPELLER	x 1 ea
AIR FLOW RATE	:	2100 m ³ /Hr	4400 x 5 mm/hg
FAN MOTOR	:	0.1 KW or	w
POWER	:	10-220v / 30 380 v	(50/60 Hz)
SIZE	:	520 x 520 x 268	(mm)
ACCESSORY	:	SUS. WEATHER COVER, SHUTTER	

V - 3 AIR CONDITONING MACHINE ROOM (GROUND FLOOR)

MACHINE NO PF-2, (=OF-2 x 1 ea)

TYPE OF VENTILATOR	:	PROPELLER	x 1 ea
AIR FLOW RATE	:	2100 m ³ /Hr	4400 x 5 mm/hg
FAN MOTOR	:	0.1 KW or	w
POWER	:	10-220v / 30 380 v	(50/60 Hz)
SIZE	:	520 x 520 x 268	(mm)
ACCESSORY	:	SUS WEATHER COVER, SHUTTER	

8/20/

V - 4 WELDING ROOM (GROUND FLOOR)

MACHINE NO PF-5	(=OF-3 x 1 ea) ✓
TYPE OF VENTILATOR	: PROPELLER x 1 ea
AIR FLOW RATE	: 550 m ³ /Hr 250 ⁺ x 5 ^{mm} A ⁸
FAN MOTOR	: 0.025 KW or W
POWER	: 1φ 220v / 3φ 380v (50/60 Hz)
SIZE	: 370 x 370 x 214 (mm)
ACCESSORY	: SUS WEATHER COVER, SHUTTER

V - 5. TOOL & SPARE PARTS STORAGE ROOM (GROUND FLOOR)

MACHINE NO PF-4	
TYPE OF VENTILATOR	: PROPELLER x 1 ea
AIR FLOW RATE	: 840 m ³ /Hr 300 ⁺ x 5 ^{mm} A ⁸
FAN MOTOR	: 0.050 KW or W
POWER	: 1φ 220v / 3φ 380v (50/60 Hz)
SIZE	: 420 x 420 x 247 (mm)
ACCESSORY	: SUS WEATHER COVER, SHUTTER

V - 6. LAVATORY (GROUND FLOOR)

MACHINE NO VF-4	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 460 m ³ /Hr x 6 ^{mm} A ⁸
FAN MOTOR	: 3W or 6Z W
POWER	: 1φ 220v / 3φ 460v (50/60 Hz)
SIZE	: 345 x 345 x 243 ^N (mm)
ACCESSORY	: 150 ⁺ VENT CAP

1049

V - 7

LAVATORY (MALE) (FIRST, SECOND FLOOR)

MACHINE NO VF - 2	
TYPE OF VENTILATOR	: AXIAL FAN x 2 ea
AIR FLOW RATE	: 680 m ³ /Hr x 8 mm AB
FAN MOTOR	: 30 or 40 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 375 ⁺ x (224 ⁺) x 320 ^L (mm)
ACCESSORY	:

V - 8

LAVATORY (MALE) (THIRD FLOOR)

MACHINE NO VF - 1	
TYPE OF VENTILATOR	: AXIAL FAN x 1 ea
AIR FLOW RATE	: 750 m ³ /Hr x 8 mm AB
FAN MOTOR	: 30 or 40 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 375 ⁺ x (224 ⁺) x 320 ^L (mm)
ACCESSORY	:

V - 9

BATTERY ROOM (FIRST FLOOR)

MACHINE NO VF - 3	(OF - 4 x 1 ea)
TYPE OF VENTILATOR	: AXIAL FAN x 1 ea
AIR FLOW RATE	: 610 m ³ /Hr x 8 mm AB
FAN MOTOR	: KW or 40 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 375 ⁺ x (224 ⁺) x 320 ^L (mm)
ACCESSORY	:

V - 10 LAVATORY (FEMALE) (FIRST, SECOND FLOOR)

MACHINE NO VF-6	
TYPE OF VENTILATOR	: CEILING x 2 ^{ea}
AIR FLOW RATE	: 230 m ³ /Hr x 7 mm ^{As}
FAN MOTOR	: 35 or 35 w
POWER	: 1ø 220v / 3ø 460v (50/ 60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

V - 11 LAVATORY (FEMALE) (THIRD FLOOR)

MACHINE NO VF-5	
TYPE OF VENTILATOR	: CEILING x 1 ^{ea}
AIR FLOW RATE	: 300 m ³ /Hr x 8 mm ^{As}
FAN MOTOR	: 35 or 46 w
POWER	: 1ø 220v / 3ø 460v (50/ 60 Hz)
SIZE	: 345 x 345 x 243 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

V - 12 LAVATORY (FIRST, SECOND FLOOR) (F18b) <S11b,a>

MACHINE NO VF-9	
TYPE OF VENTILATOR	: CEILING x 3 ^{ea}
AIR FLOW RATE	: 170 m ³ /Hr x 8 mm ^{As}
FAN MOTOR	: 35 or 35 w
POWER	: 1ø 220v / 3ø 460v (50/ 60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

V - 13

SHOWER BOOTH (FIRST, SECOND FLOOR) (F14a, b, S12a, b)

MACHINE NO VF - 11	
TYPE OF VENTILATOR	: CEILING x 4 ^{ea}
AIR FLOW RATE	: 80 m ³ /Hr x 8 ^{mm} /s
FAN MOTOR	: KW or 13 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 303 x 303 x 204 ^H (mm)
ACCESSORY	: 100 ^ø VENT CAP

V - 14

DRESSING ROOM (FIRST FLOOR)

MACHINE NO VF - 8	
TYPE OF VENTILATOR	: CEILING x 1 ^{ea}
AIR FLOW RATE	: 180 m ³ /Hr x 8 ^{mm} /s
FAN MOTOR	: KW or 35 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 ^ø VENT CAP

V - 15.

LAVATORY (FIRST FLOOR) (F18a)

MACHINE NO VF - 11	
TYPE OF VENTILATOR	: CEILING x 1 ^{ea}
AIR FLOW RATE	: 80 m ³ /Hr x 8 ^{mm} /s
FAN MOTOR	: KW or 13 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 303 x 303 x 204 ^H (mm)
ACCESSORY	: 100 ^ø VENT CAP

V - 16

KITCHENETTE

MACHINE NO VF-10	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 150 m ³ /Hr x 6 mmHg
FAN MOTOR	: 25 or 25 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 303 x 303 x 204H (mm)
ACCESSORY	: 100 ^ø VENT CAP

V - 17

LAVATORY (FIRST FLOOR) <F17>

MACHINE NO VF-8	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 180 m ³ /Hr x 5 mmHg
FAN MOTOR	: 25 or 35 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 308 x 308 x 243H (mm)
ACCESSORY	: 150 ^ø VENT CAP

V - 18

PANTRY (FIRST FLOOR)

MACHINE NO PF-6	
TYPE OF VENTILATOR	: PROPELLER x 1 ea
AIR FLOW RATE	: 250 m ³ /Hr 200 ^ø
FAN MOTOR	: 25 or 18 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 280 x 280 x 152 ^D (mm)
ACCESSORY	: SUS. WEATHER COVER, SHUTTER

V - 19

KITCHEN

MACHINE NO	RF-1	
TYPE OF VENTILATOR	:	RANGE HOOD FAN x 1 ea
AIR FLOW RATE	:	700 m ³ /Hr x 3 mm ³ A ⁸
FAN MOTOR	:	KW or 70 W
POWER	:	1 ϕ 220v / 3ϕ 460v (50/60 Hz)
SIZE	:	600 x x 580 ^H (mm)
ACCESSORY	:	SUS WEATHER COVER

V - 20

KITCHEN

MACHINE NO	VF-7	
TYPE OF VENTILATOR	:	CEILING x 1 ea
AIR FLOW RATE	:	200 m ³ /Hr x 8 mm ³ A ⁸
FAN MOTOR	:	KW or 35 W
POWER	:	1 ϕ 220v / 3ϕ 460v (50/60 Hz)
SIZE	:	308 x 308 x 243 ^H (mm)
ACCESSORY	:	150 ⁺ VENT CAP

V - 21

ELEVATOR MACHINE ROOM

MACHINE NO	PF-3	
TYPE OF VENTILATOR	:	PROPELLER x 1 ea
AIR FLOW RATE	:	1800 m ³ /Hr ϕ 400 x 5 mm ³ A ⁸
FAN MOTOR	:	0.1 KW or W
POWER	:	1ϕ 220v / 3 ϕ 380v (50/60 Hz)
SIZE	:	520 x 520 x 268 (mm)
ACCESSORY	:	SUS WEATHER COVER, SHUTTER

V - 22

RETURN FAN (G. FLOOR AIR CONDITIONING MACHINE RM.)

MACHINE NO	RAF - 1	SS # 7	
TYPE OF VENTILATOR	:	CENTRIFUGAL MULTI-BANE	x 1 ea
AIR FLOW RATE	:	54.520 m ³ /Hr x 25 m ² /s	
FAN MOTOR	:	15 KW or	w
POWER	:	14 220v / 3φ 380 v (50/60 Hz)	
SIZE	:	2500 ^L x 900 ^W x 2070 ^H	(mm)
ACCESSORY	:		

V -

MACHINE NO	:		
TYPE OF VENTILATOR	:		x ea
AIR FLOW RATE	:	m ³ /Hr	
FAN MOTOR	:	KW or	w
POWER	:	1φ 220v / 3φ	v (50/60 Hz)
SIZE	:	x	x (mm)
ACCESSORY	:		

V -

MACHINE NO	:		
TYPE OF VENTILATOR	:		x ea
AIR FLOW RATE	:	m ³ /Hr	
FAN MOTOR	:	KW or	w
POWER	:	1φ 220v / 3φ	v (50/60 Hz)
SIZE	:	x	x (mm)
ACCESSORY	:		

1055

CV-1 土木設計条件

目 次

1. 設計条件	1
2. 設計荷重	2
3. 水路水理計算	4
4. 許容応力	6
5. 適用基準	9

CV-1 土木設計条件

1. 設計条件

1) 潮 位

- a) The Highest High Water Level (The Highest Astronomical Tide is adopted as design H.H.W.L)

$$\text{H.H.W.L} = \text{E.L} + 3.23 \text{ m}$$

- b) Mean Sea Water Level

$$\text{M.S.L} = \text{E.L} + 1.64 \text{ m}$$

- c) The Lowest Low Water Level (The lowest Astronomical Tide is adopted as design L.L.W.L)

$$\text{L.L.W.L} = \text{E.L} - 0.43 \text{ m}$$

2) 風 荷 重

The design wind loads are indicated in the design concept of architectural/structural section, if necessary.

3) 現地盤高

$$\text{G.L.} = \text{E.L} + 4.80 \text{ m}$$

4) 土質条件

The soil physical values shall be determined at the normal cases as follows.

a) The N - Value

The N - Value shall be adopted from the site boring test.

b) The angle of the internal friction ϕ

In the case of sandy soil, the angle of the internal friction ϕ shall be calculated by the following equation.

$$\phi = 15 + \sqrt{15N} \leq 45^\circ \quad \text{provided that } N > 5$$

2. 設計荷重

1) 鉛直荷重の組合せ

The increment ratio

a) Long term (D.L + L.L)	1.0
b) Short term (D.L + L.L + W.L)	1.25
c) Short term (D.L + S.L)	1.50

Where	D.L :	Dead load
	L.L :	Live load
	W.L :	Wind load
	S.L :	Seismic load

2) 地震時荷重 (S.L.) L

$$F_w = K_h \cdot W$$

Where K_h : Seismic coefficient = 0.1

W : Weight of structure included dead load.

3) 活荷重

a) Truck load

Truck load (T = 20) The gross weight : 20 ton
 A front wheel weight : 2 ton
 A rear wheel weight : 8 ton

b) The impact coefficient (i)

$$i = 0.3$$

4) 粘着力 C

Cohesion C shall be calculated by the following equation.

$$C = \frac{q_u}{2} \quad q_u : \text{the uniaxial compressive stress}$$

q_u can be obtained from Table 1, if N - values can be measured.

Table 1. Relation of the N values vs consistency q_u of cohesive soil

N value	Consistency of cohesive soil	q_u (kg/cm ²)
0 to 1	Very soft	0.25 to below
2 to 4	Soft	0.25 to 0.5
5 to 8	Normal (medium)	0.5 to 1.0
9 to 15	Hard	1.0 to 2.0
16 to 30	Very hard	2.0 to 4.0
30 to above	Consolidated	4.0 to above

3. 水路水理計算

1) 損失水頭總括表

Table 2. Example of the loss in water channel

Equipment	Loss
Intake	① Loss due to inflow curtain. ② Loss due to friction between intake.
Intake Channel	① Loss due to inflow at intake channel ② Loss due to friction of water channel wall ③ Loss due to water channel's cross sectional change (Gradual contractin and gradual expansion) and bend. etc.) ④ Loss due to water channel's accessory machineries and structures.
Screen Pump Pit	① Loss due to inflow at Screen Room ② Loss due to Screens ③ Loss due to inflow at Pump Room ④ Loss due to room wall friction
Discharge Channel	① Loss due to outlet conduit and discharge culvert ② Loss due to the wall friction of channel ③ loss due to water channel's sectional change (gradual contraction, gradual expansion) ④ Loss due to water channel's accessory (machineries and structures)
Outlet	① Loss due to outlet's exit ② Loss due to the friction of water channel wall ③ Loss due to water channel's sectional change (gradual expansion, etc) ④ Loss due to water channel's necessary structures, such as hidden wier, pier, etc.

2) 粗度係数

表-2の粗度計数は、一般の水路水理計算に使用されている値である。

Table 2. The coefficient of the roughness used for water channel

Wall shape	n	Wall shape	n
Welded steel pipe	0.012	Ordinary concrete with shells stuck	0.02
Good concrete surface such as centrifugal force steel reinforced concrete pipe	0.013	Steel plate	0.02
Ordinary concrete such as cast-in-field concrete	0.015	Other especially rough surface	0.03
Concrete block	0.02		

4. 許容応力

1) 鉄筋コンクリートの許容応力

(kg/cm²)

Stresses		Permanent Stresses			
Concretes		Compression	Shear		Bond
			(1)	(2)	
Concrete for (above) C-400	plain bar	130	5.5	24	10
	Deformed bar		(slab) 11		20
Concrete for C-300	Plain bar	100	5	22	9
	Deformed bar		(slab) 10		18
Concrete for C-240	Plain bar	80	4.5	20	8
	Deformed bar		(slab) 9.0		16
Concrete for C-210	Plain bar	70	4.25	19	7.5
	Deformed bar		(slab) 8.5		15
Concrete for C-180	Plain bar	60	4	18	7
	Deformed bar		(slab) 8		14

*Remarks (1):No calculating with diagonal tention bar.

(2):Calculating with diagonal tention bar.

2) 鉄筋の許容応力度

(kg/cm²)

Materials \ Stresses	Permanent stresses	
	Tension	Compression
SD 30	1,800	1,800
SD 35	1,800	2,000
SD 30 for Pile	1,600	1,800

3) 鋼の許容応力度

(kg/cm²)

	Permanent Stresses		
Type of Steel	Tension	Compression	Shear
SS 41 SM 41	1,400	1,400	800

4) 溶接部の許容応力度

(kg/cm²)

Appli- cation	Stresses	Permanent Stresses			
	Welding Positions	Groove Weld			Fillet
	Materials	Tension	Compress	Shear	Shear
	(SS41, SM41)	1,400	1,400	800	800

5) コンクリートのヤング率

a) At the case of the displacement calculation

CX(kg/cm ²)	180	240	270	300
Ec(kg/cm ²)	2.2×10^5	2.5×10^5	2.65×10^5	2.8×10^5

b) At the case of the unit stress calculation

$$E_c = 1.4 \times 10^5 \text{ (kg/cm}^2 \text{)}$$

5. 適用基準

1) 日本土木学会

a) Standards for Calculation of Reinforced Concrete Structures

b) Design Standards for Steel Structures

c) Standards for Structural Design of Building Foundations

2) 日本道路協会

Specifications for Highway Bridges

3) 日本港湾協会

Technical Standards for Port and Harbour Facilities

4) 日本建築学会基準

Standard Specification for Concrete

5) 日本工業規格

CV-2 冷却水路計算要項

目 次

1. 開渠取水路	2
2. ポンプピット	7

1. 開渠取水路

開渠取水路の概要は、図-1, 2に示されている。

断面寸法データの根拠が次のように説明されている。




Fig 1. Typical section of Intake Open Channel




Fig 2. Plan of Intake Open Channel

a. 地盤高 (EL.+4.8m)

The ground level was determined in "Civil Design Condition" (vid.1.3, P1, ENGINEERING SHEET No.EWC-1001), so the site ground shall be leveled at EL.+4.8m.

b. 最高潮位 (EL.+2.78m)

This level was determined in consideration of the water head loss due to Intake Culvert (vid.3.1).a), P11, ENGINEERING SHEET No.EWC-1003) at the highest high sea water level (EL.+3.23m), so the calculation is as follows.

↓
(vid.1.1).a,P1,EWC-1001).

[H.H.W.L.]	(The head loss due to culvert)	
EL.+3.23m	- 0.45m	= <u>EL.+2.78m</u>

c. 最低潮位 (EL. -0.88m)

This level was determined in consideration of the water head loss due to Intake Culvert at the lowest low water level (EL. -0.43m).

↓

(vid.1.1).c,EWC-1001)

The Calculation is as follows.

$$\begin{array}{llll} \text{[L.L.W.L]} & \text{(The head loss due to Intake Culvert)} & & \\ \text{EL. -0.43m} & - & 0.45\text{m} & = \text{EL. -0.88m} \end{array}$$

d. 開渠取水路の床面高さ (EL. -4.0m)

The level of bottom floor was determined in accordance with the bottom floor level of existing Intake Culvert (EL. -1.3feet $\div$ EL. -4.0m) as shown in Fig ?

e. 開渠取水路の巾 (= 3.0m)

The width of Intake Open Channel was determined to limit the water velocity less than $V = 1.0$ m/sec at L.L.W.L.

The calculation is considered for the shells stuck 10cm.


(vid.Fig 4,P10,EWC-1003)

$$V = \frac{Q_1}{A} = \frac{(5.2\text{m}^3)}{(3.0 - 2 \times 0.1) \times (3.12 - 0.1)} = 0.61 \text{ m/sec} < 1.0 \text{ m/sec}$$

f. 貨物用レールと仮設鋼板中心線との距離

The distance was determined to avoid the influence area occurred by the relaxation of the back ground of retaining wall.

Fig 3



The section of the influence area occurred by the relaxation of the back ground is shown in Fig 4.




Fig 4. The influence area of the relaxation of the back ground




Fig 6. Profile of Pump Pit

a. ポンプ室とスクリーン室の内空幅

The internal width of Pump Room was determined by the following relations.

i) by the data from Table 1.

Let the width is B,

$$2.0 D_o \leq B \leq 2.5 D_o$$

$$3.6m \leq B \leq 4.5m$$

Where D_o : the diameter of C.W Pump's bellmouth = 1.8m

ii) by the limit of the approach velocity

The approach velocity to bar screen V_1 is usually controled by the following relation.

The internal width of Screen Room is determined by the approach velocity to bar screen, then the approach velocity V_1 is restricted by the following relation.

$$V_1 \leq \underline{0.375 \text{ m/sec}}$$

↓

(vid. Table 1)

In this design case V_1 is calculated as follows.


$$V_1 = \frac{Q}{A} = \frac{4.75}{4.3 \times 3.02} = 0.37 \text{ m/sec} < 0.375 \text{ m/sec}$$

According to the above mentioned relation, the internal width was dertermined

$$B_1 = 4.5m$$

Table 1. The compared table with the usual and the recommended dimensional data of Pump Pit

No	Items	The usual value	The recommended value	Remarks
1	The diameter of Bellmouth : D_o		$D_o = 1800\text{mm}$	
2	The width of Pump Room : B	$B = 2.0 \sim 2.5 D_o$	$B = 4500\text{mm}$	
3	The distance between Bellmouth and the bottom floor : Y	$B = 0.5 \sim 0.75 D_o$	$Y = 900\text{mm}$	$Y = 0.5 D_o$
4	The distance between the center of Pump and the back wall : Z	$Z = 0.8 \sim 1.0 D_o$	$Z = 1800\text{mm}$	The preventive wall for vortex was designed.
5	The submerged depth: Sc	$Sc \geq 1.5 D_o$	$Sc = 2700\text{mm}$	
6	The approach velocity to Pump and Screen : V_2	$V_2 \leq 0.375\text{m/sec}$		In this design case $V_2 = 0.28\text{ m/sec}$
7	The distance between the Center of Pump and the mound : A	$A \geq 6.0 D_o$	$A \geq 10.8\text{m}$	
8	The height of mound: H_m	$H_m \leq 0.8 D_o$	$H_m \leq 1.44\text{m}$	



The reference drawing

b. ポンプピットの延長

The length of Pump Pit is determined by the site layout plan.
(vid. DWG No WGTS-1002)

c. 最低潮位 (EL. -0.88m)

This water level was the same level as Intake Open Channel.

d. カーテンウォールの下端位置

The lowest side level of curtain wall is calculated as follows.

$$\begin{array}{lcl} \text{[L.L.W.L]} & \text{(the allowance)} & \\ \text{EL. -0.88m} & - \quad 0.52\text{m} & = \quad \underline{\text{EL. -1.40 m}} \end{array}$$

e. スクリーン室の床面高さ

The bottom floor level of Screen Room was determined in accordance with the bottom floor level of Intake Open Channel (vid. Fig 1), accordingly this level was setted up at EL. -4.00m.

f. ポンプ室の床面高さ

The bottom floor level of Pump Room was determined by the height of the back wall of Pump Room, and the height of the back wall of Pump Room H_b was determined by the following relation.

$$H_b = S_c + Y \geq 1.5D_o = 1.5 \times 1.8 + 0.5 \times 1.8 = \underline{3.6\text{m}}$$

accordingly H_b was determined $H_b = 4.0\text{m}$, so the bottom floor level was calculated as below.

$$\begin{array}{lcl} \text{(The lower side level of Pump Room)} & \text{[H}_b\text{]} & \\ \text{EL. -1.20m} & - \quad 4.0\text{m} & = \quad \underline{\text{EL. -5.2m}} \end{array}$$

g. バスクリーンと床面との取付け設定角度

The setting angle of Bar Screen was determined by the reference of "Design for the Civil Structures of Thermal Power Plant and Nuclear Power Plant" published by The Society of Electric Power Civil Technology, Japan. (vid.12-10-3,P435)

h. スクリーン室とポンプ室との床面高さの差

This difference in level H_m was determined by the following relation.
(vid.Item No 8 in Table 1)

$$H_m = 1.2m \leq 0.8D_o = 0.8 \times 1.8m = 1.44m$$

i. 法面の水平長

The horizontal length of the slope A was determined by the following relation to the distance between the vertical center of Pump and mound.
(vid.Item No 8 in Table 1)

$$A = 21.75m \geq 6.00D_o = 10.8m$$

j. ポンプへの接近流速

The approach velocity to Pump V_2 is calculated by the following equation.

$$V_2 = \frac{Q}{A} = \frac{4.5}{4.3 \times 3.8} \approx 0.28 \text{ m/sec} \leq \frac{0.375 \text{ m/sec}}{\downarrow}$$

(vid.Item No 6 in Table 1)

k. 渦巻き防止壁の断面寸法データ

The dimensional data of the protection wall for vortex was determined by the reference data from the mechanical design structure.

CV-3 水路水理計算

目 次


1. 水路水理計算書	2
2. 設計条件	5
3. 損失水頭計算	11
1) 取水路	11
2) 開渠取水路	14
3) ポンプ・ピット	15
4) 放水路	18
5) 放水口	21

1. 水路水理計算結果

水路水理計算は、循環水ポンプと復水器冷却水路の損失水頭により決定される。

水路水理計算結果は、図-1、図-2に表わされている。

Fig 1. The Results of Hydrographic Calculation
(UNIT I)



1080

2. 設計条件

1) 水位

All calculations are executed at the lowest low water level.

L.L.W.L :

E.L. - 0.43 m

2) 粗度係数

a) Ordinary concrete such as cast-in-field concrete

the roughness : $n = 0.015$

b) Ordinary concrete with shells stuck

the roughness : $n = 0.02$

3) 取水構造物の流量計算

The water flow chart of Intake structures are shown in Fig 3.




Fig 3. The water flow chart of Intake structures

取水構造物の流量は、下記の方程式を解くことによって計算される。

$$2Q = Q_1 + Q_2 = 19.0 \text{ m}^3 \quad \text{①}$$

$$Q = Q_2 + Q_3 = 9.5 \text{ m}^3 \quad \text{②}$$

$$Q_3 = Q_1 - Q = Q_1 - 9.5 \text{ m}^3 \quad \text{③}$$

$$h_2 + h_4 = h_1 + h_3 \quad \text{④}$$

provided that $Q_1 \leq 2Q$

$$Q_2, Q_3 \leq Q$$

Where Q_1 : Quantity of culvert tunnel [m³/sec]

Q_2 : Quantity of concrete pipes [m³/sec]


[Three pipes located]

Q_3 : Quantity of Intake Open Channel (at culvert side) [m³/sec]

Q_4 : Quantity of Intake Open Channel (at concrete pipe side) [m³/sec]

a) 取水カルバートの水頭損失計算

typical section of culvert



S : the wet perimeter [m]

A : the area [m²]

R : the hydrographic mean level [m]

Shell deposits 10cm is considered for calculation.

$$S = 4 \times (3.0 - 0.2) = 11.2 \text{ m}$$

$$A = 2.8 \times 2.8 = 7.84 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{7.84}{11.2} = 0.7 \text{ m}$$

i) The head loss due to inflow h_{e1} ,

$$V = \frac{Q_1}{A} = \frac{Q_1}{7.84} = 0.1276 Q_1$$

$$h_{e1} = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{(0.1276 Q_1)^2}{2 \times 9.8} = 0.0004 Q_1^2$$

Where f_e : the coefficient of the inflow loss = 0.5

ii) The head loss due to the wall surface friction h_{f1}

$$h_{f1} = \frac{Q_1^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{Q_1^2 \cdot 0.02^2 \cdot 155}{7.842 \times 0.74^{4/3}} = 0.0016 Q_1^2$$

iii) The head loss due to bend h_{b1}

$$h_{b1} = f_{b1} \cdot \frac{v^2}{2g} = 0.073 \times \frac{(0.1276 Q_1)^2}{2 \times 9.8} = 0.0001 Q_1^2$$


Where f_{b1} : the coefficient of the bend loss = 0.073

Accordingly the head loss due to Intake Culvert is calculated as hereinafter.

$$h_1 = h_{e1} + h_{f1} + h_{b1} = (0.0004 + 0.0016 + 0.0001) Q_1^2 = 0.0021 Q_1^2$$

b) 取水コンクリートパイプの水頭損失

typical section of concrete pipe



Shell deposits 10cm is considered for the calculation.

$$S = \pi \times (1.5 - 2 \times 0.1) = 4.08 \text{ m}$$

$$A = \frac{1}{4} \times \pi \times 1.3^2 = 1.33 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{1.33}{4.08} = 0.326 \text{ m}$$

i) The head loss due to inflow h_{e2}

$$v = \frac{Q_2}{3A} = \frac{Q_2}{1.33 \times 3} = 0.2506 Q_2$$

$$h_{e2} = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{(0.2506 Q_2)^2}{2 \times 9.8} = 0.0016 Q_2^2$$

Where f_e : the coefficient of the inflow loss = 0.5

ii) The head loss due to the wall surface friction h_{f2}

$$h_{f2} = \frac{Q_2^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{(Q_2/3)^2 \cdot 0.02^2 \cdot 200}{1.33^2 \cdot 0.326^{4/3}} = 0.0224 Q_2^2$$

iii) The head loss due to the bend loss h_{b2}


$$h_{b2} = 2 \cdot f_b \cdot \frac{v^2}{2g} = 2 \times 0.073 \times \frac{(0.2506 Q_2)^2}{2 \times 9.8} = 0.0005 Q_2^2$$

Accordingly the head loss of Intake Pipe Tunnel is calculated as hereinafter.

$$h_2 = h_{e2} + h_{f2} + h_{b2} = 0.0016 Q_2^2 + 0.0224 Q_2^2 + 0.0005 Q_2^2 = 0.0245 Q_2^2 \\ = 0.0245 (19.0 - Q_1)^2$$

c) 開渠取水路の水頭損失 (カルバート側):

the section of Intake Open Channel



Shall deposits 10cm are considered for the calculation

$$S = 2 \times 3.47 + (3 - 2 \times 0.1) = 9.74 \text{ m}$$

$$A = 2.8 \times 3.47 = 9.72 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{9.72}{9.74} = 1.00 \text{ m}$$

The head loss h_3 is the same as the head loss due to the wall surface friction.

$$h_3 = \frac{Q_2^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{Q_3^2 \times 0.02^2 \times 66}{9.72^2 \times 1.0^{4/3}} = 0.0003 Q_3^2$$

d) 開渠取水路の水頭損失 (コンクリートパイプ側)

The section and the process of calculation are the same as C), therefore

$$h_4 = \frac{Q_2^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{Q_2^2 \times 0.02^2 \times 32}{9.72^2 \times 1.0^{4/3}} = 0.0001 Q_2^2 = 0.0001 (19.0 - Q_1)^2$$

Above calculated the head losses are substituted into the previous equation ④ here.

$$(0.0245 + 0.0001) (19.0 - Q_1)^2 = 0.0021 Q_1^2 + 0.0003 (Q_1 - 9.5)^2$$

$$0.0246(Q_1^2 - 38Q_1 + 361) = 0.0024Q_1^2 - 0.0057Q_1 + 0.0271$$

$$0.0222 Q_1^2 - 0.9291 Q_1 + 8.8535 = 0$$

 Q_1 is determined by solving the above equation.

$$\underline{Q_1 = 14.7 \text{ m}^3/\text{sec}}$$

Accordingly other quantities are calculated as hereinafter.

$$\begin{aligned} Q_2 &= 19.0 - Q_1 \\ &= 19.0 - 14.7 \\ &= \underline{4.3 \text{ m}^3/\text{sec}} \end{aligned}$$

$$\begin{aligned} Q_3 &= 9.5 - Q_2 \\ &= 9.5 - 4.3 \\ &= \underline{5.2 \text{ m}^3/\text{sec}} \end{aligned}$$

3. 損失水頭の計算

1) 既設取水トンネル





Fig 4. The water flow diagram

a) 既設カルバートの損失水頭

The sectional dimensions S, A and R are calculated as hereinafter

Shell deposits 10cm is considered for calculations.

typical section of Culvert



S : the wet perimeter

$$S = 4 \times (3.0 - 0.2) = 11.2 \text{ m}$$

A : the area

$$A = 2.8 \times 2.8 = 7.84 \text{ m}^2$$

R : the hydrographic mean depth

$$R = \frac{A}{S} = \frac{7.84}{11.2} = 0.7 \text{ m}$$

i) The head loss due to inflow h_e

$$V = \frac{Q}{A} = \frac{14.7}{7.84} = 1.88 \text{ m/sec}$$

The head loss h_e

$$h_e = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{1.88^2}{2 \times 9.8} = 0.09 \text{ m}$$

Where f_e : the coefficient of the inflow loss = 0.5

ii) The head loss due to the wall surface friction h_f

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{14.7^2 \times 0.02^2 \times 155}{7.84^2 \times 0.7^{4/3}} = \underline{0.351 \text{ m}}$$

iii) The head loss due to bend h_{be}

$$h_{be} = f_{be} \cdot \frac{v^2}{2g} = 0.073 \times \frac{1.88^2}{2 \times 9.8} = \underline{0.013 \text{ m}}$$

Where f_b : the coefficient of the bend loss = 0.073
(the angle of bend = 30°)


Accordingly calculating culvert tunnel's head loss h_1

$$h_1 = h_e + h_f + h_{be} = 0.09 + 0.351 + 0.013 = \underline{0.454 \text{ m}}$$

b) 既設コンクリートパイプの損失水頭 h_2

The sectional dimensions S, A and R are calculated as hereinafter.

the section of concrete pipe



Shell deposits 10cm is considered for calculation.

$$S = \pi \times (1.5 - 2 \times 0.1) = 4.08 \text{ m}$$

$$A = \frac{1}{4} \times \pi \times 1.3^2 = 1.33 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{1.33}{4.08} = 0.326 \text{ m}$$

i) The head loss due to inflow h_e

$$v = \frac{Q}{A} = \frac{1/3 \times 4.3}{1.33} = 1.08 \text{ m/sec}$$

$$h_e = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{1.08^2}{2 \times 9.8} = \underline{0.030 \text{ m}}$$

1007

ii) The head loss due to the wall surface friction h_f

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{1.43^2 \times 0.02^2 \times 200}{1.33^2 \times 0.326^{4/3}} = \underline{0.412 \text{ m}}$$

iii) The head loss due to bend h_{be}

$$h_{be} = f_{be} \cdot \frac{v^2}{2g} = 0.073 \times \frac{1.08^2}{2 \times 9.8} = \underline{0.004 \text{ m}}$$


Accordingly calculating the head loss h_2

$$h_2 = h_e + h_f + h_{be} = 0.03 + 0.412 + 0.004 = \underline{0.446 \text{ m}}$$

2) 開渠取水路

a) 損失水頭 h_3

the section of Intake Open Channel



Shell deposits 10 cm is considered for the calculations.

$$S = 2 \times 3.02 + (3 - 2 \times 0.1) = 8.84 \text{ m}$$

$$A = 2.8 \times 3.02 = 8.46 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{8.46}{8.84} = 0.96 \text{ m}$$

The head loss h_3 is the same as the head loss due to the wall surface friction.

$$h_3 = \frac{Q_3^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{5.2^2 \times 0.02^2 \times 66}{8.46^2 \times 0.96^{4/3}} = 0.010 \text{ m}$$


b) 損失水頭 h_4

The process of calculation is the same as a).

$$h_4 = \frac{Q_3^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.3^2 \times 0.02^2 \times 32}{8.46^2 \times 0.96^{4/3}} = 0.003 \text{ m}$$

3) ポンプ・ピット

- a) カーテンウォールによる損失水頭 h_c
the section of the entrance



Shell deposits 10cm are considered for the calculation.

$$A = 4.3 \times 2.4 = 10.32 \text{ m}^2$$

$$Q = \frac{1}{2} \times 9.5 = 4.75 \text{ m}^3/\text{sec}$$

$$V = \frac{Q}{A} = \frac{4.75}{10.32} = 0.46 \text{ m/sec}$$


$$h_c = \frac{Q^2}{C^2 \cdot A^2 \cdot 2g} - \frac{V^2}{2g} = \frac{4.75^2}{0.5^2 \times 10.32^2 \times 2 \times 9.8} - \frac{0.46^2}{2 \times 9.8}$$

$$= 0.03 \text{ m}$$

where

C : the inflow coefficient = 0.5

- b) 壁面摩擦による損失水頭 h_f
the section of Screen Room



Shell deposits 10cm are considered for the calculation.


$$A = 4.3 \times 3.02 = 12.99 \text{ m}^2$$

$$S = 2 \times 3.02 + 4.3 = 10.34 \text{ m}$$

$$R = \frac{A}{S} = \frac{12.99}{10.34} = 1.26 \text{ m}$$

$$h_{f1} = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.75^2 \times 0.02^2 \times 13}{12.99^2 \times 1.26^{4/3}} = 0.0005 \text{ m}$$

the mean section of Connected Culvert



Shell deposits 10cm are considered for the calculation.

$$A = 4.3 \times 3.2 = 14.72 \text{ m}^2$$

$$S = 2 \times (3.2 + 4.6) = 15.6 \text{ m}$$

$$R = \frac{A}{S} = \frac{14.72}{15.6} = 0.94 \text{ m}$$

$$h_{f2} = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.75^2 \times 0.02^2 \times 23}{14.72^2 \times 0.94^{4/3}} = 0.001 \text{ m}$$

Accordingly h_f is calculated as follows.

$$h_f = h_{f1} + h_{f2} = 0.0005 + 0.001 = 0.0015$$

c) バー・スクリーンによる損失水頭 h_{ba}

The approach velocity to bar screen V_a

$$V_a = \frac{Q}{A} = \frac{4.75}{12.99} = 0.37 \text{ m/sec} < 0.40 \text{ m/sec}$$

Therefore the head loss h_{ba} is assumed to be 0.03 m.

(The above value 0.03 m/sec is regulated by U.S Bureau of Reclamation.)

d) トラベリング・スクリーンによる損失水頭 h_{tr}


According to Fig 5, the head loss h_{tr} is assumed to be 0.10 m for the cleanliness factor 60% of screen.

Therefore the head loss due to Pump Pit h_p is calculated as follows.

$$h_p = h_c + h_f + h_{ba} + h_{tr} = 0.03 + 0.0015 + 0.03 + 0.1 = 0.162 \text{ m}$$

Fig. 6 Travelling Screen

Pass per centage of sea water
and the head loss.



Note: 100% of pass per centage of sea water means the most clean state of screen; where has no dirt.

7/4

4) 放水路 (カルバート・トンネル)

放水カルバートの損失水頭は、復水器の放水鉄管路の損失水頭を除いて、下記のよう
に計算される。





Fig 6. Plan of Discharge Tunnels

a) 放水路 (Unit I)

the section of discharge tunnel



$$S = 4 \times 2.2 = 8.8 \text{ m}$$

$$A = 2.2 \times 2.2 = 4.84 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{4.84}{8.8} = 0.55 \text{ m}$$

$$V = \frac{9.5}{4.84} = 1.96 \text{ m/sec}$$

i) The head loss due to the water surface friction h_f

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{9.5^2 \times 0.015^2 \times 440}{4.84^2 \times 0.55^{4/3}} = \underline{0.846 \text{ m}}$$

ii) The head loss due to double curves of the same type h_{cu}

$$\begin{aligned} h_{cu} &= 2 \times \left[\left(0.131 + 0.1632 \left(\frac{D}{\rho_1} \right)^{3.5} \right) \left(\frac{90^\circ}{90^\circ} \right) \right. \\ &\quad \left. + \left(\left(0.131 + 0.1632 \left(\frac{D}{\rho_2} \right)^{3.5} \right) \left(\frac{90^\circ}{90^\circ} \right) \right) \right] \cdot \frac{V^2}{2g} \\ &= 2 \times \left[\left(0.131 + 0.1632 \left(\frac{2.48}{8} \right)^{3.5} \right) \left(\frac{90^\circ}{90^\circ} \right) \right. \\ &\quad \left. + \left(\left(0.131 + 0.1632 \left(\frac{2.48}{10.6} \right)^{3.5} \right) \left(\frac{90^\circ}{90^\circ} \right) \right) \right] \times \frac{1.96^2}{2 \times 9.8} \\ &= \underline{0.104 \text{ m}} \end{aligned}$$

Where ρ : the radius of curvature $\rho_1 = 8 \text{ m}$ $\rho_2 = 10.6 \text{ m}$
 D : the diameter of culvert

$$D = \sqrt{\frac{4.84 \times 4}{\pi}} = 2.48 \text{ m}$$

Accordingly the head loss due to discharge tunnel for unit I h_{c1} is calculated as hereinafter.

$$h_{c1} = h_f + h_{cu} = 0.846 + 0.104 = \underline{0.950 \text{ m}}$$

b) 放水路 (Unit II)

The section of culvert and the process of calculations are the same as culvert I.

i) The head loss due to the water surface friction h_f

$$h_f = \frac{9.5^2 \times 0.015^2 \times 500}{4.84^2 \times 0.55^{4/3}} = \underline{0.962 \text{ m}}$$

ii) The head loss due to curve h'_{cu}

h'_{cu} is calculated as hereinafter.

$$\begin{aligned} h'_{cu} &= \left[3 \times \left\{ 0.131 + 0.1632 \times \left(\frac{2.48}{8} \right)^{3.5} \times \left(\frac{90^\circ}{90^\circ} \right) \right. \right. \\ &\quad \left. \left. + \left\{ 0.131 + 0.1632 \times \left(\frac{2.48}{10.6} \right)^{3.5} \times \left(\frac{90^\circ}{90^\circ} \right) \right\} \times \frac{1.96^2}{2 \times 9.8} \right. \right] \\ &= \underline{0.104 \text{ m}} \end{aligned}$$

Accordingly the head loss due to culvert II h_{c2} is calculated as hereinafter.

$$h_{c2} = h_f + h_{cu} = 0.962 + 0.104 = \underline{1.066 \text{ m}}$$

5) アウトレット





Fig 7. Plan of outlet

Both outlets of unit I and unit II are the same structures, so the head loss calculation is all the same.

a) The head loss due to outlet h_o (per one culvert box)

typical section of outlet (one unit)



$$S = 4 \times 2.2 = 8.8 \text{ m (per one box)}$$

$$A = 2.2 \times 2.2 = 4.84 \text{ m}^2 \text{ (per one box)}$$

$$R = \frac{A}{S} = \frac{4.84}{8.8} = 0.55 \text{ m (per one box)}$$

$$V = \frac{Q}{A} = \frac{1/2 \times 9.5}{4.84} = 0.98 \text{ m/sec (per one box)}$$

i) The head loss due to the water surface friction h_f

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.75^2 \times 0.015^2 \times 40}{4.84^2 \times 0.55^{4/3}} = 0.019 \text{ m}$$

ii) The head loss due to the gradual expansion h_g

The entrance area of outlet A_1 (one unit)

$$A_1 = 2.2 \times 2.2 = 4.84 \text{ m}^2$$

The exit area of outlet A_2 (one unit)

$$A_2 = 4 \times 2.2 \times 2.2 = 19.36 \text{ m}^2$$

$$V_1 = \frac{Q_1}{A_1} = \frac{9.5}{4.84} = 1.96 \text{ m/sec}$$

$$V_2 = \frac{9.5}{A_2} = \frac{9.5}{19.36} = 0.49 \text{ m/sec}$$

$$h_g = f_g \cdot f_s \cdot \frac{(V_1 - V_2)^2}{2g} = 0.7 \times 0.563 \times \frac{(1.96 - 0.49)^2}{2 \times 9.8} = 0.043 \text{ m}$$

Where f_g : the coefficient of the gradual expansion loss = 0.7

f_s : the coefficient of the sudden expansion loss

$$f_s = \left(1 - \frac{A_1}{A_2}\right)^2 = \left(1 - \frac{4.84}{19.36}\right)^2 = 0.563$$

Accordingly the head loss due to outlet h_o is calculated as hereinafter.

$$h_o = h_f + h_g = 0.019 + 0.043 = 0.062 \text{ m}$$

CV-4 取水路開渠の構造設計

目 次

1. 土質条件	2
2. 構造設計の概要	4
3. 安定計算	5
4. 設計ケース	11
5. 構造計算	12

1. 開渠取水路の構造計算

1.1 土質条件

施工区域周辺のボーリングデータは、図-1の如くである。

尚、基礎地盤上のN値は次の式によって計算される。

$$N = \frac{(10+12) \times 2.0 + (12+11) \times 2.0 + (11+13) \times 2.0 + (13+6) \times 2.0 + (6+9) \times 1.54}{2 \times 9.54}$$

$$\approx 10$$

上の計算により、内部摩擦角は次式によって計算される。

$$\phi = (\sqrt{15N} + 15)^\circ = (\sqrt{15 \times 10} + 15)^\circ \approx 27^\circ$$

the bulk density of soil above the ground water γ : $\gamma = 1.9 \text{ t/m}^3$

the bulk density of soil above the ground water γ' : $\gamma' = 1.0 \text{ t/m}^3$


他の基礎条件データは、『一般土木設計条件』に記述されている。

(vid.No EW -1001)

WEST WHARF THERMAL
SITE: POWER STATION,
KARACHI.

CLIENT: KARACHI ELECTRIC SUPPLY CORPORATION.

BORE CHART OF BORING No.4



Remarks: GROUNDWATER TABLE AT 1.00 METER.

Date :- 27/12/87.

Fig 1. Soil column diagram

1.2 構造設計の概要

開渠取水路の構造は、図-2に示されている。

この構造は、渠を除いて剛構造として考えられる。




Fig.2 Typical section of Intake Open Channel

The structural design calculation is executed at the lowest low water level.
(EL - 0.88 m) (considered for the water head loss due to Intake Tunnel).

↓

(vid.1.c,P4,Na EWC-1004)

1.3 安定計算

1) 鉛直力 (単位奥行き長さ 1 m 当り)

a) Base slab

$$W_{c1} = 5.2 \times 1.0 \times 2.45 = 12.7 \text{ t}$$

b) Side wall (at one side)

$$W_{c2} = \{ 0.7 \times 0.7 + \frac{1}{2} \times (0.54 + 1.0) \times 8.3 + \frac{1}{2} \times 0.3 \times 0.3 \} \times 2.45$$

$$= 17.0 \text{ t}$$

c) Beam

$$W_{c3} = 3.0 \times 0.6 \times 0.45 \times 2.45 \div 5.0 = 0.4 \text{ t}$$

d) Soil weight W_s (at one side)

$$W_s = \{ 0.2 \times 0.5 + \frac{1}{2} \times (0.56 + 0.1) \times 8.3 \} \times 1.9 = 5.4 \text{ t}$$

e) Water weight

Water weight W_w is calculated at the highest high water level (EL + 2.78 m)
(considered for the water head loss due to Intake Tunnel.)

↓

(vid.1.b,P3, No EWC-1004)

$$W_w = (6.78 \times 3.0 - 0.3 \times 0.3) \times 1.0 = 20.3 \text{ t}$$

f) Buoyancy

Buoyancy U_b is working to the portion of concrete structure under H.H.W.L, so U_b is calculated as follows.

$$U_b = \{ 5.2 \times 1.0 + 0.3 \times 0.3 + (0.59 + 1.0) \times 6.78 \} \times 1.0$$

$$= 16.1 \text{ t}$$

According to the above calculation, the summarized vertical forces are shown in Table 1.

Table 1. Summarized table of vertical forces (per 1 m unit length)

Species	Vertical force	Remarks
W_{c1}	12.7 t	Base slab
W_{c2}	34.6 t	Side wall
W_{c3}	0.4 t	Connected beam
W_s	11.0 t	Soil weight
W_w	20.3 t	Water weight
U_b	- 16.1 t	Buoyancy
TOTAL	$V = 62.9$ t	

2) 地盤反力 q_1

$$q_1 = \frac{V}{B \cdot L} \cdot \left(1 \pm \frac{6e}{B} \right)$$

Where e : the eccentric distance
 $e = 0$

$$= \frac{62.9}{5.2 \times 1.0}$$

$$= 12.1 \text{ t/m}^2$$

1105

3) 支持力の検討

The ultimate bearing capacity is calculated by the following equation in consideration of the unbalanced inclination.

$$q_u = \alpha K C N_c + K q N_q + \frac{1}{2} \gamma_1 \beta B' N_r$$

Where C : soil cohesion = 0 t/m²

q : the surcharge load

$$q = 1.9 \times 1.0 + 1.0 \times 8.8 = 10.7 \text{ t/m}^2$$

A' : the effective load area (m²)

$$A' = 5.2 \times 1.0 = 5.2 \text{ m}^2$$

γ_1 : the bulk density of the bearing soil (t/m³)

$$\gamma_1 = 1.0 \text{ t/m}^3$$

(γ_1 is the bulk density under the ground water.)

B' : the effective width considered for the eccentric distance.

$$B' = B - 2e_b = 5.2 - 2 \times 0 = 5.2 \text{ m}$$

where B : the basic width

C_b : the eccentric distance

α, β : the coefficient of basic form $\alpha = \beta = 1.0$

K : the extra coefficient for the embedded effect $K = 1.0$

N_c, N_q, N_r : the bearing coefficients considered for the load inclination, and these coefficients are adopted from the following graphs.

$$N_c = 25 \text{ (from Fig 3.)}$$

$$N_q = 14 \text{ (from Fig 4.)}$$

$$N_r = 9 \text{ (from Fig 5.)}$$




Fig.3 Graph of the bearing coefficient N_c

where $\tan \theta : \tan \theta = \frac{H}{V} = 0$

V : Vertical Force at the foundation $V = 60 \text{ t}$

H : Horizontal Force at the foundation $H = 0 \text{ t}$

because horizontal forces are equilibrated at both sides.

ϕ : The angle of the internal friction

$\phi = 27^\circ$





Fig.4 Graph of the bearing coefficient N_q

Fig.5 Graph of the bearing coefficient N_r

Accordingly the ultimate bearing capacity q_u is calculated as below.

$$q_u = 1.0 \times 10.7 \times 14 + \frac{1}{2} \times 1.0 \times 1.0 \times 5.2 \times 9 = 173 \text{ t}$$

4) 許容支持力 q_a

The allowable bearing capacity is calculated as below.

$$q_a = \frac{1}{F_s} \cdot q_u = \frac{1}{3} \times 173 \doteq 57 \text{ t/m}^2 > q_1 = 11.5 \text{ t/m}^2$$

Where F_s : the factor of safety $F_s = 3$

Therefore the spread foundation is adopted for the foundation of Intake Open Channel.

5) 浮上りの検討

浮上りの検討は、常時（水位は、L.L.W.L）及び施工時（内水は空虚）にて行なわれ、その計算は次のようになる。

a) Total vertical force

i) at normal

$$V_1 = 12.7 + 34.6 + 0.4 + 11.0 + (3.12 \times 3.0 - 0.3 \times 0.3) \times 1.0 = 68.0 \text{ t}$$

ii) at construction

$$V_2 = 12.7 + 34.6 + 0.4 + 11.0 = 58.7 \text{ t}$$

b) Up lift U

Up lift U is calculated as below.

$$U = \gamma_w \cdot h_w \cdot A = 1.0 \times 8.8 \times 5.2 \times 1.0 = 45.8 \text{ t}$$

c) Checking on the safety factor of floating F_1

The safety factor of floating F_1 is checked by the following two cases.

i) at normal

$$F_{11} = \frac{V_1}{U} = \frac{68.0}{45.8} = 1.48 > 1.1 \text{ O.K.}$$

ii) at construction

$$F_{12} = \frac{V_2}{U} = \frac{58.7}{45.8} = 1.28 > 1.0 \text{ O.K.}$$

1.4 設計ケース

次の3ケースが構造設計計算として考えられる。

Table 2. Summary of design cases

CASE	1	2	3
CONDITION	at Normal	at Earthquake	at Construction
Earthquake	None	Considered	None
Water Content	L.L.W.L	L.L.W.L	Empty
Self weight	Considered	Considered	Considered
The surcharge load	Considered	Considered	Considered
The increment ratio of the allowable stress	1.0	1.5	1.25

1.5 構造設計

1.5.1 荷重ケース1 (常時、長期)

1) 設計構造物の骨格

Frame of the design structure is shown in Fig 6, and the design structure is considered for the rigid frame structure.




Fig 6. Frame of the design structure

2) 荷重計算 (単位奥行き長さ 1 m 当り)

a) Surcharge load at the ground level q $q = 1.0 \text{ t/m}^2$

b) Self weight

i) Side wall W_{c1} (at one side)

$$W_{c1} = \frac{1}{2} \times (0.5 + 1.0) \times 2.45 = 1.84 \text{ t/m}^2$$

ii) Base slab W_{c2} (at one side)

$$W_{c2} = 1.0 \times 2.45 = 2.45 \text{ t/m}^2$$

iii) Beam

$$W_{c3} = 0.6 \times 0.45 \times 2.45 \div 5.0 = 0.13 \text{ t/m}^2$$

c) The earth pressure and the water pressure

i) the earth pressures

$$P_0 = k \cdot q = 0.5 \times 1.0 = 0.5 \text{ t/m}^2$$

$$P_1 = k(\gamma h_1 + q) = 0.5 \times (1.9 \times 1.0 + 1.0) = 1.45 \text{ t/m}^2$$

$$P_2 = 1.45 + k \cdot \gamma \cdot h_2 = 1.45 + 0.5 \times 1.0 \times 8.3 = 5.60 \text{ t/m}^2$$

ii) the water pressure (outside)

$$P_{w0} = \gamma_w \cdot h_{w0} = 1.0 \times 8.3 = 8.3 \text{ t/m}^2$$

iii) the water pressure (inside)

$$P_{wi} = \gamma_w \cdot h_{wi} = 1.0 \times 3.12 = 3.12 \text{ t/m}^2$$

iv) up lift

$$P_u = \gamma_w \cdot H_w = 1.0 \times 8.8 = 8.8 \text{ t/m}^2$$

d) The ground reaction

$$q_r = 11.5 \text{ t/m}^2$$

According to the above calculations, the results of load calculations are shown in Fig 7.




Fig. 7 The results of load calculations

3) 荷重図

The load diagram is shown in Fig 8.




Fig.8 The load diagram

4) 断面諸元に於ける入力データ

The sectional forces are calculated by computer, so input data for the sectional dimensions are indicated in Table 3.

Table 3. Table of the sectional dimensions (per 1 m unit length)

Member's number	Section area A (m^2)	Geometrical moment of inertia I (m^4)	Remarks
(1)	0.53	0.0129	Side wall
(2)	0.68	0.0262	Side wall
(3)	0.90	0.0608	Side wall
(4)	1.0	0.0833	Footing
(5)	0.90	0.0608	Side wall
(6)	0.68	0.0262	Side wall
(7)	0.53	0.0129	Side wall
(8)	0.054	0.0016	beam @ 5.0 m

1.5.2 荷重ケース2 (地震時、短期)

1) 設計構造

Design structure is shown in Fig 9.




Fig. 9 Design structure

2) 荷重計算 (単位奥行き長さ 1m 当り)

a) The ground surface surcharge

$$q = 1.0 \text{ t/m}^2$$

b) Self weight

$$\text{i) side wall} \quad W_{c1} = 1.84 \text{ t/m}^2 \quad (\text{at one side})$$

$$\text{ii) base slab} \quad W_{c2} = 2.45 \text{ t/m}^2 \quad (\text{at one side})$$

$$\text{iii) beam} \quad W_{c3} = 0.13 \text{ t/m}^2$$

$$\text{iv) water weight} \quad W_w = 1.0 \times 3.12 = 3.12 \text{ t/m}^2$$

c) The force of inertia

Design seismic coefficient $k_h = 0.10$, so the force of inertia is calculated as below.

i) side wall (at one side)

$$W_{ch1} = k_h \cdot W_{c1} = 0.1 \times 1.84 = 0.18 \text{ t/m}^2$$

ii) base slab (at one side)

$$W_{ch2} = k_h \cdot W_{c2} = 0.1 \times 2.45 = 0.25 \text{ t/m}^2$$

iii) beam

$$W_{ch3} = k_h \cdot W_{c3} = 0.1 \times 0.13 = 0.01 \text{ t/m}^2$$

d) The seismic earth pressures and the water pressures

i) the seismic earth pressures

The coefficient of seismic active pressure is calculated by the following equations.

$$K_{ea} = \frac{\cos^2 (\phi - \theta_e - \theta)}{\cos \theta_e \cdot \cos^2 \theta \cdot \cos(\theta + \theta_e + \delta)} \left\{ 1 + \sqrt{\frac{\sin(\phi + \delta) \sin(\phi - \delta - \theta_e)}{\cos(\theta + \theta_e + \delta) \cos(\theta - \alpha)}} \right\}^2$$

Where ϕ : the angle of the internal friction = 27°

α : the angle between the ground surface and the horizontal plane
 $\alpha = 0^\circ$

θ : the angle between the back wall surface and the vertical plane

$$\theta = \tan^{-1} \frac{0.5}{8.97} \approx 3^\circ$$

δ : the angle of the wall surface friction between the back wall surface and back-fill $\delta = 0^\circ$

θ_e : the composite angle of earthquake

$$\theta_e = \tan^{-1} k_h = \tan^{-1} 0.1 \approx 5.7^\circ$$

Therefore

$$K_{ea} = \frac{\cos^2 (27^\circ - 5.7^\circ - 3^\circ)}{\cos 5.7^\circ \times \cos^2 3^\circ \times \cos(3^\circ + 5.7^\circ)} \times \left\{ 1 + \sqrt{\frac{\sin 27^\circ \cdot \sin(27^\circ - 5.7^\circ)}{\cos(3^\circ + 5.7^\circ) \cdot \cos 3^\circ}} \right\}^2$$

$$= 0.463$$

The seismic passive earth pressure is determined by balancing the force which is figured out by the inertia forces and the seismic active earth pressures.

Accordingly the seismic earth pressures are calculated as follows.

8/11

ii) the active earth pressures (Horizontal)

(Horizontal)

$$P_{EAH0} = K_{EA} \cdot \cos 3^\circ \cdot q = 0.463 \times 0.999 \times 1.0 = 0.46 \text{ t/m}^2$$

$$P_{EAH1} = 0.463 \times 0.999 \times (1.0 + 1.9 \times 1.0) = 1.34 \text{ t/m}^2$$

$$P_{EAH2} = 0.463 \times 0.999 \times (1.0 + 1.9 \times 1.0 + 1.0 \times 8.3) = 5.18 \text{ t/m}^2$$

(Vertical)

$$P_{EAV0} = K_{EA} \cdot \sin 3^\circ \cdot q = 0.463 \times 0.052 \times 1.0 = 0.02 \text{ t/m}^2$$

$$P_{EAV1} = 0.463 \times 0.052 \times (1.0 + 1.9 \times 1.0) = 0.07 \text{ t/m}^2$$

$$P_{EAV2} = 0.463 \times 0.052 \times (1.0 + 1.9 \times 1.0 + 1.0 \times 8.3) = 0.27 \text{ t/m}^2$$

iii) the passive earth pressures

Total passive pressures are balanced to total horizontal forces, so they are calculated as below.

(Horizontal)

(Vertical)

$$P_{EPH0} = 0.95 \text{ t/m}^2 \quad P_{EPU0} = P_{EPH0} \cdot \tan 3^\circ = 0.95 \times 0.052 = 0.05 \text{ t/m}^2$$

$$P_{EPH1} = 1.70 \text{ t/m}^2 \quad P_{EPU1} = P_{EPH1} \cdot \tan 3^\circ = 1.70 \times 0.052 = 0.09 \text{ t/m}^2$$

$$P_{EPH2} = 5.78 \text{ t/m}^2 \quad P_{EPU2} = P_{EPH2} \cdot \tan 3^\circ = 5.78 \times 0.052 = 0.30 \text{ t/m}^2$$

iv) the static water pressure

The static water pressures are calculated by dividing between inside and outside.

(Inside)

$$P_{wi} = \gamma_w \cdot h_i = 1.0 \times 3.12 = 3.12 \text{ t/m}^2$$

(Outside)

$$P_{wo} = \gamma_w \cdot h_o = 1.0 \times 8.3 = 8.3 \text{ t/m}^2$$

v) the dynamic water pressure

The dynamic water pressure is considered for working to side walls, therefore dynamic water pressure is calculated as below.

$$P_{ew} = \frac{7}{12} \cdot K_h \cdot \gamma_w \cdot b \cdot h^2 = \frac{7}{12} \times 0.1 \times 1.0 \times 1.0 \times 3.12^2 = 0.57 \text{ t}$$

Working point of P_{ew} (h_{ew})

$$h_{ew} = \frac{h}{2} + 0.5 = \frac{3.12}{2} + 0.5 = 2.06 \text{ m}$$

vi) up lift

$$P_u = \gamma_w \cdot H_w = 1.0 \times (8.3 + 0.5) = 8.8 \text{ t/m}^2$$

e) The ground reaction

$$q_r = 11.5 \text{ t/m}^2$$

f) The results of load calculations

The results of load calculations are shown in Fig 10.




Fig.10 The results of load calculations

3) 荷重図

The load diagram is shown in Fig 11.




Fig.11 The load diagram

4) 断面諸元に於ける入力データ 1

a) The sectional dimensions

Table 4. Table of the sectional dimensions (per 1 m unit length)

Member's number	Section Area A (m ²)	Geometrical moment of inertia I (m ⁴)	Remarks
(1)	0.53	0.013	Side wall
(2)	0.68	0.026	Side wall
(3)	0.85	0.051	Side wall
(4)	0.95	0.071	Side wall
(5)	1.00	0.083	Footing
(6)	0.95	0.071	Side wall
(7)	0.85	0.051	Side wall
(8)	0.68	0.026	Side wall
(9)	0.53	0.013	Side wall
(10)	0.054	0.0016	Beam @ 5.0m

1.5.3 荷重ケース3（施工時、短期）

1) 設計構造 structure

Design structure is shown in Fig 12.




Fig 12. Design structure

2) 荷重計算 (単位奥行き長さ 1 m 当り)ngth)

The process and the results of load calculations are the same as Case-1 excluding a calculation of inside water load.

In this design case the inside water pressure and the inside water weight is no considered(= 0).

3) 荷重図

The load diagram is shown in Fig 13.




Fig 13. The load diagram

1125

4) 断面諸元に於ける入力データ

The sectional forces are calculated by computer, so input data for the sectional dimensions are indicated in Table 5.

Table 5. Table of the sectional dimensions (per 1 m unit length)

Member's number	Section area $A \text{ (m}^2\text{)}$	Geometrical moment of inertia $I \text{ (m}^4\text{)}$	Remarks
(1)	0.53	0.0129	Side wall
(2)	0.79	0.0411	Side wall
(3)	1.0	0.0833	Footing
(4)	0.79	0.0411	Side wall
(5)	0.53	0.0129	Side wall
(6)	0.054	0.0016	Beam @ 5.0 m

Case - 1 (at Normal)

1.5.4 電算による計算結果

電算による計算結果は、曲げモーメント、せん断力、軸力であり、それらは後の図に示されている。今、3つの荷重ケースを比較すると、断面力はどのケースともほぼ同じであり、安全設計の観点から、常時の断面力が断面応力の計算に採用される。

INTAKE OPEN CHANNEL CASE-1 (NORMAL, L.L.W.L)

BENDING MOMENT




Fig 14. The bending moment diagram

Case - 2 (at Earthquake)

INTAKE OPEN CHANNEL CASE-1 (NORMAL, L.L.W.L.)

SHEARING FORCE

SHEET 30 OF





Fig 15. The shearing force diagram

1131

1/32

INTAKE OPEN CHANNEL CASE-1 (NORMAL, L.L.W.L)

AXIAL FORCE



1.0 M


(TON)


Fig 16. The axial force diagram

Table 6. Summary of the sectional forces (Normal)

** ELEMENTAL FORCES **

ELEM	J-END	AXIAL	SHEAR	MOMENT	J-END	AXIAL	SHEAR	MOMENT
1	1	2.6000E+01	-1.3504E+01	-2.8329E+00	11	0.7327E-01	-1.3284E+01	1.6349E+00
2	11	8.7327E-01	-1.3284E+01	1.6349E+00	12	1.4867E+00	-1.2959E+01	6.0126E+00
3	12	1.4867E+00	-1.2959E+01	6.0126E+00	2	2.1000E+00	-1.2529E+01	1.0263E+01
4	2	2.1000E+00	-1.2529E+01	1.0263E+01	13	3.8222E+00	-1.0514E+01	2.1170E+01
5	13	3.8222E+00	-1.0514E+01	2.1149E+01	14	5.5445E+00	-7.1860E+00	2.9556E+01
6	14	5.5445E+00	-7.1860E+00	2.9536E+01	15	7.2667E+00	-2.5435E+00	3.4212E+01
7	15	7.2667E+00	-2.5435E+00	3.4191E+01	16	8.9890E+00	3.4132E+00	2.3907E+01
8	16	8.9890E+00	3.4132E+00	3.3887E+01	3	1.0711E+01	1.0684E+01	2.7412E+01
9	3	1.0711E+01	1.0684E+01	2.7392E+01	17	1.2043E+01	1.6984E+01	1.7400E+01
10	17	1.2043E+01	1.6984E+01	1.7392E+01	18	1.3376E+01	2.3618E+01	2.7229E+00
11	18	1.3376E+01	2.3618E+01	2.7189E+00	19	1.4708E+01	3.0586E+01	-1.6879E+01
12	19	1.4708E+01	3.0586E+01	-1.6883E+01	20	1.6040E+01	3.7889E+01	-4.1646E+01
13	20	1.6040E+01	3.7889E+01	-4.1651E+01	4	1.7372E+01	4.5527E+01	-7.1823E+01
14	4	1.7372E+01	4.5527E+01	-7.1823E+01	21	4.5527E+01	-1.7676E+01	-5.2972E+01
15	21	4.5527E+01	-1.7676E+01	-5.2972E+01	22	4.5527E+01	-5.0920E+00	-4.3545E+01
16	22	4.5527E+01	-5.0920E+00	-4.3545E+01	23	4.5527E+01	5.0920E+00	-4.3545E+01
17	23	4.5527E+01	5.0920E+00	-4.3545E+01	24	4.5527E+01	1.7676E+01	-5.2972E+01
18	24	4.5527E+01	1.7676E+01	-5.2972E+01	5	4.5527E+01	2.9460E+01	-7.1827E+01
19	5	1.7372E+01	4.5527E+01	-7.1827E+01	25	1.6040E+01	-3.7889E+01	-4.1655E+01
20	25	1.6040E+01	-3.7889E+01	-4.1655E+01	26	1.4708E+01	-3.0586E+01	-1.6807E+01
21	26	1.4708E+01	-3.0586E+01	-1.6883E+01	27	1.3376E+01	-2.3618E+01	2.7149E+00
22	27	1.3376E+01	-2.3618E+01	2.7189E+00	28	1.2043E+01	-1.6984E+01	1.7392E+01
23	28	1.2043E+01	-1.6984E+01	2.7392E+01	6	1.0711E+01	-1.0684E+01	2.7388E+01
24	6	1.0711E+01	-1.0684E+01	2.7392E+01	29	8.9890E+00	-3.4132E+00	3.3866E+01
25	29	8.9890E+00	-3.4132E+00	3.3807E+01	30	7.2667E+00	2.5435E+00	3.4171E+01
26	30	7.2667E+00	2.5435E+00	3.4191E+01	31	5.5445E+00	7.1860E+00	2.9515E+01
27	31	5.5445E+00	7.1860E+00	2.9536E+01	32	3.8222E+00	1.0514E+01	2.1129E+01
28	32	3.8222E+00	1.0514E+01	2.1149E+01	7	2.1000E+00	1.2529E+01	1.0242E+01
29	7	2.1000E+00	1.2529E+01	1.0263E+01	33	1.4867E+00	1.2959E+01	6.0114E+00
30	33	1.4867E+00	1.2959E+01	6.0126E+00	34	8.7327E-01	1.3284E+01	1.6337E+00
31	34	8.7327E-01	1.3284E+01	1.6349E+00	8	2.6000E-01	1.3504E+01	-2.8329E+00
32	8	2.6000E-01	1.3504E+01	2.8329E+00	35	1.3504E+01	1.5600E-01	2.6665E+00
33	35	1.3504E+01	1.5600E-01	2.6665E+00	36	1.3504E+01	5.2000E-02	2.5833E+00
34	36	1.3504E+01	5.2000E-02	2.5833E+00	37	1.3504E+01	-5.2000E-02	2.5833E+00
35	37	1.3504E+01	-5.2000E-02	2.5833E+00	38	1.3504E+01	-1.5600E-01	2.6665E+00
36	38	1.3504E+01	-1.5600E-01	2.6665E+00	9	1.3504E+01	-2.6000E-01	2.8329E+00






9811

INTAKE OPEN CHANNELCASE-2 (EARTHQUAKE, L. L. W. L.)

AXIAL FORCE



1.0 m

(TON)

Fig 19. The axial force diagram

Table 7. Summary of the sectional forces (Earthquake)

** ELEMENTAL FORCES **

ELEM	I-END	AXIAL	SHEAR	MOMENT	J-END	AXIAL	SHEAR	MOMENT
1	1	5.4210E+01	-1.3579E+01	-3.3665E+00	13	1.4871E+00	-1.3149E+01	3.3263E+00
2	13	1.4871E+00	-1.3149E+01	3.3264E+00	2	2.4321E+00	-1.2699E+01	9.7472E+00
3	2	2.4321E+00	-1.2490E+01	9.7454E+00	14	4.7830E+00	-9.7447E+00	2.2986E+01
4	14	4.7830E+00	-9.7447E+00	2.2948E+01	15	7.1135E+00	-5.0399E+00	3.1825E+01
5	15	7.1135E+00	-5.0399E+00	3.1787E+01	16	9.4872E+00	1.6100E+00	3.4018E+01
6	16	9.4872E+00	1.6100E+00	3.3980E+01	3	1.1833E+01	1.0223E+01	2.7283E+01
7	3	1.1833E+01	1.0223E+01	2.7245E+01	17	1.2623E+01	1.3452E+01	2.2631E+01
8	17	1.2623E+01	1.3452E+01	2.2631E+01	18	1.3407E+01	1.6751E+01	1.6744E+01
9	18	1.3407E+01	1.6751E+01	1.6743E+01	19	1.4191E+01	2.0121E+01	9.5558E+00
10	19	1.4191E+01	2.0121E+01	9.5554E+00	4	1.4975E+01	2.3541E+01	1.0402E+00
11	4	1.4975E+01	2.3541E+01	1.0397E+00	20	1.6010E+01	2.8813E+01	-1.2584E+01
12	20	1.6010E+01	2.8813E+01	-1.2585E+01	21	1.7045E+01	3.3681E+01	-2.8668E+01
13	21	1.7045E+01	3.3681E+01	-2.8670E+01	22	1.8080E+01	3.8137E+01	-4.7308E+01
14	22	1.8080E+01	3.8137E+01	-4.7309E+01	5	1.9115E+01	4.3979E+01	-6.8599E+01
15	5	4.3979E+01	-2.6821E+01	-6.8601E+01	23	4.4229E+01	-1.2091E+01	-4.9145E+01
16	23	4.4229E+01	-1.2091E+01	-4.9145E+01	24	4.4479E+01	2.6390E+00	-4.4419E+01
17	24	4.4479E+01	2.6390E+00	-4.4419E+01	25	4.4729E+01	1.7369E+01	-5.4423E+01
18	25	4.4729E+01	1.7369E+01	-5.4423E+01	6	4.4979E+01	3.2099E+01	-7.9157E+01
19	6	1.8820E+01	-4.6589E+01	-7.9157E+01	26	1.7769E+01	-4.1042E+01	-5.6601E+01
20	26	1.7769E+01	-4.1042E+01	-5.6600E+01	27	1.6719E+01	-3.5689E+01	-3.6851E+01
21	27	1.6719E+01	-3.5689E+01	-3.6850E+01	28	1.5688E+01	-3.0531E+01	-1.9808E+01
22	28	1.5688E+01	-3.0531E+01	-1.9806E+01	7	1.4617E+01	-2.5567E+01	-5.3712E+00
23	7	1.4617E+01	-2.5567E+01	-5.3695E+00	29	1.3822E+01	-2.2489E+01	4.1095E+00
24	29	1.3822E+01	-2.2489E+01	4.1101E+00	30	1.3026E+01	-1.8916E+01	1.2181E+01
25	30	1.3026E+01	-1.8916E+01	1.2102E+01	31	1.2231E+01	-1.5418E+01	1.8874E+01
26	31	1.2231E+01	-1.5418E+01	1.8874E+01	8	1.1435E+01	-1.1996E+01	2.4217E+01
27	8	1.1435E+01	-1.1996E+01	2.4210E+01	32	9.0483E+00	-2.8608E+00	3.2670E+01
28	32	9.0483E+00	-2.8608E+00	3.2710E+01	33	6.6615E+00	4.2323E+00	3.1668E+01
29	33	6.6615E+00	4.2323E+00	3.1708E+01	34	4.2747E+00	9.2838E+00	2.3563E+01
30	34	4.2747E+00	9.2838E+00	2.3602E+01	9	1.8879E+00	1.2294E+01	1.0741E+01
31	9	1.8879E+00	1.2294E+01	1.0780E+01	35	9.3290E+01	1.3050E+01	4.4352E+00
32	35	9.3290E+01	1.3050E+01	4.4368E+00	10	-2.2103E-02	1.3619E+01	-2.2397E+00
33	1	1.3579E+01	5.4210E+01	3.3665E+00	36	1.3599E+01	4.1210E-01	2.8894E+00
34	36	1.3599E+01	5.4210E+01	2.8894E+00	37	1.3599E+01	2.8210E-01	2.5423E+00
35	37	1.3599E+01	2.8210E+01	2.5423E+00	38	1.3609E+01	1.5210E-01	2.3252E+00
36	38	1.3609E+01	1.5210E+01	2.3252E+00	10	1.3619E+01	2.2103E-02	2.2301E+00

SHEET

25

OF

Case - 3 (at Construction)

INTAKE OPEN CHANNEL CASE-3 (CONSTRUCTION, EMPTY)

BENDING MOMENT

SHEET 37 OF





Fig 20. The bending moment diagram

1139

1140


INTAKE OPEN CHANNEL CASE-3 (CONSTRUCTION, EMPTY)

SHEARING FORCE



1.0 m

Fig 21. The shearing force diagram



(NOI)

Fig. 22. The axial force diagram.

1.0
μ

Table 8. Summary of sectional forces (Construction)

** ELEMENTAL FORCES **

ELEM	I-END	AXIAL	SHEAR	MOMENT	J-END	AXIAL	SHEAR	MOMENT
1	1	2.6000E+01	-1.4799E+01	-2.4035E+00	9	1.1800E+00	-1.4430E+01	4.9156E+00
2	9	1.1800E+00	-1.4430E+01	4.9136E+00	2	2.1000E+00	-1.3824E+01	1.1989E+01
3	2	2.1000E+00	-1.3824E+01	1.1987E+01	10	5.9180E+00	-7.5850E+00	3.5540E+01
4	10	5.9180E+00	-7.5850E+00	3.5316E+01	11	9.7360E+00	5.1106E+00	3.9224E+01
5	11	9.7360E+00	5.1106E+00	3.9001E+01	12	1.3554E+01	2.4265E+01	9.8036E+00
6	12	1.3554E+01	2.4265E+01	9.6402E+00	3	1.7372E+01	4.9879E+01	-6.5944E+01
7	3	4.9879E+01	-3.5700E+01	-6.6168E+01	13	4.9879E+01	-1.7850E+01	-3.9393E+01
8	13	4.9879E+01	-1.7850E+01	-3.9393E+01	14	4.9879E+01	3.5283E-13	-3.0468E+01
9	14	4.9879E+01	3.0468E+01	-3.0468E+01	15	4.9879E+01	1.7850E+01	-3.9393E+01
10	15	4.9879E+01	1.7850E+01	-3.9393E+01	4	4.9879E+01	2.5700E+01	-6.6168E+01
11	4	1.7372E+01	-4.9879E+01	-6.6168E+01	16	1.3554E+01	-2.4265E+01	9.8036E+00
12	16	1.3554E+01	-2.4265E+01	9.6402E+00	17	9.7360E+00	-5.1106E+00	3.8778E+01
13	17	9.7360E+00	-5.1106E+00	3.9001E+01	18	5.9180E+00	7.5850E+00	3.5093E+01
14	18	5.9180E+00	7.5850E+00	3.5316E+01	5	2.1000E+00	1.3824E+01	1.1764E+01
15	5	2.1000E+00	1.3824E+01	1.1987E+01	19	1.1800E+00	1.4430E+01	4.9156E+00
16	19	1.1800E+00	1.4430E+01	4.9136E+00	6	2.6000E-01	1.4799E+01	-2.4055E+00
17	1	1.4799E+01	2.6000E-01	2.4035E+00	20	1.4799E+01	1.3000E-01	2.2095E+00
18	20	1.4799E+01	1.3000E-01	2.2085E+00	21	1.4799E+01	4.4520E-14	2.1435E+00
19	21	1.4799E+01	4.4673E-14	2.1435E+00	22	1.4799E+01	-1.3000E-01	2.2085E+00
20	22	1.4799E+01	-1.3000E-01	2.2085E+00	6	1.4799E+01	-2.6000E-01	2.4035E+00