

THE ISLAMIC REPUBLIC OF PAKISTAN

**DETAILED DESIGN STUDY
ON
WEST WHARF
THERMAL POWER PLANT PROJECT**

FINAL REPORT-I

VOLUME 2

JANUARY 1990

JAPAN INTERNATIONAL COOPERATION AGENCY


MPN
CR(3)
90-3(a)

THE ISLAMIC REPUBLIC OF PAKISTAN

**DETAILED DESIGN STUDY
ON
WEST WHARF
THERMAL POWER PLANT PROJECT**

FINAL REPORT-I

VOLUME 2



20635

JANUARY 1990

JAPAN INTERNATIONAL COOPERATION AGENCY



1578

国際協力事業団

20635

WEST WHARF THERMAL POWER PLANT PROJECT

DETAILED DESIGN STUDY

DRAFT FINAL REPORT - I

VOLUME 1

SECTION 1. INTRODUCTION

- I-1 PREFACE
- I-2 OUTLINE OF THE PROJECT
- I-3 SITE CONDITION AND DESIGN CONDITION

SECTION 2. GENERAL

- GP-1 PLANT PERFORMANCE
- GP-2 HEAT BALANCE FOR TURBINE
- GP-3 OPTIMUM STEAM CONDITION
- GP-4 OPTIMUM CONDENSER VACUUM
- GP-5 NUMBER OF FEEDWATER HEATERS

SECTION 3. MECHANICAL

- M-1 BOILER
- M-2 BOILER AUXILIARIES
- M-3 TURBINE
- M-4 TURBINE AUXILIARIES
- M-5 CONDENSER AND CIRCULATING WATER SYSTEM
- M-6 CONDENSER TUBE MATERIALS
- M-7 FEEDWATER HEATING SYSTEM
- M-8 TYPE AND NUMBER OF BOILER FEED PUMP
- M-9 BEARING COOLING WATER SYSTEM
- M-10 MAIN STEAM AND REHEAT STEAM PIPELINE ROUTE

M-11 SIZING OF PIPELINES

M-12 OUTDOOR PIPING

SECTION 4. COMMON AUXILIARIES

C-1 FUEL OIL SYSTEM

C-2 FUEL OIL HEATING SYSTEM

C-3 NATURAL GAS SYSTEM FOR AUXILIARY FUEL

C-4 PLANT SERVICE WATER SYSTEM

C-5 WASTE WATER TREATMENT SYSTEM

C-6 CHEMICAL FEED SYSTEM

C-7 CHLORINATION SYSTEM

C-8 CONDENSER PROTECTION SYSTEM

C-9 MAINTENANCE FACILITIES FOR SCREEN AND CWP PIT AREA

C-10 FIRE PROTECTION SYSTEM

SECTION 5. ELECTRICAL

E-1 CAPACITY OF AUXILIARY TRANSFORMER

E-2 CAPACITY OF STARTING TRANSFORMER

E-3 IMPEDANCE OF AUXILIARY TRANSFORMER

E-4 IMPEDANCE OF STARTING TRANSFORMER

E-5 CAPACITY OF BATTERY AND BATTERY CHARGER

E-6 CAPACITY AND DESIGN CRITERIA OF EMERGENCY DIESEL
ENGINE GENERATOR

E-7 CAPACITY OF GENERATOR NGR TRANSFORMER

E-8 MINIMUM CAPACITY OF GENERATOR SURGE ABSORBER

E-9 SHORT CIRCUIT CAPACITY OF IPB

E-10 BUS VOLTAGE OF ELECTRIC CIRCUIT

E-11 REQUIRED GROUNDING RESISTANCE VALUE

- E-12 DESIGN CRITERIA OF SUBSTATION
- E-13 BASIC REQUIREMENT OF LIGHTING SYSTEM

SECTION 6. PLANT INTERLOCK AND CONTROL

- PIC-1 PLANT INTERLOCK
- PIC-2 CONCEPT OF PLANT CONTROL SYSTEM
- PIC-3 TURBINE BYPASS SYSTEM
- PIC-4 APPLICATION OF COMPUTER SYSTEM FOR POWER PLANT
- PIC-5 BOILER CONTROL SYSTEM
- PIC-6 BURNER CONTROL SYSTEM
- PIC-7 TURBINE GOVERNING SYSTEM

SECTION 7. ENVIRONMENTAL PROTECTION

- EP-1 STUDY OF SO_x AND NO_x CONCENTRATION
- EP-2 STUDY OF WASTE WATER TREATMENT
- EP-3 NOISE CONTROL

SECTION 8. PROJECT IMPLEMENTATION

- PR-1 CONSTRUCTION SCHEDULE
- PR-2 CONSTRUCTION COST

ATTACHMENT:

1. STUDY TEAM MEMBERS AND THEIR AREAS OF SPECIALTY
2. SITE SURVEY RECORDS

WEST WHARF THERMAL POWER PLANT PROJECT

DETAILED DESIGN STUDY

DRAFT FINAL REPORT - I

VOLUME 2

TRANSMISSION LINE AND GRID STATION

TLG-1 OVER HEAD TRANSMISSION LINE

TLG-2 UNDERGROUND CABLE

TLG-3 CABLE CHANNEL

TLG-4 GRID STATION FACILITIES

4

WEST WHARF THERMAL POWER PLANT PROJECT

DETAILED DESIGN STUDY

DRAFT FINAL PROJECT - I

VOLUME 3

SECTION 1. ARCHITECTURAL AND STRUCTURAL

- AR-1 STRUCTURAL CALCULATION SHEETS FOR MAIN POWERHOUSE
SUPERSTRUCTURE
- AR-2 STRUCTURAL CALCULATION SHEETS FOR MAIN POWERHOUSE
SUBSTRUCTURE
- AR-3 STRUCTURAL CALCULATION SHEETS FOR STACK
- AR-4 STRUCTURAL CALCULATION SHEETS FOR ADMINISTRATION BUILDING
- AR-5 STRUCTURAL CALCULATION SHEETS FOR AUXILIARY BUILDINGS
- AR-6 STRUCTURAL CALCULATION SHEETS FOR OUTDOOR EQUIPMENT
FOUNDATIONS
- AR-7 CALCULATION SHEETS FOR AIR-CONDITIONING AND VENTILATION SYSTEM
FOR MAIN POWERHOUSE
- AR-8 CALCULATION SHEETS FOR AIR-CONDITIONING AND VENTILATION SYSTEM
FOR ADMINISTRATION BUILDING

SECTION 2. CIVIL WORKS

- CV-1 CIVIL DESIGN CONDITION
- CV-2 THE BASIC DATA FROM THE STUDY OF HYDRAULICS AT THE
COOLING WATER WAY
- CV-3 HYDROGRAPHIC CALCULATION
- CV-4 STRUCTURAL CALCULATION OF INTAKE OPEN CHANNEL
- CV-5 STRUCTURAL CALCULATION OF PUMP PIT
- CV-6 STRUCTURAL CALCULATION OF DISCHARGE TUNNEL
- CV-7 STRUCTURAL CALCULATION OF OUTLET
- CV-8 STRUCTURAL CALCULATION OF RETAINING WALL

TLG-1

OVER HEAD TRANSMISSION LINE

TLG-1 OVER HEAD TRANSMISSION LINE

1.	INTRODUCTION	TLG-1-1
1.1	General	
1.2	Summary of Design	
2.	TRANSMISSION LINE ROUTE AND TOWER HEIGHT	TLG-1-3
3.	CONDUCTOR	TLG-1-4
3.1	Characteristics of Conductor	
3.2	Current Capacity	
3.3	Sub-conductor Spacing per Phase	
4.	GROUND WIRE	TLG-1-10
4.1	Characteristics of Ground Wire	
4.2	Temperature of Ground Wire	
5.	INSULATOR STRING	TLG-1-15
5.1	Number of Insulator Discs per String	
5.2	Arcing Horn	
6.	INSULATION CLEARANCE	TLG-1-18
7.	TOWER DESIGN	TLG-1-21
7.1	Design Conception	
7.2	Cable Connection Point	
7.3	Preliminary Tower Design	
8.	CAUTION FOR TOWER MATERIAL AGAINST CORROSION	TLG-1-111
8.1	General	
8.2	Protection Process	

8.3	Details of Each Process	
9.	INSTRUCTION FOR MAINTENANCE WORK	TLG-1-115
9.1	Maintenance Work for Satisfactory Operation	
9.2	Care for Durability of Tower Life	
9.3	Measurement of Contamination on Insulator Disc	
10.	TOWER FOUNDATIONS	TLG-1-128
10.1	Geological profile	
10.2	Tower Structure	
10.2.1	Tower Types	
10.2.2	Loads	
10.3	Geological Conditions	
10.3.1	Outline	
10.3.2	Soil Consistency	
10.3.3	Groundwater	
10.4	Foundation Types	
10.5	Piles	
10.6	Comparative Study on Tower Foundations	
10.6.1	Results of Comparative Study	
10.6.2	Comments on Foundation Types for Each Tower Type	
10.7	Detailed Design	
10.7.1	Design Flowchart	
10.7.2	Design Calculation Formulas	
10.7.3	Foundation Design	
11.	LEDGER FOR INDIVIDUAL TOWER	TLG-1-246
12.	DRAWINGS	TLG-1-252

1. INTRODUCTION

1.1 General

The transmission line between the West Wharf Thermal Power Plant and the Baldia Grid Station has been studied, surveyed and checked, with the decisions planned as follows.

- o Between the substation of the West Wharf Thermal Power Station and the site of tower No. 1 of existing 66 kV Baldia line and S.I.T.E. line (1.15 km)

220 kV underground O.F. cable in tunnel

- o Between tower No. 1 and tower No. 5 of existing 66 kV line (1 km)

Overhead line of composite towers consists of 2 circuits of 220 kV line and 2 circuits of 132 kV line

- o Between tower No. 5 of existing 66 kV line and the Baldia Grid Station (22.9 km)

Overhead line of 2 circuits of 220 kV line

The area where the transmission line will be constructed is situated in a tropical zone exhibiting high temperature, high humidity and extremely low precipitation.

Also, as the area is situated nearby the sea, it has been concluded that the facilities shall be provided with effective measures against corrosion.

1.2 Summary of Design

ITEM	DESCRIPTION	
Nominal voltage	220 kV	132 kV
Route length	23.8 km	1.0 km
Number of circuits	2 cct	2 cct
Supporter	Lattice steel tower	Lattice steel composite tower
Conductor	ACSR/AS 330 mm ² x 2	ACSR/AS 680 mm ²
Ground wire	OPGW 190/90 mm ²	-
Insulator	Fog type suspension insulator ϕ 254 mm	Fog type suspension insulator ϕ 254 mm
Suspension string	22 pc./string	14 pc./string
Tension string	23 pc./string	15 pc./string
Frequency	50 Hz	50 Hz

2. TRANSMISSION LINE ROUTE AND TOWER HEIGHT

As a result of the site survey and the discussion with KESC's engineers and concerned authorities relating to the route of 220 kV transmission line, the optimum route was studied and selected taking into account the future extension plan of the transmission system, physical aspects of the tower site conditions, availability of land acquisition, ease of construction and maintenance, and the detour route around the Air Force Base.

The proposed route of the 220 kV transmission line is as shown in DWG. No. WLT-1001.

The limitations of tower heights are divided into three classes, 33 m, 45 m and 66 m so as not to interfere with the taking-off or landing of aircraft. Sections to be applied to each height limitation are as shown in DWG. No. WLT-1001.

3. CONDUCTOR

3.1 Characteristics of Conductor

(1) ACSR/AS 330 mm²

(a) Composite wire

Sectional area	379.6 mm ²
Construction	
Al	26/4.0 mm
AS	7/3.1 mm
Minimum ultimate tensile strength	10,950 kg
Overall diameter	25.3 mm
Weight per km	1.239 kg
DC resistance at 20°C	0.0835 ohm/km

(b) Aluminum wire

Diameter	4.0 mm
Minimum tensile strength	16.17 kg/mm ²
Minimum elongation in 250 mm	1.9%
Minimum conductivity at 20°C	61%

(c) Aluminum-clad steel core wire

Diameter	3.1 mm
Minimum tensile strength	130 kg/mm ²
Minimum elongation in 250 mm	1.5%
Minimum conductivity at 20°C	23%
Minimum stress at 1% extension	110 kg/mm ²
Minimum number of twisting before stranding	20 times

(2) ACSR/AS 680 mm²

(a) Composite wire

Sectional area	766.8 mm ²
Construction	
Al	54/4.0 mm
AS	7/4.0 mm
Minimum ultimate tensile strength	20,180 kg
Overall diameter	36.0 mm
Weight per km	2,446 kg
D.C. resistance at 20°C	0.0408 ohm/km

(b) Aluminum wire

Diameter	4.0 mm
Minimum tensile strength	16.17 kg/mm ²
Minimum elongation in 250 mm	1.9%
Minimum conductivity at 20°C	61%

(c) Aluminum-clad steel core wire

Diameter	4.0 mm
Minimum tensile strength	130 kg/mm ²
Minimum elongation in 250 mm	1.5%
Minimum conductivity at 20°C	23%
Minimum stress at 1% extension	110 kg/mm ²
Minimum number of twisting before stranding	20 times

3.2 Current Carrying Capacity

The concept for the conductor is to have enough capacity in continuous operation for full load in one circuit. Consequently,

the capacity is calculated on the basis of a 400 MW load for 220 kV and a 165 MVA load for 132 kV line, and were determined by power flow analysis and KESC instructions.

Required current capacity;

$$220 \text{ kV: } I = \frac{P}{\sqrt{3} V \cos\phi} = \frac{400 \text{ MW}}{\sqrt{3} \times 220 \times 0.85} = 1,235 \text{ (A)}$$

$$132 \text{ kV: } I = \frac{P}{\sqrt{3} V} = \frac{165 \text{ MVA}}{\sqrt{3} \times 132} = 722 \text{ (A)}$$

According to the calculation results shown in Table 3.1, ACSR/AS 330 mm² has 526A and 655A of capacity at 80°C and 90°C of conductor temperature, respectively, and ACSR/AS 680 mm² has 797A and 1010A of capacity at 80°C and 90°C respectively, with these values deemed to have sufficient current capacity.

Table 3.1 CURRENT CAPACITY

◆ Allowable Current	
Cond. Name : ACSR/AS 330 mm2Sec.Area = 326.8 mm2	Dia = 25.3 mm
DC Res.at 20deg= .0835 /km Max Temp.= 80 deg.	Amb.Temp.= 48 deg.
Solar Radiation= .1 W/cm2 Rad.Ratio= .9	Wind V. = .5 m/sec.
DC Res.at Max.T= 0.1035/km X = 0.95052 Beta = 1.00421	K = 1.00000
Hw = 0.0012429	Ia = 525.89 A
◆ Allowable Current	
Cond. Name : ACSR/AS 330 mm2Sec.Area = 326.8 mm2	Dia = 25.3 mm
DC Res.at 20deg= .0835 /km Max Temp.= 90 deg.	Amb.Temp.= 48 deg.
Solar Radiation= .1 W/cm2 Rad.Ratio= .9	Wind V. = .5 m/sec.
DC Res.at Max.T= 0.1069/km X = 0.93555 Beta = 1.00396	K = 1.00000
Hw = 0.0012406	Ia = 654.78 A
◆ Allowable Current	
Cond. Name : ACSR/AS 680 mm2Sec.Area = 678.8 mm2	Dia = 36 mm
DC Res.at 20deg= .0408 /km Max Temp.= 80 deg.	Amb.Temp.= 48 deg.
Solar Radiation= .1 W/cm2 Rad.Ratio= .9	Wind V. = .5 m/sec.
DC Res.at Max.T= 0.0506/km X = 1.39303 Beta = 1.01929	K = 1.02591
Hw = 0.0010419	Ia = 797.47 A
◆ Allowable Current	
Cond. Name : ACSR/AS 680 mm2Sec.Area = 678.8 mm2	Dia = 36 mm
DC Res.at 20deg= .0408 /km Max Temp.= 90 deg.	Amb.Temp.= 48 deg.
Solar Radiation= .1 W/cm2 Rad.Ratio= .9	Wind V. = .5 m/sec.
DC Res.at Max.T= 0.0522/km X = 1.37109 Beta = 1.01812	K = 1.03072
Hw = 0.0010400	Ia = 1010.26 A

3.3 Sub-conductor Spacing in Phase

Nominal spacing distance	400 mm
Configuration	Horizontal

The nominal spacing distance of ACSR/AS 330 mm² twin conductor shall be 400 mm based on the following.

- (a) The larger the nominal spacing distance becomes, the smaller the inductance becomes. However, the mode has a tendency of saturation.
- (b) The larger the nominal spacing distance becomes, the larger the capacitance becomes. However, the mode has a tendency of saturation.
- (c) Corona noise level is minimum when the spacing distance is equal to the length of about ten times the conductor diameter. In the range of a spacing distance smaller than the above, it increases sharply, while for larger spacing distance, it increases slowly.
- (d) The smaller the nominal spacing distance is, the greater the effect of wind pressure reduction. However, should the distance be excessively small, both subconductors are prone to be irregularly moved, stuck or distorted due to wind pressure.
- (e) It is not desirable to frequently change the voltage drop of transmission line or corona voltage due to irregular changing of the spacing distance of subconductors and/or wind pressure.

Therefore, the nominal spacing distance shall be selected so that the curve indicating electrical characteristics, such as the relationship between change of inductance and electrostatic capacity, corona voltage and that of nominal spacing distance, is as flat as possible.

- (f) In addition to electrical and mechanical characteristics, coordination with the design of insulator strings and stringing work, particularly the design of "vehicle for mid-air performance" for mounting spacers as well as the weight of workers mounting the vehicle, shall be taken into account in deciding the nominal spacing distance.

Based on the above, the nominal spacing distance shall be 400 mm.

4. GROUND WIRE

4.1 Characteristics of Ground Wire

(1) OPGW 190/90 mm²

Construction	1/5.2 mm OP unit + 7/4.0 mm AS + 12/4.47 mm HA1
Overall diameter	22.2 mm
Cross sectional area	
Nominal	283.59 mm ²
Minimum ultimate tensile strength	10,500 kg
Weight per km	1,136 kg
DC resistance at 20°C	0.129 ohm/km
Maximum continuous operating temperature	150°C
Maximum one second operating temperature	300°C
System fault current	40,000 A x 1 sec.

(2) Optical cable

Optical fiber type	Single mode
Number of optical fiber	5
Optical attenuation at wave length 1.3 μm	Max. 0.5 dB/km

(3) Aluminum-clad steel wire

Diameter	4.40 mm
Minimum ultimate tensile strength	116 kg/mm ²
Minimum elongation in 250 mm	1.5%
Minimum conductivity at 20°C	20.3%

Minimum stress at 1% extension	125 kg/mm ²
Minimum aluminum thickness	0.22 mm

4.2 Temperature of Ground Wire

From the viewpoint of the mechanical strength of the ground wire and characteristic of the optical fiber, the temperature of ground wire shall be lower than 150°C under normal operation and lower than 300°C at the time of one line fault of which the duration is not more than one second.

(1) Under normal operation:

Conductor temperature affected by electro magnetic induced current shall be lower than 150°C.

Assuming the conductor arrangement is as shown in Fig. 4.1, induced current will be calculated as follows.




Fig. 4.1

Mutual inductance will be as follows.

$$M_{ij} = \left[2 \log_e \frac{2}{K d_{ij}} - 0.1544 + \frac{2\sqrt{2}}{3} K (h_i + h_j) - j \left\{ \frac{\pi}{2} - \frac{2\sqrt{2}}{3} K (h_i + h_j) \right\} \right] \times 10^{-4} \quad (\text{H/km})$$

$$K = \sqrt{4\pi\omega \times 10^{-14}}$$

$$d_{ij} = \sqrt{D_{ij}^2 + (h_i - h_j)^2} \quad (\text{cm})$$

Self inductance will be,

$$L_i = \left\{ 2 \log_e \frac{2}{K r_i} - 0.1544 + \frac{4\sqrt{2}}{3} K h_i + \frac{\mu s_i}{2} \right. \\ \left. - j \left(\frac{\pi}{2} - \frac{4\sqrt{2}}{3} K h_i \right) \right\} \times 10^{-4} \quad (\text{H/km})$$

Mutual and self impedance will be,

$$Z_{ij} = j\omega M_{ij} \quad (\Omega/\text{km})$$

$$Z_{ii} = r_i + j\omega L_i \quad (\Omega/\text{km})$$

Induced current in the ground wire will be,

$$\begin{bmatrix} \dot{I}_1 \\ \dot{I}_2 \end{bmatrix} = - \begin{bmatrix} \dot{Z}_{11} & \dot{Z}_{12} \\ \dot{Z}_{21} & \dot{Z}_{22} \end{bmatrix}^{-1} \begin{bmatrix} \dot{Z}_{13} + \dot{Z}_{14} + \dot{Z}_{15} + \dots + \dot{Z}_{18} \\ \dot{Z}_{23} + \dot{Z}_{24} + \dot{Z}_{25} + \dots + \dot{Z}_{28} \end{bmatrix} \begin{bmatrix} \dot{I}_3 \\ \dot{I}_4 \\ \vdots \\ \dot{I}_8 \end{bmatrix}$$

Where;

σ : Electric conductivity of earth (m /m)

h_i : Conductor height (cm)

D_{ij} : Horizontal distance between conductors (cm)

r_i : Equivalent radius of conductor (cm)

μs_i : Specific permeability of conductor

Now, assuming that $\sigma = 100 \text{ m } \nu/\text{m}$, $\mu s_i = 5$ and the current of each phase is 1200 A, the induced current will be,

$$\dot{I}_1 = \dot{I}_2 = -122.4 + j 21.48 \quad (\text{A})$$

$$\therefore \dot{I}_1 = \dot{I}_2 = 124.3 \quad (\text{A})$$

According to the calculation result given below, the temperature of the OPGW will be lower than 64°C, thereby satisfying the requirements.

♥ Allowable Current

Cond. Name : OPGW 190/90	Sec.Area = 188.3 mm ²	Dia = 22.2 mm
DC Res.at 20deg= .129 /km	Max Temp.= 64 deg.	Amb.Temp.= 48 deg.
Solar Radiation= .1 W/cm ²	Rad.Ratio= .9	Wind V. = .5 m/sec.
DC Res.at Max.T= 0.1517/km	X =0.63003 Beta =1.00097	K = 1.01616
Hw = 0.0013307	Hr = 0.0008081	Ia = 139.10 A

(2) At one line fault

Conductor temperature must be lower than 300°C at the fault of line.

The fault current carrying capacity of overhead ground wires is generally calculated by the following formula.

$$I = n \times \sqrt{\frac{C \cdot \ln(\theta \cdot \alpha + 1)}{\alpha \cdot R_o t}} \quad (A)$$

Where,

I : Fault current (A)

α : Temperature coefficient of resistance ($\Omega/^\circ\text{C}$)

R_o: Electrical resistance at initial condition (Ω/cm)

t : Duration time (sec.)

C : Heat capacity (J/cm. $^\circ\text{C}$)

θ : Temperature rise ($^\circ\text{C}$)

n : Number of ground wires

The temperature rise under the following conditions is obtained as described hereunder.

$T_0 = 65^{\circ}\text{C}$: Initial conductor temperature

$\alpha = 0.0038/^{\circ}\text{C}$

$C = 7.72 \text{ J/cm}^{\circ}\text{C}$

$t = 1.0 \text{ sec.}$

$$R_0 = 0.129 \times 10^{-5} \times \{ 1 + 0.0038 (65 - 20) \} = 0.151 \times 10^{-5} (\Omega/\text{cm})$$

$$X = \frac{\left(\frac{I}{n}\right)^2 \times \alpha \times R_0 \times t}{C}$$

$$= \frac{20,000^2 \times 0.0038 \times 0.151 \times 10^{-5} \times 1}{7.72} = 0.297$$

$$\theta = \frac{e^X - 1}{\alpha} = \frac{e^{0.297} - 1}{0.0038} = 91^{\circ}\text{C}$$

Therefore, the temperature of the ground wire will be,

$$T_c = T_0 + \theta = 65 + 91 = 156 < 300^{\circ}\text{C}$$

5. INSULATOR STRING

5.1 Number of Insulator Discs per String

Insulator disks shall be 254 mm diameter fog type suspension insulators.

Insulator string	220 kV	132 kV
Suspension insulator string	22 discs	14 discs
Tension insulator string	23 discs	15 discs

The reason why the tension string has one more disc than the suspension string is that the increase in the length of string has little effect on the tower height. Also, from the viewpoint of maintenance, it is more difficult to exchange an insulator disc on a tension string than on a suspension string.

The number of insulator discs shall be designed so that no flashover against switching surge impulse occurs. The design shall also take into consideration the effects of salt contamination. The required number of discs for switching surge shall be 11 and 7 discs for 220 kV and 132 kV lines, respectively. Minimum flashover voltage under contamination on 254 mm normal suspension insulator disc shall be calculated by using the following formula.

$$V_t = \frac{28 k}{\left(\frac{\omega}{0.1}\right)^{1/5} \left\{1.5(K^{1/3} + 2) + \frac{5}{8} K\right\}} \quad (\text{kV})$$

V_t : Minimum flashover voltage of 254 mm normal suspension insulator disc (kV)

ω : Salt deposit density on outer surface in lower face of

disc (mg/cm²)

K : Soil deposit density = 0.1 (mg/cm²)

k : Correction factor

k = 1.15 for effective ground system

k = 1.25 for non-effective ground system

As the transmission line route is located in a coastal area, it is predicted that salt contamination will be considerably heavy.

Therefore, assuming the salt deposit density as 0.5 mg/cm², minimum flashover voltage shall be calculated as 6.2 kV and 6.7 kV for 220 kV and 132 kV, respectively. For fog type insulator, it shall be multiplied by 1.3 to become 8.0 kV and 8.7 kV.

Required withstand voltage shall be,

$$V = V_n \times \frac{1.15}{1.1} \times \frac{1}{\sqrt{3}} q$$

V_n: Nominal voltage (kV)

q : Voltage build-up rate at fault

q = 1.3 for effective ground system

q = $\sqrt{3}$ for non-effective ground system

220 kV line:

$$V = 220 \times \frac{1.15}{1.1} \times \frac{1.3}{\sqrt{3}} = 173 \text{ (kV)}$$

Required number of discs : $N = \frac{173}{8.0} = 21.6 \approx 22$

132 kV line:

$$V = 132 \times \frac{1.15}{1.1} \times \frac{\sqrt{3}}{\sqrt{3}} = 138 \text{ (kV)}$$

Required number of discs : $N = \frac{138}{8.7} = 15.9 \rightarrow 16$

The existing 132 kV line has only 12 discs per string. Also, considering that the longer the insulator string becomes, the higher the tower height, 14 discs will be adopted for the proposed 132 kV line, so as to handle the density of 0.3 mg/cm^2 of salt deposit.

5.2 Arcing Horn

There are three main purposes of the arcing horn. One is to avoid flashover on the surface of insulator discs by containing it between horns when lightning surge impulse occurs. Another is to shift the surface arc to the horn at the time insulators become contaminated so as to minimize damage to insulator discs. The other is to restrain corona discharge from insulator discs and/or hardware.

It is understood that the probability of occurrence of lightning surge is negligible in the proposed area. Also, as the insulator strings will be considerably long in view of salt contamination, it is not a practical technique to make discharge between the horns, as this requires extending their length.

Consequently, it is advantageous to allow the flashover to occur at the tower body in the rare case of a lightning attack. Moreover, the horns shall be designed to lighten the share voltage of discs located at the charged end as well as countermeasures against surface arc.

6. INSULATION CLEARANCE

(1) Standard insulation clearance

The standard insulation clearance will be 10% larger than the arcing horn gap so as to allow flashover between horns.

However, in the case of this project, as flashover will be allowed to discharge to the tower body, the clearance shall be determined by taking into account the horn gap in normal cases and BIL, or Basic Insulation Level, of the substation.

Consequently, 1,600 mm for the 220 kV line and 1,050 mm for 132 kV line will be appropriate.

(2) Minimum insulation clearance

This clearance shall withstand the switching surge impulse.

For 220 kV:

Maximum circuit voltage

$$220 \times \frac{1.2}{1.1} = 240 \text{ (kV)}$$

Switching surge voltage

$$240 \times \frac{\sqrt{2}}{\sqrt{3}} \times 2.8 = 549 \text{ (kV)}$$

$\sqrt{2}$: Ratio of absolute value of sine wave to crest value

$\sqrt{3}$: Voltage ratio of phase-to-ground to phase-to-phase

2.8 : Multiple factor of switching surge

Minimum clearance (bar gap)

$$549 \times 1.2 = 658 \text{ (kV)} \rightarrow 1,400 \text{ mm}$$

1.2: Deterioration factor of insulation by ground level and others

For 132 kV:

Maximum circuit voltage

$$132 \times \frac{1.2}{1.1} = 144 \text{ (kV)}$$

Switching surge voltage

$$144 \times \frac{\sqrt{2}}{\sqrt{3}} \times 3.3 = 388 \text{ (kV)}$$

3.3: Multiple factor of switching surge

Minimum clearance (bar gap)

$$388 \times 1.2 = 466 \text{ (kV)} \rightarrow 900 \text{ mm}$$

(3) Clearance diagram

unit: mm

	Description	220 kV	132 kV	Remarks
A	Standard clearance	1,600	1,050	
D	Minimum clearance	1,400	900	
Cs	Normal clearance for suspension tower	2,000	1,680	Cs = A+K+B
Cj	Normal clearance for tension tower	1,650	1,100	Cj = A+K
E	Abnormal clearance	1,550	1,070	E = D+L
J	Depth of jumper	3,000	2,000	
K	Consideration for tension member of cross arm	50	50	
B	Consideration for angle of catenary	350	580	Note 1
L	Consideration for step bolt and post member	150	170	

Note 1:

220 kV: $1,000 \times \tan 15^\circ + 1,600 (\sec 15^\circ - 1) = 324$ 350 mm

132 kV: $2,000 \times \tan 15^\circ + 1,050 (\sec 15^\circ - 1) = 573$ 580 mm

Where; 1,000, 2,000: Distance between hanging members of cross arm

15° : Angle of catenary of conductor

7. TOWER DESIGN

7.1 Design Conception

(1) Standard

Tower design, in principle, shall be in accordance with JEC - 127 (1965), or equivalent.

(2) Conductor

Twin conductor of ACSR/AS 330 mm² for 220 kV line and single conductor of ACSR/AS 680 mm² for 132 kV line shall be applied.

Maximum tension of conductors shall be 4,000 kg for ACSR/AS 330 mm² and 6,000 kg for ACSR/AS 680 mm².

(3) Ground wire

Two OPGW 190/90 mm² with 3,800 kg maximum tension shall be applied. Shield angle shall be less than 30°.

(4) Unbalance tension on tower

(a) Normal condition

o Suspension and angle towers

No unbalance tension will be applied.

o Dead-end towers

Full tension of all conductors and ground wire in the same span shall be applied.

o Section towers

One-third of maximum tension of all conductors and ground wire in the same span shall be applied.

(b) Abnormal condition

Unbalance tension and torsional force caused by breakage of any one conductor or two conductors in one phase in case of bundle conductors or ground wire shall be added to the normal condition.

Unbalance tension on suspension tower may be decreased but shall not be lower than 60% of assumed tension of conductor. This deduction shall not be applied on ground wire.

(5) Safety factor

Safety factor shall be more than 1.8 for normal condition and more than 1.2 for abnormal condition based on yield strength or buckling strength.

(6) Standard span

Standard span shall be 400 m. The standard span has been decided based on the following study.

- (a) Type, size and number of conductor
- (b) Type and construction of supporter
- (c) Topographic and climatic conditions in the area along the transmission line route
- (d) Applicable standards for safety based on those applied in Japan

Generally, the standard span of supporter is decided by carrying out a comparative study on the estimated total

construction cost after designing several types of towers corresponding to their span. The spans considered to be justifiable are based on the experience of the consultant in the past. These spans are as follows.

<u>Type of supporters</u>	<u>Standard span (m)</u>
Wooden pole	75 - 120
Steel pole	150 - 200
Steel tower for transmission line of up to 77 kV	200 - 300
Steel tower for 154 kV line	250 - 350
Steel tower for 275 kV line	300 - 400
Steel tower for 500 kV line	350 - 450

(7) Wind pressure

On tower:

Tower height less than 40 m	280 kg/m ²
Tower height less than 50 m	300 kg/m ²
Tower height less than 60 m	320 kg/m ²
Tower height less than 70 m	340 kg/m ²
Tower height less than 80 m	360 kg/m ²
Tower height less than 90 m	380 kg/m ²
Tower height less than 100 m	400 kg/m ²

On conductor:

Single conductor	90 kg/m ²
Twin conductor	81 kg/m ²

On insulator string: 126 kg/m²

(Wind velocity $v = 136 \text{ km/h} = 37.8 \text{ m/sec.}$)

$$P = \frac{1}{2} \rho CV^2$$

$$= 0.5 \times 0.125 \times C \times 37.8^2 \text{ (kg/m}^2\text{)}$$

q: air density (kg.sec²/m⁴)

C: Coefficient of air resistance

C = 1.0 for single conductor

C = 0.9 for twin conductor

C = 1.4 for insulator string

(8) Sag calculation

Ambient temperature Max. 48°C

Min. 0°C

Conductor temperature Max. 80°C

In no case shall ice on the conductor be considered. EDS condition shall be 25°C temperature with no wind.

Results of calculation are as shown in the attached Tables 7.1, 7.2 and 7.3.

Table 7.1 *** SAG CALCULATION ***

CONDUCTOR : ACSR/AS 330 mm² CROSS S. AREA = 379.64 (sq. mm)
 WEIGHT = 1.239 (kg/m) DIAMETER = 25.3 (mm)
 ELASTIC M. = 7450 (kg/sq. mm) EXPANSION M. = .0000203 (/deg. C)
 BASE TENSION = 4000 (kg)

	SPAN (m)	TEMP (deg. C)	WIND P. (kg/sq. m)	ICE (mm)	GRAV.	RES. WT. (kg/m)	HOR. TENS. (kg)	SAG (m)	K
H. TEMP.		0	81.00	0	0.0				
L. TEMP.		0	81.00	0	0.0				
	200	80	0.00	0	0.0	1.239	1401.48	4.420	45
	250	80	0.00	0	0.0	1.239	1539.23	6.289	41
	300	80	0.00	0	0.0	1.239	1642.26	8.488	38
	350	80	0.00	0	0.0	1.239	1720.36	11.028	37
	400	80	0.00	0	0.0	1.239	1780.38	13.918	35
	450	80	0.00	0	0.0	1.239	1827.12	17.165	34
	500	80	0.00	0	0.0	1.239	1864.00	20.772	34
	550	80	0.00	0	0.0	1.239	1893.48	24.743	33
	600	80	0.00	0	0.0	1.239	1917.31	29.080	33
	650	80	0.00	0	0.0	1.239	1936.80	33.785	32
	700	80	0.00	0	0.0	1.239	1952.90	38.859	32
	750	80	0.00	0	0.0	1.239	1966.34	44.304	32
	800	80	0.00	0	0.0	1.239	1977.64	50.120	32
	850	80	0.00	0	0.0	1.239	1987.23	56.308	32
	900	80	0.00	0	0.0	1.239	1995.43	62.868	32
	400	0	0.00	0	0.0	1.239	2374.70	10.435	27
	400	25	0.00	0	0.0	1.239	2138.11	11.590	29
	400	55	0.00	0	0.0	1.239	1921.74	12.895	33

Table 7.2 *** SAG CALCULATION ***

CONDUCTOR : ACSR/AS 680 mm² CROSS S. AREA = 766.79 (sq. mm)
 WEIGHT = 2.446 (kg/m) DIAMETER = 36 (mm)
 ELASTIC M. = 7250 (kg/sq. mm) EXPANSION M. = .0000207 (/deg.C)
 BASE TENSION = 6000 (kg)

H. TEMP. L. TEMP.	SPAN (m)	TEMP (deg.C)	WIND P. (kg/sq.m)	ICE (mm)	GRAV. (kg/m)	RES. WT. (kg/m)	HOR. TENS. (kg)	SAG (m)	K
0 0	90.00 90.00	0 0	0.00 0.00	0 0	0.0 0.0	2.446 2.446	2375.53 2635.60	5.148 7.250	52 47
80 80	200 250	80 80	0.00 0.00	0 0	0.0 0.0	2.446 2.446	2829.48 2975.74	9.725 12.587	44 42
80 80	300 350	80 80	0.00 0.00	0 0	0.0 0.0	2.446 2.446	3087.54 3174.18	15.844 19.506	40 39
80 80	400 450	80 80	0.00 0.00	0 0	0.0 0.0	2.446 2.446	3242.24 3296.41	23.576 28.058	38 38
80 80	500 550	80 80	0.00 0.00	0 0	0.0 0.0	2.446 2.446	3340.07 3375.66	32.954 38.268	37 37
80 80	600 650	80 80	0.00 0.00	0 0	0.0 0.0	2.446 2.446	3404.99 3429.40	44.000 50.150	36 36
80 80	700 750	80 80	0.00 0.00	0 0	0.0 0.0	2.446 2.446	3449.90 3467.26	56.721 63.712	36 36
80 80	800 850	80 80	0.00 0.00	0 0	0.0 0.0	2.446 2.446	3482.09 3866.39	71.123 12.653	36 32
0 0	400 400	0 25	0.00 0.00	0 0	0.0 0.0	2.446 2.446	3568.57 3282.57	13.709 14.903	35 38

Table 7.3 *** SAG CALCULATION ***

CONDUCTOR : OPGW 190/90
 WEIGHT = 1.136 (kg/m)
 ELASTIC M. = 9400 (kg/sq.mm)
 CROSS S.AREA = 283.59 (sq.mm)
 DIAMETER = 22.2 (mm)
 EXPANSION M. = .0000176 (/deg.C)

BASE TENSION = 3800 (kg)

	SPAN (m)	TEMP (deg.C)	WIND P. (kg/sq.m)	ICE (mm)	GRAV. (kg/m)	RES.WT. (kg/m)	HOR.TENS. (kg)	SAG (m)	K
H.TEMP.		0	90.00	0					
L.TEMP.		0	90.00	0	0.0				
	100	0	0.00	0	0.0	1.136	3510.01	0.405	17
	150	0	0.00	0	0.0	1.136	3200.59	0.998	18
	200	0	0.00	0	0.0	1.136	2870.51	1.979	20
	250	0	0.00	0	0.0	1.136	2592.92	3.423	22
	300	0	0.00	0	0.0	1.136	2393.98	5.338	24
	350	0	0.00	0	0.0	1.136	2393.98	5.338	24
	400	0	0.00	0	0.0	1.136	2260.07	7.697	26
	450	0	0.00	0	0.0	1.136	2169.84	10.471	27
	500	0	0.00	0	0.0	1.136	2107.42	13.645	27
	550	0	0.00	0	0.0	1.136	2062.85	17.209	28
	600	0	0.00	0	0.0	1.136	2030.04	21.160	28
							2005.24	25.493	29

(9) Distance between conductors

(a) 220 kV line

(i) Experienced distance

Horizontal distance:

$$C_h = 1.5 \times \frac{220}{1.1 \times 25} = 9.5 \text{ (m)}$$

Vertical distance:

$$C_v = 1.0 + \frac{220}{1.1 \times 45} = 5.4 \text{ (m)}$$

(ii) Transverse swing by wind

$$\begin{aligned} C_h &\geq (D-\epsilon) \frac{S_m - S}{S_m} + 2 (d+L) \sin \theta + \epsilon + 2r \\ &= (4 - 0.84) \frac{600 - 400}{600} + 2 (12.9 + 4.3) \sin 12.17^\circ \\ &\quad + 0.84 + (0.4 + 0.0253) = 9.6 \text{ (m)} \end{aligned}$$

$$\theta = \tan^{-1} \frac{W_w}{W_c} = \tan^{-1} \frac{10.6 \times 25.3 \times 10^{-3}}{1.239} = 12.17^\circ$$

where;

D : distance between busbars of outdoor
substation (m)

ϵ : power-frequency flashover distance (m)

S_m : maximum span length (m)

S : applied span length (m)

d : sag at 55°C (m)

L : insulator string length (m)

θ : swung angle of conductor (deg.)

r : radius of conductor (m)

Wc: weight of conductor (kg/m)

Ww: wind pressure on conductor at wind velocity
of 13 m/sec. (kg/m)

(iii) Statistical method

Generally, the swing of conductors will not be simultaneous at all instances. The probability of conductor being staid within the standard deviation (σ) from the mean swing angle ($\bar{\theta}$) is 68.26% and within 2σ is 95.44%. Taking into account to close conductors with 2σ , the required distance between conductors should be more than 6.2 m horizontally according to the following formula. Refer to Fig. 7.1.

$$\sigma = \frac{43.5h \cdot p \sqrt{\nu} \cdot d \cdot s}{\sqrt{\beta\gamma} \cdot \left(\frac{\gamma}{\alpha}\right)^{\frac{5}{6}}}$$
$$\alpha = \frac{w}{g} \cdot \frac{8 d^2 s}{15}$$

$$\beta = a\bar{v} (1 + \cos^2 \bar{\theta}) \frac{8 d^2 s}{15}$$

$$\gamma = (a\bar{v}^2 \sin \bar{\theta} + w \cos \bar{\theta}) \frac{2}{3} d s$$

$$\nu = \frac{1}{15kS} - \frac{2}{3(kS)^3} + \frac{2}{(kS)^4} - \frac{8}{(kS)^6}$$

$$+ \frac{2e^{-kS}}{(KS)^4} \left(1 + \frac{2}{KS}\right)^2$$

$$k = k_0 \frac{\omega}{v}$$

$$k_0 = 0.335$$

$$\omega = \sqrt{\frac{Y}{\alpha}}$$

where;

h : $\cos \bar{\theta}$

d : sag (m)

S : span (m)

\bar{p} : wind pressure on conductor (kg/m) = a_v^{-2}

w : weight of conductor (kg/m)

g : gravitational acceleration 9.8 m/sec.²

(iv) Conclusion

Horizontal distance: more than 9.6 m

Vertical distance: more than 5.4 m

(b) 132 kV line

(i) Experienced distance

Horizontal distance:

$$C_h = 1.5 + \frac{132}{1.1 \times 25} = 6.3 \text{ (m)}$$

Vertical distance:

$$C_v = 1.0 + \frac{132}{1.1 \times 45} = 3.7 \text{ (m)}$$

(ii) Transverse swing by wind

$$C_h \geq (3 - 0.504) \frac{550 - 400}{550} + 2 (14.9 + 3) \sin 8.84^\circ$$

$$+ 0.504 + 0.036 = 6.72 \text{ (m)}$$


(iii) Statistical method

Refer to Fig. 7.2

(iv) Conclusion

Horizontal distance: more than 6.8 m


Fig. 7.1 CONDUCTOR SWING BY WIND
(STATISTICAL METHOD)



Conductor	電線	ACSR/AS 330 * 2
	(Tmax)	4000 (kg)
Voltage	電圧	220 (KV)
Required Clearance	所要離隔	V ≤ 20m/sec 1612.65 mm
		V > 20m/sec 752.65 mm
Applied Span	徑間	450 (m)
Ruling Span	等価徑間	400 (m)

Wind Verocity	Conductor Temperature	Loading Factor	Sag	Tension	Swinged Angle	Standard Deviation
風速 (m/s)	電線温度 (°C)	負荷係数	弛度 (m)	張力 (kg)	横振れ角 θ (°)	標準偏差 σ (°)
15.0	55.0	1.0000	16.32	1922	14.5	2.2
20.0	55.0	1.0000	16.32	1922	24.7	3.5
25.0	55.0	1.0000	16.32	1922	35.7	4.4
30.0	55.0	1.0000	16.32	1922	46.0	4.7
35.0	55.0	1.0000	16.32	1922	54.6	4.5
40.0	55.0	1.0000	16.32	1922	61.4	4.0

Fig. 7.2 CONDUCTOR SWING BY WIND
(STATISTICAL METHOD)



Conductor	電線	ACSR/AS 680 * 1
	(Tmax)	6000 (kg)
Voltage	電圧	132 (KV)
Required Clearance	所要離隔	V ≤ 20m/sec 918 mm
		V > 20m/sec 348 mm
Applied Span	徑間	450 (m)
Ruling Span	等価徑間	400 (m)

Wind Verocity	Conductor Temperature	Loading Factor	Sag	Tension	Swinged Angle	Standard Deviation
風速 (m/s)	電線温度 (°C)	負荷係数	弛度 (m)	張力 (kg)	横振れ角 θ (°)	標準偏差 σ (°)
15.0	55.0	1.0000	18.86	3283	11.7	2.1
20.0	55.0	1.0000	18.86	3283	20.2	3.4
25.0	55.0	1.0000	18.86	3283	29.9	4.5
30.0	55.0	1.0000	18.86	3283	39.6	5.1
35.0	55.0	1.0000	18.86	3283	48.4	5.2
40.0	55.0	1.0000	18.86	3283	55.8	4.9

Vertical distance: more than 3.7 m

(c) Vertical distance between 220 kV line and 132 kV line

Unit: m

Description	Tower type	A	B	C	D
Suspension insulator string or jumper		2.9	3.0	3.0	3.8
Normal clearance		2.0	1.65	1.65	1.65
Height of personnel		1.8	1.8	1.8	1.8
Working space		0.5	0.5	0.5	0.5
Total		7.2	6.95	6.95	7.75

(10) Tower type

Type	Circuit number	Deviation angle	Wind span	Weight span
AS	2	3°	250 m	300 m
A	2	3°	400	500
AL	2	3°	500	550
B	2	15°	300	300
C	2	35°	350	400
D	2	0°, 60°	300	300
DR	2	90°	300	350
A4	4	3°	350	400
D4	4	0°	250	300
DR4	4	75°	350	350

Configurations of each tower type are as shown in DWG. NOS. WLT-1101 to WLT-1103, and the clearance diagrams are as shown in DWG. NOS. WLT-1151 to WLT-1153.

(11) Clearance from land or obstacles

Particulars	Minimum clearance (m)	
	220 kV	132 kV
Normal ground, open and agricultural land	7.75	7.75
Main road	9.20	9.20
Trees	4.00	3.20
Railway	12.00	12.00
Residential building	6.00	4.50
Telecommunication line	4.00	3.20
Shield wire of power line	4.00	3.20
Iron bridges, etc.	4.00	3.20
Highest water level of large river	15.00	15.00

(12) Accessories

(a) Spacer

The spacer for the bundle conductor shall be fitted in the mid-span and in the jumper connections.

(b) Vibration damper

The vibration damper shall be double torsional damper having the following weight.

ACSR/AS	330 mm ²	14 lb
ACSR/AS	680 mm ²	18 lb
OPGW	190/90 mm ²	12 lb

(c) Armor rod

The preformed armor rod shall be fitted in suspension strings.

(d) Connection of conductor

Dead-end clamp and mid-span joint sleeves shall be of the compression type.

7.2 Cable Connection Point

Due to space limitation at the site of tower No. 1, connection of the overhead lines to the underground cables shall be made at every circuit aligned in series, and shall be as shown in DWG. NO. WLT-1104, DWG. NO. WLT-1105 and DWG. NO. WLT-1106. Cables shall be laid in the tunnel to be constructed for extending the cable tunnel from the W.W. P.P. along the centerline of tower No. 1 and the gantries.

7.3 Preliminary Tower Design

(1) General

The tower design presented herein aims at obtaining a general idea of the tower weight, reaction force for its foundation, and estimation of the budget of the project. Design is based on DWG. No. TLT-01 to WDG. No. TLT-09. Design results given in this report are considered to be highly adequate in spite of some design conditions which are slightly different from those of actual towers.

(2) Design Condition

Tower designs presented hereunder are in accordance with JEC-127 (1965), except where otherwise stipulated.

(a) Tower type

Tower type	Circuit number	Deviation angle	Wind span	Coefficient of vertical load
AS	2	3°	250	0.03
A	2	3°	400	0.05
AL	2	3°	500	0.03
B	2	15°	300	0.03
C	2	35°	350	0.03
D	2	60°	300	0.03
DR	2	90°	300	0.03
A4	4	3°	350	0.03
D4	4	60°	250	0.03
DR4	4	75°	350	0.03

(b) Conductor

Name	Max. tension kg	Weight kg/m	Diameter mm
OPGW 190/90	3,800	1.136	22.2
ACSR/AS 330	4,000	1.239	25.30
ACSR/AS 680	6,000	2.446	36.00

(c) Insulator string

Insulator strings are as shown in DWG. No. WLT-1201 to
DWG. No. WLT-1209. Insulator disks are as shown in DWG.
No. WLT-1210.

220 kV suspension string

$$\text{Weight} : 7.3 \times 22 \times 2 + 78 = 399.2 \quad 400 \text{ kg/support}$$

$$\text{Wind pressure} : (0.027 \times 22 \times 2 + 0.33) \times 126 = 191.3$$

200 kg/support

220 kV double tension string

$$\text{Weight} : 7.3 \times 23 \times 2 \times 2 + 116 = 787.6 \quad 790 \text{ kg/support}$$

$$\text{Wind pressure} : \{0.027 \times 23 \times (1+0.3) \times 2 + 0.47\} \times 126 = 262.7$$

270 kg/support

132 kV double suspension string

$$\text{Weight} : 7.3 \times 16 \times 2 + 75 = 308.6 \quad 310 \text{ kg/support}$$

$$\text{Wind pressure} : \{0.027 \times 16 \times (1+0.3) + 0.33\} \times 126 = 112.3$$

120 kg/support

132 kV double tension string

$$\text{Weight} : 7.3 \times 17 \times 2 \times 2 + 119 = 615.4 \quad 620 \text{ kg/support}$$

$$\text{Wind pressure} : \{0.027 \times 17 \times (1+0.3) \times 2 + 0.47\} \times 126 = 209.6$$

210 kg/support

(d) Safety factor

Normal condition 1.8

Abnormal condition 1.2

(e) Slenderness ratio

- (i) Less than 200 for main posts and main members of crossarms
- (ii) Less than 220 for compression members other than (i)
- (iii) Less than 250 for redundant members used for reinforcing compression members

(f) Effective buckling length ratio

Main post	1.0
Bracing	0.9

(g) Weight ratio of plates and bolts

	Suspension tower	Tension tower
Upper side of waist	0.3	0.3
Lower side of waist	0.15	0.15
Crossarm	0.3	0.35

(3) Calculation Results

Calculation results are as shown in the pages listed hereunder.

AS : TLG-1-39 to TLG-1-44
A : TLG-1-45 to TLG-1-50
AL : TLG-1-51 to TLG-1-56
B : TLG-1-57 to TLG-1-62
C : TLG-1-63 to TLG-1-68
D : TLG-1-69 to TLG-1-75
DR : TLG-1-76 to TLG-1-82
A4 : TLG-1-83 to TLG-1-91
D4 : TLG-1-92 to TLG-1-100
DR4 : TLG-1-101 to TLG-1-110

TOWER TYPE AS			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 250 \times 10^{-3}$	500
	C ₁₋₃	$25.30 \times 2 \times 81 \times 250 \times 10^{-3}$	1,225
	Ins.	200	
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 1.5^\circ \times 2$	199
	C ₁₋₃	$4,000 \times \sin 1.5^\circ \times 2 \times 2$	419
Conductor and Insulator Weight (Wc)	G.W.	1.136×250	284
	C ₁₋₃	$1.239 \times 2 \times 250$	1,020
	Ins.	400	
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240

TOWER BODY

(AS)

UNIT STRESS		STRESS																						
		HTA				HC				Ha				P		WT	E	E'	No.					
		S	F	G	C1-3	G	C1-3	G	C1-3	G	C1-3	G	C1-3	q	Wc					Va				
No.	G	C1	C2	C3	Tc	HT	S	F	G	C1-3	G	C1-3	G	C1-3	G	C1-3	q	Wc	Va	WT	E	E'	No.	
1	0.30	0.00	0.00	0.00	0.00	16	42	2	148	0	59	0	338	0	142	57	194	0	0	0	0	0	0	1
2	0.88	0.00	0.00	0.00	0.00	86	187	9	439	0	175	0	1003	0	652	177	1245	0	0	0	0	0	0	2
3	1.56	0.41	0.00	0.00	0.41	270	653	33	778	497	310	170	1777	975	652	177	1342	0	0	0	0	0	0	3
4	2.32	1.20	0.00	0.00	1.20	574	1348	67	1160	1468	462	502	2647	2876	652	177	1433	0	0	0	0	0	0	4
5	3.12	2.02	0.00	0.00	2.02	1035	2156	108	1557	2478	620	847	3553	4856	0	1162	297	2405	0	0	0	0	0	5
6	3.87	2.81	0.38	0.00	3.18	1622	3188	159	1935	3900	771	1334	4416	6741	0	1162	297	2336	0	0	0	0	0	6
7	4.53	3.49	1.11	0.00	4.50	2268	4297	215	2261	5629	901	1925	5160	8368	0	1162	297	2656	0	0	0	0	0	7
8	5.21	4.20	1.88	0.00	6.07	3099	5535	277	2602	7436	1036	2543	5938	10068	0	1671	417	3673	0	0	0	0	0	8
9	5.51	4.59	2.51	0.42	7.52	3898	6646	332	2751	9211	1095	3150	6278	11026	0	1671	417	3861	0	0	0	0	0	9
10	5.25	4.52	2.84	1.17	8.53	4477	7216	361	2622	10442	1044	3571	5984	10840	0	1671	417	4073	0	0	0	0	0	10
11	5.04	4.45	3.11	1.77	9.34	5218	7683	384	2518	11434	1003	3910	5748	10691	0	1671	417	4402	0	0	0	0	0	11
12	4.87	4.40	3.34	2.27	10.01	6200	8066	403	2432	12256	969	4191	5551	10567	0	1671	417	4897	0	0	0	0	0	12
1	0.58	0.00	0.00	0.00	0.00	32	80	4	289	0	115	0	659	0	1275	0	0	0	0	0	0	0	0	1
2	0.57	0.00	0.00	0.00	0.00	106	201	10	283	0	113	0	646	0	1250	0	0	0	0	0	0	0	0	2
3	0.62	0.64	0.00	0.00	0.64	204	555	28	308	783	123	268	702	1534	4886	0	0	0	0	0	0	0	0	3
4	0.59	0.62	0.00	0.00	0.62	279	537	27	297	756	118	258	678	1481	4812	0	0	0	0	0	0	0	0	4
5	0.62	0.64	0.00	0.00	0.64	418	670	33	309	786	123	269	705	1540	5006	0	0	0	0	0	0	0	0	5
6	0.55	0.57	0.62	0.00	1.19	498	930	46	276	1462	110	500	629	1490	4469	0	0	0	0	0	0	0	0	6
7	0.53	0.55	0.60	0.00	1.16	577	901	45	267	1416	106	484	610	1443	4328	0	0	0	0	0	0	0	0	7
8	0.55	0.58	0.62	0.00	1.20	742	1040	52	277	1468	110	502	632	1496	4489	0	0	0	0	0	0	0	0	8
9	-0.21	-0.06	0.28	0.61	0.83	381	435	22	-106	1011	-42	346	-241	1473	4103	0	0	0	0	0	0	0	0	9
10	-0.17	-0.05	0.22	0.49	0.65	472	346	17	-84	800	-33	273	-191	1165	3246	0	0	0	0	0	0	0	0	10
11	-0.14	-0.04	0.18	0.40	0.54	612	281	14	-69	656	-27	224	-157	956	2663	0	0	0	0	0	0	0	0	11
12	-0.11	-0.03	0.14	0.32	0.43	799	225	11	-55	526	-22	180	-136	767	2136	0	0	0	0	0	0	0	0	12

(AS)

No.	DESIGN STRESS		MAX	SIZE	Lk	L/r	STRENGTH	S.F	WT	No.	
	NML	A.NML DIAG.WIND									
		(U1)	(U2)	U2/U1							
1	618	641	610	641	140	119	3914	6.11	775	1	
2	2784	2537	2810	2810	140	119	3914	1.39	4,980	2	
3	4230	4024	4366	4366	200	84	25175	5.77	5,369	3	
4	6495	6279	6790	6790	200	84	25175	3.71	5,734	4	
5	10508	10294	11091	11091	240	101	17518	1.58	9,618	5	
6	13716	13706	14665	14665	200	67	51642	3.52	10,145	6	
7	17312	17206	18634	18634	200	67	51642	2.77	10,623	7	
8	22754	21991	24595	24595	240	81	41812	1.70	14,692	8	
9	26387	25067	28726	28726	163	55	59099	2.06	15,443	9	
10	28678	26477	31345	31345	197	66	52396	1.67	16,291	10	
11	30958	27905	34058	34058	260	88	42891	1.26	17,606	11	
12	33436	29482	37114	37114	167	56	69456	1.87	19,586	12	
1	439	1371	0	1371	124	141	1675	1.22		1	
2	512	1475	0	1475	125	128	2241	1.52		2	
3	1713	4878	0	4878	143	105	6110	1.25		3	
4	1735	4763	0	4763	146	106	6013	1.26		4	
5	1938	5115	0	5115	160	108	6324	1.24		5	
6	2892	4949	0	4949	151	102	6764	1.37		6	
7	2896	4857	0	4857	153	103	6664	1.37		7	
8	3152	5205	0	5205	167	106	6949	1.34		8	
9	1612	4283	0	4283	215	121	6652	1.55		9	
10	1446	3504	0	3504	131	123	4990	1.42		10	
11	1410	3023	0	3023	169	147	3842	1.27		11	
12	1439	2631	0	2631	215	145	3930	1.49		12	

CROSSARM

(AS)

UNIT STRESS												STRENGTH OF MEMBER					
AH	AP	AV	G	Hc	Ha	P	Va	Wc	DESIGN STRESS		MAX	L	L/r	STRENGTH (U2)	S.F	U2/U1	
									NML	A.NML							UI
C				1225	419	4800	240	1020									
M	0.53	1.26	264	105	3466	144	358	4338	0	4338	0	353	181	5495	1.27		
G S	0.00	0.00	1.35	0	0	154	384	539	0	539	0	379	213	2210	4.10		
X	0.00	0.33	0.00	0	754	0	0	0	505	505	0	164	187	950	1.88		
M				622	213	13416	575	2443	17269	0	17269	0	571	172	24404	1.41	
C 1 S	0.00	0.00	2.45	0	0	589	2501	3089	0	3089	0	587	200	66173	21.42		
X	0.00	0.80	0.00	0	3918	0	0	0	2558	2558	0	170	134	4003	1.56		
M				624	214	12238	331	1408	14815	0	14815	0	663	169	19284	1.30	
C 2 S	0.00	0.00	1.47	0	0	354	1503	1857	0	1857	0	708	205	66173	35.63		
X	0.00	0.71	0.00	0	3394	0	0	0	2274	2274	0	184	145	3412	1.50		
M				627	214	11231	328	1391	13791	0	13791	0	655	167	19742	1.43	
C 3 S	0.00	0.00	1.45	0	0	350	1488	1838	0	1838	0	700	204	66173	36.01		
X	0.00	0.63	0.00	0	3030	0	0	0	2030	2030	0	198	156	2942	1.45		

CROSSARM (IN TOWER BODY)

UNIT STRESS												STRENGTH OF MEMBER				
AH	AP	AV	G	Hc	Ha	P	Va	Wc	DESIGN STRESS		MAX	L	L/r	STRENGTH (U2)	S.F	U2/U1
									NML	A.NML						
C				1225	419	4800	240	1020								
M	0.00	0.72	1.19	0	1636	136	339	474	1414	1414	0	233	119	12188	8.62	
G S	0.17	0.00	0.42	87	35	0	47	118	287	0	287	233	195	4585	15.98	
SF	0.00	0.00	1.19	0	0	135	337	472	0	472	0	236	199	4585	9.72	
SS	0.00	0.00	0.42	0	0	48	120	168	0	168	0	233	195	1168	6.95	
M				566	191	6600	566	2403	2969	6411	6411	240	62	76000	11.85	
C 1 S	0.09	0.00	0.43	111	38	0	103	437	689	0	689	240	202	4585	6.65	
SF	0.00	0.00	2.36	0	0	567	2410	2977	0	2977	0	236	199	4585	1.54	
SS	0.00	0.00	0.42	0	0	101	430	531	0	531	0	236	199	1131	2.13	
M				325	1381	1706	5163	5163	5163	5163	5163	260	65	57750	11.19	
C 2 S	0.10	0.00	0.27	122	42	0	65	276	505	0	505	260	218	4585	9.07	
SF	0.00	0.00	1.36	0	0	327	1389	1715	0	1715	0	253	212	4585	2.67	
SS	0.00	0.00	0.26	0	0	63	258	331	0	331	0	253	212	990	2.99	
M				320	1359	1679	4801	4801	4801	4801	4801	280	71	57750	12.03	
C 3 S	0.11	0.00	0.29	134	46	0	70	297	547	0	547	280	204	8226	15.03	
SF	0.00	0.00	1.34	0	0	322	1367	1689	0	1689	0	273	215	7483	4.43	
SS	0.00	0.00	0.28	0	0	68	289	358	0	358	0	273	215	1553	4.34	

FOUNDATION

(AS)

UNIT STRESS														STRESS													
No.	G	C1	C2	C3	TC	HT	HTA			HC			Ha			P			Wc	Va	WT	E	E'	No.			
							S	F	G	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G							CI-3	G	CI-3
							1.0	0.05	500	1225	199	419	1140	2400													
C	5.29	4.49	2.66	0.83	7.97	4099	6860	343	2640	9762	1052	3339	6026	10766	0	1671	417	3861	0	0	0	0	0	0			
T	5.29	4.49	2.66	0.83	7.97	4099	6860	343	2640	9762	1052	3339	6026	10766	0	0	0	-3861	0	0	0	0	0	0			
9 Qf	0.50	0.50	0.50	0.50	1.50	743	0	114	250	1837	99	628	0	2674	0	0	0	0	0	0	0	0	0	9			
Qs	0.50	0.50	0.50	0.50	1.50	743	2288	0	0	0	0	0	570	1200	2674	0	0	0	0	0	0	0	0	0			
QBf	-0.14	-0.04	0.18	0.40	0.54	248	0	16	-69	559	-27	225	0	2674	0	0	0	0	0	0	0	0	0	0			
QBs	-0.14	-0.04	0.18	0.40	0.54	248	316	0	0	0	0	0	-157	960	2674	0	0	0	0	0	0	0	0	0			
C	5.06	4.42	2.95	1.47	8.84	4726	7369	368	2529	10824	1007	3702	5772	10606	0	1671	417	4073	0	0	0	0	0	0			
T	5.06	4.42	2.95	1.47	8.84	4726	7369	368	2529	10824	1007	3702	5772	10606	0	0	0	-4073	0	0	0	0	0	0			
10 Qf	0.50	0.50	0.50	0.50	1.50	884	0	114	250	1837	99	628	0	2154	0	0	0	0	0	0	0	0	0	10			
Qs	0.50	0.50	0.50	0.50	1.50	884	2288	0	0	0	0	0	570	1200	2154	0	0	0	0	0	0	0	0	0			
QBf	-0.11	-0.03	0.14	0.32	0.43	313	0	13	-56	531	-22	191	0	2154	0	0	0	0	0	0	0	0	0	0			
QBs	-0.11	-0.03	0.14	0.32	0.43	313	255	0	0	0	0	0	-127	773	2154	0	0	0	0	0	0	0	0	0			
C	4.88	4.36	3.19	2.02	9.57	5561	7798	390	2436	11719	970	4008	5559	10471	0	1671	417	4402	0	0	0	0	0	0			
T	4.88	4.36	3.19	2.02	9.57	5561	7798	390	2436	11719	970	4008	5559	10471	0	0	0	-4402	0	0	0	0	0	0			
11 Qf	0.50	0.50	0.50	0.50	1.50	1065	0	114	250	1837	99	528	0	1716	0	0	0	0	0	0	0	0	0	11			
Qs	0.50	0.50	0.50	0.50	1.50	1065	2288	0	0	0	0	0	570	1200	1716	0	0	0	0	0	0	0	0	0			
QBf	-0.09	-0.03	0.12	0.26	0.35	394	0	10	-44	423	-18	145	0	1716	0	0	0	0	0	0	0	0	0	0			
QBs	-0.09	-0.03	0.12	0.26	0.35	394	203	0	0	0	0	0	-101	616	1716	0	0	0	0	0	0	0	0	0			
C	4.72	4.32	3.39	2.46	10.16	6662	8146	407	2360	12444	940	4256	5386	10362	0	1671	417	4897	0	0	0	0	0	0			
T	4.72	4.32	3.39	2.46	10.16	6662	8146	407	2360	12444	940	4256	5386	10362	0	0	0	-4897	0	0	0	0	0	0			
12 Qf	0.50	0.50	0.50	0.50	1.50	1313	0	114	250	1837	99	628	0	1361	0	0	0	0	0	0	0	0	0	12			
Qs	0.50	0.50	0.50	0.50	1.50	1313	2288	0	0	0	0	0	570	1200	1361	0	0	0	0	0	0	0	0	0			
QBf	-0.07	-0.02	0.09	0.20	0.27	509	0	8	-35	335	-14	115	0	1361	0	0	0	0	0	0	0	0	0	0			
QBs	-0.07	-0.02	0.09	0.20	0.27	509	161	0	0	0	0	0	-80	488	1361	0	0	0	0	0	0	0	0	0			

LOAD FOR FOUNDATION

(AS)

No.		DESIGN STRESS			MAX	WT	No.
		NML	A.NML	DIAG.WIND	(UI)		
9	C	27184	25426	29630	29630	15,443	9
	T	17374	18854	19820	19820		
	Qf	3672	4252	2337	0		
	Qs	3031	4627	1018	0		
	QBf	1052	2497	695	0		
	QBs	564	2813	228	0		
10	C	29318	26749	32131	32131	16,291	10
	T	19084	19892	21898	21898		
	Qf	3813	3998	2478	0		
	Qs	3172	4372	1102	0		
	QBf	961	2087	673	0		
	QBs	568	2342	252	0		
11	C	31573	28169	34880	34880	17,606	11
	T	20682	20872	23989	23989		
	Qf	3994	3826	2659	0		
	Qs	3353	4200	1211	0		
	QBf	910	1759	681	0		
	QBs	597	1962	287	0		
12	C	34053	29758	38015	38015	19,586	12
	T	22171	21797	26133	26133		
	Qf	4242	3753	2906	0		
	Qs	3601	4128	1360	0		
	QBf	918	1526	736	0		
	QBs	670	1687	345	0		

TOWER TYPE A			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 400 \times 10^{-3}$	799
	C ₁₋₃	$25.30 \times 2 \times 81 \times 400 \times 10^{-3}$	1,839
	Ins.	200	
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 1.5^\circ \times 2$	199
	C ₁₋₃	$4,000 \times \sin 1.5^\circ \times 2 \times 2$	419
Conductor and Insulator Weight (Wc)	G.W.	1.136×400	454
	C ₁₋₃	$1.239 \times 2 \times 400$	1,391
	Ins.	400	
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.05$	190
	C ₁₋₃	$4,000 \times 2 \times 0.05$	400

(A)

No.	DESIGN STRESS		MAX	SIZE	Lk	L/r	STRENGTH	S.F	WT	No.	
	NML	A.NML									
	DIAG.WIND (U1)										
	(U2) U2/U1										
1	837	787	813	837	L 65* 6	140	110	5882	7.03	789	1
2	3460	2990	3447	3460	L 65* 6	140	110	5882	1.70	5,017	2
3	5383	4797	5408	5408	L120* 8	200	84	25175	4.66	5,406	3
4	8401	7556	8459	8459	L120* 8	200	84	25175	2.98	5,771	4
5	13472	12280	13699	13699	L120* 8	240	101	17518	1.28	9,655	5
6	17678	16361	18114	18114	L150*10	200	67	51642	2.85	10,182	6
7	22398	20613	23020	23020	L150*10	200	67	51642	2.24	10,660	7
8	29292	26371	30248	30248	L150*10	240	81	41812	1.38	14,729	8
9	33948	30126	35232	35232	L150*10	164	55	59059	1.68	15,481	9
10	36759	31871	38272	38272	L150*10	197	66	52348	1.37	16,330	10
11	39512	33605	41392	41392	L175*12	260	76	63597	1.54	17,778	11
12	42495	35510	44941	44941	L175*12	173	50	85368	1.90	19,991	12
13	45902	37717	49176	49176	L175*12	222	64	74275	1.51	23,263	13
1	619	1389	0	1389	L 45* 4	124	141	1675	1.21		1
2	697	1509	0	1509	L 50* 4	125	128	2241	1.48		2
3	2316	4936	0	4936	L 70* 6	143	105	6110	1.24		3
4	2323	4823	0	4823	L 70* 6	146	106	6013	1.25		4
5	2560	5189	0	5189	L 75* 6	160	108	6324	1.22		5
6	3838	5566	0	5566	L 75* 6	151	102	6754	1.22		6
7	3819	5459	0	5459	L 75* 6	153	103	6664	1.22		7
8	4121	5769	0	5769	L 80* 6	167	106	6949	1.20		8
9	2037	4298	0	4298	L 90* 6	215	121	6635	1.54		9
10	1790	3515	0	3515	L 70* 6	132	123	4969	1.41		10
11	1718	3044	0	3044	L 75* 6	169	147	3817	1.25		11
12	1756	2707	0	2707	L 75* 6	220	149	3738	1.38		12
13	1897	2477	0	2477	L 90* 6	281	158	4014	1.62		13

CROSSARM

(A)

UNIT STRESS										DESIGN STRESS MAX										STRENGTH OF MEMBER									
AH	AP	AV	G	Hc	Ha	P	Va	Wc	454	NML	A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F. U2/U1												
C 1839										400										1391									
M	0.53	1.52	1.26	423	105	3466	240	574	4808	0	4808	0	L120* 8	353	148	8082	1.68												
S	0.00	0.00	1.35	0	0	0	257	615	872	0	872	0	L 90* 6	379	213	2210	2.53												
X	0.00	0.33	0.00	0	0	754	0	0	0	505	505	0	L 45* 4	164	187	950	1.88												
M	0.51	2.80	2.40	935	213	13416	958	3333	18855	0	18855	0	L200*20	671	172	24404	1.29												
S	0.00	0.00	2.45	0	0	0	981	3412	4393	0	4393	0	L175*12	687	200	63725	14.51												
X	0.00	0.80	0.00	0	0	3818	0	0	0	2558	2558	0	L 65* 6	170	134	4003	1.56												
M	0.51	2.55	1.38	938	214	12238	552	1921	15863	0	15863	0	L200*15	663	169	19284	1.22												
S	0.00	0.00	1.47	0	0	0	590	2051	2641	0	2641	0	L175*12	708	206	56173	25.05												
X	0.00	0.71	0.00	0	0	3394	0	0	0	2274	2274	0	L 65* 6	184	145	3412	1.50												
M	0.51	2.34	1.36	941	214	11231	546	1899	14831	0	14831	0	L200*15	655	167	19742	1.33												
S	0.00	0.00	1.46	0	0	0	584	2030	2614	0	2614	0	L175*12	700	204	66173	25.32												
X	0.00	0.63	0.00	0	0	3030	0	0	0	2030	2030	0	L 65* 6	198	156	2942	1.45												

CROSSARM (IN TOWER BODY)

UNIT STRESS										DESIGN STRESS MAX										STRENGTH OF MEMBER									
AH	AP	AV	G	Hc	Ha	P	Va	Wc	454	NML	A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F. U2/U1												
C 1839										400										1391									
M	0.00	0.72	1.19	0	0	1636	226	542	768	1611	1611	0	L120* 8	233	98	15113	9.38												
S	0.17	0.00	0.42	139	35	0	79	189	441	0	441	0	L 60* 4	233	195	4585	10.39												
SF	0.00	0.00	1.19	0	0	0	225	539	764	0	764	0	L 60* 4	236	199	4585	6.00												
SS	0.00	0.00	0.42	0	0	0	80	192	272	0	272	0	L 60* 4	233	195	1168	4.30												
M	0.00	1.38	2.36	0	0	5600	943	3279	4222	7251	7251	0	L200*20	240	62	76000	10.48												
S	0.09	0.00	0.43	167	38	0	171	596	973	0	973	0	L 60* 4	240	202	4585	4.71												
SF	0.00	0.00	2.36	0	0	0	945	3289	4234	0	4234	0	L 55* 6	236	186	6691	1.58												
SS	0.00	0.00	0.42	0	0	0	169	587	756	0	756	0	L 60* 4	236	199	1131	1.50												
M	0.00	1.25	1.35	0	0	6000	542	1884	2426	5645	5645	0	L200*15	250	66	57750	10.23												
S	0.10	0.00	0.27	184	42	0	108	377	711	0	711	0	L 60* 4	250	218	4585	6.45												
SF	0.00	0.00	1.36	0	0	0	545	1895	2440	0	2440	0	L 60* 4	253	212	4585	1.88												
SS	0.00	0.00	0.26	0	0	0	105	366	471	0	471	0	L 60* 4	253	212	990	2.10												
M	0.00	1.14	1.33	0	0	5486	533	1855	2388	5276	5276	0	L200*15	280	71	57750	10.95												
S	0.11	0.00	0.29	201	46	0	117	406	769	0	769	0	L 70* 6	280	204	8226	10.69												
SF	0.00	0.00	1.34	0	0	0	536	1866	2402	0	2402	0	L 65* 6	273	215	7483	3.12												
SS	0.00	0.00	0.28	0	0	0	114	395	508	0	508	0	L 65* 6	273	215	1553	3.05												

FOUNDATION

(A)

UNIT STRESS														STRESS													
No.	G	C1	C2	C3	Tc	HT	HTA			HC			Ha			P	q	Wc	Va	VT	E'	E	No.				
							S	F	G	CI-3	G	CI-3	G	CI-3	G									CI-3	G	CI-3	G
							1.0	0.05	799	1839	199	419	1140	2400													
C	5.27	4.48	2.65	0.83	7.95	4447	7540	377	4315	14630	1049	3331	6012	10742	0	2314	695	3870	0	0	0	0	0				
T	5.27	4.48	2.65	0.83	7.95	4447	7540	377	4315	14630	1049	3331	6012	10742	0	0	0	-3870	0	0	0	0	0				
9	Qf	0.50	0.50	0.50	1.50	803	0	125	400	2759	99	628	0	0	2668	0	0	0	0	0	0	0	9				
	Qs	0.50	0.50	0.50	1.50	803	2491	0	0	0	0	0	570	1200	2668	0	0	0	0	0	0	0	0				
	QBf	-0.14	-0.05	0.18	0.40	0.53	260	0	16	-115	974	-29	222	0	2668	0	0	0	0	0	0	0	0				
	QBs	-0.14	-0.05	0.18	0.40	0.53	260	325	0	0	0	0	-164	958	2668	0	0	0	0	0	0	0	0				
C	5.04	4.40	2.93	1.47	8.80	5106	8062	403	4031	16192	1003	3687	5749	10564	0	2314	695	4083	0	0	0	0	0				
T	5.04	4.40	2.93	1.47	8.80	5106	8062	403	4031	16192	1003	3687	5749	10564	0	0	0	-4083	0	0	0	0	10				
10	Qf	0.50	0.50	0.50	1.50	954	0	125	400	2759	99	628	0	0	2146	0	0	0	0	0	0	0	0				
	Qs	0.50	0.50	0.50	1.50	954	2491	0	0	0	0	0	570	1200	2146	0	0	0	0	0	0	0	0				
	QBf	-0.12	-0.04	0.14	0.32	0.43	331	0	13	-92	783	-23	178	0	2146	0	0	0	0	0	0	0	0				
	QBs	-0.12	-0.04	0.14	0.32	0.43	331	262	0	0	0	0	-132	770	2146	0	0	0	0	0	0	0	0				
C	4.85	4.34	3.17	2.01	9.52	6005	8501	425	3876	17506	965	3986	5528	10414	0	2314	695	4445	0	0	0	0	0				
T	4.85	4.34	3.17	2.01	9.52	6005	8501	425	3876	17506	965	3986	5528	10414	0	0	0	-4445	0	0	0	0	0				
11	Qf	0.50	0.50	0.50	1.50	1159	0	125	400	2759	99	628	0	0	1706	0	0	0	0	0	0	0	11				
	Qs	0.50	0.50	0.50	1.50	1159	2491	0	0	0	0	0	570	1200	1706	0	0	0	0	0	0	0	0				
	QBf	-0.09	-0.03	0.11	0.26	0.34	426	0	10	-73	623	-18	142	0	1706	0	0	0	0	0	0	0	0				
	QBs	-0.09	-0.03	0.11	0.26	0.34	426	208	0	0	0	0	-105	613	1706	0	0	0	0	0	0	0	0				
C	4.69	4.29	3.37	2.45	10.11	7260	8865	443	3747	18595	933	4234	5345	10290	0	2314	695	4998	0	0	0	0	0				
T	4.69	4.29	3.37	2.45	10.11	7260	8865	443	3747	18595	933	4234	5345	10290	0	0	0	-4998	0	0	0	0	0				
12	Qf	0.50	0.50	0.50	1.50	1450	0	125	400	2759	99	628	0	0	1342	0	0	0	0	0	0	0	12				
	Qs	0.50	0.50	0.50	1.50	1450	2491	0	0	0	0	0	570	1200	1342	0	0	0	0	0	0	0	0				
	QBf	-0.07	-0.02	0.09	0.20	0.27	564	0	8	-58	490	-14	112	0	1342	0	0	0	0	0	0	0	0				
	QBs	-0.07	-0.02	0.09	0.20	0.27	564	164	0	0	0	0	-82	482	1342	0	0	0	0	0	0	0	0				
C	4.56	4.25	3.53	2.80	10.58	8969	9152	458	3646	19455	908	4430	5201	10192	0	2314	695	5816	0	0	0	0	0				
T	4.56	4.25	3.53	2.80	10.58	8969	9152	458	3646	19455	908	4430	5201	10192	0	0	0	-5816	0	0	0	0	0				
13	Qf	0.50	0.50	0.50	1.50	1859	0	125	400	2759	99	628	0	0	1054	0	0	0	0	0	0	0	13				
	Qs	0.50	0.50	0.50	1.50	1859	2491	0	0	0	0	0	570	1200	1054	0	0	0	0	0	0	0	0				
	QBf	-0.06	-0.02	0.07	0.16	0.21	764	0	6	-45	385	-11	88	0	1054	0	0	0	0	0	0	0	0				
	QBs	-0.06	-0.02	0.07	0.16	0.21	764	129	0	0	0	0	-65	378	1054	0	0	0	0	0	0	0	0				

LOAD FOR FOUNDATION

(A)

No.		DESIGN STRESS			MAX	WT	No.
		NML	A.NML	DIAG.WIND (U1)			
9	C	34928	30599	36278	36278	15,481	9
	T	24179	23397	25529	25529		
	Qf	4814	5013	3203	0		
	Qs	3294	4799	1104	0		
	QBf	1328	2678	908	0		
	QBs	585	2822	237	0		
	<hr/>						
10	C	37514	32212	39150	39150	16,330	10
	T	26340	24725	27976	27976		
	Qf	4965	4764	3354	0		
	Qs	3445	4550	1195	0		
	QBf	1189	2235	852	0		
	QBs	592	2350	264	0		
<hr/>							
11	C	40216	33922	42299	42299	17,778	11
	T	28318	25950	30401	30401		
	Qf	5170	4607	3559	0		
	Qs	3650	4393	1318	0		
	QBf	1109	1887	841	0		
	QBs	634	1979	308	0		
<hr/>							
12	C	43219	35851	45978	45978	19,991	12
	T	30214	27138	32974	32974		
	Qf	5461	4558	3850	0		
	Qs	3941	4344	1493	0		
	QBf	1101	1637	890	0		
	QBs	728	1710	379	0		
<hr/>							
13	C	46690	38111	50415	50415	23,263	13
	T	32050	28302	35774	35774		
	Qf	5870	4639	4259	0		
	Qs	4350	4425	1738	0		
	QBf	1186	1501	1020	0		
	QBs	893	1558	491	0		

TOWER TYPE AL			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 500 \times 10^{-3}$	999
	C ₁₋₃	$25.30 \times 2 \times 81 \times 500 \times 10^{-3}$	
	Ins.	200	2,249
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 1.5^\circ \times 2$	199
	C ₁₋₃	$4,000 \times \sin 1.5^\circ \times 2 \times 2$	419
Conductor and Insulator Weight (Wc)	G.W.	1.136×500	568
	C ₁₋₃	$1.239 \times 2 \times 500$	
	Ins.	400	1,639
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240

TOWER BODY

(AL)

UNIT STRESS

STRESS

No.	G	C1	C2	C3	Tc	HT	HTA			HC			Ha			P	q	WC	Va	WT	E	E' No.
							S	F	G	CI-3	G	CI-3	G	CI-3	G							
							1.0	0.05	999	2249	199	419	1140	2400								
1	0.30	0.00	0.00	0.00	0.00	19	54	3	295	0	59	0	338	0	0	284	57	197	0	0	0	1
2	0.88	0.00	0.00	0.00	0.00	98	229	11	879	0	175	0	1003	0	0	1104	177	1254	0	0	0	2
3	1.56	0.41	0.00	0.00	0.41	306	756	38	1537	914	310	170	1777	975	0	1104	177	1366	0	0	0	3
4	2.32	1.20	0.00	0.00	1.20	650	1532	77	2319	2696	462	502	2647	2876	0	1104	177	1469	0	0	0	4
5	3.12	2.02	0.00	0.00	2.02	1173	2430	122	3113	4551	620	847	3553	4856	0	1923	297	2626	0	0	0	5
6	3.87	2.81	0.38	0.00	3.18	1838	3566	178	3870	7163	771	1334	4416	6741	0	1923	297	2761	0	0	0	6
7	4.53	3.49	1.11	0.00	4.60	2566	4779	239	4522	10339	901	1925	5160	8368	0	1923	297	2885	0	0	0	7
8	5.21	4.20	1.88	0.00	6.07	3500	6133	307	5204	13658	1036	2543	5938	10658	0	2743	417	3911	0	0	0	8
9	5.48	4.58	2.53	0.47	7.59	4438	7387	369	5476	17064	1090	3177	6249	10939	0	2743	417	4163	0	0	0	9
10	5.18	4.48	2.89	1.30	8.68	5189	8027	401	5175	19622	1030	3635	5905	10761	0	2743	417	4457	0	0	0	10
11	4.95	4.41	3.17	1.93	9.51	6167	8517	426	4946	21386	985	3982	5644	10531	0	2743	417	4916	0	0	0	11
12	4.77	4.35	3.39	2.42	10.16	7478	8902	445	4767	22845	949	4254	5440	10440	0	2743	417	5581	0	0	0	12
13	4.63	4.30	3.55	2.80	10.66	9237	9200	460	4628	23930	922	4465	5281	10331	0	2743	417	6636	0	0	0	13
1	0.58	0.00	0.00	0.00	0.00	37	103	5	577	0	115	0	659	0	1275	0	0	0	0	0	0	1
2	0.57	0.00	0.00	0.00	0.00	120	237	12	566	0	113	0	646	0	1250	0	0	0	0	0	0	2
3	0.62	0.64	0.00	0.00	0.64	230	620	31	615	1338	123	268	702	1534	4986	0	0	0	0	0	0	3
4	0.59	0.62	0.00	0.00	0.62	317	599	30	594	1388	118	258	678	1481	4812	0	0	0	0	0	0	4
5	0.62	0.64	0.00	0.00	0.64	474	742	37	618	1444	123	269	705	1540	5006	0	0	0	0	0	0	5
6	0.55	0.57	0.62	0.00	1.19	563	1018	51	552	2685	110	500	629	1490	4469	0	0	0	0	0	0	6
7	0.53	0.55	0.60	0.00	1.16	650	987	49	534	2600	106	484	610	1443	4328	0	0	0	0	0	0	7
8	0.55	0.58	0.62	0.00	1.20	833	1136	57	554	2697	110	502	532	1496	4489	0	0	0	0	0	0	8
9	-0.24	-0.08	0.28	0.65	0.85	453	454	23	-235	1921	-47	358	-269	1552	4324	0	0	0	0	0	0	9
10	-0.18	-0.06	0.22	0.49	0.65	583	348	17	-178	1455	-36	271	-204	1176	3275	0	0	0	0	0	0	10
11	-0.14	-0.05	0.17	0.38	0.50	775	271	14	-139	1135	-28	211	-159	917	2554	0	0	0	0	0	0	11
12	-0.11	-0.04	0.13	0.30	0.39	1041	211	11	-109	837	-22	165	-124	717	1936	0	0	0	0	0	0	12
13	-0.08	-0.03	0.16	0.23	0.31	1400	164	8	-84	687	-17	128	-96	535	1545	0	0	0	0	0	0	13

(AL)

No.	DESIGN STRESS		MAX	SIZE	LK	L/F	STRENGTH	S.F	WT	No.	
	NML	A.NML									DIAG.WIND (U1)
1	915	839	876	915	L 65* 6	140	110	5882	6.43	789	1
2	3699	3150	3641	3699	L 65* 6	140	110	5882	1.59	5,017	2
3	5940	5170	5847	5940	L130* 9	200	78	34366	5.79	5,464	3
4	9456	8263	9282	9456	L130* 9	200	78	34366	3.63	5,877	4
5	15272	13486	15153	15272	L130* 9	240	93	24760	1.62	10,502	5
6	20135	18007	20084	20135	L150*10	200	67	51642	2.56	11,046	6
7	25596	22756	25571	25596	L150*10	200	67	51642	2.02	11,539	7
8	33319	29069	33463	33463	L150*10	240	81	41812	1.25	15,645	8
9	38938	33457	39289	39289	L175*12	195	57	80742	2.06	16,553	9
10	42570	35732	43121	43121	L175*12	240	70	69498	1.61	17,829	10
11	45968	37888	46918	46918	L175*12	154	45	89036	1.90	19,665	11
12	49479	40146	51068	51068	L175*12	200	58	79598	1.56	22,324	12
13	53488	42758	56018	56018	L175*15	254	74	80543	1.44	26,542	13
1	734	1389	0	1389	L 45* 4	124	141	1675	1.21		1
2	810	1509	0	1509	L 50* 4	125	128	2241	1.48		2
3	2705	5153	0	5153	L 75* 6	143	97	7079	1.37		3
4	2705	5037	0	5037	L 75* 6	146	98	6982	1.39		4
5	2965	5340	0	5340	L 80* 6	160	101	7246	1.36		5
6	4460	5982	0	5982	L 80* 6	151	95	7687	1.28		6
7	4424	5864	0	5864	L 80* 6	153	97	7587	1.29		7
8	4754	6193	0	6193	L 90* 6	167	94	8814	1.42		8
9	2472	4553	0	4553	L 90* 6	239	134	5567	1.22		9
10	2113	3610	0	3610	L 75* 6	150	130	4862	1.35		10
11	1968	3030	0	3030	L 70* 6	193	141	3910	1.29		11
12	1973	2660	0	2660	L 80* 6	249	157	3574	1.34		12
13	2122	2457	0	2457	L 90* 6	318	178	3150	1.28		13

CROSSARM

(AL)

UNIT STRESS										DESIGN STRESS					STRENGTH OF MEMBER				
AH		AP	AV	G	Hc	Ha	P	Va	Wc	MAX	NML		A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F U2/UI
		C		C 2249		419		4800		240		1639							
M	0.53	1.52	1.26	529	105	3466	144	717	4961	0	4961	0	4961	L120* 8	353	148	8082	1.63	
S	0.00	0.00	1.35	0	0	0	154	759	923	0	923	0	923	L 90* 6	379	213	2210	2.39	
X	0.00	0.33	0.00	0	0	754	0	0	0	505	505	0	505	L 45* 4	164	187	950	1.88	
M	0.51	2.80	2.40	1143	213	13416	575	3927	19274	0	19274	0	19274	L200*20	671	172	24404	1.27	
S	0.00	0.00	2.45	0	0	0	589	4020	4609	0	4609	0	4609	L175*12	687	200	61277	13.30	
X	0.00	0.80	0.00	0	0	3818	0	0	0	2558	2558	0	2558	L 65* 6	170	134	4003	1.56	
M	0.51	2.55	1.38	1147	214	12238	331	2263	16193	0	16193	0	16193	L200*20	663	170	24992	1.54	
S	0.00	0.00	1.47	0	0	0	354	2417	2771	0	2771	0	2771	L175*12	708	206	66173	23.88	
X	0.00	0.71	0.00	0	0	3394	0	0	0	2274	2274	0	2274	L 65* 6	184	145	3412	1.50	
M	0.51	2.34	1.36	1151	214	11231	328	2237	15161	0	15161	0	15161	L200*15	655	167	19742	1.30	
S	0.00	0.00	1.46	0	0	0	350	2392	2742	0	2742	0	2742	L175*12	700	204	66173	24.13	
X	0.00	0.63	0.00	0	0	3030	0	0	0	2030	2030	0	2030	L 65* 6	198	155	2942	1.45	

CROSSARM (IN TOWER BODY)

UNIT STRESS										DESIGN STRESS					STRENGTH OF MEMBER				
AH		AP	AV	G	Hc	Ha	P	Va	Wc	MAX	NML		A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F U2/UI
		C		C 2249		419		4800		240		1639							
M	0.00	0.72	1.19	174	35	1636	136	677	813	1641	1641	0	1641	L120* 8	233	98	15113	9.21	
S	0.17	0.00	0.42	0	0	0	47	236	492	0	492	0	492	L 60* 4	233	195	4585	9.32	
SF	0.00	0.00	1.19	0	0	0	135	673	808	0	808	0	808	L 60* 4	236	199	4585	5.67	
SS	0.00	0.00	0.42	0	0	0	48	240	288	0	288	0	288	L 60* 4	233	195	1168	4.06	
M	0.00	1.38	2.36	204	38	6600	566	3863	4429	7389	7389	0	7389	L200*20	240	62	76000	10.28	
S	0.09	0.00	0.43	0	0	0	103	702	1048	0	1048	0	1048	L 60* 4	240	202	4585	4.38	
SF	0.00	0.00	2.36	0	0	0	567	3874	4442	0	4442	0	4442	L 65* 6	236	186	6691	1.51	
SS	0.00	0.00	0.42	0	0	0	101	691	793	0	793	0	793	L 60* 4	236	199	1131	1.43	
M	0.00	1.25	1.35	225	42	6000	325	2219	2544	5725	5725	0	5725	L200*20	260	67	76000	13.28	
S	0.10	0.00	0.27	0	0	0	65	444	776	0	776	0	776	L 60* 4	260	218	4585	5.91	
SF	0.00	0.00	1.36	0	0	0	327	2232	2559	0	2559	0	2559	L 60* 4	253	212	4585	1.79	
SS	0.00	0.00	0.26	0	0	0	63	431	494	0	494	0	494	L 60* 4	253	212	990	2.00	
M	0.00	1.14	1.33	246	46	5486	320	2185	2505	5354	5354	0	5354	L200*15	280	71	57750	10.79	
S	0.11	0.00	0.29	0	0	0	70	478	840	0	840	0	840	L 70* 6	280	204	8226	9.79	
SF	0.00	0.00	1.34	0	0	0	322	2198	2520	0	2520	0	2520	L 65* 6	273	215	7483	2.97	
SS	0.00	0.00	0.28	0	0	0	68	465	533	0	533	0	533	L 65* 6	273	215	1553	2.91	

LOAD FOR FOUNDATION

(AL)

No.		DESIGN STRESS			MAX	WT	No.
		NML	A.NML DIAG.WIND (U1)				
9	C	40264	34148	40657	40657	16,653	9
	T	28778	26452	29171	29171		
	Qf	5571	5459	3781	0		
	Qs	3336	4766	1130	0		
	QBf	1475	2715	1027	0		
	QBs	582	2736	240	0		
10	C	43556	36220	44246	44246	17,829	10
	T	31483	28131	32173	32173		
	Qf	5760	5205	3970	0		
	Qs	3525	4511	1243	0		
	QBf	1297	2214	948	0		
	QBs	601	2231	275	0		
11	C	46811	38296	48005	48005	19,665	11
	T	33819	29592	35012	35012		
	Qf	6012	5076	4222	0		
	Qs	3777	4383	1394	0		
	QBf	1206	1856	934	0		
	QBs	664	1869	332	0		
12	C	50290	40546	52251	52251	22,324	12
	T	35968	30950	37930	37930		
	Qf	6353	5071	4563	0		
	Qs	4118	4378	1599	0		
	QBf	1203	1621	991	0		
	QBs	781	1631	417	0		
13	C	54354	43206	57412	57412	26,542	13
	T	37923	32197	40982	40982		
	Qf	6820	5204	5031	0		
	Qs	4586	4511	1879	0		
	QBf	1302	1507	1137	0		
	QBs	973	1515	544	0		

TOWER TYPE B			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 300 \times 10^{-3}$	599
	C ₁₋₃	$25.30 \times 2 \times 81 \times 300 \times 10^{-3}$	1,500
	Ins.	270	
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 7.5^\circ \times 2$	992
	C ₁₋₃	$4,000 \times \sin 7.5^\circ \times 2 \times 2$	2,088
Conductor and Insulator Weight (Wc)	G.W.	1.136×300	341
	C ₁₋₃	$1.239 \times 2 \times 300$	1,533
	Ins.	790	
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240

TOWER BODY

(B)

UNIT STRESS		STRESS																									
		HTA				HC				Ha				P													
		S	F	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3										
No.	G	CI	C2	C3	Tc	HT	S	F	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3	α	Wc	Va	Wt	E	E	No.		
							1.0	0.05	599	1500	992	2088	1900	4000													
1	0.35	0.00	0.00	0.00	0.00	26	28	1	209	0	346	0	663	0	170	57	157	0	0	0	0	0	0	0	0	0	1
2	1.02	0.00	0.00	0.00	0.00	119	88	4	612	0	1013	0	1940	0	170	57	210	0	0	0	0	0	0	0	0	0	2
3	1.71	0.00	0.00	0.00	0.00	322	200	10	1024	0	1695	0	3246	0	937	177	926	0	0	0	0	0	0	0	0	0	3
4	2.56	0.55	0.00	0.00	0.55	773	602	30	1537	831	2544	1157	4872	2216	937	177	1136	0	0	0	0	0	0	0	0	0	4
5	3.35	1.44	0.00	0.00	1.44	1371	1123	56	2009	2162	3325	3011	6369	5767	1704	297	1853	0	0	0	0	0	0	0	0	0	5
6	4.05	2.23	0.50	0.00	2.73	2180	1827	91	2428	4099	4019	5709	7697	8921	1704	297	2112	0	0	0	0	0	0	0	0	0	6
7	4.70	2.96	1.31	0.00	4.27	3124	2593	130	2817	6409	4662	8926	8929	11845	2471	417	2791	0	0	0	0	0	0	0	0	0	7
8	4.87	3.32	1.85	0.38	5.56	3889	3184	159	2918	8335	4830	11608	9251	13283	2471	417	3082	0	0	0	0	0	0	0	0	0	8
9	4.54	3.35	2.21	1.08	6.64	4546	3557	178	2722	9962	4506	13874	8630	13389	2471	417	3446	0	0	0	0	0	0	0	0	0	9
10	4.28	3.37	2.50	1.63	7.50	5455	3849	192	2567	11251	4249	15659	8138	13473	2471	417	4024	0	0	0	0	0	0	0	0	0	10
11	4.08	3.38	2.72	2.06	8.17	6724	4078	204	2447	12252	4049	17053	7756	13539	2471	417	4969	0	0	0	0	0	0	0	0	0	11
1	0.60	0.00	0.00	0.00	0.00	45	46	2	361	0	597	0	1143	0	1519	0	0	0	0	0	0	0	0	0	0	0	1
2	0.57	0.00	0.00	0.00	0.00	117	58	3	343	0	568	0	1087	0	1444	0	0	0	0	0	0	0	0	0	0	0	2
3	0.58	0.00	0.00	0.00	0.00	218	120	6	349	0	577	0	1105	0	1468	0	0	0	0	0	0	0	0	0	0	0	3
4	0.65	0.74	0.00	0.00	0.74	418	398	20	391	1104	648	1537	1241	2945	1468	0	0	0	0	0	0	0	0	0	0	0	4
5	0.50	0.57	0.00	0.00	0.57	482	371	19	302	853	500	1188	959	2275	1519	0	0	0	0	0	0	0	0	0	0	0	5
6	0.56	0.63	0.70	0.00	1.33	732	630	31	336	1997	556	2782	1065	2799	5689	0	0	0	0	0	0	0	0	0	0	0	6
7	0.45	0.50	0.56	0.00	1.06	758	564	28	267	1587	442	2210	846	2224	4519	0	0	0	0	0	0	0	0	0	0	0	7
8	-0.27	0.02	0.30	0.58	0.91	414	288	14	-164	1366	-272	1902	-521	2340	4335	0	0	0	0	0	0	0	0	0	0	0	8
9	-0.22	0.02	0.24	0.46	0.72	569	224	11	-130	1077	-215	1500	-411	1845	3418	0	0	0	0	0	0	0	0	0	0	0	9
10	-0.17	0.01	0.18	0.35	0.55	774	172	9	-99	826	-165	1150	-315	1415	2622	0	0	0	0	0	0	0	0	0	0	0	10
11	-0.13	0.01	0.14	0.27	0.43	1080	132	7	-77	639	-127	890	-244	1095	2028	0	0	0	0	0	0	0	0	0	0	0	11

(B)

NO.	DESIGN STRESS		MAX	SIZE	LK	L/Γ	STRENGTH	S.F	WT	NO.
	NML	A.NML								
1	968	1092	944	1092	180	102	11036	10.10	630	1
2	2186	2764	2144	2764	180	102	11036	3.99	841	2
3	5091	5586	5119	5586	220	124	7503	1.34	3,706	3
4	9123	9377	9266	9377	170	72	31327	3.34	4,544	4
5	15789	14845	16074	16074	220	93	20827	1.30	7,413	5
6	22640	21146	23138	23138	170	57	57912	2.50	8,448	6
7	31748	29207	32482	32482	220	74	46919	1.44	11,165	7
8	37708	34164	38661	38661	190	55	81859	2.12	12,326	8
9	42122	37192	43279	43279	260	76	63489	1.47	13,784	9
10	46295	40045	47845	47845	171	50	85865	1.79	16,095	10
11	50595	42970	52790	52790	232	68	71443	1.35	19,875	11
1	1005	1845	0	1845	143	120	2989	1.62		1
2	1031	1814	0	1814	146	123	2882	1.59		2
3	1150	1951	0	1951	162	136	2417	1.24		3
4	4118	7198	0	7198	204	103	10386	1.44		4
5	3344	5670	0	5670	172	97	8574	1.51		5
6	6435	8123	0	8123	212	108	9921	1.22		6
7	5292	6573	0	6573	183	103	8077	1.23		7
8	3260	5089	0	5089	260	132	7429	1.46		8
9	2812	4174	0	4174	173	125	6300	1.51		9
10	2495	3428	0	3428	227	143	4304	1.26		10
11	2411	2975	0	2975	303	171	3955	1.33		11

CROSSARM

(B)

UNIT STRESS										STRENGTH OF MEMBER							
AH	AP	AV	G	Hc	Ha	P	Va	Wc	MAX	DESIGN STRESS	MAX	U1	SIZE	L	L/r	STRENGTH (U2)	S.F. U2/U1
				C 1500	2088	8000	240	1533									
M	0.58	0.97	0.67	350	579	3677	76	228	4910	0	4910	0	L 90* 7	240	136	6295	1.28
G S	0.00	0.00	0.83	0	0	0	95	283	378	0	378	0	L 70* 6	299	218	1620	4.29
X	0.00	0.12	0.00	0	0	441	0	0	296	0	296	0	L 45* 4	176	200	833	2.82
M	0.52	1.82	1.16	780	1086	14560	278	1776	18480	0	18480	0	L200*15	510	130	32628	1.77
C 1 S	0.00	0.00	1.27	0	0	0	305	1948	2253	0	2253	0	L130* 9	559	217	34999	15.54
X	0.00	0.44	0.00	0	0	3536	0	0	2369	0	2369	0	L 65* 6	198	156	2942	1.24
M	0.53	1.61	1.14	789	1098	12894	273	1741	16795	0	16795	0	L175*15	500	146	22348	1.33
C 2 S	0.00	0.00	1.25	0	0	0	300	1915	2215	0	2215	0	L130* 9	550	214	34999	15.80
X	0.00	0.36	0.00	0	0	2920	0	0	1956	0	1956	0	L 65* 6	219	173	2400	1.23
M	0.53	1.44	1.11	799	1113	11539	267	1709	15428	0	15428	0	L175*12	490	143	18941	1.23
C 3 S	0.00	0.00	1.23	0	0	0	295	1885	2180	0	2180	0	L130* 9	541	210	34999	15.06
X	0.00	0.30	0.00	0	0	2412	0	0	1616	0	1616	0	L 65* 6	240	189	1995	1.23

CROSSARM (IN TOWER BODY)

UNIT STRESS										STRENGTH OF MEMBER							
AH	AP	AV	G	Hc	Ha	P	Va	Wc	MAX	DESIGN STRESS	MAX	U1	SIZE	L	L/r	STRENGTH (U2)	S.F. U2/U1
				C 1500	2088	8000	240	1533									
M	0.00	0.41	0.57	0	0	1574	65	195	260	1229	1229	0	L 90* 7	248	140	5394	4.80
G S	0.30	0.00	0.35	181	299	0	39	118	637	0	637	0	L 60* 4	248	209	4585	7.20
SF	0.00	0.00	0.56	0	0	0	64	190	254	0	254	0	L 60* 4	258	217	4585	18.07
SS	0.00	0.00	0.36	0	0	0	41	122	163	0	163	0	L 60* 4	248	209	1023	6.27
M	0.00	0.88	1.11	0	0	7000	267	1708	1975	6013	6013	0	L200*15	280	71	57750	9.60
C 1 S	0.14	0.00	0.32	214	298	0	76	488	1077	0	1077	0	L 70* 6	280	204	8226	7.64
SF	0.00	0.00	1.13	0	0	0	271	1729	1999	0	1999	0	L 65* 6	268	211	7483	3.74
SS	0.00	0.00	0.30	0	0	0	73	467	540	0	540	0	L 65* 6	268	211	1606	2.97
M	0.00	0.77	1.08	0	0	6129	259	1655	1914	5389	5389	0	L175*15	310	91	43145	8.01
C 2 S	0.16	0.00	0.35	245	341	0	85	540	1210	0	1210	0	L 75* 6	310	209	8968	7.41
SF	0.00	0.00	1.09	0	0	0	262	1676	1939	0	1939	0	L 70* 6	298	218	8226	4.24
SS	0.00	0.00	0.34	0	0	0	81	519	601	0	601	0	L 70* 6	298	218	1632	2.72
M	0.00	0.68	1.05	0	0	5412	251	1603	1854	4868	4868	0	L175*12	340	99	32289	6.63
C 3 S	0.18	0.00	0.39	277	386	0	93	592	1348	0	1348	0	L 80* 6	340	215	9711	7.20
SF	0.00	0.00	1.06	0	0	0	254	1624	1878	0	1878	0	L 80* 6	328	208	9711	5.17
SS	0.00	0.00	0.37	0	0	0	89	572	661	0	661	0	L 80* 6	328	208	2056	3.11

FOUNDATION

(B)

UNIT STRESS		STRESS																E'	No.							
		HTA				HC				Ha				P												
		G	C1	C2	C3	Tc	HT	S	F	G	C1-3	G	C1-3	G	C1-3	G	C1-3			G	C1-3	G	C1-3	q	Wc	Va
		1.0	0.05	599	1500	992	2088	1900	4000																	
C	4.59	3.26	2.01	0.75	6.03	4072	3310	166	2750	9036	4551	12585	8717	13056	0	2471	417	3082	0	0	0	0	0	0	0	0
T	4.59	3.26	2.01	0.75	6.03	4072	3310	166	2750	9036	4551	12585	8717	13056	0	0	0	-3082	0	0	0	0	0	0	0	0
8 Qf	0.50	0.50	0.50	0.50	1.50	880	0	71	300	2249	496	3133	0	0	2876	0	0	0	0	0	0	0	0	0	0	8
Qs	0.50	0.50	0.50	0.50	1.50	880	1413	0	0	0	0	0	950	2000	2876	0	0	0	0	0	0	0	0	0	0	0
QBf	-0.18	0.01	0.20	0.39	0.60	275	0	11	-109	906	-181	1262	0	0	2876	0	0	0	0	0	0	0	0	0	0	0
QBs	-0.18	0.01	0.20	0.39	0.60	275	214	0	0	0	0	0	-346	1552	2876	0	0	0	0	0	0	0	0	0	0	0
C	4.30	3.29	2.33	1.36	6.98	4825	3648	182	2578	10462	4267	14571	8173	13149	0	2471	417	3446	0	0	0	0	0	0	0	0
T	4.30	3.29	2.33	1.36	6.98	4825	3648	182	2578	10462	4267	14571	8173	13149	0	0	0	-3446	0	0	0	0	0	0	0	0
9 Qf	0.50	0.50	0.50	0.50	1.50	1084	0	71	300	2249	496	3133	0	0	2203	0	0	0	0	0	0	0	0	0	0	9
Qs	0.50	0.50	0.50	0.50	1.50	1084	1413	0	0	0	0	0	950	2000	2203	0	0	0	0	0	0	0	0	0	0	0
QBf	-0.14	0.01	0.15	0.30	0.46	366	0	8	-84	694	-138	967	0	0	2203	0	0	0	0	0	0	0	0	0	0	0
QBs	-0.14	0.01	0.15	0.30	0.46	366	164	0	0	0	0	0	-265	1189	2203	0	0	0	0	0	0	0	0	0	0	0
C	4.08	3.31	2.57	1.83	7.71	5851	3907	195	2446	11558	4049	16097	7755	13221	0	2471	417	4024	0	0	0	0	0	0	0	0
T	4.08	3.31	2.57	1.83	7.71	5851	3907	195	2446	11558	4049	16097	7755	13221	0	0	0	-4024	0	0	0	0	0	0	0	0
10 Qf	0.50	0.50	0.50	0.50	1.50	1367	0	71	300	2249	496	3133	0	0	1686	0	0	0	0	0	0	0	0	0	0	10
Qs	0.50	0.50	0.50	0.50	1.50	1367	1413	0	0	0	0	0	950	2000	1686	0	0	0	0	0	0	0	0	0	0	0
QBf	-0.11	0.01	0.12	0.23	0.35	498	0	6	-64	531	-106	740	0	0	1686	0	0	0	0	0	0	0	0	0	0	0
QBs	-0.11	0.01	0.12	0.23	0.35	498	126	0	0	0	0	0	-203	910	1686	0	0	0	0	0	0	0	0	0	0	0
C	3.91	3.32	2.76	2.20	8.28	7309	4111	206	2343	12421	3877	17299	7425	13277	0	2471	417	4969	0	0	0	0	0	0	0	0
T	3.91	3.32	2.76	2.20	8.28	7309	4111	206	2343	12421	3877	17299	7425	13277	0	0	0	-4969	0	0	0	0	0	0	0	0
11 Qf	0.50	0.50	0.50	0.50	1.50	1768	0	71	300	2249	496	3133	0	0	1279	0	0	0	0	0	0	0	0	0	0	11
Qs	0.50	0.50	0.50	0.50	1.50	1768	1413	0	0	0	0	0	950	2000	1279	0	0	0	0	0	0	0	0	0	0	0
QBf	-0.08	0.01	0.09	0.17	0.27	681	0	5	-49	403	-80	561	0	0	1279	0	0	0	0	0	0	0	0	0	0	0
QBs	-0.08	0.01	0.09	0.17	0.27	681	95	0	0	0	0	0	-154	690	1279	0	0	0	0	0	0	0	0	0	0	0

LOAD FOR FOUNDATION

(B)

No.	DESIGN STRESS			MAX	WT	No.
	NML	A.NML DIAG. WIND (U1)				
8	C	39129	34964	40115	12,326	8
	T	30078	28900	31064		
	Qf	7128	6703	2809		
	Qs	2292	4803	881		
	QBf	2164	3377	875		
	QBs	489	3294	218		
9	C	43219	37767	44495	13,784	9
	T	33439	31214	34715		
	Qf	7332	6389	3013		
	Qs	2496	4489	1003		
	QBf	1814	2691	826		
	QBs	531	2628	261		
10	C	47109	40421	48876	16,095	10
	T	36173	33094	37941		
	Qf	7616	6232	3297		
	Qs	2780	4332	1174		
	QBf	1605	2205	850		
	QBs	623	2157	330		
11	C	51310	43274	53855	19,875	11
	T	38485	34681	41030		
	Qf	8016	6228	3697		
	Qs	3180	4328	1414		
	QBf	1521	1876	948		
	QBs	776	1840	432		

TOWER TYPE C			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 350 \times 10^{-3}$	699
	C ₁₋₃	$25.30 \times 2 \times 81 \times 350 \times 10^{-3}$	
	Ins.	270	1,705
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 17.5^\circ \times 2$	2,285
	C ₁₋₃	$4,000 \times \sin 17.5^\circ \times 2 \times 2$	4,811
Conductor and Insulator Weight (Wc)	G.W.	1.136×350	398
	C ₁₋₃	$1.239 \times 2 \times 350$	
	Ins.	790	1,657
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240

TOWER BODY

(C)

UNIT STRESS		STRESS																		
		HTA			HC			Hs			P									
		S	F	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3	g	WC	Va	WT	E	E	No.
		1.0	0.05	699	1705	2285	4811	1900	4000											
1	0.35	0.00	0.00	0.00	0.00	0.00	0.00	243	0	794	0	660	0	199	57	218	0	0	0	1
2	1.02	0.00	0.00	0.00	0.00	0.00	0.00	8	712	0	2326	0	1934	0	199	57	281	0	0	2
3	1.71	0.00	0.00	0.00	0.00	0.00	0.00	17	1194	0	3901	0	3243	0	1027	177	1283	0	0	3
4	2.35	0.31	0.00	0.00	0.31	0.00	0.00	34	1644	531	5372	1498	4466	1245	1027	177	1423	0	0	4
5	2.89	0.91	0.00	0.00	0.91	0.00	0.00	56	2020	1559	6603	4400	5490	3658	1027	177	1551	0	0	5
6	3.45	1.54	0.00	0.00	1.54	0.00	0.00	81	2411	2624	7878	7406	6550	6157	1856	297	2473	0	0	6
7	3.97	2.13	0.28	0.00	2.41	0.00	0.00	113	2778	4106	9077	11591	7547	8508	1856	297	2670	0	0	7
8	4.41	2.62	0.83	0.00	3.45	0.00	0.00	146	3087	5884	10087	16610	8386	10488	1856	297	2847	0	0	8
9	4.87	3.14	1.40	0.00	4.54	0.00	0.00	182	3409	7738	11141	21842	9262	12553	2685	417	3823	0	0	9
10	5.03	3.48	1.93	0.38	5.80	0.00	0.00	219	3517	9884	11493	27898	9555	13923	2685	417	4232	0	0	10
11	4.67	3.47	2.28	1.08	6.83	0.00	0.00	241	3263	11640	10662	32856	8864	13883	2685	417	4693	0	0	11
12	4.38	3.46	2.55	1.63	7.64	0.00	0.00	258	3061	13031	10005	36781	8318	13852	2685	417	5400	0	0	12
13	4.15	3.46	2.76	2.06	8.28	0.00	0.00	271	2905	14111	9494	39830	7893	13827	2685	417	5523	0	0	13
1	0.60	0.00	0.00	0.00	0.00	0.00	0.00	4	421	0	1374	0	1143	0	1828	0	0	0	0	1
2	0.57	0.00	0.00	0.00	0.00	0.00	0.00	5	401	0	1310	0	1089	0	1743	0	0	0	0	2
3	0.58	0.00	0.00	0.00	0.00	0.00	0.00	9	409	0	1336	0	1110	0	1777	0	0	0	0	3
4	0.52	0.58	0.00	0.00	0.58	0.00	0.00	21	353	992	1188	2801	988	2328	5821	0	0	0	0	4
5	0.50	0.56	0.00	0.00	0.56	0.00	0.00	20	349	952	1140	2688	948	2234	5586	0	0	0	0	5
6	0.51	0.57	0.00	0.00	0.57	0.00	0.00	24	355	968	1159	2733	963	2272	5680	0	0	0	0	6
7	0.46	0.51	0.57	0.00	1.08	0.00	0.00	34	320	1842	1046	5198	870	2271	5127	0	0	0	0	7
8	0.44	0.49	0.55	0.00	1.04	0.00	0.00	33	309	1776	1009	5013	839	2190	4945	0	0	0	0	8
9	0.45	0.50	0.56	0.00	1.06	0.00	0.00	37	313	1801	1023	5084	851	2221	5015	0	0	0	0	9
10	-0.31	-0.01	0.29	0.58	0.86	0.00	0.00	17	-213	1474	-697	4161	-580	2340	4817	0	0	0	0	10
11	-0.24	-0.01	0.23	0.46	0.68	0.00	0.00	13	-168	1162	-550	3281	-457	1845	3798	0	0	0	0	11
12	-0.18	-0.01	0.17	0.35	0.52	0.00	0.00	10	-129	892	-422	2516	-350	1415	2913	0	0	0	0	12
13	-0.14	-0.00	0.13	0.27	0.40	0.00	0.00	8	-100	690	-326	1947	-271	1095	2254	0	0	0	0	13

(C)

No.	DESIGN STRESS		MAX	SIZE	Lk	L/R	STRENGTH	S.F.	WT	No.
	NML	A.NML DIAG.WIND (U1)								
1	1542	1475	1521	1542	180	91	13970	9.06	874	1
2	3713	3783	3684	3783	180	91	13970	3.69	1,125	2
3	7949	7499	8013	7499	220	112	10361	1.29	5,134	3
4	12376	11284	12542	12542	180	61	55883	4.46	5,592	4
5	18446	16037	18688	18688	180	61	55883	2.99	6,203	5
6	26610	22217	27035	27035	220	74	46923	1.74	9,891	6
7	34711	28957	35338	35338	180	52	83954	2.38	10,679	7
8	43705	36310	44508	44508	180	52	83954	1.89	11,389	8
9	54970	45241	56065	56065	220	64	74659	1.33	15,294	9
10	64960	52852	66352	66352	190	48	123657	1.86	16,927	10
11	71797	57406	73445	73445	260	65	103537	1.41	18,772	11
12	77974	61523	80076	80076	171	43	128049	1.60	21,598	12
13	83967	65522	86796	86796	232	59	112247	1.29	26,093	13
1	1849	2464	0	2464	143	120	2979	1.21		1
2	1845	2404	0	2404	146	124	3511	1.46		2
3	1989	2523	0	2523	162	127	4371	1.73		3
4	5688	7711	0	7711	154	87	9395	1.22		4
5	5551	7462	0	7462	158	89	9235	1.24		5
6	5789	7684	0	7684	172	97	9884	1.29		6
7	9077	9517	0	9517	166	84	12389	1.30		7
8	8862	9251	0	9251	169	86	12198	1.32		8
9	9151	9491	0	9491	183	93	11461	1.21		9
10	5202	6712	0	6712	260	133	10168	1.51		10
11	4362	5467	0	5467	173	126	7255	1.33		11
12	3715	4441	0	4441	227	127	6114	1.38		12
13	3407	3793	0	3793	303	154	5460	1.44		13

CROSSARM

(C)

UNIT STRESS										DESIGN STRESS				MAX				STRENGTH OF MEMBER			
AH	AP	AV	AV	G	Hc	Ha	P	Va	Vc	Wc	NML	A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F U2/U1			
C										1705	4811	8000	240	1657							
M	0.55	1.21	0.84	384	1255	4592	96	334	334	334	6660	0	6660	L120* 8	302	127	11063	1.66			
G S	0.00	0.00	0.97	0	0	0	111	386	386	386	497	0	497	L 90* 6	350	196	2597	5.22			
X	0.00	0.21	0.00	0	0	806	0	0	0	0	0	540	540	L 45* 4	177	201	822	1.52			
M	0.52	2.06	1.31	878	2480	16492	315	2174	2174	2174	22340	0	22340	L200*20	577	148	32958	1.48			
C 1 S	0.00	0.00	1.41	0	0	0	339	2341	2341	2341	2681	0	2681	L150*10	522	209	46429	17.32			
X	0.00	0.53	0.00	0	0	4243	0	0	0	0	0	2843	2843	L 70* 6	198	145	3697	1.30			
M	0.52	1.83	1.29	886	2501	14622	309	2134	2134	2134	20453	0	20453	L200*15	567	144	26393	1.29			
C 2 S	0.00	0.00	1.39	0	0	0	334	2303	2303	2303	2637	0	2637	L150*10	612	206	46429	17.61			
X	0.00	0.44	0.00	0	0	3558	0	0	0	0	0	2384	2384	L 70* 6	219	160	3016	1.25			
M	0.53	1.64	1.26	895	2526	13096	304	2096	2096	2096	18918	0	18918	L200*15	557	142	27351	1.45			
C 3 S	0.00	0.00	1.37	0	0	0	328	2267	2267	2267	2596	0	2596	L150*10	602	203	46429	17.89			
X	0.00	0.37	0.00	0	0	2995	0	0	0	0	0	2007	2007	L 70* 6	240	175	2507	1.25			

CROSSARM (IN TOWER BODY)

UNIT STRESS										DESIGN STRESS				MAX				STRENGTH OF MEMBER			
AH	AP	AV	AV	G	Hc	Ha	P	Va	Vc	Wc	NML	A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F U2/U1			
C										1705	4811	8000	240	1657							
M	0.00	0.55	0.76	159	519	2090	87	304	304	304	391	1662	1662	L120* 8	250	105	14062	8.46			
G S	0.23	0.00	0.35	0	0	0	40	138	138	138	856	0	856	L 60* 4	250	210	4585	5.36			
SF	0.00	0.00	0.75	0	0	0	86	299	299	299	384	0	384	L 60* 4	259	218	4585	11.94			
SS	0.00	0.00	0.36	0	0	0	41	143	143	143	184	0	184	L 60* 4	250	210	1010	5.48			
M	0.00	1.00	1.27	213	601	8000	305	2109	2109	2109	2415	6978	6978	L200*20	280	72	76000	10.89			
C 1 S	0.13	0.00	0.32	0	0	0	76	527	527	527	1418	0	1418	L 70* 6	280	204	8226	5.80			
SF	0.00	0.00	1.29	0	0	0	309	2131	2131	2131	2439	0	2439	L 65* 6	269	212	7483	3.07			
SS	0.00	0.00	0.31	0	0	0	73	506	506	506	579	0	579	L 65* 6	269	212	1598	2.76			
M	0.00	0.88	1.24	242	684	7032	297	2053	2053	2053	2350	6286	6286	L200*15	310	79	54801	8.72			
C 2 S	0.14	0.00	0.35	0	0	0	85	584	584	584	1595	0	1595	L 75* 6	310	209	8968	5.62			
SF	0.00	0.00	1.25	0	0	0	300	2074	2074	2074	2375	0	2375	L 70* 6	299	218	8226	3.46			
SS	0.00	0.00	0.34	0	0	0	81	562	562	562	644	0	644	L 70* 6	299	218	1625	2.52			
M	0.00	0.78	1.20	273	772	6235	289	1996	1996	1996	2285	5709	5709	L200*15	340	87	51442	9.01			
C 3 S	0.16	0.00	0.39	0	0	0	93	640	640	640	1778	0	1778	L 80* 6	340	215	9711	5.46			
SF	0.00	0.00	1.22	0	0	0	292	2018	2018	2018	2310	0	2310	L 80* 6	329	208	9711	4.20			
SS	0.00	0.00	0.37	0	0	0	90	619	619	619	709	0	709	L 80* 6	329	208	2048	2.89			

FOUNDATION

(C)

No.	UNIT STRESS											STRESS											
	HTA					HC			Ha			P					q	We	Va	WT	E	L'	No.
	G	CI	C2	C3	Tc	HT	S	F	G	CI-3	G	CI-3	G	CI-3	G	CI-3							
	1.0	0.05	699	1705	2285	4811	1900	4000															
C	4.72	3.40	2.08	0.75	6.23	4813	4526	226	3304	10621	10798	29981	8977	13604	0	2685	417	4232	0	0	0	0	0
T	4.72	3.40	2.08	0.75	6.23	4813	4526	226	3304	10621	10798	29981	8977	13604	0	0	0	-4232	0	0	0	0	0
10 Qf	0.50	0.50	0.50	0.50	1.50	1021	1846	0	350	2557	1143	7217	0	0	0	0	0	0	0	0	0	0	10
QS	0.50	0.50	0.50	0.50	1.50	1021	1846	0	0	0	0	0	950	2000	3196	0	0	0	0	0	0	0	0
QBf	-0.20	-0.01	0.19	0.39	0.57	305	305	13	-141	978	-462	2760	0	0	0	0	0	0	0	0	0	0	0
QBS	-0.20	-0.01	0.19	0.39	0.57	305	250	0	0	0	0	0	-384	1552	3196	0	0	0	0	0	0	0	0
C	4.41	3.39	2.38	1.36	7.13	5639	4920	246	3081	12160	10070	34325	8372	13569	0	2685	417	4693	0	0	0	0	0
T	4.41	3.39	2.38	1.36	7.13	5639	4920	246	3081	12160	10070	34325	8372	13569	0	0	0	-4693	0	0	0	0	0
11 Qf	0.50	0.50	0.50	0.50	1.50	1241	0	92	350	2557	1143	7217	0	0	2448	0	0	0	0	0	0	0	11
QS	0.50	0.50	0.50	0.50	1.50	1241	1846	0	0	0	0	0	950	2000	2448	0	0	0	0	0	0	0	0
QBf	-0.16	-0.00	0.15	0.30	0.44	402	0	10	-108	749	-354	2115	0	0	2448	0	0	0	0	0	0	0	0
QBS	-0.16	-0.00	0.15	0.30	0.44	402	192	0	0	0	0	0	-295	1189	2448	0	0	0	0	0	0	0	0
C	4.16	3.39	2.61	1.83	7.83	6763	5223	261	2910	13343	9511	37664	7907	13542	0	2685	417	5400	0	0	0	0	0
T	4.16	3.39	2.61	1.83	7.83	6763	5223	261	2910	13343	9511	37664	7907	13542	0	0	0	-5400	0	0	0	0	0
12 Qf	0.50	0.50	0.50	0.50	1.50	1550	0	92	350	2557	1143	7217	0	0	1873	0	0	0	0	0	0	0	12
QS	0.50	0.50	0.50	0.50	1.50	1550	1846	0	0	0	0	0	950	2000	1873	0	0	0	0	0	0	0	0
QBf	-0.12	-0.00	0.11	0.23	0.34	545	0	7	-83	573	-271	1618	0	0	1873	0	0	0	0	0	0	0	0
QBS	-0.12	-0.00	0.11	0.23	0.34	545	147	0	0	0	0	0	-225	910	1873	0	0	0	0	0	0	0	0
C	3.97	3.38	2.79	2.20	8.37	8369	5461	273	2776	14274	9071	40292	7541	13521	0	2685	417	6523	0	0	0	0	0
T	3.97	3.38	2.79	2.20	8.37	8369	5461	273	2776	14274	9071	40292	7541	13521	0	0	0	-6523	0	0	0	0	0
13 Qf	0.50	0.50	0.50	0.50	1.50	1994	0	92	350	2557	1143	7217	0	0	1421	0	0	0	0	0	0	0	13
QS	0.50	0.50	0.50	0.50	1.50	1994	1846	0	0	0	0	0	950	2000	1421	0	0	0	0	0	0	0	0
QBf	-0.09	-0.00	0.09	0.17	0.26	750	0	6	-63	435	-208	1228	0	0	1421	0	0	0	0	0	0	0	0
QBS	-0.09	-0.00	0.09	0.17	0.26	750	111	0	0	0	0	0	-171	690	1421	0	0	0	0	0	0	0	0

LOAD FOR FOUNDATION

(c)

No.		DESIGN STRESS			MAX	WT	No.
		NML	A.NML DIAG.WIND (U1)				
10	C	67077	54056	68521	68521	16,927	10
	T	55512	46308	56955	56955		
	Qf	12379	10435	3224	0		
	Qs	2867	5402	1074	0		
	QBf	3452	4454	936	0		
	QBs	555	3553	246	0		
11	C	73317	58214	75104	75104	18,772	11
	T	60829	49847	62616	62616		
	Qf	12599	10081	3443	0		
	Qs	3087	5048	1206	0		
	QBf	2813	3525	885	0		
	QBs	594	2835	289	0		
12	C	78954	61973	81299	81299	21,598	12
	T	65053	52659	67398	67398		
	Qf	12909	9904	3753	0		
	Qs	3396	4871	1392	0		
	QBf	2390	2856	914	0		
	QBs	691	2328	364	0		
13	C	84679	65794	87896	87896	26,093	13
	T	68531	54975	71748	71748		
	Qf	13352	9898	4197	0		
	Qs	3840	4865	1658	0		
	QBf	2149	2392	1030	0		
	QBs	861	1992	478	0		

TOWER TYPE D			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 300 \times 10^{-3}$	599
	C ₁₋₃	$25.30 \times 2 \times 81 \times 300 \times 10^{-3}$	
	Ins.	270	1,500
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 30^{\circ} \times 2$	3,800
	C ₁₋₃	$4,000 \times \sin 30^{\circ} \times 2 \times 2$	8,000
Conductor and Insulator Weight (Wc)	G.W.	1.136×300	341
	C ₁₋₃	$1.239 \times 2 \times 300$	
	Ins.	790	1,533
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240

TOWER BODY

(D)

UNIT STRESS													STRESS												
No.	G	C1	C2	C3	Tc	HT	HTA			HC			Hc			F			WT	E	E'	No.			
							S	F	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3					G	CI-3	G
							1.0	0.05	599	1500	3800	8000	1900	4000											
1	0.34	0.00	0.00	0.00	0.00	28	30	2	206	0	1308	0	854	0	170	57	185	0	0	0	0	1			
2	1.01	0.00	0.00	0.00	0.00	125	96	5	606	0	3845	0	1922	0	0	57	258	0	0	0	0	2			
3	1.70	0.00	0.00	0.00	0.00	341	215	11	1021	0	6474	0	3237	0	0	177	1008	0	0	0	0	3			
4	2.40	0.36	0.00	0.00	0.35	692	501	25	1439	544	9122	2901	4561	1451	0	177	1197	0	0	0	0	4			
5	3.05	1.08	0.00	0.00	1.08	1167	898	45	1828	1620	11588	8641	5794	4320	0	177	1377	0	0	0	0	5			
6	3.67	1.77	0.00	0.00	1.77	1781	1312	66	2300	2649	13946	14131	6973	7065	0	1704	297	2223	0	0	0	6			
7	4.24	2.39	0.33	0.00	2.72	2520	1840	92	2840	4084	16106	21787	8053	9579	0	1704	297	2529	0	0	0	7			
8	4.77	2.98	0.98	0.00	3.96	3382	2452	123	2860	5945	18130	31716	9065	11935	0	1704	297	2810	0	0	0	8			
9	5.28	3.55	1.61	0.00	5.16	4381	3070	154	3167	7737	20079	41275	10039	14203	0	2471	417	3719	0	0	0	9			
10	5.30	3.78	2.08	0.38	6.25	5208	3494	175	3177	9370	20142	49966	10071	15133	0	2471	417	4101	0	0	0	10			
11	4.55	3.47	2.26	1.06	6.79	5623	3570	179	2725	10176	17274	54287	8637	13876	0	2471	417	4676	0	0	0	11			
12	3.99	3.24	2.40	1.55	7.19	6470	3626	181	2389	10775	15144	57483	7872	12942	0	2471	417	5890	0	0	0	12			
1	0.60	0.00	0.00	0.00	0.00	48	50	3	360	0	2282	0	1141	0	1487	0	0	0	0	0	0	0	1		
2	0.58	0.00	0.00	0.00	0.00	125	65	3	345	0	2188	0	1094	0	1426	0	0	0	0	0	0	0	2		
3	0.59	0.00	0.00	0.00	0.00	233	127	6	354	0	2242	0	1121	0	1461	0	0	0	0	0	0	0	3		
4	0.55	0.61	0.00	0.00	0.61	345	334	17	331	916	2099	4887	1050	2443	0	5498	0	0	0	0	0	0	4		
5	0.54	0.59	0.00	0.00	0.59	452	324	16	321	889	2038	4743	1019	2372	0	5336	0	0	0	0	0	0	5		
6	0.51	0.57	0.00	0.00	0.57	587	368	18	307	849	1946	4531	973	2265	0	5097	0	0	0	0	0	0	6		
7	0.48	0.53	0.59	0.00	1.13	713	550	28	290	1689	1838	9013	919	2368	0	4812	0	0	0	0	0	0	7		
8	0.47	0.52	0.58	0.00	1.10	830	536	27	282	1646	1790	8780	895	2307	0	4688	0	0	0	0	0	0	8		
9	0.45	0.50	0.55	0.00	1.05	971	568	28	271	1581	1719	8433	860	2216	0	4502	0	0	0	0	0	0	9		
10	-0.64	-0.27	0.15	0.57	0.45	178	58	3	-384	684	-2431	3647	-1216	2282	0	4228	0	0	0	0	0	0	10		
11	-0.47	-0.20	0.11	0.42	0.33	425	42	2	-281	500	-1780	2669	-890	1670	0	3094	0	0	0	0	0	0	11		
12	-0.33	-0.14	0.08	0.30	0.24	778	29	1	-199	354	-1260	1889	-630	1182	0	2190	0	0	0	0	0	0	12		

(D)

No.	DESIGN STRESS		MAX	SIZE	Lk	L/r	STRENGTH	S.F.	WT	No.
	NML	A. NML DIAG. WIND (U1)								
1	1956	1749	1935	L100*10	180	92	19290	9.86	740	1
2	5067	4683	5034	L100*10	180	92	19290	3.81	1,032	2
3	9969	8848	10015	L100*10	220	113	14166	1.41	4,031	3
4	17033	14468	17178	L150*12	210	71	58526	3.41	4,787	4
5	27379	22225	27621	L150*12	220	74	55646	2.01	5,509	5
6	38996	30861	39443	L150*12	220	74	55646	1.41	8,892	6
7	51658	41029	52342	L200*15	210	53	118509	2.26	10,114	7
8	66966	52864	67898	L200*15	220	56	115778	1.71	11,241	8
9	83398	65392	84682	L200*15	220	56	115778	1.37	14,874	9
10	95045	73819	96606	L200*15	211	54	118209	1.22	16,402	10
11	97827	74841	99583	L200*15	162	41	130011	1.31	18,703	11
12	101219	76488	103442	L200*20	242	62	141402	1.37	23,560	12
1	2693	2800	0	L 60* 5	144	122	3612	1.29		1
2	2661	2738	0	L 60* 5	147	124	3497	1.28		2
3	2835	2879	0	L 65* 6	161	127	4378	1.52		3
4	8595	9442	0	L100* 7	162	82	12578	1.33		4
5	8480	9243	0	L100* 7	168	85	12240	1.32		5
6	8239	8935	0	L100* 7	172	87	12048	1.35		6
7	13570	12316	0	L100*10	173	89	16610	1.22		7
8	13355	12089	0	L100*10	179	92	16138	1.21		8
9	13004	11729	0	L100*10	183	94	15858	1.22		9
10	1697	4520	0	L100* 7	284	144	6241	1.38		10
11	1536	3504	0	L 80* 6	209	132	5058	1.44		11
12	1565	2800	0	L 90* 7	307	174	3848	1.37		12

CROSSARM

(D)

UNIT STRESS										DESIGN STRESS MAX					STRENGTH OF MEMBER			
AH	AP	AV	G	Hc	Ha	P	Va	Wc	Wc	NML	A.NML	U1	SIZE	L	L/r	STRENGTH (U ₂)	S.F	(U ₂ /U ₁)
				599	3800	3800	114	341										
			C	1500	8000	8000	240	1533										
M	0.59	0.95	0.67	353	2238	3596	76	227	6489	0	6489	0	L100*7	240	122	8748	1.35	
G S	0.00	0.00	0.83	0	0	0	95	283	377	0	377	0	L 70*6	299	218	1625	4.31	
X	0.00	0.11	0.00	0	0	408	0	0	0	273	0	273	L 45*4	179	203	801	2.94	
M	0.52	1.82	1.16	780	4160	14560	278	1776	21554	0	21554	0	L200*15	510	130	32628	1.51	
C 1 S	0.00	0.00	1.27	0	0	0	305	1946	2250	0	2250	0	L130*9	558	217	34999	15.55	
X	0.00	0.44	0.00	0	0	3536	0	0	0	2369	2369	2369	L 65*6	198	156	2942	1.24	
M	0.53	1.61	1.14	789	4208	12894	273	1741	19904	0	19904	0	L200*15	500	127	33941	1.71	
C 2 S	0.00	0.00	1.25	0	0	0	299	1913	2213	0	2213	0	L130*9	549	214	34999	15.82	
X	0.00	0.36	0.00	0	0	2920	0	0	0	1956	1956	1956	L 65*6	219	173	2400	1.23	
M	0.53	1.44	1.11	799	4264	11539	267	1709	18579	0	18579	0	L175*15	490	143	23198	1.25	
C 3 S	0.00	0.00	1.23	0	0	0	295	1883	2178	0	2178	0	L130*9	540	210	34999	16.07	
X	0.00	0.30	0.00	0	0	2412	0	0	0	1616	1616	1616	L 65*6	240	189	1995	1.23	
M	0.59	0.95	0.67	353	2238	3596	76	227	6489	0	6489	0	L100*7	240	122	8748	1.35	
G S	0.00	0.00	0.83	0	0	0	95	283	377	0	377	0	L 70*6	299	218	1625	4.31	
X	0.00	0.11	0.00	0	0	408	0	0	0	273	273	273	L 45*4	179	203	801	2.94	
M	0.50	0.88	1.11	750	4000	7000	267	1708	13725	0	13725	0	L175*12	490	142	18972	1.38	
C 1 S	0.00	0.00	1.23	0	0	0	296	1888	2184	0	2184	0	L130*9	542	211	34999	16.03	
X	0.00	0.44	0.00	0	0	3336	0	0	0	2369	2369	2369	L 65*6	198	156	2942	1.24	
M	0.50	0.77	1.08	750	4000	6129	259	1655	12793	0	12793	0	L175*12	475	138	20189	1.58	
C 2 S	0.00	0.00	1.20	0	0	0	288	1840	2128	0	2128	0	L130*9	528	205	34999	16.44	
X	0.00	0.36	0.00	0	0	2920	0	0	0	1956	1956	1956	L 65*6	219	173	2400	1.23	
M	0.50	0.68	1.05	750	4000	5412	251	1603	12016	0	12016	0	L175*12	460	134	21528	1.79	
C 3 S	0.00	0.00	1.17	0	0	0	281	1793	2074	0	2074	0	L120*8	514	216	28331	13.66	
X	0.00	0.30	0.00	0	0	2412	0	0	0	1616	1616	1616	L 65*6	240	189	1995	1.23	

CROSSARM (IN TOWER BODY)

(D)

UNIT STRESS										DESIGN STRESS				STRENGTH OF MEMBER				
AH	AP	AV	Hc	Ha	P	Va	Wc	Wc	341	MAX	MML	A-NML	U1	SIZE	L	L/r	STRENGTH (U2)	S.F (U2/U1)
G																		
M	0.00	0.40	0.57	0	0	1526	64	193	193	257	1195	1195	1195	L100* 7	253	129	7772	6.50
S	0.31	0.00	0.35	187	1183	0	40	120	120	1529	0	1529	1529	L 60* 4	253	213	4585	3.00
SF	0.00	0.00	0.55	0	0	0	63	189	189	252	0	252	252	L 60* 4	262	220	4585	18.22
SS	0.00	0.00	0.36	0	0	0	41	124	124	165	0	165	165	L 60* 4	253	213	985	5.96
C 1																		
M	0.00	0.88	1.11	0	0	7000	267	1708	1708	1975	6013	6013	6013	L200*15	280	71	57750	9.60
S	0.14	0.00	0.32	214	1143	0	76	488	488	1921	0	1921	1921	L 70* 6	280	204	8226	4.28
SF	0.00	0.00	1.13	0	0	0	270	1725	1725	1995	0	1995	1995	L 65* 6	270	212	7483	3.75
SS	0.00	0.00	0.31	0	0	0	74	470	470	544	0	544	544	L 65* 6	270	212	1584	2.91
C 2																		
M	0.00	0.77	1.08	0	0	6129	259	1655	1655	1914	5389	5389	5389	L200*15	310	79	54801	10.17
S	0.16	0.00	0.35	245	1305	0	85	540	540	2175	0	2175	2175	L 75* 6	310	209	8968	4.12
SF	0.00	0.00	1.09	0	0	0	262	1673	1673	1935	0	1935	1935	L 70* 6	300	219	8226	4.25
SS	0.00	0.00	0.34	0	0	0	82	522	522	604	0	604	604	L 70* 6	300	219	1612	2.67
C 3																		
M	0.00	0.68	1.05	0	0	5412	251	1603	1603	1854	4868	4868	4868	L175*15	340	99	39789	8.17
S	0.18	0.00	0.39	277	1478	0	93	592	592	2441	0	2441	2441	L 80* 6	340	215	9711	3.98
SF	0.00	0.00	1.06	0	0	0	254	1621	1621	1874	0	1874	1874	L 80* 6	330	209	9711	5.18
SS	0.00	0.00	0.37	0	0	0	90	575	575	665	0	665	665	L 80* 6	330	209	2033	3.06

FOUNDATION

(D)

UNIT STRESS		STRESS																						
		HTA				HC				HA				F										
		G	C1	C2	C3	Tc	Ht	S	F	G	CI-3	G	CI-3	G	CI-3	G	CI-3	q	Va	WT	E	E'	No.	
		1.0	0.05	599	1500	3800	8000	1900	4000															
C	4.70	3.48	2.11	0.74	6.33	5142	3463	173	2818	9485	17866	50601	8933	13915	0	2471	417	4101	0	0	0	0	0	0
T	4.70	3.48	2.11	0.74	6.33	5142	3463	173	2818	9485	17866	50601	8933	13915	0	2471	417	4101	0	0	0	0	0	0
10 Qf	0.50	0.50	0.50	0.50	1.50	1098	0	71	300	2249	1900	12000	0	2657	0	0	0	-4101	0	0	0	0	0	10
QS	0.50	0.50	0.50	0.50	1.50	1098	1414	0	0	0	0	0	950	2000	2657	0	0	0	0	0	0	0	0	0
QBf	-0.40	-0.17	0.10	0.36	0.29	112	0	2	-241	430	-1528	2292	0	0	2657	0	0	0	0	0	0	0	0	0
QBs	-0.40	-0.17	0.10	0.36	0.29	112	43	0	0	0	0	0	-764	1434	2657	0	0	0	0	0	0	0	0	0
C	4.07	3.22	2.26	1.30	6.77	5712	3530	176	2441	10157	15477	54185	7738	12868	0	2471	417	4676	0	0	0	0	0	0
T	4.07	3.22	2.26	1.30	6.77	5712	3530	176	2441	10157	15477	54185	7738	12868	0	2471	417	4676	0	0	0	0	0	0
11 Qf	0.50	0.50	0.50	0.50	1.50	1351	0	71	300	2249	1900	12000	0	1859	0	0	0	0	0	0	0	0	0	11
QS	0.50	0.50	0.50	0.50	1.50	1351	1414	0	0	0	0	0	950	2000	1859	0	0	0	0	0	0	0	0	0
QBf	-0.28	-0.12	0.07	0.25	0.20	255	0	1	-169	301	-1069	1604	0	0	1859	0	0	0	0	0	0	0	0	0
QBs	-0.28	-0.12	0.07	0.25	0.20	255	30	0	0	0	0	0	-535	1003	1859	0	0	0	0	0	0	0	0	0
C	3.62	3.03	2.37	1.70	7.10	6776	3578	179	2169	10641	13754	56769	6877	12112	0	2471	417	5890	0	0	0	0	0	0
T	3.62	3.03	2.37	1.70	7.10	6776	3578	179	2169	10641	13754	56769	6877	12112	0	2471	417	5890	0	0	0	0	0	0
12 Qf	0.50	0.50	0.50	0.50	1.50	1756	0	71	300	2249	1900	12000	0	1285	0	0	0	-5890	0	0	0	0	0	12
QS	0.50	0.50	0.50	0.50	1.50	1756	1414	0	0	0	0	0	950	2000	1285	0	0	0	0	0	0	0	0	0
QBf	-0.19	-0.08	0.05	0.17	0.14	456	0	1	-117	208	-739	1108	0	0	1285	0	0	0	0	0	0	0	0	0
QBs	-0.19	-0.08	0.05	0.17	0.14	456	21	0	0	0	0	0	-369	693	1285	0	0	0	0	0	0	0	0	0

LOAD FOR FOUNDATION

(D)

No.		DESIGN STRESS			MAX	WT	No.
		NML	A.NML DIAG.WIND (U1)				
10	C	93073	71682	94640	94640	16,402	10
	T	81984	64253	83552	83552		
	Qf	17618	13584	3028	0		
	Qs	2513	4803	1013	0		
	QBf	1067	2494	254	0		
	QBs	155	2844	78	0		
11	C	95712	72748	97578	97578	18,703	11
	T	83473	64548	85339	85339		
	Qf	17871	13219	3281	0		
	Qs	2766	4439	1164	0		
	QBf	923	1864	355	0		
	QBs	285	2109	161	0		
12	C	99066	74490	101539	101539	23,560	12
	T	84399	64663	86872	86872		
	Qf	18276	13106	3686	0		
	Qs	3171	4325	1407	0		
	QBf	918	1476	525	0		
	QBs	477	1645	279	0		

TOWER TYPE DR			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 300 \times 10^{-3}$	599
	C ₁₋₃	$25.30 \times 2 \times 81 \times 300 \times 10^{-3}$	
	Ins.	270	1,500
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 45^{\circ} \times 2$	5,374
	C ₁₋₃	$4,000 \times \sin 45^{\circ} \times 2 \times 2$	11,314
Conductor and Insulator Weight (Wc)	G.W.	1.136×300	341
	C ₁₋₃	$1.239 \times 2 \times 300$	
	Ins.	790	1,533
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240

TOWER BODY

(DR)

No.	UNIT STRESS												STRESS												E	E'	No.
	G	C1	C2	C3	Tc	HT	HTA			HC			Ha			G	CI-3	g	Wc	Va	WT	E	E'	No.			
							S	F	G	CI-3	G	CI-3	G	CI-3	G												
	1.0	0.05	599	1500	5374	11314	1900	4000																			
1	0.34	0.00	0.00	0.00	0.00	30	30	2	206	0	1850	0	654	0	170	57	220	0	0	0	0	0	0	1			
2	1.01	0.00	0.00	0.00	0.00	138	96	5	606	0	5437	0	1922	0	170	57	304	0	0	0	0	0	0	2			
3	1.70	0.00	0.00	0.00	0.00	375	215	11	1021	0	9156	0	3237	0	937	177	1057	0	0	0	0	0	0	3			
4	2.40	0.36	0.00	0.00	0.36	758	501	25	1439	544	12900	4103	4561	1451	937	177	1303	0	0	0	0	0	0	4			
5	3.05	1.08	0.00	0.00	1.08	1276	898	45	1828	1620	16387	12220	5794	4320	937	177	1536	0	0	0	0	0	0	5			
6	3.67	1.77	0.00	0.00	1.77	1942	1312	66	2200	2649	19723	19984	6973	7065	1704	297	2436	0	0	0	0	0	0	6			
7	4.24	2.39	0.33	0.00	2.72	2741	1840	92	2540	4054	22777	30811	8053	9579	1704	297	2822	0	0	0	0	0	0	7			
8	4.77	2.98	0.98	0.00	3.96	3678	2452	123	2860	5945	25640	44854	9065	11935	1704	297	3175	0	0	0	0	0	0	8			
9	5.28	3.55	1.61	0.00	5.16	4773	3070	154	3167	7737	28395	58371	10039	14203	2471	417	4198	0	0	0	0	0	0	9			
10	5.30	3.78	2.08	0.38	6.25	5682	3502	175	3177	9370	28485	70691	10071	15133	2471	417	4650	0	0	0	0	0	0	10			
11	4.55	3.47	2.26	1.06	6.79	6120	3588	179	2725	10176	24429	76774	8637	13876	2471	417	5329	0	0	0	0	0	0	11			
12	3.99	3.24	2.40	1.55	7.19	6987	3652	183	2389	10775	21416	81293	7572	12942	2471	417	6696	0	0	0	0	0	0	12			
1	0.60	0.00	0.00	0.00	0.00	53	50	3	360	0	3227	0	1141	0	1487	0	0	0	0	0	0	0	0	0	1		
2	0.58	0.00	0.00	0.00	0.00	138	65	3	345	0	3094	0	1094	0	1426	0	0	0	0	0	0	0	0	2			
3	0.59	0.00	0.00	0.00	0.00	256	127	6	354	0	3171	0	1121	0	1461	0	0	0	0	0	0	0	0	3			
4	0.55	0.61	0.00	0.00	0.61	376	334	17	331	916	2969	6911	1050	2443	5498	0	0	0	0	0	0	0	0	4			
5	0.54	0.59	0.00	0.00	0.59	492	324	16	321	889	2882	6708	1019	2372	5336	0	0	0	0	0	0	0	0	5			
6	0.51	0.57	0.00	0.00	0.57	634	368	18	307	849	2753	6408	973	2265	5097	0	0	0	0	0	0	0	0	6			
7	0.48	0.53	0.59	0.00	1.13	771	550	28	290	1689	2599	12746	919	2368	4812	0	0	0	0	0	0	0	0	7			
8	0.47	0.52	0.58	0.00	1.10	907	536	27	282	1646	2531	12417	895	2307	4688	0	0	0	0	0	0	0	0	8			
9	0.45	0.50	0.55	0.00	1.05	1067	568	28	271	1581	2431	11926	860	2216	4502	0	0	0	0	0	0	0	0	9			
10	-0.64	-0.27	0.15	0.57	0.46	197	66	3	-384	684	-3439	5158	-1216	2282	4228	0	0	0	0	0	0	0	0	10			
11	-0.47	-0.20	0.11	0.42	0.33	441	47	2	-281	500	-3517	3775	-890	1670	3094	0	0	0	0	0	0	0	0	11			
12	-0.33	-0.14	0.08	0.30	0.24	790	33	2	-199	354	-1781	2672	-630	1182	2190	0	0	0	0	0	0	0	0	12			

(DR)

No.	DESIGN STRESS		MAX	SIZE	L _k	L/r	STRENGTH (U ₂)	S.F.	WT	No.
	NML	A.NML DIAG.WIND (U ₁)								
1	2536	2137	2516	L120* 8	180	76	29403	11.60	879	1
2	6717	5788	6891	L120* 8	180	76	29403	4.38	1,214	2
3	12734	10701	12801	L120* 8	220	92	20835	1.63	4,229	3
4	22186	17921	22371	L175*12	210	61	77160	3.45	5,212	4
5	36026	28019	36334	L175*12	220	64	74667	2.06	6,146	5
6	51000	38904	51543	L175*12	220	64	74667	1.45	9,744	6
7	67867	51889	68684	L200*20	210	54	153131	2.23	11,287	7
8	88275	67141	89384	L200*20	220	56	149630	1.67	12,701	8
9	109682	83003	111202	L200*20	220	56	149630	1.35	16,791	9
10	125127	93974	126975	L200*20	211	54	152746	1.20	18,640	10
11	128620	95472	130682	L200*20	162	41	167875	1.28	21,316	11
12	132626	97530	135170	L200*25	242	62	173821	1.29	26,783	12
1	3642	3437	0	L 65* 6	144	113	5181	1.42		1
2	3580	3354	0	L 65* 6	147	115	5042	1.41		2
3	3787	3516	0	L 70* 6	161	118	5301	1.40		3
4	11520	11402	0	L100*10	162	83	17424	1.51		4
5	11308	11151	0	L100*10	168	85	16948	1.50		5
6	10969	10764	0	L100*10	172	88	16677	1.52		6
7	18123	15367	0	L130* 9	173	67	22740	1.25		7
8	17809	15073	0	L130* 9	179	70	22740	1.28		8
9	17306	14611	0	L130* 9	183	71	22740	1.31		9
10	2220	4537	0	L100* 7	284	144	6241	1.38		10
11	1921	3519	0	L 80* 6	209	132	5058	1.44		11
12	1838	2811	0	L 90* 7	307	174	3848	1.37		12

CROSSARM

(DR)

UNIT STRESS														DESIGN STRESS				MAX				STRENGTH OF MEMBER									
AH		AP		AV		HC		Ha		P		Va		Wc		NML		A.NML		U1		SIZE		L		L/r		STRENGTH (U2)		S.F.	
				341		341		114		114		1533		1533																	
M	0.59	0.95	0.67	353	3165	3596	76	227	7416	7416	0	7416	0	23277	23277	0	23277	0	23277	0	23277	L100*10	240	123	11958	1.61					
G	0.00	0.00	0.83	0	0	0	95	283	377	377	0	377	0	0	0	273	273	0	273	0	273	L 70* 6	299	218	1625	4.31					
X	0.00	0.11	0.00	0	0	408	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	L 45* 4	179	203	801	2.94					
M	0.52	1.82	1.16	780	5883	14560	278	1776	23277	23277	0	23277	0	23277	23277	0	23277	0	23277	0	23277	L200*15	510	190	32628	1.40					
C 1	0.00	0.00	1.27	0	0	0	305	1946	2250	2250	0	2250	0	2250	2250	0	2250	0	2250	0	2250	L130* 9	558	217	34999	15.55					
X	0.00	0.44	0.00	0	0	3536	0	0	0	0	0	0	0	0	0	2369	2369	0	2369	0	2369	L 65* 6	198	156	2942	1.24					
M	0.53	1.61	1.14	789	5950	12894	273	1741	21647	21647	0	21647	0	21647	21647	0	21647	0	21647	0	21647	L200*15	500	127	33941	1.57					
C 2	0.00	0.00	1.25	0	0	0	299	1913	2213	2213	0	2213	0	2213	2213	0	2213	0	2213	0	2213	L130* 9	549	214	34999	15.82					
X	0.00	0.36	0.00	0	0	2920	0	0	0	0	0	0	0	0	0	1956	1956	0	1956	0	1956	L 65* 6	219	173	2400	1.23					
M	0.53	1.44	1.11	799	6091	11539	267	1709	20346	20346	0	20346	0	20346	20346	0	20346	0	20346	0	20346	L200*15	490	125	35233	1.73					
C 3	0.00	0.00	1.23	0	0	0	295	1883	2178	2178	0	2178	0	2178	2178	0	2178	0	2178	0	2178	L130* 9	540	210	34999	16.07					
X	0.00	0.30	0.00	0	0	2412	0	0	0	0	0	0	0	0	0	1616	1616	0	1616	0	1616	L 65* 6	240	189	1995	1.23					
M	0.59	0.95	0.67	353	3165	3596	76	227	7416	7416	0	7416	0	7416	7416	0	7416	0	7416	0	7416	L100*10	240	123	11958	1.61					
G	0.00	0.00	0.83	0	0	0	95	283	377	377	0	377	0	0	0	273	273	0	273	0	273	L 70* 6	299	218	1625	4.31					
X	0.00	0.11	0.00	0	0	408	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	L 45* 4	179	203	801	2.94					
M	0.50	0.88	1.11	750	5657	7000	267	1708	15382	15382	0	15382	0	15382	15382	0	15382	0	15382	0	15382	L175*12	490	142	18972	1.23					
C 1	0.00	0.00	1.23	0	0	0	296	1888	2184	2184	0	2184	0	2184	2184	0	2184	0	2184	0	2184	L130* 9	542	211	34999	16.03					
X	0.00	0.44	0.00	0	0	3536	0	0	0	0	0	0	0	0	0	2369	2369	0	2369	0	2369	L 65* 6	198	156	2942	1.24					
M	0.50	0.77	1.08	750	5657	6129	259	1655	14450	14450	0	14450	0	14450	14450	0	14450	0	14450	0	14450	L175*12	475	138	20189	1.40					
C 2	0.00	0.00	1.20	0	0	0	288	1840	2128	2128	0	2128	0	2128	2128	0	2128	0	2128	0	2128	L130* 9	528	205	34999	16.44					
X	0.00	0.36	0.00	0	0	2920	0	0	0	0	0	0	0	0	0	1956	1956	0	1956	0	1956	L 65* 6	219	173	2400	1.23					
M	0.50	0.68	1.05	750	5657	5412	251	1603	13672	13672	0	13672	0	13672	13672	0	13672	0	13672	0	13672	L175*12	460	134	21528	1.57					
C 3	0.00	0.00	1.17	0	0	0	281	1793	2074	2074	0	2074	0	2074	2074	0	2074	0	2074	0	2074	L120* 8	514	216	28331	13.66					
X	0.00	0.30	0.00	0	0	2412	0	0	0	0	0	0	0	0	0	1616	1616	0	1616	0	1616	L 65* 6	240	189	1995	1.23					

CROSSARM (IN TOWER BODY)

(DR)

UNIT STRESS										DESIGN STRESS					STRENGTH OF MEMBER				
ALL	AP	AV	G	Hc	Ha	P	Va	Wc	MAX	NML	A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F	U2/U1	
																			599
C 1500										8000	240	1538							
M	0.00	0.40	0.57	0	0	1526	64	193	257	1195	1195	1195	L100*10	253	130	10651	8.91		
S	0.31	0.00	0.35	187	1672	0	40	120	2019	0	2019	0	L 60* 4	253	213	4585	2.27		
SF	0.00	0.00	0.55	0	0	252	63	189	252	0	252	0	L 60* 4	262	220	4585	18.22		
SS	0.00	0.00	0.36	0	0	165	41	124	165	0	165	0	L 60* 4	253	213	985	5.96		
M	0.00	0.88	1.11	0	0	7000	267	1708	1975	6013	6013	6013	L200*15	280	71	57750	9.60		
S	0.14	0.00	0.32	214	1616	0	76	488	2395	0	2395	0	L 70* 6	280	204	8226	3.43		
SF	0.00	0.00	1.13	0	0	1995	270	1725	1995	0	1995	0	L 65* 6	270	212	7483	3.75		
SS	0.00	0.00	0.31	0	0	544	74	470	544	0	544	0	L 65* 6	270	212	1584	2.91		
M	0.00	0.77	1.08	0	0	6129	259	1655	1914	5389	5389	5389	L200*15	310	79	54801	10.17		
S	0.16	0.00	0.35	245	1846	0	85	540	2715	0	2715	0	L 75* 6	310	209	8968	3.30		
SF	0.00	0.00	1.09	0	0	1935	262	1673	1935	0	1935	0	L 70* 6	300	219	8226	4.25		
SS	0.00	0.00	0.34	0	0	604	82	522	604	0	604	0	L 70* 6	300	219	1612	2.57		
M	0.00	0.68	1.05	0	0	5412	251	1603	1854	4868	4868	4868	L200*15	340	87	51442	10.57		
S	0.18	0.00	0.39	277	2091	0	93	592	3053	0	3053	0	L 80* 6	340	215	9711	3.18		
SF	0.00	0.00	1.06	0	0	1874	254	1621	1874	0	1874	0	L 80* 6	330	209	9711	5.18		
SS	0.00	0.00	0.37	0	0	665	90	575	665	0	665	0	L 80* 6	330	209	2033	3.06		

FOUNDATION

(DR)

No.	UNIT STRESS										STRESS																
	HTA					HC					HS					F											
	G	C1	C2	C3	T6	HT	S	F	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3	G	CI-3	q	Kc	Va	WT	E	K' No.	
							1.0	0.05	599	1500	5374	11314	1900	4000													
C	4.70	3.48	2.11	0.74	6.33	5611	3475	174	2818	9485	25267	71560	8933	13915	0	2471	417	4660	0	0							
T	4.70	3.48	2.11	0.74	6.33	5611	3475	174	2818	9485	25267	71560	8933	13915	0	0	0	-4660	0	0							
10 Qf	0.50	0.50	0.50	0.50	1.50	1200	0	72	300	2249	2687	16971	0	0	2657	0	0	0	0	0	10						
Qs	0.50	0.50	0.50	0.50	1.50	1200	1430	0	0	0	0	0	950	2000	2657	0	0	0	0	0	0						
Qbf	-0.40	-0.17	0.10	0.36	0.29	124	0	2	-241	430	-2161	3241	0	0	2657	0	0	0	0	0	0						
QBS	-0.40	-0.17	0.10	0.36	0.29	124	49	0	0	0	0	0	-764	1434	2657	0	0	0	0	0	0						
C	4.07	3.22	2.26	1.30	6.77	6203	3551	178	2441	10157	21887	76630	7738	12868	0	2471	417	5329	0	0							
T	4.07	3.22	2.26	1.30	6.77	6203	3551	178	2441	10157	21887	76630	7738	12868	0	0	0	-5329	0	0	11						
11 Qf	0.50	0.50	0.50	0.50	1.50	1455	0	72	300	2249	2687	16971	0	0	1859	0	0	0	0	0	0						
Qs	0.50	0.50	0.50	0.50	1.50	1455	1430	0	0	0	0	0	950	2000	1859	0	0	0	0	0	0						
Qbf	-0.28	-0.12	0.07	0.25	0.20	265	0	2	-169	301	-1512	2268	0	0	1859	0	0	0	0	0	0						
QBS	-0.28	-0.12	0.07	0.25	0.20	265	34	0	0	0	0	0	-535	1003	1859	0	0	0	0	0	0						
C	3.62	3.03	2.37	1.70	7.10	7283	3605	180	2169	10641	19451	80284	6877	12112	0	2471	417	6696	0	0							
T	3.62	3.03	2.37	1.70	7.10	7283	3605	180	2169	10641	19451	80284	6877	12112	0	0	0	-6696	0	0	12						
12 Qf	0.50	0.50	0.50	0.50	1.50	1861	0	72	300	2249	2687	16971	0	0	1285	0	0	0	0	0	0						
Qs	0.50	0.50	0.50	0.50	1.50	1861	1430	0	0	0	0	0	950	2000	1285	0	0	0	0	0	0						
Qbf	-0.19	-0.08	0.05	0.17	0.14	463	0	1	-117	208	-1045	1567	0	0	1285	0	0	0	0	0	0						
QBS	-0.19	-0.08	0.05	0.17	0.14	463	23	0	0	0	0	0	-359	693	1285	0	0	0	0	0	0						

LOAD FOR FOUNDATION

(DR)

No.		DESIGN STRESS			MAX	WT	No.
		NML	A.NML	DIAG.WIND (U1)			
10	C	122462	91373	124316	124316	18,640	10
	T	110255	83194	112109	112109		
	Qf	23478	17510	3130	0		
	Qs	2631	4882	1078	0		
	QBf	1395	2715	266	0		
	QBs	172	2856	86	0		
11	C	125711	92848	127881	127881	21,316	11
	T	112166	83772	114336	114336		
	Qf	23733	17147	3384	0		
	Qs	2885	4519	1230	0		
	QBf	1155	2019	364	0		
	QBs	299	2118	167	0		
12	C	129592	94942	132382	132382	26,783	12
	T	113313	84035	116102	116102		
	Qf	24139	17034	3790	0		
	Qs	3291	4406	1474	0		
	QBf	1078	1583	532	0		
	QBs	487	1651	284	0		

TOWER TYPE A4			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 350 \times 10^{-3}$	699
	C ₁₋₃	$25.30 \times 2 \times 81 \times 350 \times 10^{-3}$	1,635
	Ins.	200	
	C ₄₋₆	$36.00 \times 90 \times 350 \times 10^{-3}$	1,254
	Ins.	120	
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 1.5^\circ \times 2$	199
	C ₁₋₃	$4,000 \times \sin 1.5^\circ \times 2 \times 2$	419
	C ₄₋₆	$6,000 \times \sin 1.5^\circ \times 2$	314
Conductor and Insulator Weight (Wc)	G.W.	1.136×350	398
	C ₁₋₃	$1.239 \times 2 \times 350$	1,267
	Ins.	400	
	C ₄₋₆	2.446×350	1,166
	Ins.	310	
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240
	C ₄₋₆	$6,000 \times 0.03$	180

TOWER BODY

(A4)

UNIT STRESS

No.	G	C1	C2	C3	C4	C5	C6	C1-C3	C4-C6	No.
1	0.296	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1
2	0.880	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2
3	1.558	0.406	0.000	0.000	0.000	0.000	0.000	0.406	0.000	3
4	2.322	1.198	0.000	0.000	0.000	0.000	0.000	1.198	0.000	4
5	3.117	2.023	0.000	0.000	0.000	0.000	0.000	2.023	0.000	5
6	3.873	2.809	0.376	0.000	0.000	0.000	0.000	3.185	0.000	6
7	4.526	3.487	1.110	0.000	0.000	0.000	0.000	4.596	0.000	7
8	5.209	4.195	1.877	0.000	0.000	0.000	0.000	5.072	0.000	8
9	5.830	4.874	2.689	0.504	0.000	0.000	0.000	8.067	0.000	9
10	6.289	5.419	3.429	1.439	0.000	0.000	0.000	10.286	0.000	10
11	6.599	5.786	3.928	2.070	0.000	0.000	0.000	11.785	0.000	11
12	6.879	6.118	4.380	2.541	0.467	0.000	0.000	13.139	0.467	12
13	7.136	6.424	4.794	3.165	1.129	0.000	0.000	14.383	1.129	13
14	7.354	6.682	5.145	3.608	1.688	0.415	0.000	15.435	2.103	14
15	7.556	6.921	5.471	4.020	2.207	1.005	0.000	16.412	3.212	15
16	7.745	6.900	5.587	4.274	2.632	1.544	0.456	16.761	4.632	16
17	7.126	6.648	5.557	4.465	3.100	2.196	1.292	16.670	6.589	17
18	6.837	6.439	5.531	4.623	3.488	2.736	1.984	16.594	8.208	18
19	6.597	6.266	5.510	4.755	3.810	3.184	2.558	16.531	9.551	19
1	0.578	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1
2	0.566	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2
3	0.616	0.639	0.000	0.000	0.000	0.000	0.000	0.639	0.000	3
4	0.594	0.617	0.000	0.000	0.000	0.000	0.000	0.617	0.000	4
5	0.618	0.642	0.000	0.000	0.000	0.000	0.000	0.642	0.000	5
6	0.552	0.573	0.621	0.000	0.000	0.000	0.000	1.194	0.000	6
7	0.535	0.555	0.601	0.000	0.000	0.000	0.000	1.156	0.000	7
8	0.555	0.576	0.624	0.000	0.000	0.000	0.000	1.199	0.000	8
9	0.340	0.404	0.549	0.693	0.000	0.000	0.000	1.646	0.000	9
10	0.300	0.356	0.484	0.612	0.000	0.000	0.000	1.452	0.000	10
11	0.222	0.263	0.358	0.452	0.000	0.000	0.000	1.073	0.000	11
12	0.260	0.309	0.419	0.530	0.569	0.000	0.000	1.258	0.569	12
13	0.190	0.226	0.307	0.387	0.489	0.000	0.000	0.920	0.489	13
14	0.217	0.258	0.350	0.443	0.559	0.635	0.000	1.051	1.194	14
15	0.167	0.198	0.268	0.339	0.428	0.487	0.000	0.805	0.915	15
16	-0.270	-0.195	-0.024	0.148	0.362	0.503	-0.071	-0.071	1.510	16
17	-0.224	-0.162	-0.020	0.123	0.301	0.418	0.535	-0.059	1.255	17
18	-0.185	-0.134	-0.016	0.101	0.249	0.346	0.443	-0.049	1.038	18
19	-0.155	-0.112	-0.014	0.085	0.208	0.289	0.371	-0.041	0.868	19

(A4)

No.	DESIGN STRESS		MAX	SIZE	L/k	L/r	STRENGTH (σ_c)	S.F.	WT	No.	
	NML	A. NML DIAG. (VIND) (U1)									
1	744	725	733	744	L 50* 5	140	119	3314	5.26	788	1
2	3174	2799	3205	3205	L 60* 5	140	119	3914	1.22	4,998	2
3	4977	4525	5130	5130	L120* 8	200	84	25175	4.91	5,387	3
4	7804	7156	8123	8123	L120* 8	200	84	25175	3.10	5,752	4
5	12562	11670	13206	13206	L120* 8	240	101	17518	1.33	9,653	5
6	16548	15604	17601	17601	L150*10	200	67	51642	2.93	10,181	6
7	21018	19689	22476	22476	L150*10	200	67	51642	2.30	10,658	7
8	27532	25192	29571	29571	L150*10	240	81	41812	1.41	14,727	8
9	33859	30523	36668	36668	L150*12	163	55	70367	1.92	15,730	9
10	40653	36951	44243	44243	L150*12	168	57	69302	1.57	16,717	10
11	46460	40322	50685	50685	L150*12	170	58	68674	1.35	18,780	11
12	52047	44710	57039	57039	L175*12	188	55	82179	1.44	20,138	12
13	58545	49621	64360	64360	L175*12	170	50	85947	1.34	22,416	13
14	64582	54014	71111	71111	L175*15	187	55	101737	1.43	24,013	14
15	71554	59070	78864	78864	L175*15	170	50	106255	1.35	26,694	15
16	76469	62330	84485	84485	L175*15	135	39	114173	1.35	28,613	16
17	81658	65401	90572	90572	L200*15	163	41	129808	1.43	31,231	17
18	86988	68637	97086	97086	L200*15	193	49	122952	1.27	34,603	18
19	92968	72365	104620	104620	L200*20	234	60	144482	1.38	39,814	19
1	567	1402	0	1402	L 50* 4	124	126	2285	1.63		1
2	658	1541	0	1541	L 50* 4	125	128	2241	1.45		2
3	2157	5011	0	5011	L 70* 6	143	105	6110	1.22		3
4	2181	4903	0	4903	L 70* 6	146	106	6013	1.23		4
5	2433	5296	0	5296	L 80* 6	160	101	7246	1.37		5
6	3620	5420	0	5420	L 75* 6	151	102	6764	1.25		6
7	3621	5326	0	5326	L 75* 6	153	103	6664	1.25		7
8	3937	5646	0	5646	L 80* 6	167	106	6949	1.23		8
9	4740	6282	0	6282	L 90* 7	202	114	8331	1.33		9
10	4398	5687	0	5687	L 90* 7	214	121	7635	1.35		10
11	3431	4324	0	4324	L 75* 6	177	120	5567	1.29		11
12	5328	5945	0	5945	L100* 7	243	123	8329	1.40		12
13	4113	4491	0	4491	L 80* 6	197	125	5602	1.25		13
14	5967	5982	0	5982	L100* 7	258	131	7512	1.26		14
15	4811	4743	0	4811	L 90* 6	217	122	6553	1.36		15
16	3248	3974	0	3974	L 70* 6	172	125	4837	1.22		16
17	3158	3610	0	3610	L 80* 6	207	131	5162	1.43		17
18	3200	3380	0	3380	L 90* 6	246	138	5227	1.55		18
19	3431	3332	0	3431	L100* 7	298	151	5655	1.65		19

TLG-1-86

CROSSARM

(A4)

		DESIGN STRESS										STRENGTH OF MEMBER				
		Hc	Ha	P	Va	Vc	Wc	NML	A.NML	UI	SIZE	L	L/r	STRENGTH (U2)	S.F (U2/U1)	
AH		G		699	1254	2280	114	398								
		UC		1635	419	4800	240	1267								
		LC		1254	314	3600	180	1166								
M	0.53	1.52	1.26	370	664	3466	144	502	5146	0	5146	L120* 8	353	148	8082	1.57
G	0.00	0.00	1.35	0	0	0	154	538	693	0	693	L 90* 6	379	213	2210	3.19
X	0.00	0.33	0.00	0	0	754	0	0	0	505	505	L 45* 4	164	187	950	1.88
M	0.51	2.80	2.40	831	213	13416	575	3036	18071	0	18071	L200*20	671	172	24404	1.35
C 1	0.00	0.00	2.45	0	0	0	589	3108	3697	0	3697	L175*12	687	200	66173	17.90
X	0.00	0.80	0.00	0	0	3818	0	0	0	2558	2558	L 55* 6	170	134	4003	1.56
M	0.51	2.55	1.38	833	214	12238	331	1750	15366	0	15366	L200*15	663	169	19284	1.25
C 2	0.00	0.00	1.47	0	0	0	354	1869	2223	0	2223	L175*12	708	206	66173	29.77
X	0.00	0.71	0.00	0	0	3394	0	0	0	2274	2274	L 65* 6	184	145	3412	1.50
M	0.51	2.34	1.36	937	214	11231	328	1730	14339	0	14339	L200*15	655	167	19742	1.38
C 3	0.00	0.00	1.46	0	0	0	350	1849	2199	0	2199	L175*12	700	204	66173	30.09
X	0.00	0.63	0.00	0	0	3030	0	0	0	2030	2030	L 55* 5	198	156	2942	1.45
M	0.54	1.38	1.43	673	169	4961	258	1659	7739	0	7739	L150*10	487	164	10338	1.34
C 4	0.00	0.00	1.53	0	0	0	275	1782	2058	0	2058	L120* 8	520	218	28331	13.77
X	0.00	0.28	0.00	0	0	998	0	0	0	669	669	L 60* 4	250	210	1012	1.51
M	0.55	1.18	1.39	692	173	4248	251	1625	6990	0	6990	L150*10	474	160	10901	1.56
C 5	0.00	0.00	1.49	0	0	0	263	1739	2008	0	2008	L120* 8	507	213	28331	14.11
X	0.00	0.20	0.00	0	0	724	0	0	0	485	485	L 70* 6	284	207	1797	3.70
M	0.57	1.03	1.36	717	180	3706	245	1589	6438	0	6438	L150*10	463	156	11404	1.77
C 6	0.00	0.00	1.46	0	0	0	263	1703	1966	0	1966	L120* 8	496	209	28331	14.41
X	0.00	0.14	0.00	0	0	509	0	0	0	341	341	L 75* 6	318	215	1794	5.26

FOUNDATION

(A4)

UNIT STRESS

No.	G	C1	C2	C3	C4	C5	C6	C1-C3	C4-C6	No.
16	C	7.222	6.705	5.523	4.340	2.863	1.884	0.905	16.568	5.652
	T	7.222	6.705	5.523	4.340	2.863	1.884	0.905	16.568	5.652
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	Qs	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.174	-0.125	-0.015	0.095	0.233	0.324	0.416	-0.045	0.973
	QBs	-0.174	-0.125	-0.015	0.095	0.233	0.324	0.416	-0.045	0.973
17	C	6.907	6.477	5.495	4.513	3.285	2.471	1.658	16.485	7.414
	T	6.907	6.477	5.495	4.513	3.285	2.471	1.658	16.485	7.414
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	Qs	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.144	-0.104	-0.013	0.079	0.194	0.269	0.345	-0.038	0.808
	QBs	-0.144	-0.104	-0.013	0.079	0.194	0.269	0.345	-0.038	0.808
18	C	6.649	6.291	5.473	4.654	3.631	2.954	2.276	16.418	8.861
	T	6.649	6.291	5.473	4.654	3.631	2.954	2.276	16.418	8.861
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	Qs	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.120	-0.087	-0.010	0.066	0.161	0.224	0.288	-0.031	0.673
	QBs	-0.120	-0.087	-0.010	0.066	0.161	0.224	0.288	-0.031	0.673
19	C	6.432	6.134	5.454	4.773	3.923	3.359	2.796	16.361	10.078
	T	6.432	6.134	5.454	4.773	3.923	3.359	2.796	16.361	10.078
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	Qs	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.100	-0.072	-0.009	0.055	0.134	0.187	0.239	-0.026	0.560
	QBs	-0.100	-0.072	-0.009	0.055	0.134	0.187	0.239	-0.026	0.560

LOAD FOR FOUNDATION

(A4)

No.	DESIGN STRESS				MAX	WT	No.
	NML	A.NML	DIAG. WIND (U1)				
16	C	78193	63170	86536	86536	28,613	16
	T	59351	50546	67694	67694		
	Qf	8399	6785	4466	0		
	Qs	6369	6229	2402	0		
	QBf	2094	2561	660	0		
	QBs	1083	1929	552	0		
17	C	83282	66214	92648	92648	31,231	17
	T	63130	52713	72497	72497		
	Qf	8753	6827	4821	0		
	Qs	6723	6271	2615	0		
	QBf	2034	2326	843	0		
	QBs	1195	1800	636	0		
18	C	88589	69470	99288	99288	34,603	18
	T	66751	54839	77451	77451		
	Qf	9212	6974	5280	0		
	Qs	7182	6418	2891	0		
	QBf	2077	2194	1085	0		
	QBs	1378	1756	759	0		
19	C	94702	73314	107157	107157	39,814	19
	T	70259	56937	82714	82714		
	Qf	9797	7231	5865	0		
	Qs	7767	6675	3241	0		
	QBf	2213	2149	1388	0		
	QBs	1632	1786	923	0		

TOWER TYPE D4			
Item		Calculation	Load (kg)
Wind Pressure (Hc)	G.W.	$22.2 \times 90 \times 250 \times 10^{-3}$	500
	C ₁₋₃	$25.30 \times 2 \times 81 \times 250 \times 10^{-3}$	1,295
	Ins.	270	
	C ₄₋₆	$36.00 \times 90 \times 250 \times 10^{-3}$	1,020
	Ins.	210	
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 30^{\circ} \times 2$	3,800
	C ₁₋₃	$4,000 \times \sin 30^{\circ} \times 2 \times 2$	8,000
	C ₄₋₆	$6,000 \times \sin 30^{\circ} \times 2$	6,000
Conductor and Insulator Weight (Wc)	G.W.	1.136×250	284
	C ₁₋₃	$1.239 \times 2 \times 250$	1,410
	Ins.	790	
	C ₄₋₆	2.446×250	1,232
	Ins.	620	
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240
	C ₄₋₆	$6,000 \times 0.03$	180

TOWER BODY

(D4)

UNIT STRESS

No.	G	C1	C2	C3	C4	C5	C6	C1-C3	C4-C6	No.
1	0.344	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1
2	1.012	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2
3	1.704	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	3
4	2.401	0.363	0.000	0.000	0.000	0.000	0.000	0.363	0.000	4
5	3.049	1.080	0.000	0.000	0.000	0.000	0.000	1.080	0.000	5
6	3.670	1.766	0.000	0.000	0.000	0.000	0.000	1.766	0.000	6
7	4.238	2.395	0.329	0.000	0.000	0.000	0.000	2.723	0.000	7
8	4.771	2.984	0.981	0.000	0.000	0.000	0.000	3.965	0.000	8
9	5.284	3.551	1.609	0.000	0.000	0.000	0.000	5.159	0.000	9
10	5.785	4.157	2.321	0.486	0.000	0.000	0.000	6.964	0.000	10
11	6.265	4.759	3.071	1.383	0.000	0.000	0.000	9.214	0.000	11
12	6.576	5.158	3.567	1.977	0.000	0.000	0.000	10.703	0.000	12
13	6.817	5.466	3.951	2.436	0.339	0.000	0.000	11.853	0.339	13
14	7.041	5.752	4.308	2.863	0.863	0.000	0.000	12.923	0.863	14
15	7.241	6.008	4.626	3.244	1.331	0.310	0.000	13.877	1.641	15
16	7.427	6.247	4.924	3.600	1.768	0.791	0.000	14.771	2.559	16
17	7.652	6.017	4.857	3.696	2.089	1.232	0.375	14.570	3.696	17
18	5.835	5.090	4.235	3.421	2.265	1.649	1.032	12.766	4.946	18
19	4.925	4.397	3.806	3.215	2.397	1.960	1.524	11.419	5.880	19
1	0.601	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1
2	0.576	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2
3	0.590	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	3
4	0.552	0.611	0.000	0.000	0.000	0.000	0.000	0.611	0.000	4
5	0.536	0.593	0.000	0.000	0.000	0.000	0.000	0.593	0.000	5
6	0.512	0.566	0.000	0.000	0.000	0.000	0.000	0.566	0.000	6
7	0.484	0.535	0.592	0.000	0.000	0.000	0.000	1.127	0.000	7
8	0.471	0.521	0.577	0.000	0.000	0.000	0.000	1.097	0.000	8
9	0.452	0.500	0.554	0.000	0.000	0.000	0.000	1.054	0.000	9
10	0.356	0.458	0.570	0.682	0.000	0.000	0.000	1.710	0.000	10
11	0.316	0.404	0.503	0.602	0.000	0.000	0.000	1.510	0.000	11
12	0.238	0.304	0.379	0.453	0.000	0.000	0.000	1.137	0.000	12
13	0.253	0.324	0.403	0.482	0.592	0.000	0.000	1.209	0.592	13
14	0.213	0.273	0.339	0.406	0.499	0.000	0.000	1.018	0.499	14
15	0.224	0.287	0.357	0.428	0.525	0.577	0.000	1.072	1.072	15
16	0.193	0.247	0.307	0.368	0.452	0.456	0.000	0.922	0.948	16
17	-1.050	-0.800	-0.518	-0.237	0.152	0.359	0.567	-1.556	1.078	17
18	-0.771	-0.587	-0.380	-0.174	0.111	0.264	0.416	-1.141	0.791	18
19	-0.557	-0.424	-0.275	-0.126	0.081	0.191	0.301	-0.825	0.572	19

(D4)

STRESS

No.	HT	HTA						HC						Ha						q	Va	Wc	WT	E	E'	No.	
		S		F		G		Cl-3		C4-6		G		Cl-3		C4-6		Cl-3	C4-6								1800
		1.0	0.05	500	1295	3800	8000	6000	1140	2400	1800																
1	33	33	2	172	0	1308	0	0	393	0	0	0	0	0	0	0	0	170	0	0	1						
2	149	105	5	505	0	3845	0	0	1153	0	0	0	0	0	0	0	0	142	0	0	2						
3	406	240	12	851	0	6474	0	0	1942	0	0	0	0	0	0	0	0	142	0	0	3						
4	820	569	28	1199	470	9122	2901	0	2737	870	0	0	0	0	0	0	0	847	0	0	4						
5	1377	1027	51	1523	1398	0	11588	8641	3476	2592	0	0	0	0	0	0	0	847	0	0	5						
6	2032	1508	75	1833	2287	0	13946	14131	4184	4239	0	0	0	0	0	0	0	1552	0	0	6						
7	2951	2122	106	2117	3526	0	16106	21787	4832	5747	0	0	0	0	0	0	0	2221	0	0	7						
8	3956	2832	142	2383	5133	0	18130	31716	5439	7161	0	0	0	0	0	0	0	1552	0	0	8						
9	5130	3552	178	2639	6680	0	20079	41275	6024	8522	0	0	0	0	0	0	0	2256	0	0	9						
10	6806	4615	231	2894	9016	0	22019	55715	6606	9976	0	0	0	0	0	0	0	3311	0	0	10						
11	8973	5800	290	3129	11929	0	23807	73709	7142	11422	0	0	0	0	0	0	0	417	0	0	11						
12	10711	6578	329	3285	13856	0	24991	85620	7497	12378	0	0	0	0	0	0	0	507	0	0	12						
13	12428	7348	367	3405	15345	346	25905	94822	7771	13117	610	0	0	0	0	0	0	507	0	0	13						
14	14248	8102	405	3517	16731	880	26756	103383	5179	8027	13805	1554	0	0	0	0	0	597	0	0	14						
15	16239	8916	446	3617	17966	1674	27514	111017	9844	8254	14418	2395	0	0	0	0	0	597	0	0	15						
16	18328	9707	485	3710	19123	2610	28224	118165	15355	8467	14992	3183	0	0	0	0	0	687	0	0	16						
17	19587	9543	482	3523	18862	3770	26800	116556	22175	8040	14441	3760	0	0	0	0	0	4104	0	0	17						
18	19637	8951	448	2915	16528	5045	22173	102131	29675	6652	12216	4077	0	0	0	0	0	4104	0	0	18						
19	20750	8436	422	2460	14783	5998	18714	91348	35281	5614	10553	4314	0	0	0	0	0	4104	0	0	19						
1	57	55	3	300	0	2282	0	0	585	0	0	0	0	0	0	0	0	0	0	0	1						
2	149	71	4	288	0	2198	0	0	656	0	0	0	0	0	0	0	0	0	0	0	2						
3	276	146	7	295	0	2242	0	0	673	0	0	0	0	0	0	0	0	0	0	0	3						
4	406	386	19	276	791	0	2099	4887	630	1466	0	0	0	0	0	0	0	0	0	0	4						
5	529	374	19	268	768	0	2038	4743	611	1423	0	0	0	0	0	0	0	0	0	0	5						
6	681	428	21	256	733	0	1946	4531	584	1359	0	0	0	0	0	0	0	0	0	0	6						
7	829	639	32	242	1439	0	1838	9013	551	1421	0	0	0	0	0	0	0	0	0	0	7						
8	972	622	31	235	1421	0	1790	8780	537	1384	0	0	0	0	0	0	0	0	0	0	8						
9	1144	664	33	226	1365	0	1719	8433	516	1329	0	0	0	0	0	0	0	0	0	0	9						
10	1460	871	44	179	2214	0	1359	13681	408	1637	0	0	0	0	0	0	0	0	0	0	10						
11	1650	774	39	158	1955	0	1200	12081	360	1446	0	0	0	0	0	0	0	0	0	0	11						
12	1520	847	32	119	1472	0	904	9094	271	1088	0	0	0	0	0	0	0	0	0	0	12						
13	1928	838	42	126	1565	604	961	9669	3552	288	1157	1066	0	0	0	0	0	0	0	0	13						
14	1928	760	38	106	1318	508	809	8143	2991	243	975	897	1806	0	0	0	0	0	0	0	14						
15	2371	939	47	112	1388	1124	852	8576	6612	256	1026	1039	1902	0	0	0	0	0	0	0	15						
16	2367	858	43	96	1194	967	733	7376	5687	230	883	893	1636	0	0	0	0	0	0	0	16						
17	-305	541	27	-525	-2014	1100	-3992	-12444	6470	-1198	-570	1021	1715	0	0	0	0	0	0	0	17						
18	371	392	20	-385	-1478	807	-2929	-9131	4748	-879	-418	749	1258	0	0	0	0	0	0	0	18						
19	1239	279	14	-278	-1068	583	-2116	-6597	3430	-635	-302	541	909	0	0	0	0	0	0	0	19						

(D4)

No.	DESIGN STRESS		MAX	SIZE	I.K.	L./r	STRENGTH (U ₂)	S.F	WT	No
	N _{ML}	A-NML DIAG. WIND (U ₁)								
1	1884	1526	1876	L100*10	180	92	19290	10.24	682	1
2	4947	4037	4958	L100*10	180	92	19290	3.89	973	2
3	9689	7793	9828	L100*10	220	113	14166	1.44	3,688	3
4	16650	12959	16981	L150*10	210	71	49334	2.91	4,345	4
5	26845	20315	27403	L150*10	220	74	46930	1.71	4,974	5
6	38128	28386	39032	L150*10	220	74	46930	1.20	7,661	6
7	50661	37794	51976	L200*15	210	53	118509	2.28	8,894	7
8	65811	48891	67580	L200*15	220	56	115778	1.71	10,010	8
9	81964	60625	84311	L200*15	220	56	115778	1.37	13,243	9
10	103397	75960	106580	L200*25	188	49	197306	1.85	16,166	10
11	129254	94253	133483	L200*25	188	48	197546	1.48	18,976	11
12	147688	107244	152789	L200*25	180	46	200252	1.31	22,070	12
13	164369	118916	170358	L250*25	135	32	277869	1.63	25,350	13
14	182450	131491	189363	L250*25	180	37	270830	1.43	29,064	14
15	200695	144126	208637	L250*35	154	32	377760	1.81	33,177	15
16	220206	157583	229210	L250*35	180	37	367759	1.60	37,658	16
17	227122	161847	236675	L250*35	150	31	379236	1.60	42,303	17
18	215710	152710	225398	L250*35	221	46	349227	1.55	49,472	18
19	209979	147757	220415	L250*35	329	63	282009	1.28	61,734	19
1	2642	2368	0	L 60* 5	144	122	3612	1.37		1
2	2628	2334	0	L 60* 5	147	124	3497	1.33		2
3	2821	2477	0	L 65* 6	161	127	4378	1.55		3
4	8478	7890	0	L 90* 7	162	92	10420	1.23		4
5	8364	7749	0	L 90* 7	168	95	10083	1.21		5
6	8169	7522	0	L 90* 7	172	97	9891	1.21		6
7	13411	10920	0	L100*10	173	89	16610	1.24		7
8	13229	10748	0	L100*10	179	92	16138	1.22		8
9	12921	10467	0	L100*10	183	94	15858	1.23		9
10	18936	14720	0	L150*10	238	80	27462	1.45		10
11	17082	13240	0	L150*10	247	83	26742	1.57		11
12	13140	10155	0	L120*8	205	86	16753	1.27		12
13	18446	13795	0	L150*10	243	82	27049	1.47		13
14	15841	11824	0	L130*9	222	86	20260	1.28		14
15	21082	15399	0	L150*10	258	87	25905	1.23		15
16	18464	13467	0	L150*10	240	81	27320	1.48		16
17	236	1991	0	L 65* 6	204	161	2759	1.39		17
18	763	1856	0	L 80* 6	233	185	2582	1.39		18
19	1518	1988	0	L100* 7	426	216	2773	1.39		19

CROSSARM

(D4)

UNIT STRESS										DESIGN STRESS MAX					STRENGTH OF MEMBER				
AIH	AP	AV	GC	HC	HA	F	VA	WC	U1	NHL	A.NHL	U1	SIZE	L	L/r	STRENGTH (U2)	S.F U2/U1		
			G 500	1020	2280	114	284												
			DC 1295	8000	4800	240	1410												
			LC 1020	6000	3600	180	1232												
G	M	0.59	0.67	294	601	2157	76	189	0	3317	0	3317	L 90* 6	240	135	5532	1.67		
	S	0.00	0.83	0	0	0	95	236	0	330	0	330	L 70* 6	299	218	1625	4.92		
	X	0.00	0.11	0.00	0	245	0	0	164	164	164	164	L 45* 4	179	203	801	4.89		
M	M	0.52	1.16	673	4150	8736	278	1532	0	15480	0	15480	L175*15	510	149	21483	1.39		
	S	0.00	0.00	0	0	0	305	1788	0	2093	0	2093	L130* 9	558	217	34999	16.72		
	X	0.00	0.44	0.00	0	2121	0	0	1421	1421	1421	1421	L 60* 5	198	168	1958	1.38		
M	M	0.53	1.61	681	4208	7737	273	1601	0	14498	0	14498	L175*12	500	145	18247	1.26		
	S	0.00	0.00	0	0	0	299	1759	0	2058	0	2058	L130* 9	549	214	34999	17.01		
	X	0.00	0.36	0.00	0	1752	0	0	1174	1174	1174	1174	L 60* 5	219	186	1597	1.36		
M	M	0.53	1.44	690	4264	6923	267	1571	0	13716	0	13716	L175*12	490	143	18941	1.38		
	S	0.00	0.00	0	0	0	295	1731	0	2025	0	2025	L130* 9	540	210	34999	17.28		
	X	0.00	0.30	0.00	0	1447	0	0	970	970	970	970	L 60* 5	240	204	1328	1.37		
M	M	0.57	1.02	585	3441	3673	213	1457	0	9370	0	9370	L150*10	426	143	13493	1.44		
	S	0.00	0.00	0	0	0	233	1592	0	1824	0	1824	L120* 8	465	195	28331	15.53		
	X	0.00	0.14	0.00	0	496	0	0	332	332	332	332	L 70* 6	295	215	1663	5.01		
M	M	0.60	0.91	609	3585	3288	209	1433	0	9125	0	9125	L150*10	419	141	13943	1.53		
	S	0.00	0.00	0	0	0	229	1567	0	1797	0	1797	L120* 8	458	193	28331	15.77		
	X	0.00	0.09	0.00	0	337	0	0	225	225	225	225	L 75* 6	324	219	1726	7.66		
M	M	0.63	0.83	640	3764	2981	207	1416	0	9008	0	9008	L150*10	414	139	14281	1.59		
	S	0.00	0.00	0	0	0	226	1649	0	1776	0	1776	L120* 8	453	190	28331	15.95		
	X	0.00	0.06	0.00	0	204	0	0	136	136	136	136	L 90* 6	354	199	2540	18.62		

CROSSARM (IN TOWER BODY)

(D4)

UNIT STRESS										DESIGN STRESS					STRENGTH OF MEMBER				
AP	AV	Hc	Ha	P	Ya	Wc	NML	A.NML	III	SIZE	L	I./I	STRENGTH (U2)	S.F	U2/U1				
G																			
M	0.00	0.40	0.57	0	916	64	160	225	764	L 90* 5	253	142	4953	6.48					
S	0.31	0.00	0.35	0	40	100	100	613	0	L 60* 4	253	213	4585	7.48					
SF	0.00	0.00	0.55	0	63	157	220	220	0	L 60* 4	262	220	4585	20.82					
SS	0.00	0.00	0.36	0	41	103	145	145	0	L 60* 4	253	213	985	6.81					
C 1																			
M	0.00	0.88	1.11	0	4200	267	1570	1837	4045	L175*15	280	82	46502	11.50					
S	0.14	0.00	0.32	0	76	448	1853	1853	0	L 70* 6	280	204	8226	4.44					
SF	0.00	0.00	1.13	0	270	1586	1856	0	0	L 65* 6	270	212	7483	4.03					
SS	0.00	0.00	0.31	0	74	432	506	506	0	L 65* 6	270	212	1534	3.13					
C 2																			
M	0.00	0.77	1.08	0	3677	259	1522	1781	3657	L175*12	310	90	34982	9.57					
S	0.16	0.00	0.35	0	85	497	2098	2098	0	L 75* 6	310	209	8958	4.28					
SF	0.00	0.00	1.09	0	262	1538	1800	0	0	L 70* 6	300	219	8226	4.57					
SS	0.00	0.00	0.34	0	82	480	562	562	0	L 70* 6	300	219	1612	2.87					
C 3																			
M	0.00	0.68	1.05	0	3247	251	1474	1724	3331	L175*12	340	99	32289	9.69					
S	0.18	0.00	0.39	0	93	545	2355	2355	0	L 80* 6	340	215	9711	4.12					
SF	0.00	0.00	1.06	0	254	1490	1744	0	0	L 80* 6	330	209	9711	5.57					
SS	0.00	0.00	0.37	0	90	528	618	618	0	L 80* 6	330	209	2033	3.29					
C 4																			
M	0.00	0.44	1.03	0	1601	186	1270	1456	2048	L150*10	417	141	14048	6.86					
S	0.28	0.00	0.58	0	104	714	2791	2791	0	L100* 7	417	212	14718	5.27					
SF	0.00	0.00	1.05	0	190	1297	1486	0	0	L100* 7	402	204	14718	9.90					
SS	0.00	0.00	0.56	0	100	687	788	788	0	L100* 7	402	204	3108	3.94					
C 5																			
M	0.00	0.38	0.97	0	1376	175	1200	1375	1843	L150*10	459	154	11633	6.31					
S	0.33	0.00	0.64	0	115	785	3195	3195	0	L120* 8	459	193	28331	8.87					
SF	0.00	0.00	1.00	0	179	1226	1405	0	0	L120* 8	443	186	28331	20.16					
SS	0.00	0.00	0.62	0	111	758	869	869	0	L120* 8	443	186	5139	5.91					
C 6																			
M	0.00	0.33	0.92	0	1188	165	1129	1394	1663	L150*10	500	168	9791	5.89					
S	0.38	0.00	0.69	0	125	855	3639	3639	0	L120* 8	500	210	28331	7.78					
SF	0.00	0.00	1.04	0	169	1155	1324	0	0	L120* 8	485	204	28331	21.39					
SS	0.00	0.00	0.67	0	121	829	950	950	0	L120* 8	485	204	4300	4.53					

FOUNDATION

(D4)

UNIT STRESS

No.	G	C1	C2	C3	C4	C5	C6	C1-C3	C4-C6	No.
17	C	6.139	5.299	4.358	3.417	2.114	1.419	0.724	13.074	4.257
	T	6.139	5.299	4.358	3.417	2.114	1.419	0.724	13.074	4.257
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QS	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.671	-0.510	-0.331	-0.152	0.097	0.229	0.362	-0.993	0.688
	QBS	-0.671	-0.510	-0.331	-0.152	0.097	0.229	0.362	-0.993	0.688
18	C	5.129	4.530	3.859	3.189	2.260	1.765	1.269	11.578	5.294
	T	5.129	4.530	3.859	3.189	2.260	1.765	1.269	11.578	5.294
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QS	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.478	-0.364	-0.236	-0.108	0.069	0.164	0.258	-0.708	0.491
	QBS	-0.478	-0.364	-0.236	-0.108	0.069	0.164	0.258	-0.708	0.491
19	C	4.381	3.961	3.490	3.020	2.368	2.020	1.673	10.471	6.061
	T	4.381	3.961	3.490	3.020	2.368	2.020	1.673	10.471	6.061
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QS	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.335	-0.255	-0.166	-0.076	0.048	0.115	0.181	-0.497	0.344
	QBS	-0.335	-0.255	-0.166	-0.076	0.048	0.115	0.181	-0.497	0.344

LOAD FOR FOUNDATION

(D4)

No.	DESIGN STRESS				MAX	WT	No.
	NML	A.NML DIAG.WIND (U I)					
17	C	212338	150787	221616	221616	42,303	17
	T	186396	133406	195674	195674		
	Qf	30131	20921	5052	0		
	Qs	6073	5606	2699	0		
	QBf	0	0	0	0		
	QBs	0	812	0	0		
18	C	203618	143708	213261	213261	49,472	18
	T	174091	123925	183735	183735		
	Qf	30648	21057	5569	0		
	Qs	6590	5742	3010	0		
	QBf	0	0	0	0		
	QBs	230	826	66	0		
19	C	200208	140509	210904	210904	61,734	19
	T	164550	116618	175246	175246		
	Qf	31481	21459	6402	0		
	Qs	7423	6144	3509	0		
	QBf	0	0	136	0		
	QBs	746	971	397	0		

TOWER TYPE DR4			
Item		Calculation	Load (kg)
Wind Pressure (HC)	G.W.	$22.2 \times 90 \times 350 \times 10^{-3}$	699
	C ₁₋₃	$25.30 \times 2 \times 81 \times 350 \times 10^{-3}$	1,705
	Ins.	270	
	C ₄₋₆	$36.00 \times 90 \times 350 \times 10^{-3}$	1,344
	Ins.	210	
Horizontal Transverse Component of Tension (Ha)	G.W.	$3,800 \times \sin 37.5^\circ \times 2$	4,627
	C ₁₋₃	$4,000 \times \sin 37.5^\circ \times 2 \times 2$	9,740
	C ₄₋₆	$6,000 \times \sin 37.5^\circ \times 2$	7,305
Conductor and Insulator Weight (Wc)	G.W.	1.136×350	398
	C ₁₋₃	$1.239 \times 2 \times 350$	1,657
	Ins.	790	
	C ₄₋₆	2.446×350	1,476
	Ins.	620	
Effect of Vertical Angles (Va)	G.W.	$3,800 \times 0.03$	114
	C ₁₋₃	$4,000 \times 2 \times 0.03$	240
	C ₄₋₆	$6,000 \times 0.03$	180

TOWER BODY

(DR4)

UNIT STRESS

No.	G	C1	C2	C3	C4	C5	C6	CI-C3	C4-C6	No.
1	0.344	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1
2	1.012	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2
3	1.704	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	3
4	2.401	0.363	0.000	0.000	0.000	0.000	0.000	0.363	0.000	4
5	3.049	1.080	0.000	0.000	0.000	0.000	0.000	1.080	0.000	5
6	3.670	1.766	0.000	0.000	0.000	0.000	0.000	1.766	0.000	6
7	4.238	2.395	0.329	0.000	0.000	0.000	0.000	2.723	0.000	7
8	4.771	2.984	0.981	0.000	0.000	0.000	0.000	3.965	0.000	8
9	5.284	3.551	1.609	0.000	0.000	0.000	0.000	5.159	0.000	9
10	5.795	4.157	2.321	0.486	0.000	0.000	0.000	6.964	0.000	10
11	6.265	4.759	3.071	1.383	0.000	0.000	0.000	9.214	0.000	11
12	6.576	5.158	3.567	1.977	0.000	0.000	0.000	10.703	0.000	12
13	6.817	5.466	3.951	2.436	0.339	0.000	0.000	11.853	0.339	13
14	7.041	5.752	4.308	2.863	0.863	0.000	0.000	12.923	0.863	14
15	7.241	6.008	4.626	3.244	1.331	0.310	0.000	13.877	1.641	15
16	7.427	6.247	4.924	3.600	1.768	0.791	0.000	14.771	2.559	16
17	7.053	6.017	4.857	3.696	2.089	1.232	0.375	14.570	3.696	17
18	5.835	5.090	4.255	3.421	2.265	1.649	1.032	12.766	4.946	18
19	5.098	4.530	3.892	3.254	2.371	1.901	1.430	11.576	5.702	19
20	4.711	4.235	3.701	3.167	2.427	2.033	1.639	11.102	6.099	20
1	0.601	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1
2	0.576	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2
3	0.590	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	3
4	0.552	0.611	0.000	0.000	0.000	0.000	0.000	0.611	0.000	4
5	0.536	0.593	0.000	0.000	0.000	0.000	0.000	0.593	0.000	5
6	0.512	0.566	0.000	0.000	0.000	0.000	0.000	0.566	0.000	6
7	0.484	0.535	0.592	0.000	0.000	0.000	0.000	1.127	0.000	7
8	0.471	0.521	0.577	0.000	0.000	0.000	0.000	1.097	0.000	8
9	0.452	0.500	0.554	0.000	0.000	0.000	0.000	1.054	0.000	9
10	0.358	0.458	0.570	0.682	0.000	0.000	0.000	1.710	0.000	10
11	0.316	0.404	0.503	0.602	0.000	0.000	0.000	1.510	0.000	11
12	0.238	0.304	0.379	0.453	0.000	0.000	0.000	1.137	0.000	12
13	0.253	0.324	0.403	0.482	0.592	0.000	0.000	1.209	0.592	13
14	0.213	0.273	0.339	0.406	0.499	0.000	0.000	1.018	0.499	14
15	0.224	0.287	0.357	0.428	0.525	0.577	0.000	1.072	1.102	15
16	0.193	0.247	0.307	0.368	0.452	0.496	0.000	0.922	0.948	16
17	-1.050	-0.800	-0.518	-0.237	0.152	0.359	0.567	-1.556	1.078	17
18	-0.771	-0.587	-0.380	-0.174	0.111	0.264	0.416	-1.141	0.791	18
19	-0.486	-0.370	-0.240	-0.110	0.070	0.166	0.262	-0.720	0.499	19
20	-0.405	-0.308	-0.200	-0.092	0.059	0.139	0.219	-0.600	0.416	20

(DR4)

No.	DESIGN STRESS			MAX	SIZE	L.K.	L./F	STRENGTH		S.F	WT	No.
	NML	A. NML	DIAG. WIND (U ₁)					(U ₂)	U ₂ /U ₁			
1	2307	1808	2281	2307	L100*10	180	92	19290	8.36	726	1	
2	5069	4839	6032	6069	L100*10	180	92	19290	3.18	1,063	2	
3	11661	9114	11722	11722	L100*10	220	113	14166	1.21	3,814	3	
4	20173	15349	20361	20361	L175*12	210	61	77160	3.79	4,642	4	
5	32682	24226	33009	33009	L175*12	220	64	74667	2.26	5,576	5	
6	46375	33912	46377	46977	L175*12	220	64	74667	1.59	8,757	6	
7	61697	45188	62624	62624	L200*20	210	54	153131	2.45	10,301	7	
8	80223	58547	81504	81504	L200*20	220	56	149630	1.84	11,714	8	
9	99788	72568	101566	101566	L200*20	220	56	149630	1.47	15,273	9	
10	125983	91093	128478	128478	L250*25	188	38	268459	2.09	18,957	10	
11	157473	113160	160883	160883	L250*25	188	38	268653	1.67	22,143	11	
12	179818	128771	184032	184032	L250*25	180	37	270830	1.47	25,595	12	
13	200108	142861	205142	205142	L250*35	155	32	377619	1.84	29,555	13	
14	222019	157999	227896	227896	L250*35	180	37	367759	1.61	33,890	14	
15	244010	173147	250829	250829	L250*35	154	32	377760	1.51	38,232	15	
16	267401	189203	275183	275183	L250*35	180	37	367759	1.34	42,751	16	
17	275398	194192	283686	283686	L250*35	150	31	379236	1.34	47,425	17	
18	260780	182907	269267	269267	L250*35	221	46	349227	1.30	54,587	18	
19	253194	176923	262194	262194	L250*35	141	29	382319	1.46	61,486	19	
20	251308	175186	260971	260971	L250*35	163	34	374511	1.44	70,809	20	
1	3260	2782	0	3260	L 65* 6	144	113	5181	1.59		1	
2	3224	2733	0	3224	L 65* 6	147	115	5042	1.56		2	
3	3433	2887	0	3433	L 65* 6	161	127	4378	1.28		3	
4	10374	9161	0	10374	L100* 7	162	82	12578	1.21		4	
5	10222	8994	0	10222	L100*10	168	86	16948	1.66		5	
6	9964	8725	0	9964	L100* 7	172	87	12048	1.21		6	
7	16399	12922	0	16399	L130* 9	173	67	22740	1.39		7	
8	16163	12713	0	16163	L130* 9	179	70	22740	1.41		8	
9	15762	12371	0	15762	L130* 9	183	71	22740	1.44		9	
10	23127	17528	0	23127	L150*12	238	80	32617	1.41		10	
11	20823	15746	0	20823	L150*10	247	83	26742	1.28		11	
12	15984	12061	0	15984	L130* 9	205	80	21412	1.34		12	
13	22448	16477	0	22448	L150*10	243	82	27049	1.20		13	
14	19222	14089	0	19222	L150*10	222	75	28617	1.49		14	
15	25593	18422	0	25593	L150*12	258	87	30758	1.20		15	
16	22346	16068	0	22346	L150*10	240	81	27320	1.22		16	
17	154	1936	0	1936	L 65* 6	204	161	2759	1.43		17	
18	713	1822	0	1822	L 80* 6	293	161	2582	1.42		18	
19	1126	1602	0	1602	L 75* 6	289	195	2171	1.35		19	
20	1675	1829	0	1829	L 90* 6	343	192	2705	1.48		20	

TLC-1-104

CROSSARM

(DR4)

UNIT STRESS										DESIGN STRESS					STRENGTH OF MEMBER				
	AH	AP	AV	G	UC	LC	Hc	Hs	F	Va	Wc	NML	A-NML	UI	SIZE	L	I/r	STRENGTH (U2)	S.F (U2/U1)
M	0.59	0.95	0.67	412	792	2157	76	265	3701	0	3701	0	3701	0	L 90* 6	240	135	5532	1.49
G	0.00	0.00	0.83	0	0	0	95	330	424	0	424	0	424	0	L 70* 6	299	218	1625	3.83
X	0.00	0.11	0.00	0	0	245	0	0	0	164	164	0	164	0	L 45* 4	179	203	801	4.89
M	0.52	1.82	1.16	886	5055	8736	278	1919	16885	0	16885	0	16885	0	L175*15	510	149	21483	1.27
C 1	0.00	0.00	1.27	0	0	0	305	2103	2407	0	2407	0	2407	0	L130* 9	558	217	34999	14.54
X	0.00	0.44	0.00	0	0	2121	0	0	0	1421	1421	0	1421	0	L 60* 5	198	168	1958	1.38
M	0.53	1.61	1.14	896	5123	7737	273	1882	15910	0	15910	0	15910	0	L175*15	500	146	22348	1.40
C 2	0.00	0.00	1.25	0	0	0	298	2068	2367	0	2367	0	2367	0	L130* 9	549	214	34999	14.79
X	0.00	0.36	0.00	0	0	1752	0	0	0	1174	1174	0	1174	0	L 60* 5	219	186	1597	1.36
M	0.53	1.44	1.11	909	5192	6923	267	1847	15139	0	15139	0	15139	0	L175*12	490	143	18941	1.25
C 3	0.00	0.00	1.23	0	0	0	295	2035	2330	0	2330	0	2330	0	L130* 9	540	210	34999	15.02
X	0.00	0.30	0.00	0	0	1447	0	0	0	970	970	0	970	0	L 60* 5	240	204	1328	1.37
M	0.57	1.02	1.18	771	4190	3673	213	1746	10594	0	10594	0	10594	0	L150*10	426	143	13493	1.27
C 4	0.00	0.00	1.29	0	0	0	233	1908	2140	0	2140	0	2140	0	L120* 8	465	195	28331	13.24
X	0.00	0.14	0.00	0	0	496	0	0	0	332	332	0	332	0	L 70* 6	295	215	1663	5.01
M	0.60	0.91	1.16	803	4365	3288	209	1718	10383	0	10383	0	10383	0	L150*10	419	141	13943	1.34
C 5	0.00	0.00	1.27	0	0	0	229	1879	2108	0	2108	0	2108	0	L120* 8	458	193	28331	13.44
X	0.00	0.09	0.00	0	0	337	0	0	0	225	225	0	225	0	L 75* 6	324	219	1726	7.65
M	0.63	0.83	1.15	843	4582	2981	207	1698	10311	0	10311	0	10311	0	L150*10	414	139	14281	1.39
C 6	0.00	0.00	1.26	0	0	0	226	1857	2084	0	2084	0	2084	0	L120* 8	453	190	28331	13.60
X	0.00	0.06	0.00	0	0	204	0	0	0	136	136	0	136	0	L 90* 6	354	199	2540	18.62

CROSSARM (IN TOWER BODY)

(DR4)

UNIT STRESS										DESIGN STRESS				STRENGTH OF MEMBER			
AH	AF	AV	HC	HE	P	Va	Wc	MAX		NML	A. NML	(U)	SIZE	L	L / F	STRENGTH (U2)	S.F. U2/U1
G										G				G			
M	0.00	0.40	0.57	0	0	916	255	807	807	289	807	807	L 90* 6	253	142	4953	6.14
S	0.31	0.00	0.35	218	418	0	40	816	0	816	0	816	L 60* 4	253	213	4585	5.62
SF	0.00	0.00	0.55	0	0	0	63	283	0	283	0	283	L 60* 4	262	220	4585	16.19
SS	0.00	0.00	0.36	0	0	0	41	186	0	186	0	186	L 60* 4	253	213	985	5.30
C 1										C 1				C 1			
M	0.00	0.88	1.11	0	0	4200	267	1846	4230	2113	4230	4230	L175*15	280	82	46502	10.99
S	0.14	0.00	0.32	244	1391	0	76	527	2239	2239	0	2239	L 70* 6	280	204	8226	3.67
SF	0.00	0.00	1.13	0	0	0	270	1865	2135	2135	0	2135	L 65* 6	270	212	7483	3.51
SS	0.00	0.00	0.31	0	0	0	74	508	582	582	0	582	L 85* 6	270	212	1584	2.72
C 2										C 2				C 2			
M	0.00	0.77	1.08	0	0	3677	259	1789	3836	2048	3836	3836	L175*15	310	91	43145	11.25
S	0.16	0.00	0.35	278	1589	0	85	584	2536	2536	0	2536	L 75* 6	310	209	8968	3.54
SF	0.00	0.00	1.09	0	0	0	262	1808	2070	2070	0	2070	L 70* 6	300	219	8226	3.97
SS	0.00	0.00	0.34	0	0	0	82	565	646	646	0	646	L 70* 6	300	219	1612	2.49
C 3										C 3				C 3			
M	0.00	0.68	1.05	0	0	3247	251	1733	3505	1984	3505	3505	L175*12	340	99	32289	9.21
S	0.18	0.00	0.39	315	1800	0	93	540	2848	2848	0	2848	L 80* 6	340	215	9711	3.41
SF	0.00	0.00	1.06	0	0	0	254	1732	2005	2005	0	2005	L 80* 6	330	209	9711	4.84
SS	0.00	0.00	0.37	0	0	0	90	621	711	711	0	711	L 80* 5	330	209	2033	2.86
C 4										C 4				C 4			
M	0.00	0.44	1.03	0	0	1601	186	1522	2217	1708	2217	2217	L150*10	417	141	14048	6.34
S	0.28	0.00	0.58	378	2053	0	104	856	3391	3391	0	3391	L100* 7	417	212	14718	4.34
SF	0.00	0.00	1.05	0	0	0	190	1554	1744	1744	0	1744	L100* 7	402	204	14718	8.44
SS	0.00	0.00	0.56	0	0	0	100	824	925	925	0	925	L100* 7	402	204	3108	3.36
C 5										C 5				C 5			
M	0.00	0.38	0.97	0	0	1376	175	1438	2003	1613	2003	2003	L150*10	459	154	11633	5.81
S	0.33	0.00	0.64	440	2389	0	115	940	3884	3884	0	3884	L120* 8	459	193	28331	7.29
SF	0.00	0.00	1.00	0	0	0	179	1469	1649	1649	0	1649	L120* 8	443	186	28331	17.18
SS	0.00	0.00	0.62	0	0	0	111	909	1019	1019	0	1019	L120* 8	443	186	5139	5.04
C 6										C 6				C 6			
M	0.00	0.33	0.92	0	0	1188	165	1353	1813	1518	1813	1813	L150*10	500	168	9791	5.40
S	0.38	0.00	0.69	509	2767	0	125	1025	4426	4426	0	4426	L120* 8	500	210	26699	6.03
SF	0.00	0.00	0.94	0	0	0	169	1385	1554	1554	0	1554	L120* 8	485	204	28331	18.23
SS	0.00	0.00	0.67	0	0	0	121	993	1114	1114	0	1114	L120* 8	485	204	4300	3.86

FOUNDATION

(DR4)

UNIT STRESS

No.	G	C1	C2	C3	C4	C5	C6	C1-C3	C4-C6	No.
17	C	6.139	5.299	4.358	3.417	2.114	1.419	0.724	13.074	4.257
	T	6.139	5.299	4.358	3.417	2.114	1.419	0.724	13.074	4.257
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QS	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.671	-0.510	-0.331	-0.152	0.097	0.229	0.362	-0.993	0.688
	QBS	-0.671	-0.510	-0.331	-0.152	0.097	0.229	0.362	-0.993	0.688
18	C	5.129	4.530	3.859	3.189	2.260	1.765	1.269	11.578	5.294
	T	5.129	4.530	3.859	3.189	2.260	1.765	1.269	11.578	5.294
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QS	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.478	-0.364	-0.236	-0.108	0.069	0.164	0.258	-0.708	0.491
	QBS	-0.478	-0.364	-0.236	-0.108	0.069	0.164	0.258	-0.708	0.491
19	C	4.717	4.216	3.656	3.096	2.319	1.906	1.492	10.968	5.717
	T	4.717	4.216	3.656	3.096	2.319	1.906	1.492	10.968	5.717
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QS	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.399	-0.304	-0.197	-0.090	0.058	0.137	0.216	-0.591	0.410
	QBS	-0.399	-0.304	-0.197	-0.090	0.058	0.137	0.216	-0.591	0.410
20	C	4.381	3.961	3.490	3.020	2.368	2.020	1.673	10.471	6.061
	T	4.381	3.961	3.490	3.020	2.368	2.020	1.673	10.471	6.061
	Qf	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QS	0.500	0.500	0.500	0.500	0.500	0.500	0.500	1.500	1.500
	QBf	-0.335	-0.255	-0.166	-0.076	0.048	0.115	0.181	-0.497	0.344
	QBS	-0.335	-0.255	-0.166	-0.076	0.048	0.115	0.181	-0.497	0.344

No.	HT	HTA			HC			Ha			F			Va	Wc	WT	E	E'
		S	F	G	G	C1-3	C4-6	G	C1-3	C4-6	G	C1-3	C4-6					
		1.0	0.05	699	1705	1344	4627	9740	7305	1140	2400	1800						
C	20221	8958	448	4293	22285	5721	28402	127344	31096	6998	12718	3805	0	687	4899	11856	0	0
T	20221	8958	448	4293	22285	5721	28402	127344	31096	6998	12718	3805	0	0	0	-11856	0	0
17	Qf	0	129	350	2557	2016	2313	14610	10958	0	0	0	1095	0	0	0	0	0
	QS	3595	0	0	0	0	0	0	0	570	1200	900	1095	0	0	0	0	0
	QBi	-261	0	-21	-469	-1692	925	-3102	-9671	5028	0	0	1095	0	0	0	0	0
	QBS	-261	-417	0	0	0	0	0	0	0	0	652	756	0	0	0	0	0
C	20521	8330	416	3586	19735	7115	23728	112773	38572	5847	10872	4068	0	687	4899	13647	0	0
T	20521	8330	416	3586	19735	7115	23728	112773	38572	5847	10872	4068	0	0	0	-13647	0	0
18	Qf	4121	0	129	350	2557	2016	2313	14610	10958	0	0	780	0	0	0	0	0
	QS	4121	0	0	0	0	0	0	0	570	1200	900	780	0	0	0	0	0
	QBi	189	0	-15	-334	-1206	659	-2211	-6893	3584	0	0	780	0	0	0	0	0
	QBS	189	-297	0	0	0	0	0	0	0	0	464	539	0	0	0	0	0
C	21330	8073	404	3298	18695	7683	21821	106829	41762	5377	10119	4175	0	687	4899	15372	0	0
T	21330	8073	404	3298	18695	7683	21821	106829	41762	5377	10119	4175	0	0	0	-15372	0	0
19	Qf	4754	0	129	350	2557	2016	2313	14610	10958	0	0	652	0	0	0	0	0
	QS	4754	0	0	0	0	0	0	0	570	1200	900	652	0	0	0	0	0
	QBi	687	0	-12	-279	-1008	551	-1848	-5760	2995	0	0	652	0	0	0	0	0
	QBS	687	-249	0	0	0	0	0	0	0	0	388	450	0	0	0	0	0
C	22517	7864	393	3064	17848	8146	20270	101991	44277	4994	9507	4262	0	687	4899	17702	0	0
T	22517	7864	393	3064	17848	8146	20270	101991	44277	4994	9507	4262	0	0	0	-17702	0	0
20	Qf	5480	0	129	350	2557	2016	2313	14610	10958	0	0	547	0	0	0	0	0
	QS	5480	0	0	0	0	0	0	0	570	1200	900	547	0	0	0	0	0
	QBi	1187	0	-10	-235	-846	463	-1552	-4837	2515	0	0	547	0	0	0	0	0
	QBS	1187	-209	0	0	0	0	0	0	0	0	326	378	0	0	0	0	0

LOAD FOR FOUNDATION

(DR4)

No.	DESIGN STRESS				MAX	WT	No.
	NML	A.NML DIAG.WIND (UI)		(UI)			
17	C	257252	180880	265341	265341	47,425	17
	T	227954	161250	236043	236043		
	Qf	36527	25207	5807	0		
	Qs	6176	5675	2802	0		
	QBf	0	0	0	0		
	QBs	0	768	0	0		
18	C	245879	172024	254391	254391	54,587	18
	T	213000	149995	221512	221512		
	Qf	37054	25349	6333	0		
	Qs	6703	5818	3118	0		
	QBf	0	0	0	0		
	QBs	189	799	39	0		
19	C	242780	169442	251791	251791	61,486	19
	T	206451	145102	215462	215462		
	Qf	37687	25687	6966	0		
	Qs	7336	6156	3498	0		
	QBf	0	0	0	0		
	QBs	687	1022	350	0		
20	C	241795	168372	251579	251579	70,809	20
	T	200804	140908	210589	210589		
	Qf	38413	26103	7692	0		
	Qs	8062	6572	3933	0		
	QBf	0	0	373	0		
	QBs	1187	1267	660	0		