


12. DRAWINGS

TLG-1-252

DRAWING NO.	DESCRIPTION
1. WLT-1001	ROUTE MAP
2. WLT-1002	BORING POINT AND BORING LOG
3. WLT-1101	SKELETON OF TOWER (1)
4. WLT-1102	SKELETON OF TOWER (2)
5. WLT-1103	SKELETON OF TOWER (3)
6. WLT-1104	CONFIGURATION AT THE PLACE OF TOWER NO. 1
7. WLT-1105	PLAN AT THE PLACE OF TOWER NO. 1
8. WLT-1106	ARRANGEMENT OF 220 KV INCOMING LINES AT TOWER NO. 1
9. WLT-1107	CLEARANCE DIAGRAM (1)
10. WLT-1108	CLEARANCE DIAGRAM (2)
11. WLT-1109	CLEARANCE DIAGRAM (3)
12. TLT-01	SKELETON OF TOWER AS
13. TLT-02	SKELETON OF TOWER A
14. TLT-03	SKELETON OF TOWER AL
15. TLT-04	SKELETON OF TOWER B
16. TLT-05	SKELETON OF TOWER C
17. TLT-06	SKELETON OF TOWER D & DR
18. TLT-07	SKELETON OF TOWER A4
19. TLT-08	SKELETON OF TOWER D4
20. TLT-09	SKELETON OF TOWER DR4
21. WLT-1201	220 KV V-SUSPENSION INSULATOR STRING
22. WLT-1202	220 KV SINGLE TENSION INSULATOR STRING
23. WLT-1203	220 KV DOUBLE TENSION INSULATOR STRING
24. WLT-1204	220 KV JUMPER SUPPORT INSULATOR STRING
25. WLT-1205	132 KV SINGLE SUSPENSION INSULATOR STRING
26. WLT-1206	132 KV SINGLE TENSION INSULATOR STRING

DRAWING NO.	DESCRIPTION
27.	WLT-1207 132 KV DOUBLE TENSION INSULATOR STRING
28.	WLT-1208 132 KV JUMPER SUPPORT INSULATOR STRING
29.	WLT-1209 132 KV TIE DOWN INSULATOR STRING
30.	WLT-1210 FOG TYPE SUSPENSION INSULATOR
31.	WLT-1601 INDIVIDUAL TYPE TOWER FOUNDATION (I-DRY, I-WET)
32.	WLT-1602 PILE TYPE TOWER FOUNDATION (1/2)
33.	WLT-1603 PILE TYPE TOWER FOUNDATION (2/2)
34.	WLT-1604 RIGID FRAME TOWER FOUNDATION (AL-R)



BALDIA
GRID STATION

MAURIPUR
GRID STATION


WEST WHARF
THERMAL
POWER STATION

LEGEND

- TRANSMISSION LINE
- - - UNDERGROUND CABLE

TH LIMITATION OF TOWER HEIGHT

PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
ROUTE MAP			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1001		SCALE 1/40,000	DATE 10TH JAN 1990



WEST WHARF
THERMAL
POWER STATION

BALDIA
GRID STATION

MAURIPUR
GRID STATION


LEGEND
 — TRANSMISSION LINE
 ⊙ BORING POINT

PAKISTAN
 KARACHI ELECTRIC SUPPLY CORPORATION
 WEST WHARF THERMAL POWER PLANT PROJECT
 UNITS NO.1 AND NO.2


BORING POINT AND BORING LOG
 JAPAN INTERNATIONAL COOPERATION AGENCY

TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1002	SCALE 1/40,000	DATE 10TH JAN 1990	


TYPE AL






TYPE A



TYPE AS




PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
SKELETON OF TOWER (1)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1101		SCALE 1/300	DATE 10TH JAN 1990




PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
SKELETON OF TOWER (2)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>Hakky</i>	REVIEWED BY	CHECKED BY <i>Hakky</i>	DRAWN BY <i>Hakky</i>
DRAWING NO. WLT-1102	SCALE 1/300	DATE 10TH JAN 1990	


TYPE A4







TYPE D4 & DR4





TYPE D4




PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
SKELETON OF TOWER (3)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>H. H. H.</i>	REVIEWED BY	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1103	SCALE 1/300	DATE 10TH JAN 1990	



PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
CONFIGURATION AT THE PLACE			
OF TOWER No. 1			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>Halty</i>	REVIEWED BY	CHECKED BY <i>Shiray</i>	DRAWN BY <i>Shiray</i>
DRAWING NO. WLT-1104	SCALE 1/300	DATE 10TH JAN 1990	






PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
PLAN AT THE PLACE OF TOWER No.1			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1105		SCALE 1/300	DATE 10TH JAN 1990



PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
ARRANGEMENT OF 220 kV INCOMING LINES AT TOWER No.1			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY <i>[Signature]</i>	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1106		SCALE 1/200	DATE 10TH JAN 1990


AS/A/AL

B




PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
CLEARANCE DIAGRAM (1)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY <i>[Signature]</i>	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO WLS-1107	SCALE	DATE 10TH JAN 1990	

C




D/DR




PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
CLEARANCE DIAGRAM (2)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>H. H. H.</i>	REVIEWED BY <i>H. H. H.</i>	CHECKED BY <i>H. H. H.</i>	DRAWN BY <i>H. H. H.</i>
DRAWING NO. WLT-1108		SCALE	DATE 10TH JAN 1990

A4




D4/DR4



PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
CLEARANCE DIAGRAM (3)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY	REVIEWED BY	CHECKED BY	DRAWN BY
<i>[Signature]</i>		<i>[Signature]</i>	<i>[Signature]</i>
DRAWING NO	SCALE	DATE	
WLT-1109		10TH JAN 1990	

As

S=1 / 150





$$B/H = 1 / 4.71$$

$$2 \tan \theta = .241$$

DWG.NO. TLT-01

A

S=1 / 200




B/H = 1 / 4.56
2tanθ = .244

DWG.NO. TLT-02

AL

S=1 / 200




B/H = 1 / 4.5
 $2 \tan \theta = .245$

DWG.NO. TLT-03

B

S=1 / 200




$B/H = 1 / 3.9$
 $2 \tan \theta = .297$

DWG.NO. TLT-04

C

S=1 / 200



$$B/H = 1 / 3.96$$


$$2 \tan \theta = .297$$

DWG.NO. TLT-05

81

D / DR

S=1 / 200





$$B/H = 1 / 3.6$$
$$2 \tan \theta = .384$$

DWG.NO. TLT-06

11

A4

S=1 / 300



$B/H = 1 / 6.42$



$2 \tan \theta = .187$

DWG.NO. TLT-07

02

D4

S=1 / 300




$B/H = 1 / 4.36$

$2 \tan \theta = .381$

DWG.NO. TLT-08

DR4

S=1 / 300




$B/H = 1 / 4.36$

$2 \tan \theta = .381$

DWG.NO. TLT-09

5600



ITEM	DESCRIPTION	MAIN MATERIAL	REQD.
1	ANCHOR SHACKLE	HIGH TENSION STEEL	4
2	HORN HOLDER BALL EYE	HIGH TENSION STEEL	2
3	ARCING HORN	STEEL	2
4	SUSPENSION INSULATOR	PORCELAIN	22x2
5	ARCING HORN	STEEL	1
6	SOCKET CLEVIS	DUCTILE IRON	2
7	Y O K E	STEEL	1
8	CLEVIS EYE	STEEL	2
9	SUSPENSION CLAMP	ALUMINIUM ALLOY	2
10	EYE LINK	HIGH TENSION STEEL	2
MIN. BREAKING STRENGTH OF STRING		12000kg	
SUITABLE CONDUCTOR SIZE OF CLAMP		39.3#~44.3#	
TYPE OF BALL AND SOCKET PARTS		IEC 16mm A	

PAKISTAN

KARACHI ELECTRIC SUPPLY CORPORATION

WEST WHARF THERMAL POWER PLANT PROJECT

UNITS NO.1 AND NO.2


220 kV V-SUSPENSION INSULATOR STRING

JAPAN INTERNATIONAL COOPERATION AGENCY

TOKYO JAPAN

APPROVED BY	ENTERED BY	CHECKED BY	DATE
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	10 FEB 1990
DISIGNED BY	SCALE		
	NIT-1201		

TOWER PLATE THICKNESS MAX. 19



ITEM	DESCRIPTION	MAIN MATERIAL	REQD.
1	ANCHOR SHACKLE	HIGH TENSION STEEL	/
2	HORN HOLDER BALL EYE	HIGH TENSION STEEL	/
3	SUSPENSION INSULATOR	PORCELAIN	23
4	SOCKET CLEVIS	DUCTILE IRON	/
5	ANCHOR SHACKLE	HIGH TENSION STEEL	2
6	COMPRESSION CLAMP ALUMINIUM	ALUMINIUM	2
7	YOKE	STEEL	1
8	ARCING HORN	STEEL	1
9	ARCING HORN	STEEL	1

SUITABLE CONDUCTOR SIZE OF CLAMP ACSR/AS 330mm²
 MIN. BREAKING STRENGTH OF STRING EXCEPT COMPRESSION CLAMP 12000kg
 TYPE OF BALL AND SOCKET PARTS IEC 16mm A


PAKISTAN
 KARACHI ELECTRIC SUPPLY CORPORATION
 WEST WHARF THERMAL POWER PLANT PROJECT
 UNITS NO.1 AND NO.2
 220 KV SINGLE TENSION INSULATOR STRING

JAPAN INTERNATIONAL COOPERATION AGENCY
 TOKYO JAPAN

APPROVED BY: *[Signature]*
 CHECKED BY: *[Signature]*
 DRAWN BY: *[Signature]*
 SCALE: 1:1
 DATE: 10TH JAN 1990

WLT-1202

TOWER PLATE THICKNESS MAX. 19.




ITEM	DESCRIPTION	MAIN MATERIAL	REQD.
(1)	ANCHOR SHACKLE	HIGH TENSION STEEL	2
(2)	CHAIN LINK	HIGH TENSION STEEL	1
(3)	YORK	STEEL	1
(4)	ARCING HORN	STEEL	1
(5)	BALL-CLEVIS	HIGH TENSION STEEL	2
(6)	SUSPENSION INSULATOR	PORCELAIN	23X2
(7)	SOCKET-CLEVIS	DUCTILE IRON	2
(8)	YORK	STEEL	1
(9)	ARCING HORN	STEEL	1
(10)	ANCHOR SHACKLE	HIGH TENSION STEEL	2
(11)	COMPRESSION CLAMP	ALUMINIUM	2

SUITABLE CONDUCTOR SIZE OF CLAMP ACSR/AS 330mm²
 * MIN. BREAKING STRENGTH OF STRING 24000kg
 EXCEPT COMPRESSION CLAMP
 TYPE OF BALL AND SOCKET PARTS IEC 16mm A

PAKISTAN
 KARACHI ELECTRIC SUPPLY CORPORATION
 WEST WHARF THERMAL POWER PLANT PROJECT
 UNITS NO.1 AND NO.2
 220 kV DOUBLE TENSION INSULATOR STRING
 JAPAN INTERNATIONAL COOPERATION AGENCY
 TOKYO JAPAN

APPROVED BY <i>[Signature]</i>	REVIEWED BY <i>[Signature]</i>	DESIGNED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DATE 10/01/89	SCALE 1:1	PROJECT NO. WLT-1203	DATE 10/01/89

TOWER PLATE THICKNESS MAX. 19



ITEM	DESCRIPTION	MAIN MATERIAL	REQD
①	ANCHOR SHACKLE	HIGH TENSION STEEL	1
②	BALL EYE	HIGH TENSION STEEL	1
③	SUSPENSION INSULATOR	PORCELAIN	22
④	SOCKET CLEVIS	DUCTILE IRON	1
⑤	CLEVIS EYE	STEEL	2
⑥	SUSPENSION CLAMP	ALUMINIUM ALLOY	2
⑦	YDKE	STEEL	1


SUITABLE CONDUCTOR SIZE OF CLAMP 39.3φ ~ 44.3φ
 MIN. BREAKING STRENGTH OF STRING 12000kg
 TYPE OF BALL AND SOCKET PARTS IEC 16mm A

PAKISTAN
 KARACHI ELECTRIC SUPPLY CORPORATION
 WEST WHARF THERMAL POWER PLANT PROJECT
 UNITS NO.1 AND NO.2
 220 KV JUMPER SUPPORT INSULATOR STRING

JAPAN INTERNATIONAL COOPERATION AGENCY
 TOKYO JAPAN

APPROVED BY: *[Signature]* CHECKED BY: *[Signature]* DRAWN BY: *[Signature]*
 DATE: 10/25 JULY 1990
 SCALE: 1:1
 DRAWING NO: WLT-204


TOWER PLATE THICKNESS MAX.: 19



ITEM	DESCRIPTION	MAIN MATERIAL	REQD
1	ANCHOR SHACKLE	HIGH TENSION STEEL	1
2	HORN HOLDER BALL EYE	HIGH TENSION STEEL	1
3	ARCING HORN	STEEL	1
4	SUSPENSION INSULATOR	PORCELAIN	14
5	HORN HOLDER SOCKET EYE	MALLEABLE IRON OR DUCTILE IRON	1
6	ARCING HORN	STEEL	1
7	SUSPENSION CLAMP	ALUMINIUM ALLOY	1
SUITABLE CONDUCTOR SIZE OF CLAMP			43.2φ ~ 57.1φ
MIN. BREAKING STRENGTH OF STRING			12000kg
TYPE OF BALL AND SOCKET PARTS			IEC 16mm A

PAKISTAN		TOKYO JAPAN	
KARACHI ELECTRIC SUPPLY CORPORATION		JAPAN INTERNATIONAL COOPERATION AGENCY	
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
132 KV SINGLE SUSPENSION INSULATOR STRING			
APPROVED BY	REVIEWED BY	CHECKED BY	DRAWN BY
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	N. MOKA
DATE	SCALE	DATE	SCALE
	WLT-1205	10TH JAN 1990	

IRON PLATE THICKNESS MAX. 1.9




ITEM	DESCRIPTION	MAIN MATERIAL	REQD
1	ANCHOR SHACKLE	HIGH TENSION STEEL	1
2	HORN HOLDER BALL EYE	HIGH TENSION STEEL	1
3	ARCING HORN	STEEL	1
4	SUSPENSION INSULATOR	PORCELAIN	15
5	HORN HOLDER SOCKET EYE	MALLEABLE IRON OR DUCTILE IRON	1
6	ARCING HORN	STEEL	1
7	ANCHOR SHACKLE	HIGH TENSION STEEL	1
8	COMPRESSION CLAMP	ALUMINIUM	1

SUITABLE CONDUCTOR SIZE OF CLAMP ACSR/AS 680mm²
 MIN. BREAKING STRENGTH OF STRING 12000Kg
 EXCEPT COMPRESSION CLAMP IEC 16mm A
 TYPE OF BALL AND SOCKET PARTS

PAKISTAN
 KARACHI ELECTRIC SUPPLY CORPORATION
 WEST WHARF THERMAL POWER PLANT PROJECT
 UNITS NO.1 AND NO.2
 132 KV SINGLE TENSION INSULATOR STRING
 JAPAN INTERNATIONAL COOPERATION AGENCY
 TOKYO JAPAN

APPROVED BY: *[Signature]* CHECKED BY: *[Signature]* DRAWN BY: *[Signature]*
 DATE: 10 FEB JAN 1990
 SCALE: WDT-1206

LOWER PLATE THICKNESS MAX. 19



ITEM	DESCRIPTION	MAIN MATERIAL	REQD.
1	ANCHOR SHACKLE	HIGH TENSION STEEL	2
2	CHAIN LINK	HIGH TENSION STEEL	1
3	TOYE	STEEL	2
4	ARCING HORN	STEEL	1
5	BALL-CLEMS	HIGH TENSION STEEL	2
6	SUSPENSION INSULATOR	PORCELAIN	15X2
7	SOCKET-CLEMS	MALLEABLE IRON OR DUCTILE IRON	2
8	ARCING HORN	STEEL	1
9	ANCHOR SHACKLE	HIGH TENSION STEEL	1
10	COMPRESSION CLAMP	ALUMINIUM	1


SUITABLE CONDUCTOR SIZE OF CLAMP ACSR/AS 680mm²
 MIN. BREAKING STRENGTH OF STRING 12000kg
 # FACETZ COMPRESSION CLAMP
 TYPE OF BALL AND SOCKET PART IEC 16mm A

PAKISTAN
 KARACHI ELECTRIC SUPPLY CORPORATION
 WEST WHARF THERMAL POWER PLANT PROJECT
 UNITS NO.1 AND NO.2
 132 KV DOUBLE TENSION INSULATOR STRING
 JAPAN INTERNATIONAL COOPERATION AGENCY
 TOKYO JAPAN

APPROVED BY: [Signature]
 CHECKED BY: [Signature]
 DRAWN BY: N. NOYE
 DATE: 10TH JAN 1990

REVISION NO. WJT-1207

TOWER PLATE THICKNESS MAX.: 19




ITEM	DESCRIPTION	MAIN MATERIAL	REQD
1	ANCHOR SHACKLE	HIGH TENSION STEEL	1
2	BALL EYE	HIGH TENSION STEEL	1
3	SUSPENSION INSULATOR	PORCELAIN	14
4	SOCKET-EYE	MALLEABLE IRON OR SPHERICAL GRAPHITE IRON DUCTILE IRON	1
5	SUSPENSION CLAMP	MALLEABLE IRON OR DUCTILE IRON	1
SUITABLE CONDUCTOR SIZE OF CLAMP		43.2# ~ 57.1#	
MIN. BREAKING STRENGTH OF STRING		12000kg	
TYPE OF BALL AND SOCKET PARTS		IEC 16mm A	

PAKISTAN
 KARACHI ELECTRIC SUPPLY CORPORATION
 WEST WHARF THERMAL POWER PLANT PROJECT
 UNITS NO.1 AND NO.2
 132 KV JUMPER SUPPORT INSULATOR STRING
 JAPAN INTERNATIONAL COOPERATION AGENCY
 TOKYO JAPAN

APPROVED BY: [Signature] CHECKED BY: [Signature]
 DRAWN BY: N. UDUK
 DATE: 10TH JAN 1990
 SCALE: WLS-1208

LOWER PLATE THICKNESS MAX.: 19



ITEM	DESCRIPTION	MAIN MATERIAL	REQD
①	ANCHOR SHACKLE	HIGH TENSION STEEL	1
②	BALL EYE	HIGH TENSION STEEL	1
③	SUSPENSION INSULATOR	PORCELAIN	14
④	SOCKET-EYE	MALLEABLE IRON OR DUCTILE IRON	1
⑤	STRAIN CLAMP	ALUMINIUM ALLOY	1

SUITABLE CONDUCTOR SIZE OF CLAMP	30.5φ~43.2φ
MIN. BREAKING STRENGTH OF STRING	12000kg
TYPE OF BALL AND SOCKET PARTS	IEC 16mm A



PAKISTAN	KARACHI ELECTRIC SUPPLY CORPORATION	
WEST WHARF THERMAL POWER PLANT PROJECT		
UNITS NO.1 AND NO.2		
132KV		
TIE DOWN INSULATOR STRING		
JAPAN INTERNATIONAL COOPERATION AGENCY		
TOKYO JAPAN		
APPROVED BY	CHECKED BY	DRAWN BY
<i>[Signature]</i>	<i>[Signature]</i>	N. I. M. U. Q.
DATE	SCALE	DATE
10 FEB JAN 1990	WLS-1209	

TECHNICAL DATA

SPECIFICATION APPLIED : IEC Pub. 383-1983

Characteristics Rating

Characteristics	Rating
1. Type of ball and socket coupling	IEC 16mm A
2. Creepage distance (mm)	432
3. Electro-mechanical failing load (kN)	120
4. Dry lightning impulse withstand voltage (kV)	125
5. Wet power-frequency withstand voltage (kV)	45
6. Power-frequency puncture voltage (kV)	130



ITEM	MATERIAL
①	DUCTILE IRON
②	PORCELAIN
③	HIGH TENSION STEEL
④	STAINLESS STEEL

PAKISTAN

KARACHI ELECTRIC SUPPLY CORPORATION


WEST WHARF THERMAL POWER PLANT PROJECT
UNITS NO.1 AND NO.2

FOG TYPE SUSPENSION INSULATOR


JAPAN INTERNATIONAL COOPERATION AGENCY

TOKYO JAPAN


APPROVED BY <i>[Signature]</i>	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1210	SCALE	DATE 10/10/82
		LOTS: JAN 1990




SECTION A - A



SECTION A - A



FOUNDATION PLAN



FOUNDATION PLAN

(UNIT : m)

TOWER TYPE	B	H	t	f	Df	a	a ₁	a ₂	b	L _{20θ}	L ₁	L _{1/2}	L ₂	L	ANGLE SIZE
As-D-1	2.200	1.800	0.800	0.450	2.150	0.450	0.008	0.442	0.900	0.12069	6.891	3.4455	1.4135	9.718	L150-12
A-D-1	2.300	2.000	0.800	0.450	2.350	0.550	0.006	0.494	1.050	0.12204	8.890	4.4450	1.4915	11.873	L175-12
B-D-1	2.700	2.000	0.800	0.450	2.350	0.550	0.003	0.597	1.150	0.14865	9.866	4.9330	1.7660	13.398	L175-12
C-D-1	3.400	2.400	1.000	0.450	2.950	0.600	0.015	0.935	1.150	0.14865	9.866	4.9330	2.2055	14.277	L200-15
D-D-1	3.400	2.400	1.000	0.450	2.950	0.600	0.015	0.935	1.150	0.19186	9.827	4.9135	2.3520	14.531	L200-20
DR-D-1	3.900	2.900	1.000	0.450	3.450	0.600	0.019	1.131	1.750	0.19186	9.827	4.9135	2.6980	15.223	L200-25

INDIVIDUAL TYPE TOWER FOUNDATION (I-DRY)

(UNIT : m)

TOWER TYPE	B	H	t	f	Df	a	a ₁	a ₂	b	L _{20θ}	L ₁	L _{1/2}	L ₂	L	ANGLE SIZE
As-C-1	4.000	3.000	1.000	0.450	3.550	0.450	0.013	0.737	1.200	0.12069	6.891	3.4455	2.4825	11.656	L150-12
B-C-1	4.700	3.800	1.000	0.450	4.350	0.550	0.010	1.140	1.700	0.14865	9.866	4.9330	3.0630	15.992	L175-12
C-C-1	5.600	4.200	1.200	0.450	4.950	0.600	0.020	1.630	2.250	0.14865	9.866	4.9330	3.6025	17.071	L200-15
D-C-1	5.600	4.200	1.200	0.450	4.950	0.600	0.018	1.631	2.250	0.19186	9.827	4.9135	3.8300	17.499	L200-20
DR-C-1	6.000	4.900	1.200	0.450	5.650	0.600	0.010	1.890	2.500	0.19186	9.827	4.9135	4.1700	18.167	L200-25


INDIVIDUAL TYPE TOWER FOUNDATION (I-WET)

PAKISTAN
KARACHI ELECTRIC SUPPLY CORPORATION


WEST WHARF THERMAL POWER PLANT PROJECT
UNITS NO.1 AND NO.2
INDIVIDUAL TYPE TOWER FOUNDATION (I-DRY, I-WET)

JAPAN INTERNATIONAL COOPERATION AGENCY
TOKYO JAPAN


APPROVED BY <i>[Signature]</i>	REVIEWED BY <i>[Signature]</i>	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WLT-1501	SCALE	DATE 10TH JAN 1990	




SECTION A - A



SECTION A - A




FOUNDATION PLAN
(A1 - S - III)




FOUNDATION PLAN
(A4 - S - III)

PILE TYPE TOWER FOUNDATION (1/2)

PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
PILE TYPE TOWER FOUNDATION (1/2)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY <i>[Signature]</i>	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DATE	DATE	DATE	DATE
WLT-1602			10TH JAN 1990




SECTION A - A




FOUNDATION PLAN
(DR4 - S - II)
(D4 - S - II)

PILE TYPE TOWER FOUNDATION (2/2)

PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
PILE TYPE TOWER FOUNDATION (2/2)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>[Signature]</i>	REVIEWED BY <i>[Signature]</i>	CHECKED BY <i>[Signature]</i>	DRAWN BY <i>[Signature]</i>
DRAWING NO. WWT-1603	SCALE	DATE	10TH JAN 1990




SECTION A - A s=1/100




SECTION C - C s=1/50


SECTION D - D s=1/50




SECTION E - E s=1/50



SECTION F - F s=1/50



SECTION G - G s=1/50



SECTION B - B s=1/100

RIGID FRAME TOWER FOUNDATION (AL-R)

PAKISTAN			
KARACHI ELECTRIC SUPPLY CORPORATION			
WEST WHARF THERMAL POWER PLANT PROJECT			
UNITS NO.1 AND NO.2			
RIGID FRAME TOWER FOUNDATION (AL-R)			
JAPAN INTERNATIONAL COOPERATION AGENCY			
TOKYO JAPAN			
APPROVED BY <i>Holtz</i>	REVIEWED BY	DESIGNED BY <i>Holtz</i>	DRAWN BY <i>Holtz</i>
DRAWING NO. WLT-1604	SCALE	DATE	10TH JAN 1990

TLG-2

UNDERGROUND CABLE

TLG-2 UNDERGROUND CABLE

1. Route of Underground Cable	TLG-2-1
2. Cross Section of Tunnel	TLG-2-1
3. Cable Size	TLG-2-1
4. Ventilation in Tunnel	TLG-2-6
4.1 Calculation base	
4.2 Calorific power of cable and temperature in tunnel	
5. Oil Pressure Tank	TLG-2-9
5.1 Volume of insulation oil	
5.2 Temperature of insulation oil at shutdown of load	
5.3 Oil demand	
5.4 Resistant of oil flow	
5.5 Transient variation of oil pressure	
5.6 Required number of cells	


38

TLG-2 UNDERGROUND CABLE

1. Route of Underground Cable

The route of 220 kV underground cable, starting from the West Wharf Thermal Power Plant and ending at Tower No. 1, is as shown in Fig. 1.

Total length will be approximately 1.1 km.




2. Cross Section of Tunnel

The cross section of tunnel for underground cable is shown in

Fig. 2.

Fig. 2



3. Cable Size

According to calculations made for the overhead conductor, the required current carrying capacity is 1,200 A and 720 A for 220 kV

and 132 kV lines, respectively.

The cable size will be 1,200 mm² and 500 mm² for 220 kV and 132 kV, respectively.

The specifications of the cable shall be as follows.

220 kV 1,200 mm² OFAZV

Six sector hollow copper cable

Rdc at 20°C	0.0151 Ω/km
Thermal resistance ratio of insulation	4.5°C m/W
Max. allowable temperature of insulation	85°C
Relative permittivity of insulation	ε = 3.45
Loss factor of insulation	tan δ = 0.0023
Inside diameter of conductor	12.0 mm
Outside diameter of conductor	43.6 mm
Outside diameter of binder	44.1 mm
Outside diameter of conductor cover	44.7 mm
Insulation thickness	15.2 mm
Outside diameter of core	76.8 mm
Height of aluminium wave of sheath	4.8 mm
Thickness of aluminium sheath	2.1 mm
Outside diameter of sheath	91.1 mm
Outside diameter of jacket	101.1 mm
Material of jacket	PVC

132 kV 500 mm² OFAZV

Self support copper cable

Rdc at 20°C	0.0366 Ω/km
-------------	-------------

Thermal resistance ratio of insulation	4.5°C m/W
Max. allowable temperature of insulation	85°C
Relative permittivity of insulation	$\epsilon = 3.45$
Loss factor of insulation	$\tan \delta = 0.0023$
Inside diameter of conductor	12.0 mm
Outside diameter of conductor	27.9 mm
Outside diameter of conductor cover	28.5 mm
Insulation thickness	9.1 mm
Outside diameter of core	48.4 mm
Height of aluminium wave of sheath	3.8 mm
Thickness of aluminium sheath	1.6 mm
Outside diameter of sheath	59.7 mm
Outside diameter of jacket	68.7 mm
Material of jacket	PVC

Note: The allowable current has been calculated in accordance with IEC 287 and the results are shown in Table 1 and Table 2.

Table 1. ALLOWABLE CURRENT OF 220KV CABLE

DESCRIPTION	VALUE
(1) Installation Conditions 220 kV 1 x 1,200 mm ² OFAZV	
(a) Max. conductor temperature	85 °C
(b) Ambient temperature	50 °C.
(c) Relative permittivity of insulation material (ϵ)	3.45
(d) Dielectric loss factor of insulation material ($\tan \delta$)	0.0023
(2) D.C. resistance of conductor at 20 °C	0.0151 x 10 ⁻³ Ω/m
(3) A.C. resistance of conductor at 85 °C (R)	0.0197 x 10 ⁻³ Ω/m
(4) Ratio of losses in metallic sheath to total losses in conductors of cable (λ_1)	0.1768
(5) Ratio of losses in armour to total losses in conductors of cable (λ_2)	-----
(6) Thermal resistance of :	
(a) Insulation (T1)	0.445 K.m/W
(b) Separation sheath (T2)	----- K.m/W
(c) Outer sheath (T3)	0.151 K.m/W
(d) Surrounding of cable in air (T4)	0.341 K.m/W
(7) Permissible conductor temperature rise above ambient ($\Delta \theta$)	35 °C
(8) Max. dielectric losses (Wd)	4.65 W/m
(9) Max capacitance (C)	399 pF/m
(10) Continuous current carrying capacity per conductor (I)	1255 Amps.

Table 2. ALLOWABLE CURRENT OF 132KV CABLE

DESCRIPTION	VALUE
(1) Installation Conditions 132 kV 1 x 500 mm ² OFAZV	
(a) Max. conductor temperature	85 °C
(b) Ambient temperature	50 °C
(c) Relative permittivity of insulation material (ϵ)	3.45
(d) Dielectric loss factor of insulation material ($\tan \delta$)	0.0023
(2) D.C. resistance of conductor at 20 °C	0.0366 x 10 ⁻³ Ω/m
(3) A.C. resistance of conductor at 85 °C (R)	0.0469 x 10 ⁻³ Ω/m
(4) Ratio of losses in metallic sheath to total losses in conductors of cable ($\lambda 1$)	0.0315
(5) Ratio of losses in armour to total losses in conductors of cable ($\lambda 2$)	-----
(6) Thermal resistance of :	
(a) Insulation (T1)	0.455 K.m/W
(b) Separation sheath (T2)	----- K.m/W
(c) Outer sheath (T3)	0.197 K.m/W
(d) Surrounding of cable in air (T4)	0.471 K.m/W
(7) Permissible conductor temperature rise above ambient ($\Delta \theta$)	35 °C
(8) Max. dielectric losses (Wd)	1.76 W/m
(9) Max capacitance (C)	419 pF/m
(10) Continuous current carrying capacity per conductor (I)	790 Amps.

4. Ventilation in Tunnel

4.1 Calculation base

Maximum power to be transferred through 220 kV and 132 kV cables is considered to be 480 MW, which is 20% more than the generating capacity of West Wharf Thermal Power Plant.

Calculation shall be carried out on the bases of 2 cct of 1,200 mm² of 220 kV cables and 7 cct of 500 mm² of 132 kV cables.

4.2 Calorific power of cable and the temperature in tunnel

Temperature in tunnel ΔT :

$$\Delta T = \sum_{i=1}^n W_i \cdot R_T + T_o \quad (^\circ\text{C})$$

W_i : Calorific power of cable (W/cm)

R_T : Heat resistance of tunnel ($^\circ\text{C}\cdot\text{cm}/\text{W}$)

T_o : Base temperature (30°C)

$$W_i = I_i^2 r_{aci} (1 + P_i) \cdot L_{fi} + W_{di}$$

I_i : Current (A)

r_{aci} : AC resistance of conductor (Ω/cm)

P_i : Ratio of eddy-current loss in metallic sheath

L_{fi} : Ratio of loss

W_{di} : Dielectric loss (W/cm)

$$R_T = \frac{g \cdot \eta}{2\pi} \log_e \left\{ \frac{2L}{D} + \sqrt{\left(\frac{2L}{D}\right)^2 - 1} \right\} = 13.85 \text{ } ^\circ\text{C}\cdot\text{cm}/\text{W}$$

g : Specific heat resistance of soil ($200^\circ\text{C}\cdot\text{cm}/\text{W}$)

η : Decreasing ratio of heat resistance by underground Water (0.3)

L : Depth up to center of tunnel (270 cm)

D : Equivalent diameter of tunnel

$$D = \sqrt{\text{Height} \times \text{Width}} = 240 \text{ cm}$$

(a) Normal condition

Assuming the current flow as 320 A and 200 A for 220 kV and 132 kV cables respectively, the following equations are used.

$$P = (220 \times 0.35 \times 2 + 132 \times 0.2 \times 7) \times \sqrt{3} \times 0.85 = 479 \text{ (MW)}$$

$$W_1 = 350^2 \times 0.0190 \times 10^{-5} (1+0.177) \times 1.0 + 4.65 \times 10^{-2} \\ = 0.0739 \text{ (W/cm)}$$

$$W_2 = 200^2 \times 0.0451 \times 10^{-5} (1+0.0315) \times 1.0 + 1.76 \times 10^{-2} \\ = 0.0362 \text{ (W/cm)}$$

$$\sum_{i=1}^9 W_i = (W_1 \times 2 + W_2 \times 7) \times 3 = 1.204 \text{ (W/cm)}$$

(b) All power in 1cct of 220 kV and 4 cct of 132 kV

Assuming the current flow as 600 A and 370 A for 220 kV and 132 kV cables respectively, the following equations are used.

$$P = (200 \times 0.6 + 132 \times 0.37 \times 4) \times \sqrt{3} \times 0.85 = 482 \text{ (MW)}$$

$$W_1 = 600^2 \times 0.0190 \times 10^{-5} (1+0.177) \times 1.0 + 4.65 \times 10^{-2} \\ = 0.127 \text{ (W/cm)}$$

$$W_2 = 370^2 \times 0.0451 \times 10^{-5} (1+0.0315) \times 1.0 + 1.76 \times 10^{-2} \\ = 0.0813 \text{ (W/cm)}$$

$$\sum_{i=1}^9 W_i = (W_1 + W_2 \times 4) \times 3 = 1.357 \text{ (W/cm)}$$

The temperature in tunnel will be

$$\Delta T = 1.357 \times 13.85 + 30 = 48.8 < 50 \text{ (}^\circ\text{C)}$$

TLG-2-7

Therefore, no cooling system will be required. However, it is advantageous to install one exhaust chimney so that the natural flow of air will prevent any toxic inhalation by maintenance personnel.

5. Oil Pressure Tank

5.1 Volume of insulation oil

Since the level differences are very small through the route, the PT-PT system is preferable. Standard and variation volumes of insulation oil by fluctuation of temperature of each portion are as follows.

		Standard volume of oil	Fluctuation of temperature	Q'ty	Variation of volume of oil
Cable	Conductor and 1/2 insulator	1,100 ℓ /km	60 (85-25)	1.1 km	58.1 ℓ
	Others	1,600 ℓ /km	50 (75-25)	1.1 km	70.4 ℓ
IJB		60 ℓ /each	60 (85-25)	2	5.8 ℓ
CH in air		180 ℓ /km	35 (60-25)	2	10.0 ℓ
P.T		12 ℓ /cell	20 (45-25)	N cell	0.192 N ℓ

Therefore, total variation of oil volume becomes:

$$144.3 + 0.192 N \ell.$$

5.2 Temperature of insulation oil at shutdown of load

Temperature of conductor

$$T_c = \frac{I^2 \cdot R_{20} \cdot R_{th} \cdot n (1 - 20\alpha) + T_e + T_d}{1 - I^2 \cdot R_{20} \cdot R_{th} \cdot n}$$

$$= \frac{1,200^2 \times 0.0157 \times 10^{-5} \times 70.4 \times 1 \times (1 - 20 \times 0.00393) + 25 + 2.1}{1 - 1,200^2 \times 0.0157 \times 10^{-5} \times 70.4 \times 1 \times 0.00393}$$

$$= 44.6 (^\circ\text{C})$$

47

Temperature of sheath

$$\begin{aligned} T_s &= I^2 \cdot R_{20} \{1 + \alpha(T_c - 20)\} (R_{th} - T_1) \cdot n + T_e + T_{d'} \\ &= 1,200^2 \times 0.0157 \times 10^{-5} \{1 + 0.00393 (44.6 - 20)\} (70.4 - 44.5) \\ &\quad + 25 + 2.1 = 33.5 \text{ (}^\circ\text{C)} \end{aligned}$$

Temperature of insulation oil

$$T_{oil} = (T_c + T_s)/2 = (44.6 + 33.5)/2 = 39.1 \text{ (}^\circ\text{C)}$$

Where;

I : Current (A)

R_{20} : AC resistance of conductor at 20^oC (Ω/cm)

R_{th} : Total thermal resistance ($^\circ\text{C}\cdot\text{cm}/\text{W}$)

n : Number of conductor

α : Constant mass temperature coefficient at 20^oC per Kelvin

T_e : Minimum earth temperature ($^\circ\text{C}$)

$T_{d'}$: Temperature rise by dielectric losses ($^\circ\text{C}$)

T_1 : Thermal resistance of insulation ($^\circ\text{C}\cdot\text{cm}/\text{W}$)

5.3 Oil demand

$$\begin{aligned} a &= a_o \cdot W = a_o \cdot n (I^2 R + W_d) \\ &= 24 \times 1 \times [1,200^2 \times 0.0157 \times 10^{-5} \times \{1 + 0.00393 (39.1 - 20)\} + 0.0465] \\ &= 6.96 \times 10^{-5} \text{ (cm}^3/\text{cm}\cdot\text{sec)} \end{aligned}$$

where;

a_o : Oil demand per unit loss ($\text{cm}^3/\text{cm}\cdot\text{sec}\cdot\text{W}$)

W : Load loss at shut down (W/cm)

R : AC resistance at temperature of oil (Ω/cm)

W_d : Dielectric losses (W/cm)

5.4 Resistance of oil flow

$$b = 0.815 \times \frac{\eta}{n \cdot \pi \cdot r^4} \times 10^{-4}$$
$$= 0.815 \times \frac{7.4}{1 \times \pi \times 0.6^4} \times 10^{-4} = 14.81 \times 10^{-4} \text{ (g.sec/cm}^3\text{)}$$

where;

η : Viscosity of insulation oil (Cp)

r : Radius of oil hollow (cm)

n : Number of oil hollow

5.5 Transient variation of oil pressure

See Fig. 4

$$\Delta P = \frac{1}{2} abL^2$$
$$= \frac{1}{2} \times 6.96 \times 10^{-5} \times 14.81 \times 10^{-4} \times \left(\frac{1.1 \times 10^5}{2}\right)^2 \times 10^{-3} = 0.16 \text{ (kg/cm}^2\text{)}$$

$$P_{\min B} = P_s + h_1 \rho + \Delta P$$
$$= 0.2 + (4 - 1) \times 0.087 + 0.16 = 0.62 \text{ (kg/cm}^2\text{.G)}$$
$$= 1.65 \text{ (kg/cm}^2\text{.abs)}$$

$$P_{\min A} = P_{\min B} + h_2 \rho$$
$$= 0.68 + (4 - 1.5) \times 0.087 = 0.9 \text{ (kg/cm}^2\text{.G)}$$
$$= 1.93 \text{ (kg/cm}^2\text{.abs)}$$

$$P_{\max A} = P_M - h_3 \rho$$
$$= 4.5 - (4 - 1.5) \times 0.087 = 4.28 \text{ (kg/cm}^2\text{.G)}$$
$$= 5.31 \text{ (kg/cm}^2\text{.abs)}$$

$$P_{\max B} = P_{\max A} - h_4 \rho$$
$$= 4.28 - (1.5 + 1) \times 0.087 = 4.06 \text{ (kg/cm}^2\text{.G)}$$
$$= 5.09 \text{ (kg/cm}^2\text{.abs)}$$

where;

ΔP : Transient alteration of oil pressure (kg/cm^2)

P_{minA} : Minimum oil pressure of oil tank A

P_{minB} : Minimum oil pressure of oil tank B

P_{maxA} : Maximum oil pressure of oil tank A

P_{maxB} : Maximum oil pressure of oil tank B

L : Length of the cable route for one oil tank (cm)

P_S : Surplus of minimum oil pressure ($\text{kg}/\text{cm}^2 \cdot G$)

P_M : Maximum allowable pressure of oil pressure tank ($\text{kg}/\text{cm}^2 \cdot G$)

ρ : Specific gravity of oil

h_1, h_2, h_3, h_4 : Level difference (m)




Fig. 4

5.6 Required number of cells

Absorption capacity of transient variation of oil pressure per cell is as follows.

$$P_a = C_g \left(\frac{K_{25}}{P_{\text{min}}} - \frac{K_{45}}{P_{\text{max}}} \right) - \Delta C$$

C_g : Gas constant of pre pressure ratio 1.5

K_{25} : Absolute temperature of 25°C

K_{45} : Absolute temperature of 45°C

ΔC : Variation of oil volume per cell

$$P_{aA} = 0.0646 \left(\frac{298}{1.93} - \frac{318}{5.31} \right) - 0.192 = 5.91 \text{ (/cell)}$$

$$P_{aB} = 0.0646 \left(\frac{298}{1.65} - \frac{318}{5.09} \right) - 0.192 = 7.44 \text{ (/cell)}$$

$$N > \frac{167.6 + 100}{5.91 + 7.44} = 20$$

$$N = 25$$

Dimensions of tank are shown in Fig. 5.




Fig. 5 Pressure Tank (Buried Type)
(Prepressure ratio 1.0 - 1.5)

51

TLG-3

CABLE TUNNEL

TLG-3 CABLE TUNNEL

1. Tunnel Structure

1-1 Design conditions

Tunnel dimensions (inside)	(B) x (H) = 2.4 m x 2.4 m (refer to Fig. 1)
Haunch	150 mm x 150 mm
Depth (ground surface to top of structure)	1.5 (typical) m
Allowable unit stress	
Reinforcing steel bars	According to the Standards of
Reinforcing concrete	Japanese Society of Civil Engineers Japanese Society of Civil Engineers
Dead weight (traffic) max.	20 ton (trailer-vehicle)
Note: Pavement weight should be included in the calculation.	
Water level	Assuming as up to the surface for safety side
Soil properties	Soil properties shall be referred to the result of geological investigation in this project


1-2 Load

(1) Traffic load 2.75 ton/m^2 (refer to Table 1)

Table 1

Depth (m)	1.0	1.5	2.0	2.5	3.0	3.5	4.5	9.0	10.0
Traffic load (ton/m ²)	4.50	2.75	2.05	1.50	1.20	1.15	1.10	1.05	0.95

Fig. 1




Note:

The loads indicated in the Table 1 are derived with the following assumptions.

- (a) Traffic load is derived by applying a trailer load of 20 ton.
- (b) Vehicle load is calculated by Kögler method with the


following load distribution inside soil (Fig. 2)

Fig. 2



(2) Weight of pavement

Weight of pavement is calculated as indicated in Fig. 3.



(3) Soil and water pressure


Unit weight of soil

- Back filled soil = 2.0 ton/m³
- Soil (sand, silt) = 2.0 ton/m³, $K_o = 0.5$
- = 1.1 ton/m³

(4) Imposed loads used for the structural calculation are derived as follows.

55

Fig. 4



(a) Vertical soil pressure

$$q_{ve} = 2.75 + 2.3 \times 0.35 + 2.1 \times 0.4 + 2.0 \times 0.75$$

$$= 5.895 \text{ ton/m}^2$$

(b) Horizontal soil pressure

$$q_{He1} = 0.5 \times (2.75 + 2.3 \times 0.35 + 2.1 \times 0.4 + 1.1$$

$$\times 0.875) = 2.679 \text{ ton/m}^2$$

$$q_{He2} = 2.679 + 0.5 \times (1.1 \times 2.65)$$

$$= 4.137 \text{ ton/m}^2$$

(c) Horizontal water pressure

$$q_{HW1} = 1.0 \times 1.625 = 1.625 \text{ ton/m}^2$$

$$q_{HW2} = 1.0 \times 4.275 = 4.275 \text{ ton/m}^2$$

(d) Dead weight

Ceiling plate

$$q_g = 2.5 \times 0.25 = 0.625 \text{ ton/m}^2$$

Side wall

$$P = 2.5 \times 0.25 \times 2.65 = 1.656 \text{ ton/m}^2$$

(e) Reaction force to bottom plate

$$q_{vz} = q_{ve} + q_g + 2 \times P/2.65 = 7.770 \text{ ton/m}^2$$

(f) Imposed load (summary)

$$q_{v1} = q_{ve} + q_g = 6.520 \text{ ton/m}^2$$

$$q_2 = 7.770 \text{ ton/m}^2$$

$$q_{H1} = q_{He1} + q_{HW1} = 4.304 \text{ ton/m}^2$$

$$q_{H2} = q_{He2} + q_{HW2} = 8.412 \text{ ton/m}^2$$

$$P = 1.625 \text{ ton/m}^2$$

1-3 Section force (calculation result)

(1) Side wall

	M (TON-M)	Q (TON)	N (TON)		
0-	3.6200	-7.2674	-10.2950	1	Support (face)
1-	2.7457	-6.7172	-10.2950	2	Haunch
2-	2.5792	-6.6043	-10.2950		(starting point)
3-	1.7896	-6.0251	-10.2950		
4-	-0.1749	-4.0758	-10.2950		
5-	-1.6301	-0.2038	-10.2950	3	Center
6-	-0.2947	4.3486	-10.2950		
7-	1.9599	7.3267	-10.2950		
8-	2.9386	8.3370	-10.2950		
9-	3.1496	8.5420	-10.2950	4	Haunch (starting point)
10-	4.2820	9.5813	-10.2950	5	Support

(2) Bottom plate


10-	4.2820	-10.2953	-9.5813	1	Support (face)
11-	3.0558	-9.3240	-9.5813	2	Haunch
12-	2.8252	-9.1297	-9.5813		(starting point)
13-	1.7446	-8.1585	-9.5813		
14-	-0.8334	-5.1476	-9.5813		
15-	-2.5386	0.0000	-9.5813	3	Center
16-	-0.8334	5.1476	-9.5813		
17-	1.7446	8.1585	-9.5813		
18-	2.8252	9.1297	-9.5813		
19-	3.0558	9.3240	-9.5813		
20-	4.2820	10.2952	-9.5813		

(3) Ceiling plate


30-	3.6200	-8.6390	-7.2674	1	Support (face)
31-	2.5911	-7.8240	-7.2674	2	Haunch
32-	2.3975	-7.6610	-7.2674		(starting point)
33-	1.4908	-6.8460	-7.2674		
34-	-0.6725	-4.3195	-7.2674		
35-	-2.1033	0.0000	-7.2674	3	Center
36-	-0.6725	4.3195	-7.2674		
37-	1.4908	6.8460	-7.2674		
38-	2.3975	7.6610	-7.2674		
39-	2.5911	7.8240	-7.2674		
0-	3.6200	8.6390	-7.2674		

M: Bending moment
 Q: Shearing force
 N: Axial force


Fig. 5




INPUT FIGURE



BENDING MOMENT



SHEARING FORCE



AXIAL FORCE

1-4 Stress (calculation result)

(1) Side wall

Section No.		Upper 1-(1) support (face)	Upper 1-(2) haunch starting point)
M	(t.m)	3.62	2.75
N	(t)	10.30	10.30
S	(t)	6.72	6.60
b	(cm)	100.0	100.0
h	(cm)	30.0	25.0
d	(cm)	25.0	20.0
d'	(cm)	10.0	5.0
As	(cm ²)	6.620	6.620
As'	(cm ²)	4.223	4.223
n =	Es/Ec	15.00	15.00
P=As/(b*d)	(%)	0.265	0.331
u=d-h/2	(cm)	10.000	7.500
f=M/N+u	(cm)	45.163	34.170
f/d		1.807	1.709
d'/d		0.400	0.250
As'/As		0.638	0.638
M'=M+N*u	(t.m)	4.650	3.518
x	(cm)	8.268	7.073
C		0.000	6.137
S		0.000	11.216
Z		0.000	1.082
c	(kg/cm ²)	51.7	54.0
s	(kg/cm ²)	1568.6	1479.6
s'	(kg/cm ²)	162.3	237.3
	(kg/cm ²)	0.00	3.57
m	(kg/cm ²)	2.69	3.30
ca	(kg/cm ²)	90.0	90.0
sa	(kg/cm ²)	1800.0	1800.0
a	(kg/cm ²)	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tenior
m: mean shear stress

Reinforcement
Outside D16 @ 300 = 6.62 cm²
Insiee D13 @ 300 = 4.223 cm²

Section No.	1-(3) Center	1-(4) Bottom haunch (starting point)	1-(5) Bottom support (face)
M (t.m)	1.70	3.15	4.28
N (t)	10.30	10.30	10.30
S (t)	0.00	8.34	8.54
b (cm)	100.0	100.0	100.0
h (cm)	25.0	25.0	30.0
d (cm)	20.0	20.0	25.0
d' (cm)	5.0	5.0	10.0
As (cm ²)	4.223	10.843	10.843
As' (cm ²)	6.620	4.223	4.223
n = Es/Ec	15.00	15.00	15.00
P=As/(b*d) (%)	0.211	0.542	0.434
u=d-h/2 (cm)	7.500	7.500	10.000
f=M/N+u (cm)	24.013	38.094	51.593
f/d	1.201	1.905	2.064
d'/d	0.250	0.250	0.400
As'/As	1.568	0.389	0.389
M'=M+N*u (t.m)	2.472	3.922	5.312
x (cm)	7.310	8.138	9.424
C	5.805	5.405	0.000
S	10.077	7.878	0.000
Z	1.012	1.114	0.000
c (kg/cm ²)	35.9	53.0	51.9
s (kg/cm ²)	934.2	1158.5	1285.7
s' (kg/cm ²)	170.1	306.5	47.5
m (kg/cm ²)	0.00	4.64	0.00
m (kg/cm ²)	0.00	4.17	3.42
ca (kg/cm ²)	90.0	90.0	90.0
sa (kg/cm ²)	1800.0	1800.0	1800.0
a (kg/cm ²)	4.50	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean shear stress

Reinforcement

Outside D16, D13 alternately @ 150 = 10.843 cm²
Inside D13 @ 300 = 4.223 cm²

(2) Bottom plate

Section No.	2-(1) Support (face)	Haunch 2-(2) (starting point)	2-(3) Center
M (t.m)	4.28	3.06	2.54
N (t)	9.58	9.58	9.58
S (t)	9.32	9.13	0.00
b (cm)	100.0	100.0	100.0
h (cm)	30.0	25.0	25.0
d (cm)	25.0	20.0	20.0
d' (cm)	10.0	5.0	5.0
As (cm ²)	10.843	10.843	6.620
As' (cm ²)	6.620	6.620	10.843
n = Es/Ec	15.00	15.00	15.00
P=As/(b*d) (%)	0.434	0.542	0.331
u=d-h/2 (cm)	10.000	7.500	7.500
f=M/N+u (cm)	54.691	39.393	33.995
f/d	2.188	1.970	1.700
d'/d	0.400	0.250	0.250
As'/As	0.611	0.611	1.638
M'=M+N*u (t.m)	5.240	3.774	3.257
x (cm)	9.314	7.965	6.876
C	0.000	5.361	5.923
S	0.000	8.101	11.304
Z	0.000	1.119	1.089
c (kg/cm ²)	52.0	50.6	48.2
s (kg/cm ²)	1312.5	1146.6	1380.7
s' (kg/cm ²)	57.4	282.4	197.4
(kg/cm ²)	0.00	5.11	0.00
m (kg/cm ²)	3.73	4.56	0.00
ca (kg/cm ²)	90.0	90.0	90.0
sa (kg/cm ²)	1800.0	1800.0	1800.0
a (kg/cm ²)	4.50	4.50	4.50

Reinforcement

Outside D16, D13 alternately @ 150 = 10,843 cm²

Inside D16 @ 300 = 6.62 cm²

Reinforcement with stirrup is applied because of an excess shear stress at original point of the haunch.

(3) Ceiling plate

Section No.	3-(1) Support (face)	Haunch 3-(2) (starting point)	3-(3) Center point
M (t.m)	3.62	2.59	2.10
N (t)	7.27	7.27	7.27
S (t)	7.82	7.66	0.00
b (cm)	100.0	100.0	100.0
h (cm)	30.0	25.0	25.0
d (cm)	25.0	20.0	20.0
d' (cm)	10.0	5.0	5.0
As (cm ²)	6.620	6.620	4.223
As' (cm ²)	4.223	4.223	6.620
n = Es/Ec	15.00	15.00	15.00
P=As/(b*d) (%)	0.265	0.331	0.211
u=d-h/2 (cm)	10.000	7.500	7.500
f=M/N+u (cm)	59.812	43.154	36.442
f/d	2.392	2.158	1.822
d'/d	0.400	0.250	0.250
As'/As	0.638	0.638	1.568
M'=M+N*u (t.m)	4.347	3.136	2.648
x (cm)	7.660	6.572	5.811
C	0.000	6.579	7.332
S	0.000	13.442	17.903
Z	0.000	1.092	1.061
c (kg/cm ²)	52.3	51.6	48.5
s (kg/cm ²)	1776.7	1580.9	1778.0
s' (kg/cm ²)	239.7	185.1	101.6
(kg/cm ²)	0.00	4.18	0.00
m (kg/cm ²)	3.13	3.83	0.00
ca (kg/cm ²)	90.0	90.0	90.0
sa (kg/cm ²)	1800.0	1800.0	1800.0
a (kg/cm ²)	4.50	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean shear stress

Reinforcement

Outside D16 @ 300 = 6.62 cm²

Inside D13 @ 300 = 4.223 cm²

1-5 Stirrup

Required cross sectional area req. Av

$$S_c = 1/2 \times 4.5 \times 100 \times 0.875 \times 20 \times 10^{-3} = 3.938 \text{ t}$$

$$S_v = 9.13 - 3.938 = 5.192 \text{ t}$$


$$\text{req Av} = \frac{S_v \cdot s}{s_a \cdot j \cdot d} = \frac{5.192 \times 10^3 \times 15}{1800 \times 0.875 \times 20}$$

$$= 2.472 \text{ cm}^2 < \text{D13 @ 300} = 4.223 \text{ cm}^2$$

Therefore, stirrups (D13) are placed with 15 cm space in a section and 300 cm axial pitch.

1-6 Summary

The wall thicknesses and reinforcement bars decided by the above calculation are shown in Fig. 6.



The wall thickness is decided as 250 mm with above reinforcement according to the calculation.

58


2. MANHOLE

2-1 Location of Manhole

Manholes should be positioned according to the available cable length and other locational conditions, such as public traffic, location of existing structures, facilities, etc.

At present, max. 1,300 m long cables are available, so, no manhole is needed along the underground cable.

However, in case that any manhole is needed in the West Wharf Project, the location will be planned as in Fig. 7.



2-2 Dimensions of the Manhole

The dimensions of the manhole is as shown in Fig. 8 and Fig. 9 below.

The dimensions are decided considering of the size of cable joints and the allowable curvatures of the cables.

Fig. 8





Fig. 9 Location of Cables inside Tunnel


Cable voltages: 275 kV, 154 kV



28

Fig. 10 Cable Offset inside Manhole

Note: Cable arrangement inside manhole.



$$Z_{max} = 0.625^2 + 1.815^2 = 1.9196$$

(154 kV)

TLG-3-17


Fig. 11 $\lambda_0 = \sqrt{Z_{max} \cdot (4R - Z_{max})} = \sqrt{1.9196 \cdot (4 \times 1.50 - 1.9196)} = 2.80 \text{ m}$

Manhole length $L = 2(\lambda_0 + \alpha_1) + (2\lambda_1 + 0.70) + \alpha_2$
 $= 2(2.80 + 0.40) + (2 \times 2.10 + 0.70) + \alpha_2$
 $= 11.30 \text{ m}$ * $\alpha_2 = \text{adjusted value} = 0$

R: Design radius of curvature
 154 kV 1.50 m
 275 kV 1.80 m

α'_1 = straight line length α''_1 = joint bonding length


Plan Location



2-3 Manhole Structure

2-3-1 Design condition

Same as the cable tunnel (Fig. 12)



1 - 1' Section





Fig. 13


2-2' Section (Structural section)



2-3-2 Load

Imposed loads are calculated same as that of the tunnel.

Fig. 14



(a) Vertical pressure

$$q_{ve} = 2.75 + 2.3 \times 0.35 + 2.1 \times 0.4 + 2.0 \times 0.75$$

$$= 5.895 \text{ t/m}^2$$

(b) Horizontal pressure

$$q_{He1} = 0.5 \times (2.75 + 2.3 \times 0.35 + 2.1 \times 0.4 + 1.1 \times 0.9)$$

$$= 2.693 \text{ t/m}^2$$

$$q_{He2} = 2.693 + 0.5 \times (1.1 \times 6.2) = 6.103 \text{ t/m}^2$$

(c) Horizontal water pressure

$$q_{Hw1} = 1.0 \times 1.65 = 1.65 \text{ t/m}^2$$

$$q_{Hw2} = 1.0 \times 7.85 = 7.85 \text{ t/m}^2$$

(d) Dead weight

Ceiling plate $q_{g1} = 2.5 \times 0.3 = 0.75 \text{ t/m}^2$

Middle floor $q_{g2} = 2.5 \times 0.25 = 0.625 \text{ t/m}^2$

Side wall (upper) $P_1 = 2.5 \times 0.3 \times 2.775 = 2.081 \text{ t}$

Side wall (lower) $P_2 = 2.5 \times 0.3 \times 3.425 = 2.569 \text{ t}$

(e) Reaction force to the bottom plate

$$q_{v3} = q_{ve} + q_{g1} + q_{g2} + 2 \times (P_1 + P_2)/3.6 = 9.853 \text{ t/m}^2$$

(f) Imposed load (summary)

$$q_{v1} = q_{ve} + q_{g1} = 6.645 \text{ t/m}^2$$

$$q_{v2} = q_{g2} = 0.625 \text{ t/m}^2$$

$$q_{v3} = 9.853 \text{ t/m}^2$$

$$q_{H1} = q_{He1} + q_{HW1} = 4.343 \text{ t/m}^2$$

$$q_{H2} = q_{He2} + q_{HW2} = 13.953 \text{ t/m}^2$$

$$P_1 = 2.081 \text{ t}$$

$$P_2 = 2.569 \text{ t}$$

2-3-3 Section force (calculation result)

(1) Side wall (upper)

	M (TON-M)	Q (TON)	N (TON)	
1-	5.7654	-7.7697	-14.0420	(1) Support (face)
2-	4.6497	-7.1008	-14.0420	(2) Haunch
3-	3.6369	-6.3971	-14.0420	(starting point)
4-	1.5065	-4.3838	-14.0420	
5-	-0.0978	-0.8141	-14.0420	
6-	-0.1446	-0.2518	-14.0420	(3) Center
7-	-0.1416	0.3223	-14.0420	
8-	1.3297	4.6261	-14.0420	
9-	3.9494	7.9315	-14.0420	
10-	5.0056	8.9709	-14.0420	
11-	5.2325	9.1817	-14.0420	(4) Haunch(starting point)
12-	6.4467	10.2501	-14.0420	(5) Support (face)

(2) Side wall (lower)

12-	8.0349	-16.8229	-17.7360	(1) Support (face)
13-	6.0001	-15.7302	-17.7360	(2) Haunch
14-	5.6096	-15.5088	-17.7360	(starting point)
15-	3.7408	-14.3871	-17.7360	
16-	-3.0387	-8.8530	-17.7360	
17-	-6.7806	-0.7295	-17.7360	
18-	-6.8016	0.2532	-17.7360	(3) Center
19-	-6.7360	1.2478	-17.7360	
20-	-2.2807	10.4959	-17.7360	
21-	5.5554	17.7588	-17.7360	
22-	8.3718	19.7994	-17.7360	(4) Haunch (face)
23-	11.4970	21.8749	-17.7360	(5) Support (starting point)

M: Bending moment

Q: Shear force

N: Axial force

(3) Bottom Plate

	M (TON-M)	Q (TON)	N (TON)		
23-	11.4970	-17.7354	-21.8749	(1)	Support (face)
24-	8.9475	-16.2574	-21.8749	(2)	Haunch
25-	6.6197	-14.7795	-21.8749		(starting point)
26-	-0.4744	-8.8677	-21.8749		
27-	-4.4649	0.0000	-21.8749	(3)	Center
28-	-0.4744	8.8677	-21.8749		
29-	6.6197	14.7795	-21.8749		
30-	8.9475	16.2575	-21.8749		
31-	11.4970	17.7354	-21.8749		

(4) Ceiling plate


53-	5.7654	-11.9610	-7.7697	(1)	Support (face)
54-	4.0460	-10.9642	-7.7697	(2)	Haunch
55-	2.4761	-9.9675	-7.7697		(starting point)
56-	-2.3083	-5.9805	-7.7697		
57-	-4.9995	0.0000	-7.7697	(3)	Center
58-	-2.3083	5.9805	-7.7697		
59-	2.4761	9.9675	-7.7697		
60-	4.0460	10.9643	-7.7697		
1-	5.7654	11.9610	-7.7697		

(5) Middle floor

12-	-1.5882	1.1250	-27.0730	(1)	Support (face)
61-	-1.4264	1.0313	-27.0730	(2)	Haunch
62-	-1.2788	0.9375	-27.0730		(starting point)
63-	-0.8288	0.5625	-27.0730		
64-	-0.5757	0.0000	-27.0730		
65-	-0.8288	-0.5625	-27.0730		
66-	-1.2788	-0.9375	-27.0730		
67-	-1.4264	-1.0312	-27.0730		
42-	-1.5882	-1.1250	-27.0730		

M: Bending moment
Q: Shear force
N: Axial force


Fig. 15



BENDING MOMENT

INPUT FIGURE

Fig. 16



AXIAL FORCE

SHEARING FORCE

2-3-4 Stress calculation result

(1) Side wall (upper)

Section No.		Upper 1-(1) support (face)	Upper 1-(2) haunch (starting point)	1-(3) Center
M	(t.m)	5.77	4.65	0.15
N	(t)	14.04	14.04	14.04
S	(t)	7.10	6.40	0.00
b	(cm)	100.0	100.0	100.0
h	(cm)	35.0	30.0	30.0
d	(cm)	30.0	25.0	25.0
d'	(cm)	10.0	5.0	5.0
As	(cm ²)	10.843	10.843	4.223
As'	(cm ²)	4.223	4.223	10.843
n = Es/Ec		15.00	15.00	15.00
P=As/(b*d)	(%)	0.361	0.434	0.169
u=d-h/2	(cm)	12.500	10.000	10.000
f=M/N+u	(cm)	53.558	43.113	11.068
f/d		1.785	1.725	0.443
d'/d		0.333	0.200	0.200
As'/As		0.389	0.389	0.568
M'=M+N*u	(t.m)	7.521	6.054	1.554
x	(cm)	10.969	9.699	0.000
C		6.181	5.595	0.000
S		10.725	8.827	0.000
Z		1.079	1.095	0.000
c	(kg/cm ²)	51.7	54.2	5.0
s	(kg/cm ²)	1344.3	1282.4	-58.6
s'	(kg/cm ²)	68.4	393.9	71.6
	(kg/cm ²)	2.55	2.80	0.00
m	(kg/cm ²)	2.37	2.56	0.00
ca	(kg/cm ²)	90.0	90.0	90.0
sa	(kg/cm ²)	1800.0	1800.0	1800.0
a	(kg/cm ²)	4.50	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean shear stress

Reinforcement

Outside D13, D16 alternately @ 150 = 10,843 cm²
Inside D13 @ 300 = 4.223 cm²

Section No.		Lower 1-(4) haunch (starting point)	Lower 1-(5) support (face)
M	(t.m)	5.23	6.45
N	(t)	14.04	14.04
S	(t)	8.97	9.18
b	(cm)	100.0	100.0
h	(cm)	30.0	35.0
d	(cm)	25.0	30.0
d'	(cm)	5.0	10.0
As	(cm ²)	10.843	10.843
As'	(cm ²)	4.223	4.223
n =	Es/Ec	15.00	15.00
P=As/(b*d)	(%)	0.434	0.361
u=d-h/2	(cm)	10.000	12.500
f=M/N+u	(cm)	47.263	58.410
f/d		1.891	1.947
d'/d		0.200	0.333
As'/As		0.389	0.389
M'=M+N*u	(t.m)	6.637	8.202
x	(cm)	9.403	10.671
C		5.748	6.343
S		9.533	11.490
Z		1.100	1.083
c	(kg/cm ²)	61.0	57.8
s	(kg/cm ²)	1518.5	1570.7
s'	(kg/cm ²)	428.7	54.5
	(kg/cm ²)	3.95	3.32
m	(kg/cm ²)	3.59	3.06
ca	(kg/cm ²)	90.0	90.0
sa	(kg/cm ²)	1800.0	1800.0
a	(kg/cm ²)	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-1) denotes tension
m: mean shear stress

Reinforcement

Outside D13, D16 alternately @ 150 = 10,843 cm²

Inside D13 @ 300 = 4.223 cm²

(2) Side wall (lower)

Section No.		Upper 2-(1) support (face)	Upper 2-(2) haunch (starting point)	2-(3) Center
M	(t.m)	8.03	6.00	6.90
N	(t)	17.74	17.74	17.74
S	(t)	15.73	15.51	0.00
b	(cm)	100.0	100.0	100.0
h	(cm)	35.0	30.0	30.0
d	(cm)	30.0	25.0	25.0
d'	(cm)	10.0	5.0	5.0
As	(cm ²)	13.240	13.240	13.240
As'	(cm ²)	13.240	13.240	13.240
n = Es/Ec		15.00	15.00	15.00
P=As/(b*d)	(%)	0.441	0.530	0.530
u=d-h/2	(cm)	12.500	10.000	10.000
f=M/N+u	(cm)	57.803	43.830	48.904
f/d		1.927	1.753	1.956
d'/d		0.333	0.200	0.200
As'/As		1.000	1.000	1.000
M'=M+N*u	(t.m)	10.252	7.774	8.674
x	(cm)	11.359	9.895	9.560
C		5.858	4.921	5.073
S		9.614	7.512	8.193
Z		1.094	1.116	1.120
c	(kg/cm ²)	66.7	61.2	70.4
s	(kg/cm ²)	1642.7	1401.5	1705.5
s'	(kg/cm ²)	119.8	454.1	503.7
	(kg/cm ²)	5.73	6.92	0.00
m	(kg/cm ²)	5.24	6.20	0.00
ca	(kg/cm ²)	90.0	90.0	90.0
sa	(kg/cm ²)	1800.0	1800.0	1800.0
a	(kg/cm ²)	4.50	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean shear stress

Reinforcement

Outside D16 @ 150 = 13.24 cm²

Inside D16 @ 150 = 13.24 cm²

Reinforcement with stirrup is applied because the upper shear stresses exceed the allowable stress.

Section No.		Lower 1-(4) haunch (starting point)	Lower 1-(5) support (face)
M	(t.m)	8.37	11.50
N	(t)	17.74	17.74
S	(t)	17.76	19.80
b	(cm)	100.0	100.0
h	(cm)	30.0	35.0
d	(cm)	25.0	30.0
d'	(cm)	5.0	10.0
As	(cm ²)	22.453	22.453
As'	(cm ²)	13.240	13.240
n =	Es/Ec	15.00	15.00
P=As/(b*d)	(%)	0.898	0.748
u=d-h/2	(cm)	10.000	12.500
f=M/N+u	(cm)	57.202	77.323
f/d		2.288	2.577
d'/d		0.200	0.333
As'/As		0.590	0.590
M'=M+N*u	(t.m)	10.145	13.714
x	(cm)	11.123	12.738
C		4.455	5.215
S		5.559	7.068
Z		1.151	1.144
c	(kg/cm ²)	72.3	79.5
s	(kg/cm ²)	1353.6	1615.5
s'	(kg/cm ²)	597.2	256.2
	(kg/cm ²)	8.17	7.55
m	(kg/cm ²)	<u>7.10</u>	<u>6.60</u>
ca	(kg/cm ²)	90.0	90.0
sa	(kg/cm ²)	1800.0	1800.0
a	(kg/cm ²)	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean shear stress

Reinforcement
Outside D19, D22 alternately @ 150 = 22.453 cm²
Inside D16 @ 150 = 13.24 cm²
Reinforcement with stirrup is applied because the shear stresses at lower side exceed the allowable stress.

(3) Bottom plate

Section No.	3-(1) Support (force)	Haunch 3-(2) (original point)	3-(3) Center point
M (t.m)	11.50	8.95	4.46
N (t)	21.87	21.87	21.87
S (t)	16.26	14.78	0.00
b (cm)	100.0	100.0	100.0
h (cm)	35.0	30.0	30.0
d (cm)	30.0	25.0	25.0
d' (cm)	10.0	5.0	5.0
As (cm ²)	22.453	22.453	13.240
As' (cm ²)	13.240	13.240	22.453
n = Es/Ec	15.00	15.00	15.00
P=As/(b*d) (%)	0.748	0.898	0.530
u=d-h/2 (cm)	12.500	10.000	10.000
f=M/N+u (cm)	65.058	50.903	30.411
f/d	2.169	2.036	1.216
d'/d	0.333	0.200	0.200
As'/As	0.590	0.590	1.696
M'=M+N*u (t.m)	14.231	11.135	6.652
x (cm)	13.150	11.415	11.393
C	5.058	4.362	3.941
S	6.481	5.191	4.707
Z	1.141	1.147	1.081
c (kg/cm ²)	80.0	77.7	42.0
s (kg/cm ²)	1537.2	1387.3	751.5
s' (kg/cm ²)	287.4	655.1	353.1
(kg/cm ²)	6.18	6.78	0.00
m (kg/cm ²)	5.42	5.91	0.00
ca (kg/cm ²)	90.0	90.0	90.0
sa (kg/cm ²)	1800.0	1800.0	1800.0
a (kg/cm ²)	4.50	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean rear stress

Reinforcement

Outside D19, D22 alternately @ 150 = 22.453 cm²

Inside D16 @ 150 = 13.24 cm²

Reinforcement with stirrup is applied because of the shear stresses at the end points exceed the allowable stress.

(4) Ceiling plate

Section No.	4-(1) Support (force)	Hanch 4-(2) (starting point)	4-(3) Center point)
M (t.m)	5.77	4.05	5.00
N (t)	7.77	7.77	7.77
S (t)	10.96	9.97	0.00
b (cm)	100.0	100.0	100.0
h (cm)	35.0	30.0	30.0
d (cm)	30.0	25.0	25.0
d' (cm)	10.0	5.0	5.0
As (cm ²)	10.843	10.843	10.843
As' (cm ²)	10.843	10.843	10.843
n = Es/Ec	15.00	15.00	15.00
P=As/(b*d) (%)	0.361	0.434	0.434
u=d-h/2 (cm)	12.500	10.000	10.000
f=M/N+u (cm)	86.704	62.074	74.346
f/d	2.890	2.483	2.974
d'/d	0.333	0.200	0.200
As'/As	1.000	1.000	1.000
M'=M+N*u (t.m)	6.737	4.823	5.776
x (cm)	9.789	8.471	8.196
C	3.953	5.827	6.013
S	4.754	11.372	12.327
Z	1.083	1.115	1.117
c (kg/cm ²)	51.8	45.0	55.6
s (kg/cm ²)	1602.9	1316.3	1709.0
s' (kg/cm ²)	16.7	276.4	325.1
(kg/cm ²)	0.00	4.45	0.00
m (kg/cm ²)	3.65	3.99	0.00
ca (kg/cm ²)	90.0	90.0	90.0
sa (kg/cm ²)	1800.0	1800.0	1800.0
a (kg/cm ²)	4.50	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean shear stress

Reinforcement

Outside D13, D16 alternately @ 150 = 10.843 cm²
Inside D13, D16 alternately @ 150 = 10.843 cm²

(5) Middle floor

Section No.	5-(1)	5-(2)
M (t.m)	1.59	1.43
N (t)	27.07	27.07
S (t)	1.03	0.94
b (cm)	100.0	100.0
h (cm)	40.0	30.0
d (cm)	30.0	25.0
d' (cm)	10.0	5.0
As (cm ²)	4.223	4.223
As' (cm ²)	4.223	4.223
n = Es/Ec	15.00	15.00
P=As/(b*d) (%)	0.141	0.169
u=d-h/2 (cm)	10.000	10.000
f=M/N+u (cm)	15.866	15.269
f/d	0.529	0.611
d'/d	0.333	0.200
As'/As	1.000	1.000
M'=M+N*u (t.m)	4.296	4.134
x (cm)	0.000	29.406
C	0.000	0.000
S	0.000	0.000
Z	0.000	0.000
c (kg/cm ²)	12.4	17.7
s (kg/cm ²)	-54.8	-39.7
s' (kg/cm ²)	142.0	220.0
(kg/cm ²)	0.00	0.00
m (kg/cm ²)	0.34	0.38
ca (kg/cm ²)	90.0	90.0
sa (kg/cm ²)	1800.0	1800.0
a (kg/cm ²)	4.50	4.50

Note: σ_s ; (-) denotes compression, σ_s' ; (-) denotes tension
m: mean shear stress

Reinforcement

Outside D13 @ 300 = 4.223 cm²

Inside D13 @ 300 = 4.223 cm²

2-3-5 SIRRUP

- (1) Side wall (lower side) - upper ends

Required cross sectional area req Av

$$S_c = 1/2 \times 4.5 \times 100 \times 0.875 \times 25 \times 10^{-3} = 4.922 \text{ t}$$

$$S_v = 15.51 - 4.922 = 10.588 \text{ t}$$

$$\begin{aligned} \text{req Av} &= \frac{S_v \cdot s}{s_a \cdot j \cdot d} = \frac{10.588 \times 10^3 \times 15}{1,800 \times 0.875 \times 25} \\ &= 4.034 \text{ cm}^2 > D13 @ 300 = 4.223 \text{ cm}^2 \end{aligned}$$

Therefore, stirrups (D13) are placed with 15 cm space in a section and 300 cm axial pitch.

- (2) Side wall (lower side) - lower ends

$$S_c = 4.922 \text{ t}$$

$$S_v = 17.76 - 4.922 = 12.838 \text{ t}$$

$$\begin{aligned} \text{req Av} &= \frac{12.838 \times 10^3 \times 15}{1,800 \times 0.875 \times 25} = 4.891 \text{ cm}^2 < D13 @ 150 \\ &= 8.447 \text{ cm}^2 \end{aligned}$$

Therefore, stirrups (D13) are placed with 15 cm space in a section and 150 mm axial pitch.

- (3) Bottom plate

$$S_c = 4.922 \text{ t}$$

$$S_v = 14.78 - 4.922 = 9.858 \text{ t}$$


$$\begin{aligned} \text{req Av} &= \frac{9.858 \times 10^3 \times 15}{1,800 \times 0.875 \times 25} = 3.755 \text{ cm}^2 < D13 @ 300 \\ &= 4.223 \text{ cm}^2 \end{aligned}$$

Therefore, stirrups (D13) are placed with 15 cm space in a section and 300 mm axial pitch.

2-3-6 Summary

The wall thicknesses and reinforcement bars decided by the above calculations are shown in Fig. 17 below.

Fig. 17



The wall thickness is decided as 300 mm with above reinforcement according to the calculation.

90


3. Oil Tanks

3-1 Location of the Oil Tanks

Oil tank for oil filled cable can be located at the end of the cable, in case that the cable length is about 1.3 km or less.

Oil tanks preferably be located at the station side for the convenience of maintenance and be put on the roof of the switchyard building in order to have oil pressure, thus eliminating any oil pump installation.

Fig. 18




3-2 Oil Tank Yard

One oil tank is needed for one cable.

Therefore, in the case of the West Wharf Power Plant Project, 27 units are necessary.

One oil tank having about 500 capacity (1.2 m diameter x 1.7 m height) will be sufficient.

Fig. 19




Oil tank area $A = 180 \text{ m}^2 \quad 200 \text{ m}^2$

4. Drainage

Water leaked into the tunnel will be collected in a drain pit inside the manhole and pumped up to a sewer pipe or other discharge way. Cable tunnel should have a slope of 0.2% and more for better drainage.

Fig. 20



13

TLG-4

GRID STATION FACILITIES

TLG-4 GRID STATION FACILITIES

1. General

Two (2) numbers of 220 kV transmission bays will be extended with existing facilities of the 220 kV Baldia grid station in order to receive electrical power from the West Wharf thermal power station Units No. 1 and No. 2.

2. Basic Requirement

The layout of equipment, facilities and basic specification of the 220 kV Baldia Grid Station extension plan of the Project will be in complete harmony with the existing equipment, facilities and the future extension plan of the Baldia Grid Station.

The current carrying capacity of power receiving facilities for the new 220 kV transmission line from the West Wharf Thermal Power Plant will be 1,250 Ampere based on the output of 400 MW (2 units of 200 MW).

3. Design concept

(1) Specification of switchgear

Type of switchgear	: Indoor, SF6 Gas Insulated switchgear
Bus configuration	: Double bus system
Rated voltage	: 220 kV
Highest system voltage	: 245 kV
Rated frequency	: 50 Hz

Insulation level

Impulse withstand voltage (1.2/50 wave): 950 kV (peak)
Power frequency withstand voltage : 395 kV
Max. asymmetric three-phase short-circuit : 100 kA (peak)
withstand current
Short-time current (1 sec) : 40 kA

(2) Grounding system

- (a) 150 mm² bare annealed copper wire shall be connected to the 220 kV equipment and steel structure.
- (b) Grid (mesh) grounding wire shall be 100 mm² bare annealed copper wire which shall be connected to the existing grid (mesh) grounding wire.
- (c) Grounding wire for control & protection panels, auxiliaries equipment and building facilities shall conform to the existing grounding wires.

(3) Control cables

- (a) Since 220 kV system adopts the direct grounding method, control cables shall be PVC insulated and PVC sheathed control cables with copper tape electrostatic shielding (CVV-S).
- (b) Voltage class: 600V grade
- (c) Cable laying method: Racks in trench

(4) Steel structure and pedestals of equipment

Design of the steel structure and pedestals of equipment shall conform to the existing structure.

(5) Relay and control system

- (a) Power system frequency : 50 Hz
- (b) PT secondary rating : $100/\sqrt{3}$ V
- (c) CT secondary rating : 1 A
- (d) AC auxiliary power supply : 380 V
- (e) DC auxiliary power supply : 220 V
- (f) Interlock conditions

Between circuit breaker and isolators

between circuit breaker and high speed earthing switch

between isolator and working earthing switch

- (g) Synchronizing switch: Transmission line and bus
- (h) Protection system of transmission line

Main: Directional distance relay with transfer trip by

P.L.G. system
(Single and/or three phase reclosing)

Backup: Directional distance relay and time delay

nondirectional overcurrent relay

(6) 220 kV switchgear

(a) Common features

- Type : Indoor, 220 kV SF6 Gas
Insulated Metalclad Switchgear
- Standards : IEC

- Rated voltage : 220 kV
- Maximum system voltage : 245 kV
- Rated frequency : 50 Hz
- Rated short-circuit current: 40 KA
- Insulation medium : SF6
- Materials of enclosures : Aluminum
- Impulse withstand voltage
 - at nominal gas pressure : 950 kV (peak)
 - at minimum gas pressure : 950 kV (peak)
- Power frequency withstand voltage
 - at nominal gas pressure : 395 kV
 - at minimum gas pressure : 395 kV
- Rated short-time withstand current (1 sec): 40 kA
- Rated peak short-circuit current : 100 kA

(b) Bus bar

- Rated normal current at 48°C ambient: 3,150 A
- Bus bar cross section : 3,140 mm²
- Bus bar materials : Aluminium
- Bus bar enclosed tubing : Single-phase
- Tubing diameter : 315/305 mm
- Density of SF6 in the switchgear : 33.4 kg/m³
- Rated pressure of SF6 insulation at 20°C: 5.5 bar
- Max. and min. admissible pressure at SF6: 6.5/5.0 bar
insulation at 20°C

(c) Circuit breaker

- Standards : IEC

78

- Rated voltage : 245 kV
- Rated current : 1,250 A
- Rated short circuit breaking current: 40 kA
- Rated short circuit making current : 100 kA
- Impulse withstand voltage (peak) : 950 kV
- Power frequency withstand voltage : 395 kV
- Total opening time at minimum supply: 50 m.sec
voltage and specified gas pressure
- Total closing time at minimum supply: 80 m.sec
voltage and specified gas pressure
- Driving mechanism
 - . type : Motorop.spring
 - . rated supply voltage : D.C. 220 V
 - . rated of driving motor : 800/900 VA
- Auto-reclose : Single-phase and three-phase
- Rated operating sequence : 0-0.3sec.-CO-3min.-CO
- Number of trip coils : 2
- Arc quenching medium : SF6
- Rated arc quenching pressure of SF6 insulation: 6.5 bar
at 20°C
- Max. and min. admissible pressure of SF6: 7.7/6.0 bar
insulation at 20°C

(d) Isolator

- Standards : IEC
- Rated normal current at : 1,250 A
48°C ambient

- Rated short-time withstand current : 40 kA
- Rated peak short-circuit current : 100 kA
- Impulse withstand voltage (peak) : 950 kV
- Power frequency withstand voltage : 395 kV
- Operating mechanism : Motor drive and hand-operated
 - . Motor voltage : DC 220 V
 - . Rating of driving motor : 375 VA

(e) High speed earthing switch

- Standards : IEC
- Rated making current : 40 kA
- Rated peak short-circuit current : 100 kA
- Impulse withstand voltage (peak) : 950 kV
- Power frequency withstand voltage : 395 kV
- Operating mechanism : Motor drive and hand-operated
 - . Motor voltage : DC 220 V
 - . Rating of driving motor : 375 VA

(f) Working earthing switch

- Standards : IEC
- Rated making current : 40 kA
- Impulse withstand voltage (peak) : 950 kV
- Power frequency withstand voltage : 395 kV
- Operating mechanism : Handoperated

(g) Current transformer

- Standards : IEC, BS
- Rated primary current : 700, 1,250, 3,000 A
- Rated secondary current : 1 A

150

- Accuracy class
 - . Measuring : CL 0.2
 - . Protection 1 : 5P 30
 - . Protection 2 : 5P 30
 - . Differential protection : CL X(BS 3938)
- Rated output
 - . Measuring : 20 VA
 - . Protection 1 : 40 VA
 - . Protection 2 : 40 VA
 - . Differential protection : CL X(BS 3938)
- Saturation factor
 - . Measuring : FS < 10 n
 - . Protection 1 : 30 n
 - . Protection 2 : 30 n
 - . Differential protection : V_{knee} 500 V
- Rated short-time withstand current : 100 kA
- Impulse withstand voltage (peak) : 900 kV
- Power frequency withstand voltage : 395 kV
- Insulation materials : Epoxy/SF6

(h) Voltage transformer

- Standards : IEC
- Rated primary voltage : $220/\sqrt{3}$ kV
- Rated secondary voltage : $100/\sqrt{3}$ V
- Rated tertiary voltage : $100/\sqrt{3}$ V
- Accuracy class : 1.0
- Rated output
 - . Secondary : 200 VA

- . Tertiary : 50 VA
- Impulse withstand voltage (peak) : 900 kV
- Power frequency withstand voltage : 395 kV

(7) Outdoor 200 kV equipment

(a) Bushing

- Standards : IEC
- Rated voltage : 245 kV
- Rated current : 1,250 A
- Impulse withstand voltage (peak) : 950 kV
- Power frequency withstand voltage : 395 kV
- Specified creepage distance : 3.5 cm/kV
- Conductor : Aluminium

(b) Lightning arrester

- Standards : IEC
- Rated voltage : 220 kV
- Maximum system voltage : 245 kV
- Rating of arrester : 198 kV
- Rated discharge current : 10 kA
- Maximum residual voltage : 649 kV
- Impulse withstand voltage (peak) : 950 kV
- Power frequency withstand voltage : 395 kV

(8) Power line carrier system

(a) Capacitor voltage transformer

- Type : Outdoor, CCPD
- Standards : IEC

- Rated primary voltage : $220/\sqrt{3}$ kV
- Rated secondary voltage : $100/\sqrt{3}$ V
- Rated tertiary voltage : $100/\sqrt{3}$ V
- Accuracy class : 1.0
- Rated output
 - . Secondary : 200 VA
 - . Tertiary : 50 VA
- Capacitance : 0.002 μ F
- Impulse withstand voltage (peak) : 900 kV
- Power frequency withstand voltage : 395 kV

(b) Line trap

- Standards : IEC
- Rated current : 1,250 A
- Rated short-time current : 31.5 kA
- Rated frequency : 50 Hz
- Frequency band : 100 - 500 kHz
- Inductance : 0.2 mH
- Method of mounting : Mounting on the capacitor voltage transformer

(c) Coupling filter

- Nominal impedance
 - . PLC side : $Z2 = 75/125$ ohm (unbalance)
 - . Line side : $Z1 = 240/320$ ohm
- Range of coupling capacitance : 1.5 to 13 nF
- Composite loss within passband : less than 1.0 dB
- Return loss within passband : more than 12 dB
- Crossover attenuation of hybrid : more than 20 dB

- Average continuous power : 200 W
- Nominal peak power
 - . at 50 kHz : less than 400W
 - . at 100 kHz : less than 1,000W
- Protection devices
 - . Drain coil
 - . Earthing switch
 - . Lightning arrester

(d) Power line carrier equipment

- Type : Single-sideband with reduced carrier
- RF range : 24 to 500 kHz
- Nominal bandwidth : 4 kHz
- RF system impedance : 50, 75, 125 ohm unbalanced or 150 ohm balanced
- Useful AF bandwidth : 300 to 3,480 Hz
- Ambient conditions
 - . Temperature : 0 to 55°C
 - . Humidity : < 95%

(Transmitter data)

- . RF output power : 20W
- . AF input (Speech) : 600 ohm balanced
- . Signalling : External contact keys pilot oscillator at 50 baud max.
- . Teleoperations : 5 decoupled and individually adjustable input, 600 ohm balanced.

(Receiver data)

. RF sensitivity

at carrier frequency 24 kHz : -38 dBm

at carrier frequency 496 kHz: -24 dBm

. Selectivity

from 4 kHz carrier band

≥ 0.3 kHz : 62 dB

≥ 4 kHz : 120 dB

Image rejection

≤ 400 kHz : 80 dB

≥ 400 kHz : 70 dB

I.F. rejection : ≤ 80 dB

. AF output (Speech) : 600 ohm balanced

. Signalling : Potential-free contact

(Power supplies)

. Main : A.C. 220 V ± 15% 50 Hz

. Battery : D.C. 48 V

(e) Protection signalling equipment

- Transmission time

. Blocking application : < 14 ms

. Permissive tripping : < 14 ms

. Direct tripping : < 16 ms

- Alarm output : 20 VA

- Power supply : Stabilized voltage

from PLC set -40 ± 2.5 V

- Current consumption : 160 - 450 mA

- Ambient temperature : 0 to 55°C

(Transmitter data)

Separate starting input per command input

Interface 1

Command initiated by : Potential-free contact

Input relay supply voltage : from - 40 V

Max. contact current : 4mA

Interface 2

Command initiated by : Contact + battery

Battery voltage : 220, 125, 110, 60, 48 V

Max. input current : 4mA

Command frequency

1st command A : 1,300 \pm 10 Hz

2nd command B : 1,700 \pm 10 Hz

Both command (A + B) : 1,500 \pm 10 Hz

Signal boost in PLC set : 10 to 16 dB

(Receiver data)

Receiver input : Matched to PLC set
20 dB level reserve

Command outputs

1 main contact per command : either N/C or N/O

Contact rating : 100VA, 250V D.C. 1A
10VA, 500V, 0.5A

Auxiliary output : 1 normally open contact
per command

Rating: 50VA, 250V

D.C. 1A

(f) High frequency coaxial cable for PLC

- Type : Armoured coaxial cable
- Impedance : $120 \pm 5\%$ ohm
- Capacitance : 36 pF/m
- Resistance of conductors : ≤ 37 ohm/km
- Attenuation
 - . at 40 kHz : 0.15 dB/100m
 - . at 500 kHz : 0.38 dB/100m
- Conductor : Copper single core 0.8 mm ϕ

101

4. Bill of Quantity

No.	Description	Quantity
(220 kV SF6 Gas Insulated Switchgear)		
1.	Bus bar 220 kV, 3,150 A, Single-phase Type	1 lot
2.	Circuit Breaker 3 ϕ , 220 kV, 1,250 A, 40 kA	2 sets
3.	Isolator 3 ϕ , 220 kV, 1,250 A, 40 kA mechanism	8 sets
4.	High Speed Earthing Switch 3 ϕ , 220 kV, 40 kA with motor operated mechanism	2 sets
5.	Working Earthing Switch 3 ϕ , 220 kV, 40 kA with handoperated mechanism	4 sets
6.	Current Transformer Bushing Type	6 sets
	No. 1 core 700 - 1,250/1A	
	No. 2 core 700 - 1,250/1A	
	No. 3 core 700 - 1,250/1A	
	No. 4 core 3,000/1A	
7.	Voltage Transformer 1 ϕ , $\frac{220}{\sqrt{3}}/\frac{0.10}{\sqrt{3}}/\frac{0.10}{\sqrt{3}}$ kV 200 VA, 50 VA	6 sets
8.	Bushing Outdoor type, 1 ϕ , 245 kV 1,250 A, 40 kA	6 sets
(220 kV Outdoor Equipment)		
9.	Lightning Arrester 1 ϕ , 198 kV, 10 kA	6 sets
(Power Line Carrier System)		
10.	Capacitor Voltage Transformer	2 sets
	1 ϕ , $\frac{220}{\sqrt{3}}/\frac{0.10}{\sqrt{3}}/\frac{0.10}{\sqrt{3}}$ kV 200 VA, 50 VA	

108

No.	Description	Quantity
11.	Line Trap 1,250 A, 0.2mH mounting on the C.V.T.	2 sets
12.	Coupling Filter 75/125 ohm	2 sets
13.	Power Line Carrier Equipment 24 to 500 kHz Single-sideband with reduced carrier	2 sets
14.	Protection Signalling Equipment	2 sets
15.	Coaxial Cable for PLC (Others)	1 lot
16.	Grounding System	1 lot
17.	Steel Structure and Pedestals	1 lot
18.	Control Cables	1 lot
19.	Control Panel For two (2) circuits of 220 kV transmission line	1 lot
20.	Relay Panel For two (2) circuits of 220 kV transmission line	1 lot

