

AR-6. Structural Calculation Sheets for Outdoor Equipment Foundations

938

CONTENTS

	Page
6-1 GENERAL	1
6-2 FLUE GAS DUCT SUPPORT	4
6-3 TURBINE OIL STRAGE TANK	7
6-4 FUEL OIL SERVICE TANK	9

139

6.1.1 APPLICABLE CODES AND STANDARDS

- 1) For design and allowable stress of structural materials

Reinforced concrete structure

AIJ : "Standards for calculation of reinforced concrete structures"

Foundation

AIJ : "Standards for structural design of building foundation"

* AIJ : Architectural Institute of Japan

6.1.2 STRUCTURAL MATERIALS TO BE USED AND ALLOWABLE UNIT STRESS

- 1) Qualities of materials

Concrete ; Comperessive strength of 28 days

$$F_c' = 210 \text{ kg/cm}^2$$

Reinforcement ; Deformed reinforcement

ASTM A615 Grade 40

$$f_y = 2,812 \text{ kg/cm}^2$$

- 2) Physical constants for structural materials

Modulus of elasticity

Concrete 210 t/cm²

Reinforcement 2100 t/cm²

3) ALLOWABLE UNIT STRESS

i) Allowable Unit Stress of Concrete (kg/cm²)

stresses		Permanent Stresses					Temporary Stresses		
		Compress	Shear	Bond			Compress	shear	Bond
				A	B	C			
Materials									
Normal concrete Fc-210	Plain bar Deformed bar	70	7.0	8.4 14.0	12.6 21.0	8.4 14.0	Permanent Stresses x 2.0	Permanent Stresses x 1.5	

- * Remarks A : Top bar of flexural members
- B : Bar, except "Item A", of flexural members
- C : Anchors and lap splices

ii) Allowable Unit Stress of Reinforcing Bars (kg/cm²)

Stresses	Permanent Stresses		Temporary Stresses	
	Tension Compression	Shear Reinforcement	Tension Compression	shear Reinforcement
Deformed bar ASTM A615 Grade 40	1,870	1,870	2,812	2,812

944

6.1.3 LOAD COMBINATION

1) Load combination for steel and concrete structure

Long term loading

i) $D.L+L.L+M.L+C.L$

Short term loading

i) $D.L+L.L+M.L+C.D+W.L$

ii) $D.L+L.L+M.L+C.D+S.L$

where;

D.L ; Dead load

L.L ; Live load and over burden load

M.L ; Machine load

C.L ; Crane operation load

C.D.L ; Crane dead load



W.L ; Wind load

S.L ; Seismic load


9/12

6.2 FLUE GAS DUCT SUPPORT

S/ GENERAL DRAWING



52. LOADING DATA



SEISMIC FORCE


$$H_1 = 0.1 \times 2.5 \times 15.0 = 3.75 \text{ t}$$

WIND FORCE

$$H_1 = 0.15 \times (0.8 + 0.4) \times 15.0 \times 2.6 = 7.02 \text{ t}$$


$$P_1 = 0.15 \times 0.7 \times 15.0 \times 4.8 = 7.56 \text{ t}$$

D.L



$$P_1 = 2.50 \times 15.0 = 37.5 \text{ t}$$


E.L



$$H_1 = 3.75 \text{ t}$$

$$M_1 = 3.75 \times (8.50 + 2.60/2) = 36.75 \text{ t-m}$$

W.L




$$H_1 = 7.02 \text{ t}$$

$$P_1 = 7.56 \text{ t}$$

$$M_1 = 7.02 \times 9.80 = 68.80 \text{ t-m}$$

53. DESIGN OF FOUNDATION

OUTLINE OF FOUNDATION



Foundation weight

$$N_f = 2.4 \times (36 \times 36 \times 1.7 + 10 \times 10 \times \pi \times 0.7) + 1.8 \times (36 \times 36 - 10 \times 10 \times \pi) \times 0.5 = 45.22 \text{ t}$$

CHECK OF BEARING PRESSURE


Check of Pile Reaction

$$P_1 = 75.16/4 + 80.73/(22 \times 2) = 37.14 \text{ t/pile} < 35.0 \times 1.5$$

$$P_1' = 29.94/4 + 80.73/(22 \times 2) = 25.83 \text{ t/pile}$$

DESIGN OF FOOTING

Load case	Factored Load		Pile Reaction	
	ΣN (t)	ΣM (t,m)	P_1 (t/n)	P_1' (t/n)
D.L + L.L	37.50			
D.L + L.L + W.L				
D.L + L.L + S.L				
D.L + W.L	29.94	80.73	37.14	25.83



Stress

$$QF = 25.83 \text{ t}$$

$$MF = 25.83 \times 0.1 = 2.58 \text{ t-m}$$

Reinforcement

$$D = 100 \text{ cm}, \quad d = 85 \text{ cm}, \quad j = 7/8d = 74.38 \text{ cm}$$

$$\text{nec } A_t = \frac{MF}{f_t \cdot j} = 1.23 \text{ cm}^2 \quad \left. \begin{array}{l} 19 - \#5 \\ (A_t = 38.0 \text{ cm}^2) \\ (\phi = 95.0 \text{ cm}) \end{array} \right\}$$

$$\phi = \frac{Q}{f_a \cdot j} = 11.02 \text{ cm}$$

$$\tau = \frac{Q}{b \cdot j} = 0.96 < 7.0 \text{ kg/cm}^2$$

LOADING

	N (t)	Hx (t)	Hy (t)
D.L	37.50		
L.L			
S.Lx	0	3.75	
S.Ly	0		3.75
W.Lx	-7.56	7.02	
W.Ly			

Stress at bottom of foundation


$$N = 37.50 - 7.56 + 45.22 = 75.16 \text{ t}$$

$$M = 68.80 + 7.02 \times 1.70 = 80.73 \text{ t-m}$$

9/15

6.3 TURBINE OIL STORAGE TANK

§1 FOUNDATION PLAN AND SECTION



946

§ 2. DESIGN OF FOUNDATION

8

2-1. DESIGN OF CONCRETE PILE

Foundation weight

$$N_f = 2.4 \times \{0.5 \times 5.0 \times 8.0 + 0.2 \times 0.5 \times (8.0 + 5.0) \times 2\}$$

$$= 54.24 \text{ t}$$

LOADING

$$\text{D.L. } N = 80.0 + 0.5 \times 2 = 81.0 \text{ t}$$

Stress at bottom of foundation


$$N = 81.0 + 54.24 = 135.24 \text{ t}$$

$$M = \text{---}$$

Check of Pile Reaction

$$P_i = 135.24 / 6 = 22.54 \text{ t/pile} < 35 \text{ t/pile} \text{ ok}$$


2-2. DESIGN OF FOOTING



$$W_1 = 2.4 \times 0.5 \times 2.5 = 3.00 \text{ t/m} \quad (\text{Footing weight})$$

$$P_1 = 80.0 / 2 \times 1/2 + 2.4 \times 0.2 \times 0.5 \times 2.2 / 2 = 20.26 \text{ t}$$

$$P_2 = 0.5 + 2.4 \times 0.2 \times 1.0 \times 1.5 = 1.22 \text{ t}$$




$$\downarrow (23.3^\circ)$$

$$D = 50 \text{ cm} \quad d = 40 \text{ cm} \quad j = 35.0 \text{ cm}$$

$$A_t = \frac{M}{f_c \cdot j} = \frac{6.88 \times 10^5}{1870 \times 35} = 10.51 \text{ cm}^2$$

$$\phi = \frac{Q}{f_a \cdot j} = \frac{23.3 \times 10^3}{21 \times 35} = 31.70 \text{ cm}$$



$$(l = 145 \text{ cm})$$

$$\#5 \text{ @ } 200$$


$$(A_s = 16.0 \text{ cm}^2)$$

$$(\phi = 40.0 \text{ cm})$$

$$I = \frac{Q}{b \cdot j} = \frac{23.3 \times 10^3}{145 \times 35} = 4.59 < 7.0$$

947

§1. FOUNDATION PLAN AND SECTION



§2. DESIGN OF FOUNDATION

2-1 DESIGN OF CONCRETE PILE

Foundation weight

$$N_f = 24 \times \left(\frac{8.9}{2} \times \frac{8.9}{2} \times \pi \times 0.5 + 3.9 \times 3.9 \times \pi \times 0.2 \right)$$

$$= 97.59 \text{ t}$$

Seismic force

$$H = 0.1 \times 298.0 = 29.8 \text{ t}$$

Stress at bottom of foundation

LONG TERM

$$N = 298.0 + 97.59 = 395.59 \text{ t}$$

$$M = \text{---}$$

SHORT TERM

$$N = 395.59 \text{ t}$$

$$M = 29.8 \times \left(\frac{6.1}{2} + 0.7 \right) = 111.75 \text{ t.m}$$

8/11

Check of Pile Reaction

LONG TERM

$$P_i = 395.59 / 9 = 43.95 \text{ t/pile} < 45 \text{ t/pile}$$

SHORT TERM


$$z = \frac{(3.9^2 + 2.76^2 \times 2) \times 2}{3.9} = 15.61$$

$$P_i = \frac{395.59}{9} \pm \frac{111.75}{15.61} = 51.11 \text{ t/pile} < 45 \times 2, 36.80 \text{ t/pile} > 0$$

OK.

2-2. DESIGN OF FOOTING

LONG TERM



$$w = \frac{298.0}{(8.9/2 \times 8.9/2 \times \pi)} \times 2.76 = 13.22 \text{ t/m}$$

24.79


SHORT TERM

$$w = (4.79 + \frac{111.75}{46.59}) \times 2.76 = 19.84 \text{ t/m}$$

$$z = \frac{\pi \times 7.8^3}{32} = 46.59$$

LONG TERM

$$D = 50.0 \text{ cm } d = 40.0 \text{ cm } j = 35.0 \text{ cm}$$




$$A_t = \frac{M}{f_c \cdot j} = 36.89 \text{ cm}^2$$

$$\phi = \frac{Q}{f_a \cdot j} = 42.86 \text{ cm}$$

$$l = \frac{Q}{b \cdot j} = 3.26 < 7.0$$

$l = 276 \text{ cm}$
 $\#6 @ 200$
 $(A_s = 39.76 \text{ cm}^2)$
 $\phi = 84.00 \text{ cm}$

SHORT TERM



$$A_t = 36.80 \text{ cm}^2$$

$$\phi = 42.81 \text{ cm}$$

$$l = 4.89 < 7.0 \times 1.5$$

$\#6 @ 200$
 $(A_s = 39.76 \text{ cm}^2)$
 $\phi = 84.00 \text{ cm}$

949

AR-7. Calculation Sheets For Air Conditioning and Ventilation System
For Main Powerhouse

950

C O N T E N T S

1.	DESIGN CRITERIA	-----	1
2.	DATA	-----	2
3.	HEAT TRANSMISSION	-----	4
4.	ROOM LOAD SUMMRY	-----	7
5.	EQUIPMENT LOAD	-----	21
6.	SELECTION OF COOLING EQUIPMENT	-----	29
7.	VENTILATION	-----	39

1. DESIGN CRITERIA

1 - 1 DESIGN CONDITION

1) For air conditioning system

(a) Outdoor air

Summer : 42.2°C DB, 28.6°C WB, 37%RH

(b) Room

Summer : 24°C+2°C DB, 50%RH

Winter : Not more than the condition in summer

2) Minimum ventilation air vol.

For Control Room

25 m³/Hr person

3) Lighting

20 W/m²

4) People

Refer to "Cooling and dehumidifying estimate sheets"

5) Location

25.4°(N), 68.3°(E)

RS-1

2. DATA

Data used for load estimation is based on Carrier,s Design Manual of the newest condition.

2- 1 Outdoor air

1) Dry Bulb

Time	8	9	10	11	12	13	14	15	16	17	18
Dry Bulb											
°C	28.2	30.3	32.8	35.7	38.4	40.4	41.7	42.2	41.7	40.5	38.7

2) HUmidity Ratio

Time	8	9	10	11	12	13	14	15	16	17	18
Humidity Ratio											
g/Kg	19.1	19.0	19.0	19.2	18.9	19.0	18.8	19.0	18.8	18.9	18.8

2.- 2 Solar heat gain

1) Peak solar heat gain thru ordinary glass

EXPOSURE	NL	NE	SE	SW	NW	HORIZONTAL	SHADE
HEAT							
Kcal/h m ²		366	252	252	366	674	47

2) Solar gain correction factors

- for steel sash : 1/0.85
- for dew point : 0.94

3) Load storage factors , solar heat gain thru ordinary glass

TIME EXPOSURE	8	9	10	11	12	13	14	15	16	17	18
NE	0.57	0.46	0.30	0.24	0.20	0.19	0.17	0.16	0.15	0.13	0.11
SE	0.47	0.61	0.67	0.65	0.57	0.44	0.29	0.24	0.21	0.18	0.15
SW	0.08	0.08	0.10	0.24	0.40	0.55	0.66	0.70	0.64	0.50	0.26
NW	0.09	0.09	0.10	0.10	0.10	0.10	0.16	0.34	0.52	0.65	0.64

NOTE : Venetian blind to be located on the inside of glass.

(Overall factor is 0.65)

753

2 - 3 Equivalent temperature difference

1) For wall

TIME EXPOSURE	8	9	10	11	12	13	14	15	16	17	18
NE	4.6	7.9	16.8	16.0	15.3	13.3	11.3	11.9	12.6	13.0	13.5
SE	5.4	8.6	11.1	12.4	13.6	13.8	13.9	12.9	12.4	11.8	11.5
SW	2.6	3.1	3.7	5.0	5.9	9.8	12.1	15.8	18.6	19.2	19.5
NW	3.7	4.5	5.3	6.6	7.9	10.1	11.3	13.5	15.4	19.5	23.2

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 200Kg/m².

2) For wall

TIME EXPOSURE	8	9	10	11	12	13	14	15	16	17	18
NE	15.7	16.2	16.8	14.8	12.8	12.7	12.4	13.0	13.7	13.6	13.5
SE	7.4	9.6	12.1	13.1	14.1	14.4	14.2	13.1	12.6	12.0	11.5
SW	1.9	2.8	3.7	5.7	7.0	12.2	14.9	17.9	20.3	20.4	20.5
NW	3.7	4.7	5.7	7.4	9.1	11.3	12.4	15.8	18.3	22.4	25.5

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 100Kg/m².





3) For roof

TIME For roof	8	9	10	11	12	13	14	15	16	17	18
°C	10.3	10.2	10.8	12.4	14.9	18.0	21.2	24.0	26.2	27.8	28.5

These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 300Kg/m².






784

3 HEAT TRANSMISSION : K-Value



TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE ($m^2H^{\circ}C/Kcal$)	AIR FILM ($m^2H^{\circ}C/Kcal$)	K-Value ($Kcal/m^2H^{\circ}C$)
ROOF 1. 	① CONCRETE BLOCK	30	0.067	$\gamma_0 = 0.05$	0.46
	② SAND	10	0.015		
	③ ASPHALT ROOFING	10	0.108		
	④ CONCRETE	100	0.071		
	⑤ DECK PLATE	1.2	-		
	⑥ AIR SPACE			0.2	
	⑦ GLASS WOOL	50	1.36		
	⑧ CEILING	25	0.132	$\gamma_i = 0.189$ (2.192)	
CEILING 1 FLOOR 1 	① CEMENT MORTAL	30	0.023	$\gamma_i = 0.125$	1.16
	② CINDER CONCRETE	60	0.084		
	③ ASPHALT WATER PROOF	10	0.108		
	④ CONCRETE	100	0.071		
	⑤ DECK PLATE	1.2	-		
	⑥ AIR SPACE			0.2	
	⑦ CEILING	25.0	0.132	$\gamma_i = 0.125$ (0.868)	
FLOOR 2 CEILING 2 	① VINYL ASBESTOS TILE	2	0.054	$\gamma_i = 0.125$	2.52
	② CEMENT MORTAL	28	0.022		
	③ CONCRETE	100	0.071		
	④ DECK PLATE	1.2	-	$\gamma_i = 0.125$ (0.397)	
FLOOR 3. 	① FLOORING	12	0.086	$\gamma_i = 0.125$	1.59
	② AIR SPACE			0.2	
	③ CONCRETE	130	0.093		
	④ DECK PLATE	1.2	-	$\gamma_i = 0.125$ (0.629)	

PKS

HEAT TRANSMISSION : K-Value

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE ($m^2H^{\circ}C/Kcal$)	AIR FILM ($m^2H^{\circ}C/Kcal$)	K-Value ($Kcal/m^2H^{\circ}C$)	
WALL 1 				$\gamma_o = 0.05$		
	① PRECAST CONCRETE	120	0.086			
	② GLASS WOOL	50	1.36			
	③ AIR SPACE			0.2		
	④ PLASTER BOARD	12	0.064			
				$\gamma_i = 0.133$ (1.893)	0.53	
WALL 2 				$\gamma_o = 0.05$		
	① CONCRETE BLOCK	150	0.334			
	② AIR SPACE			0.2		
	③ PLASTER BOARD	12	0.064			
					$\gamma_i = 0.133$ (0.781)	1.29
WALL 3 				$\gamma_o = 0.05$		
	① STEEL	-	-			
	② GLASS WOOL	50	1.36			
	③ AIR SPACE			0.2		
	④ PLASTER BOARD	12	0.064			
				$\gamma_i = 0.133$ (1.807)	0.56	
PARTITION 1 				$\gamma_i = 0.133$		
	① CONCRETE BLOCK	150	0.334			
	② PLASTER BOARD	12	0.064			
					$\gamma_i = 0.133$ (0.664)	1.51
PARTITION 2 				$\gamma_i = 0.133$		
	① PLASTER BOARD	12	0.064			
	② AIR SPACE			0.2		
	③ PLASTER BOARD	12	0.064			
					$\gamma_i = 0.133$ (0.594)	1.69

HEAT TRANSMISSION : K-Value

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE ($m^2H^\circ C/Kcal$)	AIR FILM ($m^2H^\circ C/Kcal$)	K-Value ($Kcal/m^2H^\circ C$)	
PARTITION 3 	① PLASTER BOARD	12	0.064	$\gamma_i = 0.133$ (2.088)		
	② CONCRETE BLOCK	150	0.334			
	③ GLASS WOOL	50	1.36			
	④ PLASTER BOARD	12	0.064			
DOOR 	① STEEL	12	-	$\gamma_i = 0.133$ (0.966)		
	② AIR SPACE				0.2	
	③ STEEL	12	-			2.15
WINDOW (OUT)	ORDINARY GLASS	3			5.1	
WINDOW (IN)	ORDINARY GLASS	3			3.8	

4. ROOM LOAD SUMMARY
 4-1. AC-Z
 1) ROOM PEAK LOAD

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(%)	DENUM.AIR (m ³ /H)	OUT AIR (m ³ /H)
					R.S.H (Kcal/H)	R.T.H (Kcal/H)			
OPER. FLOOR 0-2	CENTRAL CONTROL ROOM	328.29	978.87	5	42.936	43.656	12.9		650
	SUB TOTAL				42.936	43.656	12.6	14.500	650
FOURTH FLOOR F-1	SHIFT ROOM	56.0	156.8	6	4.365	4.791	12.2	1470	150
F-2	REST ROOM	19.6	54.88	2	1.273	1.415	12.1	450	50
F-3	CONFERENCE RM.	88.0	246.4	10	5.358	6.169	11.8	1.850	400
F-4	ELECTRICAL & INSTRUMENT REPAIR ROOM	198.0	554.4	6	10.023	10.551	12.5	3.400	300
F-5	PABX ROOM	67.68	189.5	4	3.938	4.223	12.4	1.330	100
	SUB TOTAL				24.957	27.149		8.500	1000
	TOTAL				67.893	70.805	12.6	23.000	1.650
					SHF = 0.96				

958

2). LOAD SUMMARY (TIME)

NO.	ROOM NAME	3:00		4:00		5:00	
		E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)
OPER.	CENTRAL	*	*				
D-2	CONTROL ROOM	42.936	43.656	42.568	43.278	41.670	42.380
	SUB TOTAL	42.936	43.656	42.568	43.278	41.670	42.380
4F				*	*		
F-1	SHIFT ROOM	4.358	4.786	4.365	4.791	4.215	4.641
F-2	REST ROOM	1.175	1.318	1.273	1.415	1.166	1.308
F-3	CONFERENCE ROOM	5.331	6.159	5.358	6.169	5.307	6.118
F-4	ELECTRICAL & INSTRUMENT REPAIR ROOM	9.905	10.437	10.023	10.551	10.013	10.541
F-5	PABX ROOM	3.811	4.096	3.926	4.220	3.938	4.223
	SUB TOTAL	24.580	26.796	24.945	27.146	24.639	26.831
AC-2	TOTAL	* 67.516	* 70.452	67.513	70.424	66.309	69.211

4-2 AC-1

3100

9

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	R.S.H (Kcal/h)	R.T.H (Kcal/h)	INDICATED A.D.P(°C)	DEHUM.AIR (m ³ /h)	OUT.AIR (m ³ /h)
OPER. FLOOR 0-1	COMPUTER ROOM UNIT NO. 2	84°	252	4	23.754	24.040	13.°	8.400	100
0-3	COMPUTER ROOM UNIT NO. 1	127.21	381.63	6	35.257	35.685	13.°	12.300	150
TOTAL		211.21	633.63	10	59.011	59.725	13.°	20.700	250

SHF=0.99

4-3 AC-3

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	R.S.H (Kcal/h)	R.T.H (Kcal/h)	INDICATED A.D.P(°C)	DEHUM.AIR (m ³ /h)	OUT.AIR (m ³ /h)
MEZZ. FLOOR M-1	UNIT NO. 1 & NO. 2 CONTROL EQUIPMENT ROOM	216.33	605.73	6	41.732	42.160	13	14.600	150
TOTAL		216.33	605.73	6	41.732	42.160	13	14.600	150

SHF=0.99

4-4 AC-4

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	R.S.H (Kcal/h)	R.T.H (Kcal/h)	INDICATED A.D.P(°C)	DEHUM.AIR (m ³ /h)	OUT.AIR (m ³ /h)
MEZZ. FLOOR M-1	FUEL LABORATORY	65.57	183.60	4	6.265	6.605	12.5	2.200	100
M-2	WATER ANALITICAL ANALITICAL INSTRUMENT ROOM	134.75	377.3	7	12.970	13.464	12.6	4.400	210
TOTAL				11	19.235	20.069	12.6	6.600	310

SHF=0.96

096

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **CENTRAL CONTROL ROOM (0-2)** SYSTEM _____
 SIZE $m \times m = 328.29 \text{ m}^2$ X $3 \text{ mH} = 978.87 \text{ m}^3$

SHEET No. 10
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
				3:00	CORRECTION	5:00					
SOLAR GAIN — GLASS											
(SE) 3.0	$m^2 \times 23.0 \times 1.0 / 85 \times 0.94 \times 0.65$			131	115	98	HOURS OF OPERATION	Hour (-)			
	$m^2 \times$	X					OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH	
	$m^2 \times$	X					CONDITIONS	DB °C	WB °C	%RH	
	$m^2 \times$	X					OUTSIDE	42.2	28.6	37	
	$m^2 \times$	X					ROOM	24.0	50	9.9	
	$m^2 \times$	X					DIFFERENCE	18.2	X X X	X X X	
SOLAR & TRANS GAIN—WALLS & ROOF											
WALL (SE) 132.0	$m^2 \times 13.1 \times 0.56$			969	932	887	BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L M D			
	$m^2 \times$	X					GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE			
	$m^2 \times$	X					COLOR	LIGHT, MEDIUM, DARK.			
	$m^2 \times$	X					WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)		
	$m^2 \times$	X					INTERNAL HEAT	W/m ²	m ² /PEOPLE		
ROOF—SUN	$m^2 \times$	X					INFILTRATION				
ROOF—SHADED	$m^2 \times$	X					SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF											
GLASS 3.0	$m^2 \times 18.2 \times 5.1$			279	271	258	REVOLVING DOORS	PEOPLE X CMH/PER.			
CEILING 76.04	$m^2 \times 9.1 \times 1.16$			793	771	719	OPEN DOORS	DOORS X CMH/DOOR			
FLOOR 328.29	$m^2 \times 9.1 \times 2.52$			7529	7322	6826	EXHAUST AIR				
PARTITION (1) 73.74	$m^2 \times 9.1 \times 1.51$			1014	986	919	CRACK	m X	CMH/m		
(2) 2.7	$m^2 \times 9.1 \times 1.69$			42	41	38	INFILTRATION	CMH	■		
DOOR (IN) 5.9	$m^2 \times 9.1 \times 2.15$			106	103	96	VENTILATION				
GLASS (IN) 3.66	$m^2 \times 9.1 \times 5.8$			127	123	115	5 PEOPLE X	25	CMH/PER.	125	
							$m^2 \times$	CMH/m ²	↓		
							VENTILATION	CMH	■	650	
INTERNAL HEAT											
PEOPLE	5 PEOPLE X 41			205	205	205	SENSIBLE HEAT FACTOR				
Kw	29.7 Kw X 0.8 X		860	20434	20434	20434	E.S.H.F. =	42.936 (ERSH)	= 0.98 (17.0°)		
LIGHTS	328.29 X 20 W X		1.08	7091	7091	7091		43.656 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR				
							APPARATUS DEWPOINT	12.6 °C			
								42.936 (ERSH)			
							(24RM - 12.6ADP) (1 - BF) X 0.29	= 14.500 CMH			
NOTES											
							$SR = 23.0 \times 13.1 + 6.0 + (30.5 + 5.0) \times 1.5 = 328.29$				
							GLASS (SE): $15 \times 1.0 \times 2 = 3.0$				
							WALL (SE): $27.0 \times 5.0 - 3.0 = 132.0$				
							PARTITION (1): $27.0 \times 3.0 - (3.66 + 3.6) = 73.74$				
							(2): $15 \times 3.0 - 1.8 = 2.7$				
							DOOR (IN): $0.9 \times 2.0 \times 3 = 5.9$				
							GLASS (IN): $3.05 \times 1.2 = 3.66$				
							CEILING: $23.0 \times 3.0 + (3.05 + 5.0) \times 1.5 = 75.04$				
							FLOOR: SR				
ROOM SENSIBLE HEAT SUB TOTAL											
				38720	38394	37681					
SUPPLY DUCT	SUPPLY DUCT	FAN									
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	3872	3840	3769					
BYPASS OUTSIDE AIR				$650 \text{ CMH} \times 18.2 \times 0.1 \text{ BF} \times 0.29$	344	334	215				
EFFECTIVE ROOM SENSIBLE HEAT				42936	42568	41690					
ROOM LATENT HEAT											
INFILTRATION	CMH X	g/kg X	0.72								
PEOPLE	5 PEOPLE X	49		245							
STEAM		kg/h X	540								
APPLIANCES ETC.											
ROOM LATENT HEAT SUB TOTAL											
				245	245	245					
SUPPLY DUCT LEAKAGE LOSS		10%		25	25	25					
BYPASS OUTSIDE AIR				$650 \text{ CMH} \times 9.6 \text{ g/kg} \times 0.1 \text{ BF} \times 0.72$	450	440	440				
EFFECTIVE ROOM LATENT HEAT				720	710	710					
EFFECTIVE ROOM TOTAL HEAT				43656	43278	42400					
OUTSIDE AIR HEAT											
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29									
LATENT:	CMH X	g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT SUB TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	- H.P.	- PIPE GAIN	= %							
(U.S.R.T)				GRAND TOTAL HEAT							

961

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.	INQUIRED BY	SHEET NO.
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR	SHIFT ROOM (E-1)	REVISION
SYSTEM		PERSON IN CHARGE
SIZE	m x m = 56.0 m ² x 2.8 m(H) = 156.8 m ³	

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
					CORRECTION							
SOLAR GAIN - GLASS							4:00	5:00	3:00			
(SE)	3.0 m ²	253 x 0.21 x 0.85 x 0.84 x 0.65		115	98	131	HOURS OF OPERATION Hour (-)					
(NE)	1.5 m ²	266 x 0.15 x 0.85 x 0.94 x 0.65		60	52	64	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ²	x					CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ²	x					OUTSIDE	21.7	28.4	38		18.8
	m ²	x					ROOM	24.0		50		9.4
	m ²	x					DIFFERENCE	17.7	X X X	X X X	X X X	9.9
SOLAR & TRANS GAIN - WALLS & ROOF												
WALL (SE)	32.48 m ²	12.6 x 0.56		230	219	239	BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D				
(NE)	32.52 m ²	13.7 x 0.56		250	248	237	GLASS	ORDINARY THICK. ABSORBENT. % DOUBLE				
	m ²	x					COLOR	LIGHT, MEDIUM, DARK.				
	m ²	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ²	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN	56.0 m ²	26.2 x 0.46		675	717	619	INFILTRATION					
ROOF - SHADED	m ²	x					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF												
GLASS	4.5 m ²	17.7 x 5.1		407	399	418	REVOLVING DOORS	PEOPLE X CMH/PER.				
CEILING	m ²	x					OPEN DOORS	DOORS X CMH/DOOR				
FLOOR	25.65 m ²	8.85 x 1.16		264	246	271	EXHAUST AIR					
PARTITION (1)	12.76 m ²	8.85 x 1.51		171	123	176	CRACK	m x	CMH/m			
(2)	15.68 m ²	8.85 x 1.69		235	196	242	INFILTRATION	CMH				
DOOR (IN)	1.8 m ²	8.85 x 2.15		35	32	36	VENTILATION					
INFILTRATION	CMH x deg X 0.29						6 PEOPLE X	25	CMH/PER.		150	
INTERNAL HEAT												
PEOPLE	6 PEOPLE X 41			246	246	246	m ²	CMH/m ²				
KW	KW X 860						VENTILATION	CMH				
LIGHTS	56.0 x 20 WX 1.08			1210	1210	1210	SENSIBLE HEAT FACTOR					
APPLIANCES ETC.							E.S.H.F. =	4365	(IERSH) = 0.91 (12.2)			
								4791	(IERTH)			
CREDIT FOR THERMAL STORAGE												
	m ²	deg X					DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT	12.6 °C				
								4365 (IERSH)				
							24 RM - 126 ADP (1 - BF) X 0.29 = 1470 CMH					
SAFETY FACTOR %												
ROOM SENSIBLE HEAT Sub Total							3898	3766	3889	NOTES		
SUPPLY DUCT	SUPPLY DUCT	FAN					GLASS (SE) : 1.0 x 1.5 x 2 = 3.0					
HEAT GAIN	+ LEAK LOSS	+ HP = 10%		390	377	389	(NE) : 1.0 x 1.5 = 1.5					
BYPASS OUTSIDE AIR	150 CMH x 17.7 deg x 0.1 BF x 0.29			77	72	80	WALL (SE) : 7.3 x 4.86 x 3.0 = 32.48					
EFFECTIVE ROOM SENSIBLE HEAT							4365	4215	4358	(NE) : 7.0 x 4.86 x 1.5 = 32.52		
ROOM LATENT HEAT										PARTITION (1) : 5.3 x 2.8 x 1.8 = 12.76		
INFILTRATION	CMH X g/kg X 0.72						(2) : 5.6 x 2.8 = 15.68					
PEOPLE	6 PEOPLE X 49			294		294	DOOR (IN) : 0.9 x 2.0 = 1.8					
STEAM	kg/h X 540						FLOOR : 3.3 x 7.0 + 1.7 x 1.5 = 25.65					
APPLIANCES ETC.							ROOF : SR					
VAPOR TRANS.										SR = 7.3 x 7.0 + 1.4 x 3.5 = 56.0		
Sub Total												
SAFETY FACTOR %												
ROOM LATENT HEAT Sub Total							294	294	294			
SUPPLY DUCT LEAKAGE LOSS	10 %			30	30	30						
BYPASS OUTSIDE AIR	150 CMH X 9.4 g/kg X 0.1 BF X 0.72			102	102	109						
EFFECTIVE ROOM LATENT HEAT							476	476	478			
EFFECTIVE ROOM TOTAL HEAT							4791	4641	4786			
OUTSIDE AIR HEAT												
SENSIBLE:	CMH X deg X (1 - BF) X 0.29											
LATENT:	CMH X g/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT Sub Total												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	+ LEAK GAIN	+ H.P.	+ GAIN = %									
(U.S.R.T) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **REST ROOM (F-2)** SYSTEM _____
 SIZE **5.6 m x 3.5 m = 19.6 m²** x **2.8 m(H) = 54.88 m³**

SHEET No. **12**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
				4:00	5:00	3:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
(SE)	1.5 m ²	252 x 0.21 / 0.25 x 0.94 x 0.65		58	49	66	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ²	x					CONDITIONS	DB C	WB C	%RH	DP C	g/kg
	m ²	x					OUTSIDE	41.7	28.4	38		18.8
	m ²	x					ROOM	24.0		50		9.4
	m ²	x					DIFFERENCE	17.7	X X X	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D					
WALL (SE)	15.51 m ²	12.6 x	0.56	196	105	114	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ²	x					COLOR	LIGHT, MEDIUM, DARK.				
	m ²	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ²	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN	19.6 m ²	26.2 x	0.46	237	251	217	INFILTRATION					
ROOF - SHADED	m ²	x					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.					
GLASS	1.5 m ²	17.7 x	5.1	136	127	140	OPEN DOORS DOORX CMH/DOOR					
CEILING	m ²	x					EXHAUST AIR					
FLOOR	m ²	x					CRACK m X CMH/m					
PARTITION	m ²	x					INFILTRATION CMH					
INTERNAL HEAT							VENTILATION					
INFILTRATION	CMH X	deg X	0.29				2 PEOPLE X		25 CMH/PER.		50	
PEOPLE	2 PEOPLE X	41		82	82	82	m ² X		CMH/m ²			
Kw	Kw X	x	860				VENTILATION CMH					
LIGHTS	19.6 x 20 W X		1.08	424	424	424	SENSIBLE HEAT FACTOR					
APPLIANCES ETC.							E.S.H.F. = 1.273 (ERSH) = 0.9 (12.1)					
CREDIT FOR THERMAL STORAGE							14.15 (ERTH)					
Sub TOTAL							DEHUMIDIFIED AIR					
SAFETY FACTOR							APPARATUS DEWPOINT 12.6 C					
ROOM SENSIBLE HEAT Sub TOTAL				1133	1038	1043	1.273 (ERSH)					
SUPPLY DUCT	SUPPLY DUCT	FAN					(24 RM. (ADP) (1 - BF) X 0.29 = 430 CMH					
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	114	104	105						
BYPASS OUTSIDE AIR	50 CMH X 17.7 deg X 0.1 BF X 0.29			26	24	27						
EFFECTIVE ROOM SENSIBLE HEAT				1273	1166	1175						
ROOM LATENT HEAT												
INFILTRATION	CMH X	g/kg X	0.72									
PEOPLE	2 PEOPLE X	49		98		98						
STEAM		kg/h X	540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub TOTAL												
SAFETY FACTOR												
ROOM LATENT HEAT Sub TOTAL				98	98	98						
SUPPLY DUCT LEAKAGE LOSS			10%	10	10	10						
BYPASS OUTSIDE AIR	25 CMH X 9.4 g/kg X 0.1 BF X 0.72			34	34	35						
EFFECTIVE ROOM LATENT HEAT				142	142	143						
EFFECTIVE ROOM TOTAL HEAT				1415	1308	1318						
OUTSIDE AIR HEAT												
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29										
LATENT:	CMH X	g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	+ LEAK GAIN	- H.P	+ GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **CONFERENCE ROOM (F-3)** SYSTEM _____
 SIZE: 8.0 m² x 11 m² x 2.8 m HI = 246.4 m³

SHEET NO. **13**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 4		
SOLAR GAIN - GLASS				4100	5:00	3:00	HOURS OF OPERATION Hour (-)					
(SE) 4.5	m ² x 252 x 0.21 / 0.85 x 0.94 x 0.65			172	147	196	OUTSIDE DESIGN CONDITIONS: CDB CWB %RH					
	m ² x	x					CONDITIONS	DB C	WB C	%RH	DP C	g/kg
	m ² x	x					OUTSIDE	41.7	22.9	38		18.8
	m ² x	x					ROOM	24.0		50		9.4
	m ² x	x					DIFFERENCE	17.7	x x x	x x x	x x x	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D					
WALL (SE) 34.38	m ² x	12.6 x	0.56	243	231	253	GLASS ORDINARY, THICK, ABSORBENT, % DOUBLE					
	m ² x	x					COLOR	LIGHT, MEDIUM, DARK				
	m ² x	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ² x	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN 88	m ² x	26.2 x	0.46	1061	1126	972	INFILTRATION					
ROOF - SHADED	m ² x	x					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.					
GLASS 4.5	m ² x	17.7 x	5.1	407	379	418	OPEN DOORS DOORSX CMH/DOOR					
CEILING	m ² x	x					EXHAUST AIR					
FLOOR	m ² x	x					CRACK m x CMH/m					
PARTITION (1) 18.8	m ² x	8.85 x	1.51	252	235	259	INFILTRATION CMH					
(2) 11.2	m ² x	8.85 x	1.69	168	157	173	VENTILATION					
DOOR 3.6	m ² x	8.85 x	2.15	69	64	71	D PEOPLEX 25 CMH/PER. 250					
INFILTRATION	CMH x	deg x	0.29				m ² x CMH/m ² ↓					
INTERNAL HEAT							VENTILATION CMH 400					
PEOPLE	10 PEOPLE x	41		416	410	410	SENSIBLE HEAT FACTOR					
KW	KW x	x	860				E.S.H.F. = 5.358 (ERSH) = 0.87 (11.8°C)					
LIGHTS	88.0 x 20 W x		1.08	1901	1901	1901	6.169 (ERTH)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
CREDIT FOR THERMAL STORAGE	m ² x	deg x					APPARATUS DEWPOINT 12.6 C					
							5358 (ERSH)					
							24 RM - 12.6 ADP (1 - BF) x 0.29 = 1800 CMH					
SUB TOTAL							NOTES					
SAFETY FACTOR			%				GLASS (SE): 1.0 x 1.5 x 3 = 4.5					
ROOM SENSIBLE HEAT SUB TOTAL				4683	4650	4653	WALL (SE): 8.0 x 4.86 - 4.5 = 34.38					
SUPPLY DUCT	SUPPLY DUCT	FAN					PARTITION (1): 8.0 x 2.8 - 3.6 = 18.8					
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	469	465	466	(2): 4.0 x 2.8 = 11.2					
BYPASS OUTSIDE AIR 400 CMH x 17.7 deg x 0.1 BF x 0.29				206	192	212	ROOF: SR					
EFFECTIVE ROOM SENSIBLE HEAT				5358	5307	5331	DOOR (IN): 1.8 x 2.0 = 3.6					
ROOM LATENT HEAT												
INFILTRATION	CMH x	g/kg x	0.72									
PEOPLE	10 PEOPLE x	49		490		490						
STEAM		kg/h x	540									
APPLIANCES ETC.												
VAPOR TRANS.												
SUB TOTAL												
SAFETY FACTOR			%									
ROOM LATENT HEAT SUB TOTAL				490	490	490						
SUPPLY DUCT LEAKAGE LOSS			10%	50	50	50						
BYPASS OUTSIDE AIR 400 CMH x 9.4 g/kg x 0.1 BF x 0.72				271	271	288						
EFFECTIVE ROOM LATENT HEAT				811	811	828						
EFFECTIVE ROOM TOTAL HEAT				6169	6118	6159						
OUTSIDE AIR HEAT												
SENSIBLE:	CMH x	deg x (1 - BF) x 0.29										
LATENT:	CMH x	g/kg x (1 - BF) x 0.72										
GRAND TOTAL HEAT SUB TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	+ LEAK GAIN	- H.P.	+ GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY No. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED For **ELECTRICAL & INSTRUMENT REPAIR ROOM (F-d) SYSTEM**
 SIZE **18.0 m x 11.0 m = 198.0 m²** x **2.8 m(H) = 554.4 m³**

SHEET No. **14**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 4	
				A:00	5:00	3:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION		Hour (-)		
(SE)	6.0 m ²	25.2 x 0.21 / 0.85 x 0.94 x 0.65		229	196	261	OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH	
	m ²	X					CONDITIONS	DB C	WB C	%RH	
	m ²	X					OUTSIDE	41.7	28.4	78	
	m ²	X					ROOM	24.0		50	
	m ²	X					DIFFERENCE	17.7	X X X	X X X	
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND		NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D		
WALL (SE)	81.48 m ²	12.5 X	0.56	575	548	598	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE			
	m ²	X					COLOR	LIGHT, MEDIUM, DARK.			
	m ²	X					WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)		
	m ²	X					INTERNAL HEAT	Wm ²	m ² /PEOPLE		
ROOF - SUN	198.0 m ²	26.2 X	0.46	2387	2532	2186	INFILTRATION				
ROOF - SHADED	m ²	X					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS		PEOPLEX CMH/PER.		
GLASS	6.0 m ²	17.7 X	5.1	542	505	557	OPEN DOORS	DOOREX CMH/DOOR			
CEILING	m ²	X					EXHAUST AIR				
FLOOR	m ²	X					CRACK	m X	CMH/m		
PARTITION	43.2 m ²	8.85 X	1.51	578	539	594	INFILTRATION	CMH			
DOOR	7.2 m ²	8.85 X	2.15	137	128	141	VENTILATION				
INFILTRATION							CMH X	deg X	0.29		
INTERNAL HEAT							6 PEOPLEX		25 CMH/PER.		150
PEOPLE	6 PEOPLE	41		246	246	246	m ² X	CMH/m ²		↓	
Kw	Kw X	X	860				VENTILATION		CMH		
LIGHTS	198.0 x 20 W X	1.08		4277	4277	4277	SENSIBLE HEAT FACTOR				
APPLIANCES ETC.							E.S.H.F. =		10.023 (ERSH) = 0.95 (125°C)		
									10.551 (ERTH)		
DEHUMIDIFIED AIR							APPARATUS DEWPOINT		12.6 C		
CREDIT FOR THERMAL STORAGE							10023 (ERSH)				
Sub Total							(24 RM - 12.6 ADP) (1 - BF) X 0.29		3,400 CMH		
SAFETY FACTOR							NOTES				
ROOM SENSIBLE HEAT Sub Total							8971	8971	8860		
SUPPLY DUCT	SUPPLY DUCT	FAN					GLASS (SE): 1.0 x 1.5 x 4 = 6.0				
HEAT GAIN	- LEAK LOSS	+ HP	= 10%	898	898	886	WALL (SE): 18.0 x 4.86 - 6.0 = 81.48				
BYPASS OUTSIDE AIR 300 CMH x 17.7 deg x 0.1 BF x 0.29							154	144	159		
EFFECTIVE ROOM SENSIBLE HEAT							10023	10013	9905		
ROOM LATENT HEAT							PARTITION: 18.0 x 2.8 - 7.2 = 43.2				
INFILTRATION	CMH X	g/kg X	0.72				DOOR (IN): 1.8 x 2.0 x 2 = 7.2				
PEOPLE	6 PEOPLE	49		294		294	ROOF : SR				
STEAM		kg/h X	540								
APPLIANCES ETC.											
VAPOR TRANS.											
Sub Total											
SAFETY FACTOR											
ROOM LATENT HEAT Sub Total							294	294	294		
SUPPLY DUCT	LEAKAGE LOSS		16 %	30	30	30					
BYPASS OUTSIDE AIR 300 CMH x 9.4 g/kg x 0.1 BF x 0.72							204	204	208		
EFFECTIVE ROOM LATENT HEAT							528	528	532		
EFFECTIVE ROOM TOTAL HEAT							10551	10541	10537		
OUTSIDE AIR HEAT											
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29									
LATENT:	CMH X	g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub Total											
RETURN DUCT	RETURN DUCT	PUMP	Pipe								
HEAT GAIN	+ LEAK GAIN	- H.P	+ GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

965

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY No. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **PABX ROOM (F-5)** SYSTEM _____
 SIZE mX m = **67.68 m²** X **2.8 m(H) = 189.50 m³**

SHEET No. **15**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 5
				5:00	CORRECTION	4:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION	Hour (-)		
	m ² X	X			3:00	4:00	OUTSIDE DESIGN CONDITIONS	'CDB	'CWB	%RH
	m ² X	X					CONDITIONS	DB °C	WB °C	%RH
	m ² X	X					OUTSIDE	40.5	28.2	79
	m ² X	X					ROOM	24.5	50	9.4
	m ² X	X					DIFFERENCE	16.5	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D		
WALL (SE)	33.05 m ² X	12.0	X 0.56	222	243	234	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
(SW)	41.80 m ² X	20.4	X 0.56	478	419	476	COLOR	LIGHT, MEDIUM, DARK.		
	m ² X	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)
	m ² X	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE
ROOF - SUN	67.68 m ² X	27.8	X 0.46	866	748	816	INFILTRATION			
ROOF - SHADED	m ² X	X					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS	PEOPLEX CMH/PER		
GLASS	m ² X	X					OPEN DOORS	DOORS X CMH/DOOR		
CEILING	m ² X	X					EXHAUST AIR			
FLOOR	m ² X	X					CRACK	m X CMH/m		
PARTITION	22.40 m ² X	8.25	X 1.51	280	309	300	INFILTRATION	CMH		
DOOR (IN)	3.6 m ² X	8.25	X 2.15	64	71	69	VENTILATION			
							4 PEOPLEX	25 CMH/PER		100
INFILTRATION	CMH X deg X		0.29				m ² X	CMH/m ²		
INTERNAL HEAT							VENTILATION	CMH		
PEOPLE	4 PEOPLEX	41		164	164	164	SENSIBLE HEAT FACTOR			
Kw	Kw X	X	860				E.S.H.F =	3938 (ERSH) = 0.93 (12.4)		
LIGHTS	67.68 X 20. W X		1.08	1462	1462	1462		4223 (ERTH)		
APPLIANCES ETC.							DEHUMIDIFIED AIR			
							APPARATUS DEWPOINT	12.6 °C		
								3.938 (ERSH)		
CREDIT FOR THERMAL STORAGE	m ² X deg X						(24 RM - 12.6 ADP) (1 - 2.1 BF) X 0.29 = 1336 CMH			
Sub TOTAL										
SAFETY FACTOR							NOTES			
ROOM SENSIBLE HEAT Sub TOTAL				3536	3418	3521	SR = 68 X 11.0 - 2.85 X 2.5 = 67.68			
SUPPLY DUCT	SUPPLY DUCT	FAN					WALL (SE): 6.8 X 4.86 = 33.05			
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	354	342	353	(SW): 8.6 X 4.86 = 41.80			
BYPASS OUTSIDE AIR 100 CMH X 16.5 deg X 0.1 BF X 0.29				48	53	52	PARTITION: 9.3 X 2.8 - 3.6 = 22.44			
EFFECTIVE ROOM SENSIBLE HEAT				3938	3811	3926	DOOR (IN): 1.8 X 2.0 = 3.6			
ROOM LATENT HEAT							ROOF: SR			
INFILTRATION	CMH X	g/kg X	0.72							
PEOPLE	4 PEOPLEX	49		196	196	196				
STEAM		kg/h X	540							
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR										
ROOM LATENT HEAT Sub TOTAL				196	196	196				
SUPPLY DUCT LEAKAGE LOSS			10%	20	20	20				
BYPASS OUTSIDE AIR 100 CMH X 9.5 g/kg X 0.1 BF X 0.72				69	69	68				
EFFECTIVE ROOM LATENT HEAT				285	285	284				
EFFECTIVE ROOM TOTAL HEAT				4223	4096	4220				
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X deg X (1 - BF) X 0.29									
LATENT:	CMH X g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	- H.P	+ GAIN	= %						
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET No. 16

INQUIRING No. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED For COMPUTER RM. UNIT No. 2 (0-1) SYSTEM _____
 SIZE 12.0 m x 7.0 m = 84 m² x 3.0 m(H) = 252 m³

DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR:	AM PM	PEAK LOAD	AM PM3	
				3:00	CORRECTION					
SOLAR GAIN --- GLASS						HOURS OF OPERATION Hour (-)				
	m ² X	X				OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
	m ² X	X				CONDITIONS: DB C WB C %RH DP C g/kg				
	m ² X	X				OUTSIDE	22.2	28.6	37	19.0
	m ² X	X				ROOM	24.0		50	9.4
	m ² X	X				DIFFERENCE	18.2	X X X	X X X	X X X
SOLAR & TRANS GAIN-WALLS & ROOF						BLIND NON-EXISTENCE(OUTSIDE, INSIDE) L M D				
WALL	m ² X	X				GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m ² X	X				COLOR LIGHT, MEDIUM, DARK.				
	m ² X	X				WEIGHT		kg/m ² (FLOOR)	kg/m ² (WALL)	
	m ² X	X				INTERNAL HEAT:		W/m ²	m ² /PEOPLE	
ROOF-SUN	m ² X	X				INFILTRATION				
ROOF-SHADED	m ² X	X				SWINGING				
TRANS. GAIN-EXCEPT WALLS & ROOF						REVOLVING DOORS PEOPLEX CMH/PER				
GLASS	m ² X	X				OPEN DOORS DOORSX CMH/DOOR				
CEILING	49.0 m ² X	9.1	X	1.16	518	EXHAUST AIR				
FLOOR	84.0 m ² X	9.1	X	1.59	1216	CRACK m X CMH/m				
PARTITION(1)	135 m ² X	9.1	X	1.51	186	INFILTRATION CMH				
(2) 50.0 m ² X	9.1	X	1.69	776		VENTILATION				
DOOR(IN)	3.6 m ² X	9.1	X	2.15	71	4 PEOPLEX 25 CMH/PER. 100				
INFILTRATION	CMH X deg X		0.29			m ² X CMH/m ²				
INTERNAL HEAT						VENTILATION CMH				
PEOPLE	4 PEOPLEX	41			164	SENSIBLE HEAT FACTOR				
Kw	KWX	X	860		16800	E.S.H.F = 23.754 (ERSH) = 0.99 (13°C)				
LIGHTS	84.0 x 20 WX		1.08		1815	24040 (ERTH)				
APPLIANCES ETC.						DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE	m ² X deg X					APPARATUS DEWPOINT 13°C				
						23.754 (ERSH)				
						24040 (ERTH)				
						8400 CMH				
						(24RM - 13 ADP)(1 - BF) X 0.29				
						Sub TOTAL				
SAFETY FACTOR %						NOTES				
ROOM SENSIBLE HEAT Sub TOTAL						PARTITION(1): 45 x 3.0 = 135				
SUPPLY DUCT	SUPPLY DUCT	FAN			21546	(2): 180 x 3.0 - 3.6 = 50.4				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%		2155	DOOR(IN): 1.8 x 2.0 = 3.6				
BYPASS OUTSIDE AIR 160 CMH X 18.2 deg X 0.1 BF X 0.29						CEILING : 7.0 x 7.0 = 49.0				
						FLOOR : SR				
EFFECTIVE ROOM SENSIBLE HEAT ■						23754				
ROOM LATENT HEAT										
INFILTRATION	CMH X	g/kg X	0.72							
PEOPLE	4 PEOPLEX	49			196					
STEAM		kg/h X	540							
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL						196				
SUPPLY DUCT	LEAKAGE LOSS		10%		20					
BYPASS OUTSIDE AIR 100 CMH X 9.6 g/kg X 0.1 BF X 0.72						70				
EFFECTIVE ROOM LATENT HEAT ■						286				
EFFECTIVE ROOM TOTAL HEAT ■						24040				
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29								
LATENT:	CMH X	g/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE	= %						
HEAT GAIN	LEAK GAIN	H.P	GAIN							
(U.S.R.T) GRAND TOTAL HEAT ■										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET NO. 17

INQUIRING NO.	INQUIRED BY	DATE ORIGINAL	
JOB NAME	ADDRESS	REVISION	
SPACE USED FOR COMPUTER ROOM UNIT NO. 1 (0-3)		SYSTEM	
SIZE	m x m = 127.21 m	x	3.0 m(H) = 381.6 m

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DFF.	FACTOR	Kcal/h		ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3		
				3.00	CORRECTION						
SOLAR GAIN - GLASS						HOURS OF OPERATION Hour (-)					
	m ² X	X				OUTSIDE DESIGN CONDITIONS COB CWB %RH					
	m ² X	X				CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ² X	X				OUTSIDE	42.2	28.6	37		19.0
	m ² X	X				ROOM	24.0		50		9.4
	m ² X	X				DIFFERENCE	18.2	XXX	XXX	XXX	9.6
SOLAR & TRANS GAIN - WALLS & ROOF						BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D					
WALL (SE)	51.5 m ² X	13.1	X	0.56	378	GLASS ORDINARY THCK. ABSORBENT. % DOUBLE					
(SW)	43.0 m ² X	17.9	X	0.56	431	COLOR LIGHT. MEDIUM. DARK.					
	m ² X	X				WEIGHT		kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² X	X				INTERNAL HEAT		W/m ²		m ² /PEOPLE	
ROOF - SUN	m ² X	X				INFILTRATION					
ROOF - SHADED	m ² X	X				SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF						REVOLVING DOORS PEOPLEX CMH/PER					
GLASS	m ² X	X				OPEN DOORS DOORSX CMH/DOOR					
CEILING	22.35 m ² X	9.1	X	1.16	236	EXHAUST AIR					
FLOOR	127.21 m ² X	9.1	X	1.59	1841	CRACK m X CMH/m					
PARTITION	42.35 m ² X	9.1	X	1.51	588	INFILTRATION CMH					
DOOR	3.6 m ² X	9.1	X	2.15	71	VENTILATION					
INFILTRATION	CMHX	deg X	0.29			6 PEOPLEX		25 CMH/PER.		150	
INTERNAL HEAT						VENTILATION CMH					
PEOPLE	6 PEOPLEX	41			246	SENSIBLE HEAT FACTOR					
KW	KWX	X	860		25440	E.S.H.F = 35257 (ERSH) = 0.99 (13°C)					
LIGHTS	127.21 x 20 WX	1.08			2748	35685 (ERTH)					
APPLIANCES ETC.						DEHUMIDIFIED AIR					
						APPARATUS DEWPOINT 13.0 °C					
						35.257 (ERSH)					
CREDIT FOR THERMAL STORAGE	m ² X	deg X				124RM - 13 ADP (1 - BF) X 0.29 = 12.300 CMH					
Sub Total											
SAFETY FACTOR %											
ROOM SENSIBLE HEAT Sub Total						31979					
SUPPLY DUCT	SUPPLY DUCT	FAN									
HEAT GAIN	+ LEAK LOSS	- HP	= 10%		3198						
BYPASS OUTSIDE AIR 150 CMH x 9.6 g/kg BF x 0.29						80					
EFFECTIVE ROOM SENSIBLE HEAT						35257					
ROOM LATENT HEAT											
INFILTRATION	CMHX	g/kg X	0.72								
PEOPLE	6 PEOPLEX	49			294						
STEAM		kg/h X	540								
APPLIANCES ETC.											
VAPOR TRANS.											
Sub Total											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub Total						294					
SUPPLY DUCT LEAKAGE LOSS %						30					
BYPASS OUTSIDE AIR 150 CMH x 9.6 g/kg BF x 0.72						104					
EFFECTIVE ROOM LATENT HEAT						428					
EFFECTIVE ROOM TOTAL HEAT						35685					
OUTSIDE AIR HEAT											
SENSIBLE: CMHX deg X (1 - BF) X 0.29											
LATENT: CMHX g/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT Sub Total											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	- H.P.	+ GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

NOTES
 SR = 10.3 x 8.6 + 5.15 x 7.5 = 127.21
 WALL (SE): 10.3 x 5.0 = 51.5
 (SW): 8.6 x 5.0 = 43.0
 PARTITION: 15.45 x 3.0 - 3.6 = 42.75
 DOOR (IN): 1.8 x 2.0 = 3.6
 CEILING: 7.45 x 3.0 = 22.35
 FLOOR: SR

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET NO. 18

INQUIRING NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR UNITS NO. 1 & NO. 2 CONTROL EQUIPMENT ROOM (M=3) SYSTEM
 SIZE m² x m = 216.33 m² x 2.8 m(H) = 605.73 m³

DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR:	AM PM	PEAK LOAD	AM PM 3
				3:00	CORRECTION				
SOLAR GAIN - GLASS						HOURS OF OPERATION Hour (-)			
m ² X		X				OUTSIDE DESIGN CONDITIONS 'CDB 'CWB %RH			
m ² X		X				CONDITIONS DB °C WB °C %RH DP °C g/kg			
m ² X		X				OUTSIDE 42.2 28.6 37 19.0			
m ² X		X				ROOM 24.0 50 9.4			
m ² X		X				DIFFERENCE 18.2 X X X X X X X X X 9.6			
SOLAR & TRANS GAIN - WALLS & ROOF						BLIND (NON-EXISTENCE OUTSIDE,INSIDE) L.M.D			
WALL (SE) 51.24 m ² X	12.9	X	0.53	351		GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE			
(SW) 26.23 m ² X	15.8	X	0.53	220		COLOR LIGHT, MEDIUM, DARK			
m ² X		X				WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)			
m ² X		X				INTERNAL HEAT: W/m ² m ² /PEOPLE			
ROOF - SUN m ² X		X				INFILTRATION			
ROOF - SHADED m ² X		X				SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF						REVOLVING DOORS PEOPLEX CMH/PER.			
GLASS m ² X		X				OPEN DOORS DOORX CMH/DOOR			
CEILING 216.33 m ² X	9.1	X	2.52	4961		EXHAUST AIR			
FLOOR 216.33 m ² X	9.1	X	2.52	4961		CRACK m X CMH/m			
PARTITION (1) 56.06 m ² X	9.1	X	1.51	771		INFILTRATION CMH			
(2) 38.5 m ² X	9.1	X	1.67	592		VENTILATION			
DOOR (IN) 5.9 m ² X	9.1	X	2.15	106		6 PEOPLEX 25 CMH/PER. 150			
INFILTRATION CMH X deg X 0.29						m ² X CMH/m ²			
INTERNAL HEAT						VENTILATION CMH 150			
PEOPLE 6 PEOPLEX 41				246		SENSIBLE HEAT FACTOR			
KW 30.5 KW X 0.8 X			860	20.984		E.S.H.F = 41.732 (ERSH) = 0.99 (13.0 C)			
LIGHTS 216.33 X 20 WX			1.08	4673		42.160 (ERTH)			
APPLIANCES ETC.						DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE m ² X deg X (-) (-)						APPARATUS DEWPOINT 13.0 °C			
SUB TOTAL						41.732 (ERSH)			
SAFETY FACTOR %						24RM - 13 ADP (1 - BF) X 0.29 = 14600 CMH			
ROOM SENSIBLE HEAT SUB TOTAL						NOTES			
SUPPLY DUCT SUPPLY DUCT FAN				37865		WALL (SE): 16.8 x 3.05 = 51.24			
HEAT GAIN - LEAK LOSS - HP = 10%				3787		(SW): 8.6 x 3.05 = 26.23			
BYPASS OUTSIDE AIR 150 CMH X (82 - 24) X 0.1 BF X 0.29				80		CEILING: SR			
EFFECTIVE ROOM SENSIBLE HEAT				41.732		FLOOR: SR			
ROOM LATENT HEAT						PARTITION (1): 21.95 x 2.8 - 5.4 = 56.06			
INFILTRATION CMH X g/kg X 0.72				294		(2): 13.75 x 2.8 = 38.5			
PEOPLE 6 PEOPLE X 4.9				294		DOOR (IN): (1.8 + 0.9) x 2.0 = 5.4			
STEAM kg/h X 540						SR = 16.8 x 13.75 - 2.85 x 5.15 = 216.33			
APPLIANCES ETC.									
VAPOR TRANS.									
SUB TOTAL									
SAFETY FACTOR %									
ROOM LATENT HEAT SUB TOTAL									
SUPPLY DUCT LEAKAGE LOSS 10%				30					
BYPASS OUTSIDE AIR 150 CMH X 9.6 g/kg X BF X 0.72				104					
EFFECTIVE ROOM LATENT HEAT				428					
EFFECTIVE ROOM TOTAL HEAT				42160					
OUTSIDE AIR HEAT									
SENSIBLE: CMH X deg X (1 - BF) X 0.29									
LATENT: CMH X g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT SUB TOTAL									
RETURN DUCT RETURN DUCT PUMP PIPE									
HEAT GAIN LEAK GAIN H.P. GAIN = %									
(U.S.R.T) GRAND TOTAL HEAT									

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY No. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **FUEL LABORATORY (M-1.)** SYSTEM _____
 SIZE **8.3** m X **7.9** m = **65.57** m² X **2.8** m(H) = **183.60** m³

SHEET No. **19**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h		ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3		
				3:00	CORRECTION						
SOLAR GAIN - GLASS						HOURS OF OPERATION Hour (-)					
(SE)	3.0 m ²	252 x 0.24 / 685 x 0.94 x 0.65		131		OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH					
	m ²	X				CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ²	X				OUTSIDE	42.2	28.6	37		19.0
	m ²	X				ROOM	24.0		50		9.4
	m ²	X				DIFFERENCE	18.2	X X X	X X X	X X X	9.6
SOLAR & TRANS GAIN - WALLS & ROOF						BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.H.D					
WALL (SE)	22.32 m ²	12.9 X	0.53	153		GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
(NE)	24.10 m ²	11.9 X	0.53	152		COLOR LIGHT, MEDIUM, DARK					
	m ²	X				WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)					
	m ²	X				INTERNAL HEAT W/m ² m ² /PEOPLE					
ROOF - SUN	m ²	X				INFILTRATION					
ROOF - SHADED	m ²	X				SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF						REVOLVING DOORS PEOPLE X CMH/PER.					
GLASS	3.0 m ²	18.2 X	5.1	279		OPEN DOORS DOORS X CMH/DOOR					
CEILING	65.57 m ²	9.1 X	2.52	1504		EXHAUST AIR					
FLOOR	65.57 m ²	9.1 X	2.52	1504		CRACK m X CMH/m					
PARTITION (1)	7.98 m ²	9.1 X	1.51	110		INFILTRATION CMH					
(2)	15.12 m ²	9.1 X	1.69	233		VENTILATION					
						4 PEOPLE X 25 CMH/PER. 100					
						1' m X CMH/m ²					
						VENTILATION CMH					
INFILTRATION	CMH X	deg X	0.29			SENSIBLE HEAT FACTOR					
INTERNAL HEAT						E.S.H.F. = $\frac{6.265 \text{ (ERSH)}}{6.605 \text{ (ERTH)}} = 0.95 \text{ (12.5°C)}$					
PEOPLE	4 PEOPLE X			164		DEHUMIDIFIED AIR					
Kw	Kw X	X	860			APPARATUS DEWPOINT 12.6 °C					
LIGHTS	65.57 x 20 W X		1.08	1417		6.265 (ERSH)					
APPLIANCES ETC.						(2 RM. 12.6 ADP) (1 - BF) X 0.29 = 2.200 CMH					
CREDIT FOR THERMAL STORAGE	m ²	deg X	(-)	(-)		NOTES					
Sub TOTAL						GLASS (SE): 1.0 x 1.5 x 2 = 3.0					
SAFETY FACTOR %						WALL (SE): 8.3 x 3.05 = 25.32					
ROOM SENSIBLE HEAT Sub TOTAL						(NE): 7.9 x 3.05 = 24.1					
SUPPLY DUCT	SUPPLY DUCT	FAN				CEILING: SR					
HEAT GAIN	+ LEAK LOSS	+ HP = 10%		565		FLOOR: SR					
BYPASS OUTSIDE AIR 100 CMH x 18.2 deg x 0.1 BF x 0.29 = 53						PARTITION (1) 2.85 x 2.8 = 7.98					
EFFECTIVE ROOM SENSIBLE HEAT 6265						(2) 5.4 x 2.8 = 15.12					
ROOM LATENT HEAT											
INFILTRATION	CMH X	g/kg X	0.72								
PEOPLE	5 PEOPLE X			245							
STEAM	kg/h X			540							
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL						245					
SUPPLY DUCT	LEAKAGE LOSS	%		25							
BYPASS OUTSIDE AIR 100 CMH x 9.6 g/kg x 0.1 BF x 0.72 = 70											
EFFECTIVE ROOM LATENT HEAT 340											
EFFECTIVE ROOM TOTAL HEAT 6605											
OUTSIDE AIR HEAT											
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29									
LATENT:	CMH X	g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	P %								
HEAT GAIN	LEAK GAIN	H.P	GAIN	%							
(U.S.R.T) GRAND TOTAL HEAT 6605											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____ (M-2)
 SPACE USED FOR WATER ANALYSIS & ANALYTICAL INSTRUMENT ROOM SYSTEM
 SIZE m² x m = 134.75 m² x 2.8 m(H) = 377.3 m³

SHEET No. - 20
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h	
				3100	CORRECTION
SOLAR GAIN — GLASS					
(SE)	3.0 m ²	252 x 0.24 x 0.65	0.94 x 0.65	131	
	m ² x	X			
	m ² x	X			
	m ² x	X			
	m ² x	X			
SOLAR & TRANS GAIN—WALLS & ROOF					
WALL (SE)	23.23 m ²	12.9	X 0.53	159	
	m ² x	X			
	m ² x	X			
	m ² x	X			
ROOF—SUN	m ² x	X			
ROOF—SHADED	m ² x	X			
TRANS. GAIN—EXCEPT WALLS & ROOF					
GLASS	3.0 m ²	18.2	X 5.1	279	
CEILING	134.75 m ²	9.1	X 2.5 ²	3090	
FLOOR	134.75 m ²	9.1	X 2.5 ²	3090	
PARTITION (1)	19.8 m ²	9.1	X 1.51	688	
	(2) 20.88 m ²	9.1	X 1.69	322	
	(3) 38.5 m ²	9.1	X 1.69	592	
DOOR (IN)	7.2 m ²	9.1	X 2.15	191	
INTERNAL HEAT					
PEOPLE	7 PEOPLE	41		287	
KW	Kw x	X	860		
LIGHTS	134.75 x 20 W x		1.08	2911	
APPLIANCES ETC.					
CREDIT FOR THERMAL STORAGE m ² x deg x (-) (-)					
Sub TOTAL					
SAFETY FACTOR				%	
ROOM SENSIBLE HEAT Sub TOTAL				11690	
SUPPLY DUCT	SUPPLY DUCT	FAN			
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	1169	
BYPASS OUTSIDE AIR 210 CMH x 18.2 deg x 0.1 BF x 0.29				111	
EFFECTIVE ROOM SENSIBLE HEAT				12970	
ROOM LATENT HEAT					
INFILTRATION	CMH x	g/kg x	0.72		
PEOPLE	7 PEOPLE	49		343	
STEAM		kg/h x	540		
APPLIANCES ETC.					
VAPOR TRANS.					
Sub TOTAL					
SAFETY FACTOR				%	
ROOM LATENT HEAT Sub TOTAL				343	
SUPPLY DUCT LEAKAGE LOSS	10 %			35	
BYPASS OUTSIDE AIR 210 CMH x 9.6 g/kg x 0.1 BF x 0.72				146	
EFFECTIVE ROOM LATENT HEAT				524	
EFFECTIVE ROOM TOTAL HEAT				13494	
OUTSIDE AIR HEAT					
SENSIBLE:	CMH x	deg x (1 - BF) x 0.29			
LATENT:	CMH x	g/kg x (1 - BF) x 0.72			
GRAND TOTAL HEAT Sub TOTAL					
RETURN DUCT	RETURN DUCT	PUMP PIPE	= %		
HEAT GAIN	+ LEAK GAIN	- H.P	+ GAIN		
(U.S.R.T) GRAND TOTAL HEAT					

ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM3
HOURS OF OPERATION	Hour (-)		
OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
CONDITIONS	DB °C	WB °C	DP °C
OUTSIDE	42.2	28.6	37
ROOM	24.0	50	94
DIFFERENCE	18.2	X X X	X X X
BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D		
GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
COLOR	LIGHT, MEDIUM, DARK.		
WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)	
INTERNAL HEAT	W m ²	m ² /PEOPLE	
INFILTRATION			
SWINGING			
REVOLVING DOORS	PEOPLE x CMH/PER.		
OPEN DOORS	DOORS x CMH/DOOR		
EXHAUST AIR			
CRACK	m x	CMH/m	
INFILTRATION	CMH		
VENTILATION			
7 PEOPLE x	25 CMH/PER.	175	
m ² x	CMH/m ²		
VENTILATION	CMH	210	
SENSIBLE HEAT FACTOR			
E.S.H.F. =	12970 (ERSH)	= 0.96 (12.6°C)	
	13494 (ERTH)		
DEHUMIDIFIED AIR			
APPARATUS DEWPOINT	12.6 °C		
	12.970 (ERSH)		
(24RM - 12.6ADP) (1 - BF) x 0.29	= 4400 CMH		

NOTES
 SR = 13.15 x 8.6 + 5.5 x 3.0 = 134.75
 GLASS (SE): 1.0 x 1.5 x 2 = 3.0
 WALL (SE): 8.6 x 3.05 - 3.0 = 23.23
 CEILING: SR
 FLOOR: SR
 PARTITION (1): 19.8 x 2.8 - 5.4 = 50.04
 (2): 8.1 x 2.8 - 1.8 = 20.88
 (3): 13.75 x 2.8 = 38.5
 DOOR (IN): 1.8 x 2.0 + 0.9 x 2.0 x 2 = 7.2

5. EQUIPMENT LOAD

5-1 AHU-1 x 2ea (100% STANBY)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE	42.2°C	28.6°C	22.0 kcal/kg
R.S.H	59.011	kcal/h	
S.H.F	0.99		
DEHUMIDIFIED AIR		20.700 m ³ /h	
OUT AIR		250 m ³ /h	
RETURN AIR		20.450	

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{250 \text{ m}^3/\text{h} \times 22.0 \text{ kcal/kg} + 20450 \text{ m}^3/\text{h} \times 11.5 \text{ kcal/kg}}{20700 \text{ m}^3/\text{h}}$$

$$= 11.6 \text{ kcal/kg}$$

$$\therefore \left[20700 \text{ m}^3/\text{h} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (11.6 - 8.7) \frac{\text{kcal}}{\text{kg}} \right] \times (1 - 0.1) \times 1.05$$

$$= 68.000 \text{ kcal/h}$$

◎ PEAK LOAD (PM 3:00)

$$\text{E.R.T.H} : 59.725 \text{ kcal/h}$$

$$\text{OUTSIDE AIR HEAT} : 250 \text{ m}^3/\text{h} \times 18.7 \times (1 - 0.1) \times 0.29 = 1.188 \text{ kcal/h} \quad \textcircled{2}$$

$$250 \text{ m}^3/\text{h} \times 9.6 \times (1 - 0.1) \times 0.72 = 1.556 \text{ kcal/h} \quad \textcircled{3}$$

$$\text{TOTAL} = \textcircled{1} + \textcircled{2} + \textcircled{3}$$

$$= (59.725 + 1.188 + 1.556) \times 1.05 = 66.000 \text{ kcal/h}$$

266

PSYCHROMETRIC CHART

ZONE NAME: COMPUTER ROOM (AC-1)

SA : 20.700 CMH


OA : 350 CMH

RA : 20.450 CMH

MIX POINT = $\frac{250 \times 42.2 + 20450 \times 24.9}{20700}$

= 24.7

SHE = 0.99



5 - 2 AHU - 2 $\times 2 ea$ (50% $\times 2$)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	: 24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE	: 42.2°C	28.6°C	22.0 kcal/kg
R.S.H	: 67.893	kcal/h / 2 = 33.947 kcal/h	
S.H.F	: 0.9		
DEHUMIDIFIED AIR	: 23000 m ³ /h / 2 = 11500 m ³ /h		
OUT AIR	: 1.650 m ³ /h / 2 = 825		
RETURN AIR	: 21.350 m ³ /h / 2 = 10675		

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{825 \text{ m}^3/\text{h} \times 22.0 \text{ kcal/kg} + 10675 \text{ m}^3/\text{h} \times 11.5 \text{ kcal/kg}}{11500}$$

$$= 12.3 \text{ kcal/kg}$$

$$\therefore [11500 \text{ m}^3/\text{h} \times 1.2 \text{ kg/m}^3 \times (12.3 - 8.6) \text{ kcal/kg} \times (1 - 0.1) \times 1.05]$$

$$= 48.000 \text{ kcal/h}$$

⊙ PEAK LOAD (PM 3:00)

$$\text{E.R.T.H} : 70452 \text{ kcal/h} \dots \text{①}$$

$$\text{OUTSIDE AIR HEAT} : 1650 \text{ m}^3/\text{h} \times 18.2 \times (1 - 0.1) \times 0.29 = 7.838 \text{ kcal/h} \dots \text{②}$$

$$1650 \text{ m}^3/\text{h} \times 9.6 \times (1 - 0.1) \times 0.72 = 10.265 \text{ kcal/h} \dots \text{③}$$

$$\text{TOTAL} = \text{①} + \text{②} + \text{③}$$

$$= (70452 + 7838 + 10265) \times 1.05 / 2 = 47.000 \text{ kcal/h}$$

PSYCHROMETRIC CHART

ZONE NAME: CENTRAL CONTROL ROOM etc
(AC-2 x 2)


SA: 11,500 CMH

OA: 825 CMH

RA: 10,675 CMH

MIX POINT = $\frac{825 \times 42.2 + 10,675 \times 24.0}{11,500} = 25.3$

SHT = 0.97



995

5 - 3 AHU - 3 x 2 ea (50% x 2)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM :	24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE :	42.2°C	28.6°C	22.0 kcal/kg
R.S.H :	41.733	kcal/h / 2 = 20.867 kcal/h	
S.H.F :	0.99		
DEHUMIDIFIED AIR :	14.600 m ³ /h	/ 2 = 7300 m ³ /h	
OUT AIR :	150 m ³ /h	/ 2 = 75	
RETURN AIR :	14.450 m ³ /h	/ 2 = 7.225	

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{75 \frac{\text{m}^3}{\text{h}} \times 22.0 \frac{\text{kcal}}{\text{kg}} + 7.225 \frac{\text{m}^3}{\text{h}} \times 11.5 \frac{\text{kcal}}{\text{kg}}}{7.300} = 11.6 \text{ kcal/kg}$$

$$\therefore \left[7.300 \frac{\text{m}^3}{\text{h}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (11.6 - 8.7) \frac{\text{kcal}}{\text{kg}} \times (1 - 0.1) \times 1.05 \right] = 24.000 \text{ kcal/h}$$

⊙ PEAK LOAD (PM 3:00)

E.R.T.H = 42.160 kcal/h ... ①

OUTSIDE AIR HEAT : $150 \frac{\text{m}^3}{\text{h}} \times 18.2 \times (1 - 0.1) \times 0.29 = 713 \text{ kcal/h} \dots \text{②}$
 $150 \frac{\text{m}^3}{\text{h}} \times 9.6 \times (1 - 0.1) \times 0.72 = 934 \text{ kcal/h} \dots \text{③}$

TOTAL = ① + ② + ③
 = (42.160 + 713 + 934) x 1.05 / 2 = 23.000 kcal/h

996


PSYCHROMETRIC CHART

ZONE NAME: UNIT NO. 1 1/2 NO. 2 CONTROL EQUIPMENT ROOM (AC-3x2)

SA : 7.300 CMH
 OA : 75 CMH
 RA : 7.225 CMH

MIX POINT = $75 \times 42.2 + 7.225 \times 24.2 = 24.2$
 7.300

S.H.F. = 0.9.9



5 - 4 AHU - 4 x 2 ea (50% x 2)

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM :	24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE :	42.2°C	28.6°C	22.0 kcal/kg
R.S.H :	19.235	kcal/h/2 = 9.618 kcal/h	
S.H.F :	0.96		
DEHUMIDIFIED AIR :	6.600 m ³ /h / 2 = 3.300		
OUT AIR :	310 m ³ /h / 2 = 155		
RETURN AIR :	6.290 m ³ /h / 2 = 3.145		

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{155 \text{ m}^3/\text{h} \times 22.0 \text{ kcal/kg} + 3.145 \text{ m}^3/\text{h} \times 11.5 \text{ kcal/kg}}{3.300} = 12.0 \text{ kcal/kg}$$

$$\therefore \left[3.300 \text{ m}^3/\text{h} \times 1.2 \text{ kg/m}^3 \times (12.0 - 8.5) \text{ kcal/kg} \right] \times (1 - 0.1) \times 1.05 = 13.000 \text{ kcal/h}$$

⊙ PEAK LOAD (PM 3:00)

$$\text{E.R.T.H} = 20.069 \text{ kcal/h} \dots \text{①}$$

$$\text{OUTSIDE AIR HEAT} : \begin{aligned} & 310 \text{ m}^3/\text{h} \times 18.2 \times (1 - 0.1) \times 0.29 = 1.473 \dots \text{②} \\ & 310 \text{ m}^3/\text{h} \times 9.6 \times (1 - 0.1) \times 0.72 = 1.929 \dots \text{③} \end{aligned}$$

$$\text{TOTAL} = \text{①} + \text{②} + \text{③} = (20.069 + 1.473 + 1.929) \times 1.05 / 2 = 13.000 \text{ kcal/h}$$

866

PSYCHROMETRIC CHART

FUEL LABORATORY
ZONE NAME : WATER ANALYSIS ANALYTICAL INSTRUMENT RM
(AC-4)


SA: 3.300 CMH

OA: 155 CMH

RA: 3,145 CMH

MIX POINT: $155 \times 42 + 3,145 \times 74 = 24,9$
3,300

SHE = 0.96



24.9

17.6

12.6

7.2

17.6

7.2

177

6. SELECTION OF COOLING EQUIPMENT

6-1. TOTAL LOAD SUMMARY

AHU-1	66.000 Kcal/H/2 (REHEAT 20.000 Kcal/H)
AHU-2	94 000 Kcal/H/2
AHU-3	46 000 Kcal/H/2
AHU-4	26.000 Kcal/H/2

TOTAL 116.000 Kcal/H RT-2 (50% x 2 ea)

CAPACITY , CHILLED WATER .

RT-1. FOR AHU-1

$$66.000 \text{ Kcal/H} / 3024 = 22 \text{ RT}$$

$$66.000 \text{ Kcal/H} / 5 \times 60 = 220 \text{ l/min}$$

RT-2. FOR AHU - 1 ~ 4.

$$116.000 \text{ Kcal/H} / 3024 = 39 \text{ RT}$$

$$116.000 \text{ Kcal/H} / 5 \times 60 = 387 \text{ l/min}$$

980

6-2 EQUIPMENT

(1) AIR COOLED
PACKAGED LIQUID CHILLER UNIT

R-1

COOLING LOAD CAPACITY : 66,000 Kcal/Hr (22 RT)
 CHILLED WATER
 WATER TEMP. : IN 12 - OUT 7 °C
 WATER FLOW RATE : 220 lit/min
 WATER FRICTION LOSS : 0.8 m (COIL SECTION)
 CONNECTION PIPE DIA. : ϕ 65 (GAS STEEL PIPE)

REFRIGERANT TYPE : R- 22

ELECTRIC POWER(OUTPUT)

COMPRESSOR : 30 Kw (3 ϕ - V)
 FAN : 0.75 x 3 Kw (-do-)
 : Kw (-do-)
 : Kw (-do-)

DIMENSION : W 3,300 x D 1,200 x H 2,000 (mm)
 WEIGHT : Kg (OPERATING 1,810 Kg)
 Mfr. MODEL NO : 30AE040 (or equal)
 (CARRIER)

NOTE : TON IS REFGIGATION(U.S) IS 3,024 Kcal/Hr.

AIR COOLED

PACKAGED LIQUID CHILLER UNIT

R-2 x 2 ea

COOLING LOAD CAPACITY : 116,000 Kcal/Hr (39 RT)

CHILLED WATER

WATER TEMP. : IN 12 - OUT 7 °C

WATER FLOW RATE : 387 lit/min

WATER FRICTION LOSS : 2.1 m (COIL SECTION)

CONNECTION PIPE DIA. : ϕ 80 (GAS STEEL PIPE)

REFRIGERANT TYPE : R-22

ELECTRIC POWER(OUTPUT)

COMPRESSOR : 30 x 2 Kw (3 ϕ - 380 V)

FAN : 0.75 x 6 Kw (-do-)

: Kw (-do-)

: Kw (-do-)

DIMENSION : W 3,690 x D 2,000 x H 2,300 (mm)

WEIGHT : Kg (OPERATING 2,810 Kg)

Mfr. MODEL NO : 30AE080 (or equal)
(CARRIER)

NOTE : TON IS REFGIGATION(U.S) IS 3,024 Kcal/Hr.

982

(2) PUMP

PUMP / VOLUTE CWP - 1 x 20A

WATER RATE FLOW	:	220	lit/min
WATER FLOW PIPE DIA.	:	φ 65	
WATER FLOW SPEED	:	1.1	m/sec
PIPE FRICTION LOSS (R)	:	40	mmAq/m
PIPE EQUIVALENT LENGTH (Le)			
STRAIGHT PIPE	:	150	m
ELBOW	:	ea x	m/ea = 150 m
GATE VALVE	:	ea x	m/ea = x m
CHECK VALVE	:	ea x	m/ea = 0.5 m
OTHERS	:		= 75 m
TOTAL (Le)		225	m
PIPE HEAD LOSS (*1)	:	(Le) 225 m x (R) 0.04	= 9 m
LIFT HEAD (*2)	:	5	m
EQUIPMENT or OTHERS HEAD LOSS			
1. R-1 Coil	:	0.8	m
2. AHV coil	:	2	m
3. Reheater	:	2	m
4.	:		m
TOTAL (*3)		4.8	m
TOTAL PIPE HEAD LOSS : (*1)+(*2)+(*3) = 18.8 m x 10%			
= 20 m			

SELECTION OF PUMP

TYPE	:	<u>VOLUTE</u> / TURBINE / IN_LINE
DIA.	:	φ 50x40
WATER FLOW RATE	:	220 lit/min
POWER OUTPUT	:	2.2 Kw (φ 3 - 380 V)
NUMBER	:	2 ea
WEIGHT	:	81 Kg
Mfr. MODEL NO.	:	50x40FS4J52.7 or equal (EBARA)

NOTE :

PES

PUMP / VOLUTE CWP-2 X2ea

WATER RATE FLOW : 387 lit/min
 WATER FLOW PIPE DIA. : ϕ 80
 WATER FLOW SPEED : 1.2 m/sec
 PIPE FRICTION LOSS(R) : 40 mmAq/m
 PIPE EQUIVALENT LENGTH (Le)

STRAIGHT PIPE	:	160	m	
ELBOW	:	ea x	m/ea =	} 160 x 0.5 = 80
GATE VALVE	:	ea x	m/ea =	
CHECK VALVE	:	ea x	m/ea =	
OTHERS	:		=	

TOTAL (Le) 240 m

PIPE HEAD LOSS(*1) : (Le) 240 m x (R) 0.04 = 9.6 m

LIFT HEAD(*2) : 5 m

EQUIPMENT or OTHERS HEAD LOSS

1. R-1 Coil	:	2.1	m
2. AHU Coil	:	2	m
3.	:		m
4.	:		m

TOTAL (*3) 4.1 m

TOTAL PIPE HEAD LOSS : (*1)+(*2)+(*3) = 18.7 m x 10%
 = 20 m

SELECTION OF PUMP

TYPE	:	<u>VOLUTE</u> / TURBINE / IN_LINE
DIA.	:	ϕ 65x50
WATER FLOW RATE	:	387 lit/min
POWER OUTPUT	:	3.7 Kw (ϕ 3 - 380 V)
NUMBER	:	2 ea
WEIGHT	:	130 Kg
Mfr. MODEL NO.	:	65x50FS4J53.7 or equal (CEBARA)

NOTE :


788

* EQUIVALENT LENGTH OF PIPE FITTINGS & VALVES

DIA	90°ELBOW	90°TEE	GATE VALVE	GLOVE VALVE	CHECK VALVE
20	0.75	1.2	0.15	6.0	1.6
25	0.9	1.5	0.18	7.5	2.0
32	1.2	1.8	0.24	10.5	2.5
40	1.5	2.1	0.3	13.5	3.1
50	2.1	3.0	0.39	16.5	4.0
65	2.4	3.6	0.48	19.5	4.6
80	3.0	4.5	0.63	24.0	5.7
100	4.2	6.3	0.81	37.5	7.6
125	5.1	7.5	0.99	42.0	10.0
150	6.0	9.0	1.20	49.5	12.0
200	6.5	14.0	1.40	70.0	15.0
250	8.0	20.0	1.70	90.0	19.0

* FRICTIONAL RESISTANCE CHART OF PIPING

(at GALVANIZED STEEL PIPE)



985

(3) AIR HANDLING UNIT

AHU-1 x 2 ea (one for stand by)
 AIR FLOW RATE : 20.700 m³/H (345 m³/min)
 COOLING LOAD : 66.000 Kcal/H (REHEAT LOAD : 20.000 Kcal/H)
 FAN MOTOR : 11 kW
 EXTERNAL STATIC PRES.: 70 mmAq
 AIR INLET : 24.2°C DB, 17.3°C WB, 11.6 Kcal/Kg
 OUTLET : 14.1°C DB, 13.4°C WB, 9.0 Kcal/Kg
 CHILLED WATER : 220 lit/min (66.000 / 5 x 60)

TYPE	: VERTICAL
AIR FLOW RATE	: 20.700 m ³ /H
COOLING COIL	: 1 x 26
FAN MOTOR	: 11 Kw, REHEATER : 24 kW
POWER	: Ø3- 380 ^V , 50Hz
TAPPING SIZE	: CHILLED WATER 65x2, DRAIN 20A
DIMENSION	: 3000 x 845 x 1.930 ^H (mm)
WEIGHT	: 1.660 Kg

MODEL : 39 ACT II (CARRIER)

286

AIR HANDLING UNIT

AHU-2 x 2 ea

- AIR FLOW RATE : 11,500 m³/H (192 m³/min)
- COOLING LOAD : 47,000 Kcal/H
- FAN MOTOR : 3.7 KW
- EXTERNAL STATIC PRES.: 60 mmAq
- AIR INLET : 25.3°C DB , 17.3°C WB , 12.3 Kcal/Kg
- OUTLET : 13.9°C DB , 13.4°C WB , 9.0 Kcal/Kg
- CHILLED WATER : 157 lit/min (47,000/5x60)

TYPE	: VERTICAL
AIR FLOW RATE	: 11,500 m ³ /H
COOLING COIL	: 1x22
FAN MOTOR	: 3.7 Kw
POWER	: Ø3-380 ^V , 50Hz
TAPPING SIZE	: CHILLED WATER 40 Ax2, DRAIN 20 A
DIMENSION	: 2090 x 980 x 1790 ^H (mm)
WEIGHT	: 1.060 Kg

MODEL : 39ACT 9 (CARRIER)

AIR HANDLING UNIT

AHU-3 x 2 ea

AIR FLOW RATE : 7.300 m³/H (122 m³/min)
 COOLING LOAD : 23.000 Kcal/H
 FAN MOTOR : 2.2 KW
 EXTERNAL STATIC PRES.: 60 mmHg
 AIR INLET : 24.2°C DB, 17.2°C WB, 11.6 Kcal/Kg
 OUTLET : 14.1°C DB, 13.4°C WB, 9.0 Kcal/Kg
 CHILLED WATER : 77 lit/min (23.000/5x60)

TYPE	:	VERTICAL
AIR FLOW RATE	:	7.300 m ³ /H
COOLING COIL	:	1 x 22
FAN MOTOR	:	2.2 KW
POWER	:	Ø3-380 ^V , 50Hz
TAPPING SIZE	:	CHILLED WATER 40 Ax2, DRAIN 20 A
DIMENSION	:	1.580 x 780 x 1.790 ^H (mm)
WEIGHT	:	810 Kg

MODEL : 39 ACJ 8 (CARRIER)

AIR HANDLING UNIT

AHU - 4 x 2ed

AIR FLOW RATE : 3.300 m³/H (55 m³/min)
 COOLING LOAD : 13.000 Kcal/H.
 FAN MOTOR : 1.5 kW
 EXTERNAL STATIC PRES.: 60 mmAq
 AIR INLET : 24.9°C DB, 17.7°C WB, 12.0 Kcal/Kg
 OUTLET : 13.8°C DB, 13.1°C WB, 8.8 Kcal/Kg
 CHILLED WATER : 44 lit/min (13.000 / 5x60)

TYPE	: VERTICAL
AIR FLOW RATE	: 3.300 m ³ /H
COOLING COIL	: 1 x 16
FAN MOTOR	: 1.5 Kw
POWER	: Ø3-380 ^V , 50Hz
TAPPING SIZE	: CHILLED WATER 32 Ax2, DRAIN 20 A
DIMENSION	: 1.125 x 670 x 1.550 ^H (mm)
WEIGHT	: 360 Kg

MODEL : 39ACTJ 6 (CARRIER)

7.7 換 気

7. VENTILATION SYSTEM

7-1 ESTIMATE OF VENTILATION AIR VOLUME

FLOOR	ROOM NAME	AREA (m ²)	VOL. (m ³)	AIR CHANGE (T/Hr)	AIR FLOW (m ³ /Hr)	EXHAUST AIR (m ³ /Hr)	SUPPLY AIR (m ³ /Hr)	
MEZZANINE FLOOR	STORAGE ROOM	146	40.9	5	205	210 *	-	(III) VF-4
	BATTERY ROOM	144.5	404.6	10 (35 m ³ /m ²)	4046	-		(I)
					5058 *	5060	5060	0AG EF-3
	SUB TOTAL					5.270	5060	
CABLE TREATMENT FLOOR	CABLE TREATMENT AREA	628.9	1509	10	15090	15100	15100	OF-1 (I) EF-1
	SUB TOTAL					15.100		
OPERATING FLOOR	KITCHEN	5.4	16.2	10	162	170		(III) VF-5
	LAVATORY	19.1	57.3	10	573	600 *	650	(III) VF-2
	JAN	2.3	6.9	5	35	50 *		(III) VF-7
	SUB TOTAL					820		
FORTH FLOOR	LOCKER ROOM	22.4	62.7	10	627	630 *	1000	(II) VF-1
	KITCHEN	5.3	14.8	10	148	150		(III) VF-6
	JAN	2.3	6.4	5	32	50 *	(III) VF-7	
	LAVATORY	11.5	32.2	10	322	320 *	(III) VF-3	
	AIR CONDITIONING MACHINE ROOM	310	1500	10	15000	15000		(III) EF-2
	SUB TOTAL					16.150		
ROOF	TURBINE ROOM	$\frac{200.000 \text{ kW} \times 0.003 \times 860 \text{ kcal/kWh}}{0.29 \times 5}$		7	$\frac{355.862}{356.000 / 16} = 22.300 / \text{EA}$			(III) RF-1
		$VR = 220 \times 111.6 \times 155 + 110.9 \times 111.6 \times 5 = 43,435 \text{ m}^3$			305.450			

ppd

7-2 SELECTION OF VENTILATION EQUIPMENT

V - 1

MEZZANINE FLOOR STORAGE ROOM

MACHINE NO	VF-4
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 210 m ³ /Hr x 8mmA8
FAN MOTOR	: 35 or 35 w
POWER	: 1φ 220v / 3φ (50/60 Hz)
SIZE	: 308 x 308 x 226 ^H (mm)
ACCESSORY	: 150 ^φ VENT CAP

V - 2

MEZZANINE FLOOR BATTERY ROOM

MACHINE NO	EF-2 SS # 2 1/2
TYPE OF VENTILATOR	: CENTRIFUGAL MULTI-BANE x 1 ea
AIR FLOW RATE	: 5060 m ³ /Hr x 25mmA8
FAN MOTOR	: 1.5 KW or w
POWER	: 1φ 220v / 3φ 380v (50/60 Hz)
SIZE	: 960 ^L x 360 ^W x 805 ^H (mm)
ACCESSORY	:

V - 3

CABLE TREATMENT AREA

MACHINE NO	EF-1 (OF-1) SS #4
TYPE OF VENTILATOR	: DITTO x 1/ea
AIR FLOW RATE	: 15100 m ³ /Hr x 25mmA8
FAN MOTOR	: 3.7 KW or w
POWER	: 1φ 220v / 3φ 380v (50/60 Hz)
SIZE	: 1540 ^L x 545 ^W x 1.140 ^H (mm)
ACCESSORY	:

V - 4

OPERATING FLOOR : KITCHEN

MACHINE NO	VF-5
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 170 m ³ /Hr x 8 mm ²
FAN MOTOR	: ## or 35 w
POWER	: 1φ 220v / 3φ (50/60 Hz)
SIZE	: 308 x 308 x 226 ^H (mm)
ACCESSORY	: 150 ^φ VENT CAP

V - 5

OPERATING FLOOR LAUATORY

MACHINE NO	VF-2
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 600 m ³ /Hr x 8 mm ²
FAN MOTOR	: ## or 95 w
POWER	: 1φ 220v / 3φ (50/60 Hz)
SIZE	: 464 x 464 x 278 ^H (mm)
ACCESSORY	: 150 ^φ VENT CAP

V - 6

OPERATING FLOOR JAN (= FORTH FLOOR JAN)

MACHINE NO	VF-7
TYPE OF VENTILATOR	: CEILING x 2 ea
AIR FLOW RATE	: 50 m ³ /Hr x 6 mm ²
FAN MOTOR	: ## or 18 w
POWER	: 1φ 220v / 3φ (50/60 Hz)
SIZE	: 223 x 223 x 165 ^H (mm)
ACCESSORY	: 100 ^φ VENT CAP

pp2

V - 7

FORTH FLOOR LOCKER ROOM

MACHINE NO VF - 1	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 630 m ³ /Hr x 8 mm ²
FAN MOTOR	: ## or 95 w
POWER	: 1φ 220v / 3φ (50/60 Hz)
SIZE	: 464 x 464 x 278 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

V - 8

FORTH FLOOR KITCHEN

MACHINE NO VF - 6	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 150 m ³ /Hr x 8 mm ²
FAN MOTOR	: ## or 35 w
POWER	: 1φ 220v / 3φ (50/60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

V - 9

FORTH FLOOR LAVATORY

MACHINE NO VF - 3	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 320 m ³ /Hr x 7 mm ²
FAN MOTOR	: ## or 46 w
POWER	: 1φ 220v / 3φ (50/60 Hz)
SIZE	: 345 x 345 x 243 ^H (mm)
ACCESSORY	: 150 ⁺ VENT CAP

773

V - 10

FORTH FLOOR AIR CONDITIONING MACHINE ROOM

MACHINE NO	EF-3
TYPE OF VENTILATOR	: AXIAL. x 1 ea
AIR FLOW RATE	: 15.000 m ³ /Hr x 15 mmHg
FAN MOTOR	: 2.2 KW or w
POWER	: 1φ 220v / 3φ 380v (50/60 Hz)
SIZE	: x x (mm)
ACCESSORY	:

V - 11

ROOF TURBINE ROOM

MACHINE NO	RF-1
TYPE OF VENTILATOR	: ROOF VENTILATOR x 16 ea
AIR FLOW RATE	: 22.300 m ³ /Hr x 10 mmHg (41200)
FAN MOTOR	: 3.7 KW or w
POWER	: 1φ 220v / 3φ 380v (50/60 Hz)
SIZE	: 2.250 x 2.250 x 1520H. (mm)
ACCESSORY	:

V - 1

MACHINE NO	
TYPE OF VENTILATOR	: x ea
AIR FLOW RATE	: m ³ /Hr
FAN MOTOR	: KW or w
POWER	: 1φ 220v / 3φ v (50/60 Hz)
SIZE	: x x (mm)
ACCESSORY	:

994

V - 12.

FORTH FLOOR: AIR CONDITIONING MACHINE ROOM

MACHINE NO EF-4	< FOR AHU-1 >
TYPE OF VENTILATOR	: AXIAL x 1 ea
AIR FLOW RATE	: 250 m ³ /Hr x 10 ^{mmA8}
FAN MOTOR	: 11 or 80 w
POWER	: 1ø 220v / 3ø (50/60 Hz)
SIZE	: 375 ^ø x 320 ^L x (mm)
ACCESSORY	:

V - 13


MACHINE NO EF-5	< FOR AHU-3 >
TYPE OF VENTILATOR	: AXIAL x 1 ea
AIR FLOW RATE	: 150 m ³ /Hr x 10 ^{mmA8}
FAN MOTOR	: 11 or 12 w
POWER	: 1ø 220v / 3ø (50/60 Hz)
SIZE	: 250 ^ø x 220 ^L x 274 ^H (mm)
ACCESSORY	:

V - 14

MACHINE NO EF-6	< FOR AHU-4 >
TYPE OF VENTILATOR	: AXIAL x 1 ea
AIR FLOW RATE	: 100 m ³ /Hr x 7 ^{mmA8}
FAN MOTOR	: 11 or 12 w
POWER	: 1ø 220v / 3ø (50/60 Hz)
SIZE	: 250 ^ø x 220 ^L x 274 ^H (mm)
ACCESSORY	:

995

AR-8. Calculation Sheets For Air Conditioning and Ventilation System
For Administration Building



C O N T E N T S

1.	DESIGN CRITERIA	-----	1
2.	DATA	-----	2
3.	HEAT TRANSMISSION	-----	4
4.	ROOM LOAD SUMMRY	-----	6
5.	EQUIPMENT LOAD	-----	43
6.	SELECTION OF COOLING EQUIPMENT	-----	47
7.	VENTILATION	-----	49

156

1. DESIGN CRITERIA

1 - 1 DESIGN CONDITION

1) For air conditioning system

(a) Outdoor air

Summer : 42.2°C DB, 28.6°C WB, 37%RH

(b) Room

Summer : 24°C±2°C DB, 50%RH

Winter : Not more than the condition in summer

2) Minimum ventilation air vol.

For Control Room

25 m³/Hr person

3) Lighting

20 W/m²

4) People

Refer to "Cooling and dehumidifying estimate sheets"

5) Location

25.4°(N), 68.3°(E)

885

2. DATA

Data used for load estimation is based on Carrier,s Design Manual of the newest condition.

2- 1 Outdoor air

1) Dry Bulb

Time	8	9	10	11	12	13	14	15	16	17	18
Dry Bulb											
°C	28.2	30.3	32.8	35.7	38.4	40.4	41.7	42.2	41.7	40.5	38.7

2) HUmidity Ratio

Time	8	9	10	11	12	13	14	15	16	17	18
Humidity Ratio											
g/Kg	19.1	19.0	19.0	19.2	18.9	19.0	18.8	19.0	18.8	18.9	18.8

2.- 2 Solar heat gain

1) Peak solar heat gain thru ordinary glass

EXPOSURE	NL	NE	SE	SW	NW	HORIZONTAL	SHADE
HEAT							
Kcal/h m ²		366	252	252	366	674	47

2) Solar gain correction factors

- for steel sash : 1/0.85
- for dew point : 0.94

166

3) Load storage factors , solar heat gain thru ordinary glass

EXPOSURE	TIME	8	9	10	11	12	13	14	15	16	17	18
NE		0.57	0.46	0.30	0.24	0.20	0.19	0.17	0.16	0.15	0.13	0.11
SE		0.47	0.61	0.67	0.65	0.57	0.44	0.29	0.24	0.21	0.18	0.15
SW		0.08	0.08	0.10	0.24	0.40	0.55	0.66	0.70	0.64	0.50	0.26
NW		0.09	0.09	0.10	0.10	0.10	0.10	0.16	0.34	0.52	0.65	0.64

NOTE : Venetian blind to be located on the inside of glass.
 (Overall factor is 0.65)

2 - 3 Equivalent temperature difference

1) For wall

EXPOSURE	TIME	8	9	10	11	12	13	14	15	16	17	18
NE		4.6	7.9	16.8	16.0	15.3	13.3	11.3	11.9	12.6	13.0	13.5
SE		5.4	8.6	11.1	12.4	13.6	13.8	13.9	12.9	12.4	11.8	11.5
SW		2.6	3.1	3.7	5.0	5.9	9.8	12.1	15.8	18.6	19.2	19.5
NW		3.7	4.5	5.3	6.6	7.9	10.1	11.3	13.5	15.4	19.5	23.2




These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 200Kg/m².

2) For roof

For roof	TIME	8	9	10	11	12	13	14	15	16	17	18
°C		10.3	10.2	10.8	12.4	14.9	18.0	21.2	24.0	26.2	27.8	28.5





These figures are basing on medium color, outside air temperature at 42.2°C DB, inside air temperature at 24°C DB daily range of 16.7°C and specific weight of wall 300Kg/m².

02/1

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE (m ² H°C/Kcal)	AIR FILM (m ² H°C/Kcal)	K-Value (Kcal/m ² H°C)
WALL 				$\gamma_0 = 0.05$	
	① CEMENT PLASTER	10	0.016		
	② BRICK	150	0.283		
	③ CEMENT PLASTER	10	0.016		
				$\gamma_i = 0.133$ (0.498)	2.008 \Rightarrow 2.1
PARTITION 1. DITTO				$\gamma_i = 0.133$	
	① CEMENT PLASTER	10	0.016		
	② BRICK	150	0.283		
	③ CEMENT PLASTER	10	0.016		
				$\gamma_i = 0.133$ (0.581)	1.722 \Rightarrow 1.8
PARTITION 2 				$\gamma_i = 0.133$	
	① CEMENT PLASTER	10	0.016		
	② CONCRETE	150	0.107		
	③ CEMENT PLASTER	10	0.016		
				$\gamma_i = 0.133$ (0.405)	2.47 \Rightarrow 2.5
DOOR (IN) 				$\gamma_i = 0.133$	
	① WOOD	12	0.092		
	② AIR SPACE		0.200		
	③ WOOD	12	0.092		
				$\gamma_i = 0.133$ (0.650)	1.539 \Rightarrow 1.6
WINDOW (OUT)	ORDINARY GLASS	3			5.1
WINDOW (IN)	ORDINARY GLASS	3			3.8

1001

ADMINISTRATION BUILDING

TYPE OF STRUCTURE	MATERIALS	THICKNESS (mm)	RESISTANCE (m ² H°C/Kcal)	AIR FILM (m ² H°C/Kcal)	K-Value (Kcal/m ² H°C)
ROOF 1 	① BRICK TILE ② SAND ③ POLYETHYLENE FILM ④ ROOFING ⑤ CONCRETE ⑥ CEMENT PLASTER	10 30 1 10 150 25	0.019 0.057 0.034 0.112 0.107 0.040	Y ₀ = 0.05 Y _i = 0.189 (0.608)	1.645 ⇒ 1.7
ROOF 2 	① BRICK TILE ② SAND ③ POLYETHYLENE FILM ④ ROOFING ⑤ CONCRETE ⑥ AIR SPACE ⑦ ACOUSTICAL TILE BOARD	10 30 1 10 150 12	0.019 0.057 0.034 0.112 0.107 0.200 0.187	Y ₀ = 0.05 Y _i = 0.189 (0.955)	1.048 ⇒ 1.1
CEILING 1 	① TERRAZZO ② MORTAR ③ CONCRETE ④ AIR SPACE ⑤ ALUM SHEET	30 40 150 2	0.020 0.031 0.107 0.200 -	Y _i = 0.189 Y _i = 0.189 (0.736)	1.359 ⇒ 1.4
FLOOR 1 DITTO	DITTO	DITTO	DITTO	Y _i = 0.125 (0.608)	1.645 ⇒ 1.7
CEILING 2 	① TERRAZZO ② MORTAR ③ CONCRETE	30 40 150	0.020 0.031 0.107	Y _i = 0.189 Y _i = 0.189 (0.536)	1.866 ⇒ 1.9
FLOOR 2 DITTO	DITTO	DITTO	DITTO	Y _i = 0.125 (0.403)	2.482 ⇒ 2.5

1002