

4. ROOM LOAD SUMMARY
 4-1. PAC-1 (NW-SYSTEM)
 1) ROOM PEAK LOAD (1)

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(°C)	DEHUM AIR (m ³ /H)	OUT AIR (m ³ /H)
					R.S.H (Kcal/H)	R.T.H (Kcal/H)			
1F G02	ENTRANCE & ENTRANCE HALL	84.0	240.63	-	4967	5285	12.5	1.660	460
	SUB TOTAL	84.0	240.63	-	4967	5285		1.660	460
2F F02	SECRETARY ROOM	16.0	40.0	2	1593	1736	12.3	530	50
F02	ASSISTANT SUPERINTENDENT RM.	42.25	126.75	4	6610	6895	12.6	2.210	100
F01	SUPERINTENDENT RM	84.5	253.5	8	10716	11285	12.5	3580	200
F01	SECRETARY ROOM	24.0	60.0	4	1856	2142	11.8	620	100
F07	TELCOMUNICATION ROOM	52.25	156.75	5	4872	5228	12.4	1.630	125
F04	CANTEEN	78.5	251.18	15	14403	16360	11.9	4810	1695
	SUB TOTAL	297.5	888.18	38	40050	43645		13.380	2270
3F S02	SECRETARY ROOM	16.0	40.0	2	927	1070	11.8	310	50
S02	ASSISTANT SUPERINTENDENT RM.	42.25	160.55	4	5306	5591	12.5	1770	100
S01	SECRETARY ROOM	16.0	40.0	2	1130	1273	12.0	380	50
S01	ASSISTANT SUPERINTENDENT RM	42.25	160.55	4	4239	4523	12.5	1420	100
S03C	JUNIOR ENGINEER ROOM	68.25	225.55	6	4976	5402	12.3	1.660	150
S03b	DITTO	68.25	225.55	6	5196	5622	12.3	1.740	150
S03a	DITTO	62.25	200.55	6	7970	8397	12.5	2.660	150
	SUB TOTAL	315.25	1052.75	30	29744	31878		9.940	750

1003

1) ROOM PEAK LOAD (Z)

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(%)	DEHWIM AIR (m ³ /h)	OUT AIR (m ³ /h)
					R.S.H (Kcal/h)	R.T.H (Kcal/h)			
4F To1e	JUNIOR ENGINEER ROOM	68.25	225.55	6	9.579	10.005	12.6	3.200	150
To1d	DITTO	68.25	225.55	6	8.116	8.542	12.6	2.710	150
To1c	DITTO	68.25	225.55	6	7.979	8.405	12.6	2660	150
To1b	DITTO	68.25	225.55	6	8.125	8.551	12.6	2.710	150
To1a	DITTO	60.25	205.55	6	10.916	11.343	12.6	3.640	150
	Σ SUB TOTAL	333.25	1107.75	30	44.715	46.846		14.920	750
PAC-1	TOTAL	1030	3289.31	98	119.476	127.654	12.5	39.900	4.230
					SHF = 0.94				

peel

2). PEAK LOAD TIME (1)

NO.	ROOM NAME	3:00		5:00		6:00	
		E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)
1F. G02	ENTRANCE & ENTRANCE HALL	* 4.967	* 5.285	4706	5.021	4.428	4.740
	SUB TOTAL	4.967	5.285	4706	5.021	4.428	4.740
2F F02	SECRETARY ROOM	* 1.593	* 1.736	1.520	1.663	1.336	1.478
F02	ASSISTANT SUPERINTENDENT RM.	6.184	6.468	* 6.610	* 6.895	6.417	6.700
F01	SUPERINTENDENT RM.	9.598	10.169	* 10.715	* 11.285	10.417	10.985
F01	SECRETARY ROOM	* 1.856	* 2.142	1.723	2.008	1.581	1.865
F07	TELCOMMUNICATION ROOM	4.277	4.634	* 4.872	* 5.228	4.843	5.198
F04	PEAK 4:00 CANTEEN	14.152	16.133	13.964	15.921	12.738	14.395
	SUB TOTAL	37.660	41.282	39.405	43.000	37.332	40.621
3F S02	SECRETARY ROOM	* 927	* 1.070	884	1.027	840	982
S02	ASSISTANT SUPERINTENDENT RM.	4.687	4.971	* 5.306	* 5.591	5.304	5.587
S01	SECRETARY ROOM	* 1.130	* 1.273	1.067	1.210	1.003	1.145
S01	ASSISTANT SUPERINTENDENT RM.	3.078	3.363	4.187	4.470	* 4.239	* 4.523
S03C	JUNIOR ENGINEER ROOM	3.823	4.251	4.928	5.355	* 4.976	* 5.402
S03b	DITTO	4.695	4.523	4.807	5.234	* 5.196	* 5.622
S03a	DITTO	7.013	7.441	* 7.970	* 8.397	7.559	7.985
	SUB TOTAL	24.753	26.892	29.149	31.284	29.117	31.246

1005

2). PEAK LOAD TIME (2)

No.	ROOM NAME	3:00		5:00		6:00	
		E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)
4F	JUNIOR					*	*
To1e	ENGINEER ROOM	8083	8511	9.541	9.968	9.579	10.005
To1d	DITTO	6.465	6.893	7.990	8.417	8.116	8.542
To1c	DITTO	6.294	6.722	7.835	8.262	7.979	8.405
To1b	DITTO	6.475	6.903	7.999	8.426	8.125	8.551
To1a	DITTO	9.576	10.004	10.916	11.343	10.575	11.001
	SUB TOTAL	36.893	39.033	44.281	46.416	44.374	46.504
PAC-1	TOTAL	104.273	112.492*	117.541*	125.721	115.251	123.111

4-2 PAC-2 (SE-SYSTEM)
1) ROOM PEAK LOAD

NO	ROOM NAME	AREA (m ²)	VOLUME (m ³)	PEOPLE	PEAK LOAD		INDICATED A.D.P.(%)	DEHUM AIR (m ³ /H)	OUT AIR (m ³ /H)
					R.S.H (Kcal/H)	R.T.H (Kcal/H)			
2F									
F03	CONFERENCE ROOM	84.5	253.5	16	9658	10.792	12.1	3.220	400
F09	CORRIDOR	87.25	218.13	-	6.523	6.523	13.2	2180	-
	SUB TOTAL	171.75	471.63	16	16.181	17.315		5400	400
3F									
S05d	EXECUTIVE ENGINEER ROOM	21.13	80.29	2	1.926	2.069	12.3	640	50
S05c	DITTO	21.13	80.29	2	1.709	1.852	12.3	570	50
S05b	DITTO	21.13	80.29	2	1.709	1.852	12.3	570	50
S05a	DITTO	21.13	80.29	2	2.010	2.153	12.3	670	50
S04	PRAY ROOM	42.25	160.55	12	5809	6.664	11.8	1940	300
S06	CORRIDOR	101.5	253.75	-	5.102	5.102	13.2	1700	-
	SUB TOTAL	228.27	735.46	20	18.265	19.692		6090	500
4F									
T03d	EXECUTIVE ENGINEER ROOM	21.13	80.29	2	2.770	2.912	12.5	920	50
T03c	DITTO	21.13	80.29	2	2.503	2.646	12.5	840	50
T03b	DITTO	21.13	80.29	2	2.503	2.646	12.5	840	50
T03a	DITTO	21.13	80.29	2	2.873	3.015	12.5	960	50
T02	LIBRARY & STRAGE ROOM	42.25	160.55	4	7009	7.293	12.6	2340	100
T04	CORRIDOR	101.5	253.75	-	7.963	7.963	13.2	2.660	-
	SUB TOTAL	228.27	735.46	12	25.621	26.475		8560	300
PAC-2 TOTAL		628.29	1942.55	48	60.067	63.482	12.5°C	20.050	1.200

SHP=0.95

Leaf

2). PEAK LOAD TIME

NO.	ROOM NAME	2:00		3:00		4:00	
		E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)	E.R.S.H (Kcal/h)	E.R.T.H (Kcal/h)
2F		*	*				
F03	CONFERENCE ROOM	9.658	10.792	9.616	10.752	9.047	10.180
F09	CORRIDOR	6.378	6.378	6.523	6.523	6.378	6.378
	SUB TOTAL	16.036	17.170	16.139	17.275	15.425	16.558
3F							
S05 d	EXCUTIVE (PEAK 12:00) ENGINEER ROOM	1.614	1.942	1.791	1.934	1.703	1.845
S05 c	DITTO (PEAK 12:00)	1.673	1.815	1.517	1.660	1.438	1.580
S05 b	DITTO (PEAK 12:00)	1.673	1.815	1.517	1.660	1.438	1.580
S05 a	DITTO	1.905	1.950	1.897	2.040	1.808	1.950
S04	PRAY ROOM	5.652	6.502	5.809	6.664	5.764	6.614
S06	CORRIDOR	4.969	4.969	5.102	5.102	5.038	5.038
	SUB TOTAL	17.486	18.993	17.633	19.060	17.189	18.607
4F							
T03 d	EXCUTIVE ENGINEER ROOM	2.669	2.811	2.737	2880	2770	2.912
T03 c	DITTO	2.401	2.543	2.463	2.606	2.503	2.646
T03 b	DITTO	2.401	2.543	2.463	2.606	2.503	2.646
T03 a	DITTO	2.772	2.914	2.843	2.986	2.878	3.015
T02	LIBRARY & STRAGE ROOM	5.447	5.731	6.886	7172	7009	7293
T04	CORRIDOR	7.378	7.378	7.806	7806	7.963	7963
	SUB TOTAL	23.068	23.920	25.198	26.056	25.626	26.475
	PAC-2 TOTAL	36.590	60.083	38.970	62.391	58.240	61.640

8001

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **ENTRANCE - ENTRANCE HALL (902) PAC-1 SYSTEM**
 SIZE m² x m² = **84.0 m²** x m(H) = **240.63 m³**

SHEET No. 12
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3	
				MAX	3:00	5:00					6:00
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)				
	m ² X	X					OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
	m ² X	X					CONDITIONS: DB °C WB °C %RH DP °C g/kg				
	m ² X	X					OUTSIDE	42.2	28.6	37	19.0
	m ² X	X					ROOM	24.0	17.1	50	9.4
	m ² X	X					DIFFERENCE	18.2	X X X	X X X	9.6
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D				
WALL	m ² X	X					GLASS	ORDINARY, THICK, ABSORBENT, % DOUBLE			
	m ² X	X					COLOR	LIGHT, MEDIUM, DARK			
	m ² X	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² X	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE	
Roof - SUN	m ² X	X					INFILTRATION				
Roof - SHADED	m ² X	X					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.				
GLASS	13.5 m ² X	9.1	X	3.8	536	486	433	OPEN DOORS DOORSX CMH/DOOR			
CEILING	16.0 m ² X	9.1	X	1.4	204	185	165	EXHAUST AIR			
DOOR	6.8 m ² X	18.2	X	1.6	198	180	160	CRACK m ² CMH/m			
PARTITION (1)	21.6 m ² X	18.2	X	1.8	708	642	572	INFILTRATION CMH			
(2)	3.2 m ² X	22.0	X	1.8	150	150	150	VENTILATION			
(3)	30.0 m ² X	9.1	X	2.5	683	619	552	PEOPLE X CMH/PER.			
INFILTRATION	CMH X degX	0.29						1' m ² CMH/m ²			
INTERNAL HEAT							VENTILATION CMH				
PEOPLE	PEOPLE X							SENSIBLE HEAT FACTOR			
Kw	KwX	X	860				E.S.H.F =	496.7 (ERSH) = 0.94 (12.5°C)			
LIGHTS	84.0 X 20 W X	1.08	1815	1815	1815			5285 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE							APPARATUS DEWPOINT 12.5 °C				
	m ² X	degX						496.7 (ERSH)			
								24.0 RM - (2.5 ADP) (1 - BF) X 0.29 = 1.660 CMH			
SAFETY FACTOR							NOTES				
ROOM SENSIBLE HEAT Sub Total							PARTITION				
SUPPLY DUCT	SUPPLY DUCT	FAN					(1) : 10.0 x 2.5 - 1.7 x 2.0 = 21.6				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	430	408	385	(2) : 2.0 x 2.5 - 0.9 x 2.0 = 3.2				
BYPASS OUTSIDE AIR	460 CMH X 18.2 deg X 0.1 BF X 0.29			243	221	196	(3) : 12.0 x 2.5 = 30.0				
EFFECTIVE ROOM SENSIBLE HEAT							GLASS (IN) : 6.2 x 2.5 = 15.5				
ROOM LATENT HEAT							DOOR (IN) : 1.7 x 2.0 x 2 = 6.8				
INFILTRATION	CMH X g/kg X	0.72					CEILING : 4.0 x 4.0 + 6.0 = 22.0				
PEOPLE	1 PEOPLE X						SR : 12.0 x 6.5 + 2.0 x 3.0 = 84.0				
STEAM	kg/h X	540					VR : 6.5 x 3.5 x 2.5 + (8.5 x 6.5 + 2.0 x 3.0) x 3.0 = 240.63				
APPLIANCES ETC.											
VAPOR TRANS.											
SAFETY FACTOR											
ROOM LATENT HEAT Sub Total											
SUPPLY DUCT LEAKAGE LOSS											
BYPASS OUTSIDE AIR	460 CMH X 9.6 g/kg X 0.1 BF X 0.72			318	315	312					
EFFECTIVE ROOM LATENT HEAT											
EFFECTIVE ROOM TOTAL HEAT											
OUTSIDE AIR HEAT											
SENSIBLE:	CMH X deg X (1 - BF) X 0.29										
LATENT:	CMH X g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub Total											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	+ H.P	+ PIPE GAIN								
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET No. 13

INSURING No. _____ INSURED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED For SECRETARY ROOM (FO2) PAC-1 SYSTEM

DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3		
				MAX	3:00	6:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
	m ² X	X					OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH					
	m ² X	X					CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ² X	X					OUTSIDE	47.2	28.6	37		19.0
	m ² X	X					ROOM	24.0	17.1	50		9.4
	m ² X	X					DIFFERENCE	18.2	XXX	XXX	XXX	9.6
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D					
WALL	m ² X	X					GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² X	X					COLOR LIGHT, MEDIUM, DARK.					
	m ² X	X					WEIGHT		kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² X	X					INTERNAL HEAT W/m ² m ² /PEOPLE					
ROOF - SUN	m ² X	X					INFILTRATION					
ROOF - SHADED	m ² X	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS: PEOPLEX CMH/PER.					
GLASS	m ² X	X					OPEN DOORS: DOORSX CMH/DOOR					
CEILING	m ² X	X					EXHAUST AIR					
FLOOR	16.0 m ² X	13.2	X	2.5	528	508	388	CRACK: mX CMH/m				
PARTITION (1)	10.2 m ² X	9.1	X	1.8	167	152	135	INFILTRATION CMH				
	(2) 12.0 m ² X	9.1	X	2.5	273	248	221	VENTILATION				
DOOR	1.8 m ² X	9.1	X	1.6	27	24	22	2 PEOPLEX		25 CMH/PER.	50	
INFILTRATION	CMHX	degX	0.29					1 m ² X		CMH/m ²		
INTERNAL HEAT								VENTILATION CMH				
PEOPLE	2 PEOPLEX	41			82	82	82	SENSIBLE HEAT FACTOR				
Kw	KwX	X	860					E.S.H.F. = 1.593 (ERSH) = 0.92 (12.3°C)				
LIGHTS	16.0 X 20 Wx		1.08		346	346	346	1736 (ERTH)				
APPLIANCES ETC.								DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE	m ² X	degX	(-)					APPARATUS DEWPOINT 12.5 °C				
								1.593 (ERSH)				
								(24 RM-12.5 ADP) (1 - BF) X 0.29 = 530 CMH				
Sub Total								NOTES				
SAFETY FACTOR %								PARTITION:				
ROOM SENSIBLE HEAT Sub Total					1423	1360	1194	(1) : 4.0 x 3.0 = 12.0				
SUPPLY DUCT	SUPPLY DUCT	FAN						(2) : 4.0 x 3.0 = 12.0				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%		143	136	120	FLOOR : 4.0 x 4.0 = 16.0				
BYPASS OUTSIDE AIR	50 CMHX	18.2 degX	0.1 BF X 0.29		27	24	22	DOOR : 0.9 x 2.0 = 1.8				
EFFECTIVE ROOM SENSIBLE HEAT					1593	1520	1336					
ROOM LATENT HEAT												
INFILTRATION	CMHX	g/kgX	0.72									
PEOPLE	2 PEOPLEX	49			98	98	98					
STEAM		kg/hX	540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub Total					98	98	98					
SAFETY FACTOR %												
ROOM LATENT HEAT Sub Total												
SUPPLY DUCT LEAKAGE LOSS			10%		10	10	10					
BYPASS OUTSIDE AIR	50 CMHX	9.6 g/kgX	0.1 BF X 0.72		35	35	34					
EFFECTIVE ROOM LATENT HEAT					143	143	142					
EFFECTIVE ROOM TOTAL HEAT					1736	1663	1478					
OUTSIDE AIR HEAT					(109)							
SENSIBLE:	CMHX	degX	(1 - BF) X 0.29									
LATENT:	CMHX	g/kgX	(1 - BF) X 0.72									
GRAND TOTAL HEAT Sub Total												
RETURN DUCT	RETURN DUCT	PUMP	PFE									
HEAT GAIN	LEAK GAIN	H.P	GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No.	INQUIRED BY	SHEET No. 14
Job NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR ASSISTANT SUPERINTENDENT ROOM (FO2) PAC-1 SYSTEM		REVISION
SIZE 6.5 m x 6.5 m = 42.25 m ² x 9.0 m(H) = 126.75 m ³		PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PMS	
				MAX	3:00	6:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (- -)				
NE)	6.9 m ²	3.6 x 0.13 x 1/0.95 x 0.94 x 0.165		236	291	200	OUTSIDE DESIGN CONDITIONS COB CWB %RH				
NW)	5.4 m ²	3.6 x 0.15 x 1/0.85 x 0.94 x 0.165		924	483	923	CONDITIONS DB °C WB °C %RH DP °C g/kg				
	m ²	x					OUTSIDE	40.5	28.2	99	18.9
	m ²	x					ROOM	24.0	17.1	50	9.4
	m ²	x					DIFFERENCE	16.5	x x x	x x x	9.5
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D				
WALL (NE)	19.1 m ²	13.0 x	2.1	522	478	542	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
(NW)	20.6 m ²	19.5 x	2.1	844	584	1004	COLOR (LIGHT, MEDIUM, DARK)				
	m ²	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ²	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE	
ROOF - SUN	m ²	x					INFILTRATION				
ROOF - SHADED	m ²	x					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER				
GLASS	12.3 m ²	16.5 x	5.1	1035	1142	923	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m ²	x					EXHAUST AIR				
FLOOR	42.25 m ²	11.5 x	2.5	1125	1395	1025	CRACK m x CMH/m				
PARTITION	7.5 m ²	8.25 x	1.8	112	123	100	INFILTRATION CMH				
INFILTRATION CMH x deg x 0.29							VENTILATION				
INTERNAL HEAT							4 PEOPLE X 25 CMH/PER. 100				
PEOPLE	4 PEOPLE X	41		164	164	164	VENTILATION CMH				
Kw	Kw x	x	860				SENSIBLE HEAT FACTOR				
LIGHTS	42.25 x 20 W x		1.08	913	913	913	E.S.H.F. = $\frac{6610}{6895}$ (ERSH) = 0.96 (12.5°C)				
APPLIANCES ETC.							DEHUMIDIFIED AIR				
CREDIT FOR THERMAL STORAGE m ² x deg x (-) (-)							APPARATUS DEWPOINT 12.5 °C				
Sub TOTAL							$\frac{6610}{(24RM - 12. ADP)(1.0 BF) \times 0.29} = 2210$ CMH				
SAFETY FACTOR %							NOTES				
ROOM SENSIBLE HEAT Sub TOTAL							GLASS (NE): 15 x 1.8 + 1.5 x 2.8 = 6.9				
SUPPLY DUCT	SUPPLY DUCT	FAN		597	558	580	(NW): 1.5 x 1.8 x 2 = 5.4				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%				WALL (NE): 6.5 x 4.0 = 6.9 = 19.1				
BYPASS OUTSIDE AIR 100 CMH x 16.5 deg x 0.1 BF x 0.29							(NW): 6.5 x 4.0 = 5.4 = 20.6				
EFFECTIVE ROOM SENSIBLE HEAT							PARTITION: 25 x 3.0 = 7.5				
ROOM LATENT HEAT							FLOOR: SR				
INFILTRATION	CMH x	g/kg x	0.72								
PEOPLE	4 PEOPLE X	49		196	196	196					
STEAM		kg/h x	540								
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL											
SUPPLY DUCT	LEAKAGE LOSS		10%	20	20	20					
BYPASS OUTSIDE AIR 100 CMH x 9.5 g/kg x 0.1 BF x 0.72											
EFFECTIVE ROOM LATENT HEAT											
EFFECTIVE ROOM TOTAL HEAT											
OUTSIDE AIR HEAT (164)											
SENSIBLE:	CMH x	deg x (1 - BF) x 0.29									
LATENT:	CMH x	g/kg x (1 - BF) x 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	H.P	+ GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

10/1

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INSURING No. _____ INSURED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED For SUPERINTENDENT ROOM (E01) PAC-1 SYSTEM
 SIZE 13.0 m² X 6.5 m² X 84.5 m² X 3.0 m(H) = 2535 m³

SHEET No. 15
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
				MAX	3:00	6:00						
SOLAR GAIN — GLASS							HOURS OF OPERATION Hour (-)					
(NW)	12.3 m ²	366 x 0.65 / 0.94 x 0.65	X	2104	1101	2072	OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH					
	m ²	X					CONDITIONS:	DB °C	WB °C	%RH	DP °C	e/kg
	m ²	X					OUTSIDE	40.5	28.2	39		18.9
	m ²	X					ROOM	24.0	17.1	50		9.4
	m ²	X					DIFFERENCE	16.5	X X X	X X X	X X X	9.5
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L M D					
WALL (NW)	39.7 m ²	195 X 2.1	X	1626	1126	1935	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ²	X					COLOR LIGHT, MEDIUM, DARK.					
	m ²	X					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)					
	m ²	X					INTERNAL HEAT W/m ² m ² /PEOPLE					
ROOF—SUN	m ²	X					INFILTRATION					
ROOF—SHADED	m ²	X					SWINGING					
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.					
GLASS	12.3 m ²	16.5 X 5.1	X	1053	1142	923	OPEN DOORS DOORS X CMH/DOOR					
CEILING	m ²	X					EXHAUST AIR					
FLOOR	84.5 m ²	11.5 X 2.5	X	2430	2789	2050	CRACK m X CMH/m					
PARTITION	17.7 m ²	8.25 X 1.8	X	263	290	235	INFILTRATION CMH					
DOOR	1.8 m ²	8.25 X 1.6	X	24	27	22	VENTILATION					
INFILTRATION	CMH X deg X		0.29				8 PEOPLE X 25 CMH/PER. 200					
INTERNAL HEAT							VENTRATION CMH 200					
PEOPLE	8 PEOPLE X	41	X	328	328	328	SENSIBLE HEAT FACTOR					
KW	KW X	X	860				E.S.H.F = 10716 (ERSH) = 0.95 (12.5°C)					
LIGHTS	84.5 X 20 WX	X	1.08	1826	1826	1826	11285 (ERTH)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
CREDIT FOR THERMAL STORAGE m ³ X deg X (-) (-)							APPARATUS DEWPOINT 12.5 °C					
Sub TOTAL							10716 (ERSH) = 3580 CMH					
Safety Factor %							(4 RM · 12.5 ADP) (1 - BF) X 0.29					
ROOM SENSIBLE HEAT Sub TOTAL							NOTES					
SUPPLY DUCT	SUPPLY DUCT	FAN		966	863	940	• GLASS (NW) : 1.5 x 1.8 x 3 + 1.5 x 2.8 = 12.3					
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%				• WALL (NW) : 13.0 x 4.0 - 12.2 = 39.7					
BYPASS OUTSIDE AIR	200 CMH X 16.5 deg X 0.1 BF X 0.29			96	106	86	• PARTITION : 6.5 x 3.0 - 1.8 = 17.7					
EFFECTIVE ROOM SENSIBLE HEAT							• DOOR : 0.9 x 2.0 = 1.8					
ROOM LATENT HEAT							• FLOOR : SR					
INFILTRATION	CMH X g/kg X		0.72									
PEOPLE	8 PEOPLE X	49		392								
STEAM	kg/h X		540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub TOTAL												
Safety Factor X												
ROOM LATENT HEAT Sub TOTAL												
SUPPLY DUCT LEAKAGE LOSS			10%	40	40	40						
BYPASS OUTSIDE AIR	200 CMH X 95 g/kg X 0.1 BF X 0.72			137	139	136						
EFFECTIVE ROOM LATENT HEAT												
EFFECTIVE ROOM TOTAL HEAT												
OUTSIDE AIR HEAT (124)												
SENSIBLE:	CMH X deg X (1 - BF) X 0.29											
LATENT:	CMH X g/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT + RETURN DUCT - PUMP - PIPE	HEAT GAIN	LEAK GAIN	H.P. GAIN	= %								
(U.S.R.T.) GRAND TOTAL HEAT												

1012

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **SECRETARY ROOM (FO1)** PAC-1 SYSTEM
 SIZE $m \times m = 24.0 \text{ m}^2$ $\times 2.5 \text{ m(H)} = 60 \text{ m}^3$

SHEET No. 16
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3		
					CORRECTION							
SOLAR GAIN - GLASS				MAX 3:00	5:00	6:00	HOURS OF OPERATION Hour (-)					
	$m^2 \times$	X					OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	$m^2 \times$	X					CONDITIONS	DB °C	WB °C	%RH	DP °C	e/kg
	$m^2 \times$	X					OUTSIDE	42.2	28.6	39		19.0
	$m^2 \times$	X					ROOM	24.0	17.1	50		9.4
	$m^2 \times$	X					DIFFERENCE	18.2	X X X	X X X	X X X	9.6
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE (OUTSIDE, INSIDE) L M D					
WALL	$m^2 \times$	X					GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	$m^2 \times$	X					COLOR (LIGHT, MEDIUM, DARK)					
	$m^2 \times$	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	$m^2 \times$	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN	$m^2 \times$	X					INFILTRATION					
ROOF - SHADED	$m^2 \times$	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.					
GLASS	$m^2 \times$	X					OPEN DOORS DOORSX CMH/DOOR					
CEILING	$m^2 \times$	X					EXHAUST AIR					
FLOOR	24.0 $m^2 \times$	13.2	X	2.5	792	690	582	CRACK m X CMH/m				
PARTITION	10.0 $m^2 \times$	9.1	X	1.8	164	149	133	INFILTRATION CMH				
INTERNAL HEAT								VENTILATION				
INFILTRATION	CMHX	deg X	0.29					4 PEOPLEX	25	CMH/PER.	100	
PEOPLE	4 PEOPLEX	41			164	164	164	1	m ² X	CMH/m ²		
KW	KWX	X	860					VENTILATION CMH				
LIGHTS	24.0 X 20 WX		1.08		519	519	519	SENSIBLE HEAT FACTOR				
APPLIANCES ETC.								E.S.H.F. = 1.856 (ERSH) = 0.87 (11.8°C)				
								2142 (ERTH)				
CREDIT FOR THERMAL STORAGE								DEHUMIDIFIED AIR				
	$m^2 \times$	deg X						APPARATUS DEWPOINT 12.5 °C				
		Sub TOTAL						1856 (ERSH)				
								(24RM: 12, ADP)(1 - BF) X 0.29 = 620 CMH				
								0.1				
SAFETY FACTOR								NOTES				
ROOM SENSIBLE HEAT Sub TOTAL					1639	1522	1398	SR: 6.5 X 4.0 - 2.0 = 24.0				
SUPPLY DUCT	SUPPLY DUCT	FAN						PARTITION: 4.0 X 2.5 = 10.0				
HEAT GAIN	+ LEAK LOSS	- HP	= 10%		164	153	140	FLOOR: SR.				
BYPASS OUTSIDE AIR 100 CMHX 18.2 deg X 0.1 BF X 0.29					53	48	43					
EFFECTIVE ROOM SENSIBLE HEAT					1856	1723	1581					
ROOM LATENT HEAT												
INFILTRATION	CMHX	g/kg X	0.72									
PEOPLE	4 PEOPLEX	49			196							
STEAM		kg/h X	540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub TOTAL												
SAFETY FACTOR												
ROOM LATENT HEAT Sub TOTAL					196	196	196					
SUPPLY DUCT	LEAKAGE LOSS		10%		20	20	20					
BYPASS OUTSIDE AIR 100 CMHX 9.6 g/kg X 0.1 BF X 0.72					70	67	68					
EFFECTIVE ROOM LATENT HEAT					286	285	284					
EFFECTIVE ROOM TOTAL HEAT					2142	2008	1865					
OUTSIDE AIR HEAT					(89)							
SENSIBLE: CMHX deg X (1 - BF) X 0.29												
LATENT: CMHX g/kg X (1 - BF) X 0.72												
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	LEAK GAIN	H.P	+ GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

10/13

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET NO. 17

INQUIRING NO.	INSURED BY	SHEET NO.
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR	TELECOMMUNICATION ROOM (F07)	PAC-1 SYSTEM
SIZE	m x m = 57.25 m²	x 3 m (H) = 166.75 m³

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM5	
					CORRECTION						
SOLAR GAIN — GLASS				MAX 5:00	2:00	6:00	HOURS OF OPERATION Hour ()				
(NW)	5.4	m² x 366 x 0.65 x 0.85 x 0.94 x 0.65		975	484	910	OUTSIDE DESIGN CONDITIONS GDB CWB %RH				
	m²	x					CONDITIONS DB °C WB °C %RH DP °C g/kg				
	m²	x					OUTSIDE 40.5 28.2 39 18.9				
	m²	x					ROOM 24.0 17.1 50 6.4				
	m²	x					DIFFERENCE 16.5 x x x x x x x x x x 9.5				
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND NON-EXISTENCE(OUTSIDE, INSIDE) L.M.D				
WALL(NW)	20.6	m² x 19.5 x 2.1		844	584	1004	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m²	x					COLOR LIGHT, MEDIUM, DARK				
	m²	x					WEIGHT kg/m²(FLOOR) kg/m²(WALL)				
	m²	x					INTERNAL HEAT W/m² m²/PEOPLE				
TRANS. GAIN—EXCEPT WALLS & ROOF							INFILTRATION				
GLASS	m²	x					SWINGING				
CEILING	m²	x					REVOLVING DOORS PEOPLE X CMH/PER				
FLOOR	19.5	m² x 11.5 x 2.5		561	644	473	OPEN DOORS DOORS X CMH/DOOR				
PARTITION	45.4	m² x 8.25 x 1.8		675	744	601	EXHAUST AIR				
DOOR	2.6	m² x 8.25 x 1.6		35	38	31	CRACK m x CMH/m				
INTERNAL HEAT							INFILTRATION CMH				
PEOPLE		5 PEOPLE X 41		205	205	205	VENTILATION CMH				
KW		KW X 860					VENTILATION CMH				
LIGHTS		57.25 x 20 WX 1.08		129	1129	1129	SENSIBLE HEAT FACTOR				
APPLIANCES ETC.							E.S.H.F = 4.872 (ERSH) = 0.93 (124°C)				
							5228 (ERTH)				
CREDIT FOR THERMAL STORAGE							DEHUMIDIFIED AIR				
							APPARATUS DEWPOINT 12.5 °C				
							4.872 (ERSH)				
							(24 RM - 125 ADP) (1 - BF) X 0.29 = 1.630 CMH				
							Sub TOTAL				
SAFETY FACTOR				%			NOTES				
ROOM SENSIBLE HEAT Sub TOTAL					4374	3828	4353	SR : 10.5 x 6.5 - 4.0 x 4.0 = 57.25			
SUPPLY DUCT		SUPPLY DUCT	FAN				GLASS(NW): 1.5 x 1.8 x 2 = 5.4				
HEAT GAIN		+LEAK LOSS	+HP	=0%	438	383	436	WALL(NW): 6.5 x 4.0 - 5.4 = 20.6			
BYPASS OUTSIDE AIR 125 CMH x 16 F _{out} x 0.1 BF x 0.29					60	66	54	PARTITION: 16.0 x 3.0 - 2.6 = 45.4			
EFFECTIVE ROOM SENSIBLE HEAT					4872	4277	4943	FLOOR: 3.0 x 6.5 = 19.5			
ROOM LATENT HEAT								DOOR: 1.3 x 2.0 = 2.6			
INFILTRATION		CMH X g/kg X 0.72									
PEOPLE		5 PEOPLE X 49		245	245	245					
STEAM		kg/h X 540									
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR				%							
ROOM LATENT HEAT Sub TOTAL											
SUPPLY DUCT		LEAKAGE LOSS 10%		25	25	25					
BYPASS OUTSIDE AIR 125 CMH X 9.5 g/kg X 0.1 BF X 0.72					86	87	85				
EFFECTIVE ROOM LATENT HEAT					356	357	355				
EFFECTIVE ROOM TOTAL HEAT					5228	4634	5198				
OUTSIDE AIR HEAT											
SENSIBLE:		CMH X deg X (1 - BF) X 0.29		(101)							
LATENT:		CMH X g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT		RETURN DUCT	PUMP PIPE								
HEAT GAIN		+ LEAK GAIN	- H.P	+ GAIN	= %						
(U.S.R.T.) GRAND TOTAL HEAT											

FORM E-20E

10/14

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED By _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **CANTEEN (FO4)** **PAC-1 SYSTEM**
 SIZE $m \times m$ $m = 78.5 \text{ m}$ $\times 3.8, 2.5 \text{ m(H)} = 251.18 \text{ m}^3$

SHEET No. **18**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
				MA	4:00	5:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
(NW)	5.4	$m^2 \times 266 \times 0.52 / 0.85 \times 0.94 \times 0.65$		1739	484	925	OUTSIDE DESIGN CONDITIONS: CDB CWB %RH					
(SW)	12.3	$m^2 \times 252 \times 0.64 / 0.85 \times 0.94 \times 0.65$		1426	1560	1115	CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	$m^2 \times$	\times					OUTSIDE	41.7	28.4	38		18.8
	$m^2 \times$	\times					ROOM	24°	17.1	50		9.4
	$m^2 \times$	\times					DIFFERENCE	17.7	XXX	XXX	XXX	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D					
WALL (NW)	20.6	$m^2 \times 15.4 \times 2.1$		667	584	844	GLASS ORDINARY THICK. ABSORBENT. % DOUBLE					
(SW)	39.7	$m^2 \times 18.6 \times 2.1$		1551	1318	1601	COLOR LIGHT. MEDIUM. DARK.					
	$m^2 \times$	\times					WEIGHT		kg/m² (FLOOR)		kg/m² (WALL)	
	$m^2 \times$	\times					INTERNAL HEAT		W/m²		m²/PEOPLE	
ROOF - SUN	$m^2 \times$	\times					INFILTRATION					
ROOF - SHADED	$m^2 \times$	\times					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.					
GLASS	17.7	$m^2 \times 17.7 \times 5.1$		1598	1643	1490	OPEN DOORS DOORSX CMH/DOOR					
CEILING	$m^2 \times$	\times					EXHAUST AIR					
FLOOR	78.5	$m^2 \times 12.7 \times 2.5$		2493	2591	2257	CRACK mX CMH/m					
PARTITION (1)	26.6	$m^2 \times 8.85 \times 1.8$		424	436	395	INFILTRATION CMH					
(2)	24.7	$m^2 \times 17.7 \times 2.5$		1093	1124	1019	VENTILATION					
							15 PEOPLEX		25 CMH/PER.			
INFILTRATION	CMHX	degX	0.29				f m²X		CMH/m²			
INTERNAL HEAT							VENTILATION CMH					
PEOPLE	15 PEOPLEX	41		615	615	615	SENSIBLE HEAT FACTOR					
KW	KWX	X	860				E.S.H.F. = 14.403 (ERSH) = 0.88 (119°C)					
LIGHTS	78.5 x 20 WX	1.08		1696	1676	1676	16.360 (ERTH)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
CREDIT FOR THERMAL STORAGE							APPARATUS DEWPOINT 12.5 °C					
							14.403 (ERSH)		24 RM. (2.5 ADP) (1 - BF) X 0.29 = 481.0 CMH			
SAFETY FACTOR							NOTES					
ROOM SENSIBLE HEAT Sub Total				12302	12051	11957	SR: $13.0 \times 6.5 - 1.5 \times 4.0 = 78.5$					
SUPPLY DUCT	SUPPLY DUCT	FAN					GLASS (NW): $1.5 \times 1.8 \times 2 = 5.4$					
HEAT GAIN	+ LEAK LOSS	- HP = 10%		1231	1206	1198	(SW): $1.5 \times 1.8 \times 3 + 1.5 \times 2.5 = 12.3$					
BYPASS OUTSIDE AIR $1.695 \text{ CMHX} \times 17.7 \text{ deg} \times 0.1 \text{ BF} \times 0.29$				870	875	811	WALL (NW): $6.5 \times 4.0 = 20.6$					
EFFECTIVE ROOM SENSIBLE HEAT				14403	14152	13964	(SW): $13.0 \times 4.0 = 12.3 = 39.7$					
ROOM LATENT HEAT							PARTITION					
INFILTRATION	CMHX	g/kgX	0.72				(1): $7.0 \times 3.8 = 26.6$		(2): $6.5 \times 3.8 = 24.7$			
PEOPLE	15 PEOPLEX	49		735			FLOOR: SR					
STEAM	kg/hX	540					VR = $6.5 \times 6.5 \times 3.8 + (6.5 \times 6.5 - 1.5 \times 4) \times 2.5 = 251.18$					
APPLIANCES ETC.							(6:00): 14,395					
VAPOR TRANS.							OUTSIDE AIR HEAT					
Sub Total							(209)					
SAFETY FACTOR							SENSIBLE: CMHX degX (1 - BF) X 0.29					
ROOM LATENT HEAT Sub Total				735	735	735	LATENT: CMHX g/kgX (1 - BF) X 0.72					
SUPPLY DUCT LEAKAGE LOSS 10%				74	74	74	GRAND TOTAL HEAT Sub Total					
BYPASS OUTSIDE AIR $1.695 \text{ CMHX} \times 9.4 \text{ g/kg} \times 0.1 \text{ BF} \times 0.72$				1148	1172	1148	RETURN DUCT RETURN DUCT PUMP PIPE					
EFFECTIVE ROOM LATENT HEAT				1957	1981	1957	HEAT GAIN + LEAK GAIN H.P. + GAIN = %					
EFFECTIVE ROOM TOTAL HEAT				16360	16333	15921	(U.S.R.T) GRAND TOTAL HEAT					

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED By _____ SHEET No. 19
 Job Name _____ ADDRESS _____ DATE ORIGINAL _____
 SPACE USED For SECRETARY ROOM (502) PAC-1 SYSTEM REVISION _____
 SIZE 4.0 m x 4.0 m = 16.0 m² x 2.5 m(H) = 4.0 m³ PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3
				MAX	3:00	5:00				
SOLAR GAIN - GLASS										
	m ² X	X					HOURS OF OPERATION	Hour (-)		
	m ² X	X					OUTSIDE DESIGN CONDITIONS	'CDB	'CWB	%RH
	m ² X	X					CONDITIONS	DB °C	WB °C	%RH
	m ² X	X					OUTSIDE	42.2	28.6	37
	m ² X	X					ROOM	24.0	17.1	50
	m ² X	X					DIFFERENCE	XXX	XXX	XXX
										9.6
SOLAR & TRANS GAIN - WALLS & ROOF										
WALL	m ² X	X					BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D		
	m ² X	X					GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
	m ² X	X					COLOR	LIGHT, MEDIUM, DARK.		
	m ² X	X					WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)	
	m ² X	X					INTERNAL HEAT	W/m ²	m ² /PEOPLE	
ROOF - SUN	m ² X	X					INFILTRATION			
ROOF - SHADED	m ² X	X					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS	PEOPLE X CMH/PER.		
GLASS	m ² X	X					OPEN DOORS	DOORS X CMH/DOOR		
CEILING	m ² X	X					EXHAUST AIR			
FLOOR	m ² X	X					CRACK	m X	CMH/m	
PARTITION (1) 8.2	m ² X	9.1	X	1.8		135	122	109	INFILTRATION	CMH
(2) 10.0	m ² X	9.1	X	2.5		228	207	184	VENTILATION	
DOOR	1.8 m ²	9.1	X	1.6		27	24	22	Z PEOPLE X	25 CMH/PER.
INFILTRATION	CMHX	degX	0.29						1' m ² X	CMH/m ²
INTERNAL HEAT									VENTILATION	CMH
PEOPLE	Z PEOPLE X	4.1				82	82	82	SENSIBLE HEAT FACTOR	
Kw	KWX	X	860						E.S.H.F. =	927 (ERSH) = 0.87 (11.8°C)
LIGHTS	16.0 x 20 WX	1.08				346	346	346		1070 (ERTH)
APPLIANCES ETC.									DEHUMIDIFIED AIR	
									APPARATUS DEWPOINT	12.5 °C
										927 (ERSH)
									12 RM - 12.5 ADP (1.0 BF) X 0.29 = 310 CMH	
									NOTES	
Sub Total										
SAFETY FACTOR	%									
ROOM SENSIBLE HEAT Sub Total							818	781	743	
SUPPLY DUCT	SUPPLY DUCT	FAN								
HEAT GAIN	+ LEAK LOSS	- HP	= 10%				82	79	75	
BYPASS OUTSIDE AIR	50 CMH X 1.8 deg X 0.1 BF X 0.29						27	24	22	
EFFECTIVE ROOM SENSIBLE HEAT							927	884	840	
ROOM LATENT HEAT										
INFILTRATION	CMHX	g/kgX	0.72							
PEOPLE	Z PEOPLE X	4.9					98			
STEAM	kg/hX	540								
APPLIANCES ETC.										
Sub Total										
SAFETY FACTOR	%									
ROOM LATENT HEAT Sub Total							98	98	98	
SUPPLY DUCT LEAKAGE LOSS	10 %						10	10	10	
BYPASS OUTSIDE AIR	50 CMH X 9.6 g/kg X 0.1 BF X 0.72						35	35	34	
EFFECTIVE ROOM LATENT HEAT							143	143	142	
EFFECTIVE ROOM TOTAL HEAT							1070	1027	982	
OUTSIDE AIR HEAT							(67)			
SENSIBLE:	CMHX	degX(1 - BF)X0.29								
LATENT:	CMHX	g/kgX(1 - BF)X0.72								
GRAND TOTAL HEAT Sub Total										
RETURN DUCT	RETURN DUCT	PUMP	P _{RE}							
HEAT GAIN	+ LEAK GAIN	+ H.P.	+ GAIN	= %						
(U.S.R.T) GRAND TOTAL HEAT										

9101

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **ASSISTANT SUPERINTENDENT ROOM (502) PAC-1 SYSTEM**
 SIZE **6.5 m x 6.5 m = 42.25 m²** x **2.8 m H = 160.5 m³**

SHEET No. **20**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
				MAX	3:00	6:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)				
(NE)	6.9	m ² x 366 x 0.13 / 0.85 x 0.94 x 0.65		236	291	200	OUTSIDE DESIGN CONDITIONS °C DB °C WB °C %RH DP °C g/kg				
(NW)	5.4	m ² x 366 x 0.65 / 0.85 x 0.94 x 0.65		925	484	910	OUTSIDE	40.5	28.2	39	19.0
		m ² x	X				ROOM	24.0	17.1	50	9.4
		m ² x	X				DIFFERENCE	16.5	X X X	X X X	9.6
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D				
WALL (NE)	19.1	m ² x 13.0 x 2.1		522	478	542	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE			
(NW)	20.6	m ² x 19.5 x 2.1		844	584	1004	COLOR	LIGHT, MEDIUM, DARK.			
		m ² x	X				WEIGHT	kg/m ² (FLOOR)			
		m ² x	X				INTERNAL HEAT	W/m ² m ² /PEOPLE			
ROOF - SUN		m ² x	X				INFILTRATION				
ROOF - SHADED		m ² x	X				SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS: PEOPLE X CMH/PER				
GLASS	12.3	m ² x 16.5 x 5.1		1035	1102	923	OPEN DOORS: DOORS X CMH/DOOR				
CEILING		m ² x	X				EXHAUST AIR				
FLOOR		m ² x	X				CRACK m x CMH/m				
PARTITION	9.5	m ² x 8.25 x 1.8		141	156	126	INFILTRATION CMH				
INTERNAL HEAT							VENTILATION				
PEOPLE	4	PEOPLEX 41		164	164	164	4	PEOPLEX	25	CMH/PER	100
Kw		Kw x	X	860			f	m ²	CMH/m ²		
LIGHTS	42.25	x 20 Wx	1.08	913	913	913	VENTILATION CMH				
APPLIANCES ETC.							SENSIBLE HEAT FACTOR				
CREDIT FOR THERMAL STORAGE							E.S.H.F. = $\frac{5306}{5591}$ (ERSH) = 0.95 (12.5°C)				
INTERNAL HEAT							E.S.H.F. = $\frac{5306}{5591}$ (ERTH)				
INTERNAL HEAT							DEHUMIDIFIED AIR				
INTERNAL HEAT							APPARATUS DEWPOINT 12.5 °C				
INTERNAL HEAT							5306 (ERSH)				
INTERNAL HEAT							(24 RM - 12.5 ADP) (1 - 0.95) x 0.29 = 1770 CMH				
INTERNAL HEAT							NOTES				
INTERNAL HEAT							GLASS (NE): 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
INTERNAL HEAT							(NW): 1.5 x 1.8 x 2 = 5.4				
INTERNAL HEAT							WALL (NE): 6.5 x 4.0 - 6.9 = 19.1				
INTERNAL HEAT							(NW): 6.5 x 4.0 - 5.4 = 20.6				
INTERNAL HEAT							PARTITION: 2.5 x 3.8 = 9.5				
INTERNAL HEAT							ROOM LATENT HEAT				
INFILTRATION		CMH x	g/kg x	0.72							
PEOPLE	4	PEOPLEX 49		196							
STEAM		kg/h x	540								
APPLIANCES ETC.											
VAPOR TRANS.							Sub TOTAL				
VAPOR TRANS.							SAFETY FACTOR %				
VAPOR TRANS.							ROOM LATENT HEAT Sub TOTAL				
VAPOR TRANS.							4780 4212 4782				
VAPOR TRANS.							SUPPLY DUCT SUPPLY DUCT FAN				
VAPOR TRANS.							HEAT GAIN + LEAK LOSS - HP = 10%				
VAPOR TRANS.							478 422 499				
VAPOR TRANS.							BYPASS OUTSIDE AIR 100 CMH x 16.5 g/kg x 0.1 BF x 0.29				
VAPOR TRANS.							48 53 43				
VAPOR TRANS.							EFFECTIVE ROOM LATENT HEAT				
VAPOR TRANS.							5306 4687 5304				
VAPOR TRANS.							ROOM LATENT HEAT				
VAPOR TRANS.							INFILTRATION CMH x g/kg x 0.72				
VAPOR TRANS.							PEOPLE 4 PEOPLEX 49				
VAPOR TRANS.							196				
VAPOR TRANS.							STEAM kg/h x 540				
VAPOR TRANS.							APPLIANCES ETC.				
VAPOR TRANS.							Sub TOTAL				
VAPOR TRANS.							SAFETY FACTOR %				
VAPOR TRANS.							ROOM LATENT HEAT Sub TOTAL				
VAPOR TRANS.							196 196 196				
VAPOR TRANS.							SUPPLY DUCT LEAKAGE LOSS 10%				
VAPOR TRANS.							20 20 20				
VAPOR TRANS.							BYPASS OUTSIDE AIR 100 CMH x 16.5 g/kg x 0.1 BF x 0.72				
VAPOR TRANS.							69 70 68				
VAPOR TRANS.							EFFECTIVE ROOM LATENT HEAT				
VAPOR TRANS.							285 284 283				
VAPOR TRANS.							EFFECTIVE ROOM TOTAL HEAT				
VAPOR TRANS.							5591 4971 5587				
VAPOR TRANS.							OUTSIDE AIR HEAT				
VAPOR TRANS.							(133)				
VAPOR TRANS.							SENSIBLE: CMH x deg x (1 - BF) x 0.29				
VAPOR TRANS.							LATENT: CMH x g/kg x (1 - BF) x 0.72				
VAPOR TRANS.							GRAND TOTAL HEAT Sub TOTAL				
VAPOR TRANS.							RETURN DUCT + RETURN DUCT - PUMP PIPE HEAT GAIN + LEAK GAIN - H.P. + GAIN = %				
VAPOR TRANS.							(U.S.R.T) GRAND TOTAL HEAT				

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED By _____ SHEET No. 21
 Job NAME _____ ADDRESS _____ DATE ORIGINAL _____
 SPACE Used For SECRETARY ROOM (501) PAC-1 SYSTEM REVISION _____
 SIZE 4.0 m x 4.0 m = 16.0 m² x 2.5 m H = 4.0 m³ PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX	5:00	6:00				
SOLAR GAIN - GLASS				MAX	3100	5:00	6:00	HOURS OF OPERATION Hour ()		
m ² X		X						OUTSIDE DESIGN CONDITIONS 'COB' 'CWB' '%RH'		
m ² X		X						CONDITIONS: DB °C WB °C %RH DP °C g/kg		
m ² X		X						OUTSIDE 42.2 28.6 37 19.0		
m ² X		X						ROOM 24.0 17.1 50 9.4		
m ² X		X						DIFFERENCE 18.2 X X X X X X X X X 9.6		
SOLAR & TRANS GAIN - WALLS & ROOF								BLIND (NON-EXISTENCE) (OUTSIDE, INSIDE) L M D		
WALL	m ² X	X						GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE		
m ² X		X						COLOR LIGHT, MEDIUM, DARK.		
m ² X		X						WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)		
m ² X		X						INTERNAL HEAT W/m ² m ² /PEOPLE		
ROOF - SUN	m ² X	X						INFILTRATION		
ROOF - SHADED	m ² X	X						SWINGING		
TRANS. GAIN - EXCEPT WALLS & ROOF								REVOLVING DOORS PEOPLEX CMH/PER		
GLASS	m ² X	X						OPEN DOORS DOORSX CMH/DOOR		
CEILING	m ² X	X						EXHAUST AIR		
FLOOR	16.0 m ² X	9.1 X	1.7	248	225	200		CRACK m X CMH/m		
PARTITION	18.2 m ² X	9.1 X	1.8	299	271	241		INFILTRATION CMH		
DOOR	1.8 m ² X	9.1 X	1.6	27	24	22		VENTILATION		
INFILTRATION	CMHX	deg X	0.29					2 PEOPLEX 25 CMH/PER 50		
INTERNAL HEAT								VENTILATION CMH 50		
PEOPLE	2 PEOPLEX	41		82	82	82		SENSIBLE HEAT FACTOR		
Kw	KwX	X	860					E.S.H.F. = $\frac{1.130 \text{ (ERSH)}}{1.273 \text{ (ERTH)}} = 0.89 (12.0)$		
LIGHTS	16.0 X 20 W X		1.08	346	346	346		DEHUMIDIFIED AIR		
APPLIANCES ETC.								APPARATUS DEWPOINT 12.5 °C		
CREDIT FOR THERMAL STORAGE	m ² X	deg X	(-)	(-)	(-)	(-)		1130 (ERSH)		
Sub Total								124RM - (25ADP) (1.7 BF) X 0.29 = 380 CMH		
Safety Factor %								NOTES		
ROOM SENSIBLE HEAT Sub Total				1002	948	891		PARTITION: 8.0 x 2.5 - 1.8 = 18.2		
SUPPLY DUCT	SUPPLY DUCT	FAN						DOOR: 0.9 x 2.0 = 1.8		
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	101	95	90		FLOOR: SR.		
BYPASS OUTSIDE AIR	50 CMH X 18.2 deg X 0.1 BF X 0.29			27	24	22				
EFFECTIVE ROOM SENSIBLE HEAT				1130	1067	1003				
ROOM LATENT HEAT										
INFILTRATION	CMHX	g/kg X	0.72							
PEOPLE	2 PEOPLEX	49		98						
STEAM	kg/h X	540								
APPLIANCES ETC.										
VAPOR TRANS. Sub Total										
Safety Factor %										
ROOM LATENT HEAT Sub Total				98	98	98				
SUPPLY DUCT LEAKAGE LOSS		10 %		10	10	10				
BYPASS OUTSIDE AIR	50 CMH X 9.6 g/kg X 0.1 BF X 0.72			35	35	34				
EFFECTIVE ROOM LATENT HEAT				143	143	142				
EFFECTIVE ROOM TOTAL HEAT				1273	1210	1145				
OUTSIDE AIR HEAT				(80)						
SENSIBLE:	CMHX	deg X (1 - BF) X 0.29								
LATENT:	CMHX	g/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT Sub Total										
RETURN DUCT	RETURN DUCT	PUMP PIPE	= %							
HEAT GAIN	+ LEAK GAIN	H.P	+ GAIN							
(U.S.R.T.) GRAND TOTAL HEAT										

10/18

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR ASSISTANT SUPERINTENDENT ROOM (501) PAC-1 SYSTEM
 SIZE 6.5 m x 3.8 m = 24.75 m² x 3.8 m HI = 160.55 m³

SHEET NO. 22
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
					CORRECTION							
SOLAR GAIN — GLASS				MAX 6:00	3:00	5:00	HOURS OF OPERATION Hour (-)					
(NW)	6.9	m ² x 3.6 x 0.85 x 0.94 x 0.65		1162	618	1180	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ²	X					CONDITIONS	DB °C	WB °C	%RH	DP °C	e/kg
	m ²	X					OUTSIDE	38.7	27.6	43		18.2
	m ²	X					ROOM	24.0	17.1	50		9.9
	m ²	X					DIFFERENCE	14.7	X X X	X X X	X X X	
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND NON-EXISTENCE(OUTSIDE, INSIDE) L M D					
WALL (NW)	19.1	m ² x 23.2	X 2.1	931	258	783	GLASS ORDINARY THICK. ABSORBENT. % DOUBLE					
	m ²	X					COLOR	LIGHT. MEDIUM. DARK.				
	m ²	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ²	X					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF—SUN	m ²	X					INFILTRATION					
ROOF—SHADED	m ²	X					SWINGING					
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.					
GLASS	6.9	m ² x 14.7	X 5.1	518	641	581	OPEN DOORS DOORSX CMH/DOOR					
CEILING	m ²	X					EXHAUST AIR					
FLOOR	m ²	X					CRACK m x CMH/m					
PARTITION	9.5	m ² x 7.35	X 1.0	126	156	141	INFILTRATION CMH					
INFILTRATION							VENTILATION					
	CMH x deg X		0.29				4 PEOPLEX	25 CMH/PER.		100		
INTERNAL HEAT							VENTILATION CMH					
PEOPLE	4	PEOPLEX 41		164	164	164	SENSIBLE HEAT FACTOR					
KW	KWX	X	860				E.S.H.F = 4.239 (ERSH) = 0.94(12.5°C)					
LIGHTS	4275	X 20 W X	1.08	913	913	913	4.523 (ERTH)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
CREDIT FOR THERMAL STORAGE							APPARATUS DEWPOINT 12.5 °C					
	m ² x deg X						4.239 (ERSH)					
Sub TOTAL							124 RM - 12.5 ADP (1 - BF) X 0.29 = 1420 CMH					
SAFETY FACTOR							NOTES					
ROOM SENSIBLE HEAT Sub TOTAL				3814	2750	3762	GLASS (NW) : 1.5 x 1.8 + 1.5 x 2.8 = 6.9					
SUPPLY DUCT	SUPPLY DUCT	FAN		382	275	377	WALL (NW) : 6.5 x 4.0 - 6.9 = 19.1					
HEAT GAIN	+LEAK LOSS	+HP	= 10%				PARTITION : 2.5 x 3.8 = 9.5					
BYPASS OUTSIDE AIR				43	53	48						
EFFECTIVE ROOM SENSIBLE HEAT				41239	3078	4187						
ROOM LATENT HEAT												
INFILTRATION	CMH X	g/kg X	0.72									
PEOPLE	4	PEOPLEX 49		196								
STEAM		kg/h X	540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub TOTAL												
SAFETY FACTOR												
ROOM LATENT HEAT Sub TOTAL				196	196	196						
SUPPLY DUCT LEAKAGE LOSS				20	20	20						
BYPASS OUTSIDE AIR				68	70	69						
EFFECTIVE ROOM LATENT HEAT				284	285	283						
EFFECTIVE ROOM TOTAL HEAT				4523	3363	4470						
OUTSIDE AIR HEAT				(107)								
SENSIBLE:	CMH X deg X (1 - BF) X 0.29											
LATENT:	CMH X g/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	LEAK GAIN	H.P	GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

1019

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INSURING No. _____ INSURED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (503c)** PAC-1 SYSTEM
 SIZE **10.5** m² x **6.5** m = **68.25** m² x **3.8** m (H) = **225.55** m³

SHEET No. **23**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
					CORRECTION							
SOLAR GAIN - GLASS				MAX 6100	3100	5:00	HOURS OF OPERATION Hour (-)					
(NW) 6.9	m² x 3.66 x 0.64 / 0.85 x 0.94 x 0.65			1162	618	1180	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ² x	X					CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ² x	X					OUTSIDE	38.7	27.6	43		18.8
	m ² x	X					ROOM	24.0	17.1	50		9.4
	m ² x	X					DIFFERENCE	14.7	X X X	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE (OUTSIDE, INSIDE) L M D					
WALL (NW) 19.1	m² x 23.2	X	2.1	931	258	983	GLASS (ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² x	X					COLOR	LIGHT, MEDIUM, DARK.				
	m ² x	X					WEIGHT	kg/m² (FLOOR)		kg/m² (WALL)		
	m ² x	X					INTERNAL HEAT	W/m²		m²/PEOPLE		
ROOF - SUN	m² x	X					INFILTRATION					
ROOF - SHADED	m² x	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE CMH/PER					
GLASS 6.9	m² x 14.7	X	5.1	518	641	581	OPEN DOORS DOORS X CMH/DOOR					
CEILING	m² x	X					EXHAUST AIR					
FLOOR	m² x	X					CRACK	m X		CMH/m		
PARTITION 10.0	m² x 7.35	X	1.8	133	164	149	INFILTRATION CMH ■					
							VENTILATION					
							6 PEOPLE X	25 CMH/PER.		150		
INFILTRATION	CMH X	deg X	0.29				i' m² X	CMH/m²				
							VENTILATION CMH ■ 150					
INTERNAL HEAT							SENSIBLE HEAT FACTOR					
PEOPLE	6 PEOPLE X	41		246	246	246	E.S.H.F. =					
KW	KW X	X	860				4.976 (ERSH)		= 0.92 (123°C)			
LIGHTS	68.25 X 20 WX	1.08		1475	1475	1475	6.402 (ERTH)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT		12.5 °C			
CREDIT FOR THERMAL STORAGE	m² X	deg X	(-)	(-)			4.977 (ERSH)		= 1.660 CMH			
							(24RM - 12.5ADP)(1 - BF) X 0.29					
SUB TOTAL							NOTES					
SAFETY FACTOR			%				VR = 6.5 x 6.5 x 3.8 + 6.5 x 4.0 x 2.5 = 225.55					
ROOM SENSIBLE HEAT SUB TOTAL				4465	3402	4414						
SUPPLY DUCT	SUPPLY DUCT	FAN										
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	447	341	442						
BYPASS OUTSIDE AIR	150 CMH x 14.7 deg X 0.1 BF X 0.29			64	80	72	GLASS (NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9					
EFFECTIVE ROOM SENSIBLE HEAT				4976	3823	4928	WALL (NW): 6.5 x 4.0 - 6.9 = 19.1					
ROOM LATENT HEAT							PARTITION: 4.0 x 2.5 = 10.0					
INFILTRATION	CMH X	g/kg X	0.72									
PEOPLE	6 PEOPLE X	49		294								
STEAM		kg/h X	540									
APPLIANCES ETC.												
VAPOR TRANS.												
SUB TOTAL												
SAFETY FACTOR			%									
ROOM LATENT HEAT SUB TOTAL				294	294	294						
SUPPLY DUCT LEAKAGE LOSS			10%	30	30	30						
BYPASS OUTSIDE AIR	150 CMH x 9.4 g/kg x 0.1 BF x 0.72			102	104	103						
EFFECTIVE ROOM LATENT HEAT				426	428	427						
EFFECTIVE ROOM TOTAL HEAT				5402	4251	5355						
OUTSIDE AIR HEAT												
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29										
LATENT:	CMH X	g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT SUB TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	+ LEAK GAIN	H.P.	+ GAIN	= %								
(U.S.R.T.) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (503 b)** PAC-1 SYSTEM
 SIZE m'x m' = **68.25** m' x **3.8** m(H) = **225.55** m'

SHEET No. **24**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM PM 6	
				MAX	3:00	5:00					
SOLAR GAIN - GLASS				MAX 6:00	3:00	5:00	HOURS OF OPERATION Hour ()				
(NW) 6.9	m'x 3.66 x 0.64 / 1.5 x 0.94 x 0.65			1162	618	1180	OUTSIDE DESIGN CONDITIONS °C DB °C WB °C %RH DP °C g/kg				
	m'x	X					OUTSIDE	28.7	27.6	43	18.8
	m'x	X					ROOM	24.0	17.1	50	9.4
	m'x	X					DIFFERENCE	14.7	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D				
WALL (NW) 19.1	m'x 23.2	X	2.1	931	258	783	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m'x	X					COLOR LIGHT, MEDIUM, DARK.				
	m'x	X					WEIGHT kg/m² (FLOOR) kg/m² (WALL)				
	m'x	X					INTERNAL HEAT W/m² m²/PEOPLE				
ROOF - SUN	m'x	X					INFILTRATION				
ROOF - SHADED	m'x	X					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.				
GLASS 6.9	m'x 14.7	X	5.1	518	641	246	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m'x	X					EXHAUST AIR				
FLOOR 16.0	m'x 7.35	X	1.7	200	248	225	CRACK m'x CMH/m				
PARTITION 10.0	m'x 7.35	X	1.8	133	164	149	INFILTRATION CMH				
INTERNAL HEAT							VENTILATION				
INFILTRATION	CMHX	degX	0.29				6 PEOPLE X 25 CMH/PER. 150				
PEOPLE	6 PEOPLE X 4.1			246	246	246	1' m'x CMH/m' 150				
Kw	KwX	X	860				VENTILATION CMH				
LIGHTS	68.25 x 20 W X		1.08	1475	1475	1405	SENSIBLE HEAT FACTOR				
APPLIANCES ETC.							E.S.H.F. = 5196 (ERSH) = 0.92 (12.3°C)				
CREDIT FOR THERMAL STORAGE							DEHUMIDIFIED AIR				
	m'x	degX					APPARATUS DEWPOINT 12.5 °C				
							5196 (ERSH)				
							(2 ARM - 12.5 ADP) (1 - BF) X 0.29 = 1740 CMH				
SUB TOTAL							NOTES				
SAFETY FACTOR	%						• VR = 6.5 x 6.5 x 3.8 + 6.5 x 4.0 x 2.5 = 225.55				
ROOM SENSIBLE HEAT SUB TOTAL				4665	3650	4304	• GLASS (NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
SUPPLY DUCT SUPPLY DUCT FAN							• WALL (NW): 6.5 x 4.0 - 6.9 = 19.1				
HEAT GAIN + LEAK LOSS + HP = 10%				467	365	431	• PARTITION: 4.0 x 2.5 = 10.0				
BYPASS OUTSIDE AIR 150 CMH x 14.7 deg x 0.1 BF x 0.29				64	80	72	• FLOOR: 4.0 x 4.0 = 16.0				
EFFECTIVE ROOM SENSIBLE HEAT				5196	4095	4807					
ROOM LATENT HEAT											
INFILTRATION	CMHX	g/kgX	0.72								
PEOPLE	6 PEOPLE X 4.9			294							
STEAM	kg/hX										
APPLIANCES ETC.											
VAPOR TRANS.											
SUB TOTAL											
SAFETY FACTOR	%										
ROOM LATENT HEAT SUB TOTAL				294	294	294					
SUPPLY DUCT LEAKAGE LOSS 10%				30	30	30					
BYPASS OUTSIDE AIR 150 CMH x 9.4 g/kg x 0.1 BF x 0.72				102	104	103					
EFFECTIVE ROOM LATENT HEAT				426	428	427					
EFFECTIVE ROOM TOTAL HEAT				5622	4523	5234					
OUTSIDE AIR HEAT											
SENSIBLE:	CMHX	degX (1 - BF) X 0.29									
LATENT:	CMHX	g/kgX (1 - BF) X 0.72									
GRAND TOTAL HEAT SUB TOTAL											
RETURN DUCT + RETURN DUCT - PUMP PIPE											
HEAT GAIN + LEAK GAIN - H.P. + GAIN = %											
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

SHEET No. **25**
 DATE ORIGINAL
 REVISION
 PERSON IN CHARGE

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (503a)** **PAC-1 SYSTEM**
 SIZE **m x m = 62.25 m²** **x 3.8, 2.5 m(H) = 200.55 m³**

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR.	AM PM	PEAK LOAD	AM P.M.	
					CORRECTION						
SOLAR GAIN - GLASS				MAX 5:00	3:00	6:00	HOURS OF OPERATION Hour (~)				
(NN) 6.9	m ² x 3.6 x 0.65	0.85 x 0.94 x 0.65		1180	618	1162	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
(SW) 8.1	m ² x 2.2 x 0.50	0.85 x 0.94 x 0.65		734	1028	382	CONDITIONS DB °C WB °C %RH DP °C E/KE				
	m ² x	x					OUTSIDE	40.5	28.2	39	18.7
	m ² x	x					ROOM	24.0	17.1	50	9.4
	m ² x	x					DIFFERENCE	16.5	x x x	x x x	9.5
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D				
WALL (NW) 19.1	m ² x	19.5 x	2.1	783	258	931	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
(SW) 33.9	m ² x	19.2 x	2.1	1267	1125	1389	COLOR LIGHT, MEDIUM, DARK.				
	m ² x	x					WEIGHT kg/m² (FLOOR) kg/m² (WALL)				
	m ² x	x					INTERNAL HEAT W/m² m²/PEOPLE				
ROOF - SUN	m ² x	x					INFILTRATION				
ROOF - SHADED	m ² x	x					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.				
GLASS 15.0	m ² x	16.5 x	5.1	1263	1393	1125	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m ² x	x					EXHAUST AIR				
FLOOR	m ² x	x					CRACK m x CMH/m				
PARTITION 17.6	m ² x	8.25 x	1.8	262	289	233	INFILTRATION CMH				
							VENTILATION				
							6 PEOPLE X 25 CMH/PER. 150				
INFILTRATION	CMH x	deg x	0.29				i m² x CMH/m²				
							VENTILATION CMH 150				
INTERNAL HEAT							SENSIBLE HEAT FACTOR				
PEOPLE	6 PEOPLE X	41		246	246	246	E.S.H.F. = 7970 (ERSH) = 0.75 (12.5°C)				
Kw	Kw x	x	860				8397 (ERTH)				
LIGHTS	62.25 x 20 W x	1.08		1345	1345	1345	DEHUMIDIFIED AIR				
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C				
							7.976 (ERSH)				
CREDIT FOR THERMAL STORAGE	m ² x	deg x	(-)	(-)	(-)	(-)	(24RM - 12.5ADP)(1 - BF) X 0.29 = 2.660 CMH				
Sub TOTAL											
SAFETY FACTOR %							NOTES				
ROOM SENSIBLE HEAT Sub TOTAL				7180	6302	6813	SR = 6.5 x 10.5 - 1.5 x 4 = 62.25				
SUPPLY DUCT	SUPPLY DUCT	FAN					VR = 6.5 x 6.5 x 3.8 + 4.0 x 4.0 x 2.5 = 200.55				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	718	631	682	GLASS				
BYPASS OUTSIDE AIR 150 CMH x 16.5 deg x 0.1 BF x 0.29				72	80	64	(NW) = 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
EFFECTIVE ROOM SENSIBLE HEAT				7970	7013	7559	(SW) = 1.5 x 1.8 x 3 = 8.1				
ROOM LATENT HEAT							WALL				
INFILTRATION	CMH x	g/kg x	0.72				(NW): 6.5 x 4.0 - 6.9 = 19.1				
PEOPLE	6 PEOPLE X	49		294			(SW): 10.5 x 4.0 - 8.1 = 33.9				
STEAM	kg/h x	540					PARTITION: 4.0 x 2.5 + 2.0 x 3.8 = 17.6				
APPLIANCES ETC.											
VAPOR TRANS. Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL				294	294	294					
SUPPLY DUCT	LEAKAGE LOSS	10%		30	30	30					
BYPASS OUTSIDE AIR 150 CMH x 9.5 g/kg x 0.1 BF x 0.72				103	104	102					
EFFECTIVE ROOM LATENT HEAT				427	428	426					
EFFECTIVE ROOM TOTAL HEAT				8397	7441	7985					
OUTSIDE AIR HEAT (135)											
SENSIBLE:	CMH x	deg x (1 - BF) x 0.29									
LATENT:	CMH x	g/kg x (1 - BF) x 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	+ H.P	+ GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

1032

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR JUNIOR ENGINEER ROOM (TOILE) PAC - 1 SYSTEM
 SIZE 10.5 m x 6.5 m = 68.25 m² x 2.5, 3.8 m(H) = 225.55 m³

SHEET NO. 26
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
				MAX	CORRECTION	5:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)				
(NE)	5.4 m ² x 366 x 0.11 / 0.85 x 0.94 x 0.65			157	228	185	OUTSIDE DESIGN CONDITIONS COB CWB %RH				
(NW)	6.9 m ² x 366 x 0.11 / 0.85 x 0.94 x 0.65			1162	618	1180	CONDITIONS DB °C WB °C %RH DP °C g/kg				
	m ² x	x					OUTSIDE	38.7	27.6	43	18.8
	m ² x	x					ROOM	24.0	17.1	50	9.4
	m ² x	x					DIFFERENCE	14.7	x x x	x x x	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D				
WALL (NE)	20.6 m ² x	13.5 x	2.1	584	515	563	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
(NW)	19.1 m ² x	23.2 x	2.1	431	258	783	COLOR LIGHT, MEDIUM, DARK.				
	m ² x	x					WEIGHT		kg/m ² (FLOOR)		kg/m ² (WALL)
	m ² x	x					INTERNAL HEAT		W/m ²		m ² /PEOPLE
ROOF - SUN	42.25 m ² x	28.5 x	1.7	2047	1724	1997	INFILTRATION				
ROOF - SHADED	26.0 m ² x	28.5 x	1.1	816	687	795	SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.				
GLASS	12.3 m ² x	14.7 x	5.1	923	1142	1036	OPEN DOORS DOORSX CMH/DOOR				
CEILING	m ² x	x					EXHAUST AIR				
FLOOR	10.0 m ² x	7.35 x	1.7	125	155	141	CRACK		m x CMH/m		
PARTITION	10.0 m ² x	7.35 x	2.5	184	228	207	INFILTRATION		CMH		
INFILTRATION CMH x deg x 0.29							VENTILATION				
INTERNAL HEAT							6 PEOPLEX 25 CMH/PER. 150				
PEOPLE	6 PEOPLEX 41			246	246	246	VENTILATION		CMH		
KW	KWX	x	860				SENSIBLE HEAT FACTOR				
LIGHTS	68.25 x 20 WX		1.08	1475	1475	1475	E.S.H.F. = 9.579 (ERSH) = 0.76 (12.6 °C)				
APPLIANCES ETC.							10.005 (ERTH)				
CREDIT FOR THERMAL STORAGE m ² x deg x							DEHUMIDIFIED AIR				
Sub TOTAL							APPARATUS DEWPOINT 12.5 °C				
SAFETY FACTOR %							9.579 (ERSH)				
ROOM SENSIBLE HEAT Sub TOTAL							(24 RM - (2.5 ADP) (1 - BF) x 0.29 = 3.200 CMH				
SUPPLY DUCT	SUPPLY DUCT	FAN		865	728	861	NOTES				
HEAT GAIN	+ LEAK LOSS	- HP	= 10%				GLASS (NE): 1.5 x 1.8 x 2 = 6.4				
BYPASS OUTSIDE AIR 150 CMH x 14.7 deg x 0.1 BF x 0.29							(NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
EFFECTIVE ROOM SENSIBLE HEAT							WALL (NE): 6.5 x 4.0 - 5.4 = 20.6				
ROOM LATENT HEAT							(NW): 6.5 x 4.0 - 6.9 = 19.1				
INFILTRATION	CMH x	g/kg x	0.72				PARTITION: 4.0 x 2.5 = 10.0				
PEOPLE	6 PEOPLEX 49			294			FLOOR: 4.0 x 2.5 = 10.0				
STEAM	kg/h x		540				ROOF (1): 4.0 x 6.5 = 26.0				
APPLIANCES ETC.							(2): 6.5 x 6.5 = 42.25				
VAPOR TRANS.							VR: 6.5 x 4.0 x 2.5 + 6.5 x 6.5 x 3.8 = 225.55				
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL							294 294 294				
SUPPLY DUCT LEAKAGE LOSS 10%							30 30 30				
BYPASS OUTSIDE AIR 150 CMH x 9.4 g/kg x 0.1 BF x 0.72							102 104 103				
EFFECTIVE ROOM LATENT HEAT							426 428 427				
EFFECTIVE ROOM TOTAL HEAT							10005 8511 9968				
OUTSIDE AIR HEAT (147)											
SENSIBLE: CMH x deg x (1 - BF) x 0.29											
LATENT: CMH x g/kg x (1 - BF) x 0.72											
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	+ LEAK GAIN	- H.P.	+ GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

10/1

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____ SHEET No. 27
 JOB NAME _____ ADDRESS _____ DATE ORIGINAL _____
 SPACE USED FOR JUNIOR ENGINEER ROOM (To 1d) PAC - 1 SYSTEM REVISION _____
 SIZE 10.5 m x 6.5 m = 68.25 m² x _____ m(H) = 225.55 m PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
					CORRECTION					
SOLAR GAIN - GLASS							HOURS OF OPERATION	Hour (-)		
(NW)	6.9 m ²	366 x 0.64 x 0.94 x 0.65	X	1162	618	1180	OUTSIDE DESIGN CONDITION	CDB	CWB	%RH
	m ²	X					CONDITIONS	DB °C	WB °C	%RH
	m ²	X					OUTSIDE	38.7	27.6	43
	m ²	X					ROOM	24.0	17.1	50
	m ²	X					DIFFERENCE	14.7	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D		
WALL (NW)	19.1 m ²	23.2 X 2.1	X	931	258	783	GLASS	ORDINARY THICK ABSORBENT. % DOUBLE		
	m ²	X					COLOR	LIGHT, MEDIUM, DARK.		
	m ²	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)
	m ²	X					INTERNAL HEAT	W/m ² m ² /PEOPLE		
ROOF - SUN	42.25 m ²	28.5 X 1.7	X	2047	1724	1997	INFILTRATION			
ROOF - SHADE	26 m ²	28.5 X 1.1	X	816	687	795	SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.			
GLASS	6.9 m ²	14.7 X 5.1	X	518	641	581	OPEN DOORS DOORS X CMH/DOOR			
CEILING	m ²	X					EXHAUST AIR			
FLOOR	10.0 m ²	7.35 X 1.7	X	125	155	141	CRACK m X CMH/m			
PARTITION	m ²	X					INFILTRATION CMH			
INFILTRATION							VENTILATION			
	CMH X deg X	0.29					6 PEOPLE X	25 CMH/PER.	150	
INTERNAL HEAT							VENTILATION CMH			
PEOPLE	6 PEOPLE X 41			246	246	246	SENSIBLE HEAT FACTOR			
Kw	Kw X X	860					E.S.H.F. = $\frac{8116}{8542}$ (ERSH) = 0.95 (12.6°C)			
LIGHTS	68.25 X 20 W X	1.08		1475	1475	1475	DEHUMIDIFIED AIR			
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C			
CREDIT FOR THERMAL STORAGE							8.116 (ERSH)			
	m ² deg X						(24 RM - 12.5 ADP) (1.2 BF) X 0.29 = 2710 CMH			
Sub TOTAL										
SAFETY FACTOR %										
ROOM SENSIBLE HEAT Sub TOTAL				7320	5804	7196	NOTES			
SUPPLY DUCT	SUPPLY DUCT	FAN		732	581	720	GLASS (NW) : 1.5 x 1.8 + 1.5 x 2.8 = 6.9			
HEAT GAIN	+ LEAK LOSS	- HP	= 10%	64	80	72	WALL (NW) : 6.5 x 4.0 = 6.9 = 19.1			
BYPASS OUTSIDE AIR	150 CMH x 14.7 deg X 0.1 BF X 0.29						FLOOR : 4.0 x 2.5 = 10.0			
EFFECTIVE ROOM SENSIBLE HEAT				8116	6465	7990	ROOF (1) : 4.0 x 6.5 = 26.0			
ROOM LATENT HEAT							(2) : 6.5 x 6.5 = 42.25			
INFILTRATION	CMH X e/kg X	0.72								
PEOPLE	6 PEOPLE X 49			294	294	294				
STEAM	kg/h X	540								
APPLIANCES ETC.										
VAPOR TRANS.										
Sub TOTAL										
SAFETY FACTOR %										
ROOM LATENT HEAT Sub TOTAL				294	294	294				
SUPPLY DUCT	LEAKAGE LOSS	10 %		30	30	30				
BYPASS OUTSIDE AIR	150 CMH x 9.4 e/kg X 0.1 BF X 0.72			102	104	103				
EFFECTIVE ROOM LATENT HEAT				426	428	427				
EFFECTIVE ROOM TOTAL HEAT				8542	6893	8417				
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X deg X (1 - BF) X 0.29									
LATENT:	CMH X e/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	+ H.P.	+ GAIN	= %						
(U.S.R.T) GRAND TOTAL HEAT										

1024

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (TOIC)** PAC-1 SYSTEM
 SIZE **10.5 m x 6.5 m = 68.25 m²** x **m(H) = 2.25 m**

SHEET No. **28**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
					CORRECTION							
SOLAR GAIN — GLASS							HOURS OF OPERATION Hour (-)					
(NW)	6.9 m ²	366 x 0.64 / 0.85 x 0.94 x 0.65		MAX 6:00	3:00	5:00	OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH					
	m ²	x		1162	618	1180	CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ²	x					OUTSIDE	38.7	27.6	43		18.8
	m ²	x					ROOM	24.0	17.1	50		9.4
	m ²	x					DIFFERENCE	14.7	XXX	XXX	XXX	9.4
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D					
WALL (NW)	19.1 m ²	23.2 x 2.1		931	258	783	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m ²	x					COLOR	LIGHT, MEDIUM, DARK.				
	m ²	x					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ²	x					INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF—SUN	42.25 m ²	28.5 x 1.7		2047	1724	1997	INFILTRATION					
ROOF—SHADE	26.0 m ²	28.5 x 1.1		816	687	795	SWINGING					
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER					
GLASS	6.9 m ²	14.7 x 5.1		518	641	581	OPEN DOORS DOORX CMH/DOOR					
CEILING	m ²	x					EXHAUST AIR					
FLOOR	m ²	x					CRACK m x CMH/m					
PARTITION	m ²	x					INFILTRATION CMH					
							VENTILATION					
							6 PEOPLEX 25 CMH/PER. 150					
							m ² CMH/m ²					
							VENTILATION CMH 150					
INTERNAL HEAT							SENSIBLE HEAT FACTOR					
PEOPLE	6 PEOPLEX	41		246	246	246	E.S.H.F. = 7.979 (ERSH) = 0.85 (12.6°C)					
Kw	KwX	x	860				8405 (ERTH)					
LIGHTS	68.25 x 20 Wx	1.08		1475	1475	1475	DEHUMIDIFIED AIR					
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C					
							(ERSH)					
CREDIT FOR THERMAL STORAGE							24 RM (2.5 ADP) (1.8 BF) x 0.29 = 2.670 CMH					
SAFETY FACTOR							NOTES					
ROOM SENSIBLE HEAT Sub TOTAL							VR = 4.0 x 6.5 x 2.5 + 6.5 x 6.5 x 3.8 = 225.55					
SUPPLY DUCT	SUPPLY DUCT	FAN		7195	5649	7057	GLASS (NW) : 1.5 x 1.8 + 1.5 x 2.8 = 6.9					
HEAT GAIN	+LEAK LOSS	+HP = 70%		1720	565	706	WALL (NW) : 6.5 x 4.0 - 6.9 = 19.1					
BYPASS OUTSIDE AIR	6 CMH x 14.7 deg x 0.1 BF x 0.29			64	80	92	ROOF (1) : 4.0 x 6.5 = 26.0					
EFFECTIVE ROOM SENSIBLE HEAT							(2) : 6.5 x 6.5 = 42.25					
ROOM LATENT HEAT												
INFILTRATION	CMH x g/kg x 0.72											
PEOPLE	6 PEOPLEX	49										
STEAM	kg/h x	540		294								
APPLIANCES ETC.												
VAPOR TRANS.												
Sub TOTAL												
SAFETY FACTOR												
ROOM LATENT HEAT Sub TOTAL												
SUPPLY DUCT LEAKAGE LOSS		10 %		294	294	294						
BYPASS OUTSIDE AIR	15 CMH x 9.4 g/kg x 0.1 BF x 0.72			30	30	30						
EFFECTIVE ROOM LATENT HEAT												
EFFECTIVE ROOM TOTAL HEAT												
OUTSIDE AIR HEAT												
SENSIBLE:	CMH x deg x (1 - BF) x 0.29			8405	6722	8262						
LATENT:	CMH x g/kg x (1 - BF) x 0.72			(120)								
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT + LEAK GAIN	RETURN DUCT + LEAK GAIN	PUMP + H.P.	PIPE + GAIN = %									
(U.S.T.) GRAND TOTAL HEAT												

1025

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED For **JUNIOR ENGINEER ROOM (TO 16)** PAC-1 SYSTEM
 SIZE 10.5 m x 6.5 m = 68.25 m² x 2.5 m H = 225.55 m³

SHEET No. **29**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
				MAX	3:00	5:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
(NW) 6.9	m ² x 3.6 x 0.65 x 0.94 x 0.65			1162	118	1180	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ² x	X					CONDITIONS	DB C	WB C	%RH	DP C	g/kg
	m ² x	X					OUTSIDE	38.7	27.6	43		18.8
	m ² x	X					ROOM	24.0	17.1	50		9.4
	m ² x	X					DIFFERENCE	14.7	X X X	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D					
WALL (NW) 19.1	m ² x 23.2	X	2.1	931	258	783	GLASS ORDINARY, THICK, ABSORBENT, % DOUBLE					
	m ² x	X					COLOR LIGHT, MEDIUM, DARK					
	m ² x	X					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)					
	m ² x	X					INTERNAL HEAT W/m ² m ² /PEOPLE					
ROOF - SUN 42.25	m ² x 28.5	X	1.7	2047	1724	1997	INFILTRATION					
ROOF - SHADE 26.0	m ² x 28.5	X	1.1	816	687	795	SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER					
GLASS 6.9	m ² x 14.7	X	5.1	518	641	581	OPEN DOORS DOORS X CMH/DOOR					
CEILING	m ² x	X					EXHAUST AIR					
FLOOR	m ² x	X					CRACK m X CMH/m					
PARTITION 10.0	m ² x 7.35	X	1.8	133	164	149	INFILTRATION CMH					
							VENTILATION					
							6 PEOPLE X	25	CMH/PER.		150	
INFILTRATION	CMH X	deg X	0.29				1' m ² X		CMH/m ²			
INTERNAL HEAT							VENTILATION CMH					
PEOPLE	6 PEOPLE X	41		246	246	246	SENSIBLE HEAT FACTOR					
Kw	Kw X	X	860				E.S.H.F. 8125 (ERSH) = 0.95 (12.6°C)					
LIGHTS	68.25 x 20 W X	1.08		1475	1475	1475	8551 (ERTH)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT 12.5 °C					
							8125 (ERSH)					
							(24RM: 12.5ADP) (1 - BF) X 0.29 = 2.710 CMH					
CREDIT FOR THERMAL STORAGE												
	m ² x	deg X										
Sub TOTAL												
SAFETY FACTOR												
ROOM SENSIBLE HEAT Sub TOTAL				7328	5813	7206						
SUPPLY DUCT	SUPPLY DUCT	FAN										
HEAT GAIN	+ LEAK LOSS	+ HP	= 0 %	733	582	721						
BYPASS OUTSIDE AIR 150 CMH x 14.7 deg X 0.1 BF X 0.29				64	80	72						
EFFECTIVE ROOM SENSIBLE HEAT				8125	6475	7449						
ROOM LATENT HEAT												
INFILTRATION	CMH X	g/kg X	0.72									
PEOPLE	6 PEOPLE X	49		294								
STEAM		kg/HX	540									
APPLIANCES ETC.												
VAPOR TRANS.												
Sub TOTAL												
SAFETY FACTOR												
ROOM LATENT HEAT Sub TOTAL				294	294	294						
SUPPLY DUCT	LEAKAGE LOSS		10 %	30	30	30						
BYPASS OUTSIDE AIR 50 CMH x 9.4 g/kg X 0.1 BF X 0.72				102	104	103						
EFFECTIVE ROOM LATENT HEAT				426	428	427						
EFFECTIVE ROOM TOTAL HEAT				8551	6903	8426						
OUTSIDE AIR HEAT				(126)								
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29										
LATENT:	CMH X	g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	+ LEAK GAIN	+ H.P.	+ GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

NOTES
 GLASS (NW): 1.5 x 1.8 + 1.5 x 2.8 = 6.9
 WALL (NW): 6.5 x 4.0 = 6.9 = 19.1
 ROOF (1): 4.0 x 6.5 = 26.0
 (2): 6.5 x 6.5 = 42.25
 PARTITION: 4.0 x 2.5 = 10.0
 VR = 4.0 x 6.5 x 2.5 + 6.5 x 6.5 x 3.8 = 225.55

1026

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **JUNIOR ENGINEER ROOM (To 1 a)** PAC-1 SYSTEM
 SIZE m x m = 60.25 m² x 25.38 m (H) = 205.55 m³

SHEET No. **30**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 5		
				MAX	CORRECTION	6:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
(NW)	6.9	m ² x 266 x 0.85 / 0.85 x 0.94 x 0.65		1180	618	1162	OUTSIDE DESIGN CONDITIONS					
(SW)	8.1	m ² x 252 x 0.85 / 0.85 x 0.94 x 0.65		734	1028	982	CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
		m ² x	X				OUTSIDE	40.5	28.2	39		18.9
		m ² x	X				ROOM	24.0	17.1	50		9.4
		m ² x	X				DIFFERENCE	16.5	X X X	X X X	X X X	9.5
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND (NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.					
WALL (NW)	19.1	m ² x 19.5	X 2.1	783	258	931	GLASS	ORDINARY THICK. ABSORBENT. % DOUBLE				
(SW)	33.9	m ² x 19.2	X 2.1	1367	1125	1389	COLOR	LGHT. MEDIUM. DARK.				
		m ² x	X				WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
		m ² x	X				INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN	42.25	m ² x 29.8	X 1.7	1997	1724	2047	INFILTRATION					
ROOF - SHADDED	18.0	m ² x 29.8	X 1.1	551	476	565	SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.					
GLASS	15.0	m ² x 16.5	X 5.1	1263	1393	1125	OPEN DOORS DOOREX CMH/DOOR					
CEILING		m ² x	X				EXHAUST AIR					
FLOOR		m ² x	X				CRACK m x CMH/m					
PARTITION	17.6	m ² x 8.25	X 1.8	262	289	233	INFILTRATION CMH					
INTERNAL HEAT							VENTILATION					
PEOPLE	6	PEOPLEX 41		246	246	246	6		25	CMH/PER.	150	
KW		KWX X 860					f		m ² x	CMH/m ²		
LIGHTS	60.25	X 20 WX 1.08		1475	1475	1475	VENTILATION CMH					
APPLIANCES ETC.							SENSIBLE HEAT FACTOR					
CREDIT FOR THERMAL STORAGE							DEHUMIDIFIED AIR					
		m ² x deg X 0.29					APPARATUS DEWPOINT		12.5 °C			
Sub TOTAL							10916 (ERSH) = 6.96 (12.6°C)					
SAFETY FACTOR %							11343 (ERTH)					
ROOM SENSIBLE HEAT Sub TOTAL							10916 (ERSH) = 3.640 CMH					
SUPPLY DUCT		SUPPLY DUCT FAN		986	864	956	NOTES					
HEAT GAIN		+ LEAK LOSS + HP = 16%					$SR = 10.5 \times 6.5 - 20 \times 4.0 = 60.25$ GLASS (NW): $15 \times 1.8 + 15 \times 2.8 = 6.9$ (SW): $15 \times 1.8 \times 3 = 8.1$ WALL (NW): $6.5 \times 4.0 - 6.9 = 19.1$ (SW): $10.5 \times 4.0 - 8.1 = 33.9$ ROOF (1): $4.0 \times 4.5 = 18.0$ (2): $6.5 \times 6.5 = 42.25$ PARTITION: $40 \times 2.5 + 20 \times 3.8 = 17.6$ VR: $4.0 \times 4.5 \times 2.5 + 6.5 \times 6.5 \times 3.8 = 205.55$					
BYPASS OUTSIDE AIR	150	CMH x 16.5 g/kg x 0.1 BF x 0.29		72	80	64						
EFFECTIVE ROOM SENSIBLE HEAT												
ROOM LATENT HEAT												
INFILTRATION		CMH X g/kg X 0.72										
PEOPLE	6	PEOPLEX 49		294								
STEAM		kg/h X 540										
APPLIANCES ETC.												
VAPOR TRANS. Sub TOTAL												
SAFETY FACTOR %												
ROOM LATENT HEAT Sub TOTAL												
SUPPLY DUCT		LEAKAGE LOSS 10%		30	30	30						
BYPASS OUTSIDE AIR	50	CMH x 9.5 g/kg x 0.1 BF x 0.72		103	104	102						
EFFECTIVE ROOM LATENT HEAT												
EFFECTIVE ROOM TOTAL HEAT												
OUTSIDE AIR HEAT (189)												
SENSIBLE:		CMH X deg X (1 - BF) X 0.29										
LATENT:		CMH X g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT		RETURN DUCT PUMP PIPE										
HEAT GAIN		+ LEAK GAIN + H.P. + GAIN = %										
(U.S.R.T) GRAND TOTAL HEAT												

1027

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE Used For **CONFERENCE ROOM (F03)** PAC-2 SYSTEM
 SIZE **13.0** m x **6.5** m = **84.5** m² x **3.0** m(H) = **253.5** m³

SHEET No. **31**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 2		
				MAY 2:00	3:00	4:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
(SE) 12.3	m ² x 252 x 0.79 / 85 x 0.94 x 0.65			647	535	428	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ² x	X					CONDITIONS: DB °C	WB °C	%RH	DP °C	e/kg	
	m ² x	X					OUTSIDE	41.7	28.4	38	18.8	
	m ² x	X					ROOM	24.0	17.1	50	9.4	
	m ² x	X					DIFFERENCE	17.7	X X X	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D					
WALL (SE) 39.7	m ² x 13.9	X	2.1	1159	1076	777	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² x	X					COLOR LIGHT, MEDIUM, DARK.					
	m ² x	X					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)					
	m ² x	X					INTERNAL HEAT W/m ² m ² /PEOPLE					
ROOF - SUN	m ² x	X					INFILTRATION					
ROOF - SHADED	m ² x	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER					
GLASS 12.78	m ² x 17.7	X	5.1	1154	1187	1154	OPEN DOORS DOORS X CMH/DOOR					
CEILING	m ² x	X					EXHAUST AIR					
FLOOR 84.5	m ² x 12.7	X	2.5	2683	2789	2683	CRACK m x CMH/m					
PARTITION (1) 12.6	m ² x 8.85	X	1.8	201	207	201	INFILTRATION CMH					
(2) 12.0	m ² x 8.85	X	2.5	266	273	266	VENTILATION					
							16 PEOPLE X	25 CMH/PER.		400		
INFILTRATION	CMH x deg x	0.29					1' m ² x	CMH/m ²				
							VENTILATION CMH					
										400		
INTERNAL HEAT							SENSIBLE HEAT FACTOR					
PEOPLE	16 PEOPLE X	41		656	656	656	E.S.H.F. = $\frac{9.658}{10.792}$ (IERSH) = 0.91 (12.1 °C)					
KW	KW X	X	860				(ERTH)					
LIGHTS	84.5 x 20	WX	1.08	1826	1826	1826						
APPLIANCES ETC.							DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT 12.5 °C					
							$\frac{9.658}{10.792}$ (IERSH)					
							$(24 RM - 12.5 ADP) (10.792) (BF) \times 0.29 = 3,220$ CMH					
							Sub Total					
							SAFETY FACTOR %					
							ROOM SENSIBLE HEAT Sub Total 8592 8549 8031					
							SUPPLY DUCT SUPPLY DUCT FAN					
							HEAT GAIN + LEAK LOSS + HP = 70% 860 855 804					
							BYPASS OUTSIDE AIR 400 CMH x 17.7 deg x 0.1 BF x 0.29 206 212 212					
							EFFECTIVE ROOM SENSIBLE HEAT 9658 9616 9047					
ROOM LATENT HEAT							NOTES					
							GLASS (SE): 1.5 x 1.8 x 3 + 1.5 x 2.8 = 12.3					
							WALL (SE): 13.0 x 4.0 - 12.3 = 39.7					
							PARTITION					
							(1): 4.2 x 3.0 = 12.6					
							(2): 4.0 x 3.0 = 12.0					
							FLOOR: SR					
							INFILTRATION CMH X g/kg X 0.72					
							PEOPLE 16 PEOPLE X 49 784 784 784					
							STEAM kg/h X 540					
							APPLIANCES ETC.					
							VAPOR TRANS.					
							Sub Total					
							SAFETY FACTOR %					
							ROOM LATENT HEAT Sub Total 784 784					
							SUPPLY DUCT LEAKAGE LOSS 10% 79 79					
							BYPASS OUTSIDE AIR 400 CMH x 9.4 g/kg x 0.1 BF x 0.72 271 271 274					
							EFFECTIVE ROOM LATENT HEAT 1134 1.136 1133					
							EFFECTIVE ROOM TOTAL HEAT 10792 10752 10180					
							OUTSIDE AIR HEAT (128)					
							SENSIBLE: CMH X deg X (1 - BF) X 0.29					
							LATENT: CMH X g/kg X (1 - BF) X 0.72					
							GRAND TOTAL HEAT Sub Total					
							RETURN DUCT RETURN DUCT PUMP PIPE					
							HEAT GAIN + LEAK GAIN + H.P + GAIN = %					
							(U.S.R.T) GRAND TOTAL HEAT					

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR CORRIDOR (FO9) PAC-2 SYSTEM
 SIZE m² m = 87.25 m² x 2.5 m(H) = 218.13 m³

SHEET No. 32
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3	
				MAX 3:00	2:00	4:00					
SOLAR GAIN — GLASS											
	m ² X	X					HOURS OF OPERATION Hour (-)				
	m ² X	X					OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH				
	m ² X	X					OUTSIDE	42.2	28.6	37	19.0
	m ² X	X					ROOM	24.0	17.1	50	9.4
	m ² X	X					DIFFERENCE	18.2	X X X	X X X	9.6
SOLAR & TRANS GAIN—WALLS & ROOF											
WALL	m ² X	X					BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L M, D			
	m ² X	X					GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE			
	m ² X	X					COLOR	LIGHT, MEDIUM, DARK.			
	m ² X	X					WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² X	X					INTERNAL HEAT:	W/m ²		m ² /PEOPLE	
ROOF—SUN	m ² X	X					INFILTRATION				
ROOF—SHADED	m ² X	X					SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF											
GLASS	m ² X	X					REVOLVING DOORS. PEOPLEX CMH/PER				
CEILING	m ² X	X					OPEN DOORS. DOOREX CMH/DOOR				
FLOOR	56.25 m ² X	13.2	X	2.5	1857	1786	EXHAUST AIR				
PARTITION (1) 8.15 m ² X	9.1	X	1.8	1336	1299		CRACK m X CMH/m				
(2) 30.15 m ² X	9.1	X	2.5	686	667		INFILTRATION CMH				
DOOR 11.34 m ² X	9.1	X	1.6	166	161		VENTILATION				
INFILTRATION CMH X deg X 0.29							PEOPLE X CMH/PER				
INTERNAL HEAT											
PEOPLE	PEOPLE X						f m ² X CMH/m ²				
Kw	Kw X	X	860				VENTILATION CMH				
LIGHTS	87.25 X 20 W X		1.08	1885	1885		SENSIBLE HEAT FACTOR				
APPLIANCES ETC.							E.S.H.F = $\frac{6523}{6623}$ (ERSH) = 1.0 (13.2°C)				
							6623 (ERTH)				
							DEHUMIDIFIED AIR				
							APPARATUS DEWPOINT 12.5 °C				
							6523 (ERSH) = 2180 CMH				
							24 RM - (7.5 ADP) (1 - BF) X 0.29				
CREDIT FOR THERMAL STORAGE m ² X deg X (-) (-)							NOTES				
Sub TOTAL											
SAFETY FACTOR %											
ROOM SENSIBLE HEAT Sub TOTAL 5930 5798											
SUPPLY DUCT SUPPLY DUCT FAN							SR = $26.0 \times 2.5 + 2.0 \times 2.0 + 4.5 \times 2.5 + 2.0 = 87.25$				
HEAT GAIN +LEAK LOSS +HP =10%				593	580		PARTITION				
BYPASS OUTSIDE AIR CMH X deg X BF X 0.29							(1) $35.5 \times 2.5 - 0.9 \times 2.0 \times 4 = 81.65$				
EFFECTIVE ROOM SENSIBLE HEAT 6523 6378 6378							(2) $13.5 \times 2.5 - 0.9 \times 2.0 \times 2 = 30.15$				
ROOM LATENT HEAT											
INFILTRATION CMH X g/kg X 0.72							DOOR: $0.9 \times 2.0 \times 6 = 10.8$				
PEOPLE PEOPLE X							FLOOR: $2.5 \times 22.5 = 56.25$				
STEAM kg/h X				540							
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL											
SUPPLY DUCT LEAKAGE LOSS %											
BYPASS OUTSIDE AIR CMH X g/kg X BF X 0.72											
EFFECTIVE ROOM LATENT HEAT											
EFFECTIVE ROOM TOTAL HEAT 6523 6378 6378											
OUTSIDE AIR HEAT											
SENSIBLE: CMH X deg X (1 - BF) X 0.29											
LATENT: CMH X g/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT + RETURN DUCT + PUMP + PIPE											
HEAT GAIN + LEAK GAIN + H.P + GAIN = %											
(U.S.R.T) GRAND TOTAL HEAT											

1029

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING No. _____ INQUIRED BY _____
 Job Name _____ ADDRESS _____
 SPACE USED FOR EXECUTIVE ENGINEER ROOM (505d) PAC-2 SYSTEM
 SIZE 3.75 m x 6.5 m = 24.13 m² x 3.8 m(H) = 80.29 m³

SHEET No. 33
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM 12 PM		
					CORRECTION							
SOLAR GAIN — GLASS				MAX: 12:00	3:00	4:00	HOURS OF OPERATION Hour (-)					
(SE) 4.2	m ² x 25.2 x 1.57 / 0.85 x 0.94 x 0.65			434	183	160	OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH					
	m ² x	X					CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ² x	X					OUTSIDE	28.4	27.6	43		18.9
	m ² x	X					ROOM	24.0	17.1	50		9.4
	m ² x	X					DIFFERENCE	14.4	X X X	X X X	X X X	9.5
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L. M. D					
WALL (SE) 8.8	m ² x 13.6 x 2.1	X		252	239	230	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² x	X					COLOR LIGHT, MEDIUM, DARK.					
	m ² x	X					WEIGHT		kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² x	X					INTERNAL HEAT W/m ² m ² /PEOPLE					
ROOF—SUN	m ² x	X					INFILTRATION					
ROOF—SHADED	m ² x	X					SWINGING					
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.					
GLASS 4.2	m ² x 14.4 x 5.1	X		309	393	354	OPEN DOORS DOORSX CMH/DOOR					
CEILING	m ² x	X					(354) EXHAUST AIR					
FLOOR	m ² x	X					CRACK m x CMH/m					
PARTITION 15.2	m ² x 7.2 x 1.8	X		197	249	243	INFILTRATION CMH					
							(243) VENTILATION					
							2 PEOPLEX 25 CMH/PER. 50					
INFILTRATION	CMH x deg x 0.29						VENTILATION CMH					
							50					
INTERNAL HEAT							SENSIBLE HEAT FACTOR					
PEOPLE	2 PEOPLEX 41			82	82	82	E.S.H.F. = 1.926 (ERSH) = 0.93 (12.3°C)					
Kw	Kw x X 860						2.069 (ERTH)					
LIGHTS	21.13 x 20 W x 1.08			457	457	457						
APPLIANCES ETC.							DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT 12.5 °C					
CREDIT FOR THERMAL STORAGE	m ³ x deg x (-)						1926 (ERSH)					
							(24RM - 17.5ADP)(1 - 0.1BF) x 0.29 = 620 CMH					
Sub Total												
SAFETY FACTOR %							(164) NOTES					
ROOM SENSIBLE HEAT Sub Total				1731	1603	1526	GLASS (SE): 1.5 x 2.8 = 4.2					
SUPPLY DUCT	SUPPLY DUCT FAN						(162)					
HEAT GAIN	-LEAK LOSS +HP = 10%			174	161	153	WALL (SE): 3.75 x 4.0 - 4.2 = 8.8					
BYPASS OUTSIDE AIR	50 CMH x 14.9 deg x 0.1 BF x 0.29			21	27	24	PARTITION: 4.0 x 3.8 = 15.2					
EFFECTIVE ROOM SENSIBLE HEAT				1926	1791	1703						
ROOM LATENT HEAT							(1800)					
INFILTRATION	CMH x g/kg x 0.72											
PEOPLE	2 PEOPLEX 49			98								
STEAM	kg/h x 540											
APPLIANCES ETC.												
VAPOR TRANS.												
Sub Total												
SAFETY FACTOR %												
ROOM LATENT HEAT Sub Total				98	98	98						
SUPPLY DUCT LEAKAGE LOSS	10 %			10	10	10						
BYPASS OUTSIDE AIR	50 CMH x 9.5 g/kg x 0.1 BF x 0.72			35	35	34						
EFFECTIVE ROOM LATENT HEAT				143	143	142						
EFFECTIVE ROOM TOTAL HEAT				2069	1934	1845	(2:00): 1942					
OUTSIDE AIR HEAT				(98)								
SENSIBLE:	CMH x deg x (1 - BF) x 0.29											
LATENT:	CMH x g/kg x (1 - BF) x 0.72											
GRAND TOTAL HEAT Sub Total												
RETURN DUCT	RETURN DUCT PUMP PIPE = %											
HEAT GAIN	LEAK GAIN H.P + GAIN											
(U.S.T.) GRAND TOTAL HEAT												

1001

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **EXECUTIVE ENGINEER ROOM (SO5b, SO5c) PAC-2 SYSTEM**
 SIZE **6.5** m² x **9.25** m = **21.13** m² x **3.8** m(H) = **80.29** m³

SHEET NO. **34**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM			
				MAX	12:00	CORRECTION							
SOLAR GAIN - GLASS				MAX	12:00	3:00	4:00	HOURS OF OPERATION Hour ()					
(SE)	4.2	m ² x 252 x 0.57 x 0.85 x 0.94 x 0.65		434	183	160		OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ² x	X				(221)		CONDITIONS	DB C	WB C	%RH	DP C	E/KE
	m ² x	X						OUTSIDE	38.4	27.6	43		18.9
	m ² x	X						ROOM	24.0	17.1	50		9.4
	m ² x	X						DIFFERENCE	14.4	X X X	X X X	X X X	9.5
SOLAR & TRANS GAIN - WALLS & ROOF								BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.					
WALL (SE)	8.8	m ² x 13.6	X 2.1	252	239	230		GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² x	X				(257)		WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)		
	m ² x	X						INTERNAL HEAT	W/m ²		m ² /PEOPLE		
ROOF - SUN	m ² x	X						INFILTRATION					
ROOF - SHADED	m ² x	X						SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF								REVOLVING DOORS PEOPLE X CMH/PER.					
GLASS	4.2	m ² x 14.4	X 5.1	309	393	354		OPEN DOORS DOORS X CMH/DOOR					
CEILING	m ² x	X						EXHAUST AIR					
FLOOR	m ² x	X				(354)		CRACK	m X CMH/m				
PARTITION	m ² x	X						INFILTRATION	CMH				
INTERNAL HEAT								VENTILATION					
PEOPLE	2	PEOPLE X 41		82	82	82		2 PEOPLE X 25 CMH/PER. 50					
KW	KW X	X	860					1' m ² CMH/m ²					
LIGHTS	21.13 x 20	WX	1.08	457	457	457		VENTILATION CMH 50					
APPLIANCES ETC.								SENSIBLE HEAT FACTOR					
CREDIT FOR THERMAL STORAGE	m ² x	deg X						E.S.H.F. = 1.709 (ERSH) = 0.92 (12.3°C)					
								1.852 (ERTH)					
								DEHUMIDIFIED AIR					
								APPARATUS DEWPOINT 12.5 °C					
								1.709 (ERSH)					
								(24 RM - 12.5 ADP) (1 - BF) X 0.29 = 550 CMH					
SAFETY FACTOR							(1371)	NOTES					
ROOM SENSIBLE HEAT SUB TOTAL				1534	1354	1283		GLASS (SE) : 4.2					
SUPPLY DUCT	SUPPLY DUCT	FAN		154	136	129		WALL (SE) : 8.8					
HEAT GAIN	+ LEAK LOSS	- HP	-10%										
BYPASS OUTSIDE AIR	50 CMH X (4.900 - 0.1) BF X 0.29			21	27	26							
EFFECTIVE ROOM SENSIBLE HEAT				1709	1517	1438							
ROOM LATENT HEAT							(1673)						
INFILTRATION	CMH X	E/KE X	0.72										
PEOPLE	2	PEOPLE X 49		98									
STEAM		kg/h X	540										
APPLIANCES ETC.													
VAPOR TRANS.													
SAFETY FACTOR													
ROOM LATENT HEAT SUB TOTAL				98	98	98							
SUPPLY DUCT LEAKAGE LOSS			10%	10	10	10							
BYPASS OUTSIDE AIR	50 CMH X 7.5 g/kg X 0.1 BF X 0.72			35	35	34							
EFFECTIVE ROOM LATENT HEAT				143	143	142							
EFFECTIVE ROOM TOTAL HEAT				1852	1660	1580		(2:00) 1815					
OUTSIDE AIR HEAT				(88)									
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29											
LATENT:	CMH X	g/kg X (1 - BF) X 0.72											
GRAND TOTAL HEAT SUB TOTAL													
RETURN DUCT	RETURN DUCT	PUMP	PIPE										
HEAT GAIN	+ LEAK GAIN	- H.P.	+ GAIN	=	%								
(U.S.R.T) GRAND TOTAL HEAT													

1031

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **EXECUTIVE ENGINEER ROOM (505 a)** PAC-2 SYSTEM
 SIZE **9.25 m x 6.5 m = 21.13 m²** x **3.8 m(H) = 80.29 m³**

SHEET No. **35**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX	3:00	4:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION		Hour ()	
(SE)	42 m ²	252 x 0.57 / 0.85 x 0.94 x 0.65		434	183	160				
	m ² X	X					OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
	m ² X	X				(21)	OUTSIDE	38.4	27.6	43
	m ² X	X					ROOM	24.0	17.1	50
	m ² X	X					DIFFERENCE	14.4	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND		NON-EXISTENCE (OUTSIDE, INSIDE) L M D	
WALL (SE)	8.8 m ²	13.6 X	2.1	252	239	230	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
	m ² X	X					COLOR	LIGHT, MEDIUM, DARK.		
	m ² X	X				(257)	WEIGHT	kg/m ² (FLOOR) kg/m ² (WALL)		
	m ² X	X					INTERNAL HEAT	W/m ² m ² /PEOPLE		
ROOF - SUN	m ² X	X					INFILTRATION			
ROOF - SHADED	m ² X	X					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.			
GLASS	4.2 m ²	14.4 X	5.1	309	393	354	OPEN DOORS	DOORS X CMH/DOOR		
CEILING	m ² X	X				(354)	EXHAUST AIR			
FLOOR	m ² X	X					CRACK	m X CMH/m		
PARTITION	15.2 m ²	17.2 X	2.5	274	346	337	INFILTRATION	CMH		
						(337)	VENTILATION			
							2 PEOPLE X	25 CMH/PER. 50		
INFILTRATION	CMH X	deg X	0.29				1' m ² X	CMH/m ²		
INTERNAL HEAT							VENTILATION CMH			
PEOPLE	2 PEOPLE X	4		82	82	82	SENSIBLE HEAT FACTOR			
KW	KW X	X	860				E.S.H.F. =	2010 (ERSH) = 0.93 (12.3°C)		
LIGHTS	21.13 X 20 W X	1.08		457	457	457		2153 (ERTH)		
APPLIANCES ETC.							DEHUMIDIFIED AIR			
							APPARATUS DEWPOINT	12.5 °C		
								2010 (ERSH)		
CREDIT FOR THERMAL STORAGE	m ² X	deg X					(24 RM. / 12 ADP) (1 - BF) X 0.29			
								CMH		
SUB TOTAL										
SAFETY FACTOR			%			(11708)	NOTES			
ROOM SENSIBLE HEAT SUB TOTAL				1808	1700	1620	GLASS (SE): 1.5 x 2.8 = 4.2			
SUPPLY DUCT	SUPPLY DUCT	FAN				(171)	WALL (SE): 3.25 x 4 = 4.2 = 8.8			
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	181	170	162	PARTITION: 4.0 x 3.8 = 15.2			
BYPASS OUTSIDE AIR	50 CMH X 4.4 deg X 0.1 BF X 0.29			21	27	26				
EFFECTIVE ROOM SENSIBLE HEAT				2010	1897	1808				
ROOM LATENT HEAT						(1905)				
INFILTRATION	CMH X	g/kg X	0.72							
PEOPLE	2 PEOPLE X	49		98						
STEAM		kg/h X	540							
APPLIANCES ETC.										
VAPOR TRANS.										
SUB TOTAL										
SAFETY FACTOR			%							
ROOM LATENT HEAT SUB TOTAL				98						
SUPPLY DUCT LEAKAGE LOSS		10%		10						
BYPASS OUTSIDE AIR	CMH X 9.5 g/kg X 0.1 BF X 0.72			35	35	34				
EFFECTIVE ROOM LATENT HEAT				143	143	142				
EFFECTIVE ROOM TOTAL HEAT				2153	2040	1950	(2:00) : 2047			
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29								
LATENT:	CMH X	g/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT SUB TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	LEAK GAIN	H.P	GAIN							
(U.S.R.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO. _____ INQUIRED BY _____
 JOB NAME _____ ADDRESS _____
 SPACE USED FOR **PRAY ROOM (504)** **PAC-2 SYSTEM**
 SIZE **6.5 m x 6.5 m = 42.25 m²** x **3.8 m(H) = 160.55 m³**

SHEET No. **36**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
				MAX	Z:ON	4:00						
SOLAR GAIN - GLASS				300	363	263	HOURS OF OPERATION					
(SE)	6.9	m ² x 252 x 0.74 / 0.85 x 0.94 x 0.65		300	363	263	OUTSIDE DESIGN CONDITIONS					
(SW)	5.4	m ² x 252 x 0.7 / 0.85 x 0.94 x 0.65		685	646	627	CONDITIONS	DB °C	WB °C	%RH	DP °C	g/kg
	m ² x	x					OUTSIDE	42.2	28.6	37		19.0
	m ² x	x					ROOM	24.0	17.1	50		9.4
	m ² x	x					DIFFERENCE	18.2	x x x	x x x	x x x	9.6
SOLAR & TRANS GAIN - WALLS & ROOF				518	558	498	BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D					
WALL (SE)	19.1	m ² x 12.9	x 2.1	518	558	498	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
(SW)	20.6	m ² x 15.8	x 2.1	684	624	605	COLOR LIGHT, MEDIUM, DARK.					
	m ² x	x					WEIGHT		kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² x	x					INTERNAL HEAT		W/m ²		m ² /PEOPLE	
Roof - SUN	m ² x	x					INFILTRATION					
Roof - SHADED	m ² x	x					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF				641	623	623	REVOLVING DOORS PEOPLE CMH/PER.					
GLASS	6.9	m ² x 18.2	x 5.1	641	623	623	OPEN DOORS DOORS x CMH/DOOR					
CEILING	m ² x	x					EXHAUST AIR					
FLOOR	42.25	m ² x 9.1	x 1.7	654	636	636	CRACK		m x CMH/m			
PARTITION	15.2	m ² x 9.1	x 1.8	249	243	243	INFILTRATION CMH					
							VENTILATION					
							12 PEOPLE X		25 CMH/PER.		300	
INFILTRATION				CMH x deg x 0.29			VENTILATION		CMH/m ²			
INTERNAL HEAT							VENTILATION		CMH		300	
PEOPLE	12	PEOPLE X 41		492	492	492	SENSIBLE HEAT FACTOR					
KW	KW x	x	860				E.S.H.F. =		5.809 (ERSH)		0.87 (11.8%)	
LIGHTS	42.25 x 20	WX	1.08	913	913	913			6.664 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR					
							APPARATUS DEWPOINT		12.5		0	
CREDIT FOR THERMAL STORAGE				m ² x deg x					5.809 (ERSH)			
				Sub TOTAL					124 RM - 12.5 ADP (1 - BF) x 0.29		1,940 CMH	
SAFETY FACTOR				%	5.136	4998	5100	NOTES				
ROOM SENSIBLE HEAT Sub TOTAL							GLASS (SE): 1.5 x 1.8 + 1.5 x 2.8 = 6.9					
SUPPLY DUCT	SUPPLY DUCT	FAN		514	500	510	WALL (SE): 6.5 x 4.0 - 6.9 = 19.1					
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	159	154	154	PARTITION: 4.0 x 3.8 = 15.2					
EFFECTIVE ROOM SENSIBLE HEAT					5.809	5652	5764	GLASS (SW): 1.5 x 1.8 x 2 = 5.4				
ROOM LATENT HEAT							WALL (SW): 6.5 x 4.0 - 5.4 = 20.6					
INFILTRATION	CMH x	g/kg x	0.72									
PEOPLE	12	PEOPLE x 49		588								
STEAM		kg/h x	540									
APPLIANCES ETC.												
VAPOR TRANS.												
				Sub TOTAL								
SAFETY FACTOR				x								
ROOM LATENT HEAT Sub TOTAL					588	588	588					
SUPPLY DUCT	LEAKAGE LOSS		10%	59	59	59						
EFFECTIVE ROOM LATENT HEAT					208	203	203					
EFFECTIVE ROOM TOTAL HEAT					6.664	6502	6614					
OUTSIDE AIR HEAT												
SENSIBLE:	CMH x	deg x (1 - BF) x 0.29										
LATENT:	CMH x	g/kg x (1 - BF) x 0.72										
GRAND TOTAL HEAT Sub TOTAL												
RETURN DUCT	RETURN DUCT	PUMP	PIPE									
HEAT GAIN	+ LEAK GAIN	- H.P	+ GAIN	= %								
(U.S.R.T) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.	INQUIRED BY	SHEET NO. 37
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR CORRIDOR (S06)	AC-2 SYSTEM	REVISION
SIZE 1 m X m = 101.5 m ² X 2.5 m(H) = 253.75 m ³		PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 3
				MAX	2:00	4:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION		Hour (-)	
(SW) 4.2	m ² 25.2 x 0.7 / 1.85 x 0.94 x 0.65			573	503	487	OUTSIDE DESIGN CONDITIONS		COB CWB %RH	
m ² X	X						CONDITIONS	DB C	WB C	%RH
m ² X	X						OUTSIDE	42.2	28.6	37
m ² X	X						ROOM	24.0	17.1	50
m ² X	X						DIFFERENCE	18.2	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND		NON-EXISTENCE (OUTSIDE, INSIDE) L.H.D.	
WALL (SW) 5.8	m ² X 15.8	X	2.1	193	148	227	GLASS		ORDINARY, THICK, ABSORBENT. % DOUBLE	
m ² X	X						COLOR		LIGHT, MEDIUM, DARK.	
m ² X	X						WEIGHT		kg/m ² (FLOOR) kg/m ² (WALL)	
m ² X	X						INTERNAL HEAT		W. m ² m ² /PEOPLE	
ROOF - SUN	m ² X	X					INFILTRATION			
ROOF - SHADED	m ² X	X					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.			
GLASS 4.2	m ² X 18.2	X	5.1	390	380	380	OPEN DOORS DOORS X CMH/DOOR			
CEILING	m ² X	X					EXHAUST AIR			
FLOOR	m ² X	X					CRACK		m X CMH/m	
PARTITION (1) 30.15	m ² X 9.1	X	1.8	494	481	481	INFILTRATION CMH			
(2) 33.2	m ² X 9.1	X	2.5	1756	735	735	VENTILATION			
DOOR 5.4	m ² X 9.1	X	1.6	79	77	77	PEOPLEX CMH/PER.			
INFILTRATION	CMH X deg X		0.29				I' m ² CMH/m ²			
INTERNAL HEAT							VENTILATION CMH			
PEOPLE	PEOPLEX						SENSIBLE HEAT FACTOR			
KW	KW X	X	860				E.S.H.F. = 5.102 (ERSH) = 1.0 (13.2)			
LIGHTS	101.5 X 20 WX		1.08	2193	2193	2193	5.102 (ERTH)			
APPLIANCES ETC.							DEHUMIDIFIED AIR			
CREDIT FOR THERMAL STORAGE	m ² X deg X		-1				APPARATUS DEWPOINT 12.5			
Sub. TOTAL							5.102 (ERSH)			
SAFETY FACTOR	%						24 RM - 12.5 ADP (1 - BF) X 0.29 = 1680 CMH			
ROOM SENSIBLE HEAT Sub. TOTAL							NOTES			
SUPPLY DUCT	SUPPLY DUCT	FAN		4638	4571	4580	SR = 32.5 x 2.5 + 2.0 x 2.0 + 6.5 x 2.5 = 101.5			
HEAT GAIN	- LEAK LOSS	+ HP	= 10%	464	457	458	GLASS (SW) : 1.5 x 2.8 = 4.2			
BYPASS OUTSIDE AIR	CMH X deg X	BF X 0.29					WALL (SW) : 2.5 x 4.0 - 4.2 = 5.8			
EFFECTIVE ROOM SENSIBLE HEAT							PARTITION			
ROOM LATENT HEAT							(1) : 13.5 x 2.5 - 3.6 = 30.15			
INFILTRATION	CMH X g/kg X	0.72					(2) : 14.0 x 2.5 - 1.8 = 33.2			
PEOPLE	PEOPLEX						DOOR : 0.9 x 2.0 x 3 = 5.4			
STEAM	kg/h X	540								
APPLIANCES ETC.										
Sub. TOTAL										
SAFETY FACTOR	%									
ROOM LATENT HEAT Sub. TOTAL										
SUPPLY DUCT LEAKAGE LOSS	%									
BYPASS OUTSIDE AIR	CMH X g/kg X	BF X 0.72								
EFFECTIVE ROOM LATENT HEAT										
EFFECTIVE ROOM TOTAL HEAT							5.102 4969 5038			
OUTSIDE AIR HEAT										
SENSIBLE:	CMH X deg X (1 - BF) X 0.29									
LATENT:	CMH X g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub. TOTAL										
RETURN DUCT	RETURN DUCT	PUMP	PIPE							
HEAT GAIN	+ LEAK GAIN	- H.P	+ GAIN	= %						
(U.S.T) GRAND TOTAL HEAT										

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRY No. _____ INQUIRED By _____
 Job NAME _____ ADDRESS _____
 SPACE Used For **EXECUTIVE ENGINEER ROOM (To3d) PAC-2 SYSTEM**
 SIZE **3.25 m x 6.5 m = 21.13 m²** x **3.8 m(H) = 80.29 m³**

SHEET No. **38**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM		
				MAX 4:00	2:00	3:00						
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)					
(SE) 4.2	m ² x 2.5 x 0.21 / 0.95 x 0.94 x 0.65			160	221	183	OUTSIDE DESIGN CONDITIONS CDB CWB %RH					
	m ² x	X					CONDITIONS	DB C	WB C	%RH	DP C	e/ke
	m ² x	X					OUTSIDE	41.7	28.4	38		18.8
	m ² x	X					ROOM	24.0	17.1	50		9.9
	m ² x	X					DIFFERENCE	17.7	X X X	X X X	X X X	9.9
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D					
WALL (SE) 8.8	m ² x 12.4	X	2.1	230	257	239	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE					
	m ² x	X					COLOR LIGHT, MEDIUM, DARK.					
	m ² x	X					WEIGHT		kg/m ² (FLOOR)		kg/m ² (WALL)	
	m ² x	X					INTERNAL HEAT		W/m ²		m ² /PEOPLE	
ROOF - SUN 21.13	m ² x 26.2	X	1.7	947	762	863	INFILTRATION					
ROOF - SHADED	m ² x	X					SWINGING					
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.					
GLASS 4.2	m ² x 17.7	X	5.1	380	380	390	OPEN DOORS DOORS X CMH/DOOR					
CEILING	m ² x	X					EXHAUST AIR					
FLOOR	m ² x	X					CRACK		m X		CMH/m	
PARTITION 15.2	m ² x 8.85	X	1.8	243	243	249	INFILTRATION CMH					
INFILTRATION CMH X deg X 0.29							VENTILATION					
INTERNAL HEAT							Z PEOPLE X 25 CMH/PER. 50					
PEOPLE 2 PEOPLE X 41							VENTILATION CMH 50					
Kw	Kw X	X	860	82	82	82	SENSIBLE HEAT FACTOR					
LIGHTS	21.13 x 20 W X		1.08	457	457	457	E.S.H.F. = $\frac{2.770}{2.912}$ (ERSH) = 0.95 (12.5°C)					
APPLIANCES ETC.							DEHUMIDIFIED AIR					
CREDIT FOR THERMAL STORAGE m ² X deg X (-) (-)							APPARATUS DEWPOINT 12.5 °C					
Sub Total							$\frac{2.770}{2.912}$ (ERSH) = 920 CMH					
Safety Factor %							(24RM - 12.5 ADP) (1 - BF) X 0.29					
ROOM SENSIBLE HEAT Sub Total							2494	2407	2463	NOTES		
SUPPLY DUCT	SUPPLY DUCT	FAN					GLASS (SE) : 1.5 x 2.8 = 4.2					
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	250	241	247	WALL (SE) : 3.75 x 4.0 - 4.2 = 8.8					
BYPASS OUTSIDE AIR 50 CMH x 17.7 deg x 0.1 BF x 0.29							26	26	27	PARTITION : 4.0 x 3.8 = 15.2		
EFFECTIVE ROOM SENSIBLE HEAT							2170	2689	2737	ROOF : SR		
ROOM LATENT HEAT												
INFILTRATION	CMH X	g/kg X	0.72									
PEOPLE	2 PEOPLE X	49		98								
STEAM	kg/h X	540										
APPLIANCES ETC.												
VAPOR TRANS.												
Sub Total												
Safety Factor %												
ROOM LATENT HEAT Sub Total							98	98	98			
SUPPLY DUCT	LEAKAGE LOSS	10%		10	10	10						
BYPASS OUTSIDE AIR 50 CMH x 9.4 g/kg x 0.1 BF x 0.72							34	34	35			
EFFECTIVE ROOM LATENT HEAT							142	142	143			
EFFECTIVE ROOM TOTAL HEAT							2192	2811	2880			
OUTSIDE AIR HEAT (138)												
SENSIBLE:	CMH X	deg X (1 - BF) X 0.29										
LATENT:	CMH X	g/kg X (1 - BF) X 0.72										
GRAND TOTAL HEAT Sub Total												
RETURN DUCT	RETURN DUCT	PUMP PIPE										
HEAT GAIN	+ LEAK GAIN	- H.P	+ GAIN = %									
(U.S.R.T) GRAND TOTAL HEAT												

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.	INQUIRED BY	SHEET NO. 39
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR EXECUTIVE ENGINEER ROOM (T03C, T03D) PAL-2 SYSTEM		
REVISION		
SIZE 3.25 m x 6.5 m = 21.13 m²		PERSON IN CHARGE
(H) = 3.0 m (H) = 80.29 m		

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 4
				MAX	2:00	3:00				
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)			
(SE) 4.2	m ² x 2.32 x 0.21 / 0.85 x 0.94 x 0.65			160	221	183	OUTSIDE DESIGN CONDITIONS °CDB °CWB %RH			
m ² x	x						CONDITIONS	DB °C	WB °C	%RH
m ² x	x						OUTSIDE	41.7	28.4	38
m ² x	x						ROOM	24.0	17.1	50
m ² x	x						DIFFERENCE	17.7	x x x	x x x
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L M D			
WALL (SE) 8.8	m ² x 12.4 x 2.1			230	257	239	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE			
m ² x	x						COLOR	LIGHT, MEDIUM, DARK		
m ² x	x						WEIGHT	kg/m ² (FLOOR) kg/m ² (WALL)		
m ² x	x						INTERNAL HEAT	W/m ² m ² /PEOPLE		
ROOF - SUN 21.13	m ² x 26.2 x 1.7			942	762	863	INFILTRATION			
ROOF - SHADED	m ² x						SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.			
GLASS 4.2	m ² x 17.7 x 5.1			380	380	390	OPEN DOORS DOORSX CMH/DOOR			
CEILING	m ² x						EXHAUST AIR			
FLOOR	m ² x						CRACK m x CMH/m			
PARTITION	m ² x						INFILTRATION CMH			
INTERNAL HEAT							VENTILATION			
INFILTRATION	CMH x deg X 0.29						2 PEOPLEX	25 CMH/PER.	50	
PEOPLE	2 PEOPLEX 41			82	82	82	1' m ²	CMH/m ²		
KW	KWX X 860						VENTILATION CMH			
LIGHTS	21.13 x 20 WX 1.08			457	457	457	50			
APPLIANCES ETC.							SENSIBLE HEAT FACTOR			
CREDIT FOR THERMAL STORAGE	m ² x deg X						E.S.H.F. = 2.503 (ERSH) = 0.95 (12.5°C)			
INTERNAL HEAT							2646 (ERTH)			
DEHUMIDIFIED AIR							APPARATUS DEWPOINT 12.5 °C			
INTERNAL HEAT							2.503 (ERSH)			
INTERNAL HEAT							24 RM - 12.5 ADP (1 - BF) x 0.29 = 830 CMH			
INTERNAL HEAT							Sub TOTAL			
INTERNAL HEAT							SAFETY FACTOR %			
INTERNAL HEAT							ROOM SENSIBLE HEAT Sub TOTAL			
INTERNAL HEAT							2251 2159 2214			
INTERNAL HEAT							SUPPLY DUCT SUPPLY DUCT FAN			
INTERNAL HEAT							HEAT GAIN + LEAK LOSS + HP = 1%			
INTERNAL HEAT							226 216 222			
INTERNAL HEAT							BYPASS OUTSIDE AIR 50 CMH x 17.7 deg x 0.18 x 0.29			
INTERNAL HEAT							26 26 27			
INTERNAL HEAT							EFFECTIVE ROOM SENSIBLE HEAT			
INTERNAL HEAT							2503 2401 2463			
INTERNAL HEAT							ROOM LATENT HEAT			
INTERNAL HEAT							INFILTRATION CMH x g/kg X 0.72			
INTERNAL HEAT							PEOPLE 2 PEOPLEX 49			
INTERNAL HEAT							98			
INTERNAL HEAT							STEAM kg/h X 540			
INTERNAL HEAT							APPLIANCES ETC.			
INTERNAL HEAT							VAPOR TRANS.			
INTERNAL HEAT							Sub TOTAL			
INTERNAL HEAT							SAFETY FACTOR %			
INTERNAL HEAT							ROOM LATENT HEAT Sub TOTAL			
INTERNAL HEAT							98 98 98			
INTERNAL HEAT							SUPPLY DUCT LEAKAGE LOSS 10 %			
INTERNAL HEAT							10 10 10			
INTERNAL HEAT							BYPASS OUTSIDE AIR 50 CMH x 9.4 g/kg x 0.18 x 0.72			
INTERNAL HEAT							34 34 35			
INTERNAL HEAT							EFFECTIVE ROOM LATENT HEAT			
INTERNAL HEAT							143 142 143			
INTERNAL HEAT							EFFECTIVE ROOM TOTAL HEAT			
INTERNAL HEAT							2646 2543 2606			
INTERNAL HEAT							OUTSIDE AIR HEAT			
INTERNAL HEAT							SENSIBLE: CMH x deg X (1 - BF) x 0.29			
INTERNAL HEAT							LATENT: CMH x g/kg X (1 - BF) x 0.72			
INTERNAL HEAT							GRAND TOTAL HEAT Sub TOTAL			
INTERNAL HEAT							RETURN DUCT RETURN DUCT - PUMP PIPE			
INTERNAL HEAT							HEAT GAIN + LEAK GAIN - H.P. - GAIN = %			
INTERNAL HEAT							(U.S.T) GRAND TOTAL HEAT			

NOTES
 GLASS (SE): 1.5 x 2.8 = 4.2
 WALL (SE): 3.25 x 4.0 = 13.0
 ROOF: SR

950

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.	INQUIRED BY	SHEET NO. 40
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR EXECUTIVE ENGINEER ROOM (TO3A)	PAC-2 SYSTEM	REVISION
SIZE 2.25 m x 6.5 m = 21.13 m²	x 3.8 m HI = 80.29 m³	PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM 4	
				MAX	2:00	3:00					
SOLAR GAIN - GLASS							HOURS OF OPERATION Hour (-)				
(SE)	4.2 m ²	252 x 0.85 x 0.94 x 0.65		160	221	183	OUTSIDE DESIGN CONDITIONS				
	m ²	X					DB C	WB C	%RH	DP C	g/kg
	m ²	X					41.7	28.4	38		18.8
	m ²	X					ROOM	24.0	17.1	50	9.0
	m ²	X					DIFFERENCE	17.7	X X X	X X X	9.4
SOLAR & TRANS GAIN - WALLS & ROOF							BLIND NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D.				
WALL (SE)	8.8 m ²	12.4 X 2.1		230	257	239	GLASS ORDINARY, THICK, ABSORBENT. % DOUBLE				
	m ²	X					COLOR LIGHT, MED. DARK.				
	m ²	X					WEIGHT kg/m ² (FLOOR) kg/m ² (WALL)				
	m ²	X					INTERNAL HEAT W/m ² m ² /PEOPLE				
ROOF - SUN	21.13 m ²	26.2 X 1.7		942	962	863	INFILTRATION				
ROOF - SHADED	m ²	X					SWINGING				
TRANS. GAIN - EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLE X CMH/PER.				
GLASS	4.2 m ²	17.7 X 5.1		380	380	390	OPEN DOORS DOORS X CMH/DOOR				
CEILING	m ²	X					EXHAUST AIR				
FLOOR	m ²	X					CRACK m X CMH/m				
PARTITION	15.2 m ²	8.85 X 2.5		337	337	346	INFILTRATION CMH				
INFILTRATION CMH X deg X 0.29							VENTILATION				
INTERNAL HEAT							2 PEOPLE X 25 CMH/PER. 50				
PEOPLE	2 PEOPLE X	41		82	82	82	i' m ² CMH/m ²				
Kw	Kw X	X	860				VENTILATION CMH 50				
LIGHTS	21.13 x 20 W X	1.08		457	457	457	SENSIBLE HEAT FACTOR				
APPLIANCES ETC.							E.S.H.F. = $\frac{2.873}{3.015}$ (ERSH) = 0.95 (12.5°C)				
CREDIT FOR THERMAL STORAGE m ² X deg X (-) (-)							DEHUMIDIFIED AIR				
SAFETY FACTOR %							APPARATUS DEWPOINT 12.5 °C				
ROOM SENSIBLE HEAT Sub TOTAL							2873 (ERSH)				
SUPPLY DUCT	SUPPLY DUCT	FAN					(24RM - 17.5ADP)(1 - BF) X 0.29 = 960 CMH				
HEAT GAIN	+ LEAK LOSS	+ HP	= 10%	259	250	256	NOTES				
BYPASS OUTSIDE AIR	50 CMH X 17.7 deg X 0.1 BF X 0.29			26	26	27	GLASS (SE): 1.5 x 2.8 = 4.2				
EFFECTIVE ROOM SENSIBLE HEAT							WALL (SE): 3.25 x 4.0 - 4.2 = 8.8				
ROOM LATENT HEAT							PARTITION: 4.0 x 3.8 = 15.2				
INFILTRATION	CMH X	g/kg X	0.72				ROOF: SR				
PEOPLE	2 PEOPLE X	49		98							
STEAM	kg/h X	540									
APPLIANCES ETC.											
VAPOR TRANS.											
Sub TOTAL											
SAFETY FACTOR %											
ROOM LATENT HEAT Sub TOTAL							98 98 98				
SUPPLY DUCT	LEAKAGE LOSS	10 %		10	10	10					
BYPASS OUTSIDE AIR	CMH X 9.4 g/kg X 0.1 BF X 0.72			34	34	35					
EFFECTIVE ROOM LATENT HEAT							142 142 143				
EFFECTIVE ROOM TOTAL HEAT							3015 2914 2986				
OUTSIDE AIR HEAT							(143)				
SENSIBLE	CMH X	deg X (1 - BF) X 0.29									
LATENT	CMH X	g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT	RETURN DUCT	PUMP	PIPE								
HEAT GAIN	LEAK GAIN	H.P	GAIN	= %							
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INSURING No. _____ INSURED BY _____
 Job NAME _____ ADDRESS _____
 SPACE USED FOR **LIBRARY & STORAGE ROOM (TOZ)** **PAC-2 SYSTEM**
 SIZE **6.5** m X **6.5** m = **42.25** m² X **3.8** m(H) = **160.55** m³

SHEET No. **41**
 DATE ORIGINAL _____
 REVISION _____
 PERSON IN CHARGE _____

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM	
					CORRECTION						
SOLAR GAIN — GLASS				MAX	4:00	2:00	3:00	HOURS OF OPERATION Hour ()			
(SW)	5.4	m ² X 252 x 0.64	685 x 0.94 x 0.65	627	646	685	OUTSIDE DESIGN CONDITIONS CDB CWB %RH				
(SE)	6.9	m ² X 252 x 0.21	685 x 0.94 x 0.65	263	363	700	CONDITIONS DB C WB C %RH DP C E/KG				
		m ² X	X				OUTSIDE	41.7	28.4	78	18.8
		m ² X	X				ROOM	24.0	17.1	50	9.4
		m ² X	X				DIFFERENCE	17.7	X X X	X X X	X X X
SOLAR & TRANS GAIN—WALLS & ROOF							BLIND	NON-EXISTENCE(OUTSIDE,INSIDE) L.M.D.			
WALL (SW)	21.6	m ² X	18.6 X 2.1	805	524	684	GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE			
(SE)	19.1	m ² X	12.4 X 2.1	498	558	518	COLOR	LIGHT, MEDIUM, DARK.			
		m ² X	X				WEIGHT	kg/m ² (FLOOR)		kg/m ² (WALL)	
		m ² X	X				INTERNAL HEAT	W/m ²		m ² /PEOPLE	
ROOF—SUN	36.25	m ² X	26.2 X 1.7	1625	1307	1479	INFILTRATION				
ROOF—SHADED		m ² X	X				SWINGING				
TRANS. GAIN—EXCEPT WALLS & ROOF							REVOLVING DOORS PEOPLEX CMH/PER.				
GLASS	12.3	m ² X	17.7 X 5.1	1111	1111	1142	OPEN DOORS DOORSX CMH/DOOR				
CEILING	6.0	m ² X	8.85 X 1.4	95	95	97	EXHAUST AIR				
FLOOR		m ² X	X				CRACK m X CMH/m				
PARTITION	15.2	m ² X	8.85 X 1.8	243	243	249	INFILTRATION CMH				
							VENTILATION				
							4 PEOPLEX	25 CMH/PER.		100	
INFILTRATION		CMH X	deg X 0.29					m ² X CMH/m ²			
INTERNAL HEAT							VENTILATION CMH				
PEOPLE		4 PEOPLEX	41	164	164	164	SENSIBLE HEAT FACTOR				
KW		KWX X 860					E.S.H.F. = $\frac{7009}{7293}$ (ERSH) = 0.96 (12.6°C)				
LIGHTS		42.25 X 20 WX X 1.08		913	913	913	DEHUMIDIFIED AIR				
APPLIANCES ETC.							APPARATUS DEWPOINT 12.5 °C				
							$\frac{7009}{2.340}$ (ERSH) = 2.340 CMH				
CREDIT FOR THERMAL STORAGE		m ² X	deg X (-)				(24RM-17.5ADP)(1-BF)X0.29				
			Sub TOTAL								
SAFETY FACTOR %							NOTES				
ROOM SENSIBLE HEAT Sub TOTAL				6324	4904	6211	GLASS (SW) : 1.5 x 1.8 x 2 = 5.4				
SUPPLY DUCT		SUPPLY DUCT	FAN				(SE) : 1.5 x 1.8 + 1.5 x 2.8 = 6.9				
HEAT GAIN		+ LEAK LOSS	+ HP = 10%	633	491	622	WALL (SW) : 6.5 x 4.0 x 5.4 = 20.6				
BYPASS OUTSIDE AIR		100 CMH X 17.7 deg X 0.1 BF X 0.29		52	52	53	(SE) : 6.5 x 4.0 x 6.9 = 19.1				
EFFECTIVE ROOM SENSIBLE HEAT				17009	5447	6886	PARTITION : 4.0 x 3.8 = 15.2				
ROOM LATENT HEAT							ROOF : SR - 6.0 = 36.25				
INFILTRATION		CMH X	g/kg X 0.72				CEILING : 3.0 x 2.0 = 6.0				
PEOPLE		4 PEOPLEX	49	196							
STEAM		kg/h X	540								
APPLIANCES ETC.											
VAPOR TRANS.											
			Sub TOTAL								
SAFETY FACTOR X											
ROOM LATENT HEAT Sub TOTAL				196	196	196					
SUPPLY DUCT LEAKAGE LOSS		10 %		20	20	20					
BYPASS OUTSIDE AIR		100 CMH X 9.4 g/kg X 0.1 BF X 0.72		68	68	70					
EFFECTIVE ROOM LATENT HEAT				284	284	286					
EFFECTIVE ROOM TOTAL HEAT				7293	5731	7172					
OUTSIDE AIR HEAT				(173)							
SENSIBLE:		CMH X deg X (1 - BF) X 0.29									
LATENT:		CMH X g/kg X (1 - BF) X 0.72									
GRAND TOTAL HEAT Sub TOTAL											
RETURN DUCT		RETURN DUCT	PUMP PIPE								
HEAT GAIN		LEAK GAIN	H.P. GAIN								
(U.S.R.T) GRAND TOTAL HEAT											

COOLING AND DEHUMIDIFYING ESTIMATE (METRIC)

INQUIRING NO.	INQUIRED BY	SHEET NO. 47
JOB NAME	ADDRESS	DATE ORIGINAL
SPACE USED FOR CORRIDOR (TO4)	PAC-2 SYSTEM	REVISION
SIZE		PERSON IN CHARGE

ITEM	AREA OR QUANTITY	SUN GAIN OR TEMP. DIFF.	FACTOR	Kcal/h			ESTIMATE FOR	AM PM	PEAK LOAD	AM PM
				MAX 4:00	CORRECTION					
SOLAR GAIN - GLASS										
(SW)	4.2 m ²	253 x 0.85 x 0.94 x 0.65		487	503	533	HOURS OF OPERATION	Hour		
	m ²	X					OUTSIDE DESIGN CONDITIONS	CDB	CWB	%RH
	m ²	X					CONDITIONS	DB °C	WB °C	%RH
	m ²	X					OUTSIDE	41.7	28.6	38
	m ²	X					ROOM	24.0	17.1	50
	m ²	X					DIFFERENCE	17.7	X X X	X X X
SOLAR & TRANS GAIN - WALLS & ROOF										
WALL (SW)	5.8 m ²	18.6 X 2.1		227	148	193	BLIND	NON-EXISTENCE (OUTSIDE, INSIDE) L.M.D		
	m ²	X					GLASS	ORDINARY, THICK, ABSORBENT. % DOUBLE		
	m ²	X					COLOR	LGHT. MEDIUM, DARK.		
	m ²	X					WEIGHT	kg/m ² (FLOOR)	kg/m ² (WALL)	
	m ²	X					INTERNAL HEAT	W/m ²	m ² /PEOPLE	
ROOF - SUN	85.25 m ²	26.2 X 1.1		2457	1988	2251	INFILTRATION			
ROOF - SHADED	m ²	X					SWINGING			
TRANS. GAIN - EXCEPT WALLS & ROOF										
GLASS	4.2 m ²	17.7 X 5.1		380	380	390	REVOLVING DOORS PEOPLE X CMH/PER			
CEILING	16.25 m ²	8.85 X 1.4		202	202	207	OPEN DOORS DOORS X CMH/DOOR			
FLOOR	m ²	X					EXHAUST AIR			
PARTITION (1)	30.15 m ²	8.85 X 1.8		481	481	494	CRACK m X CMH/m			
(2)	33.2 m ²	8.85 X 2.5		735	735	756	INFILTRATION CMH			
DOOR	5.4 m ²	8.85 X 1.6		77	77	79	VENTILATION			
INFILTRATION	CMHX	deg X 0.29					PEOPLE X CMH/PER			
INTERNAL HEAT										
PEOPLE	PEOPLE X						m ² X CMH/m ²			
Kw	Kw X	X	860				VENTILATION CMH			
LIGHTS	101.5 X 20 W X		1.08	2193	2193	2193	SENSIBLE HEAT FACTOR			
APPLIANCES ETC.							E.S.H.F. = $\frac{7966 \text{ (ERSH)}}{7966 \text{ (ERTH)}} = 1.0$			
CREDIT FOR THERMAL STORAGE										
	m ²	deg X					DEHUMIDIFIED AIR			
		Sub TOTAL					APPARATUS DEWPOINT 12.5 °C			
SAFETY FACTOR										
		%					7966 (ERSH)			
ROOM SENSIBLE HEAT SUB TOTAL										
				7239	6707	7096	(24 RM - (2.5 ADP) (1 - BF) X 0.29) CMH			
SUPPLY DUCT	SUPPLY DUCT	FAN					NOTES			
HEAT GAIN	+ LEAK LOSS	+ HP = 10%		724	671	710	SR = 2.5 x 32.5 + 2.0 x 2.0 + 6.5 x 2.5 = 101.5			
BYPASS OUTSIDE AIR	CMHX	deg X BF X 0.29					GLASS (SW) : 1.5 x 2.8 = 4.2			
EFFECTIVE ROOM SENSIBLE HEAT										
				71963	7378	7806	WALL (SW) : 2.5 x 4.0 - 4.2 = 5.8			
ROOM LATENT HEAT										
INFILTRATION	CMHX	g/kg X 0.72					PARTITION			
PEOPLE	PEOPLE X						(1) : 13.5 x 2.5 - 3.6 = 30.15			
STEAM	kg/h X	540					(2) : 14.0 x 2.5 - 1.8 = 33.2			
APPLIANCES ETC.							DOOR : 0.9 x 2.0 x 3 = 5.4			
VAPOR TRANS.										
		Sub TOTAL					ROOF : SR - 2.5 x 6.5 = 85.25			
SAFETY FACTOR										
		%					CEILING : 2.5 x 6.5 = 16.25			
ROOM LATENT HEAT SUB TOTAL										
SUPPLY DUCT LEAKAGE LOSS		%								
BYPASS OUTSIDE AIR	CMHX	g/kg X BF X 0.72								
EFFECTIVE ROOM LATENT HEAT										
				71963	7378	7806				
EFFECTIVE ROOM TOTAL HEAT										
OUTSIDE AIR HEAT										
SENSIBLE:	CMHX	deg X (1 - BF) X 0.29								
LATENT:	CMHX	g/kg X (1 - BF) X 0.72								
GRAND TOTAL HEAT SUB TOTAL										
RETURN DUCT	RETURN DUCT	PUMP Pwr								
HEAT GAIN	+ LEAK GAIN	+ H.P. + GAIN								
(U.S.R.T) GRAND TOTAL HEAT										

8.5 設備負荷

5. EQUIPMENT LOAD

5-1 PAC-1

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	: 24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE	: 42.2°C	28.6°C	22.0 kcal/kg
R.S.H	: 119.476	kcal/h	
S.H.F	: 0.94		
DEHUMIDIFIED AIR	: 39.900	m ³ /h	
OUT AIR	: 4.230	m ³ /h	
RETURN AIR	: 35670	m ³ /h	

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{4230 \frac{\text{m}^3}{\text{h}} \times 22.0 \frac{\text{kcal}}{\text{kg}} + 35670 \frac{\text{m}^3}{\text{h}} \times 11.5 \frac{\text{kcal}}{\text{kg}}}{39.900 \frac{\text{m}^3}{\text{h}}}$$

$$= 12.6 \frac{\text{kcal}}{\text{kg}}$$

$$\therefore \left[39.900 \frac{\text{m}^3}{\text{h}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (12.6 - 8.5) \frac{\text{kcal}}{\text{kg}} \times (1 - 0.1) \times 1.05 \right]$$

$$= 185.000 \text{ kcal/h.}$$

① PEAK LOAD (PM. 5:00)

$$\text{E.R.T.H} : 125.721 \text{ kcal/h} \dots \text{①}$$

$$\text{OUT SIDE AIR HEAT} : 4.230 \frac{\text{m}^3}{\text{h}} \times 165 \times (1 - 0.1) \times 0.29 = 18.217 \text{ kcal/h} \text{---} \text{②}$$

$$4.230 \times 9.5 \times (1 - 0.1) \times 0.72 = 26.040 \text{ kcal/h} \text{---} \text{③}$$

$$\text{TOTAL } \text{①} + \text{②} + \text{③} = (125.721 + 18.217 + 26.040) \times 1.05 = 179.000 \text{ kcal/h}$$

PSYCHROMETRIC CHART

ZONE NAME :


SA = 39,900 CMH

OA = 4,330 CMH

RA = 35,670 CMH

MIX. POINT = $\frac{4330 \times 42.5 + 35670 \times 24.0}{39900} = 25.9$

SHE = 0.94



S - 2 PAC - 2

(1) CONDITIONS

	D.B	W.B	ENTHALPY
ROOM	: 24.0°C	17.1°C	11.5 kcal/kg
OUTSIDE	: 42.2°C	28.6°C	22.0 kcal/kg
R.S.H	: 60.067	kcal/h	
S.H.F	: 0.95		
DEHUMIDIFIED AIR	: 20.050	m ³ /h	
OUT AIR	: 1.200	m ³ /h	
RETURN AIR	: 18.850	m ³ /h	

(2) REQUIRED COOLING CAPACITY

$$\text{MIX POINT} = \frac{1200 \frac{\text{m}^3}{\text{h}} \times 22.0 \frac{\text{kcal}}{\text{kg}} + 18.850 \frac{\text{m}^3}{\text{h}} \times 11.5 \frac{\text{kcal}}{\text{kg}}}{20.050 \frac{\text{m}^3}{\text{h}}}$$

$$= 12.1 \frac{\text{kcal}}{\text{kg}}$$

$$\therefore \left[20050 \frac{\text{m}^3}{\text{h}} \times 1.2 \frac{\text{kg}}{\text{m}^3} \times (12.1 - 8.5) \frac{\text{kcal}}{\text{kg}} \times (1 - 0.1) \times 1.05 \right]$$

$$= 82.000 \text{ kcal/h}$$

⊙ PEAK LOAD (PM)

$$\text{E.R.T.H} : 62.391 \text{ kcal/h} \quad \text{--- ①}$$

$$\text{OUT SIDE AIR HEAT} : 1200 \frac{\text{m}^3}{\text{h}} \times 18.2 \times (1 - 0.1) \times 0.29 = 5.701 \text{ kcal/h} \quad \text{②}$$

$$: 1200 \times 9.6 \times (1 - 0.1) \times 0.72 = 7.465 \text{ kcal/h} \quad \text{③}$$

$$\text{TOTAL} = \text{①} + \text{②} + \text{③} = (62.391 + 5.701 + 7.465) \times 1.05 = 80.000 \text{ kcal/h}$$

10/12

PSYCHROMETRIC CHART

ZONE NAME :


SA = 26.050 CM.H

PA = 1.200 CM.H

RA = 18.850 CM.H

$$\text{MIX POINT} = \frac{1.200 \times 42 + 18.850 \times 24}{20050}$$

$$= 24.1$$



10/13

6. SELECTION OF COOLING EQUIPMENT

6-1 EQUIPMENT PAC-1 x 1ea
AIR-COOLED PACKAGED AIR CONDITIONER

AIR FLOW RATE : 39.900 m³/H (665 m³/min)
 COOLING LOAD (T.H.R.) : 179,000 Kcal/H
 (SHC) : 119.476
 EXTERNAL STATIC PRES. : 70 mmA_g
 AIR INLET : 25.9°C DB , 18.4°C WB , 12.6 Kcal/Kg
 OUTLET : 13.8°C DB , 13.2°C WB , 8.9 Kcal/Kg

CONDENSING TEMPERATURE : 50° DB
 TEMPERATURE DIFFERENCE : 15°C

TYPE	: FLOOR (DUCT TYPE)
AIR FLOW RATE	: 39.900 m ³ /H
COMPRESSOR (3ea)	: 83.5 Kw (INPUT)
FAN MOTOR	: 18.5 Kw (IN), 0.75 ^{Kw} x 3 x 3 (OUT)
POWER	: Ø3-380 ^V , 50Hz
TAPPING SIZE	: (1-3/8" + 7/8") x 3, DRAIN 40A
DIMENSION (INDOOR):	3.700 x 1.600 x 2130 ^H (mm)
(OUTDOOR):	2.922 x 1.204 x 1126 ^H x 3
WEIGHT	: (IN) 2.660 Kg, (OUT) 410 Kg x 3

MODEL INDOOR UNIT : 50 BM 100 x 1ea (CARRIER)
 OUTDOOR UNIT : 09 DC 024 x 3ea

$$SHC = 151,000 + 665 \times 17.4 \times (1 - 0.17) \times (24 - 27) = 122,000 \text{ kcal/h}$$

7570

6-2 EQUIPMENT PAC-2 x 1ea

AIR-COOLED PACKAGED AIR CONDITIONER

AIR FLOW RATE : 20.050 m³/H (345 m³/min)COOLING LOAD (T.H.R) : 80.000 Kcal/H
(S.H.C) : 60.067 Kcal/HEXTERNAL STATIC PRES. : 65 mm A₃

AIR INLET : 25.1°C DB, 18.1°C WB, 12.1 Kcal/Kg

OUTLET : 13.8°C DB, 13.2°C WB, 8.9 Kcal/Kg

CONDENSING TEMPERATURE : 50°C DB

TEMPERATURE DIFFERENCE : 15°C

TYPE	: FLOOR (DUCT TYPE)
AIR FLOW RATE	: 20.050 m ³ /H
COMPRESSOR (2ea)	: 45.0 Kw (INPUT)
FAN MOTOR	: 7.5 Kw (IN), 0.3 Kw x 2 x 2 (OUT)
POWER	: Ø3-380 V, 50Hz
TAPPING SIZE	: (1-1/8" + 1-3/8") x 2 . DRAIN 40 A
DIMENSION (INDOOR): (OUTDOOR)	: 2.600 x 1.600 x 1.900 ^H (mm). 1.900 x 1.118 x 1.028 ^H x 2.
WEIGHT	: (IN) 1.550 Kg (OUT) 180 Kg x 2

MODEL INDOOR UNIT : 50BM 054 x 1ea (CARRIER)

OUTDOOR UNIT : 09DE012 x 2ea

$$SHC' = 79.000 + 345 \times 17.4 \times (1 - 0.2) \times (24 - 27) = 64.600 \text{ Kcal/H}$$

7. VENTILATION SYSTEM

7-1 ESTIMATE OF VENTILATION AIR VOLUME

ADMINISTRATION BUILDING (1)

FLOOR	ROOM NAME	AREA (m ²)	VOL. (m ³)	AIR CHANGE (T/Hr)	AIR FLOW (m ³ /Hr)	EXHAUST AIR (m ³ /Hr)	SUPPLY AIR (m ³ /Hr)		
GROUND FLOOR	(G04) MACHINE SHOP	310.	1488	10	14.880	15.000	15.000	OF-1x4 (I) PF-1x4	
	(G05) WELDING ROOM	22.8	109.4	5	547	550	550	OF-3 (I) PF-5	
	(G06) TOOL & SPARE PARTS STORAGE ROOM	35.0	168.0	5	840	840	DG: 840	(III) PF-4	
	(G07) AIR CONDITIONING MACHINE ROOM	84.5	405.6	5	2028	2100	2100	OF-2 (I) PF-2	
	(G08) ELECTRIC ROOM	21.1	101.3	20	2026	2100	2100	OF-2 (I) PF-2	
	(G09) LAVATORY	18.4	46	10	460	460 *	-	(III) VF-4	
	SUB TOTAL					21.050	20590	SA: 1660 RA: 1200 OA: 460	
	FIRST FLOOR	(F15) LAVATORY (MALE)	27.0	67.5	10	675	680 *	2670	(III) VF-2
		(F16) LAVATORY (FEMALE)	9.0	22.5	10	225	230 *	-	(II) VF-6
(F18b) LAVATORY		6.8	17.0	10	170	170 *	-	(II) VF-9	
(F14b) SHOWER BOOTH		3.2	8	10	80	80	-	(III) VF-11	
(F14a) SHOWER BOOTH		3.0	7.5	10	75	80	-	(III) VF-11	
(F12) DRESSING RM.		7.0	17.5	10	175	180 *	-	(III) VF-8	
(F18a) LAVATORY		3.0	7.5	10	75	80 *	-	(III) VF-11	
(F13) KITCHENETTE		6.0	15.0	10	150	150	-	(III) VF-10	
(F17) LAVATORY		7.0	17.5	10	175	180 *	-	(III) VF-8	
(F06) PANTRY		9.0	22.5	10	225	250 *	-	(III) PF-6	
(F08) BATTERY ROOM		16.0	60.8	10	608	610	610	OF-4 (I) VF-3	
(F05) KITCHEN		33.3	83.25	10	833	900 *	700 200	PF-1 (III) VF-7	
SUB TOTAL						3.590		(13380+2400) SA: 18.780 RA: 16.110 OA: 2670	

1046

(2270+400)

ESTIMATE OF VENTILATION AIR VOLUME

ADMINISTRATION BUILDING (2)

50

FLOOR	ROOM NAME	AREA (m ²)	VOL. (m ³)	AIR CHANGE (T/Hr)	AIR FLOW (m ³ /Hr)	EXHAUST AIR (m ³ /Hr)	SUPPLY AIR (m ³ /Hr)	
SECOND FLOOR	(S09) LAVATORY (MALE)	27.0	67.5	10	675	680 *	1250	(III) VF-2
	(S10) LAVATORY (FEMALE)	9.0	22.5	10	225	230 *	-	(III) VF-6
	(S11b) LAVATORY	6.8	17.0	10	170	170 *	-	(III) VF-9
	(S12b) SHOWER BOOTH	3.2	8	10	80	80	-	(III) VF-11
	(S11a) LAVATORY	6.8	17.0	10	170	170 *	-	(III) VF-9
	(S12a) SHOWER BOOTH	3.2	8	10	80	80	-	(III) VF-11
	SUB TOTAL					1.410	-	SA = 16.030 RA = 14.780 OA = 1.250
THIRD FLOOR	(T07) LAVATORY (MALE)	27.0	67.5	10	675	750 *	1050	(III) VF-1
	(T08) LAVATORY (FEMALE)	9.0	22.5	10	225	300 *	-	(III) VF-5
	SUB TOTAL					1050		SA = 23.480 RA = 22.430 OA = 1050
ROOF	(R01) ELEVATOR MACHINE ROOM	27.7	85.9	20	1.718	1800		(III) PF-3
	G. TOTAL							TSA: 59.950 TRA: 54.520 TEA/OA: 5430

10/1

7-2. SELECTION OF VENTILATION EQUIPMENT
V - 1. MACHINE SHOP (GROUND FLOOR)

MACHINE NO PF-1 (=OF-1 x 4 ea)	
TYPE OF VENTILATOR	: PROPELLER x 4 ea
AIR FLOW RATE	: 3750 m ³ /HR ϕ 500 x 5 mm ^{1/8}
FAN MOTOR	: 0.4 KW OR W
POWER	: 1ϕ 220V / 3 ϕ 380 V (50/ 60 Hz)
SIZE	: 620 x 620 x 332 (mm)
ACCESSORY	: SUS WEATHER COVER, SHUTTER

V - 2 ELECTRIC ROOM. (GROUND FLOOR)

MACHINE NO PF-2 (=OF-2 x 1 ea)	
TYPE OF VENTILATOR	: PROPELLER x 1 ea
AIR FLOW RATE	: 2100 m ³ /HR ϕ 400 x 5 mm ^{1/8}
FAN MOTOR	: 0.1 KW OR W
POWER	: 1ϕ 220V / 3 ϕ 380 V (50/ 60 Hz)
SIZE	: 520 x 520 x 268 (mm)
ACCESSORY	: SUS. WEATHER COVER, SHUTTER

V - 3 AIR CONDITONING MACHINE ROOM (GROUND FLOOR)

MACHINE NO PF-2, (=OF-2 x 1 ea)	
TYPE OF VENTILATOR	: PROPELLER x 1 ea
AIR FLOW RATE	: 2100 m ³ /HR ϕ 400 x 5 mm ^{1/8}
FAN MOTOR	: 0.1 KW OR W
POWER	: 1ϕ 220V / 3 ϕ 380 V (50/ 60 Hz)
SIZE	: 520 x 520 x 268 (mm)
ACCESSORY	: SUS WEATHER COVER, SHUTTER

V - 4 WELDING ROOM (GROUND FLOOR)

MACHINE NO	PF-5	(=OF-3 x 1 ea) ↓
TYPE OF VENTILATOR	: PROPELLER	x 1 ea
AIR FLOW RATE	: 550 m ³ /HR	250 ^φ x 5 ^{mm} A ⁸
FAN MOTOR	: 0.025 KW or	w
POWER	: 1φ 220v / 3φ 380v	(50/ 60 Hz)
SIZE	: 370 x 370 x 214	(mm)
ACCESSORY	: SUS WEATHER COVER, SHUTTER	

V - 5. TOOL & SPARE PARTS STORAGE ROOM (GROUND FLOOR)

MACHINE NO	PF-4
TYPE OF VENTILATOR	: PROPELLER x 1 ea
AIR FLOW RATE	: 840 m ³ /HR 300 ^φ x 5 ^{mm} A ⁸
FAN MOTOR	: 0.050 KW or w
POWER	: 1φ 220v / 3φ 380v (50/ 60 Hz)
SIZE	: 420 x 420 x 247 (mm)
ACCESSORY	: SUS WEATHER COVER, SHUTTER

V - 6. LAVATORY (GROUND FLOOR)

MACHINE NO	VF-4
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 460 m ³ /HR x 6 ^{mm} A ⁸
FAN MOTOR	: 3W or 62 w
POWER	: 1φ 220v / 3φ 460v (50/ 60 Hz)
SIZE	: 345 x 345 x 243 ^H (mm)
ACCESSORY	: 150 ^φ VENT CAP

1049

V - 7 LAVATORY (MALE) (FIRST, SECOND FLOOR)

MACHINE NO	VF - 2	
TYPE OF VENTILATOR	: AXIAL FAN	x 2 ea
AIR FLOW RATE	: 680 m ³ /Hr	x 8mmA ₈
FAN MOTOR	: 37 or 40 w	
POWER	: 1ϕ 220v / 3ϕ 460v	(50/ 60 Hz)
SIZE	: 375 ⁺ x (224 ⁺) x 320 ⁻	(mm)
ACCESSORY	:	

V - 8 LAVATORY (MALE) (THIRD FLOOR)

MACHINE NO	VF - 1	
TYPE OF VENTILATOR	: AXIAL FAN	x 1 ea
AIR FLOW RATE	: 750 m ³ /Hr	x 8mmA ₈
FAN MOTOR	: 37 or 40 w	
POWER	: 1ϕ 220v / 3ϕ 460v	(50/ 60 Hz)
SIZE	: 375 ⁺ x (224 ⁺) x 320 ⁻	(mm)
ACCESSORY	:	

V - 9 BATTERY ROOM (FIRST FLOOR)

MACHINE NO	VF - 3	(OF - 4 x 1 ea)
TYPE OF VENTILATOR	: AXIAL FAN	x 1 ea
AIR FLOW RATE	: 610 m ³ /Hr	x 8mmA ₈
FAN MOTOR	: KW or 40 w	
POWER	: 1ϕ 220v / 3ϕ 460v	(50/ 60 Hz)
SIZE	: 375 ⁺ x (224 ⁺) x 320 ⁻	(mm)
ACCESSORY	:	

1050

V - 10

LAVATORY (FEMALE) (FIRST, SECOND FLOOR)

MACHINE NO VF-6	
TYPE OF VENTILATOR	: CEILING x 2 ^{ea}
AIR FLOW RATE	: 230 m ³ /Hr x 7 ^{mm A₈}
FAN MOTOR	: 35 or 35 w
POWER	: 1 ϕ 220v / 3ϕ 460v (50/ 60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 [#] VENT CAP

V - 11

LAVATORY (FEMALE) (THIRD FLOOR)

MACHINE NO VF-5	
TYPE OF VENTILATOR	: CEILING x 1 ^{ea}
AIR FLOW RATE	: 300 m ³ /Hr x 8 ^{mm A₈}
FAN MOTOR	: 35 or 46 w
POWER	: 1 ϕ 220v / 3ϕ 460v (50/ 60 Hz)
SIZE	: 345 x 345 x 243 ^H (mm)
ACCESSORY	: 150 [#] VENT CAP

V - 12

LAVATORY (FIRST, SECOND FLOOR) (F18b) <S11b,a>

MACHINE NO VF-9	
TYPE OF VENTILATOR	: CEILING x 3 ^{ea}
AIR FLOW RATE	: 170 m ³ /Hr x 8 ^{mm A₈}
FAN MOTOR	: 35 or 35 w
POWER	: 1 ϕ 220v / 3ϕ 460v (50/ 60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 [#] VENT CAP

V - 13

SHOWER BOOTH (FIRST, SECOND FLOOR) (F14a, b, S12a, b)

MACHINE NO VF - 11	
TYPE OF VENTILATOR	: CEILING x 4 ea
AIR FLOW RATE	: 80 m ³ /Hr x 8 mm ^{1/8}
FAN MOTOR	: KW or 13 w
POWER	: 1ϕ 220v / 3ϕ 460v (50/60 Hz)
SIZE	: 303 x 303 x 204 ^H (mm)
ACCESSORY	: 100 ^ϕ VENT CAP

V - 14

DRESSING ROOM (FIRST FLOOR)

MACHINE NO VF - 8	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 180 m ³ /Hr x 8 mm ^{1/8}
FAN MOTOR	: KW or 35 w
POWER	: 1ϕ 220v / 3ϕ 460v (50/60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 ^ϕ VENT CAP

V - 15

LAVATORY (FIRST FLOOR) (F18a)

MACHINE NO VF - 11	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 80 m ³ /Hr x 8 mm ^{1/8}
FAN MOTOR	: KW or 13 w
POWER	: 1ϕ 220v / 3ϕ 460v (50/60 Hz)
SIZE	: 303 x 303 x 204 ^H (mm)
ACCESSORY	: 100 ^ϕ VENT CAP

V - 16

KITCHENETE

MACHINE NO VF-10	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 150 m ³ /Hr x 6 mmHg
FAN MOTOR	: 25 or 25 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 303 x 303 x 204H (mm)
ACCESSORY	: 100 ^ø VENT CAP

V - 17

LAVATORY (FIRST FLOOR) <F17>

MACHINE NO VF-8	
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 180 m ³ /Hr x 5 mmHg
FAN MOTOR	: 25 or 35 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 308 x 308 x 243H (mm)
ACCESSORY	: 150 ^ø VENT CAP

V - 18

PANTRY (FIRST FLOOR)

MACHINE NO PF-6	
TYPE OF VENTILATOR	: PROPELLER x 1 ea.
AIR FLOW RATE	: 250 m ³ /Hr 200 ^ø
FAN MOTOR	: 18 or 18 w
POWER	: 1ø 220v / 3ø 460v (50/60 Hz)
SIZE	: 280 x 280 x 152 ^D (mm)
ACCESSORY	: SUS. WEATHER COVER, SHUTTER

1053

V - 19

KITCHEN

MACHINE NO	RF-1
TYPE OF VENTILATOR	: RANGE HOOD FAN x 1 ea
AIR FLOW RATE	: 700 m ³ /Hr x 3 mmA ⁸
FAN MOTOR	: 1/2 KW or 70 w
POWER	: 1 ϕ 220v / 3ϕ 460v (50/60 Hz)
SIZE	: 600 x x 580 ^H (mm)
ACCESSORY	: SUS WEATHER COVER

V - 20

KITCHEN

MACHINE NO	VF-7
TYPE OF VENTILATOR	: CEILING x 1 ea
AIR FLOW RATE	: 200 m ³ /Hr x 8 mmA ⁸
FAN MOTOR	: KW or 35 w
POWER	: 1 ϕ 220v / 3ϕ 460v (50/60 Hz)
SIZE	: 308 x 308 x 243 ^H (mm)
ACCESSORY	: 150 ϕ VENT CAP

V - 21

ELEVATOR MACHINE ROOM

MACHINE NO	PF-3
TYPE OF VENTILATOR	: PROPELLER x 1 ea
AIR FLOW RATE	: 1800 m ³ /Hr ϕ 400 x 5 mmA ⁸
FAN MOTOR	: 0.1 KW or w
POWER	: 1ϕ 220v / 3 ϕ 380v (50/60 Hz)
SIZE	: 520 x 520 x 268 (mm)
ACCESSORY	: SUS WEATHER COVER, SHUTTER

750

V - 22

RETURN FAN (G. FLOOR AIR CONDITIONING MACHINE RM.)

MACHINE NO	RAF-1	SS#7		
TYPE OF VENTILATOR	:	CENTRIFUGAL MULTI-BANE	x /	ea
AIR FLOW RATE	:	54.520 m ³ /Hr	x 25	mm ²
FAN MOTOR	:	15 KW or	w	
POWER	:	1φ 220v / 3φ 380v	(50/60 Hz)	
SIZE	:	2500 ^L x 900 ^W x 2070 ^H		(mm)
ACCESSORY	:			

V -

MACHINE NO	:			
TYPE OF VENTILATOR	:		x	ea
AIR FLOW RATE	:	m ³ /Hr		
FAN MOTOR	:	KW or	w	
POWER	:	1φ 220v / 3φ	v (50/60 Hz)	
SIZE	:	x	x	(mm)
ACCESSORY	:			

V -

MACHINE NO	:			
TYPE OF VENTILATOR	:		x	ea
AIR FLOW RATE	:	m ³ /Hr		
FAN MOTOR	:	KW or	w	
POWER	:	1φ 220v / 3φ	v (50/60 Hz)	
SIZE	:	x	x	(mm)
ACCESSORY	:			

1055

