

## CV-1 CIVIL DESIGN CONDITION

### 1. Design Condition

#### 1) Sea water level

- a) The Highest High Water Level (The Highest Astronomical Tide is adopted as design H.H.W.L)

$$\text{H.H.W.L} = \text{E.L} + 3.23 \text{ m}$$

- b) Mean Sea Water Level

$$\text{M.S.L} = \text{E.L} + 1.64 \text{ m}$$

- c) The Lowest Low Water Level (The lowest Astronomical Tide is adopted as design L.L.W.L)

$$\text{L.L.W.L} = \text{E.L} - 0.43 \text{ m}$$

#### 2) Wind load

The design wind loads are indicated in the design concept of architectural/structural section, if necessary.

#### 3) Ground level (G.L)

$$\text{G.L.} = \text{E.L} + 4.80 \text{ m}$$

## 4) Soil condition

The soil physical values shall be determined at the normal cases as follows.

## a) The N - Value

The N - Value shall be adopted from the site boring test.

b) The angle of the internal friction  $\phi$ 

In the case of sandy soil, the angle of the internal friction  $\phi$  shall be calculated by the following equation.

$$\phi = 15 + \sqrt{15N} \leq 45^\circ \quad \text{provided that } N > 5$$

## 2. Design load

1) Composite vertical load	The increment ratio
a) Long term ( D.L + L.L )	1.0
b) Short term ( D.L + L.L + W.L )	1.25
c) Short term ( D.L + S.L )	1.50

Where	D.L :	Dead load
	L.L :	Live load
	W.L :	Wind load
	S.L :	Seismic load

## 2) Seismic load ( S.L )

$$F_w = K_h \cdot W$$

Where  $K_h$  : Seismic coefficient = 0.1

W : Weight of structure included dead load.



## 3. Hydrographic calculation

## 1) The Summary of the water head loss

Table 2. Example of the loss in water channel

Equipment	Loss
Intake	<ul style="list-style-type: none"> <li>① Loss due to inflow curtain.</li> <li>② Loss due to friction between intake.</li> </ul>
Intake Channel	<ul style="list-style-type: none"> <li>① Loss due to inflow at intake channel</li> <li>② Loss due to friction of water channel wall</li> <li>③ Loss due to water channel's cross sectional change (Gradual contractin and gradual expansion) and bend, etc.)</li> <li>④ Loss due to water channel's accessory machineries and structures.</li> </ul>
Screen Pump Pit	<ul style="list-style-type: none"> <li>① Loss due to inflow at Screen Room</li> <li>② Loss due to Screens</li> <li>③ Loss due to inflow at Pump Room</li> <li>④ Loss due to room wall friction</li> </ul>
Discharge Channel	<ul style="list-style-type: none"> <li>① Loss due to outlet conduit and discharge culvert</li> <li>② Loss due to the wall friction of channel</li> <li>③ Loss due to water channel's sectional change (gradual contraction, gradual expansion)</li> <li>④ Loss due to water channel's accessory (machineries and structures)</li> </ul>
Outlet	<ul style="list-style-type: none"> <li>① Loss due to outlet's exit</li> <li>② Loss due to the friction of water channel wall</li> <li>③ Loss due to water channel's sectional change (gradual expansion, etc)</li> <li>④ Loss due to water channel's necessary structures, such as hiden wier, pier, etc.</li> </ul>

## 2) The coefficient of roughness

The values given in Table 2 are used as the standard coefficients of the roughness used for hydrographic calculation of a water channel.

Table 2. The coefficient of the roughness used for water channel

Wall shape	n	Wall shape	n
Welded steel pipe	0.012	Ordinary concrete with shells stuck	0.02
Good concrete surface such as centrifugal force steel reinforced concrete pipe	0.013	Steel plate	0.02
Ordinary concrete such as cast-in-field concrete	0.015	Other especially rough surface	0.03
Concrete block	0.02		

## 4. The Allowable Unit Stress

1) The allowable unit stress of reinforced concrete ( kg/cm<sup>2</sup> )

Stresses		Permanent Stresses			
		Compression	Shear		Bond
			(1)	(2)	
Concretes					
Concrete for (above) C-400	plain bar	130	5.5	24	10
	Deformed bar		(slab) 11		20
Concrete for C-300	Plain bar	100	5	22	9
	Deformed bar		(slab) 10		18
Concrete for C-240	Plain bar	80	4.5	20	8
	Deformed bar		(slab) 9.0		16
Concrete for C-210	Plain bar	70	4.25	19	7.5
	Deformed bar		(slab) 8.5		15
Concrete for C-180	Plain bar	60	4	18	7
	Deformed bar		(slab) 8		14

\*Remarks (1):No calculating with diagonal tention bar.

(2):Calculating with diagonal tention bar.

2) The allowable unit stress of reinforcing bars ( kg/cm<sup>2</sup> )

Materials \ Stresses	Permanent stresses	
	Tension	Compression
SD 30	1,800	1,800
SD 35	1,800	2,000
SD 30 for Pile	1,600	1,800

3) The allowable unit stress of steel ( kg/cm<sup>2</sup> )

Type of Steel	Permanent Stresses		
	Tension	Compression	Shear
SS 41 SM 41	1,400	1,400	800

4) The allowable unit stress of welded joint ( kg/cm<sup>2</sup> )

Appli- cation	Stresses	Permanent Stresses			
	Welding Positions	Groove Weld			Fillet
	Materials	Tension	Compress	Shear	Shear
	( SS41,SM41 )	1,400	1,400	800	800

1062

5) The young's modulus of concrete

a) At the case of the displacement calculation

CK( kg/cm <sup>2</sup> )	180	240	270	300
E <sub>c</sub> ( kg/cm <sup>2</sup> )	$2.2 \times 10^5$	$2.5 \times 10^5$	$2.65 \times 10^5$	$2.8 \times 10^5$

b) At the case of the unit stress calculation

$$E_c = 1.4 \times 10^5 \text{ ( kg/cm}^2 \text{ )}$$



## 5. Applicable Standards

### 1) Japan Society of Civil Engineers

- a) Standards for Calculation of Reinforced Concrete Structures
- b) Design Standards for Steel Structures
- c) Standards for Structural Design of Building Foundations

### 2) Japan Road Association

Specifications for Highway Bridges

### 3) Japan Port and Harbour Research Institute

Technical Standards for Port and Harbour Facilities

### 4) Standards of Architectural Institute of Japan

Standard Specification for Concrete

### 5) Japanese Industrial Standards ( JIS )

7901



CV-2 THE BASIC DATA FROM THE STUDY OF HYDRAULICS AT THE COOING  
WATER WAY

Contents of this note is shown as below.


Contents

1. Intake Open Channel .....	2
2. Pump Pit .....	7

1. Intake Open Channel

Outline of Intake Open Channel is shown in Fig 1, Fig 2.

The bases of the dimensional data are explained as follows.



Unit: m

Fig 1. Typical section of Intake Open Channel

1006




Fig 2. Plan of Intake Open Channel

a. The ground level (EL. +4.8m)

The ground level was determined in "Civil Design Conditon" (vid.1.3,P1, ENGINEERING SHEET No.EWC-1001), so the site ground shall be leveled at EL. +4.8m.

b. The highest high water level (EL. +2.78m)

This level was determined in consideration of the water head loss due to Intake Culvert (vid.3.1).a), P11, ENGINEERING SHEET No.EWC-1003) at the highest high sea water level (EL. +3.23m), so the calculation is as follows.

↓  
(vid.1.1).a,P1,EWC-1001).

[H.H.W.L.]	(The head loss due to culvert)	
EL. +3.23m	- 0.45m	= EL. +2.78m

199

## c. The lowest low water level(EL. -0.88m)

This level was determined in consideration of the water head loss due to Intake Culvert at the lowest low water level(EL. -0.43m).

↓  
(vid.1.1).c,EWC-1001)

The Calculation is as follows.

$$\begin{array}{rcll} \text{[L.L.W.L]} & \text{(The head loss due to Intake Culvert)} & & \\ \text{EL. -0.43m} & - & 0.45\text{m} & = \underline{\text{EL. -0.88m}} \end{array}$$

d. The level of the bottom floor of Intake Open Channel  
(EL. -4.00m)

The level of bottom floor was determined in accordance with the bottom floor level of existing Intake Culvert (EL. -1.3feet  $\approx$  EL. -4.0m) as shown in Fig 3.

## e. The width of Intake Open Channel(= 3m)

The width of Intake Open Channel was determined to limit the water velocity less than  $V = 1.0$  m/sec at L.L.W.L.


The calculation is considered for the shells stuck 10cm.

(vid.Fig 4,P10,EWC-1003)

$$V = \frac{Q_1}{A} = \frac{5.2\text{m}^3}{(3.0 - 2 \times 0.1) \times (3.12 - 0.1)} = 0.61 \text{ m/sec} < 1.0 \text{ m/sec}$$


## f. The distance between the rails of the freight train and the center line of temporary retaining wall(steel sheet pile).

The distance was determined to avoid the influence area occurred by the relaxation of the back ground of retaining wall.



LOCATION PLAN. Scale: 1 inch = 50 feet

- NOTES**
1. All concrete is 1:2:4 mix unless otherwise stated.
  2. Extent of works under New Contract denoted thus: [Symbol]
  3. Extent of K.P.T.'s work denoted thus: [Symbol]
  4. All dowel bars grouted into 1 1/2" diameter holes by 3'-0" long drilled into existing concrete. Grout to be 2:1 sand cement mortar with admixture of an approved expanding agent.
  5. Dimensions denoted thus \* to be checked at site.







The section of the influence area occurred by the relaxation of the back ground is shown in Fig 4.





Fig 4. The influence area of the relaxation of the back ground

1070

2. Pump pit

Outline of Pump Pit is shown in Fig 5, Fig 6.

The bases of the dimensional data are explained as follows.



Unit : m

Fig 5. Plan of Pump Pit

1071




Fig 6. Profile of Pump Pit

1072

a. The internal width of Pump Room and Screen Room.

The internal width of Pump Room was determined by the following relations.

i) by the data from Table 1.

Let the width is B,

$$2.0 D_o \leq B \leq 2.5 D_o$$

$$3.6m \leq B \leq 4.5m$$

Where  $D_o$  : the diameter of C.W Pump's bellmouth = 1.8m

ii) by the limit of the approach velocity

The approach velocity to bar screen  $V_1$  is usually controlled by the following relation.

The internal width of Screen Room is determined by the approach velocity to bar screen, then the approach velocity  $V_1$  is restricted by the following relation.

$$V_1 \leq \frac{0.375 \text{ m/sec}}{\downarrow}$$

(vid. Table 1)

In this design case  $V_1$  is calculated as follows.


$$V_1 = \frac{Q}{A} = \frac{4.75}{4.3 \times 3.02} = 0.37 \text{ m/sec} < 0.375 \text{ m/sec}$$

According to the above mentioned relation, the internal width was determined

$$B_1 = 4.5m$$

Table 1. The compared table with the usual and the recommended dimensional data of Pump Pit

No	Items	The usual value	The recommended value	Remarks
1	The diameter of Bellmouth :Do	/	Do=1800mm	
2	The width of Pump Room :B	B=2.0~2.5Do	B = 4500mm	
3	The distance between Bellmouth and the bottom floor :Y	B=0.5~0.75Do	Y = 900mm	Y = 0.5Do
4	The distance between the center of Pump and the back wall :Z	Z=0.8~1.0Do	Z = 1800mm	The preventive wall for vortex was designed
5	The submerged depth:Sc	Sc $\geq$ 1.5Do	Sc= 2700mm	
6	The approach velocity to Pump and Screen :V <sub>2</sub>	V <sub>2</sub> $\leq$ 0.375m/sec	/	In this design case V <sub>2</sub> = 0.28 m/sec
7	The distance between the Center of Pump and the mound :A	A $\geq$ 6.0Do	A $\geq$ 10.8m	
8	The height of mound:Hm	Hm $\leq$ 0.8Do	Hm $\leq$ 1.44m	



The reference drawing

## b. The length of Pump Pit

The length of Pump Pit is determined by the site layout plan.  
(vid. DWG No WGTS-1002)

## c. The lowest low water level (EL. -0.88m)

This water level was the same level as Intake Open Channel.

## d. The lowest side level of curtain wall

The lowest side level of curtain wall is calculated as follows.

$$\begin{array}{rcl} \text{[L.L.W.L]} & \text{(the allowance)} & \\ \text{EL. -0.88m} & - 0.52\text{m} & = \underline{\text{EL. -1.40 m}} \end{array}$$

## e. The bottom floor level of Screen Room

The bottom floor level of Screen Room was determined in accordance with the bottom floor level of Intake Open Channel (vid. Fig 1), accordingly this level was setted up at EL. -4.00m.

## f. The bottom floor level of Pump Room

The bottom floor level of Pump Room was determined by the height of the back wall of Pump Room, and the height of the back wall of Pump Room  $H_b$  was determined by the following relation.

$$H_b = S_c + Y \cong 1.5D_o = 1.5 \times 1.8 + 0.5 \times 1.8 = \underline{3.6\text{m}}$$

accordingly  $H_b$  was determined  $H_b = 4.0\text{m}$ , so the bottom floor level was calculated as below.

$$\begin{array}{rcl} \text{(The lower side level of Pump Room)} & \text{[H}_b\text{]} & \\ \text{EL. -1.20m} & - 4.0\text{m} & = \underline{\text{EL. -5.2m}} \end{array}$$

- g. The setting angle between Bar Screen and the bottom floor.

The setting angle of Bar Screen was determined by the reference of "Design for the Civil Structures of Thermal Power Plant and Nuclear Power Plant" published by The Society of Electric Power Civil Technology, Japan. (vid.12-10-3,P435)

- h. A difference in level between the bottom of Screen Room and that of Pump Room.

This difference in level  $H_m$  was determined by the following relation. (vid.Item No 8 in Table 1)

$$H_m = 1.2m \leq 0.8D_o = 0.8 \times 1.8m = 1.44m$$

- i. The horizontal length of the slope

The horizontal length of the slope  $A$  was determined by the following relation to the distance between the vertical center of Pump and mound. (vid.Item No 8 in Table 1)

$$A = 21.75m \geq 6.00D_o = 10.8m$$

- j. The approach velocity to Pump

The approach velocity to Pump  $V_2$  is calculated by the following equation.

$$V_2 = \frac{Q}{A} = \frac{4.5}{4.3 \times 3.8} \doteq 0.28 \text{ m/sec} \leq \frac{0.375\text{m/sec}}{\downarrow}$$

(vid.Item No 6 in Table 1)

- k. The dimensional data of the protection wall for vortex

The dimensional data of the protection wall for vortex was determined by the reference data from the mechanical design structure.





## CV-3 HYDROGRAPHIC CALCULATION

Contents of this calculation note is shown as below.

### Contents


1. The Results of Hydrographic Calculation .....	2
2. Design Condition .....	5
3. The Calculation of The Water Head Loss .....	11
1) Intake Tunnel .....	11
2) Intake Open Channel .....	14
3) Pump Pit .....	15
4) Discharge Tunnel .....	18
5) Outlet .....	21

1977

### 1. The Results of Hydrographic Calculation

Hydrographic calculation is executed to determine the water head of circulating water pump and the water head loss of condenser cooling water way.  
The results of hydrographic calculation are shown in Fig 1. and Fig 2.


Fig 1. The Results of Hydrographic Calculation  
(UNIT 1)



NOTE  
 V: Water velocity (m/sec)  
 Q: Quantity of water (m<sup>3</sup>/sec)

1078

Fig 2: The Results of Hydrographic Calculator  
(UNIT II)



NOTE  
 V: Water velocity (m/sec)  
 Q: Quantity of water (m<sup>3</sup>/sec)

2801

2. Design Condition

1) Water level

All calculations are executed at the lowest low water level.

L.L.W.L : E.L. - 0.43 m

2) The coefficient of roughness

a) Ordinary concrete such as cast-in-field concrete

the roughness :  $n = 0.015$

b) Ordinary concrete with shells stuck

the roughness :  $n = 0.02$

3) The quantity calculation of Intake structures

The water flow chart of Intake structures are shown in Fig 3.




Fig 3. The water flow chart of Intake structures

1801

Quantities of Intake structures  $Q_1$  are determined to solve the following equations.

$$2Q = Q_1 + Q_2 = 19.0 \text{ m}^3 \quad \text{_____} \quad \textcircled{1}$$

$$Q = Q_2 + Q_3 = 9.5 \text{ m}^3 \quad \text{_____} \quad \textcircled{2}$$

$$Q_3 = Q_1 - Q = Q_1 - 9.5 \text{ m}^3 \quad \text{_____} \quad \textcircled{3}$$


$$h_2 + h_4 = h_1 + h_3 \quad \text{_____} \quad \textcircled{4}$$

provided that  $Q_1 \leq 2Q$   
 $Q_2, Q_3 \leq Q$

Where  $Q_1$  : Quantity of culvert tunnel [m<sup>3</sup>/sec]  
 $Q_2$  : Quantity of concrete pipes [m<sup>3</sup>/sec]  
 [Three pipes located]  
 $Q_3$  : Quantity of Intake Open Channel (at culvert side) [m<sup>3</sup>/sec]  
 $Q_4$  : Quantity of Intake Open Channel (at concrete pipe side) [m<sup>3</sup>/sec]

a) The water head loss of Intake Culvert  $h_1$

typical section of culvert



$S$  : the wet perimeter [m]

$A$  : the area [m<sup>2</sup>]

$R$  : the hydrographic mean level [m]

Shell deposits 10cm is considered for calculation.

$$S = 4 \times (3.0 - 0.2) = 11.2 \text{ m}$$

$$A = 2.8 \times 2.8 = 7.84 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{7.84}{11.2} = 0.7 \text{ m}$$

1002

i) The head loss due to inflow  $h_{e1}$ ,

$$V = \frac{Q_1}{A} = \frac{Q_1}{7.84} = 0.1276 Q_1$$

$$h_{e1} = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{(0.1276 Q_1)^2}{2 \times 9.8} = 0.0004 Q_1^2$$

Where  $f_e$  : the coefficient of the inflow loss = 0.5

ii) The head loss due to the wall surface friction  $h_{r1}$

$$h_{r1} = \frac{Q_1^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{Q_1^2 \cdot 0.02^2 \cdot 155}{7.84^2 \times 0.7^{4/3}} = 0.0016 Q_1^2$$

iii) The head loss due to bend  $h_{b1}$

$$h_{b1} = f_{b1} \cdot \frac{v^2}{2g} = 0.073 \times \frac{(0.1276 Q_1)^2}{2 \times 9.8} = 0.0001 Q_1^2$$


Where  $f_{b1}$  : the coefficient of the bend loss = 0.073

Accordingly the head loss due to Intake Culvert is calculated as hereinafter.

$$h_1 = h_{e1} + h_{r1} + h_{b1} = (0.0004 + 0.0016 + 0.0001) Q_1^2 = 0.0021 Q_1^2$$

b) The water head loss due to Intake Concrete Pipes  $h_2$

typical section of concrete pipe



Shell deposits 10cm is considered for the calculation.

$$S = \pi \times (1.5 - 2 \times 0.1) = 4.08 \text{ m}$$

$$A = \frac{1}{4} \times \pi \times 1.3^2 = 1.33 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{1.33}{4.08} = 0.326 \text{ m}$$

i) The head loss due to inflow  $h_{e2}$

$$V = \frac{Q_2}{3A} = \frac{Q_2}{1.33 \times 3} = 0.2506 Q_2$$

$$h_{e2} = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{(0.2506 Q_2)^2}{2 \times 9.8} = 0.0016 Q_2^2$$

Where  $f_e$  : the coefficient of the inflow loss = 0.5

ii) The head loss due to the wall surface friction  $h_{f2}$

$$h_{f2} = \frac{Q_2^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{(Q_2/3)^2 \cdot 0.02^2 \cdot 200}{1.33^2 \cdot 0.326^{4/3}} = 0.0224 Q_2^2$$

iii) The head loss due to the bend loss  $h_{b2}$

$$h_{b2} = 2 \cdot f_b \cdot \frac{v^2}{2g} = 2 \times 0.073 \times \frac{(0.2506 Q_2)^2}{2 \times 9.8} = 0.0005 Q_2^2$$

Accordingly the head loss of Intake Pipe Tunnel is calculated as hereinafter.


$$\begin{aligned} h_2 &= h_{e2} + h_{f2} + h_{b2} = 0.0016Q_2^2 + 0.0224Q_2^2 + 0.0005Q_2^2 = 0.0245Q_2^2 \\ &= 0.0245(19.0 - Q_1)^2 \end{aligned}$$

1024



c) The water head loss due to Intake Open Channel [ at culvert side ]

the section of Intake Open Channel



Shall deposits 10cm are considered for the calculation

$$S = 2 \times 3.47 + (3 - 2 \times 0.1) = 9.74 \text{ m}$$

$$A = 2.8 \times 3.47 = 9.72 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{9.72}{9.74} = 1.00 \text{ m}$$

The head loss  $h_3$  is the same as the head loss due to the wall surface friction.

$$h_3 = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{Q_3^2 \times 0.02^2 \times 66}{9.72^2 \times 1.0^{4/3}} = 0.0003 Q_3^2 = 0.0003 (Q_1 - 9.5)^2$$

d) The water head loss due to Intake Open Channel  $h_4$  [ at concrete pipe side ]

The section and the process of calculation are the same as C), therefore

$$h_4 = \frac{Q_2^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{Q_2^2 \times 0.02^2 \times 32}{9.72^2 \times 1.0^{4/3}} = 0.0001 Q_2^2 = 0.0001 (19.0 - Q_1)^2$$

Above calculated the head losses are substituted into the previous equation ④ here.

$$(0.0245 + 0.0001) (19.0 - Q_1)^2 = 0.0021 Q_1^2 + 0.0003 (Q_1 - 9.5)^2$$

$$0.0246(Q_1^2 - 38Q_1 + 361) = 0.0024Q_1^2 - 0.0057Q_1 + 0.0271$$

$$0.0222 Q_1^2 - 0.9291 Q_1 + 8.8535 = 0$$

$Q_1$  is determined by solving the above equation.

$$\underline{Q_1 = 14.7 \text{ m}^3/\text{sec}}$$

Accordingly other quantities are calculated as hereinafter.

$$\begin{aligned} Q_2 &= 19.0 - Q_1 \\ &= 19.0 - 14.7 \\ &= \underline{4.3 \text{ m}^3/\text{sec}} \end{aligned}$$

$$\begin{aligned} Q_3 &= 9.5 - Q_2 \\ &= 9.5 - 4.3 \\ &= \underline{5.2 \text{ m}^3/\text{sec}} \end{aligned}$$

3. The Calculation of The Water Head Loss

1) Intake Tunnel





Fig 4. The water flow diagram

a) The head loss due to existing culvert  $h_1$

The sectional dimensions S, A and R are calculated as hereinafter

Shell deposits 10cm is considered for calculations.

typical section of Culvert



S : the wet perimeter

$$S = 4 \times (3.0 - 0.2) = 11.2 \text{ m}$$

A : the area

$$A = 2.8 \times 2.8 = 7.84 \text{ m}^2$$

R : the hydrographic mean depth

$$R = \frac{A}{S} = \frac{7.84}{11.2} = 0.7 \text{ m}$$

i) The head loss due to inflow  $h_e$

$$V = \frac{Q}{A} = \frac{14.7}{7.84} = 1.88 \text{ m/sec}$$

The head loss  $h_e$

$$h_e = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{1.88^2}{2 \times 9.8} = 0.09 \text{ m}$$

Where  $f_e$  : the coefficient of the inflow loss = 0.5

2801

ii) The head loss due to the wall surface friction  $h_f$

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{14.7^2 \times 0.02^2 \times 155}{7.84^2 \times 0.7^{4/3}} = \underline{0.351 \text{ m}}$$

iii) The head loss due to bend  $h_{be}$

$$h_{be} = f_{be} \cdot \frac{v^2}{2g} = 0.073 \times \frac{1.88^2}{2 \times 9.8} = \underline{0.013 \text{ m}}$$

Where  $f_b$  : the coefficient of the bend loss = 0.073  
( the angle of bend =  $30^\circ$  )


Accordingly calculating culvert tunnel's head loss  $h_1$

$$h_1 = h_e + h_f + h_{be} = 0.09 + 0.351 + 0.013 = \underline{0.454 \text{ m}}$$

b) The head loss due to Intake pipes  $h_2$

The sectional dimensions  $S$ ,  $A$  and  $R$  are calculated as hereinafter.

the section of concrete pipe



Shell deposits 10cm is considered for calculation.

$$S = \pi \times (1.5 - 2 \times 0.1) = 4.08 \text{ m}$$

$$A = \frac{1}{4} \times \pi \times 1.3^2 = 1.33 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{1.33}{4.08} = 0.326 \text{ m}$$

i) The head loss due to inflow  $h_e$

$$v = \frac{Q}{A} = \frac{1/3 \times 4.3}{1.33} = 1.08 \text{ m/sec}$$

$$h_e = f_e \cdot \frac{v^2}{2g} = 0.5 \times \frac{1.08^2}{2 \times 9.8} = \underline{0.030 \text{ m}}$$

ii) The head loss due to the wall surface friction  $h_f$

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{1.43^2 \times 0.02^2 \times 200}{1.33^2 \times 0.326^{4/3}} = \underline{0.412 \text{ m}}$$

iii) The head loss due to bend  $h_{be}$

$$h_{be} = f_{be} \cdot \frac{v^2}{2g} = 0.073 \times \frac{1.08^2}{2 \times 9.8} = \underline{0.004 \text{ m}}$$


Accordingly calculating the head loss  $h_2$

$$h_2 = h_e + h_f + h_{be} = 0.03 + 0.412 + 0.004 = \underline{0.446 \text{ m}}$$

## 2) Intake Open Channel

a) The water head loss ( at culvert side )  $h_3$ 

the section of Intake Open Channel



Shell deposits 10 cm is considered for the calculations.

$$S = 2 \times 3.02 + (3 - 2 \times 0.1) = 8.84 \text{ m}$$

$$A = 2.8 \times 3.02 = 8.46 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{8.46}{8.84} = 0.96 \text{ m}$$

The head loss  $h_3$  is the same as the head loss due to the wall surface friction.

$$h_3 = \frac{Q_3^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{5.2^2 \times 0.02^2 \times 66}{8.46^2 \times 0.96^{4/3}} = \underline{0.010 \text{ m}}$$


b) The head loss ( at pipe side )  $h_4$ 

The process of calculation is the same as a).

$$h_4 = \frac{Q_3^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.3^2 \times 0.02^2 \times 32}{8.46^2 \times 0.96^{4/3}} = \underline{0.003 \text{ m}}$$

3) Pump Pit

a) The head loss due to curtain wall  $h_c$  the section of the entrance



Shell deposits 10cm are considered for the calculation.

$$A = 4.3 \times 2.4 = 10.32 \text{ m}^2$$

$$Q = \frac{1}{2} \times 9.5 = 4.75 \text{ m}^3/\text{sec}$$


$$V = \frac{Q}{A} = \frac{4.75}{10.32} = 0.46 \text{ m/sec}$$

$$h_c = \frac{Q^2}{C^2 \cdot A^2 \cdot 2g} - \frac{V^2}{2g} = \frac{4.75^2}{0.5^2 \times 10.32^2 \times 2 \times 9.8} - \frac{0.46^2}{2 \times 9.8} = 0.03 \text{ m}$$

where

C : the inflow coefficient = 0.5

b) The head loss due to the wall surface friction  $h_{f1}$  the section of Screen Room



Shell deposits 10cm are considered for the calculation.


$$A = 4.3 \times 3.02 = 12.99 \text{ m}^2$$

$$S = 2 \times 3.02 + 4.3 = 10.34 \text{ m}$$

$$R = \frac{A}{S} = \frac{12.99}{10.34} = 1.26 \text{ m}$$

$$h_{f1} = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.75^2 \times 0.02^2 \times 13}{12.99^2 \times 1.26^{4/3}} = 0.0005 \text{ m}$$

the mean section of Connected Culvert



Shell deposits 10cm are considered for the calculation.

$$A = 4.3 \times 3.2 = 14.72 \text{ m}^2$$

$$S = 2 \times (3.2 + 4.6) = 15.6 \text{ m}$$

$$R = \frac{A}{S} = \frac{14.72}{15.6} = 0.94 \text{ m}$$

$$h_{r2} = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.75^2 \times 0.02^2 \times 23}{14.72^2 \times 0.94^{4/3}} = 0.001 \text{ m}$$

Accordingly  $h_r$  is calculated as follows.

$$h_r = h_{r1} + h_{r2} = 0.0005 + 0.001 = 0.0015$$

c) The head loss due to bar screen  $h_{ba}$

The approach velocity to bar screen  $V_a$

$$V_a = \frac{Q}{A} = \frac{4.75}{12.99} = 0.37 \text{ m/sec} < 0.40 \text{ m/sec}$$

Therefore the head loss  $h_{ba}$  is assumed to be 0.03 m.

(The above value 0.03 m/sec is regulated by U.S Bureau of Reclamation.)

d) The head loss due to traveling screen  $h_{tr}$

According to Fig 5, the head loss  $h_{tr}$  is assumed to be 0.10 m for the cleanliness factor 60% of screen.


Therefore the head loss due to Pump Pit  $h_p$  is calculated as follows.

$$h_p = h_c + h_r + h_{ba} + h_{tr} = 0.03 + 0.0015 + 0.03 + 0.1 = 0.162 \text{ m}$$



Fig. 5 Travelling Screen

Pass per centage of sea water and the head loss.



Note: 100% of pass per centage of sea water means the most clean state of screen; where has no dirt.

10 cm

10933

4) Discharge Tunnel (culvert)

The head losses due to culvert tunnels are calculated as hereinunder excluding the head loss of connected steel pipe for condenser.





Fig 6. Plan of Discharge Tunnels

a) Discharge tunnel for Unit I

the section of discharge tunnel



$$S = 4 \times 2.2 = 8.8 \text{ m}$$

$$A = 2.2 \times 2.2 = 4.84 \text{ m}^2$$

$$R = \frac{A}{S} = \frac{4.84}{8.8} = 0.55 \text{ m}$$

$$V = \frac{9.5}{4.84} = 1.96 \text{ m/sec}$$

1084

i) The head loss due to the water surface friction  $h_f$

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{9.5^2 \times 0.015^2 \times 440}{4.84^2 \times 0.55^{4/3}} = \underline{0.846 \text{ m}}$$

ii) The head loss due to double curves of the same type  $h_{cu}$

$$\begin{aligned} h_{cu} &= 2 \times \left\{ \left( 0.131 + 0.1632 \left( \frac{D}{\rho_1} \right)^{3.5} \right) \left( \frac{90^\circ}{90^\circ} \right) \right. \\ &\quad \left. + \left\{ \left( 0.131 + 0.1632 \left( \frac{D}{\rho_2} \right)^{3.5} \right) \left( \frac{90^\circ}{90^\circ} \right) \right\} \cdot \frac{V^2}{2g} \right. \\ &= 2 \times \left\{ \left( 0.131 + 0.1632 \left( \frac{2.48}{8} \right)^{3.5} \right) \left( \frac{90^\circ}{90^\circ} \right) \right. \\ &\quad \left. + \left\{ \left( 0.131 + 0.1632 \left( \frac{2.48}{10.6} \right)^{3.5} \right) \left( \frac{90^\circ}{90^\circ} \right) \right\} \times \frac{1.96^2}{2 \times 9.8} \right. \\ &= \underline{0.104 \text{ m}} \end{aligned}$$

Where  $\rho$  : the radius of curvature  $\rho_1 = 8 \text{ m}$   $\rho_2 = 10.6 \text{ m}$

$D$  : the diameter of culvert

$$D = \sqrt{\frac{4.84 \times 4}{\pi}} = 2.48 \text{ m}$$

Accordingly the head loss due to discharge tunnel for unit I  $h_{c1}$  is calculated as hereinafter.

$$h_{c1} = h_f + h_{cu} = 0.846 + 0.104 = \underline{0.950 \text{ m}}$$

b) Discharge tunnel for unit II

The section of culvert and the process of calculations are the same as culvert I.

i) The head loss due to the water surface friction  $h_f$

$$h_f = \frac{9.5^2 \times 0.015^2 \times 500}{4.84^2 \times 0.55^{4/3}} = \underline{0.962 \text{ m}}$$

ii) The head loss due to curve  $h'_{cu}$

$h'_{cu}$  is calculated as hereinafter.

$$\begin{aligned}
 h'_{cu} &= \left[ 3 \times \left( 0.131 + 0.1632 \times \left( \frac{2.48}{8} \right)^{3.5} \times \left( \frac{90^\circ}{90^\circ} \right) \right) \right. \\
 &\quad \left. + \left( 0.131 + 0.1632 \times \left( \frac{2.48}{10.6} \right)^{3.5} \times \left( \frac{90^\circ}{90^\circ} \right) \right) \right] \times \frac{1.96^2}{2 \times 9.8} \\
 &= \underline{0.104 \text{ m}}
 \end{aligned}$$

Accordingly the head loss due to culvert II  $h_{c2}$  is calculated as hereinafter.

$$h_{c2} = h_f + h_{cu} = 0.962 + 0.104 = \underline{1.066 \text{ m}}$$

5) Outlet





Fig 7. Plan of outlet

Both outlets of unit I and unit II are the same structures, so the head loss calculation is all the same.

- a) The head loss due to outlet  $h_o$  ( per one culvert box )  
 typical section of outlet ( one unit )



$$S = 4 \times 2.2 = 8.8 \text{ m ( per one box )}$$

$$A = 2.2 \times 2.2 = 4.84 \text{ m}^2 \text{ ( per one box )}$$

$$R = \frac{A}{S} = \frac{4.84}{8.8} = 0.55 \text{ m ( per one box )}$$

$$V = \frac{Q}{A} = \frac{1/2 \times 9.5}{4.84} = 0.98 \text{ m/sec ( per one box )}$$

- i) The head loss due to the water surface friction  $h_f$

$$h_f = \frac{Q^2 \cdot n^2 \cdot L}{A^2 \cdot R^{4/3}} = \frac{4.75^2 \times 0.015^2 \times 40}{4.84^2 \times 0.55^{4/3}} = 0.019 \text{ m}$$

460

ii) The head loss due to the gradual expansion  $h_g$

The entrance area of outlet  $A_1$  ( one unit )

$$A_1 = 2.2 \times 2.2 = 4.84 \text{ m}^2$$

The exit area of outlet  $A_2$  ( one unit )

$$A_2 = 4 \times 2.2 \times 2.2 = 19.36 \text{ m}^2$$

$$V_1 = \frac{Q_1}{A_1} = \frac{9.5}{4.84} = 1.96 \text{ m/sec}$$

$$V_2 = \frac{9.5}{A_2} = \frac{9.5}{19.36} = 0.49 \text{ m/sec}$$

$$h_g = f_g \cdot f_s \cdot \frac{(V_1 - V_2)^2}{2g} = 0.7 \times 0.563 \times \frac{(1.96 - 0.49)^2}{2 \times 9.8} = \underline{0.043 \text{ m}}$$

Where  $f_g$  : the coefficient of the gradual expansion loss = 0.7

$f_s$  : the coefficient of the sudden expansion loss

$$f_s = \left(1 - \frac{A_1}{A_2}\right)^2 = \left(1 - \frac{4.84}{19.36}\right)^2 = 0.563$$

Accordingly the head loss due to outlet  $h_o$  is calculated as hereinafter:

$$h_o = h_f + h_g = 0.019 + 0.043 = \underline{0.062 \text{ m}}$$

## CV-4 STRUCTURAL CALCULATION OF INTAKE OPEN CHANNEL

Contents of this calculation note is shown as below.

### Contents

1. Soil Condition .....	2
2. Outline of The Structural Design .....	4
3. Stability Calculation .....	5
4. Design Case .....	11
5. Structural Design .....	12

10/10

## 1. Structural Calculation of Intake Open Channel

## 1.1 Soil Condition

Boring data around the construction area is shown in Fig 1.

Now the average N-value above the foundation level is conjectured by the following calculation.

$$N = \frac{(10+12) \times 2.0 + (12+11) \times 2.0 + (11+13) \times 2.0 + (13+6) \times 2.0 + (6+9) \times 1.54}{2 \times 9.54}$$

$$\cong 10$$

According to the above calculation, the angle of the internal friction is calculated by the following equation.

$$\phi = (\sqrt{15N} + 15)^\circ = (\sqrt{15 \times 10} + 15)^\circ \cong 27^\circ$$

the bulk density of soil above the ground water  $\gamma$  :  $\gamma = 1.9 \text{ t/m}^3$

the bulk density of soil under the ground water  $\gamma'$  :  $\gamma' = 1.0 \text{ t/m}^3$ .


Moreover other basic condition data are published in "Civil Design Condition" (vid.No EWC-1001).



WEST WHARF THERMAL  
SITE : POWER STATION,  
KARACHI.

CLIENT : KARACHI ELECTRIC SUPPLY CORPORATION.

BORE CHART OF BORING No.4



Remarks : GROUNDWATER TABLE AT 1.00 METER.

Date :- 27/12/87.

Fig 1. Soil column diagram

1.2 Outline of The Structural Design

Structure of Intake Open Channel is shown in Fig.2.

This structure is considered as the rigid frame excluding the beam.




Fig.2 Typical section of Intake Open Channel

The structural design calculation is executed at the lowest low water level. (EL - 0.88 m) (considered for the water head loss due to Intake Tunnel).

↓  
(vid.1.c,P4, No EWC-1004)

1102

## 1.3 Stability Calculation

1) Vertical forces ( per 1 m unit length )

a) Base slab

$$W_{c1} = 5.2 \times 1.0 \times 2.45 = 12.7 \text{ t}$$

b) Side wall ( at one side )

$$W_{c2} = (0.7 \times 0.7 + \frac{1}{2} \times (0.54 + 1.0) \times 8.3 + \frac{1}{2} \times 0.3 \times 0.3) \times 2.45$$

$$= 17.0 \text{ t}$$

c) Beam

$$W_{c3} = 3.0 \times 0.6 \times 0.45 \times 2.45 \div 5.0 = 0.4 \text{ t}$$

d) Soil weight  $W_s$  ( at one side )

$$W_s = (0.2 \times 0.5 + \frac{1}{2} \times (0.56 + 0.1) \times 8.3) \times 1.9 = 5.4 \text{ t}$$

e) Water weight

Water weight  $W_w$  is calculated at the highest high water level (EL + 2.78 m)  
(considered for the water head loss due to Intake Tunnel.)

↓  
(vid.1.b,P3, No EWC-1004)

$$W_w = (6.78 \times 3.0 - 0.3 \times 0.3) \times 1.0 = 20.3 \text{ t}$$

f) Buoyancy

Buoyancy  $U_b$  is working to the portion of concrete structure under H.H.W.L, so  $U_b$  is calculated as follows.

$$U_b = (5.2 \times 1.0 + 0.3 \times 0.3 + (0.59 + 1.0) \times 6.78) \times 1.0$$

$$= 16.1 \text{ t}$$

According to the above calculation, the summarized vertical forces are shown in Table 1.

Table 1. Summarized table of vertical forces (per 1 m unit length)

Species	Vertical force	Remarks
$W_{c1}$	12.7 t	Base slab
$W_{c2}$	34.6 t	Side wall
$W_{c3}$	0.4 t	Connected beam
$W_s$	11.0 t	Soil weight
$W_w$	20.3 t	Water weight
$U_b$	- 16.1 t	Buoyancy
TOTAL	$V = 62.9$ t	

2) The ground reaction  $q_1$

$$q_1 = \frac{V}{B \cdot L} \cdot \left( 1 \pm \frac{6e}{B} \right) \quad \text{Where } e : \text{ the eccentric distance}$$

$$e = 0$$

$$= \frac{62.9}{5.2 \times 1.0}$$

$$= 12.1 \text{ t/m}^2$$

3) Study of the bearing capacity  $q_u$ 

The ultimate bearing capacity is calculated by the following equation in consideration of the unbalanced inclination.

$$q_u = \alpha K C N_c + K q N_q + \frac{1}{2} \gamma_1 \beta B^{\wedge} N_r$$

Where  $C$  : soil cohesion = 0 t/m<sup>2</sup>

$q$  : the surcharge load

$$q = 1.9 \times 1.0 + 1.0 \times 8.8 = 10.7 \text{ t/m}^2$$

$A^{\wedge}$  : the effective load area (m<sup>2</sup>)

$$A^{\wedge} = 5.2 \times 1.0 = 5.2 \text{ m}^2$$

$\gamma_1$  : the bulk density of the bearing soil (t/m<sup>3</sup>)

$$\gamma_1 = 1.0 \text{ t/m}^3$$

( $\gamma_1$  is the bulk density under the ground water.)

$B^{\wedge}$  : the effective width considered for the eccentric distance.

$$B^{\wedge} = B - 2e_b = 5.2 - 2 \times 0 = 5.2 \text{ m}$$

where  $B$  : the basic width

$e_b$  : the eccentric distance

$\alpha, \beta$  : the coefficient of basic form  $\alpha = \beta = 1.0$

$K$  : the extra coefficient for the embedded effect  $K = 1.0$

$N_c, N_q, N_r$  : the bearing coefficients considered for the load inclination, and these coefficients are adopted from the following graphs.

$$N_c = 25 \text{ (from Fig 3.)}$$

$$N_q = 14 \text{ (from Fig 4.)}$$

$$N_r = 9 \text{ (from Fig 5.)}$$




Fig.3 Graph of the bearing coefficient  $N_c$

where  $\tan \theta : \tan \theta = \frac{H}{V} = 0$

V : Vertical Force at the foundation  $V = 60 \text{ t}$

H : Horizontal Force at the foundation  $H = 0 \text{ t}$

because horizontal forces are equilibrated at both sides.

$\phi$  : The angle of the internal friction

$\phi = 27^\circ$




Fig.4 Graph of the bearing coefficient  $N_c$




Fig.5 Graph of the bearing coefficient  $N_r$

Accordingly the ultimate bearing capacity  $q_u$  is calculated as below.

$$q_u = 1.0 \times 10.7 \times 14 + \frac{1}{2} \times 1.0 \times 1.0 \times 5.2 \times 9 = 173 \text{ t}$$

4) The allowable bearing capacity  $q_a$

The allowable bearing capacity is calculated as below.

$$q_a = \frac{1}{F_s} \cdot q_u = \frac{1}{3} \times 173 \approx 57 \text{ t/m}^2 > q_1 = 11.5 \text{ t/m}^2$$

Where  $F_s$  : the factor of safety  $F_s = 3$

Therefore the spread foundation is adopted for the foundation of Intake Open Channel.

10/11

## 5) Study of floating

The calculation of floating is executed at normal (The internal water condition is at L.L.W.L) and at construction (The internal water condition is empty), so this calculation is as follows.

## a) Total vertical force

## i) at normal

$$V_1 = 12.7 + 34.6 + 0.4 + 11.0 + (3.12 \times 3.0 - 0.3 \times 0.3) \times 1.0 = 68.0 \text{ t}$$

## ii) at construction

$$V_2 = 12.7 + 34.6 + 0.4 + 11.0 = 58.7 \text{ t}$$

## b) Up lift U

Up lift U is calculated as below.

$$U = \gamma_w \cdot h_w \cdot A = 1.0 \times 8.8 \times 5.2 \times 1.0 = 45.8 \text{ t}$$

c) Checking on the safety factor of floating  $F_1$ 

The safety factor of floating  $F_1$  is checked by the following two cases.

## i) at normal

$$F_{11} = \frac{V_1}{U} = \frac{68.0}{45.8} = 1.48 > 1.1 \text{ O.K.}$$

## ii) at construction

$$F_{12} = \frac{V_2}{U} = \frac{58.7}{45.8} = 1.28 > 1.0 \text{ O.K.}$$



## 1.4 Design Case

The following three cases are considered for the structural design calculation.

Table 2. Summary of design cases

CASE	1	2	3
CONDITION	at Normal	at Earthquake	at Construction
Earthquake	None	Considered	None
Water Content	L.L.W.L	L.L.W.L	Empty
Self weight	Considered	Considered	Considered
The surcharge load	Considered	Considered	Considered
The increment ratio of the allowable stress	1.0	1.5	1.25

1.5 Structural Design

1.5.1 Load Case-1 ( Normal, Long term )

1) Frame of the design structure

Frame of the design structure is shown in Fig 6, and the design structure is considered for the rigid frame structure.




Fig 6. Frame of the design structure

1110

## 2) Load calculation (per 1m unit length)

a) Surcharge load at the ground level  $q = 1.0 \text{ t/m}^2$ 

b) Self weight

i) Side wall  $W_{c1}$  ( at one side )

$$W_{c1} = \frac{1}{2} \times (0.5 + 1.0) \times 2.45 = 1.84 \text{ t/m}^2$$

ii) Base slab  $W_{c2}$  ( at one side )

$$W_{c2} = 1.0 \times 2.45 = 2.45 \text{ t/m}^2$$

iii) Beam

$$W_{c3} = 0.6 \times 0.45 \times 2.45 \div 5.0 = 0.13 \text{ t/m}^2$$

c) The earth pressure and the water pressure

i) the earth pressures

$$P_0 = k \cdot q = 0.5 \times 1.0 = 0.5 \text{ t/m}^2$$

$$P_1 = k(\gamma h_1 + q) = 0.5 \times (1.9 \times 1.0 + 1.0) = 1.45 \text{ t/m}^2$$

$$P_2 = 1.45 + k \cdot \gamma \cdot h_2 = 1.45 + 0.5 \times 1.0 \times 8.3 = 5.60 \text{ t/m}^2$$

ii) the water pressure ( outside )

$$P_{w0} = \gamma_w \cdot h_{w0} = 1.0 \times 8.3 = 8.3 \text{ t/m}^2$$

iii) the water pressure ( inside )

$$P_{wi} = \gamma_w \cdot h_{wi} = 1.0 \times 3.12 = 3.12 \text{ t/m}^2$$

iv) up lift

$$P_u = \gamma_w \cdot H_w = 1.0 \times 8.8 = 8.8 \text{ t/m}^2$$

d) The ground reaction

$$q_r = 11.5 \text{ t/m}^2$$

According to the above calculations, the results of load calculations are shown in Fig 7.




Fig.7 The results of load calculations

3) The load diagram

The load diagram is shown in Fig 8.




Fig.8 The load diagram

4) Input data for the sectional dimensions.

The sectional forces are calculated by computer, so input data for the sectional dimensions are indicated in Table 3.

Table 3. Table of the sectional dimensions (per 1 m unit length)

Member's number	Section area $A$ ( $m^2$ )	Geometrical moment of inertia $I$ ( $m^4$ )	Remarks
(1)	0.53	0.0129	Side wall
(2)	0.68	0.0262	Side wall
(3)	0.90	0.0608	Side wall
(4)	1.0	0.0833	Footing
(5)	0.90	0.0608	Side wall
(6)	0.68	0.0262	Side wall
(7)	0.53	0.0129	Side wall
(8)	0.054	0.0016	beam @ 5.0 m

1.5.2 Load Case-2 (Earthquake, Short term)

1) Design structure

Design structure is shown in Fig 9.




Fig.9 Design structure

2) Load calculation (per 1 m unit length)

a) The ground surface surcharge

$$q = 1.0 \text{ t/m}^2$$

11/5

## b) Self weight

i) side wall  $W_{c1} = 1.84 \text{ t/m}^2$  ( at one side )

ii) base slab  $W_{c2} = 2.45 \text{ t/m}^2$  ( at one side )

iii) beam  $W_{c3} = 0.13 \text{ t/m}^2$

iv) water weight  $W_w = 1.0 \times 3.12 = 3.12 \text{ t/m}^2$

## c) The force of inertia

Design seismic coefficient  $k_h = 0.10$ , so the force of inertia is calculated as below.

## i) side wall ( at one side )

$$W_{ch1} = k_h \cdot W_{c1} = 0.1 \times 1.84 = 0.18 \text{ t/m}^2$$

## ii) base slab ( at one side )

$$W_{ch2} = k_h \cdot W_{c2} = 0.1 \times 2.45 = 0.25 \text{ t/m}^2$$

## iii) beam

$$W_{ch3} = k_h \cdot W_{c3} = 0.1 \times 0.13 = 0.01 \text{ t/m}^2$$



d) The seismic earth pressures and the water pressures

i) the seismic earth pressures

The coefficient of seismic active pressure is calculated by the following equations.

$$K_{ea} = \frac{\cos^2 (\phi - \theta_0 - \theta)}{\cos \theta_0 \cdot \cos^2 \theta \cdot \cos(\theta + \theta_0 + \delta)} \left\{ 1 + \sqrt{\frac{\sin(\phi + \delta) \sin(\phi - \delta - \theta_0)}{\cos(\theta + \theta_0 + \delta) \cos(\theta - \alpha)}} \right\}^2$$

Where  $\phi$  : the angle of the internal friction =  $27^\circ$

$\alpha$  : the angle between the ground surface and the horizontal plane  
 $\alpha = 0^\circ$

$\theta$  : the angle between the back wall surface and the vertical plane

$$\theta = \tan^{-1} \frac{0.5}{8.97} \cong 3^\circ$$

$\delta$  : the angle of the wall surface friction between the back wall surface and back-fill  $\delta = 0^\circ$

$\theta_0$  : the composite angle of earthquake

$$\theta_0 = \tan^{-1} k_h = \tan^{-1} 0.1 \cong 5.7^\circ$$

Therefore

$$K_{ea} = \frac{\cos^2 (27^\circ - 5.7^\circ - 3^\circ)}{\cos 5.7^\circ \times \cos^2 3^\circ \times \cos(3^\circ + 5.7^\circ)} \times \left\{ 1 + \sqrt{\frac{\sin 27^\circ \cdot \sin(27^\circ - 5.7^\circ)}{\cos(3^\circ + 5.7^\circ) \cdot \cos 3^\circ}} \right\}^2$$

$$= 0.463$$

The seismic passive earth pressure is determined by balancing the force which is figured out by the inertia forces and the seismic active earth pressures.

Accordingly the seismic earth pressures are calculated as follows.

## ii) the active earth pressures ( Horizontal )

(Horizontal)

$$P_{EAH0} = K_{EA} \cdot \cos 3^\circ \cdot q = 0.463 \times 0.999 \times 1.0 = 0.46 \text{ t/m}^2$$

$$P_{EAH1} = 0.463 \times 0.999 \times (1.0 + 1.9 \times 1.0) = 1.34 \text{ t/m}^2$$

$$P_{EAH2} = 0.463 \times 0.999 \times (1.0 + 1.9 \times 1.0 + 1.0 \times 8.3) = 5.18 \text{ t/m}^2$$

(Vertical)

$$P_{EAV0} = K_{EA} \cdot \sin 3^\circ \cdot q = 0.463 \times 0.052 \times 1.0 = 0.02 \text{ t/m}^2$$

$$P_{EAV1} = 0.463 \times 0.052 \times (1.0 + 1.9 \times 1.0) = 0.07 \text{ t/m}^2$$

$$P_{EAV2} = 0.463 \times 0.052 \times (1.0 + 1.9 \times 1.0 + 1.0 \times 8.3) = 0.27 \text{ t/m}^2$$

## iii) the passive earth pressures

Total passive pressures are balanced to total horizontal forces, so they are calculated as below.

(Horizontal)

(Vertical)

$$P_{EPH0} = 0.95 \text{ t/m}^2 \quad P_{EPU0} = P_{EPH0} \cdot \tan 3^\circ = 0.95 \times 0.052 = 0.05 \text{ t/m}^2$$

$$P_{EPH1} = 1.70 \text{ t/m}^2 \quad P_{EPU1} = P_{EPH1} \cdot \tan 3^\circ = 1.70 \times 0.052 = 0.09 \text{ t/m}^2$$

$$P_{EPH2} = 5.78 \text{ t/m}^2 \quad P_{EPU2} = P_{EPH2} \cdot \tan 3^\circ = 5.78 \times 0.052 = 0.30 \text{ t/m}^2$$

## iv) the static water pressure

The static water pressures are calculated by dividing between inside and outside.

( Inside )

$$P_{wi} = \gamma_w \cdot h_i = 1.0 \times 3.12 = 3.12 \text{ t/m}^2$$

( Outside )

$$P_{wo} = \gamma_w \cdot h_o = 1.0 \times 8.3 = 8.3 \text{ t/m}^2$$

v) the dynamic water pressure

The dynamic water pressure is considered for working to side walls, therefore dynamic water pressure is calculated as below.

$$P_{ew} = \frac{7}{12} \cdot K_h \cdot \gamma_w \cdot b \cdot h^2 = \frac{7}{12} \times 0.1 \times 1.0 \times 1.0 \times 3.12^2 = 0.57 \text{ t}$$

Working point of  $P_{ew}$  (  $h_{ew}$  )

$$h_{ew} = \frac{h}{2} + 0.5 = \frac{3.12}{2} + 0.5 = 2.06 \text{ m}$$

vi) up lift

$$P_u = \gamma_w \cdot H_w = 1.0 \times ( 8.3 + 0.5 ) = 8.8 \text{ t/m}^2$$

e) The ground reaction

$$q_r = 11.5 \text{ t/m}^2$$

f) The results of load calculations

The results of load calculations are shown in Fig 10.




Fig.10 The results of load calculations

1120

3) The load diagram

The load diagram is shown in Fig 11.




Fig.11 The load diagram

## 4) Input data for the sectional dimensions

## a) The sectional dimensions

Table 4. Table of the sectional dimensions (per 1 m unit length)

Member's number	Section Area A (m <sup>2</sup> )	Geometrical moment of inertia I (m <sup>4</sup> )	Remarks
(1)	0.53	0.013	Side wall
(2)	0.68	0.026	Side wall
(3)	0.85	0.051	Side wall
(4)	0.95	0.071	Side wall
(5)	1.00	0.083	Footing
(6)	0.95	0.071	Side wall
(7)	0.85	0.051	Side wall
(8)	0.68	0.026	Side wall
(9)	0.53	0.013	Side wall
(10)	0.054	0.0016	Beam @ 5.0m

### 1.5.3 Load Case (at construction, Short term)

#### 1) Design structure

Design structure is shown in Fig 12.




Fig 12. Design structure

#### 2) Load calculation (per 1 m unit length)

The process and the results of load calculations are the same as Case-1 excluding a calculation of inside water load.

In this design case the inside water pressure and the inside water weight is no considered (= 0).

3) The load diagram

The load diagram is shown in Fig 13.




Fig 13. The load diagram

11/11



4) Input data for the sectional dimensions.

The sectional forces are calculated by computer, so input data for the sectional dimensions are indicated in Table 5.

Table 5. Table of the sectional dimensions (per 1 m unit length)

Member's number	Section area A (m <sup>2</sup> )	Geometrical moment of inertia I (m <sup>4</sup> )	Remarks
(1)	0.53	0.0129	Side wall
(2)	0.79	0.0411	Side wall
(3)	1.0	0.0833	Footing
(4)	0.79	0.0411	Side wall
(5)	0.53	0.0129	Side wall
(6)	0.054	0.0016	Beam @ 5.0 m

125

Case - 1 (at Normal)

1126

#### 1.5.4 The Computer Calculation Results

The computer calculation results are bending moment, shearing force and axial force, so they are shown in the following figures. Now comparing with three load cases, the sectional forces are almost same at both cases, so the sectional forces at normal case are mainly adopted to calculate the sectional stresses and the arrangement of reinforcing bars from the view point of safety design.

121

INTAKE OPEN CHANNEL CASE-1 (NORMAL, L.L.W.L.)

BENDING MOMENT




Fig. 14. The bending moment diagram

1128

Case - 2 (at Earthquake)

11/29

INTAKE OPEN CHANNEL CASE-1 (NORMAL, L.L.W.L)

SHEARING FORCE





Fig 15. The shearing force diagram

1130

1/11

# INTAKE OPEN CHANNEL CASE-1 (NORMAL, L.L.W.L)

AXIAL FORCE



1.0 M

(TON)

Fig 16. The axial force diagram

Table 6. Summary of the sectional forces (Normal)

\*\* ELEMENTAL FORCES \*\*

ELEM	I-END	AXIAL	SHEAR	MOMENT	J-END	AXIAL	SHEAR	MOMENT
1	1	2.600E-01	-1.3504E+01	-2.8329E+00	11	8.7327E-01	-1.3284E+01	1.6349E+00
2	11	8.7327E-01	-1.3284E+01	1.6343E+00	12	1.4867E+00	-1.2959E+01	6.0126E+00
3	12	1.4867E+00	-1.2959E+01	6.0120E+00	2	2.1000E+00	-1.2529E+01	1.0263E+01
4	2	2.1000E+00	-1.2529E+01	1.0263E+01	13	3.8222E+00	-1.0514E+01	2.1170E+01
5	13	3.8222E+00	-1.0514E+01	2.1149E+01	14	5.5445E+00	-7.1860E+00	2.9556E+01
6	14	5.5445E+00	-7.1860E+00	2.9536E+01	15	7.2667E+00	-2.5435E+00	3.4212E+01
7	15	7.2667E+00	-2.5435E+00	3.4191E+01	16	8.9890E+00	3.4132E+00	3.3907E+01
8	16	8.9890E+00	3.4132E+00	3.3807E+01	3	1.0711E+01	1.0684E+01	2.7412E+01
9	3	1.0711E+01	1.0684E+01	2.7392E+01	17	1.2043E+01	1.6984E+01	1.7400E+01
10	17	1.2043E+01	1.6984E+01	1.7396E+01	18	1.3376E+01	2.3618E+01	2.7229E+00
11	18	1.3376E+01	2.3618E+01	2.7189E+00	19	1.4708E+01	3.0586E+01	-1.6879E+01
12	19	1.4708E+01	3.0586E+01	-1.6883E+01	20	1.6040E+01	3.7889E+01	-4.1646E+01
13	20	1.6040E+01	3.7889E+01	-4.1651E+01	4	1.7372E+01	4.5527E+01	-7.1823E+01
14	4	1.7372E+01	4.5527E+01	-7.1827E+01	21	4.5527E+01	-5.8920E+00	-4.3545E+01
15	21	4.5527E+01	-5.8920E+01	-7.1827E+01	22	4.5527E+01	5.8920E+00	-4.3545E+01
16	22	4.5527E+01	-5.8920E+00	-4.3545E+01	23	4.5527E+01	5.8920E+00	-4.3545E+01
17	23	4.5527E+01	5.8920E+00	-4.3545E+01	24	4.5527E+01	1.7676E+01	-5.2972E+01
18	24	4.5527E+01	1.7676E+01	-5.2972E+01	5	4.5527E+01	2.9460E+01	-7.1827E+01
19	5	4.5527E+01	-7.1827E+01	-5.2972E+01	25	1.6040E+01	-3.7889E+01	-4.1655E+01
20	25	1.6040E+01	-3.7889E+01	-4.1651E+01	26	1.4708E+01	-3.0586E+01	-1.6807E+01
21	26	1.4708E+01	-3.0586E+01	-4.1651E+01	27	1.3376E+01	-2.3618E+01	2.7149E+00
22	27	1.3376E+01	-2.3618E+01	-1.6883E+01	28	1.2043E+01	-1.6984E+01	1.7392E+01
23	28	1.2043E+01	-1.6984E+01	2.7189E+00	6	1.0711E+01	-1.0684E+01	2.7388E+01
24	6	1.0711E+01	-1.0684E+01	2.7392E+01	29	8.9890E+00	-3.4132E+00	3.2866E+01
25	29	8.9890E+00	3.4132E+00	3.3887E+01	30	7.2667E+00	2.5435E+00	3.4171E+01
26	30	7.2667E+00	2.5435E+00	3.4191E+01	31	5.5445E+00	7.1860E+00	2.9515E+01
27	31	5.5445E+00	7.1860E+00	2.9536E+01	32	3.8222E+00	1.0514E+01	2.1129E+01
28	32	3.8222E+00	1.0514E+01	2.1149E+01	7	2.1000E+00	1.2529E+01	1.0242E+01
29	7	2.1000E+00	1.2529E+01	1.0263E+01	33	1.4867E+00	1.2959E+01	6.0114E+00
30	33	1.4867E+00	1.2959E+01	6.0120E+00	34	8.7327E-01	1.3284E+01	1.6337E+00
31	34	8.7327E-01	1.3284E+01	1.6343E+00	8	2.6000E-01	1.3504E+01	-2.8334E+00
32	8	2.6000E-01	1.3504E+01	1.6343E+00	35	1.3504E+01	1.5600E-01	2.6665E+00
33	35	1.3504E+01	1.5600E-01	2.8329E+00	36	1.3504E+01	5.2000E-02	2.5833E+00
34	36	1.3504E+01	5.2000E-02	2.8329E+00	37	1.3504E+01	-5.2000E-02	2.5833E+00
35	37	1.3504E+01	-5.2000E-02	2.8329E+00	38	1.3504E+01	-1.5600E-01	2.6665E+00
36	38	1.3504E+01	-1.5600E-01	2.6665E+00	8	1.3504E+01	-2.6000E-01	2.8329E+00

4932



1133

INTAKE OPEN CHANNELCASE-2 (EARTHQUAKE, L. L. W. L)

BENDING MOMENT




Fig 17. The bending moment diagram





Fig 18. The shearing force diagram

1134

1135

# INTAKE OPEN CHANNEL CASE-2 (EARTHQUAKE, L. L. W. L.)

AXIAL FORCE



1.0 m

(TON)

Fig 19. The axial force diagram

Table 7. Summary of the sectional forces (Earthquake)

\*\* ELEMENTAL FORCES \*\*

ELEM	I-END	AXIAL	SHEAR	MOMENT	J-END	AXIAL	SHEAR	MOMENT
1	1	5.4210E+01	-1.3579E+01	-3.3665E+00	13	1.4871E+00	-1.3149E+01	3.3263E+00
2	13	1.4671E+00	-1.3149E+01	3.3244E+00	2	2.4321E+00	-1.2499E+01	9.7472E+00
3	2	2.4321E+00	-1.2499E+01	9.7454E+00	14	4.7838E+00	-9.7447E+00	2.2986E+01
4	14	4.7838E+00	-9.7447E+00	2.2948E+01	15	7.1355E+00	-5.0399E+00	3.1825E+01
5	15	7.1355E+00	-5.0399E+00	3.1787E+01	16	9.4872E+00	1.6160E+00	3.4018E+01
6	16	9.4872E+00	1.6160E+00	3.3980E+01	3	1.1839E+01	1.0223E+01	2.7283E+01
7	3	1.1839E+01	1.0223E+01	2.7245E+01	17	1.2623E+01	1.3452E+01	2.2631E+01
8	17	1.2623E+01	1.3452E+01	2.2631E+01	18	1.3407E+01	1.6751E+01	1.6744E+01
9	18	1.3407E+01	1.6751E+01	1.6743E+01	19	1.4191E+01	2.0121E+01	9.5558E+00
10	19	1.4191E+01	2.0121E+01	9.5554E+00	4	1.4975E+01	2.3561E+01	1.0402E+00
11	4	1.4975E+01	2.0121E+01	1.0397E+00	20	1.6010E+01	2.8813E+01	-1.2584E+01
12	20	1.6010E+01	2.8813E+01	-1.2585E+01	21	1.7045E+01	3.3681E+01	-2.8668E+01
13	21	1.7045E+01	3.3681E+01	-2.8670E+01	22	1.8080E+01	3.8737E+01	-4.7308E+01
14	22	1.8080E+01	3.8737E+01	-4.7309E+01	5	1.9115E+01	4.3979E+01	-6.8599E+01
15	5	4.3979E+01	-4.7309E+01	-6.8601E+01	23	4.4229E+01	-1.2091E+01	-4.9145E+01
16	23	4.4229E+01	-1.2091E+01	-6.8601E+01	24	4.4479E+01	2.6390E+00	-4.4419E+01
17	24	4.4479E+01	2.6390E+00	-4.4419E+01	25	4.4729E+01	1.7369E+01	-5.4423E+01
18	25	4.4729E+01	1.7369E+01	-5.4423E+01	6	4.4979E+01	3.2099E+01	-7.9157E+01
19	6	1.8820E+01	-4.6589E+01	-7.9157E+01	26	1.7769E+01	-4.1042E+01	-5.6601E+01
20	26	1.7769E+01	-4.1042E+01	-5.6600E+01	27	1.6719E+01	-3.5689E+01	-3.6851E+01
21	27	1.6719E+01	-3.5689E+01	-3.6850E+01	28	1.5668E+01	-3.0531E+01	-1.9808E+01
22	28	1.5668E+01	-3.0531E+01	-1.9806E+01	7	1.4617E+01	-2.5567E+01	-5.3712E+00
23	7	1.4617E+01	-2.5567E+01	-5.3695E+00	29	1.3822E+01	-2.2489E+01	4.1096E+00
24	29	1.3822E+01	-2.2489E+01	4.1101E+00	30	1.3026E+01	-1.8916E+01	1.2181E+01
25	30	1.3026E+01	-1.8916E+01	1.2182E+01	31	1.2231E+01	-1.5418E+01	1.8874E+01
26	31	1.2231E+01	-1.5418E+01	1.8874E+01	8	1.1435E+01	-1.1996E+01	2.4217E+01
27	8	1.1435E+01	-1.1996E+01	2.4218E+01	32	9.0483E+00	-2.8608E+00	3.2670E+01
28	32	9.0483E+00	-2.8608E+00	3.2710E+01	33	6.6615E+00	4.2323E+00	3.1668E+01
29	33	6.6615E+00	4.2323E+00	3.1708E+01	34	4.2747E+00	9.2838E+00	2.3563E+01
30	34	4.2747E+00	9.2838E+00	2.3602E+01	9	1.8879E+00	1.2294E+01	1.0741E+01
31	9	1.8879E+00	1.2294E+01	1.0780E+01	35	9.3290E-01	1.3050E+01	4.4352E+00
32	35	9.3290E-01	1.3050E+01	4.4368E+00	10	-2.2103E-02	1.3619E+01	-2.2397E+00
33	1	1.3579E+01	5.4210E-01	3.3665E+00	36	1.3589E+01	4.1210E-01	2.8894E+00
34	36	1.3589E+01	5.4210E-01	2.8894E+00	37	1.3599E+01	2.8210E-01	2.5423E+00
35	37	1.3599E+01	2.8210E-01	2.5423E+00	38	1.3609E+01	1.5210E-01	2.3252E+00
36	38	1.3609E+01	1.5210E-01	2.3252E+00	10	1.3619E+01	2.2103E-02	2.2381E+00

9/11

Case - 3 (at Construction)

1137

INTAKE OPEN CHANNEL CASE-3 (CONSTRUCTION, EMPTY)

BENDING MOMENT





Fig 20. The bending moment diagram

1138

1131

INTAKE OPEN CHANNEL CASE-3 (CONSTRUCTION, EMPTY)

SHEARING FORCE




1.0 M

(TON)

Fig 21. The shearing force diagram

INTAKE OPEN CHANNEL CASE-3 (CONSTRUCTION, EMPTY)

AXIAL FORCE



1.0 M

(TON)

Fig. 22. The axial force diagram

1140



Table 8. Summary of sectional forces (Construction)

\*\* ELEMENTAL FORCES \*\*

ELEM	I-END	AXIAL	SHEAR	MOMENT	J-END	AXIAL	SHEAR	MOMENT
1	1	2.6000E+01	-1.4799E+01	-2.4035E+00	9	1.1800E+00	-1.4430E+01	4.9156E+00
2	9	1.1800E+00	-1.4430E+01	4.9136E+00	2	2.1000E+00	-1.3824E+01	1.1969E+01
3	2	2.1000E+00	-1.3824E+01	1.1987E+01	10	5.9180E+00	-7.5858E+00	3.5540E+01
4	10	5.9180E+00	-7.5858E+00	3.5316E+01	11	9.7360E+00	5.1106E+00	3.9224E+01
5	11	9.7360E+00	5.1106E+00	3.9001E+01	12	1.3554E+01	2.4265E+01	9.8636E+00
6	12	1.3554E+01	2.4265E+01	9.6402E+00	3	1.7372E+01	4.9879E+01	-6.5944E+01
7	3	4.9879E+01	-3.5700E+01	-6.6168E+01	13	4.9879E+01	-1.7850E+01	-3.9393E+01
8	13	4.9879E+01	-1.7850E+01	-3.9393E+01	14	4.9879E+01	3.5283E-13	-3.0468E+01
9	14	4.9879E+01	4.8406E-13	-3.0468E+01	15	4.9879E+01	1.7850E+01	-3.9393E+01
10	15	4.9879E+01	1.7850E+01	-3.9393E+01	4	4.9879E+01	3.5700E+01	-6.6168E+01
11	4	1.7372E+01	-4.9879E+01	-6.6168E+01	16	1.3554E+01	-2.4265E+01	9.4169E+00
12	16	1.3554E+01	-2.4265E+01	9.6402E+00	17	9.7360E+00	-5.1106E+00	3.8778E+01
13	17	9.7360E+00	-5.1106E+00	3.9001E+01	18	5.9180E+00	7.5858E+00	3.5093E+01
14	18	5.9180E+00	7.5858E+00	3.5316E+01	5	2.1000E+00	1.3824E+01	1.1764E+01
15	5	2.1000E+00	1.3824E+01	1.1987E+01	19	1.1800E+00	1.4430E+01	4.9116E+00
16	19	1.1800E+00	1.4430E+01	4.9136E+00	6	2.6000E-01	1.4799E+01	-2.4055E+00
17	1	1.4799E+01	2.6000E-01	2.4035E+00	20	1.4799E+01	1.3000E-01	2.2085E+00
18	20	1.4799E+01	1.3000E-01	2.2085E+00	21	1.4799E+01	4.4520E-14	2.1435E+00
19	21	1.4799E+01	4.4673E-14	2.1435E+00	22	1.4799E+01	-1.3000E-01	2.2085E+00
20	22	1.4799E+01	-1.3000E-01	2.2085E+00	6	1.4799E+01	-2.6000E-01	2.4035E+00

111

1.5.5 The Calculation Results of the Stress

The stress calculations are shown in the following Tables, and the general arrangement of reinforcing bars are figured in Fig.26, now the allowable stress of reinforced concrete is stated again as below.

- 1) The allowable bending stress of the reinforcing bars  $\sigma_{bs}$

$\sigma_{bs} = 1800 \text{ kg/cm}^2$

- 2) The allowable compressive stress  $\sigma_{cs}$

$\sigma_{cs} = 70 \text{ kg/cm}^2$

- 3) The allowable shearing stress  $\tau_s$

Table 9. The allowable shearing stress  $\tau_s$

Classification		$\tau_s$ (kg/cm <sup>2</sup> )
No considered for the diagonal tension bars	Beam	4.25
	Slab	8.5
Considered for the diagonal tension bars	As working force is the shearing force only	19.0

In this design case the design structure is considered for the slab structure, so the allowable shearing stress is determined  $\tau_s = 8.5 \text{ kg/cm}^2$ .

112

## 4) Study of coping

Coping is considered for the continuous beam, so the bending moment  $M_b$  and the shearing force  $S$  are calculated as follows, then the uniformly distributed load is  $q = 13.5 \text{ t/m}$ .




Fig. 23 The load diagram

## a) The bending moment

## i) at the support

$$M_{be} = -\frac{1}{10} q \cdot l^2 = -\frac{1}{10} \times 13.5 \times 5^2 = -33.8 \text{ t/m}$$

## ii) at the middle point of beam

The maximum bending moment at the middle of beam is occurred at both end spans, then the bending moment is calculated as below.

$$M_{bm} = \frac{8}{100} q \cdot l^2 = \frac{8}{100} \times 13.5 \times 5^2 = 27.0 \text{ t/m}$$




Fig. 24 The bending moment diagram

b) The shearing stress

The shearing stress is equal to the reaction force at the support.

$$S = \frac{1}{2} q \cdot l = \frac{1}{2} \times 13.5 \times 5.0 = 33.8 \text{ t}$$




Fig.25 The shearing force diagram

[ Intake Open Channel ]

Table 10-1 The Calculation Results of The Stress

Member	Point	The Sectional Force			The Sectional Dimensions				The Arrangement of Reinforcing Bars			The stresses (kg/cm <sup>2</sup> )			Remarks	
		M [kg·cm]	N [kg]	S [kg]	B [cm]	H [cm]	d [cm]	d' [cm]	D [mm]	Pitch [mm]	As [cm <sup>2</sup> ]	A's [cm <sup>2</sup> ]	σ <sub>b</sub>	σ <sub>c</sub>		τ
(1)	1	0	300	14 000	100	50	40	10	∅25	125	40.5	15.5	-1	0.1	3.5	Calculated on hypothetical section.
	Center	600 000	1 500	13 000	100	54	44	10	∅25	250	40.5	15.5	386	17.6	3.0	
	2	1 030 000	2 100	12 600	100	56	46	10	∅25	125	40.5	15.5	633	27.9	2.8	
(2)	2	1 030 000	2 100	12 600	100	56	46	10	∅25	250	40.5	15.5	633	27.9	2.8	
	Center	3 420 000	7 300	2 500	100	69	59	10	∅25	125	40.5	15.5	1 543	58.5	0.7	
	3	2 740 000	10 700	10 700	100	78	68	10	∅25	250	40.5	15.5	999	37.5	1.6	
(3)	3	2 740 000	10 700	10 700	100	78	68	10	∅25	125	40.5	15.5	999	37.5	1.6	
	Center	-1 690 000	14 700	30 600	100	91	81	10	∅25	250	51.4	40.5	327	15.1	1.3	
	4	-7 180 000	17 400	45 500	100	110	100	10	∅25	125	51.4	40.5	1 394	44.0	4.6	
(4)	4	-7 180 000	45 500	29 500	100	110	100	10	∅29	125	51.4	15.5	1 172	49.9	3.0	
	Center	-4 350 000	45 500	5 900	100	100	90	10	∅29	250	51.4	15.5	1 002	34.2	0.0	
	5	-7 180 000	45 500	29 500	100	110	100	10	∅29	125	51.4	15.5	1 172	49.9	3.0	

Where M : Bending moment      B : The Width      D : Diameter of bars      σ<sub>b</sub> : The bending stress  
 N : Axial force                  H : The Height      As : The area of tension bars      σ<sub>c</sub> : The compressive stress  
 S : Shearing force                d : The effective height      A's : The area of compression bars      τ : The shearing stress  
 d' : The covering of compression bar

[Intake Open Channel]

Table/O-2 The Calculation Results of The Stress

Member	Point	The Sectional Force				The Sectional Dimensions				The Arrangement of Reinforcing Bars				The stresses (kg/cm <sup>2</sup> )		Remarks
		M [kg·cm]	N [kg]	S [kg]	B [cm]	H [cm]	d [cm]	d' [cm]	D [mm]	Pitch [mm]	As [cm <sup>2</sup> ]	A's [cm <sup>2</sup> ]	σ <sub>b</sub>	σ <sub>c</sub>	τ	
(5)	5	-7 180 000	17 400	45 500	100	110	100	10	φ29	125	51.4	70.5	1 394	44.0	4.6	Considered for the design of tension bars
	Center	-1 690 000	14 700	30 600	100	91	81	10	φ25	125	51.4	40.5	327	15.1	1.3	
(6)	6	2 740 000	10 700	10 700	100	78	68	10	φ24	250	40.5	15.5	999	37.5	1.6	
	6	2 740 000	10 700	10 700	100	78	68	10	φ25	250	40.5	15.5	999	37.5	1.6	
(6)	Center	3 420 000	7 300	2 500	100	69	59	10	φ25	250	40.5	15.5	1 543	58.5	0.4	
	7	1 030 000	2 100	12 600	100	56	46	10	φ25	250	40.5	15.5	633	27.9	2.8	
(7)	7	1 030 000	2 100	12 600	100	56	46	10	φ22	250	40.5	15.5	633	27.9	2.8	
	Center	600 000	1 500	13 000	100	54	44	10	φ25	250	40.5	15.5	386	17.6	3.0	
(8)	8	0	300	14 000	100	50	40	10	φ22	250	40.5	15.5	-1	0.1	3.5	Calculated on hypothetical section.
	1	0	67 500	1 300	45	60	52.5	7.5	φ22	3 pieces	11.6	11.6	0	66.6	0.6	
(8)	Center	1 290 000	67 500	300	45	60	52.5	7.5	φ22	3 pieces	11.6	11.6	283	66.6	0.1	
	8	0	67 500	1 300	45	60	52.5	7.5	φ22	3 pieces	11.6	11.6	0	66.6	0.6	

where M : Bending moment      B : The Width      D : Diameter of bars      σ<sub>b</sub> : The bending stress  
 N : Axial force                  H : The Height      As : The area of tension bars      σ<sub>c</sub> : The compressive stress  
 S : Shearing force                d : The effective height      A's : The area of compression bars      τ : The shearing stress  
 d' : The covering of compression bar

1148

[Intake Open Channel]  
Coping

Table. / O-3 The Calculation Results of The Stress

Member	Point	The Sectional Force			The Sectional Dimensions				The Arrangement of Reinforcing Bars			The stresses (kg/cm <sup>2</sup> )			Remarks	
		M [kg·cm]	N [kg]	S [kg]	B [cm]	H [cm]	d [cm]	d' [cm]	D [mm]	Pitch [mm]	As [cm <sup>2</sup> ]	A's [cm <sup>2</sup> ]	σ <sub>b</sub>	σ <sub>c</sub>		τ
Coping	end	-338000	0	338	70	75	60	15	Ø25	Ø pieces	40.5	40.5	1639	66.4	8.0	Considered for the diagonal tension.
	middle	2700000	0	0	70	90	75	15	Ø25	Ø pieces	40.5	40.5	1026	35.9	0.0	

Where M : Bending moment B : The Width D : Diameter of bars σ<sub>b</sub> : The bending stress  
N : Axial force H : The Height As : The area of tension bars σ<sub>c</sub> : The compressive stress  
S : Shearing force d : The effective height A's : The area of compression bars τ : The shearing stress  
d' : The covering-of compression bar




Fig. 26 The general arrangement of reinforcing bars

8/11



1.5.6 Study of End Wall

1) Outline of design structure




Fig 26. Outline of end wall

2) Structural design

End wall is considered for a two dimensional plate with three edges fixed and one edge free, so the structural design calculation is executed at normal case as follows.

a) The load diagram (Normal)

Working load to end wall is the same load as the channel, then the uniformly distributed load of end wall is transformed to the uniformly varying load that is shown in Fig 23.




Fig 27. The load diagram

b) The calculation of the sectional force

i) the bending moment




Fig 28. The bending moment diagram

$$M_{x1} = ( 0.0425 \times 0.5 + 0.0095 \times 12.5 ) \times 10^2 = 14 \text{ t}\cdot\text{m}$$

$$M_{x2} = ( 0.0287 \times 0.5 + 0.0118 \times 12.5 ) \times 10^2 = 16.2 \text{ t}\cdot\text{m}$$

$$M_{x3} = ( -0.0836 \times 0.5 - 0.0156 \times 12.5 ) \times 10^2 = -23.7 \text{ t}\cdot\text{m}$$

$$M_{x4} = ( -0.0563 \times 0.5 - 0.0239 \times 12.5 ) \times 10^2 = -32.7 \text{ t}\cdot\text{m}$$

$$M_{y1} = ( -0.0523 \times 0.5 - 0.029 \times 12.5 ) \times 10^2 = -38.9 \text{ t}\cdot\text{m}$$

ii) the shearing force




Fig 29. The reaction force diagram

$$S_{x1} = (0.656 \times 0.5 + 0.057 \times 12.5) \times 10.0 = 10.4 \text{ t}$$

$$S_{x2} = (0.414 \times 0.5 + 0.194 \times 12.5) \times 10.0 = 26.3 \text{ t}$$

$$S_{x3} = (0.406 \times 0.5 + 0.286 \times 12.5) \times 10.0 = 37.8 \text{ t}$$

According to the above calculation, the results of the stress calculations are shown in the following tables and the general arrangement of reinforcing bars is shown in Fig 30.

[End Wall]

Intake Open Channel

Table. 11-1 The Calculation Results of The Stress

Member	Point	The Sectional Force			The Sectional Dimensions				The Arrangement of Reinforcing Bars			The stresses (kg/cm <sup>2</sup> )		Remarks		
		M [kg·cm]	N [kg]	S [kg]	B [cm]	h [cm]	d [cm]	d' [cm]	D [mm]	Pitch [mm]	A's [cm <sup>2</sup> ]	A's [cm <sup>2</sup> ]	σ <sub>b</sub>		σ <sub>c</sub>	τ
(1)	1	-2370000	0	10400	100	90	80	10	φ25	125	40.5	40.5	0/5	220	1.5	
	2	-3270000	0	26300	100	75	65	10	φ25	125	40.5	40.5	1405	42.8	4.0	
	3	0	0	37800	100	110	100	10	φ22	125	31.0	31.0	0	0	3.8	
(2)	3	0	0	37800	100	110	100	10	φ22	125	31.0	31.0	0	0	3.8	
	4	-3890000	0	37800	100	110	100	10	φ22	125	31.0	31.0	1369	28.8	3.8	
	5	0	0	37800	100	110	100	10	φ22	125	31.0	31.0	0	0	3.8	
(3)	5	0	0	37800	100	110	100	10	φ22	125	31.0	31.0	0	0	3.8	
	6	-3270000	0	26300	100	75	65	10	φ25	125	40.5	40.5	1405	42.8	4.0	
	7	-2370000	0	10400	100	90	80	10	φ25	125	40.5	40.5	815	22.0	1.5	
(4)	4	-3890000	0	37800	100	110	100	10	φ22	125	31.0	31.0	1369	28.8	3.8	
	8	1620000	0	0	100	75	65	10	φ22	125	31.0	31.0	900	24.2	0	
	9	1400000	0	0	100	90	80	10	φ25	125	40.5	40.5	482	13.0	0	

Where M : Bending moment      B : The Width      D : Diameter of bars      σ<sub>b</sub> : The bending stress  
 N : Axial force                  h : The height              A's : The area of tension bars      σ<sub>c</sub> : The compressive stress  
 S : Shearing force                d : The effective height      A's : The area of compression bars      τ : The shearing stress  
 d' : The covering-of compression bar


1152

[End Wall]  
Intake Open Channel

Table. 11-2 The Calculation Results of The Stress

Member	Point	The Sectional Force			The Sectional Dimensions			The Arrangement of Reinforcing Bars			The stresses (kg/cm <sup>2</sup> )		Remarks		
		M [kg·cm]	N [kg]	S [kg]	B [cm]	h [cm]	d [cm]	d' [cm]	D [mm]	Pitch [mm]	A's [cm <sup>2</sup> ]	σ <sub>b</sub>		σ <sub>c</sub>	τ
(5)	2	3270000	0	0	100	75	65	0	φ25	52	40.5	504	0.22	0	
	8	1620000	0	0	100	75	65	0	φ25	52	40.5	906	0.22	0	
	9	3270000	0	0	100	75	65	0	φ25	52	40.5	504	0.22	0	
(6)	1	2370000	0	0	100	90	80	0	φ25	52	40.5	815	0.22	0	
	9	1400000	0	0	100	90	80	0	φ25	52	40.5	487	0.31	0	
	7	2370000	0	0	100	90	80	0	φ25	52	40.5	815	0.22	0	

Where  
 M : Bending moment  
 N : Axial force  
 S : Shearing force  
 B : The Width  
 h : The Height  
 d : The effective height  
 d' : The covering-of compression bar  
 D : Diameter of bars  
 A's : The area of tension bars  
 A's : The area of compression bars  
 σ<sub>b</sub> : The bending stress  
 σ<sub>c</sub> : The compressive stress  
 τ : The shearing stress



Elevation

Unit : m

Fig 30. The general arrangement of reinforcing bars

1/54