

**FEASIBILITY STUDY
ON
SMALL-SCALE POWER PLANTS
REHABILITATION PROJECT
IN
THE REPUBLIC OF COLOMBIA**


**ZARAGOZA HYDROELECTRIC
POWER PLANT**

MARCH 1990


Japan International Cooperation Agency

MAP OF SOUTH AMERICA

NEW WORLD ATLAS
JINBUNSHA CO., LTD.
(1972)



POLITICAL DIVISION IN THE REPUBLIC OF COLOMBIA




SCALE 0 250 500 km

LEGEND


- Border
- - - Limit of Department
- ⊙ Capital
- Capital of Department
- 1 Intendency
- 2 Commissary

NOTES

- No. Department (Capital)
- 1 CALDAS (Manizales)
 - 2 RISARALDA (Pereira)
 - 3 QUINDIO (Armenia)




Location Map of Study Area




Rio Surata and Diversion weir




Conduction channel



Powerhouse



Francis turbine



Substation

Location Map of Study Area

Photographs

CONTENTS

| | Page |
|---|------|
| CHAPTER 1 INTRODUCTION | 1-1 |
| CHAPTER 2 SUMMARY OF STUDY RESULTS | 2-1 |
| CHAPTER 3 STUDY PLAN | 3-1 |
| 3.1 Organization of Study Team | 3-1 |
| 3.2 Study Items and Study Schedule | 3-2 |
| 3.3 Detail of Field Survey Work | 3-5 |
| CHAPTER 4 PRESENT CONDITIONS OF THE STUDY AREA | 4-1 |
| 4.1 Power Conditions in the Power Sector | 4-1 |
| 4.2 Operation Record of the Existing Power Plant | 4-6 |
| 4.3 General Condition of Generating Equipment and Civil Structures | 4-7 |
| CHAPTER 5 BASIC DATA COLLECTION | 5-1 |
| 5.1 Topographic Maps | 5-1 |
| 5.2 Geological Survey Data | 5-2 |
| 5.3 Hydrometeorological Data | 5-2 |
| 5.4 Other Related Data | 5-4 |
| CHAPTER 6 PRESENT CONDITIONS OF TOPOGRAPHY AND GEOLOGY | 6-1 |
| 6.1 Topography and Geology in the Area | 6-1 |
| 6.2 Geology in the Project Site | 6-2 |
| 6.3 Distribution of Concrete Aggregates | 6-3 |
| 6.4 Geotechnological Evaluation | 6-3 |
| 6.5 Geological Problems | 6-4 |

| | | |
|-----------|---|-----|
| CHAPTER 7 | HYDROLOGICAL ANALYSIS | 7-1 |
| 7.1 | Meteorological Conditions of the Site | 7-1 |
| 7.2 | Discharge Analysis | 7-4 |

| | | |
|-----------|---|-----|
| CHAPTER 8 | GENERATION PLAN | 8-1 |
| 8.1 | Study of Alternative Plans | 8-1 |
| 8.2 | Generated Output | 8-3 |
| 8.3 | Annual Potential Generated Energy | 8-6 |

| | | |
|-----------|---|-----|
| CHAPTER 9 | REHABILITATION PLAN | 9-1 |
| 9.1 | Formulation of Rehabilitation Plans | 9-1 |
| 9.2 | Estimated Rehabilitation Construction Costs | 9-2 |
| 9.3 | Comparison of Economic Indices | 9-6 |

Drawings

Attached Data

CHAPTER 1 INTRODUCTION

The feasibility study (hereinafter referred to as the FS) for the rehabilitation plan of Zaragoza run-of-river type hydroelectric power plant (rated output of 1.56 MW) was conducted following the pre-FS that was carried out for eight months from November, 1987 to June, 1988. This report is prepared to summarize the results of the FS.

This FS was performed in accordance with the Scope of Work (S/W) agreed and signed in July 1988 between Japan International Cooperation Agency (JICA) and Instituto Colombiano de Energia-Eléctrica (ICEL). The study was conducted during 17 months from November, 1988 to March, 1990.

From among 62 small-scale hydroelectric power plants operated by ICEL that were nominated for the study of the rehabilitation plan, Zaragoza hydroelectric power plant (hereinafter referred to as Zaragoza P/P) was selected as a candidate for the FS for the following reasons:

- 1) Although the rated output is 1,560 kW, the present output has dropped to 1,200 kW.
- 2) An increase in generated output, estimated from the discharge and hydrological regime of the Surata River, is anticipated.

From this FS, post-rehabilitation generating scale at Zaragoza P/P for which JICA Study Team proposes as an optimum rehabilitation plan is as follows:

- Maximum output : 2.6 MW
- Annual potential generated power : 18.4 GWh
- Facility utilization factor : 78%

CHAPTER 2 SUMMARY OF STUDY RESULTS

The power plant owned by ESSA, is the run-of-river type (rated output: 1,560 kW), located along the Surata River in Santander Department.

There are three horizontal shaft type Francis turbines, each with an output of 520 kW and manufactured in 1932, 1937 and 1950, respectively. In September, 1989 the output was 77% (1,200 kW) of rated output. Furthermore, the annual generated energy in 1988 was recorded as 4,870.3 MWh.

(1) Present condition of generating facilities and their problems

At the intake site a longitudinal dike, instead of a diversion weir, is installed obliquely across the river to lead the water to the intake. The intake equipment has been repeatedly broken and repaired making it possible to maintain machine potential but difficult to claim it to be a well designed structure. The 1,700-meter-long headrace (open culvert) was constructed along a steep slope down a mountain side along narrow space. The capacity of the head tank is small.

For repair purposes the turbines have been occasionally stopped, although all three turbines (#1, #2 and #3) are still in operation. However, the recorded annual generated energy shows that the equipment utilization ratio is very low, at 36-57%.

| Year | Annual generated energy (GWh) | Equipment utilization ratio (%) |
|------|-------------------------------|---------------------------------|
| 1984 | 6,882.4 | 50 |
| 1985 | 7,757.5 | 57 |
| 1986 | 6,883.7 | 50 |
| 1987 | 5,067.9 | 37 |
| 1988 | 4,870.3 | 36 |

Downstream from the power plant's tailrace, the diversion weir for Bucaramanga City's water supply system and its water purification plant are built. The Study Team gathered

site of the water purificant plant. However, many non-observed dates are contained in the first five years. Only the 1987 and 1988 records can be used as year-round data.

The existence of an active fault, running in the N30°W direction, has been confirmed at a point 300 m downstream from the powerhouse, but this is not directly related to the rehabilitation plans.

(2) Alternative rehabilitation plans

The flow-duration curve for the intake at Zaragoza hydroelectric power plant (see Fig. 2.1) indicates that the existing power plant's maximum available discharge, $Q=6.5 \text{ m}^3/\text{s}$, is a suitable value for the design discharge of a run-of-river power plant, but a plan for increasing the maximum available discharge to $10 \text{ m}^3/\text{s}$ is studied for the purpose of comparison.

Table 2.1 shows the summary of alternative rehabilitation plans.

Fig-2.1 TYPICAL FLOW DURATION CURVE AT INTAKE SITE




Table 2.1 Alternative Plans for Zaragoza Hydroelectric
Power Plant Rehabilitation

| Item | Alternative | |
|--------------------------------------|---|---|
| | Rehabilitation of the existing facilities | Increase of power output |
| | REH-1 | ALT-1 |
| Discharge, Q (m ³ /s) | 6.5 | 10.0 |
| Max. output, P (kW) | 1,700 | 2,600 |
| Facility utilization factor (%) | 96.5 | 78 |
| Rehabilitation and improvement plan: | | |
| Diversion weir | Maintain the structure of longitudinal dike. | Will be reconstructed into diversion weir and sand flush gate will be built. |
| Intake | Maintain as existing. | Design will be changed to accommodate diversion weir. |
| Desilting basin | A new, suitable-sized one will be constructed. | |
| Conduction channel | Maintain as existing. | Will be extended and reconstructed. |
| Head tank | Will be expanded to increase storage capacity. | |
| Penstocks | Maintain as existing. | New construction. |
| Generating equipment | Will be installed new 2 units. | |
| Powerhouse building | New foundations for generating equipment will be built in existing building. | |

(3) Selection of optimum plan

Comparative study results of alternative plans are summarized in Table 2.2. ALT-1 has more benefits than REH-1, therefore ALT-1 is selected as optimum plan.

Table 2.2 Comparison of Rehabilitation Plan for the Zaragoza Power Plant

| Alternative Plan | ① Specifications for Existing Generating Facilities | | | | | ② Rehabilitation Plan | | | | | | | ③ Recovered or Increased Energy | |
|------------------|---|--------------------------|-------------------------------|-----------------------------|------------------------------------|--|-----------------------------------|---|--------------------------------|---|--|---|---|---|
| | ⑩ | ⑪ | ⑫ | ⑬ Present facility capacity | | ⑳ | ㉑ | ㉒ | ㉓ | ㉔ | ㉕ | ㉖ | ㉗ | ㉘ |
| | Max. available discharge Q_0 (m^3/s) | Net head H_0 (m) | Rated output P_0 (kW) | ⑭ | ⑮ | Max. available discharge Q_1 (m^3/s) | Standard net head H_1 (m) | Theoretical output $= 9.8 \times ㉒ \times ㉔$ (kW) | Resultant efficiency η | Output $= ㉒ \times ㉓$ P_1 (kW) | Annual probable generated energy E_1 (GWh) | Facility utilization factor ε (%) | Output $= ㉒ - ㉔$ ΔP (kW) | Annual probable generated energy ΔE (GWh) |
| | | | | Output P_e (kW) | Generated energy E_e (GWh) | | | | | | | | | |
| REH-1 | 6.5 | 30.0 | 1,560 | 1,200 | 6.29 | 6.5 | 32.8 | 2,089 | 0.830 | 1,700 | 14.7 | 96.5 | 500 | 8.4 |
| ALT-1 | | | | | | 10.0 | 32.8 | 3,214 | 0.830 | 2,600 | 18.4 | 78 | 1,400 | 12.1 |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |

| Alternative Plan | ④ Rehabilitation Work Cost (US\$1000) | | | | | ⑤ Construction Cost per kW (US\$/kW) | | ⑥ Total of Annual Cost at Generating Terminal (US\$1000) | | | | | ⑦ Average Generating Cost per kWh (mills/kWh) | | ⑧ Cost/Benefit | ⑨ |
|------------------|---------------------------------------|------------------------------------|----------------|--------------------------|--------------|--|--|--|---|------------------------------|-------|-------|---|---|----------------|----------------|
| | ④⑩ Generating Equipment Cost | | | ④④ | ④⑤ | ⑤⑩ | ⑤⑪ | ⑥⑩ | ⑥① Principal repayment amount for construction cost (25-year average) | | | ⑥③ | ⑦⑩ | ⑦⑪ | C/B | Priority order |
| | ④① | ④② | ④③ | Civil work cost C_2 | ④③+④④ C | Cost per ΔP $= ④⑤/⑤⑩$ $C/\Delta P$ | Cost per P_1 $= ④⑤/⑤⑪$ C/P_1 | Operation and maintenance costs AOM | ⑥② | ⑥③ | ⑥④ | ⑥③+⑥④ | per E_1 $= ⑥③/㉕$ $\div 0.95$ | per ΔE $= ⑥③/㉘$ $\div 0.95$ | | |
| | Foreign currency portion C_{1f} | Local currency portion C_{1l} | ④①+④② C_1 | | | | | | 2.610 x ④① $\div 25$ | 2.016 x [④②+④④] $\div 25$ | ⑥②+⑥③ | | | | | |
| REH-1 | 2,100 | 850 | 2,950 | 400 | 3,350 | 6,650 | 1,950 | 6.0 | 220 | 98 | 318 | 324 | 23 | 40 | 1.91 | 2 |
| ALT-1 | 2,250 | 900 | 3,150 | 1,000 | 4,150 | 2,900 | 1,600 | 10.4 | 236 | 154 | 390 | 400 | 23 | 35 | 1.74 | 1 |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | |

(Notes) ① : For the existing generating equipment specifications, refer to the facility register record attached to the pre-FS report.

⑦ : Generating cost = $\frac{\text{Total of annual average cost at generating terminal}}{\text{Annual average supplied electric power}}$

③ : C/B is the value of cost and benefit ratio calculated according to the financial analysis.

⑬ : E_e is computed according to the average annual operation record for 5 years from 1984 to 1988.

㉓ : η is the resultant efficiency of turbine and generator.

㉕ : E_1 (Energia Media)

㉖ : $\varepsilon = \frac{\text{Annual water amount for turbine } (m^3/s \cdot hr) \times 100(\%)}{Q_1 \times 365 \times 24}$

⑥⑤ : The annual AOM is the amount which is equivalent to US\$4 per kW.

⑥⑥ : Interest is calculated by a repayment of principal in equal annual amounts under the following conditions.

Foreign currency portion: Annual interest rate of 10%, unredeemable for 4 years, repayment over 25 years
Local currency portion : Annual interest rate of 21%, unredeemable for 1 year, repayment over 8 years

CHAPTER 3 STUDY PLAN

3.1 Organization of Study Team

3.1.1 JICA FS Study Team

JICA FS Study Team, listed below, includes the team leader and two members who participated in the pre-FS, engineers, geologists, a hydrologist and an economist.

| Name | Position | Assignment |
|-------------------|-------------|---|
| Masami Ono | Team leader | Total coordinator (civil engineer) |
| Murao Toyama | Team member | Power generation planner (civil engineer) |
| Susumu Nonaka | " | Hydrologist |
| Yoshio Kawasaki | " | Generating equipment planner (civil engineer) |
| Akira Takahashi | " | Generating equipment planner (mechanical engineer) |
| Masayuki Tamai | " | Generating equipment planner (electrical engineer) |
| Nobuhiko Uchiseto | " | Geologist |
| Takashi Inoue | " | Geologist |
| Masaaki Ueda | " | Economist |

3.1.2 Counterpart Engineers from ICEL

Engineers who were engaged in this study as counterparts of the JICA FS Study Team are as follows:

| Name | Field | Position |
|---------------------------|-------------------|---------------------------|
| Juvenal Peñaloza Rosas | Civil Engineering | Head of Central Eng. Div. |
| Jairo E. Gonzalez Morales | Civil Engineering | Central Eng. Div. |
| Mario Gutierrez Ospina | Civil Engineering | Central Eng. Div. |
| Rafael Torres Mariño | Civil Engineering | Central Eng. Div. |
| Rafael Gomez Florez | Civil Engineering | Central Eng. Div. |
| Jorge E. Hurtado Muños | Civil Engineering | Central Eng. Div. |

3.1.3 Supporting Technical Staff from ESSA

JICA FS Study Team obtained cooperation and support from the technical staff listed below, in conducting the site reconnaissance, collecting data and performing engineering consultation necessary for this study.

| Supporting Staff | Position |
|---------------------|------------------------|
| Hernando Uribe Niño | President |
| Ruben Gelves Diaz | Director of Operations |

3.2 Study Items and Study Schedule

The FS was conducted for 17 months from November, 1988 to March, 1990 in accordance with S/W agreed and signed in July, 1988 between JICA and ICEL.

3.2.1 Study Items

Study items for the FS as described in the S/W are as follows:

- (1) Review of the existing data
- (2) Site reconnaissance
- (3) Field work

- 1) Topographic survey
- 2) Photogrammetric mapping
- 3) Geological investigation
- 4) Data collection
- (4) Power survey
- (5) Optimum plan
- (6) Feasibility design
- (7) Stability and safety analyses
- (8) Construction method
- (9) Cost estimation
- (10) Economic and financial analyses
- (11) Maintenance manual

3.2.2 Study Schedule

Table 3.1 shows the overall study schedule as indicated in the S/W.

Two field surveys were conducted at Zaragoza P/P, as shown in Table 3.2.

In the first site reconnaissance, two civil engineers conducted the present-condition study of the existing facilities (mainly civil structures) and collected necessary data.

In the second field survey, a geologist and hydroelectric power generation planner (civil engineer) gathered data relating to the geological survey.

Table 3.1 Time Schedule of FS

| Working item | Year | | 1988 | | | | | | | | | | | | 1989 | | | | | | | | | | | | 1990 | | | |
|--------------|-------------------------------------|--|------|----|---|---|---|---|---|---|---|----|----|----|------|----|----|----|----|---|--|--|--|--|--|--|------|--|--|--|
| | Month | | 11 | 12 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 1 | 2 | 3 | 4 | | | | | | | | | | |
| | Project month | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 | 16 | 17 | | | | | | | | | | | |
| Field works | 1. Review of existing data | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 2. Site reconnaissance | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | (1) Programming | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | (2) Procurement procedure | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | (3) Ground survey | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | (4) Photogrammetric mapping | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | (5) Geological investigation | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | (6) Data collection | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 4. Power survey | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 5. Optimum plan | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 6. Feasibility design | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| Report | 7. Stability & safety analyses | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 8. Construction method | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 9. Cost estimation | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 10. Economic and financial analyses | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 11. Maintenance manual | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 1. Inception report | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 2. Progress report | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 3. Interim report | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 4. Draft final report | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | 5. Final report | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |

Legend:

JICA field operation

ICEL field operation

JICA operation in Japan

Report submission

Legend: JICA field operation JICA operation in Japan Report submission

Table 3.2 Field Survey Schedule

The first site reconnaissance

| Date | Schedule | Detail of Study Item | Member | |
|---------|----------------------|---|-----------|---------------------------------|
| | | | ICEL | JICA |
| Jan. 23 | Bogota → Bucaramanga | Discussion at ESSA, and data collection | R. Torres | Murao Toyama Yoshio Kawasaki |
| Jan. 24 | | Field survey at Zaragoza P/P | | |
| Jan. 25 | | Discussion at ESSA, and data collection | | |

The second field survey

| Date | Schedule | Detail of Study Item | Member | |
|--------|----------------------|--|-----------|----------------------------------|
| | | | ICEL | JICA |
| July 7 | Bogota → Bucaramanga | Discussion at ESSA, and field survey at Zaragoza P/P | R. Torres | Yoshio Kawasaki Takashi Inoue |
| July 8 | Bucaramanga | Field survey at Zaragoza P/P | | |

3.3 Detail of Field Survey Work

The field survey work planned in consultations between JICA Study Team and ICEL counterpart staff according to the results of the site reconnaissance, included topographic surveying and boring survey as described below, but did not include photogrammetric mapping.

3.3.1 Scope of Topographic Surveying

The scope of topographic surveying is shown in Fig. 3.1. The scales for the topographic maps are as follows:

- (1) The diversion weir, conduction channel, desilting basin, head tank and powerhouse building are drawn on a scale of 1/200 with contour lines of 2 m. The bench marks were set up at three locations.

3.3.2 Boring Survey Work Plan

The boring survey was conducted at four locations as shown in Fig. 3.1.




Fig. 3.1

CHAPTER 4 PRESENT CONDITIONS OF THE STUDY AREA

4.1 Power Conditions in the Power Sector

Power conditions in the public electric power company, operating the power plant under study for rehabilitation (hereinafter called public electric power company) are described below.

4.1.1 Balance of Power Supply and Demand

Table 4.1 shows figures for power supply and demand during the five years from 1983 to 1987. In 1987, peak demand was 151 MW, while installed capacity was 135 MW (89%). In 1987, electric power was 599 GWh, while supplied power was 234 GWh, representing about 39% of total electric power. The public electric power company bought electricity to cover electric power of 545 GWh from an other electric power company.

The breakdown of power demand in 1987 indicates that power demand for residential, commercial, industrial, and miscellaneous uses was 50%, 15%, 23% and 12% respectively. Power demand for residential was high, while that for commercial was low.

Annual average rate of increase in power demand from 1983 to 1987 was 5.0%, while that of generated energy dropped to -15.2%, and the rate of electricity buying increased.

Table 4.1 Transition of Power Supply and Demand
(1983-1987)

| Item | 1983 | 1984 | 1985 | 1986 | 1987 | Annual Average Increase Rate(%) * |
|----------------------------|------|------|------|------|------|--|
| DEMAND | | | | | | |
| 1. Peak Demand (MW) | 106 | 125 | 144 | 137 | 151 | 9.2 |
| 2. Electric Power (GWh) | | | | | | |
| 1) Residential | 245 | 266 | 281 | 291 | 298 | 5.0 |
| 2) Commercial | 74 | 84 | 87 | 86 | 89 | 4.7 |
| 3) Industrial | 105 | 129 | 144 | 127 | 135 | 6.5 |
| 4) Industrial | 68 | 131 | 119 | 69 | 77 | 3.2 |
| Total | 492 | 610 | 631 | 573 | 599 | 5.0 |
| SUPPLY | | | | | | |
| 1. Installed Capacity (MW) | 159 | 159 | 135 | 135 | 135 | -4.0 |
| 2. Generated Energy (GWh) | 453 | 451 | 530 | 191 | 234 | -15.2 |
| 3. Power Loss (GWh) | 94 | 77 | 100 | 163 | 180 | 17.6 |

(Source: INFORME ESTADISTICO; RESUMEN 1983-1987)

* Annual average increase rate is calculated as follows:

Example: When peak demand is 9.2%,

$$106 \times (1 + x)^4 = 151$$

$$x = 0.092 \text{ (9.2\%)}$$

4.1.2 Present Conditions of Generating Facilities

(1) Generating facilities

Table 4.2 shows total installed capacity of the public electric power company. Its generating system facilities include hydroelectric power and thermal power.

Table 4.2 Total Installed Capacity of the Public Electric Power Company
(1983 - 87)

| Item | 1983 | 1984 | 1985 | 1986 | 1987 | Annual Average Increase Rate (%) |
|----------------------------------|------|------|------|------|------|---|
| Total Installed Capacity (MW) | | | | | | |
| 1. Thermal | 133 | 133 | 109 | 109 | 109 | -4.9 |
| 2. Hydroelectric | 26 | 26 | 26 | 26 | 26 | 0 |
| 3. Others | 0 | 0 | 0 | 0 | 0 | 0 |
| Total | 159 | 159 | 135 | 135 | 135 | -4.0 |

(Source: INFORME ESTADISTICO: RESUMEN 1983-87)

Table 4.3 shows conditions of Zaragoza power plant for which this FS was conducted.

Table 4.3 Conditions of Zaragoza Power Plant
(1984-1988)

| Item | 1984 | 1985 | 1986 | 1987 | 1988 |
|----------------------------|-------|-------|-------|-------|-------|
| 1) Installed capacity (kW) | 1,560 | 1,560 | 1,560 | 1,560 | 1,560 |
| 2) Generated energy (MWh) | 6,883 | 7,757 | 6,884 | 5,068 | 4,870 |
| 3) Utilization factor (%) | 50 | 57 | 50 | 37 | 36 |
| 4) Operating time (%) | 63 | 69 | 62 | 45 | 45 |

(Source: ESSA)

(2) Transmission facilities

The public electric power company provides 115 kV transmission lines. The voltage transmitted is 11.4 kV.

4.1.3 Generating Cost and Electric Charges

Table 4.4 indicates the transition of generating costs and electric charges in the past five years from 1983 to 1987.

Table 4.4 Generating Cost and Electric Charges

| Item | 1983 | 1984 | 1985 | 1986 | 1987 | Annual Average Increase Rate(%) |
|---|---------|---------|---------|---------|---------|---|
| Generating Cost (COL \$/kWh) | 4.30 | 4.50 | 5.67 | 7.84 | 9.33 | 21.4 |
| Electric Charge (Average): (COL\$/kWh) | | | | | | |
| 1. Residential | 2.95 | 3.25 | 3.23 | 5.93 | 7.93 | 28.0 |
| 2. Commercial | 4.85 | 5.70 | 7.00 | 9.77 | 12.45 | 26.6 |
| 3. Industrial | 3.16 | 3.48 | 3.99 | 9.48 | 11.71 | 38.7 |
| 4. Public use | 3.29 | 3.92 | 4.62 | 6.86 | 8.78 | 27.8 |
| 5. Average | 3.27 | 3.55 | 4.08 | 7.35 | 9.49 | 30.5 |
| Breakdown of Power Demand by customer | | | | | | |
| 1. Residential | 140,211 | 155,422 | 174,494 | 185,247 | 197,318 | 8.9 |
| 2. Commercial | 13,823 | 14,932 | 14,891 | 15,269 | 14,979 | 2.0 |
| 3. Industrial | 1,617 | 1,717 | 1,656 | 1,551 | 1,532 | -1.3 |
| 4. Others | 2,686 | 2,944 | 3,253 | 4,496 | 3,292 | 5.2 |
| 5. Total | 158,337 | 175,015 | 194,294 | 206,563 | 217,121 | 8.2 |
| Diffusion of Electricity | | | | | | |
| 1. Overall (1000 households) | 1,381 | 1,408 | 1,438 | 1,467 | 1,497 | 2.0 |
| 2. Power demand (1000 households) | 670 | 743 | 834 | 885 | 943 | 8.9 |
| 3. Electrification rate (%) | 49 | 53 | 58 | 60 | 63 | 6.5 |

(Source: INFORME ESTADISTICO: RESUMEN 1983-87)

4.1.4 Forecast of Power Supply and Demand

The supply and demand balance until 1995 are estimated, as shown Fig. 4.1, based on the conditions of supply and demand as shown in Table 4.1. The estimated annual average increase in electric power is as follows.

- 1) the annual average increase rate in power demand is 5.0%
- 2) the annual average increase in generated power is -15.2%
- 3) the average increase in power loss is 17.6%
- 4) the amount of electricity to be bought is calculated by the following formula:
Electricity to be bought = (demand + power loss) - generated power

As an example, the power demand in 1995 will be as follows:

$$599 \times (1 + 0.05)^8 = 885 \text{ GWh}$$




Fig. 4.1 Estimation of Power Demand

4.2 Operation Record of the Existing Power Plant

4.2.1 Generated Energy

Records of generated energy and operating time during five years from 1984 to 1988 are shown in Table 4.5. Long stoppage periods during these five years were as follows;

Unit 1: Mar. - Apr. 1985
Jan. 1986
Jun. - Aug. 1987

Unit 2: Oct. - Dec. 1988

Unit 3: Nov. 1986 - June 1988
Aug. - Sept. 1988

During these five years the average equipment utilization ratio was 46% and it is presumed that the turbine's efficiency has been reduced.

Table 4.5 Record of Generated Energy and Running Time

| Year | Unit No. | Output inscribed on the name plate (MW) | Generated energy (MWh) | Total generated energy (MWh) | Running time (hour) | Total running period (hour) | Facility utilization factor (%) | Total facility utilization factor (%) | Operation factor (%) | Total operation factor (%) |
|------|----------|---|------------------------|------------------------------|---------------------|-----------------------------|---------------------------------|---------------------------------------|----------------------|----------------------------|
| 1984 | 1 | 0.52 | 2,181.4 | 6,882.4 | 5,385 | 16,680 | 48 | 50 | 61 | 63 |
| | 2 | 0.52 | 2,801.0 | | 6,495 | | 61 | | 74 | |
| | 3 | 0.52 | 1,900.0 | | 4,800 | | 42 | | 55 | |
| 1985 | 1 | 0.52 | 1,592.2 | 7,757.5 | 3,982 | 18,150 | 35 | 57 | 45 | 69 |
| | 2 | 0.52 | 3,312.6 | | 7,429 | | 73 | | 85 | |
| | 3 | 0.52 | 2,852.7 | | 6,739 | | 63 | | 77 | |
| 1986 | 1 | 0.52 | 1,831.0 | 6,883.7 | 4,684 | 16,266 | 40 | 50 | 53 | 62 |
| | 2 | 0.52 | 3,080.0 | | 7,045 | | 68 | | 80 | |
| | 3 | 0.52 | 1,972.7 | | 4,537 | | 43 | | 52 | |
| 1987 | 1 | 0.52 | 1,947.2 | 5,067.9 | 4,602 | 1,869 | 43 | 37 | 53 | 45 |
| | 2 | 0.52 | 3,120.7 | | 7,267 | | 69 | | 83 | |
| | 3 | 0.52 | 0.0 | | 0 | | 0 | | 0 | |
| 1988 | 1 | 0.52 | 2,764.0 | 4,870.3 | 6,647 | 11,724 | 61 | 36 | 76 | 45 |
| | 2 | 0.52 | 1,650.0 | | 3,921 | | 36 | | 45 | |
| | 3 | 0.52 | 456.3 | | 1,156 | | 10 | | 13 | |

(Note)

$$1. \text{ Facility utilization (\%)} = \frac{\text{Generated energy (MWh)}}{8,760(\text{hr}) \times \text{Output inscribed on the name plate (MW)}} \times 100$$

$$2. \text{ Operation factor (\%)} = \frac{\text{Running time (hr)}}{8,760 (\text{hr})} \times 100$$

4.3 General Condition of Generating Equipment and Civil Structures

4.3.1 General Condition of Generating Equipment

Conditions of generating equipment are summarized below:

(1) Generating equipment

The turbines were manufactured in 1950 (#1 unit), 1932 (#2 unit) and 1937 (#3 unit) and so are 40, 58 and 53 years old respectively. Since they are old machines, equipment utilization ratio in the latest five years has been 46% and it is presumed that the turbine's efficiency has decreased. According to an ESSA survey, it is reported that the casing and runner of each of the three units have been worn out by sand and therefore ESSA need replacements with more efficient new equipment.

(2) Substation

Four transformers are installed next to the powerhouse building, and these boost the generator voltage of 11.4 kV for distribution to two locations. These transformers are 60 years old but are still in working condition.

(3) Distribution line

Distribution lines of 11.4 kV run from this plant to Principal substation, Matanza Surata, California, etc. These distribution lines are in working condition.

4.3.2 General Condition of Civil Structures

(1) Intake facilities

Instead of the diversion weir, the longitudinal dike (65 m long, 3 m high) is installed obliquely across the river to lead the water to the intake. The longitudinal dike is provided with two wooden stop gates (2.0 m(W) x 3.0 m) and one 2 m wide metal gate. The wooden gates were damaged, but the metal gate does not function properly.


Only the screens are installed at the intake. There is no regulating gate installed. Intake facilities have been damaged and rehabilitated. Though they are maintained in good condition, their structures are not fairly designed.

(2) Conduction channel

The open culvert (3.0 m wide, 1.5 m deep, 1,685 m long) is built on a steep slope on the lower part of the mountain. Because of steep longitudinal gradient, the water tends to flow obliquely in the channel. Because of geological restrictions, the expansion of the channel is not advisable for the rehabilitation.

(3) Desilting basin

The overflow type desilting basin is located 180 m downstream from the intake.



The desilting basin (average width: 13.0 m, length: 60.0 m, average depth: 2.9 m) has sufficient capacity to the designed discharge of 6.5 m³/s. But gates have deteriorated.

(4) Head tank

The effective storage capacity of the head tank (width: 2.6~11.0 m, length: 35.5 m, depth: 2.1 m) is about 450 m³ which is equivalent to a 70-second capacity; 1/2 of targeted capacity (120 seconds).

(5) Penstock

The maintenance of the penstocks ($\phi = 1.52$ m, $L = 107.3$ m) has been done properly, and this makes it unnecessary for the penstocks to be rehabilitated.

(6) Powerhouse building

The RC building (14.0 m wide, 26.0 m long, 7.0 m high) has been maintained in rigid state. Three generators are installed in the spacious building.

CHAPTER 5 BASIC DATA COLLECTION

The pre-FS was conducted from November, 1987 to July, 1988. It was followed by the FS from November, 1988, to collect topographical, geological and hydrometeorological data, detailed in the following.

5.1 Topographic Maps

Zaragoza P/P is located north of Bucaramanga City, and the intake is 1 km downstream from where the Toma River and the Surata River meet.

The JICA study team collected the following topographic data.

- Topographic maps (scale 1:25,000 - 1:400,000) published by IGAC
- Topographic maps from measurements taken by ESSA for this study.

(1) Topographic maps published by IGAC

| Scale | Drawing No. | Description |
|-----------|--------------|--------------------------------|
| 1:100,000 | 109 | vicinity of power plant |
| 1:100,000 | 110 | vicinity of power plant |
| 1:100,000 | 120 | downstream area of power plant |
| 1:100,000 | 121 | downstream area of power plant |
| 1:25,000 | 109-IV-B,C,D | vicinity of power plant |
| 1:25,000 | 110-III-C | vicinity of power plant |
| 1:25,000 | 120-II-B | downstream area of power plant |
| 1:25,000 | 121-I-A | downstream area of power plant |

(2) Topographic Maps Measured by ESSA

| Scale | Drawing No. | Description |
|----------|-------------|--|
| H:1/1000 | 1 de 6 | Plan and profile of conduction channel (1/2) |
| V:1/100 | 2 de 6 | Plan and profile of conduction channel (2/2) |
| 1/200 | 3 de 6 | Plan of intake facilities and vicinity |
| " | 4 de 6 | Plan of desilting basin and vicinity |
| " | 5 de 6 | Plan of head tank ~ power plant |
| " | 6 de 6 | Longitudinal section of conduction channel |

5.2 Geological Survey Data

Geological survey data collected for this survey is as follows:

- Mapa Geologico de Colombia 1988, INGEOMINAS
- Aerial photographs of this power plant and vicinity
- Optimizacion planta de Zaragoza de la electrificadora de Santander 1989, Ingenieria de Suelos Ltda

5.3 Hydrometeorological Data

Since Zaragoza P/P does not have the facilities for monitoring precipitation levels and discharge, JICA Study Team gathered hydrometeorological data from HIMAT and CAMBSA (Compañía del Acueducto Metropolitano de Bacaramanga S.A.) when conducting this survey.

Precipitation observation and gauging stations, and the duration of monitoring records are listed below. JICA Study Team obtained discharge observation recorded for 7 years from 1982 to 1988 on the Surata River which is directly related to this FS.

Table 5.3 List of Data Collected Relating to Hydrometeorology

(1) Precipitation-observation record

| Meteorological station | | Controller | Location | | Altitude (m) | Observation period |
|------------------------|----------------------|------------|----------|-----------|--------------|--------------------|
| No. | Name | | Latitude | Longitude | | |
| 2319-036 | Portachuelo | HIMAT | 0720 | 7310 | 800 | 1971-86 |
| 2319-034 | Matajira | " | 0713 | 7304 | 996 | 1967-86 |
| 2319-035 | Llano de Polmas | " | 0715 | 7312 | 778 | 1967-86 |
| 2319-504 | Unive Ind. Santander | " | 0708 | 7306 | 1018 | 1961-85 |

(2) Discharge-observation record

| Hydrological gauging station | | River | Controller | Establishment | Location | | Altitude (m) | Catchment area (km ²) | Observation period |
|------------------------------|-------------|---------|------------|---------------|----------|-----------|--------------|-----------------------------------|--------------------|
| No. | Name | | | | Latitude | Longitude | | | |
| 2319729 | Cafe Madrid | Lebrija | HIMAT | 1968-12 | 0717 | 7308 | 600 | 1284 | 1975-85 |
| | Zaragoza | Surata | CAMBSA | - | - | - | 700 | - | 1982-88 |

(3) Water quality data

The observation data of water quality for the Surata River which was controlled by CAMBSA was obtained.

- 1) pH : Oct. 1981 ~ Dec. 1983, Mar. ~ Apr., 1989
- 2) Conductivity : May 19 ~ May 26, 1989
- 3) S : 1982, Jan. ~ Dec. 1983
- 4) Fe : 1982, 1983
- 5) Cl : March 1982 ~ May 1989

In addition, the water quality data for the Lebrija River was obtained.

Observation period : Nov. 30, 1983 ~ Dec. 15, 1984

Observation items : pH, Cl, HCO₃, etc.

(4) Sediment data

JICA Study Team collected records relating to sediment at the places listed below, along the Surata River controlled by CAMBSA.

| Place | Observation year | Altitude (MSNH) |
|----------|------------------|-----------------|
| Zaragoza | 1986 ~ 1989 | 700 |
| Bahondo | 1987 ~ 1989 | - |
| Matajira | 1987 ~ 1989 | 950 |
| Siparas | 1986 ~ 1989 | 1,140 |
| Charta | 1986 ~ 1989 | 1,600 |
| Unagato | 1986 ~ 1989 | 1,725 |
| Povedas | 1986 ~ 1989 | 1,930 |
| La Baja | 1987 ~ 1989 | 2,000 |

5.4 Other Related Data

5.4.1 Construction Prices Data

Construction prices for civil works in Colombia are based on "Catalogo de Precios de Materiales de Construcción (Catalog of Construction Material Prices)" published by CAMACOL (Camera Colombiano de la Construcción) in Santander Department. However, the above publication is not published in all departments of Colombia. To coordinate the data of the power plant sites where the FS was conducted, construction prices used for this study are based on price data used within ESSA (refer to Table 5.2).

Table 5.2 UNIT PRICE LIST
表-5.2 建設工事単価表

| | UNIT | EADE | CHEC | CEDELCA | | E. CHOCO | CEDENAR | ESSA | ELECTROLIMA |
|-------------------------------|------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-------------|
| | | | | SILVIA | OVEJAS | | | | |
| 1. EARTH WORK (EARTH) | p/m ³ | NOV./88 | FEB./89 | JUN./89 | JUN./89 | MAR./89 | JUN./89 | APR./89 | MAY/89 |
| 2. EARTH WORK (ROCK) | p/m ³ | 2,400 | 2,925 | 700 | 800 | 2,950 | 990 | 2,500 | 1,100 |
| 3. CONCRETE WORK (MASS CON.) | p/m ³ | - | 3,965 | - | - | 24,000 | 1,900 | - | 2,800 |
| 4. CONCRETE WORK (STRUCTURAL) | p/m ³ | 26,300 | 27,625 | 34,000 | 40,000 | 26,800 | 20,500 | 15,600 | 17,900 |
| 5. REINFORCING BAR | p/t | 354,000 | 454,000 | 350,000 | 360,000 | 447,500 | 300,000 | 320,000 | 215,000 |
| 6. GATE | p/t | 1,682,000 | 500,000 | 1,310,000 | 1,420,000 | 1,100,000 | 1,100,000 | 1,100,000 | 480,000 |
| 7. SCREEN | p/t | 1,682,000 | 5,000,000 | 804,195 | 874,125 | 1,000,000 | 1,000,000 | 1,000,000 | 650,000 |
| 8. PENSTOCK | p/t | 1,000,000 | 1,000,000 | 1,250,000 | 1,250,000 | - | 815,000 | 1,260,000 | 420,000 |
| 9. POWER HOUSE (REPAIR) | p/m ² | - | 10,000 | - | - | - | - | - | - |
| 10. POWER HOUSE (NEW CONST.) | p/m ² | - | 40,000 | 47,000 | 55,000 | 50,000 | 50,000 | 50,000 | 50,000 |
| 11. CYCLOPEAN CONCRETE | p/m ³ | - | 14,000 | 17,000 | 20,000 | - | - | 8,000 | 9,000 |
| 12. DEMOLITION CONCRETE | p/m ³ | 13,000 | 14,000 | 17,000 | 20,000 | - | - | 8,000 | 9,000 |
| 13. STEEL PIPE | p/t | - | - | - | 1,250,000 | - | - | - | - |
| 14. GABION | p/m ³ | - | - | 8,800 | - | - | - | - | - |
| 15. TUNNEL EXCAVATION | p/m ³ | - | - | - | - | - | - | - | 19,600 |
| 16. TUNNEL CONCRETE | p/m ³ | - | - | - | - | - | - | - | 25,000 |

5.4.2 Power Condition Data

- (1) JICA Study Team collected the following data for the purpose of examining ESSA's power condition.
 - 1) ESSA's power schematic diagram
- (2) JICA Study Team gathered the following data relating to Zaragoza P/P.
 - 1) Residual value

CHAPTER 6 PRESENT CONDITIONS OF TOPOGRAPHY AND GEOLOGY

6.1 Topography and Geology in the Area

6.1.1 Topography





The source of the River Surata is in the western slope of the northern part of the east mountain range, and flows southwest to join the Lebrija River, a tributary of the Magdalena River near Bucaramanga City, the capital of Santander Department.

The project site is situated halfway downstream of the Surata River. The topography around the project site is formed by relatively steep V-shaped valleys.

6.1.2 Geology

The bedrock consists of pre-cambrian gneiss, on which laterized terrace, talus and riverbed deposits are distributed locally. The Bucaramanga Active Fault is located 300 m west of the power plant site in a NNW-SSE direction. The stratigraphy in the vicinity of the project site is shown in Table 6.1.

Table 6.1 Stratigraphy in the Vicinity of Project Site

| Era | Schematic column | Strata | Remarks |
|-------------------|---|---|---------|
| Quaternary period |  | Riverbed deposits Debris flow deposits | |
| |  | Talus deposits | |
| |  | Terrace deposits | |
| Pre-Cambrian |  | Gneiss | |

6.1.3 Geological Structure

The topography to the west of the power plant has a clear contour, corresponding to the Bucaramanga Fault. According to a survey there are gneiss outcrops at least

300 m west of the power plant. From here the fault line runs in a westward direction.

6.2 Geology in the Project Site

The general conditions for the various geological bases for the foundations of the power plant are outlined below.

1) Diversion weir

While there are gneiss outcrops on the right bank of the river, there are no outcrops on the left bank. Upstream, on the right bank, there is a deep swamp and near the mouth of the swamp the gneiss is overlain by debris flow deposits. The riverbed deposits are about 2 m thick so that the diversion weir is not directly on rock.

2) Conduction channel

The conduction channel is built on gneiss, and terrace and talus deposits are distributed on both the mountain side and river-side of the channel.

3) Desilting basin

In the vicinity of the desilting basin, a good terrace deposit covers the gneiss. Thus, the desilting basin has a good rock foundation.

4) Head tank and penstock

The head tank is built on gneiss while the penstock is built on talus deposit. In the vicinity of the head tank the gneiss is well-weathered and decomposed.




Fig. 6.1 Schematic Geological Profile

5) Powerhouse

In the powerhouse area, terrace deposits cover gneiss. The powerhouse structure is built on terrace deposits. According to a boring survey the level of bedrock under the terrace is the same as the riverbed level.

6.3 Distribution of Concrete Aggregates

Both the riverbed and the debris flow deposits are suitable for aggregates.

6.4 Geotechnological Evaluation

- 1) The project site has generally thin-layered deposits overlying a deep bedrock. The bedrock is a pre-cambrian gneiss, which is hard and fine grained in a natural state. The foundations for the various buildings and a 10 m high concrete dam have sufficient bearing capacity and impermeability.
- 2) Civil structures, except the diversion weir, have no geological problems since they are built on bedrock. It is presumed that the diversion weir is built on the 2 m thick riverbed deposits.

According to an on-site survey, the riverbed deposits have a sufficient bearing load to support a dam of the existing size. However, a new dam will need to be built on bedrock, because of load and impermeability requirements.

- 3) In the vicinity of the project site there is no evidence of large-scale landslides, although one large section of the conduction channel has collapsed. Furthermore at a steep gradient section of the water channel there is evidence of falling stones.

6.5 Geological Problems

- 1) Regional literature suggests that the Bucaramanga Fault is still active. At the detailed design stage, a region survey will evaluate the activity. It will also be necessary to design the various buildings to resist earthquakes.
- 2) Countermeasures to prevent falling stones and further collapse of the conduction channel will need to be implemented.

CHAPTER 7 HYDROLOGICAL ANALYSIS

The locations of the gauging stations for monitoring precipitation and discharge at the watershed of this project site are shown in Table 7.1.

7.1 Meteorological Conditions of the Site

Santander Department, in north Colombia, lies at 5°43'~8°11' north latitude, near the equator. Tolima Department is mainly divided into mountainous and plain areas.

Generally, the lowland has a tropical climate, with a humid and rainy area. It changes from a temperate to a frigid climate zone with increasing altitude. The temperature is 28° C in the lowland area, dropping to 12° C at an elevation of 1800 - 2800 m, and around 10° C over 3000 m. The capital, Bucaramanga City, is located at an elevation of 1000 m with an average temperature of 20° C.


Annual average rainfall is recorded at 2000 - 3000 mm in the lowland areas, but drops to 1000 - 2000 mm at higher elevations.

The Surata River originates on the western slope of the Andes Mountain range, flowing downward to the south, and branches into the Oro River, near Bucaramanga City and Lebrija River in the northwest. Including Magdalena River, the Surata River is about 45 km long.

Bucaramanga City is located at an elevation of 800 m, in a temperate climate with an average temperature of 20° C and annual rainfall of 1000 m - 2000 m. Rainfall fluctuates year to year, though the rainy and dry seasons are not readily distinguishable (refer to Fig. 7.2).

| Observation Item | Gauging Station | | Latitude | Longitude |
|---------------------|-----------------|---------------------|----------|-----------|
| | No | Name | | |
| Discharge | 2319-729 | Cafe Madrid | 0717 | 7308 |
| | ----- | Zaragoza | ----- | ----- |
| Preciptation | 2319-036 | Portachuelo | 0720 | 7310 |
| | 2319-034 | Matjira | 0713 | 7304 |
| | 2319-035 | Ilano De Palmas | 0715 | 7312 |
| | 2319-504 | Unive Ind Santander | 0708 | 7306 |

2319-729
G.S:Cafe Madrid
C.A:1,311.3 Km²



Legend

- :Boundary of Watershed (Intake)
- :Boundary of Watershed (Gauging Station)
- :Gauging Station (Discharge)
- △:Gauging Station (Preciptation)

Scale
0 5km

Fig-7.1 Location Map of Gauging Stations in The Watershed of The Study Area.

Meteorological station No.2319-504 Univ Ind Santander
 North latitude: 7°08'
 West longitude; 73°06'
 Elevation: 1,018 m
 Annual average precipitation: 1,254.1 mm




Fig.7.2 Monthly Average Precipitation in the Project Site (1961-85)

7.2 Discharge Analysis

The discharge and flow duration curves in the project site were compiled by comparing the records of Cafe Madrid and Zaragoza gauging stations. One-year observations recorded at Zaragoza in 1987 were used as the basis for data, after adjustments for the river basin, since it is located very near Zaragoza's intake site.

7.2.1 Collation of Discharge Data

The observation periods for the discharge data collected by the JICA Study Team are as follows:

| Gauging Station | Date established | Observations period |
|-----------------|------------------|---------------------|
| Zaragoza | N/A | 1982 - 1988 |
| Cafe Madrid | December, 1968 | 1975 - 1985 |

Since there were many non-surveyed days during the seven-year period at the Zaragoza gauging station along the Surata River, the application of runoff data is restricted to data collected in 1987 - 88.

All eleven years of observation at Cafe Madrid gauging station at the Surata River can be used as observations were recorded year-round.

(1) Collation of Catchment Area

Since there are no records for the catchment area from HIMAT, the JICA Study Team site survey confirmed the location of the catchment area and plotted the points on IGAC-published topographic maps, scale 1:100,000, as shown in Fig. 7.1.

Table 7.1 Gauging Station Location and Catchment Area Collation

| Item | Cafe Madrid Gauging Station | | |
|-------------------|-----------------------------|-----------|-----------------------------------|
| | Latitude | Longitude | Catchment area (km ²) |
| HIMAT ledger | 0717 | 7308 | 1284 |
| CAMB S.A | - | - | - |
| Observation value | 0710 | 7309 | 1311.3 |
| Difference | 0007 | 0001 | 27.3 |

(2) Collation of Unit Flow Duration Curve per 100 km²

Since only 2-year's discharge data from Zaragoza station is available, it is not considered very reliable. Thus, a comparison of Zaragoza gauging station flow duration curve per 100 km² to the Cafe Madrid gauging station flow duration curve per 100 km² is shown in Fig. 7.3. The fluctuation of annual rainfall during the two-years of data is noted, and the average unit flow duration curve per 100 km² for 1987 at Zaragoza is comparable to that of Cafe Madrid.

Cafe Madrid Gauging Station vs Zaragoza Gauging Station

(Comparison of 11-year average flow-duration curve at Cafe Madrid gauging station and year-to-year average flow-duration curves at Zaragoza gauging station)




Fig. 7.3 Comparison of Unit Flow-duration Curve per 100 km²

7.2.2 Standard Flow-Duration Curve

Year-to-year fluctuations of the river flow-duration curve occur at the same site. To draw a standard flow-duration curve for a particular site, the following methods are considered.

(a) Parallel method

Daily average discharge for 365 days is arranged in descending order, and the flow-duration curves for each year are drawn and averaged.

(b) Standard year method

Flow-duration curves for each year are drawn. From these curves, the median curve is selected and used as the flow-duration curve in the standard year.

(c) Series method

Daily average discharge for 5 years is arranged in descending order, with only the Y-axis adjusted for the one-year curve.

(d) Curve insertion method

Average values of 355-days flow, nine-month flow, ordinary water discharge and three-month flow for long periods (minimum 10 years) are calculated, plotted and drawn according to a discharge handbook.

Standard flow duration curves are drawn according to the parallel method. The X-axis is labeled as daily average discharge (m^3/s), and the Y-axis as number of days (%).

7.2.3 Discharge and Flow-Duration Curve of Zaragoza Gauging Station

Discharge data from the Zaragoza gauging station, located 1.9 km downstream from the intake of Zaragoza power plant, are arranged using 2-year data, as shown in Table 7.3.

In calculating monthly average discharge in Table 7.3, the months with fewer than 10-days of observation data are excluded. From the graphic representation of the monthly average discharge (Drawing No. ZA-H-01, No.1), September to December is determined to be the flow period, while January through August is the drought period.

Using the parallel method, standard flow-duration curves for 1987 are calculated, as shown in Drawing No. ZA-H-01. Flow-duration curves for three-month flow, ordinary flow, nine-month flow and 355-days flow periods are indicated in numerical values, as shown in Table 7.4.

Table-7.3 MONTHLY FLOW TABLE OF DAILY AVERAGE FLOW AT G.S. SITE

| | | GAUGING ST.: --- ZARAGOZA | | | | | | | | | | | | (UNIT: M3/S) | |
|--------------|------|---------------------------|------|------|------|------|------|------|------|------|------|------|------|--------------|--|
| | | RIVER NAME: SURATA | | | | | | | | | | | | | |
| GAUGING YEAR | TYPE | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | ANNUAL TOTAL | |
| 1987 | MAX. | 8.2 | 8.0 | 9.0 | 9.0 | 67.1 | 9.7 | 9.0 | 9.4 | 27.4 | 57.9 | 87.5 | 16.3 | 87.5 | |
| | MEAN | 7.3 | 6.5 | 5.7 | 6.1 | 13.5 | 7.6 | 6.9 | 7.3 | 8.5 | 22.8 | 24.3 | 13.1 | 10.8 | |
| | MIN. | 7.0 | 4.0 | 3.6 | 3.6 | 6.0 | 6.0 | 4.5 | 4.5 | 5.6 | 8.9 | 10.6 | 9.0 | 3.6 | |
| 1988 | MAX. | 10.2 | 33.9 | 13.0 | 32.5 | 39.3 | 34.2 | 19.8 | 47.8 | 62.9 | 50.1 | 99.5 | 32.5 | 99.5 | |
| | MEAN | 9.0 | 11.3 | 9.1 | 11.0 | 12.7 | 12.4 | 16.6 | 20.5 | 29.4 | 26.1 | 43.2 | 20.7 | 18.5 | |
| | MIN. | 8.2 | 8.2 | 6.5 | 8.2 | 8.2 | 7.8 | 14.6 | 14.5 | 11.8 | 14.7 | 21.4 | 16.3 | 6.5 | |
| TOTAL | MAX. | 10.2 | 33.9 | 13.0 | 32.5 | 67.1 | 34.2 | 19.8 | 47.8 | 62.9 | 57.9 | 99.5 | 32.5 | 99.5 | |
| | MEAN | 8.1 | 8.9 | 7.4 | 8.5 | 13.1 | 10.0 | 11.8 | 13.9 | 18.9 | 24.5 | 33.7 | 16.9 | 14.6 | |
| | MIN. | 7.0 | 4.0 | 3.6 | 3.6 | 6.0 | 6.0 | 4.5 | 4.5 | 5.6 | 8.9 | 10.6 | 9.0 | 3.6 | |

Table-7.4

| GAUGING ST.: RIVER NAME: | | SURATA | | | ZARAGOZA | | | (UNIT: M3/S) | |
|-----------------------------|-------------------|---------------------|-----------------------|------------------|-----------------------|--------------------|------|--------------|--|
| GAUGING YEAR | MAX. (1ST DAY) | PLENTY (95 DAY) | ORDINARY (185 DAY) | LQW (275 DAY) | DROUGHTY (355 DAY) | MIN. (LAST DAY) | MEAN | | |
| 1987 | 87.5 | 10.3 | 7.4 | 7.0 | 4.5 | 3.6 | 10.8 | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| MEAN | 87.5 | 10.3 | 7.4 | 7.0 | 4.5 | 3.6 | 10.8 | | |

7.2.4 Discharge and Flow Duration Curves for the Intake Site

The discharge and flow duration curve for the intake site located 1.9 km downstream from the Zaragoza gauging station are calculated by multiplying the catchment area ratio with measurements taken at the gauging station. Since there is no set numerical value for the catchment area, the JICA Study Team's measurement of the watershed area will be adopted. Thus, the ratio of the Zaragoza Power Plant's intake to the gauging station catchment area is set to $685.6/686.7 \div 1.00$.

1) Monthly average discharge

| Item | Month | | | | | | | | | | | | |
|---|-------|------|------|------|------|------|------|------|-------|------|------|------|--------|
| | Jan. | Feb. | Mar. | Apr. | May | Jun. | Jul. | Aug. | Sept. | Oct. | Nov. | Dec. | Annual |
| Max. average discharge (m ³ /s) | 9.0 | 11.3 | 9.1 | 11.0 | 13.5 | 12.4 | 16.6 | 20.5 | 29.4 | 26.1 | 43.2 | 20.7 | 18.5 |
| Daily average discharge (m ³ /s) | 8.1 | 8.9 | 7.4 | 8.5 | 13.1 | 10.0 | 11.8 | 13.9 | 18.9 | 24.5 | 33.7 | 16.9 | 14.6 |
| Min. average discharge (m ³ /s) | 7.3 | 6.5 | 5.7 | 6.1 | 12.7 | 7.6 | 6.9 | 7.3 | 8.5 | 22.8 | 24.3 | 13.1 | 10.8 |

2) Typical discharge of flow-duration curve

| Three-month flow (95-day flow) | Ordinary water discharge (185-day flow) | Nine-month flow (275-day flow) | 355-day flow |
|--------------------------------|---|--------------------------------|-----------------------|
| 10.3 m ³ /s | 7.4 m ³ /s | 6.9 m ³ /s | 4.5 m ³ /s |

The river utilization factor* of a certain available discharge to typical flow-duration curves at the intake site and facility utilization factor** are shown graphically in Drawing No. ZA-H-01 (5).

* The ratio of total available discharge and total river discharge flowing into the intake.

** The ratio of total discharge of water that can flow into the intake to the available discharge throughout the year.

CHAPTER 8 GENERATION PLAN

Since this generation plan is based on a maximum discharge of $6.50 \text{ m}^3/\text{s}$ at the existing plant, to effectuate this plan technologically and economically, the power output and annual output will be calculated from the maximum discharges using the standard discharge-duration curves of the intake site, provided that the facility utilization factor for all of the maximum discharge is not less than 50%.


8.1 Study of Alternative Plans

In rehabilitating the power generating facilities at this site, the intake structure and part of the headrace need to be restored and the head tank needs to be expanded, and the generating facility and transformers require new replacements. Thus, a comparative study will be made of generation-optimizing plans, including the rehabilitation of existing generating facilities.

(1) Maximum available discharge

The existing conduction channel has a discharge capacity of $6.5 \text{ m}^3/\text{s}$. Therefore design discharge of $6.5 \text{ m}^3/\text{s}$ is set and the alternative value is set at $10 \text{ m}^3/\text{s}$.

Fig-8.1 TYPICAL FLOW DURATION CURVE AT INTAKE SITE



(2) Standard net head

Assuming the net head for determining the turbine output and calculating the generating energy is constant, the standard net head (H_e) is calculated accordingly.

$$H_e = H_g - H$$

$$H = v^2/2g (1+f_1 + f_2.L/D + f_m) + h = v^2/2g (1.85 + f_2.L/D) + h$$

where:

H_g = gross head

Head tank water level (732.32 m) - tailrace water level (697.40 m) = 34.92 m

H = total loss of head (m)

$V^2/2g$ = velocity head (m)

f_1 = coefficient of inflow loss; 0.1

f_2 = coefficient of frictional loss; $124.6 n/D$

L = penstock length (m)

D = penstock diameter (m)

f_m = loss coefficient at the branched part, 0.75

h = margin (m)

n = coefficient of roughness, 0.012

Table 8.1 Calculated Result of Standard Net Head

| Q (m^3/s) | D (m) | L (m) | V (m/s) | $v^2/2g$ (m) | $f.L/D$ | $v^2/2g(\Sigma f)$ (m) | h (m) | H (m) | H_e (m) |
|--------------------|------------|------------|--------------|-----------------|---------|---------------------------|------------|------------|--------------|
| 6.5 | 1.52 | 124.5 | 3.58 | 0.654 | 1.28 | 2.05 | 0.47 | 2.52 | 32.40 |
| 10.0 | 2.10 | 124.5 | 2.89 | 0.426 | 0.83 | 1.14 | 0.48 | 1.62 | 33.30 |

Accordingly, the standard net head is set at 32.8 m.

8.2 Generated Output

The theoretical output, extrapolated from available discharge (Q) and standard net head (H_e) is multiplied by the resultant equipment efficiency coefficient as follows.

$$P = 9.8 \times Q \times H_e \times \eta$$

where:

P = generated output (kW)

Q = arbitrary available discharge (m³/s)

H_e = standard net head (m)

η = resultant efficiency of turbine and generator (resultant efficiency of the single unit capacity)

9.8 = constant (acceleration of gravity, m/s²)

Resultant efficiency (η) represents total efficiency, and is calculated as follows.

$$\eta = \eta_t \times \eta_g$$

where:

η_t = turbine efficiency


η_g = generator efficiency

Resultant efficiency corresponds to the value of the maximum available discharge ratio in the resultant efficiency curve shown in Fig. 8.2. Table 8.2 shows the calculation result of the generated output for the alternative plans.

Table 8.2 Generated Output Calculations

| Item Alternative plan | ① | ② | ③ | ④ | ⑤ |
|---|--|----------------------------|---|---------------------------|--|
| | Available discharge Q (m ³ /s) | Standard net head H (m) | $9.8 \times ① \times ②$ Theoretical output (kW) | Resultant efficiency η | $③ \times ④$ Generated output P (kW) |
| Plan for rehabilitating existing facilities (REH-1) | 6.5 | 32.8 | 2,089 | 0.830 | 1,734 |
| Power output increase (ALT-1) | 10.0 | 32.8 | 3,214 | 0.830 | 2,667 |

Fig. 8.2 Resultant Efficiency Curve of Francis Turbine and Generator



(Source: The above curve is drawn according to the study standard for formulation of hydroelectric development plan (March, 1981).

8.3 Annual Potential Generated Energy

Generated energy is calculated as follows.

$$\begin{aligned} E &= P \times t \text{ (kWh)} \\ &= 9.8 \times Q \times H_e \times \eta \times t \end{aligned}$$

where:

$$\begin{aligned} P &= \text{generated output (kW)} \\ t &= \text{operation time (hour)} \end{aligned}$$

Assuming that the power plant operation is not interrupted by accident, nor suspended for maintenance, inspection or repair during the year, the annual potential generated energy is calculated as follows:

- (1) From the runoff data, daily discharge is added to net head and the resultant efficiency coefficient.
- (2) Combining hydrological regime and the resultant efficiency coefficient from the flow-duration curve.
- (3) Using the generating output to available discharge ratio.


Item (2) is used in this calculation for the following reasons.

- (1) The discharge data used in this study was not collected at the water intake, but collected at Zaragoza gauging station, located 1.9 km down stream, run by CAMB S.A.
- (2) Since there are no records for either Zaragoza or the water intake site for the same time period, a simple catchment area ration was used in the calculation of discharge data.

(3) A flow duration curve is also used in (3), but it is not as accurate as (2).

By combining the resultant efficiency coefficient and flow duration data from the flow duration curve, annual potential generated energy can be estimated. Calculation using the hydrological regime-efficiency method is as follows.

ic



Max. available discharge = m^3/s Net head = m

| ① Day | ② Number of days | ③ Available discharge (m^3/s) | ④ Burden ratio $\frac{\text{Available discharge}}{\text{Max. available discharge}}$ | ⑤ Resultant efficiency η | ⑥ Generating power (kW) | ⑦ Average power (kW) | ⑧ Generated energy (kWh) |
|----------|---------------------------|--|---|--|----------------------------------|-------------------------------|-----------------------------------|
| Max. | | | | | | | |
| 95 | 95- | | | | | | |
| 185 | 185-95 = 90 | | | | | | |
| 275 | 275-185 = 90 | | | | | | |
| 355 | 355-275 = 80 | | | | | | |
| 365 | 365-355 = 10 | | | | | | |
| Total | 365 | | | | | () | |

- ① Possible intake-water days of maximum available discharge are inserted for the day order ①.
- ② Represents the difference of the day order of calculation stage and right above stage. This example employed hydrological regime representative days as a matter of convenience.
- ③ The discharge of the day order topped out by maximum available discharge shall be an available discharge.
- ④ Available discharge divided by maximum available discharge shall be input load factor, and the resultant efficiency ⑤ shall be read and entered.
- ⑥ $9.8 \times Q \times H_e \times \eta$
- ⑦ Mean value of generated output of calculation stage and right above stage.
- ⑧ $⑦ \times ② \times 24$ is the generated energy for calculated days, and the total value becomes yearly possible generated energy.

Fig. 8.3 Calculation of Annual Potential Generated Energy According to the Hydrological Regime-Efficiency Method

8.3.1 Calculation of Annual Potential Generated Energy

The annual potential generated energy for respective alternative plans is calculated according to the hydrological regime and efficiency method, with the following results.

- (1) The annual potential generated energy for the rehabilitation plan of the existing facilities (max. available discharge = $3.25 \text{ m}^3/\text{s} \times 2$ units):

14.7 GWh (96.5%)

- (2) The annual potential generated energy for the alternative plan 1 (ALT-1) (max. available discharge = $5.0 \text{ m}^3/\text{s}$):

18.4 GWh (78%)

Table 8.3 Calculation of Annual Potential Generated Energy

- (1) Rehabilitation plan of existing facilities (REH-1)

Max. available discharge $Q = 3.25 \text{ m}^3/\text{s} \times 2$ units

Standard net head $H_e = 32.8 \text{ m}$

Turbine type: Francis turbine

| Day | Number of days | Available discharge (m^3/s) | Burden ratio $\frac{\text{Available discharge}}{\text{Max. available discharge}}$ | Resultant efficiency η | Generating power (kW) | Average power (kW) | Generated energy (MWh) |
|-------|----------------|---|--|-----------------------------|-----------------------|--------------------|------------------------|
| Max. | 294 | 6.5 | 1.000 | 0.830 | 1,734 | 1,734 | 12,235 |
| 306 | 12 | 6.0 | 0.923 | 0.840 | 1,620 | 1,677 | 482 |
| 324 | 18 | 5.6 | 0.861 | 0.842 | 1,515 | 1,567 | 676 |
| 341 | 17 | 5.5 | 0.846 | 0.842 | 1,488 | 1,501 | 612 |
| 359 | 18 | 4.5 | 0.692 | 0.827 | 1,196 | 1,342 | 579 |
| 365 | 6 | 3.5 | 0.538 | 0.779 | 876 | 1,036 | 149 |
| Total | 365 | | | | | (1,476) | 14,733 |

(2) Alternative plan 1 (ALT-1)

Max. available discharge: $Q = 5.0 \text{ m}^3/\text{s} \times 2 \text{ units}$

Standard net head (H_e): 32.8 m

Turbine type: Francis turbine

| Day | Number of days | Available discharge (m^3/s) | Burden ratio $\frac{\text{Available discharge}}{\text{Max. available discharge}}$ | Resultant efficiency η | Generating power (kW) | Average power (kW) | Generated energy (MWh) |
|-------|----------------|---|--|-----------------------------|-----------------------|--------------------|------------------------|
| Max. | 99 | 10.0 | 1.00 | 0.830 | 2,667 | 2,667 | 6,336 |
| 105 | 6 | 9.7 | 0.97 | 0.834 | 2,600 | 2,633 | 379 |
| 110 | 5 | 9.3 | 0.93 | 0.839 | 2,508 | 2,554 | 306 |
| 125 | 15 | 9.0 | 0.90 | 0.840 | 2,430 | 2,469 | 888 |
| 130 | 5 | 8.6 | 0.86 | 0.842 | 2,327 | 2,378 | 285 |
| 135 | 5 | 8.2 | 0.82 | 0.842 | 2,219 | 2,273 | 272 |
| 150 | 15 | 8.0 | 0.80 | 0.841 | 2,162 | 2,190 | 788 |
| 155 | 5 | 7.9 | 0.79 | 0.840 | 2,133 | 2,147 | 257 |
| 182 | 27 | 7.8 | 0.78 | 0.840 | 2,106 | 2,119 | 1,373 |
| 195 | 13 | 7.4 | 0.74 | 0.835 | 1,986 | 2,046 | 638 |
| 292 | 97 | 6.9 | 0.69 | 0.826 | 1,832 | 1,909 | 4,444 |
| 294 | 2 | 6.5 | 0.65 | 0.817 | 1,707 | 1,769 | 84 |
| 306 | 12 | 6.0 | 0.60 | 0.802 | 1,546 | 1,626 | 468 |
| 324 | 18 | 5.6 | 0.56 | 0.788 | 1,418 | 1,482 | 640 |
| 341 | 17 | 5.5 | 0.55 | 0.784 | 1,386 | 1,402 | 572 |
| 359 | 18 | 4.5 | 0.45 | 0.731 | 1,057 | 1,221 | 527 |
| 365 | 6 | 3.5 | 0.35 | 0.645 | 725 | 891 | 128 |
| Total | 365 | | | | | (1,986) | 18,385 |

CHAPTER 9 REHABILITATION PLAN

Since the present facilities-rehabilitating and output increase plans are not based on scrap and build methods, the power-generating capacity will be recovered or improved by making maximum use of existing facilities. The rehabilitation plan will be formulated according to standards established by ISA (Interconexion Electrica SA) in June, 1987.

9.1 Formulation of Rehabilitation Plans

As stated in 4.3, channel structures, except for the desilting basin, penstock and powerhouse building, need to be reconstructed or newly constructed. The generating equipment and transformer require new procurement or replacement with new equipment. To compare the maximum available discharge, the following two rehabilitation plans are shown in Table 9.1.

$$Q = 6.5 \text{ m}^3/\text{s}$$

$$Q = 10.00 \text{ m}^3/\text{s}$$

For each rehabilitation plan the total costs, including construction costs per kW output and generating costs are calculated and compared. The optimum rehabilitation plan is then chosen.

Table 9.1 Comparison of Alternative Rehabilitation Plans

| Item | Alternative | |
|--------------------------------------|---|---|
| | Rehabilitation of the existing facilities | Increase of power output |
| | REH-1 | ALT-1 |
| Discharge, Q (m ³ /s) | 6.5 | 10.0 |
| Max. output, P (kW) | 1,700 | 2,600 |
| Facility utilization factor (%) | 96.5 | 78 |
| Rehabilitation and improvement plan: | | |
| Diversion weir | Maintain the structure of longitudinal dike. | Will be reconstructed into diversion weir and sand flush gate will be built. |
| Intake | Maintain as existing. | Design will be changed to accommodate diversion weir. |
| Desilting basin | A new, suitable-sized one will be constructed. | |
| Conduction channel | Maintain as existing. | Will be expanded and reconstructed. |
| Head tank | Will be expanded to increase storage capacity. | |
| Penstocks | Maintain as existing. | New construction. |
| Generating equipment | Will be installed new 2 units. | |
| Powerhouse building | New foundations for generating equipment will be built in existing building. | |

9.2 Estimated Rehabilitation Construction Costs

The estimated construction costs can be calculated from the estimated costs for generating equipment and civil construction. This can then be divided into the foreign

currency and local currency portions which are calculated at current exchange rates (September 1989), based on the U.S. dollar.

9.2.1 Estimated Generating Equipment Costs

According to the ISA valuation standard, generating equipment CIF costs are calculated based on the FOB from Japan. The generating equipment specifications and FOB costs are shown in Table 9.2.

The CIF/FOB ratio for the CIF costs is 1.12, as shown in Table 9.3.

Table 9.2 Generating Equipment Specifications and FOB Costs

| Item | Alternative | |
|--------------------------------------|-------------|---------|
| | REH-1 | ALT-1 |
| 1. Specifications | | |
| Design discharge (m ³ /s) | 3.25 | 5.0 |
| Net head (m) | 32.8 | 32.8 |
| Theoretical output (kW) | 1,045 | 1,607 |
| Turbine type | HF* | HF* |
| Turbine output (kW) | 920 | 1,400 |
| Generator power factor | 0.9 | 0.9 |
| Generator output (kVA) | 1,000 | 1,500 |
| Main transformer capacity (kVA) | 2,000 | 3,000 |
| 2. FOB costs (US\$1,000) | | |
| Generating equipment | | |
| (1) Turbine etc. | 421.45 | 437.15 |
| (2) Generator etc. | 227.1 | 242.85 |
| (3) = (1)+(2) Sub-total: | 648.55 | 680 |
| (4) Number of units | 2 | 2 |
| (5) = (3)x(4) Subtotal: | 1,297.1 | 1,360 |
| (6) Generator switchgear etc. | 97.9 | 97.9 |
| (7) Main transformer, switchgear | 67.1 | 111.4 |
| (8) = (5)+(6)+(7) Total: | 1,462.1 | 1,569.3 |

* HF = horizontal Francis

Table 9.3 Implementation Cost of Generating Equipment

(units: US\$ 10³)

| Item | | Alternative | | | |
|------------------------------------|--------------|-------------|-------|---------|-------|
| | | RBH-1 | | ALT-1 | |
| | | A | B | A | B |
| 1) FOB cost | | 1,462.1 | - | 1,569.3 | - |
| 2) Transportation costs, insurance | | | | | |
| | 1) x 0.12 | 175.5 | - | 188.3 | - |
| 3) Tax | 1) x 0.223 | - | 326.0 | - | 350.0 |
| 4) Value-added tax | 1) x 0.134 | - | 196.0 | - | 210.3 |
| 5) Others | 1) x 0.22 | - | 321.7 | - | 345.2 |
| 6) Subtotal | | 1,637.6 | 843.7 | 1,757.6 | 905.5 |
| 7) Contingency | 1) x 0.17 | 248.6 | - | 233.8 | - |
| 8) Eng. fees | 1) x 0.149 | 217.9 | - | 233.8 | - |
| 9) Subtotal | 6) + 7) + 8) | 2,104.1 | 843.7 | 2,258.2 | 905.5 |
| 10) Total | | 2,947.8 | | 3,163.7 | |

Note: A = foreign currency
B = local currency

9.2.2 Estimation of Civil Construction Cost

The work volume for the rehabilitation or improvement of the main structures is multiplied by the unit costs (as shown in Table 5.2) as decided by ESSA. The civil construction cost estimates are in the local currency base.

The total civil construction costs for each rehabilitation plan are calculated and compared as shown in Table 9.4.

Table 9.4 Estimation of Civil Construction Cost

(unit: 10⁶ pesos)

| Item | Alternative | |
|--|-------------|-------|
| | REH-1 | ALT-1 |
| Diversion weir and intake construction | 20.6 | 76.4 |
| Desilting basin construction | 17.6 | 20.3 |
| Conduction channel construction | 0 | 48.8 |
| Head tank construction | 36.5 | 42.8 |
| Penstock construction | 6.4 | 63.4 |
| Foundation of equipment construction | 5.1 | 10.8 |
| Powerhouse building construction | - | - |
| Temporary facilities construction | 5.6 | 5.6 |
| Other construction | 3.9 | 3.9 |
| ① Subtotal | 95.7 | 272.0 |
| ② Contingency (① x 0.15) | 14.4 | 40.8 |
| ③ Engineering fees ((① + ②) x 0.10) | 11.0 | 31.3 |
| ④ Total (① + ② + ③) | 121.1 | 344.1 |
| ⑤ Output loss | 17.7 | 24.6 |
| Grand total ④ + ⑤ | 138.8 | 368.7 |

9.3 Comparison of Economic Indices

To compare the economic indices of the construction cost per kW and the generating cost per kW, the basic conditions for all the alternative plans are as follows.

- (1) Exchange rate based on September 1989, is as follows.

US\$ 1 = ¥140

US\$ 1 = 369.4 pesos

1 peso = ¥0.379

- (2) The expected life of new generating equipment, as well as repaired and reconstructed structures is 25 years.
- (3) The interest rate is divided into the foreign currency and local currency portions under the following conditions.
 - The foreign currency portion is based on an annual interest rate of 10% (unredeemable for 4 years), with repayment of the principal in equal annual amounts over 25 years.
 - The local currency portion is based on an annual interest rate of 21% (unredeemable for 1 year), with repayment of the principal in equal annual amounts over 8 years.
- (4) The operation, maintenance and management costs of hydroelectric power plants per year is US\$4 per installed-capacity (kW).

9.3.1 Comparison of Construction Cost per kW

A comparison of the construction cost per kW is shown in Table 9.5. The ALT-1 plan calls for US\$2,900 /kW per increase in power output, which is the lowest cost.

Table 9.5 Comparison of Construction Costs per kW

| Item | Alternative | |
|---------------------------------------|-------------|-------|
| | REH-1 | ALT-1 |
| Existing equipment output (kW) | | |
| Rated output P_o | 1,560 | 1,560 |
| Available output P_e | 1,200 | 1,200 |
| Post-rehabilitation output P_1 (kW) | 1,700 | 2,600 |
| Recovered/increased output | | |
| $\Delta P = P_1 - P_e$ (kW) | 500 | 1,400 |
| Rehabilitation work cost (US\$1,000) | | |
| Foreign currency portion C_f | 2,100 | 2,250 |
| Local currency portion C | 1,250 | 1,900 |
| Total $C = C_f + C$ | 3,350 | 4,150 |
| Construction cost per kW (US\$/kW) | | |
| C/P_1 | 1,950 | 1,600 |
| $C/\Delta P$ | 6,650 | 2,900 |

9.3.2 Comparison of Generating Cost per kWh

The generating cost per kWh is calculated from the following equation:

$$\text{Generating cost} = \frac{\text{Total cost at generating terminal}}{\text{Supplied output per year}}$$

where

$$\begin{aligned} \text{the supplied output per year} &= \text{annual potential generated energy (E) x} \\ &\quad \text{utilization factor} \\ &= 0.95 E \end{aligned}$$

The annual total cost at generating terminal is shown in Figure 9.1. Since the estimated service life of the hydroelectric power plant is 25 years, the operation, maintenance and management costs (AOM per year = US\$4 per kW) plus interest payments for the construction are totaled and divided by 25 years.




Fig-9.1 Cost and Benefit of Rehabilitation Plan for Hydroelectric Power Plant

The results of calculation of generating costs per kWh are shown in Table 9.6.

Table 9.6 Comparison of Generating Cost per kWh







| Item | | Alternative | |
|--|------------------------------|-------------|---------|
| | | REH-1 | ALT-1 |
| Existing equipment capacity: | | | |
| Power output | Po (kW) | 1,560 | 1,560 |
| Energy | Ec (Gwh) | 6.29 | 6.29 |
| Rehabilitation plan: | | | |
| Power output | P ₁ (kW) | 1,700 | 2,600 |
| Generated energy | E ₁ (Gwh) | 14.7 | 18.4 |
| Recovered/increased power | | | |
| Output | $\Delta P = P_1 - P_e$ (kW) | 500 | 1,400 |
| Energy | $\Delta E = E_1 - E_e$ (Gwh) | 8.4 | 12.1 |
| Total of expenses at generating terminal: (US\$1,000) | | | |
| Construction work cost | | | |
| Foreign currency portion Cf ₁ | | 2,100 | 2,250 |
| Local currency portion Cl ₁ | | 1,250 | 1,900 |
| Construction cost total C ₁ = Cf ₁ + Cl ₁ | | 3,350 | 4,150 |
| Interest payment C ₂ | | | |
| Foreign currency portion Cf ₂ | | 3,381 | 3,622.5 |
| Local currency portion Cl ₂ | | 1,270 | 1,930.4 |
| Total C ₂ = Cf ₂ + Cl ₂ | | 4,651 | 5,552.9 |
| AOM C ₃ = US\$4 x P ₁ x 25 years | | 170 | 260 |
| Total $\Sigma C_i = C_1 + C_2 + C_3$ | | 8,171 | 9,962.9 |
| Average annual cost C = $\Sigma C_i / 25$ | | 326.8 | 398.5 |
| Generating cost per annually supplied energy (Mills/kWh) | | | |
| Per E ₁ | C (E ₁ x 0.95) | 23 | 23 |
| Per ΔE | C (ΔE x 0.95) | 40 | 35 |

9.3.3 Overall Evaluation

ALT-1 plan is thus selected as the optimum plan taking the construction costs per kW and generating costs per kWh for each alternative plan into account in the cost-benefit analysis.

Drawings

| Title | Drawing No. |
|--------------------------------|-------------|
| General Plan of Diversion Weir | ZA-C-01 |
| Head Tank & Powerhouse | ZA-C-02 |
| Duration Curve | ZA-H-01 |
| Geological Plan | ZA-G-01 |
| One Line Diagram (ALT-1) | ZA-E-01 |




| |
|---|
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) |
| INSTITUTO COLOMBIANO DE ENERGIA ELECTRICA (ICEL) |
| FEASIBILITY STUDY ON SMALL-SCALE POWER PLANTS REHABILITATION PROJECT IN THE REPUBLIC OF COLOMBIA |



GENERAL PLAN DIVERSION WEIR

| | | | |
|-------------|---------------------|---------|--|
| DRAWING NO. | | ZA-C-01 | |
| SCALE | 1/100, 1/200, 1/300 | DATE | |

POWER HOUSE (S-1300)






| | | |
|---|--------------|---------|
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) | | |
| INSTITUTO COLOMBIANO DE ENERGIA ELECTRICA (ICEL) | | |
| FEASIBILITY STUDY ON SMALL-SCALE POWER PLANTS REHABILITATION PROJECT IN THE REPUBLIC OF COLOMBIA | | |
| HEAD TANK & POWER HOUSE | | |
| DRAWING NO. | | ZA-C-02 |
| SCALE | 1/200, 1/300 | DATE |





Data of Hydrological Gauging Station

| | |
|-----------------------------------|--------------|
| No. of Station | --- |
| Name of Station | Zaragoza |
| River | Surata |
| Management | CAMB S.A |
| Installation Year - Month | --- |
| Coordinates (Deg. - Min.) | --- |
| Latitude | --- |
| Longitude | --- |
| Above Sea Level s.n.m. (m) | --- |
| Long River (km) | --- |
| Catchment Area (km ²) | --- |
| Water Shed (m) | 700 |
| Observation Period | 1982 -- 1988 |



| | | | |
|--|---------------|------|-----|
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) | | | |
| INSTITUTO COLOMBIANO DE ENERGIA ELECTRICA (ICEL) | | | |
| FEASIBILITY STUDY ON SMALL-SCALE POWER PLANTS | | | |
| REHABILITATION PROJECT IN THE REPUBLIC OF COLOMBIA | | | |
| DURATION CURVES | | | |
| DRAWING NO. | Z A - H - 0 1 | | |
| SCALE | --- | DATE | --- |





| | | | |
|---|-----|---------|--|
| JAPAN INTERNATIONAL COOPERATION AGENCY (JICA) | | | |
| INSTITUTO COLOMBIANO DE ENERGIA ELECTRICA (ICEL) | | | |
| FEASIBILITY STUDY ON SMALL-SCALE POWER PLANTS REHABILITATION PROJECT IN THE REPUBLIC OF COLOMBIA | | | |
| ONE LINE DIAGRAM (ALT-1) | | | |
| DRAWING NO. | | ZA-E-01 | |
| SCALE | --- | DATE | |

2765

Attached Data

1. Facility Register for the Existing Power Plant
2. Survey Record

Facility Register for the Existing Power Plant

| | |
|------------------------|--------------------|
| Power Plant | Zaragoza |
| Electric Power Company | ESSA |
| Location | Zaragoza/Santander |
| River | Surata |
| Generating Method | Run-of-River |
| Year Installed | 1931/1935/1948 |
| Years in Service | 1931 |
| Installed Capacity | 1,560 kW |
| Available Capacity | 800 kW |

| Civil | | |
|-------|------------------------------------|---------------------|
| | Item | Data |
| 1. | Dam | |
| | 1) Type | concrete |
| | 2) Height (m) | 3.0 |
| | 3) Crest length (m) | 65.0 |
| | 4) Height of overflowing crest (m) | 737.8 |
| | 5) Width of overflowing crest (m) | 65.0 |
| | 6) Depth of overflowing crest (m) | no data available |
| 2. | Intake Gate | |
| | 1) Type | " |
| | 2) Number of gates | " |
| | 3) Dimensions (W x H)(m) | " |
| 3. | Intake | |
| | 1) Intake sill height (m) | no data available |
| | 2) Number of intake | 1 |
| | 3) Dimensions (W x H)(m) | 4.0 x 2.0 |
| 4. | Desilting Basin | |
| | 1) Dimensions (W x L x H)(m) | 13.0 x 60.0 x 2.9 |
| 5. | Sand Trap Gate | |
| | 1) Type | wood metal sluice |
| | 2) Number of gates | 2 1 |
| | 3) Dimensions (W x H)(m) | 2.0 x 3.0 2.0 x 2.0 |
| 6. | Headrace | |
| | 1) Type | conc. open channel |
| | 2) Dimensions (W x H)(m) | 3.0 x 1.5 |
| | 3) Length (m) | 1,685 |

| Civil | |
|------------------------------|-------------------------|
| Item | Data |
| 7. Reservoir Tank | |
| 1) Dimensions (W x L x H)(m) | 2.6 ~ 11.0 x 35.5 x 2.1 |
| 8. Forebay | |
| 1) Dimensions (W x H)(m) | no data available |
| 9. Penstock | |
| 1) Number of lines | 1 |
| 2) Penstock diameter (d)(m) | 1.52 |
| 3) Penstock length (L)(m) | 107.3 |
| 10. Tailrace | |
| 1) Dimensions (W x H)(m) | no data available |

| Equipment | | | |
|-------------------------------|---|----------|-------------|
| Item | Data | | |
| | #1 | #2 | #3 |
| 1. Water Turbine | | | |
| 1) Manufacturer's name | Aktiebolaget Finshvttans | Brunk | "Suecia" |
| 2) Year manufactured | 1950 | 1932 | 1937 |
| 3) Type | Francis | Francis | Francis |
| 4) Output (kW) | 520 | 520 | 520 |
| 5) Revolution (rpm) | 720 | 720 | 720 |
| 6) Ancillary equipment | | | |
| a) Type of governor | Kt-Aktiebolaget | | Finshvttans |
| b) Inlet valve | | | |
| - Type | Gate | Gate | Gate |
| - Diameter (mm) | 700 | 700 | 700 |
| 2. Generator and Exciter | | | |
| 1) Manufacturer's name | ASEA | ASEA | ASEA |
| 2) Year manufactured | 1950 | 1932 | 1937 |
| 3) Type | Synchro. | Synchro. | Synchro. |
| 4) Capacity (kVA) | 650 | 650 | 650 |
| 5) Power factor (%) | 80 | 80 | 80 |
| 6) Voltage (V) | 2,300 | 2,300 | 2,300 |
| 7) Frequency (Hz) | 60 | 60 | 60 |
| 8) Revolution (rpm) | 720 | 720 | 720 |
| 9) Method of neutral earthing | One resistance (266 ohm) for three generators | | |
| 10) Type of exciter | no data available | | |

| Equipment | | | | |
|----------------------------|---------------------|---------------------|---------------------|---------------------|
| Item | Data | | | |
| 3. Transformer | | | | |
| 1) Manufacturer's name | ASEA | ASEA | ASEA | ASEA |
| 2) Year manufactured | 1930 | 1930 | 1930 | 1940 |
| 3) Type | TKL | TKL | TKL | TKL |
| 4) Capacity (kVA) | 500 | 500 | 500 | 500 |
| 5) Primary voltage (kV) | 2.3 | 2.3 | 2.3 | 2.3 |
| 6) Secondary voltage (kV) | 11.4 | 11.4 | 11.4 | 11.4 |
| 7) Number of unit | 1 | 1 | 1 | 1 |
| 8) Vector-group symbol | Y/Y OA ₂ | Y/Y OA ₂ | Y/Y OA ₂ | Y/Y OA ₂ |
| 9) Impedance (%) | 5.52 | 5.44 | 5.44 | 5.30 |
| 10) Purpose for use | Step-up | Set-up | Set-up | Set-up |
| 4. Circuit Breaker | | | | |
| 1) Manufacturer's name | GE | | ASEA | |
| 2) Year manufactured | 1925 | | 1928 | |
| 3) Type | FK-192-4.16-25 | | HL 813/150 | |
| 4) Voltage (kV) | 4.16 | | 13.2 | |
| 5) Rated current (A) | 100 | | 100, 150 | |
| 6) Rupturing capacity (kA) | 0.6 | | 0.4 at 13k | |
| 7) Purpose for use | Generator | | Transformer and 11 | |
| 5. Transmission Line | | | | |
| 1) Destination | | | | |
| 2) Length (m) | 8,000 | | | |
| 3) Voltage (kV) | 11.4 | | | |
| 4) Number of circuit | 2 | | | |
| 5) Number of pylons | no data available | | | |
| 6) Size of conductors | 1/0 | | | |
| 7) Materials of conductors | Copper | | | |

| Equipment | |
|-------------------------|--------------------------|
| Item | Data |
| 6. Battery | |
| 1) Manufacturer's name | N/A |
| 2) Year manufactured | |
| 3) Capacity (AH/HR) | |
| 4) DC voltage (V) | |
| 5) Type | |
| 7. Battery Charger | N/A |
| 1) Manufacturer's name | |
| 2) Year manufactured | |
| 3) Capacity | |
| 4) Incoming voltage (V) | |
| 8. Overhead Crane | <i>no data available</i> |
| 1) Weight (ton) | |
| 2) Method of operation | |
| 3) Span (m) | |

Survey Records

Zaragoza Hydroelectric Power Plant

I. RECORDS BY VISUAL INSPECTION AND HEARING SURVEY

Unit No.: /

Type of Turbine: Francis

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|----------------------------|
| Francis Turbine | Casing | 1) No 2) Yes 3) No |
| | Runner | 1) No 2) Yes |
| | Shaft | 1) No |
| | Bearing | 1) No 2) No |
| | Governor control | 1) Yes 2) Yes 3) Yes |
| | | 4) No |
| | | 5) Yes |
| | | |
| | | |
| | | |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|--------------------------------|
| Francis Turbine | Oil pressure equipment | 1) No 2) Yes |
| | Inlet valve | 1) Manual 2) Good 3) Yes |
| | Guide vanes | 1) Yes 2) No 3) No |
| | Sealing device | 1) Yes 2) Yes |

Unit No. 1

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|---|
| Generator | Rotor | 1) Discoloration of winding surface due to heat 2) Existence of erosion for core 3) Fitness of between rotor and shaft 1) No 2) No 3) No |
| | Stator winding | 1) Frequency of burning trouble or repair 2) Reduction of insulation resistance 3) Rust and erosion of core 1) No 2) No 3) No |
| | Bearing | 1) Occurrence of deformation on metal surface 2) Lack of oil lubrication 3) Occurrence of temperature rise 1) No 2) No 3) No |
| | Exciter | 1) Exchange frequency of brushes worn out 2) Sufficient stock of spare brush 1) Yes 2) Yes |
| | Voltage regulator | 1) Operation method of voltage regulator 2) Response of voltage detection for load variation 1) Automatic 2) Constant load |

Unit No.: 2Type of Turbine: Francis

| Francis Turbine | Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------|-----------------------|---|---------|
| | Casing | 1) Existence of corrosion | 1) No |
| | | 2) Wear in thickness | 2) Yes |
| | | 3) Presence of vibration | 3) No |
| | Runner | 1) Existence of corrosion | 1) No |
| | | 2) Occurrence of porosity by sand pitting | 2) Yes |
| | Shaft | 1) Shaking of shaft axis | 1) No |
| | Bearing | 1) Oil-shortage on bearing surface | 1) No |
| | | 2) Lack of oil viscosity | 2) No |
| | Governor control | 1) Control by belt-driven type | 1) Yes |
| | | 2) Speed detection device | 2) Yes |
| | | 3) Speed regulation system | 3) Yes |
| | | 4) Installation of load limiter | 4) No |
| | | 5) Accuracy of governor speed regulation | 5) Yes |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|---|
| Francis Turbine | Oil pressure equipment | 1) Existence of oil leakage 2) Application of oil pressure pumping system 1) <i>No</i> 2) <i>Yes</i> |
| | Inlet valve | 1) Operation method 2) Locking condition 3) Smoothness of pressurized oil operation 1) <i>Manual</i> 2) <i>Good</i> 3) <i>Yes</i> |
| | Guide vanes | 1) Smoothness of control 2) Presence of water leakage from casing when guide vanes are closed 3) Break frequency of shear pins 1) <i>Yes</i> 2) <i>No</i> 3) <i>No</i> |
| | Sealing device | 1) Sufficiency of water sealing for shaft 2) Sufficiency of packing for shaft seal 1) <i>Yes</i> 2) <i>Yes</i> |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|----------------------------------|
| Generator | Rotor | 1) No 2) No 3) No |
| | Stator winding | 1) No 2) No 3) No |
| | Bearing | 1) No 2) No 3) No |
| | Exciter | 1) Yes 2) Yes |
| | Voltage regulator | 1) Automatic 2) Constant Load |

Unit No.: 3

Type of Turbine: Francis

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|--|----------------------------|
| Francis Turbine | Casing | 1) No 2) Yes 3) No |
| | Runner | 1) No 2) Yes |
| | Shaft | 1) No |
| | Bearing | 1) No 2) No |
| | Governor control | 1) Yes 2) Yes 3) Yes |
| | | 4) No |
| | | 5) Yes |
| | 1) Existence of corrosion 2) Wear in thickness | |
| | 3) Presence of vibration | |
| | 1) Existence of corrosion 2) Occurrence of porosity by sand pitting | |
| | 1) Shaking of shaft axis 1) Oil shortage on bearing surface 2) Lack of oil viscosity | |
| | 1) Control by belt-driven type 2) Speed detection device 3) Speed regulation system 4) Installation of load limiter 5) Accuracy of governor speed regulation | |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|---|
| Francis Turbine | Oil pressure equipment | 1) <i>No</i> 2) <i>Yes</i> |
| | Inlet valve | 1) <i>Manual</i> 2) <i>Good</i> 3) <i>Yes</i> |
| | Guide vanes | 1) <i>Yes</i> 2) <i>No</i> 3) <i>No</i> |
| | Sealing device | 1) <i>Yes</i> 2) <i>Yes</i> |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|---|
| Generator | Rotor | 1) Discoloration of winding surface due to heat 2) Existence of erosion for core 3) Fitness of between rotor and shaft 1) No 2) No 3) No |
| | Stator winding | 1) Frequency of burning trouble or repair 2) Reduction of insulation resistance 3) Rust and erosion of core 1) No 2) No 3) No |
| | Bearing | 1) Occurrence of deformation on metal surface 2) Lack of oil lubrication 3) Occurrence of temperature rise 1) No 2) No 3) No |
| | Exciter | 1) Exchange frequency of brushes worn out 2) Sufficient stock of spare brush 1) Yes 2) Yes |
| | Voltage regulator | 1) Operation method of voltage regulator 2) Response of voltage detection for load variation 1) Automatic 2) Constant load |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|--|
| Control Board | Metering equipment | 1) Sufficiency of accuracy for instruments 2) Lack of necessary instruments 3) Items constantly recorded |
| | Protection equipment | 1) Good 2) No 3) No |
| | Remote control equipment | 1) Lack of relays to be installed 2) Operation method in case of accident in transmission lines 1) No 2) Manual |
| | | 1) Control method for turbine and generator operation 2) Control method for voltage and speed control 3) Operation method of synchronized switching 1) Manual 2) Automatic 3) Manual by synchroscope and lamp |
| | Power system | 1) Power supply voltage (kV) after rehabilitation work 1) 13.8 kV |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|---|
| Indoor Switchgear | <p>Insulation level</p> <p>1) Sufficiency of insulation level</p> <p>2) Unification of insulation level</p> <p>3) Reduction of insulation resistance</p> <p>Accessibility and Safety</p> <p>1) Accessibility to high voltage devices</p> <p>2) Sufficiency of protection for high voltage cable terminals</p> <p>3) Method and reliability of operation for synchronizing circuit breaker</p> | <p>1) <i>Yes</i></p> <p>2) <i>Yes</i></p> <p>3) <i>No</i></p> <p>1) <i>Yes</i></p> <p>2) <i>Yes</i></p> <p>3) <i>Good</i></p> |

| Generating Facilities | Check item by visual inspection and hearing | Results |
|-----------------------|---|---------------------|
| Outdoor Equipment | Transformer | 1) No |
| | Circuit breaker | 1) Yes 2) Yes |
| | Line switch | 1) Manual 2) Yes |
| | Insulator | 1) No |
| | Structural steel | 1) No 2) No |
| | Line protection | 1) Yes |

II. ACTUAL GENERATED ENERGY AND OPERATION TIME

Unit No.: /

Installed Capacity of Generator: _____ KVA

Type of Turbine: _____

| YEAR | | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | ANNUAL TOTAL | REMARKS |
|------|--------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|-----------------|---------|
| 1983 | MWH | | | | | | | | | | | | | | |
| | OPE. TIME | | | | | | | | | | | | | | |
| 1984 | MWH | 165.8 | 107.4 | 76.5 | 76.4 | 76.5 | 221.5 | 131.9 | 293.4 | 261.8 | 277.9 | 220.1 | 272.2 | 2,181.4 | |
| | OPE. TIME | 484:12 | 309:27 | 117:06 | 174:12 | 117:06 | 612:24 | 366:00 | 674:24 | 663:00 | 618:06 | 552:42 | 696:35 | 5385:14 | |
| 1985 | MWH | 286.0 | 23.9 | 0 | 0 | 37.7 | 249.0 | 302.8 | 123.7 | 167.2 | 83.3 | 277.7 | 40.9 | 1,592.2 | |
| | OPE. TIME | 738:15 | 62:30 | 0 | 0 | 141:12 | 628:24 | 683 | 342:30 | 430:36 | 208:36 | 652:24 | 95:04 | 3,982:31 | |
| 1986 | MWH | 0 | 21.9 | 120.8 | 202.9 | 107.5 | 164.1 | 32.2 | 30.5 | 271.4 | 249.8 | 299.3 | 330.6 | 1,831 | |
| | OPE. TIME | 0 | 62 | 495:18 | 486:24 | 356:18 | 490:48 | 115 | 78:54 | 674:06 | 557:36 | 638:54 | 729:18 | 4,684:36 | |
| 1987 | MWH | 326.5 | 227 | 168.8 | 254.1 | 168.8 | 0 | 0 | 0 | 126.1 | 97.9 | 280.4 | 297.6 | 1,947.2 | |
| | OPE. TIME | 736 | 618:12 | 375:10 | 588:54 | 375:10 | 0 | 0 | 0 | 338:35 | 225:42 | 648:42 | 696:6 | 4,602:31 | |
| 1988 | MWH | 299.9 | 76.5 | 47.9 | 269.3 | 300.4 | 285.8 | 294.4 | 281.8 | 191.2 | 299.2 | 154.57 | 263.157 | 2,764.127 | |
| | OPE. TIME | 706:48 | 178:18 | 132:24 | 669:18 | 686:54 | 627:14 | 720:51 | 662:09 | 445:20 | 688:40 | 400 | 729:18 | 6,647:14 | |

Unit No.: 2

Installed Capacity of Generator: _____ KVA

Type of Turbine: _____

| YEAR | | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | ANNUAL TOTAL | REMARKS |
|------|--------------|---------|---------|---------|---------|---------|---------|---------|---------|--------|---------|---------|---------|-----------------|---------|
| 1983 | MWH | | | | | | | | | | | | | | |
| | OPE. TIME | | | | | | | | | | | | | | |
| 1984 | MWH | 122.05 | 227.372 | 144.628 | 166.3 | 144.628 | 289.256 | 282.586 | 301.127 | 271.7 | 290.928 | 249.464 | 310.908 | 2,800.967 | |
| | OPE. TIME | 239:12 | 526:18 | 321:24 | 377:18 | 321:24 | 693:12 | 689:00 | 712:30 | 663:00 | 673:30 | 578:12 | 700:20 | 6,495:20 | |
| 1985 | MWH | 289.925 | 293.942 | 311.986 | 318.838 | 176.191 | 283.237 | 236.671 | 320.3 | 303.47 | 238.3 | 277.635 | 262.1 | 3,312.595 | |
| | OPE. TIME | 703:30 | 643 | 712:12 | 687:24 | 389:36 | 643:24 | 520:06 | 705:24 | 675:06 | 513:30 | 622:06 | 614 | 7,429:18 | |
| 1986 | MWH | 319.8 | 296.195 | 307.146 | 247.456 | 177.817 | 117.374 | 283.655 | 334.316 | 262.76 | 191.11 | 297.61 | 294.78 | 3,080.019 | |
| | OPE. TIME | 698 | 661:30 | 706:36 | 559:54 | 457:06 | 348:30 | 671:48 | 706:54 | 614:48 | 413:48 | 639:30 | 567:24 | 7,045:48 | |
| 1987 | MWH | 333.313 | 253.726 | 224.55 | 147.5 | 224.5 | 316.4 | 257.237 | 334.985 | 261.25 | 227.476 | 269.108 | 270.697 | 3,120.742 | |
| | OPE. TIME | 735:42 | 631:42 | 501:30 | 362:36 | 501:30 | 662:12 | 616:15 | 735:48 | 688:54 | 527:48 | 648:12 | 655:24 | 7,267:33 | |
| 1988 | MWH | 289.841 | 74.822 | 40.044 | 264.343 | 286.242 | 256.903 | 255.732 | 121.220 | 60.860 | 0 | 0 | 0 | 1,650.007 | |
| | OPE. TIME | 708:18 | 177:42 | 129:42 | 620:12 | 677:24 | 590:41 | 625:47 | 304:40 | 86:57 | 0 | 0 | 0 | 3,921:23 | |

Unit No.: 3

Installed Capacity of Generator: _____ KVA

Type of Turbine: _____

| YEAR | | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | ANNUAL TOTAL | REMARKS |
|------|--------------|---------|---------|---------|--------|---------|---------|---------|---------|---------|---------|--------|---------|-----------------|---------|
| 1983 | MWH | | | | | | | | | | | | | | |
| | OPE. TIME | | | | | | | | | | | | | | |
| 1984 | MWH | 162.184 | 44.308 | 65.178 | 90.200 | 65.178 | 144.628 | 183.92 | 127.072 | 222.376 | 275.88 | 225.72 | 293.603 | 1,900.247 | |
| | OPE. TIME | 441:12 | 103:12 | 155:00 | 187:30 | 155:00 | 392:24 | 513:00 | 346:18 | 579:00 | 667:06 | 552:12 | 708:15 | 4,800:09 | |
| 1985 | MWH | 277.97 | 271.967 | 288.153 | 321.84 | 245.127 | 253.726 | 162.769 | 208.6 | 185.76 | 231.0 | 172.55 | 233.2 | 2,852.662 | |
| | OPE. TIME | 716:30 | 663 | 714:18 | 679:42 | 548:30 | 598:36 | 345 | 603:24 | 402:54 | 475:48 | 428 | 563:18 | 6,739 | |
| 1986 | MWH | 324.3 | 283.738 | 198.634 | 39.543 | 54.424 | 244.697 | 234.247 | 320.522 | 151.82 | 120.8 | 0 | 0 | 1,972.725 | |
| | OPE. TIME | 687:54 | 611:36 | 464:06 | 85:48 | 150:12 | 621:54 | 612:00 | 662:24 | 368:36 | 273 | 0 | 0 | 4,537:30 | |
| 1987 | MWH | 0 | | | | | | | | | | | → 0 | 0 | |
| | OPE. TIME | 0 | | | | | | | | | | | → 0 | 0 | |
| 1988 | MWH | 0 | | | | | → 0 | 9.8648 | 0 | 0 | 168.788 | 24.996 | 252.629 | 456.278 | |
| | OPE. TIME | 0 | | | | | → 0 | 39:19 | 0 | 0 | 378:24 | 60:55 | 678 | 1,156:38 | |

III. REPAIR RECORDS

| No. | Study Item | Results |
|-----|--|---|
| | <p>The past records concerning the following items shall be obtained to evaluate reliability of generating facilities.</p> | |
| 1) | Repaired locations and method for repairing | 1) Intake |
| 2) | Causes for damage/defect | 2) Damage in the dam by increasing of the river |
| 3) | Duration of repairing and power supply stoppage | 3) 2 years |
| 4) | Repaired by; | 4) Staff of the Enterprise (civil work, electric maintenance and staff of the power plant) |
| a) | staff in Power Plant | |
| b) | manufacturer | |
| c) | other | |
| 5) | Repair cost | 5) \$ 20,000,000 |
| 6) | Operation life after the completion of repairing work | 6) 6 years |

215

The economic losses by the damage in intake were in following form :

| | |
|--|---------------|
| 1) Loss of generation 1200KW/h | \$150.000.000 |
| 2) Purchase of this energy to the interconnected system | \$150.000.000 |
| 3) Repair cost (dam) | \$ 10.000.000 |
| 4) Repair of various canal conductions | \$ 1.000.000 |
| 5) General maintenance of turbines, generators and electric equipments | \$ 4.000.000 |
| 6) Other expenses | \$ 5.000.000 |

| | |
|-----------|---------------------|
| T o t a l | \$320.000.000 |
|-----------|---------------------|

IV. SITUATION OF STOCK SPARE PARTS

| No. | Study Item | Results |
|-----|---|---|
| | <p>Data on the situation of stock spare parts shall be obtained to evaluate maintainability of generating facilities.</p> | <p>The power plant hasn't stock spare parts for maintenance of generating facilities.</p> <p>The maintenances are realized by the staff of same Enterprise, reconstructing their wasted components.</p> |

V. ESSA'S INTENTION FOR REHABILITATION

| No. | Study Item | Results | | |
|-----|--|---------|------------------|------------------------|
| | Mark with in pertinent columns. | | | |
| | - Inlet valve | ✓ | Leaving as it is | Good |
| | - Turbine, governor, auxiliary equipment | ✓ | Repair work | Bigger efficiency |
| | - Generator, exciter | ✓ | Replacement | Bigger efficiency |
| | - Control panel | ✓ | | Modernization |
| | - Switchgear | ✓ | | New system fitting |
| | - Transformer | ✓ | | Expansion of load |
| | - Substation equipment (Circuit breaker, Isolator, etc.) | ✓ | | Expansion |
| | - Transmission tower, conductor and insulator | ✓ | | Increasing of capacity |
| | - Power House | ✓ | | Adaptations |

