

REPUBLIC OF PERU
SERVICIO DE AGUA POTABLE Y ALCANTARILLADO DE LIMA
(SEDAPAL)

THE FEASIBILITY STUDY
ON
THE IMPROVEMENT OF SEWERAGE SYSTEM
IN
SOUTHERN PART OF LIMA

FINAL REPORT

VOLUME I
SUMMARY

MARCH, 1990

JAPAN INTERNATIONAL COOPERATION AGENCY

SSS

90-067(1/3)

JICA LIBRARY



1082738141

21222

REPUBLIC OF PERU
SERVICIO DE AGUA POTABLE Y ALCANTARILLADO DE LIMA
(SEDAPAL)

THE FEASIBILITY STUDY
ON
THE IMPROVEMENT OF SEWERAGE SYSTEM
IN
SOUTHERN PART OF LIMA

FINAL REPORT

VOLUME I
SUMMARY

MARCH, 1990

JAPAN INTERNATIONAL COOPERATION AGENCY



PREFACE

In response to a request from the Government of the Republic of Peru, the Japanese Government decided to conduct a Feasibility Study on the Improvement of the Sewerage System in the Southern Part of Lima and entrusted the study to the Japan International Cooperation Agency (JICA).

JICA sent to Peru a survey team headed by Mr. Hiroshi Irie, Nippon Jogesuido Sekkei Co., Ltd., from April to June, 1989, and from October to November, 1989.

The team held discussions with concerned officials of the Government of Peru, and conducted field surveys. After the team returned to Japan, further studies were made and the present report was prepared.

I hope that this report will contribute to the promotion of the project and to the enhancement of friendly relations between our two countries.

I wish to express my sincere appreciation to the officials concerned of the Government of Peru for their close cooperation extended to the team.


March, 1990



Kensuke Yanagiya

President

Japan International Cooperation Agency



FEASIBILITY STUDY
ON
IMPROVEMENT OF SEWERAGE SYSTEM
IN
SOUTHERN PART OF LIMA

ORGANIZATION OF REPORTS

| <u>Volume No.</u> | <u>Title</u> |
|-------------------|--------------|
| I | Summary |
| II | Main Report |
| III | Appendices |

VOLUME I - SUMMARY

| | <u>PAGE</u> |
|------------------------------------------------------|-------------|
| PREFACE | |
| LOCATION MAP | |
| TABLE OF CONTENTS | i |
| LIST OF TABLES | v |
| LIST OF FIGURES | v |
| ACRONYMS AND ABBREVIATIONS | vi |
| | |
| CHAPTER S.1 INTRODUCTION | |
| S.1.1 Background of the Study | S-1 |
| S.1.2 Objectives of the Study | S-1 |
| S.1.3 Scope of the Study | S-2 |
| | |
| CHAPTER S.2 DESCRIPTION OF THE STUDY AREA | |
| S.2.1 Brief History of Metropolitan Lima | S-3 |
| S.2.2 Natural Conditions | S-3 |
| S.2.3 Economy | S-4 |
| S.2.4 Public Health Condition | S-4 |
| S.2.5 Energy Supply Condition | S-5 |
| S.2.6 Water Supply System in Metropolitan Lima | S-6 |
| S.2.7 Other Infrastructures | S-6 |

| | |
|------------------------------------------------|-----------------------------------------------------------------------|
| CHAPTER S.3 EXISTING SEWERAGE SYSTEM | |
| S.3.1 | Master Plan of Sewerage System S-7 |
| S.3.2 | Sewer Systems S-7 |
| S.3.3 | Sewage Pumping Stations S-10 |
| S.3.4 | Sewage Treatment Plants S-11 |
| | |
| CHAPTER S.4 POPULATION | |
| S.4.1 | Past Demographic Trends S-13 |
| S.4.2 | Projection of the Future Population S-13 |
| S.4.3 | Projected Population Within Surco Drainage Area.. S-15 |
| | |
| CHAPTER S.5 SEWAGE QUANTITY AND QUALITY | |
| S.5.1 | Present Sewage Quantity S-19 |
| S.5.1.1 | Flow Measurements on the Surco Outfall.. S-19 |
| S.5.1.2 | Flow Measurements on the Intake Points.. S-21 |
| S.5.2 | Future Sewage Quantity S-22 |
| S.5.2.1 | Surco Outfall S-22 |
| S.5.2.2 | Intake Points S-23 |
| S.5.3 | Present Sewage Quality S-24 |
| S.5.3.1 | Biochemical Oxygen Demand (BOD) and Suspended Solid (SS)..... S-24 |
| S.5.3.2 | Heavy Metals S-24 |
| S.5.4 | Projected Sewage Quality S-25 |
| | |
| CHAPTER S.6 ALTERNATIVES | |
| S.6.1 | Principle for Planning S-27 |
| S.6.2 | Outline of Alternatives S-30 |
| S.6.2.1 | Alternative A S-30 |
| S.6.2.2 | Alternative B S-31 |
| S.6.2.3 | Alternative C S-31 |
| S.6.2.4 | Alternative D S-31 |
| S.6.2.5 | Alternative E S-31 |
| S.6.3 | Summary of Planned Sewage Quantity S-31 |

CHAPTER S.7 PRELIMINARY ENGINEERING DESIGN OF ALTERNATIVES

S.7.1 Intake Facility S-39

S.7.2 Transmission Facility S-42

S.7.3 Grit Chamber and Pumping Facility S-45

 S.7.3.1 Grit Chambers S-45

 S.7.3.2 Pumping Facility S-46

S.7.4 Sewage Treatment Plant S-46

S.7.5 Evaluation of Alternatives S-48

 S.7.5.1 Construction Cost S-48

 S.7.5.2 Operation and Maintenance Cost S-48

 S.7.5.3 Technical Evaluation S-50

 S.7.5.4 Selection of Optimum Plans S-50

CHAPTER S.8 POLLUTION ANALYSIS FOR THE COAST OF CHILA

S.8.1 Introduction..... S-53

S.8.2 Present Sea Water Pollution Condition S-53

 S.8.2.1 Bacteria S-53

 S.8.2.2 Heavy Metals S-56

S.8.3 Computer Simulation and Results S-57

S.8.4 Conclusion S-57

CHAPTER S.9 PROJECT EVALUATION

S.9.1 Implementation Program S-61

 S.9.1.1 Implementation Plan S-61

 S.9.1.2 Capital Investment Schedule S-61

S.9.2 Organization and Managerial Aspect S-63

S.9.3 Financial Analysis S-63

 S.9.3.1 Present Financial Situation S-63

 S.9.3.2 Funding Arrangements S-63

 S.9.3.3 Alternative Financing Plan S-63

 S.9.3.4 Revenue Plan S-65

 S.9.3.5 Administrative Expenses of
 the Project..... S-66

 S.9.3.6 Cash Flow Statement S-66

S.9.4 Economic Analysis S-66

 S.9.4.1 Economic Benefits of the Project S-66

 S.9.4.2 Economic Costs of the Project S-68

 S.9.4.3 Economic Analysis S-68

S.9.5 Sensitivity Analysis S-68

PAGE

S.9.6 Justification of the Project S-70

CHAPTER S.10 CONCLUSION AND RECOMMENDATION

S.10.1 Conclusion S-71

S.10.2 Recommendation S-74

LIST OF TABLES

| <u>TABLE</u> | | <u>PAGE</u> |
|--------------|-------------------------------------------------------------------------|-------------|
| S-1 | Pertinent Data on Drainage Area..... | S-8 |
| S-2 | Pertinent Data on Sewage Pumping Station..... | S-10 |
| S-3 | Estimated Population by District..... | S-14 |
| S-4 | Projected Population (Surco Drainage Area)..... | S-16 |
| S-5 | Distribution of Population by District..... | S-17 |
| S-6 | Results of Sewage Flow Measurement at Surco Outfall..... | S-19 |
| S-7 | Domestic Sewage Quantity..... | S-21 |
| S-8 | Results of Sewage Flow Measurement..... | S-22 |
| S-9 | Domestic Sewage Quantity..... | S-22 |
| S-10 | Available Sewage Quantity at Each Intake Point..... | S-23 |
| S-11 | Present Sewage Quality..... | S-24 |
| S-12 | Present Sewage Quality in Main Sewers..... | S-24 |
| S-13 | Heavy Metals of Raw Sewage In Main Sewers..... | S-25 |
| S-14 | Summary of Planned Sewage Quantity..... | S-38 |
| S-15 | Planned Intake Amount..... | S-39 |
| S-16 | Design Flow of Sewage Treatment Plant in Each Proposed Site..... | S-47 |
| S-17 | Design Criteria of Waste Stabilization Pond..... | S-47 |
| S-18 | Design Criteria for Aerated Lagoon (Dual Power Aeration System)..... | S-48 |
| S-19 | Comparison of Construction Cost..... | S-49 |
| S-20 | Comparison of Operation and Maintenance Cost..... | S-49 |
| S-21 | Comparison of Technical Evaluation..... | S-51 |
| S-22 | Comparison of Evaluation..... | S-51 |
| S-23 | Quality of Sea Water..... | S-55 |
| S-24 | Coliform Number and Sewage Flow..... | S-56 |
| S-25 | Project Sewage Discharge Quantity..... | S-57 |
| S-26 | Summary of Project Cost..... | S-61 |
| S-27 | Disbursement Schedule of Optimum Plan..... | S-65 |
| S-28 | Income from Sewerage Charge..... | S-66 |
| S-29 | Summary of Economic Benefits..... | S-67 |

LIST OF FIGURES

| <u>FIGURE</u> | | <u>PAGE</u> |
|---------------|---------------------------------------------------------------------------------|-------------|
| S-1 | Existing Sewerage System | S-9 |
| S-2 | Location of Sewage Flowrate Measuring Points..... | S-20 |
| S-3 | Schematic Plans of Alternatives..... | S-28 |
| S-4 | Layout Plan of Alternatives..... | S-29 |
| S-5 | Alternative-A (Pumping & Gravity)..... | S-32 |
| S-6 | Alternative-B (Gravity)..... | S-33 |
| S-7 | Alternative-C (Gravity + Pumping)..... | S-34 |
| S-8 | Alternative-D (Gravity + Pumping)..... | S-36 |
| S-9 | Alternative-E (Gravity)..... | S-37 |
| S-10 | Location of Intake Facilities..... | S-40 |
| S-11 | Intake Facility..... | S-41 |
| S-12 | Alternative-E (Plan E ₁ -Layout Plan & Longitudinal Section)..... | S-43 |
| S-13 | Outline of Grit Chamber Structure..... | S-45 |
| S-14 | Location of Sampling Points..... | S-54 |
| S-15 | Simulated Contour Line of Fecal Coliform..... | S-59 |
| S-16 | Implementation Plan..... | S-62 |

ABBREVIATIONS AND ACRONYMS

UNIT

| | |
|--------------------------------------|-----------------------------------------|
| CFU: | colony formed unit |
| cu.m/s: | cubic meter per second |
| ha: | hectare |
| I/.: | Peruvian intis |
| kg/cm ² : | kilogram per square centimeter |
| kW: | kilowatt |
| kWH: | kilowatt-hour |
| l/capita/day: | liter per capita per day |
| lpcd: | liter per capita per day |
| m: | meter |
| m ² : | square meter |
| m ³ : | cubic meter |
| m ³ /m ² /day: | cubic meter per square meter per day |
| m ³ /min: | cubic meter per minute |
| m ³ /s: | cubic meter per second |
| m ³ /sec: | cubic meter per second |
| m ³ /year: | cubic meter per year |
| µg/kg: | microgram per kilogram |
| mg/kg: | miligram per kilogram |
| µg/l: | microgram per liter |
| mg/l: | miligram per liter |
| mm: | milimeter |
| MPN/100ml: | most probable number per 100 milliliter |
| m/s: | meter per second |
| µS/cm: | micro-siemens per centimeter |
| MW: | megawatt |
| %: | percentage |
| ppb: | parts per bilion |
| ppm: | parts per milion |
| sec.: | second |
| ton/m ² : | ton (metric) per square meter |
| ton/m ³ : | ton (metric) per cubic meter |
| US\$: | United States dollar |
| Yen: | Japanese yen |

ORGANIZATION

| | |
|-----------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| CEPIS: | Centro Panamericano de Ingenieria Sanitaria y Ciencias del Ambiente (Pan American Center for Sanitary Engineering and Environmental Sciences) |
| DITESA: | Direccion Tecnica de Salud Ambienta, Ministerio de Salud (Environmental Health Technical Office, Ministry of Health) |
| GOJ: | Government of Japan |
| GOP: | Government of Peru |
| IMARPE: | Instituto del Mar del Peru (Peruvian Institute of the Sea) |
| INE: | Instituto Nacional de Estadistica (National Institute of Statistics) |
| JICA: | Japan International Cooperation Agency |
| SEDAPAL: | Servicio de Agua Potable y Alcantarillado de Lima (Lima Water Supply and Sewerage Service) |
| SEDTACNA: | Servicio de Agua Potable y Alcantarillado de Tacna (Tacna Water Supply and Sewerage Service) |
| SENAPA: | Servicio Nacional de Abastecimiento de Agua Potable y Alcantarillado (National Water Supply and Sewerage Service) |
| UNI: | Universidad Nacional de Ingeneiria (National University of Engineering) |

OTHERS

| | |
|--------------------|--------------------------------------|
| AL: | Aerated Lagoon System |
| ASP: | Activated Sludge Processing System |
| BOD: | Biological Oxigen Demand |
| BOD ₅ : | Biological Oxigen Demand in 5 days |
| COD: | Chemical Oxigen Demand |
| D/S.H: | Direct Water Supply High Consumption |
| D/S.L: | Direct Water Supply Low Consumption |
| EAP: | Exrended Aeration Processing System |
| EIRR: | Economic Internal Rate of Return |
| FIRR: | Financial Internal Rate of Return |

FIRR: Financial Internal Rate of Return
GDP: Gross Domestic Product
G.F.: Gravity Flow
GL: Ground Level
GNP: Gross National Product
HWL: High Water Level
I.D.: Indirect Water Supply
IRR: Internal Rate of Return
I.S.: Inverted Siphon
LWL: Low Water Level
MUC: Mercado Unico de Cambios (Sole Market Exchange Rate)
OD: Oxidation Ditch System
SS: Suspended Solid
STP or S.T.P.: Sewage Treatment Plant
TF: Trickling Filter System
WSP: Waste Stabilization Pond System

SUMMARY

CHAPTER 1

INTRODUCTION

SUMMARY

CHAPTER S.1 INTRODUCTION

S.1.1 Background of the Study

The existing sewerage system of Metropolitan Lima consists principally of 6,000 kilometers sanitary sewers, around 30 sewage relay pumping stations, and two major treatment plants with a combined capacity of 0.4 m³/sec. However, a study conducted in 1985 indicated that the city generated the amount of domestic sewage and industrial wastewater equivalent to 16 m³/sec, thus the bulk of the remaining sewage is discharged without any form of treatment directly to the sea. As a result, the coastal area and beaches of Lima have become severely contaminated, creating a serious social problem which the Peruvian government decided must be addressed urgently.

Treated water is utilized for agricultural and silviculture irrigation, and has been considered in a recent experiment for use in aquiculture. Although prohibited, the reuse of raw sewage for food crop cultivation is practiced in some areas. In parks in the urbanized area of Lima, watering of lawns and trees are sometimes done by plugging the sewers. The contribution of the park greenery to the environment is a positive aspect and is a strong argument for the reuse of sewage for irrigation. As raw sewage constitutes a potential health hazard to farmers as well as to people who consume agricultural crops irrigated with it, prior treatment to a desired level is required before sewage is used for irrigation.

Taking into account the current situation then, the Government of Peru in August 1986, conducted initial inquiries on the possibility of implementing a sewerage system improvement project with the assistance of the Japanese Government. In September 1988, the Government of Peru presented an official request together with a Terms of Reference for the improvement of the sewerage system of southern Lima with the end view of upgrading environmental conditions.

In response to the request, the Japanese Government decided to carry out a feasibility study of the proposal and dispatched a preliminary Survey Team through the Japan International Cooperation Agency (JICA) between the end of November and the beginning of December 1988. Investigation on the problem of the existing sewerage system was made in coordination with the Servicio de Agua Potable y Alcantarillado de Lima (SEDAPAL) which is the counterpart agency for the Study. The Scope of Work for this Study was agreed between the JICA Survey Team and SEDAPAL in Lima on December 7, 1988.

S.1.2 Objectives of the Study

Based on the contents of the request of the Government of Peru, the objectives of the Study are: i) to carry out a feasibility study relative to the improvement of the existing sewerage system in the southern part of Lima and, subsequently, to carry out the feasibility study relative to the plan for construction of a Treatment Plant, and ii) to transfer relevant technology applied in the Study to Peru through activities of the Study Team.

S.1.3 Scope of the Study

The Study Area covers the southern part of Lima, specifically extending from an intake point to be constructed at the middle point of the Colector Surco and/or the main sewers on the north, to the Quebrada Pucara northern boundary of the San Bartolo plain on the south. Target year for the Project in this Study is year 2000.

The Study which consisted of field work in Peru and home office work in Japan, covered several tasks items in pursuit of the objectives and in accordance with the Agreement and the Minutes of Meeting prepared by the JICA Study Team on December 7, 1988. These tasks are: data collection and review; field survey work consisting of measurement of sewage quantity and quality, and topographic survey and soil investigation; preparation of alternatives; identification of the optimum plan which includes facilities planning, implementation planning, and organization, operation and management planning; and evaluation of the proposed system.

CHAPTER 2

DESCRIPTION OF THE STUDY AREA

CHAPTER S.2 DESCRIPTION OF THE STUDY AREA

S.2.1 Brief History of Metropolitan Lima

Metropolitan Lima, which now comprise the Province of Lima and the Constitutional Province of Callao, started in 1535 as a principal part of Lima province and expanded with the annexation of the neighboring constitutional province of Callao during the Second World War. From its population of 64,000 inhabitants as Lima province in 1820, the population of Metropolitan Lima has grown to more than 6 million in 1989. The city is experiencing rapid development in recent years especially in the southern part where migrants have built new settlements called "Pueblos Jóvenes" in wide area.

S.2.2 Natural Condition

The Study Area encompasses 16 of the 41 districts which make up the province of Lima. It occupies 122 square kilometers of the 2,800 square kilometers area of the province of Lima and includes 1.8 million of its 6 million inhabitants. The Study especially covers the "Pueblos Jóvenes" because they are in immediate need of water supply and sewerage services.

Lima is situated in the coast of a fan-shaped valley formed by the Rimac, Chillón and Lurín rivers, and lies at an altitude of 40 to 200 meters above sea level. The Study Area falls between the Rimac and Lurín rivers. Except for low-lying river valleys, the area was desert previously with cliffs rising abruptly from the sea shore. Ground surface gradient in river valleys is less than 5 percent while it is around 5 percent sloping towards the sea in the deserts.

A formation consisting of Tertiary strata base and overlying sands from the Quarternary era characterizes the geology of the Study Area. These sands originated from river depositions, fluvial terraces, and dunes formed by aeolian deposits.

Metropolitan Lima is traversed by three rivers: the Chillón river which runs in the northern part, the Rimac river which cuts through the heart of the city, and the Lurín river which traverses the Study Area. Chillón river is mainly used for irrigation and is being eyed as a possible source of domestic supply in the year 2000. Rimac river is the principal source of water supply for Metropolitan Lima and is also used for irrigation. Sole use of the Lurín river at present is for irrigation.

The sea fronting Peru is subject to ocean currents called the Humboldt, South Equatorial and Equatorial Counter currents, which combined action either creates rare heavy rainfalls along the coasts or spawn great volumes of plankton. Thus, the marine area of Peru has a strong and varied influence on the fishing and on the coastal agro-industry.

Earthquake is the only probable natural disaster of significant proportion that could occur in Peru. The Andes area is considered to be most earthquake-prone but this is far from Lima. Except in the San Bartolo plain where many traces of debris flow are found, the Study Area does not experience landslide or debris flow.

Lima falls under a desert type climate. Because of the influence of

the cold Humboldt ocean current, humidity is high and temperature is lower than in an area in Brazil of the same latitude. Annual average relative humidity is more than 80 percent while the average monthly minimum and maximum relative humidity ranges from 60 to 95 percent. Monthly average temperature ranges from 12.7 to 28.9 degrees Centigrade with an average annual value of 18 degrees Centigrade.

In Metropolitan Lima, precipitation is very minimal to practically nil, storms and seasonal winds do not occur, and atmospheric pressures and winds are stable at any time of the year. Average annual evaporation is in the order of 1,470 mm with monthly averages ranging from 70 to 170 mm.

Solar exposure is greatest during the month of April at 58-60 percent and is least during the month of August at 14-16 percent.

S.2.3 Economy

The Gross Domestic Product (GDP) of Peru, which registered increases of 9.5 and 7.8 percent in 1986 and 1987, respectively, ended up in 1988 with a decrease of 8.4 percent. The economic growth in 1986 and 1987 adversely resulted to the reduction of foreign currency reserves and to the economic plunge in 1988. Because of the increased money supply, the inflation rate went up to 62.9, 114.5 and 1,722.3 percent in 1986, 1987, 1988, respectively. In 1988, only the agriculture and fishing sectors gained in GDP, the latter owing to the favorable ocean currents which increased the fish catch.

Peru's main products are derived from agriculture and mining. The agriculture - forestry, fishery and mining industries accounted for 10.9, 0.8 and 10.1 percent, respectively, of the GDP in 1987. Except for a slight increase in the manufacturing sector, no major change had taken place in the industrial structure of Peru since 1985.

Tourism is a principal foreign currency earning industry in Peru. In 1987, about 1,890,000 tourists consisting of 250,000 foreigners and 1,640,000 Peruvian nationals visited Metropolitan Lima, earning for the tourism industry the amount of US\$ 393 million. Major tourist spots in Lima include several beach resorts along the Pacific coast. Another beach resort in the coast of Chira is being planned for the promotion of tourism but a raw sewage outfall locally known as Colector Surco has polluted the sea water in the area and is causing major environmental problems.

As for the trade balance of Peru, there was a surplus of US\$ 1,172 million in 1985 and but has since then incurred deficits, the biggest being US\$ 463 million in 1987.

S.2.4 Public Health Condition

Sanitary and health conditions in Peru are generally still considered unsatisfactory as infectious diseases continue to affect and claim lives of many Peruvians every year. Although a number of water-borne diseases have been kept almost at the same level through the 9-year period from 1980 to 1988, incidence rates of other infectious diseases had been on the steady rise since 1982. Infectious water-borne diseases in Peru are definitely serious problems caused by insanitary water and inadequate sewage treat-

ment. Infantile mortality is very much higher compared to other age groups at a ratio of more than 9:1. High infantile mortality, as expected, occurs in departments where there are few hospitals, beds, doctors and nurses. Medical condition in Peru which is presently insufficient, will be worsen due to lack of medicine caused by current economic regression of Peru.

Although infantile mortality is lower in Lima than in other departments and nourishment conditions are quite better in comparison to other areas, incidence rates of infectious diseases including water-borne diseases during the last 4 years from 1985 to 1988 are high, some even higher than the nationwide figure. Typhoid and Paratyphoid, Virus-Hepatitis, and Gastroenteritis had the highest rates of incidence among the water-borne and infectious diseases. These diseases particularly occur in high number of cases in children younger than 4 years old.

Results of separate questionnaire surveys conducted recently by the SEDAPAL and the Villareal University epidemiology class indicated an interrelation between the incidence of skin rash and allied diseases in bathers of the coasts near the Surco Outfall, to the pollution of seawater in the marine recreational areas.

Residents of Lima obtain their supply of water from various sources like the systems of the SEDAPAL groundwater from wells, communal faucets, water vendors, etc. Of these, water bought from tank trucks which are stored in cisterns for several days and water taken from some private wells are most likely subject to contamination by causative agents of infectious diseases. As before mentioned, some of the raw sewage is reused for irrigation including vegetable cultivation, a practice which results to the transmittal of infectious water-borne diseases.

S.2.5 Energy Supply Condition

ELECTROPERU is the national agency responsible for policy decisions on plans for the development of sources, generation and supply of power. It distributes power to local agencies, among them ELECTROLIMA, which supplies electricity to the Study Area.

As of 1986, only 41 percent of the country was electrified. Completion of a power supply network that would cover practically the entire country is expected by the year 2000.

Due to the reduction of the equipment capacity caused by various factors, the effective output of power generating facilities is now only about three-fourths of the installed capacity. Occasional planned power cuts occur in the Study Area but there had been no instance when power supply totally stopped over the whole area.

Based on 1987 and 1988 statistics, the SEDAPAL consumed electricity equivalent to approximately 1.5 percent of the total maximum demand on the North-Central grid, the largest in Peru. A sewage treatment plant employing aerated lagoon system with 1.0 m³/sec capacity would roughly contribute an additional 8 percent to the total consumption of SEDAPAL. Expenditure on electric charges represents 1.6 percent of the total expenses of SEDAPAL, if reserve costs like depreciation is included; otherwise the proportion would be 3.5 percent.

With the apparent power supply shortage in Metropolitan Lima, any planning for pumping stations and treatment facilities must be made in consultation with ELECTROLIMA and that provisions must be made for power outages.

S.2.6 Water Supply System in Metropolitan Lima

The sources of potable water supply for Metropolitan Lima are the Rimac river and wells. Water from the Rimac river is treated at the Atarjea Treatment Plant while groundwater from wells is treated by chlorination in accordance with SEDAPAL standards. Based on records of the SEDAPAL, the combined production of the sources between January 1988 and February 1989 averaged about 20.5 m³/sec/day.

The SEDAPAL system currently supplies water to about 5 million of the 6.5 million inhabitants of Metropolitan Lima, indicating a service coverage of 77 percent. Average per capita consumption based on the total population and water actually consumed is 244 l/day. Unaccounted for water is approximately 13.5 percent of the total volume supplied.

In particular, the water supply to the Surco drainage area which also comprises the Study Area is under the responsibility of SEDAPAL. Amount of water supplied to the drainage area in 1989 was 5.1 m³/sec.

S.2.7 Other Infrastructures

Networks of air, overland and maritime transportation centered around Lima link the major Peruvian cities. Air transport routes radiate from the Jorge Chavez International Airport in Lima. A railroad line used mainly for cargo transport passes through a central station in Lima. The construction is underway for an urban railway, principally for the carriage of passengers connecting the southern part of Lima to the central area. Most important highway networks in the country are the Pan-americana along the coast and the Central Highway which crosses the Andes from Lima and branches inland. In maritime transportation, the largest terminal for domestic and overseas maritime transport in Peru is the port of Callao in Lima.

The around 2,200 km Peruvian coastline has numerous fishing harbors and ports, 15 of which are classified as principal ports. Port of Callao, being the principal port of entry, handles the bulk of the import and export cargoes. Establishments dependent on the fishing industry also abounds in the said port. Chorillos, a port near the Study Area unloads tons of fresh fish mainly for the consumption of Lima. The largest petroleum refinery in Peru, which supplies the fuel requirements of the port of Callao and the Jorge Chavez International Airport, is located in Ventanilla which is located north of Callao.

In the Study Area, patches of the surrounding desert are being developed through conversion to agricultural lands or green areas. Works are in progress by a relevant government agency to provide several large public parks with ample green areas.

CHAPTER 3

EXISTING SEWERAGE SYSTEM

CHAPTER S.3 EXISTING SEWERAGE SYSTEM

S.3.1 Master Plan of Sewerage System

The master plan for the sewerage system of Lima, first developed in 1945, had undergone changes on many occasions. Most recent of these revisions is the total restructuring of the master plan for the water supply and sewerage system of Lima done in 1981 through the financial assistance of the International Bank for Reconstruction and Development (IBRD). A related project, the feasibility study for recycling sewage to irrigate part of the arid zone south of Lima, was carried out in 1985. Results of these currently in force master plan and feasibility study formed the bases for studies under this Project.

The 1981 water supply and sewerage system master plan study including an investigation into the recycling of treated waste water, which was prepared by the Engineering Science Inc., covers 580 square kilometers of Metropolitan Lima. Planning period extends 30 years from 1981 to 2010, within which span of time the population in the planning area was projected to grow from 5.0 million in 1980 to 15.2 million in 2010. Average sewage quantity was estimated to increase from 13.8 m³/sec in 1980 to 31.3 m³/sec (if special control is adopted) or 36.8 m³/sec (if there is no special control). Maximum daily sewage flow was taken as 110 percent of the average. Important features of the master plan are: i) the flow direction of the Surco sewer system is maintained but all sewage discharge to rivers and sea will be intercepted, ii) by the year 2000, 11.2 m³/sec of sewage will be recycled as groundwater recharge, and for agriculture and parks irrigation, iii) remaining unrecycled sewage will be discharged to the sea through submerged pipes after primary treatment, iv) sewage not connected to the public sewerage system, which is estimated to reach 1.8 m³/sec in the year 2000, will be treated in an oxidation lagoon and emptied into nearby canals, v) considerable length of pipes with diameter greater than 350 mm are planned to be installed, and vi) the construction of a 4 m³/sec or 5 m³/sec capacity treatment plant together with a conveyance system for the transport of sewage for irrigation.

The feasibility study for recycling sewage for irrigation purposes was undertaken by the TAHAL Consulting Engineers Inc. with financial assistance from the Inter American Development Bank. The project involves treatment and conveyance of sewage from the Surco main sewer for the irrigation of around 5,000 hectares of desert in the San Bartolo plain. After a study of several alternatives. The scheme found to be most attractive is a system with, i) a capacity of 2.4 m³/sec, ii) combined gravity and pumped transmission line from the intake point at San Juan primary treatment facility to San Bartolo plain consisting of buried steel pipe and open channel, and iii) primary treatment through sedimentation in nearby open lands and park, and secondary treatment by aeration lagoon in San Bartolo. Except for the intake amount and transmission route, this present Study and that of the TAHAL study are fundamentally the same.

S.3.2 Sewer Systems

The existing sewerage system of Metropolitan Lima is able to serve the entire urban areas of Lima and Callao but the sewer network in other parts is insufficient. In old sections of the city, particularly, sewer

lines are so deteriorated by antiquity that breaks often occur. Frequent street flooding also occurs due to the insufficiency of the drainage capacity of sewers caused by the increase in sewage discharge. Parts of the sewer network, notably that on the northern and southern outskirts of the city, are currently being expanded.

The public sewerage system which is shown in FIGURE S-1, consists of 7 drainage areas, namely: Comas, Callao, Costanero, Surco, Area No.6, San Martin/Rio Bamba, and San Juan Miraflores. In areas where such public facility is not available, large establishments like factories and commercial centers have their own sewerage system. Operation of the system is mostly by gravity except in some low-lying areas where pumps are employed. Pertinent data on the drainage areas are outlined in TABLE S-1. Surco drainage area, which is the largest in the system and subject of the Study, has about 30 sewer lines flowing into the Colector Surco, the drainage area's trunk sewer. Colector Surco empties to the sea in the vicinity of "Punta la Chira".


TABLE S-1 Pertinent Data on Drainage Area

| NAME | DRAIN.AREA (ha) | MAIN SEWER | DIA. (mm) | LENGTH (m) | CAPACITY (m ³ /sec) | DISCHARGE (1988) daily avg.(m ³ /sec) | REMARKS |
|-------------------------|--------------------|-------------|--------------|---------------|-----------------------------------|-----------------------------------------------------|-----------------------|
| Comas | 4,000 | Colector | 1,200 | 64,452 | 4.00 | 1.700 | |
| | | Comas | - 350 | | | (1.70) | |
| Callao | 5,100 | Colector | 1,300 | 61,050 | 6.27 | 3.016 | |
| | | Centenario | - 350 | | | (3.70) | |
| Costanero | 4,000 | Colector | 1,300 | 63,350 | 4.34 | 3.038 | |
| | | Costanero | - 350 | | | (3.30) | |
| Surco | 11,900 | Colector | 2,100 | 144,091 | 10.77 | 4.770 | Disc. 5.359 (1989) |
| | | Surco | - 350 | | | (5.70) | |
| No.6 | 2,300 | Colector | 1,500 | 34,221 | 4.60 | 1.530 | |
| | | No.6 | - 350 | | | | |
| San Martin Rio Bamba | 700 | Colector | 900 | 11,106 | 0.32 | 0.280 | 2 outfalls |
| | | Conde Villa | - 350 | | | 0.210 | |
| | | Zarumilla | | | | | |
| San Juan | 800 | Colector | 700 | 5,730 | 0.38 | - | Disc. 0.275 (1989) |
| | | San Juan | - 350 | | | | |
| TOTAL | 28,800 | - | - | 384,000 | - | - | |

Source: SEDAPAL Measuring Date: 9/23/1988, June/1989

* Values in parenthesis are estimated.

It is estimated that half of the water produced from the private wells are discharged into the public sewerage system. Based on the results of the latest investigation conducted by the SEDAPAL, the Surco drainage area absorbs 0.32 m³/sec of industrial wastewater from 249 factories.



SCALE IN METER



FIGURE S-1

EXISTING SEWERAGE SYSTEM

S.3.3 Sewage Pumping Stations

There are around 30 sewage pumping stations installed at some low-lying branch sewer lines where sewage cannot be conveyed to the mains by gravity flow. Pertinent data on these pumping stations are outlined in TABLE S-2. Several other sewage pumping facilities are under construction. Submersible sewage pumps are normally used for smaller facilities while vertical shaft centrifugal pumps are used for medium and large facilities. In principle, automatic operation is adopted but due to breakdowns, pumps are often operated manually. There are no facilities for measurement of flow, hence discharge is calculated from the duration of pump operation. All pumping stations are operated using commercial power supply, although a few of them are equipped with emergency units for use during periods of outages. Most of the stations using vertical pumps are provided with manual rakes for screens but none of them have grit chambers.

TABLE S-2 Pertinent Data on Sewage Pumping Station

| No. | Name | District | Design Flow Rate (l/s) | Capacity of Pump (φ) | Total Electrical Capacity (kW) | Installed Year | Remarks |
|-----|----------------------|-------------------|------------------------|------------------------------------------|--------------------------------|----------------|-----------|
| 1 | M. de la Marina | Miraflores | 300 | 200 x 150 l/s 2sets 150 x 80 l/s 1set | 113 | 1983 | operation |
| 2 | B. Baños de Barranco | Barranco | 50 | 100 x 25 l/s 3sets | 54 | 1983 | operation |
| 3 | Domosola | Miraflores | | | 3 | | |
| 4 | Malecon Armendariz | Miraflores | | | 75 | | |
| 5 | Malecon Iglesias | Chorrillos | 40 | 125 x 40 l/s 2sets | 18 | 1985 | operation |
| 6 | Matellini | Chorrillos | 25 | 100 x 25 l/s 2sets | 22 | | operation |
| 7 | C.C. La Laguna 1 | La Molina | | 80 x 1/s 1set 100 x 1/s 1set | 24 | | operation |
| 8 | Los Alamos | Surco | | | | | |
| 9 | San J. de Miraflores | Sn.J.de Miraf. | | | 150 | | |
| 10 | Canto Grande | Canto Grande | | | | | |
| | | Parque El Bosque | | | | | |
| 11 | Pro | Sn.M.de Porras | | | | | |
| 12 | Cocharcas | Chorrillos | | 100 x 1/s 2sets | 90 | | operation |
| 13 | Sta. Leonor | Chorrillos | | 80 x 1/s 2sets | 8 | | operation |
| 14 | Laguna de la Molina | La Molina | | 80 x 1/s 2sets | 3 | | operation |
| 15 | Jose Olaya | Surco | | 80 x 1/s 1set | 2 | | operation |
| 16 | Marbella | Magdalena | | | | | |
| | del Mar | | 50 | 100 x 25 l/s 2sets | 45 | | operation |
| 17 | Cedros de Villa | Chorrillos | 270 | 200 x 90 l/s 3sets | 111 | 1986 | operation |
| 18 | S. Ignacio de Loyola | Sn.J.de Miraf. | | 80 x 1/s 2sets | 4 | | operation |
| 19 | Camara Unica | | | | | | |
| | del Callao | Callao | 948 | 300 x 316 l/s 4sets | 450 | 1954 | operation |
| 20 | Camara No.2 | V.El Salvador | 30 | 100 x 15 l/s 3sets | 41 | 1983 | operation |
| 21 | Camara No.3 | Lurin | 15 | 160 x 15 l/s 1set | 9 | | operation |
| 22 | Camara No.4, | | | | | | |
| | Pachacamac | V.El Salvador | 100 | 150 x 50 l/s 3sets | 165 | 1984 | operation |
| 23 | Camara No.5 | Virgen de Lourdes | 12 | 100 x 12 l/s 2sets | 18 | | operation |

Source: SEDAPAL

S.3.4 Sewage Treatment Plants

Sewage treatment facilities in Metropolitan Lima consists of the San Juan Sewage Treatment Plant, Carapongo Sewage Treatment Plant, and several waste stabilization ponds.

San Juan STP, located in the southern part of Lima within the Study Area, operates as a facultative pond with the treated water being reused for irrigation. It is the center in South America for studies and experiments conducted on subjects concerning sewage treatment. The plant consists of 2-cell facultative ponds having a total area of 22.1 ha (8.9 primary and 13.2 secondary). Numerous reports have been made on the San Juan STP by the Pan-America Center for Sanitary Engineering and Environmental Sciences (CEPIS) and useful data and information have been provided with regard to items like design methods and removal of parasites and bacteria. For example, one such report recommended an areal BOD loading of under 400 kg-BOD/ha/day on primary pond from the climate condition in Peru, as a result of long-term research done in the San Juan STP. In comparison, high areal BOD loads are experienced in its operation, resulting to the emission of strong odor from the primary ponds particularly in winter when the temperature is low. Deposited sludge in the primary ponds is removed once every 5 years and once every 7 years in secondary ponds.

Carapongo STP treats sewage from the districts of Chosica and Chacacayo which are located 20 km from Lima upstream of the Rimac river. Design capacity of this plant is 24,000 m³/day, of which facilities to take care of half this design capacity have been completed. Method of treatment being employed in these existing facilities is the aerated lagoon system; the use of oxidation ditch process is being considered for its future expansion. The STP is composed of a grit chamber, facultative aerated lagoon, sedimentation pond, and chlorination tank. Design influent water quality is 200 mg/l for both BOD₅ and SS. Except for the abnormal generation of algae during the early days in operation, and the much accumulation of sludge especially in the upstreammost lagoon, the treatment plant is in generally good operational condition.

Apart from the San Juan STP, there are three other existing waste stabilization ponds in the southern part of Lima while treated water are all utilized for irrigation. Additionally, one other such treatment facility is under construction while another is still in the planning stage.

CHAPTER 4
POPULATION

CHAPTER S.4 POPULATION

S.4.1 Past Demographic Trends

Population of Peru and Metropolitan Lima for the years 1940, 1961, 1972 and 1981 as adjusted and interpolated from official census records of the Instituto Nacional de Estadística (INE) are shown in TABLE S-3. As indicated, the population of Peru for said years were around 7.08 million, 10.22 million, 13.95 million, and 17.75 million, compared to that of Metropolitan Lima which were about 0.65 million, 2.36 million, 3.42 million and 4.84 million, respectively.

TABLE S-3 also significantly shows a large influx of people from the rural areas to Lima from 1940 to 1961, which trend still continues to this time but at a diminished rate except in the fringe areas of the city and in "Pueblo Jóvenes".

S.4.2 Projection of the Future Population

Various entities including the SEDAPAL, INE, Engineering-Science Inc., and TAHAL Consulting Engineers Inc., have developed population projections for Metropolitan Lima. The bases of all these projections were the past census records, the latest of which was that for 1981. Although it is believed that these population studies may have been valid at the time they were prepared, such projections seem unreliable under current conditions, considering the length of time since the last census was taken and the apparent abnormal increase in population between 1981 and the present. Thus, the Survey Team attempted to calculate the future population of the Study Area based on the data of the last three census years employing different mathematical methods, namely: Logistic Curve, Exponential Curve, and Geometrical Methods.

Results of the analyses were compared with each other as well as with the projection of INE and consequently the mean values for each district obtained from the three calculation methods were adopted for the planning of this Project. However, for those districts where the calculated growth rates are absurd, values obtained from other formulas which are regarded as appropriate are adopted instead. The projected population of Metropolitan Lima based on this manner of calculation is as follows:

| <u>Year</u> | <u>Population</u> |
|-------------|-------------------|
| 1989 | 5,993,400 |
| 1990 | 6,145,200 |
| 1995 | 6,899,300 |
| 2000 | 7,661,400 |

The above figure for 1990 as well as that which concerns solely the population for the 16 districts of Surco drainage area agree closely with the INE projection.

TABLE S-3 Estimated Population by District

| DISTRICT | 1940 | 1961 1/ | 1972 | 1981 2/ |
|------------------------------------|-----------|------------|------------|------------|
| LIMA | 276,734 | 262,400 | 366,501 | 390,513 |
| ANCON | 1,428 | 4,000 | 5,792 | 8,865 |
| ATE | 11,061 | 80,900 | 63,235 | 138,746 |
| BARRANCO | 19,162 | 43,700 | 50,746 | 48,907 |
| BRENA | - | 102,800 | 116,031 | 118,271 |
| CARABAYLLO | 12,317 | 43,500 | 28,981 | 55,558 |
| CHACLACAYO | 1,160 | 9,600 | 22,195 | 33,243 |
| CHORRILLOS | 7,244 | 33,300 | 94,088 | 149,294 |
| CIENEGUILLA | - | 1,300 | 2,628 | 4,783 |
| COMAS | - | 97,400 | 179,819 | 297,870 |
| EL AGUSTINO | - | 77,100 | 121,445 | 176,537 |
| INDEPENDENCIA | - | 85,100 | 113,827 | 144,918 |
| JESUS MARIA | - | 86,600 | 86,991 | 87,525 |
| LA MOLINA | - | 2,100 | 6,218 | 29,786 |
| LA VICTORIA | 56,947 | 201,800 | 274,735 | 284,922 |
| LINCE | 26,443 | 84,800 | 85,878 | 84,660 |
| LURIGANCHO-CHOSICA | 7,731 | 33,500 | 53,220 | 68,542 |
| LURIN | 3,817 | 6,400 | 13,259 | 18,104 |
| MAGDALENA DEL MAR | 16,574 | 57,400 | 58,816 | 58,437 |
| PUEBLO LIBRE | 6,184 | 70,600 | 80,864 | 88,374 |
| MIRAFLORES | 46,757 | 91,100 | 103,235 | 108,859 |
| PACHACAMAC | 3,711 | 12,100 | 4,705 | 7,134 |
| PUCUSANA | - | 1,800 | 2,941 | 4,319 |
| PUENTE PIEDRA | 2,625 | 8,600 | 19,616 | 35,694 |
| PUNTA HERMOSA | - | 300 | 940 | 1,063 |
| PUNTA NEGRA | - | 400 | 768 | 582 |
| RIMAC | 58,841 | 148,600 | 178,538 | 194,123 |
| SAN BARTOLO | - | 1,000 | 1,518 | 3,067 |
| SAN BORJA 3/ | - | 53,600 | 68,862 | 59,270 |
| SAN ISIDRO | 9,082 | 39,000 | 65,513 | 72,706 |
| S.J. DE LURIGANCHO | - | 23,300 | 90,393 | 272,943 |
| S.J. DE MIRAFLORES | - | 64,000 | 110,833 | 174,426 |
| SAN LUIS | - | 8,600 | 25,072 | 53,306 |
| SAN MARTIN DE PORRES | - | 99,900 | 239,973 | 426,010 |
| SAN MIGUEL | 4,115 | 23,900 | 65,559 | 104,405 |
| SANTA MARIA DEL MAR | - | 100 | 46 | 101 |
| SANTA ROSA | - | 100 | 226 | 518 |
| SANTIAGO DE SURCO | 7,397 | 46,600 | 69,817 | 147,105 |
| SURQUILLO | - | 23,500 | 29,792 | 98,269 |
| VILLA EL SALVADOR 4/ | - | - | - | 142,567 |
| V.M. DEL TRIUNFO | - | 94,800 | 188,115 | 187,878 |
| Sub Total (PROV. LIMA) | 579,330 | 2,125,600 | 3,091,731 | 4,382,200 |
| CALLAO | 72,441 | 124,600 | 205,631 | 270,499 |
| BELLAVISTA | 8,580 | 44,300 | 41,239 | 69,148 |
| CARMEN DE LA LEGUA | - | 18,300 | 26,977 | 39,498 |
| LA PERLA | - | 22,000 | 34,627 | 48,362 |
| LA PUNTA | 3,686 | 6,100 | 6,916 | 6,416 |
| VENTANILLA | - | 17,200 | 17,341 | 20,177 |
| Sub Total (PROV.CALLAO) | 84,707 | 232,500 | 332,731 | 454,100 |
| TOTAL (METRO. LIMA) | 664,037 | 2,358,100 | 3,424,462 | 4,836,300 |
| PERU 2/ | 7,080,000 | 10,217,500 | 13,954,700 | 17,754,800 |
| Proportion of Metro. Lima | 9.38% | 23.08% | 24.54% | 27.24% |
| Average Annual Growth Rate of Lima | | 6.39% | 3.46% | 3.95% |
| - do - Callao | | 4.93% | 3.31% | 3.52% |
| - do - M.Lima | | 6.22% | 3.45% | 3.91% |
| - do - Peru | | 1.76% | 2.87% | 2.71% |

- 1/ SEDAPAL (Adjusted the influence of independence of new districts)
2/ Proyecciones de Poblacion por Años Calendarios (Boletin Especial No.10), Dec.1986, INE
3/ Summation of a part of Santiago de Surco and Surquillo in proportion to belonging area before independence
4/ Adjusted with V. M. del Triunfo

S.4.3 Projected Population Within Surco Drainage Area

The population projection for the Surco drainage area based on the correlation of the area and population of related districts and that of the area of the Surco drainage area itself is given in TABLE S-4. As indicated, the estimated population is 1,732,500 for 1989 and 2,687,100 for the year 2000, an increase of 55.1 percent in 11 years or an average annual growth rate of 4.1 percent. This growth rate is high compared to that of the rest of Metropolitan Lima, owing to the presence of the "Pueblos Jóvenes."

The projected population of the Surco drainage area is further broken down into three categories in accordance with the type of water supply and water consumption amount defined in the report for the Master plan of Lima Sewerage System as follows:

- Direct Service High Consumption Group - D/S.H
- Direct Service Low Consumption Group - D/S.L
- Indirect Service Group - ID

The population data corresponding to each category and district for the same periods are listed in TABLE S-5.

TABLE S-4 PROJECTED POPULATION (SURCO DRAINAGE AREA)

| DISTRICT | 1989 | 2000 | 1989 | 2000 | 1989 | 2000 | 1989 | 1990 | 1991 | 1992 | 1993 | 1994 | 1995 |
|-----------------------------------------|-------------------|------------|----------------|------------|---------------------|---------------------|---------------------|---------------------|---------------------|----------------------|----------------------|----------------------|----------------------|
| AREA (ha) | TOTAL SURCO D.(%) | | 1/ POP. R. (%) | | 2/ | | | | | | | | |
| LIMA | 2,121 | 2 | 2 | 2 | 8,100 | 8,200 | 8,200 | 8,200 | 8,200 | 8,200 | 8,300 | 8,300 | 8,300 |
| ATE | 9,822 | 8 | 39 | 50 | 81,000 | 85,400 | 85,400 | 85,400 | 89,900 | 94,600 | 99,400 | 104,200 | 109,100 |
| BARRANCO | 273 | 100 | 100 | 100 | 48,100 | 48,000 | 48,000 | 48,000 | 47,900 | 47,900 | 47,800 | 47,700 | 47,700 |
| CHORRILLOS | 3,681 | 25 | 81 | 90 | 159,100 | 161,800 | 161,800 | 161,800 | 164,400 | 166,700 | 168,900 | 171,000 | 172,800 |
| EL AGUSTINO | 1,836 | 19 | 21 | 50 | 102,600 | 106,100 | 106,100 | 106,100 | 109,600 | 113,100 | 116,600 | 120,000 | 123,400 |
| LA MOLINA | 4,169 | 35 | 60 | 80 | 66,400 | 74,900 | 74,900 | 74,900 | 84,200 | 94,300 | 105,300 | 117,300 | 130,100 |
| LA VICTORIA | 909 | 93 | 93 | 93 | 270,900 | 271,600 | 271,600 | 271,600 | 272,100 | 272,800 | 273,300 | 273,900 | 274,400 |
| MIRAFLORES | 512 | 45 | 45 | 45 | 50,900 | 51,100 | 51,100 | 51,100 | 51,300 | 51,600 | 51,800 | 52,000 | 52,200 |
| SAN BORJA | 1,046 | 100 | 100 | 100 | 56,800 | 56,700 | 56,700 | 56,700 | 56,500 | 56,300 | 56,200 | 56,100 | 56,000 |
| SAN ISIDRO | 1,007 | 27 | 27 | 27 | 21,000 | 21,100 | 21,100 | 21,100 | 21,200 | 21,400 | 21,500 | 21,700 | 21,800 |
| S.J. DE MIRAFLORES (SÁN JUAN STP) 3/ | 2,351 (850) | 40 (36) | 86 (36) | 41 (37) | 100,700 (91,000) | 114,600 (94,200) | 114,600 (94,200) | 114,600 (94,200) | 129,300 (97,400) | 144,700 (100,600) | 161,000 (103,800) | 178,000 (107,000) | 195,900 (110,100) |
| SAN LUIS | 356 | 100 | 100 | 100 | 64,100 | 65,000 | 65,000 | 65,000 | 65,800 | 66,500 | 67,200 | 67,700 | 68,200 |
| SANTIAGO DE SURCO | 3,493 | 77 | 91 | 95 | 191,000 | 200,900 | 200,900 | 200,900 | 211,200 | 221,700 | 232,600 | 243,700 | 255,100 |
| SURQUILLO | 413 | 100 | 100 | 100 | 101,200 | 101,600 | 101,600 | 101,600 | 101,900 | 102,100 | 102,400 | 102,500 | 102,700 |
| VILLA EL SALVADOR | 3,368 | 28 | 78 | 90 | 225,900 | 241,500 | 241,500 | 241,500 | 257,600 | 274,100 | 291,000 | 308,200 | 325,800 |
| V.M. DEL TRIUNFO | 7,149 | 18 | 39 | 90 | 275,700 | 292,200 | 292,200 | 292,200 | 309,000 | 326,300 | 343,800 | 361,700 | 379,800 |
| TOTAL | 42,906 | - | - | - | 1,823,500 | 1,900,700 | 1,900,700 | 1,900,700 | 1,980,100 | 2,062,300 | 2,147,100 | 2,234,000 | 2,323,300 |

| DISTRICT | 1996 | 1997 | 1998 | 1999 | 2000 |
|-----------------------------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
| LIMA | 8,400 | 8,400 | 8,400 | 8,500 | 8,500 |
| ATE | 114,200 | 119,400 | 124,700 | 130,100 | 135,600 |
| BARRANCO | 47,600 | 47,600 | 47,500 | 47,500 | 47,400 |
| CHORRILLOS | 174,600 | 176,300 | 177,900 | 179,400 | 180,900 |
| EL AGUSTINO | 126,700 | 130,000 | 133,300 | 136,600 | 139,700 |
| LA MOLINA | 144,100 | 159,200 | 175,300 | 192,700 | 211,300 |
| LA VICTORIA | 275,000 | 275,600 | 276,100 | 276,600 | 277,100 |
| MIRAFLORES | 52,400 | 52,600 | 52,800 | 53,000 | 53,200 |
| SAN BORJA | 55,800 | 55,700 | 55,500 | 55,600 | 55,500 |
| SAN ISIDRO | 21,900 | 22,100 | 22,200 | 22,300 | 22,400 |
| S.J. DE MIRAFLORES (SÁN JUAN STP) 3/ | 214,600 (113,300) | 234,200 (116,500) | 254,200 (119,700) | 276,200 (122,900) | 298,500 (126,100) |
| SAN LUIS | 68,600 | 68,900 | 69,300 | 69,500 | 69,800 |
| SANTIAGO DE SURCO | 266,800 | 278,700 | 290,900 | 303,300 | 315,900 |
| SURQUILLO | 102,800 | 102,900 | 103,000 | 103,000 | 103,100 |
| VILLA EL SALVADOR | 343,700 | 362,100 | 380,700 | 399,600 | 419,000 |
| V.M. DEL TRIUNFO | 398,400 | 417,200 | 436,200 | 455,600 | 475,300 |
| TOTAL | 2,415,600 | 2,510,900 | 2,608,700 | 2,709,500 | 2,813,200 |

Note: 1/ Area collected by Surco Interceptor in each district
 2/ Ratio of population collected by the Collector Surco in each district. Ratios from 1990 to 1999 are interpolated.
 3/ Values for S.J. de Miraflores includes those of existing San Juan STP. Those are presented in parenthesis.

TABLE S-5 DISTRIBUTION OF POPULATION BY DISTRICT

| NAME OF DISTRICT | 1989 | | | | 2000 | | | | RATE OF INCREASE |
|-------------------|----------------------|----------|--------------------|---------|----------------------|----------|--------------------|----------|------------------|
| | ESTIMATED POPULATION | DS/H | SERVICE LEVEL DS/L | ID | PROJECTED POPULATION | DS/H | SERVICE LEVEL DS/L | ID | |
| Lima | 8,100 | 5,240 | 2,140 | 720 | 8,500 | 5,500 | 2,250 | 750 | 1.05 |
| Ate | 81,000 | 29,960 | 45,440 | 5,600 | 135,600 | 50,180 | 75,950 | 9,470 | 1.67 |
| Barranco | 48,100 | 26,960 | 14,450 | 6,690 | 47,400 | 26,560 | 16,150 | 4,690 | 0.99 |
| Chorrillos | 159,100 | 31,720 | 73,130 | 54,250 | 180,900 | 36,200 | 126,530 | 18,070 | 1.14 |
| El Agustino | 102,600 | 13,480 | 48,370 | 40,750 | 139,700 | 18,330 | 107,430 | 13,940 | 1.36 |
| La Molina | 66,400 | 59,760 | 6,640 | 0 | 211,300 | 190,200 | 21,100 | 0 | 3.18 |
| La Victoria | 270,900 | 197,810 | 46,170 | 26,920 | 277,100 | 202,330 | 47,220 | 27,550 | 1.02 |
| Miraflores | 50,900 | 39,640 | 11,260 | 0 | 53,200 | 41,440 | 11,760 | 0 | 1.05 |
| San Borja | 56,800 | 29,540 | 23,290 | 3,970 | 55,500 | 28,860 | 22,760 | 3,880 | 0.98 |
| San Isidro | 21,000 | 17,010 | 3,990 | 0 | 22,400 | 18,150 | 4,250 | 0 | 1.07 |
| S.J.de Miraflores | 100,700 | 15,110 | 77,560 | 8,030 | 298,500 | 44,800 | 229,810 | 23,890 | 2.96 |
| (San Juan STP) | (91,000) | (13,600) | (70,120) | (7,280) | (126,100) | (18,840) | (97,170) | (10,090) | (1.39) |
| San Luis | 64,100 | 34,750 | 21,070 | 8,280 | 69,800 | 37,840 | 25,100 | 6,860 | 1.09 |
| Santiago de Surco | 191,000 | 80,170 | 93,610 | 17,220 | 315,900 | 132,680 | 154,830 | 28,390 | 1.65 |
| Surquillo | 101,200 | 61,750 | 33,330 | 6,120 | 103,100 | 62,900 | 33,950 | 6,250 | 1.02 |
| Villa El Salvador | 225,900 | 2,370 | 169,370 | 54,160 | 419,000 | 8,450 | 335,260 | 75,290 | 1.85 |
| V.M.del Triunfo | 275,700 | 8,380 | 237,150 | 30,170 | 475,300 | 14,330 | 413,490 | 47,480 | 1.72 |
| TOTAL | 1,823,500 | 653,650 | 906,970 | 262,880 | 2,813,200 | 918,750 | 1,637,940 | 258,510 | 1.55 |
| Ratio (%) | 100 | 36 | 50 | 14 | 100 | 33 | 58 | 9 | |

CHAPTER 5

SEWAGE QUANTITY AND QUALITY

CHAPTER S.5 SEWERAGE QUANTITY AND QUALITY

Sewerage flow measurements on the Surco outfall and three planned intake points were conducted during the Study to determine the present sewage discharge amount which would serve as basis, together with the data on population projection, for estimating the amount of sewage discharge in year 2000. Measurements were made under two conditions: one is with the intake from the Rimac river to the Surco river open, and the other with the intake close.

Simultaneous with the flow measurements, sewage water quality analyses were carried out to determine the required capacity of sewage treatment plant. Analyses on Heavy Metals were also performed taking into consideration the possibility of irrigation use.

S.5.1 Present Sewage Quantity

S.5.1.1 Flow Measurements on the Surco Outfall


Sewerage flow measurements were conducted two times each at the points shown in FIGURE S-2. It is assumed that the flow of Surco outfall is the sum of the flows of three main sewers, namely: Colector Surco, Colector Circunvalacion and Colector Balnearios del Sur. On the second measurement, the intake gates of the Surco river were closed in order to discount the possible influence of the "acequia" on the sewage flow. Results of these measurements are summarized in TABLE S-6.

TABLE S-6 Results of Sewerage Flow Measurement at Surco Outfall
unit: m³/s

| | May 31 - June 1, 1989 | | | | | October 19 - 20, 1989 | | | | |
|--------------------------|-----------------------|---------|-------|---------|-------|-----------------------|---------|-------|---------|-------|
| | Surco | Circun. | B.Sur | Total Q | Rate | Surco | Circun. | B.Sur | Total Q | Rate |
| Maximum Q _{max} | 4.929 | 1.454 | 0.305 | 6.569 | 1.223 | 4.477 | 1.612 | 0.296 | 6.324 | 1.274 |
| Average Q _{avg} | 4.058 | 1.134 | 0.178 | 5.370 | 1 | 3.625 | 1.157 | 0.181 | 4.963 | 1 |
| Minimum Q _{min} | 2.769 | 0.839 | 0.082 | 3.756 | 0.699 | 2.313 | 0.841 | 0.076 | 3.240 | 0.652 |

Location of Measuring Point, and Measuring Date and Time

1. Surco: Colector Surco, Diameter 1.54 meters
Av. Jr Mexico 270, Surquillo
1st: from 10:00, May 31 to 10:00, June 1, 1989
2nd: from 8:45, October 19 to 8:30, October 20, 1989
2. Circun.: Colector Circunvalacion, Diameter 1.31 meters
Av. Julio Calero 140, Surquillo
1st: from 10:30, May 31 to 10:30, June 1, 1989
2nd: from 8:45, October 19 to 8:30, October 20, 1989
3. B. Sur: Colector Balnearios del Sur, Diameter 0.75 meters
Av. Daniel Portocarrero 264, Surquillo
1st: from 10:30, May 31 to 10:30, June 1, 1989
2nd: from 8:45, October 19 to 8:30, October 20, 1989



CIUDAD SUR

7) SAN JUAN DE MIRAFLORES DRAINAGE AREA

EMISOR GRAL VILLA MARIA DEL TRIUNFO

(PAMPA MAMAY)

Intake Point No. 1

Intake Point No. 2

Intake Point No. 3

COLE SAN JUAN DE MIRAFLORES

EMISOR GRAL VILLA EL SALVADOR

SAN JUAN S.T.P. STABILIZATION POND SYSTEM

4) SURCO DRAINAGE AREA

LIMA

Surco Outfall

(PUNTA LA CHRAJ)


SURCO OUTFALL

FIGURE S-2

LOCATION OF SEWAGE FLOWRATE MEASURING POINTS

LEGEND

| | |
|--|---------------------------------|
| | Trunk Sewer Over $\phi 16'$ |
| | Drainage Area |
| | Sewage Flowrate Measuring Point |



As can be seen from the TABLE S-6, there was a difference of about 0.41 m³/sec (5.370 m³/sec in the first as against 4.963 m³/sec in the second) between the two measured average flows. This difference is attributed to the reduction of sewage discharge due to the decrease in water consumption, and the prevention of intrusion flow from the Surco river. About 0.13 m³/sec of this is supposed to have been due to lower water consumption as deduced from a comparison of records of amount supplied by the Atarjea Treatment Plant during same period, the balance of 0.28 m³/sec is attributed to the stoppage of intrusion flow from the Surco river.

The present (1989) average flow was assumed at 5.0 m³/sec, which is roughly the mean of the first measurement done in this Study (5.37 m³/sec) and the measurement performed by the SEDAPAL in 1988 (4.77 m³/sec). Due to obvious reasons, the result of the second measurement made in this Study was disregarded in the reckoning of the average flow.

With reference to the design standard of SEDAPAL, the estimated actual water supply amount, the results of sewage flow measurements, and the guidelines adopted in Japan, the per capita domestic sewage quantity for different service groups is projected as follows:

| Service Group | Per Capita Sewage Discharge (lpcd) |
|---------------------------------------|------------------------------------------|
| Direct Service High Water Consumption | 210 |
| Direct Service Low Water Consumption | 180 |
| Indirect Service Group | 110 |

Based on the above assumptions and on an estimate of population falling under the respective service category, the estimated domestic sewage quantity for 1989 was 3.62 m³/sec.

TABLE S-7 Domestic Sewage Quantity (1989)

| | Categories | | | TOTAL |
|---------------------------------------|------------|---------|---------|-----------|
| | D/S.H | D/S.L | ID | |
| Population | 639,660 | 829,320 | 263,520 | 1,732,500 |
| Sewage Discharge (lpcd) | 210 | 180 | 110 | |
| Sewage Quantity (m ³ /sec) | 1.555 | 1.728 | 0.336 | 3.619 |

As before mentioned, industrial wastewater and intrusion water were estimated at 0.32 and 0.28 m³/sec, respectively. Miscellaneous wastewater comprises the 0.78 m³/sec to complete sewage flow balance of the estimated 5.0 m³/sec average sewage quantity.

S.5.1.2 Flow Measurements on the Intake Points

Results of flow measurements on three intake points of the Surco outfall given in TABLE S-8, show no unexplainable difference between the

two measurements carried out on intake point No. 1 and intake point No. 3. The variances obtained are regarded as normal fluctuations in daily sewage discharge. On the other hand, the very large difference in measurement results for intake point No. 2 can be explained by a sudden decrease in sewage flow due to the shifting of the distribution of water supply to another drainage area.

TABLE S-8 Results of Sewage Flow Measurement

unit: m³/s

| | Intake Point No.1 Circunvalacion | | | | Intake Point No.2 Villa Maria | | | | Intake Point No.3 Surco | | | |
|--------------|-------------------------------------|------|----------|------|----------------------------------|------|----------|------|----------------------------|------|----------|------|
| | 6/06-07 | | 10/24-25 | | 6/06-07 | | 10/24-25 | | 6/06-07 | | 10/24-25 | |
| | Flow | Rate | Flow | Rate | Flow | Rate | Flow | Rate | Flow | Rate | Flow | Rate |
| Maximum Qmax | 0.6071 | 1.67 | 0.6693 | 1.57 | 0.2222 | 1.83 | 0.0827 | 1.70 | 3.3469 | 1.21 | 3.1344 | 1.21 |
| Average Qavg | 0.3632 | 1 | 0.4243 | 1 | 0.1209 | 1 | 0.0486 | 1 | 2.7611 | 1 | 2.5751 | 1 |
| Minimum Qmin | 0.1501 | 0.41 | 0.2006 | 0.47 | 0.0936 | 0.77 | 0.0222 | 0.45 | 1.5189 | 0.55 | 1.5138 | 0.58 |

Location of Measuring Point, and Measuring Date and Time

- Intake Pt. No.1: Colector Circunvalacion, Diameter 1.3 meters
Parque Fundadores, Av. J. de Aliaga, Santiago de Surco
1st: from 10:45, June 6 to 10:30, June 7, 1989
2nd: from 9:45, October 24 to 9:30, October 25, 1989
- Intake Pt. No.2: Emisor General Villa Maria del Triunfo
1st: Av. Pachacutec 828, Diameter 1.2 meters
from 11:15, June 6 to 11:00, June 7, 1989
2nd: Av. Pachacutec/Jose Carlos Mariategui, Dia. 0.632 meters
from 9:30, October 24 to 9:15, October 25, 1989
- Intake Pt. No.3: Colector Surco, Diameter 1.25 meters
Av. Nueva Tomas Marsano/Jorge Chavez CDA 38
1st: from 11:00, June 6 to 10:45, June 7, 1989
(Data at 9:30, 9:45 and 10:15 are interpolated.)
2nd: from 9:15, October 24 to 9:00, October 25, 1989

S.5.2 Future Sewage Quantity

S.5.2.1 Surco Outfall

Based on the same per capita sewage discharge according to service group adopted for 1989, the sewage quantity in year 2000 is estimated to reach 5.68 m³/sec.

TABLE S-9 Domestic Sewage Quantity (2000)

| | Categories | | | TOTAL |
|-------------------------------------|------------|-----------|---------|-----------|
| | D/S.H | D/S.L | ID | |
| Population | 899,290 | 1,507,860 | 279,950 | 2,687,100 |
| Sewage Discharge (lpcd) | 210 | 180 | 110 | |
| Sewage Quantity (m ³ /s) | 2.186 | 3.141 | 0.356 | 5.683 |

Industrial wastewater is expected to increase by 10 percent from the 1989 figure to 0.36 m³/sec. Intrusion flow which was suspected to have come from the Surco river is eliminated. Quantity of miscellaneous wastewater is projected to decrease to 60 percent of its present level or to 0.47 m³/sec. The predicted total sewage flow in the year 2000 is therefore 6.51 m³/sec.

S.5.2.2 Intake Points

Projected available sewage flows at the intake points in the year 2000 are summarized by category in TABLE S-10. Sewage flows are 0.74 m³/sec at intake point No. 1, 0.92 m³/sec at intake point No. 2, 2.39 m³/sec at intake point No. 3, and 2.46 m³/sec at remaining main sewers.

TABLE S-10 Available Sewage Quantity at Each Intake Point

| INTAKE POINT, NAME OF MAIN SEWER | SEWAGE QUANTITY BY CLASSIFICATION (m ³ /s) | | | |
|----------------------------------------------|-------------------------------------------------------|------------|--------|-------|
| | DOMESTIC | INDUSTRIAL | OTHERS | TOTAL |
| No.1, Colector Circunvalacion | 0.651 | 0.036 | 0.053 | 0.740 |
| No.2, Emisor General Villa Maria del Triunfo | 0.857 | 0.000 | 0.066 | 0.923 |
| No.3, Colector Surco | 1.932 | 0.264 | 0.172 | 2.388 |
| Remaining | 2.244 | 0.035 | 0.176 | 2.455 |
| Total Sewage Quantity | 5.684 | 0.355 | 0.467 | 6.506 |

The sewage quantities planned to be taken at the intake point as called for in the selected optimum alternative are 1.0 m³/sec each at intake point No. 1 and intake point No. 2 in Phase I, and 2.0 m³/sec at intake point No. 3 in Phase II. This shows that, i) there will be enough sewage flow at intake point No. 3 in the year 2000, ii) available sewage flow at intake point No. 2 will be almost the same as the planned intake amount, and iii) intake point No. 1 will have insufficient flow. It may be possible to secure additional sewage flow for intake point No. 1 through interception of flows from other areas, and if the efficiency of the water supply system is improved. However, due to many unpredictable factors, it is advisable to consider these measures after assessment of actual conditions when the Project is completed. Additionally, if the planned intake quantity cannot be obtained by any of the above measures, pumping sewage from the Colector Surco would be another possible alternative solution.

S.5.3 Present Sewage Quality

S.5.3.1 Biochemical Oxygen Demand (BOD₅) and Suspended Solid (SS)

Summary of past records of the SEDAPAL and results obtained in this Study with regard to the water quality analyses at existing sewage facilities, namely: the main sewers, San Juan STP and Carapongo STP, are as follows:

TABLE S-11 Present Sewage Quality
(unit: mg/l)

| Facility | BOD ₅ | | Suspended Solid (SS) | |
|---------------|------------------|---------|----------------------|---------|
| | Range | Average | Range | Average |
| Main Sewers | 146-333 | 227 | 152-289 | 239 |
| San Juan STP | 214-300 | 252 | 88-306 | 221 |
| Carapongo STP | 130-280 | 187 | 171-590 | 298 |

BOD₅ concentration in the Carapongo STP is lower than in other facilities possibly because of the influence of water intrusion from the "acequia".

Colector Surco and Colector Circunvalacion, which raw sewage will be diverted for irrigation reuse in this Project, have the following water quality values:

TABLE S-12 Present Sewage Quality in Main Sewers
(unit: mg/l)

| Name of Main Sewer | BOD ₅ (mg/l) | | SS (mg/l) | |
|-------------------------|-------------------------|---------|-----------|---------|
| | Range | Average | Range | Average |
| Colector Surco | 231-333 | 269 | 241-300 | 270 |
| Colector Circunvalacion | 146-233 | 185 | 152-278 | 228 |

S.5.3.2 Heavy Metals

Since it is highly possible that treated sewage will be reused for irrigation under this Project, it is important to consider the presence and concentration of heavy metals in sewage. In this regard, Class III of Water Quality Standards is applied for irrigation based on the General Law of Water in Peru.

Results of past analyses (TABLE S-13), including those obtained in this Study, on the raw sewage from Colector Surco and Circunvalacion indicated that except for Lead and Iron, concentrations of all other items were below the limit of the standards. However, it is expected that the

Lead and Iron concentrations in raw sewage will decrease to permissible levels once treated in stabilization ponds. In addition, there has been no reported harm done by heavy metals so far, even though raw sewage is being used for irrigation in many places in Lima.

TABLE S-13 Heavy Metals of Raw Sewage in Main Sewers

| Items | Past Record | Analyses Result in this Study | Water Quality Standard * |
|-------------------|-------------------|--------------------------------------|-----------------------------|
| | Colector Surco | Colector Surco and Circunvalacion | Class - III |
| Sampling Date | Nov., 1984 | Oct. & Nov., 1989 | - |
| Mercury Hg µg/l | - | 0.3 - 1.3 | 10 |
| Cadmium Cd mg/l | 0.01 - 0.03 | 0.005 - 0.02 | 0.05 |
| Lead Pb mg/l | 0.15 - 0.35 | 0.02 - 0.27 | 0.1 |
| Chromium Cr mg/l | - | 0.00 | 1.0 |
| Iron Fe mg/l | 3.2 - 6.25 | 1.2 - 1.44 | 1.0 |
| Manganese Mn mg/l | 0.05 - 0.12 | 0.06 - 0.08 | 0.5 |
| Copper Cu mg/l | 0.1 - 0.55 | 0.06 - 0.22 | 0.5 |
| Zinc Zn mg/l | 0.16 - 0.34 | 0.32 - 0.53 | 25 |
| Arsenic As mg/l | 0.02 - 0.04 | - | 0.2 |

*: Ley General de Aguas, Decreto Ley No.17752, Nov., 1983, Government of Peru. This law is based on the Standards of EPA, United States.

It may appear from the above analyses that heavy metals in irrigation is not a problem in the planned reuse of treated water for irrigation but considering their long-term effect, it is recommendable that, i) standards for receiving of industrial wastewater be consolidated, and ii) a control system for industrial wastewater quality be established.

S.5.4 Projected Sewage Quality

Projection of sewage quality for the design of sewage treatment plant was investigated and decided in consideration of the present sewage quality in existing facilities and per capita pollutant loading.

Ranges and averages of BOD₅ and SS concentrations in existing facilities are given in Subsection S.5.3.1. In determining the pollutant loading per capita, references used were the World Bank Technical Paper and the actual planning values adopted in Japan. Results of calculation for BOD₅ concentration of raw sewage are 225 mg/l in 1989 and 240 mg/l in year 2000.

Taking into account the above-mentioned data and considering such other factors as the ratio of flow between the two main sewers under study, the present sewage quality, and the need to provide for a slightly higher value to take care of load fluctuations, the adopted design sewage quality is 250 mg/l for both the BOD₅ and SS.

CHAPTER 6

ALTERNATIVES

CHAPTER S.6 ALTERNATIVES

Five alternatives have been studied to establish an appropriate plan for the Project both for improvement of sewerage system and construction of sewage treatment plant. These are further subdivided into subalternatives in accordance with the phased implementation plan. Major differences in the alternatives involve transmission route, existence of pumping station, sewage intake points and sewage amount.

Schematic plan and layout of the different alternatives are drawn in FIGURES S-3 and S-4.

S.6.1 Principle for Planning

The total amount of raw sewage discharged from the Surco Outfall shall be treated.

The total outflow was estimated to be 6.5 m³/sec average in the year 2000. Of this, 4.0 m³/sec shall be treated in San Bartolo or along the way to San Bartolo to the extent of available land area for treatment facilities (about 0.5 m³/sec of the treated sewage shall be used to irrigate areas in Villa El Salvador) and the remaining 2.5 m³/sec shall be treated by optimum treatment method at the Cerro La Chira site owned by SEDAPAL. Raw sewage transmission at San Bartolo shall either be at elevation 100 m or elevation 50 m.

The aerated lagoon method is adopted for the northern area of Rio Lurin (right bank) considering the difficulty of land acquisition with sufficient area, and the stabilization pond method for the southern area (left bank) where land acquisition is easy.

Screen and grit chambers shall be provided at sewage intake facilities to avoid clogging and provisions shall be made at inverted siphon section to remove sand and silt deposits.

Reinforced concrete pipe shall be used for gravity flowing sections; ductile cast iron pipe for inverted siphon sections with pressure over 4 kg/cm²; prestressed concrete pipe for inverted siphon sections with pressure less than 4 kg/cm²; fiberglass reinforced plastic mortar pipe for places with high salinity. Concrete lined open channels shall be used for gravity flowing sections located within sparsely populated areas.

FIGURE S-3 Schematic Plans of Alternatives

| PLAN | PHASE I | | PHASE II | | LEGEND | |
|------|--------------------------|-------------------------|--------------------------|-------------------------|--------|-------------------------------------------------------------------------------------|
| | Qty m ³ /s | unit: m ³ /s | Qty m ³ /s | unit: m ³ /s | | |
| A | A ₁ | 4.0 | | — | — | ☒ Stabilization Pond Ⓚ Aerated Lagoon ○ Intake Facility ⊕ Pumping Facility |
| | A ₂ | 2.0 | | 2.0 | | |
| | A ₃ | 1.0 | | 3.0 | | |
| B | B ₁ | 4.0 | | — | — | |
| | B ₂ | 2.0 | | 2.0 | | |
| | B ₃ | 1.0 | | 3.0 | | |
| C | C ₁ | 2.83 | | 1.67 | | |
| | C ₂ | 1.83 | | 2.17 | | |
| | C ₃ | 0.83 | | 3.17 | | |
| D | C ₃ | 1.0 | | 3.0 | | |
| | D ₁ | 1.5 | | 2.5 | | |
| E | D ₂ | 1.0 | | 3.0 | | |
| | E ₁ | 2.0 | | 2.0 | | |
| | E ₂ | 1.0 | | 3.0 | | |




FIGURE S-4 LAYOUT PLAN OF ALTERNATIVES

Prospective sites (Refer to FIGURE S-4 for location) for the treatment plant are as follows:

| LOCATION | AREA (ha) | REQUIREMENT FOR ACQUISITION |
|----------------------------------|--------------|--------------------------------------------------|
| Existing San Juan STP** | 10 | Approval of Ministry of Housing & Construction |
| San Juan | 35 | Moving of plantation |
| Villa El Salvador | 40 | Moving of plantation and school, Existing lagoon |
| Villa Rica * | 40 | Large outlay for land acquisition |
| San Bartolo (Elevation 100 m) | 60 x 7 | Easy to acquire |
| San Bartolo (Elevation 50 m) | 60 x 7 | Easy to acquire |
| Cerro La Chira ** | 20 | Planned site for future project of SEDAPAL |

* Shelved in the meantime because of difficulty in raising necessary funds.

** Reserved for future project of SEDAPAL

The maximum sewage treatment capacity of each proposed site is as follows:

| LOCATION | TREATMENT CAPACITY (m ³ /sec) | |
|---------------------------|------------------------------------------|----------------|
| | STABILIZATION POND | AERATED LAGOON |
| San Juan S.T.P. | ---- | 0.5 |
| San Juan | 0.19 | 1.0 |
| Villa El Salvador | 0.19 | 1.0 |
| San Bartolo (Elev. 100 m) | 0.5 x 7 | --- |
| San Bartolo (Elev. 50 m) | 0.5 x 7 | --- |

S.6.2 Outline of Alternatives

S.6.2.1 Alternative A (Pumping and Gravity Flow)

Sewage shall be conveyed from the southern part of Lima to San Bartolo at elevation 100 m. This is accomplished by pumping from the diversion points then by gravity through inverted siphons and open channels. Treated water is supplied to the irrigation areas. FIGURE S-5 shows the schematic diagrams of three plans for this alternative.

Sewage treatment plants shall consist of aerated lagoons at Villa El Salvador and stabilization ponds at San Bartolo.

S.6.2.2 Alternative B (Gravity Flow)

Sewage shall be conveyed from the southern part of Lima to San Bartolo at elevation 50 m. Sewage is transmitted by gravity from San Juan via Villa El Salvador, Lomo de Corvina Beach and Pachacamac up to San Bartolo where it will be treated and reused for irrigation. Schematic diagram of this alternative is illustrated in FIGURE S-6. Sewage treatment plants shall be of the same methods as in Alternative A. Approval for passage through the Pachacamac Ruins and the Explosives Plant has not been obtained. However, it will be possible after settling of several problems.

S.6.2.3 Alternative C (Gravity Flow and Pumping)

Sewage from the southern part of Lima is first treated at the right bank of the Rio Lurin to the extent facilities for water treatment will allow, then conveyed to San Bartolo at elevation 50 m (Phase I). Treatment plants shall be erected in San Bartolo like in Alternate B to take care of the remaining sewage water (Phase II). FIGURE S-7 shows the schematic arrangement under several plans or subalternatives.

S.6.2.4 Alternative D (Gravity Flow and Pumping)

Alternative D is basically the same as Alternate C except the location of the treatment plant. FIGURE S-8 shows the schematic diagram of the proposed system.

S.6.2.5 Alternative E (Gravity Flow)

Sewage from the southern part of Lima is transmitted to San Bartolo, treated, and supplied for irrigation. In Phase I, the target elevation at San Bartolo is 100 m whereas in Phase II, Elevation 50 m (FIGURE S-9). This alternative was made considering the advantages of alternative A and B.

S.6.3 Summary of Planned Sewage Quantity

The sewage quantity for each alternative is summarized in TABLE S-14.







FIGURE S-5 ALTERNATIVE-A (PUMPING & GRAVITY)




| FACILITY | PHASE I | PHASE II | S.T.P. |
|--------------|------------------|--------------|--------|
| GRIT CHAMBER | 0.9+2.6+0.5 m³/s | 0.5+3.5 m³/s | — |
| PHASE I | 0.9+2.6+0.5 m³/s | 0.5+3.5 m³/s | — |
| PHASE II | — | — | — |

| FACILITY | PHASE I | PHASE II | S.T.P. |
|--------------|----------------|----------|--------------|
| GRIT CHAMBER | 1.5 + 0.5 m³/s | 2.0 | 0.5+1.5 m³/s |
| PHASE I | 1.5 + 0.5 m³/s | 2.0 | 0.5+1.5 m³/s |
| PHASE II | — | — | — |

| FACILITY | PHASE I | PHASE II | S.T.P. |
|--------------|----------------|----------|----------------|
| GRIT CHAMBER | 0.5 + 0.5 m³/s | 3.0 | 0.2 + 0.5 m³/s |
| PHASE I | 0.5 + 0.5 m³/s | 3.0 | 0.2 + 0.5 m³/s |
| PHASE II | — | — | — |

FIGURE S-6 ALTERNATIVE - B (GRAVITY)



| FACILITY | GRIT CHAMBER | S.T.P. |
|----------|--------------------------------|--------------------------------|
| PHASE I | 1.8+0.8+0.33 m ³ /s | 0.5+1.0+0.83 m ³ /s |
| PHASE II | 1.67 | 1.87 |

- CASE OF MAXIMUM TREATMENT CAPACITY ON RIGHT BANK OF RIO LURIN.
- FOR TRANSMISSION BEYOND THE PACHACAMAC, PUMPING STATION IS NECESSARY DUE TO LOW ELEVATION OF S.T.P.
- FIGURES WITH * ARE SHOWN AS GROUND ELEVATION.

| FACILITY | GRIT CHAMBER | S.T.P. |
|----------|--------------------------------|----------------------------|
| PHASE I | 1.0+0.5+0.33 m ³ /s | 1.0+0.83 m ³ /s |
| PHASE II | 2.17 | 2.17 |

• CASE OF 3) TREATMENT PLANT

FIGURE S-7 ALTERNATIVE-C (GRAVITY+PUMPING)





FIGURE S-7 (CONT'D)

| FACILITY | | GRIT CHAMBER | S.T.P. |
|----------|-----------------------|-----------------------|---------------------------|
| PHASE I | 1.5 m ³ /s | 1.5 m ³ /s | 0.5+1.0 m ³ /s |
| PHASE II | 2.5 m ³ /s | 2.5 m ³ /s | 2.5 |

PHASE I 1.5 m³/s
PHASE II 2.5 m³/s




GRAVITY FLOW (G.F.)

| | | | | | | | | |
|----------|--------|------|--------|------|--------|------|--------|--------|
| PHASE I | Ø 1350 | I.S. | Ø 1100 | G.F. | Ø 1200 | I.S. | Ø 1500 | S.T.P. |
| PHASE II | Ø 1650 | | Ø 1500 | | Ø 1650 | | Ø 1500 | S.P. |

FACILITY

| | | | | |
|----------|-----------------------|------|---------------|--------|
| PHASE I | 1.0 m ³ /s | G.F. | Ø 1700 x 950 | S.T.P. |
| PHASE II | 3.0 m ³ /s | | Ø 2300 x 1150 | S.P. |



G.F.

| | | | | | | | | |
|----------|--------|------|--------|------|--------|------|--------|--------|
| PHASE I | Ø 1200 | I.S. | Ø 900 | G.F. | Ø 1000 | I.S. | Ø 900 | S.T.P. |
| PHASE II | Ø 1650 | | Ø 1650 | | Ø 1800 | | Ø 1650 | S.P. |

FIGURE S-8 ALTERNATIVE -D (GRAVITY + PUMPING)




FIGURE S-9 ALTERNATIVE - E (GRAVITY)

TABLE S-14 Summary of Planned Sewage Quantity

| Plan | Location of STP | Treatment Method | T O T A L P R O J E C T | | | | | | | | | | REMARKS | | | | |
|------|-----------------|------------------|-------------------------|-----------------------|-------------------------|------------------------|-------------|-----------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------|--|-----------------------|
| | | | PHASE I | | | | | PHASE II | | | | | | | | | |
| | | | (a) | (b) | (c) | (e) | (f) | (b) | (c) | (e) | (f) | Total | | | | | |
| A | A ₁ | Pressurized Flow | SAN JUAN STP | SAN JUAN | VILLA EL SALVADOR | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | Total | | |
| | | | | | 0.5 m ³ /s | | | 3.5 m ³ /s | | | | | | | | | |
| | | | | | 0.5 | | | 1.5 | | | | | | | | | 2.0 m ³ /s |
| B | B ₁ | Gravity Flow | | 0.5 m ³ /s | | | | | | | | | | | Total | | |
| | | | | 0.5 | | | | | | | | | | | | | 2.0 m ³ /s |
| | | | | 0.5 | | | | | | | | | | | | | 3.0 |
| C | C ₁ | Pressurized Flow | SAN JUAN STP | SAN JUAN | VILLA EL SALVADOR | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | SAN BARTOLO | Total | | |
| | | | | 0.5 m ³ /s | 1.0 m ³ /s * | 0.83 m ³ /s | | 3.5 m ³ /s | | | | | | | | | |
| | | | | 0.5 | 1.0 * | 0.83 | | 1.5 | | | | | | | | | |
| D | D ₁ | Gravity Flow | | | | | | | | | | | | | Total | | |
| | | | | 0.5 m ³ /s | 1.0 m ³ /s * | | | | | | | | | | | | |
| | | | | 0.5 | 1.0 * | | | | | | | | | | | | |
| E | E ₁ | Gravity Flow | | | | | | | | | | | | | Total | | |
| | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | |

CHAPTER S.7 PRELIMINARY ENGINEERING DESIGN OF ALTERNATIVES

Preliminary engineering design based on the concepts developed in Chapter S.6 was undertaken to provide a basic data for cost estimation. Major facilities necessary to be constructed for the project are: intake facility, transmission facility, pumping facility, and sewage treatment facility.

S.7.1 Intake Facility

Sewage intake shall be located at a point on the Colector Surco, the Colector Circunvalacion, the Colector Villa Maria del Triunfo and the Colector Villa El Salvador as shown in FIGURE S-10. TABLE S-15 shows the allocation of sewage intake corresponding to the alternatives outlined in the previous section.

TABLE S-15 Planned Intake Amount

| Main Sewer | Colector Circunvalacion | Emisor General Villa Maria Del Triunfo | Colector Surco | Emisor General Villa El Salvador |
|-----------------|-------------------------|----------------------------------------|----------------------|----------------------------------|
| A ₁ | 0.9 | 0.5 | 2.6 | - |
| A ₂ | 0.9 (II) | 0.5 (I) | 1.5 (I) 1.1 (II) | - |
| A ₃ | 0.5 (I) | 0.5 (I) | 3.0 (II) | - |
| B ₁ | 0.9 | 0.5 | 2.6 | - |
| B ₂ | 0.9 (II) | 0.5 (I) | 1.5 (I) 1.1 (II) | - |
| B ₃ | 0.9 (II) | 0.5 (I) | 0.5 (I) 2.1 (II) | - |
| C ₁ | - | 0.5 (I) | 1.5 (I) 1.67 (II) | 0.33 (I) |
| C ₂ | - | 0.5 (I) | 1.0 (I) 2.17 (II) | 0.33 (I) |
| C ₃ | - | 0.5 (I) | 3.17 (II) | 0.33 (I) |
| C _{3'} | - | 0.5 (I) | 3.00 (II) | 0.33 (I) 0.17 (I)* |
| D ₁ | - | - | 1.5 (I) 2.5 (II) | - |
| D ₂ | - | - | 1.0 (I) 3.0 (II) | - |
| E ₁ | 1.0 (I) | 1.0 (I) | 2.0 (II) | - |
| E ₂ | 1.0 (I) | - | 3.0 (II) | - |

* : Branch Sewer of Emisor General Villa El Salvador.

Sluice gate type intake facility such as that shown in FIGURE S-11 shall be used.




FIGURE S-10 Location of Intake Facilities

Possible capacity Q is 1.0m³/sec/basin






FIGURE S-11 Intake Facility

| |
|--------------------------------------------------------------------------------|
| SEDAPAL Servicio de Agua Potable y Alcantarillado de Lima |
| FERTILITY STUDY ON IMPROVEMENT OF SEWAGE SYSTEM IN COCHINQUE PART OF LIMA |
| TITLE: Intake Facility |
| SCALE: as above DATE: - '96 DRAWING No.: JUAN ESPINOSAVAL COOPERATION AGENT |


S.7.2 Transmission Facility

Conduit capacity is decided based on planned intake amount and its daily fluctuation. Manning's formula is applied for gravity flow with free water surface while the Hazen - Williams formula is adopted for sections of pressure flow.

Pipe materials planned for the alternatives are: reinforced concrete pipe for gravity flow section, ii) ductile cast iron pipe for pumping flow section, iii) prestressed concrete pipe and ductile cast iron pipe for inverted siphon, and iv) concrete lining for open channel.

The inverted siphons will be made up with inlet chamber with screen and grit chambers. Manhole will be installed in location where there are changes in pipe diameter, unevenness of invert level, pipe intersections, and where required for maintenance. Blow-off valves will be installed at appropriate intervals of inverted siphons. Drain pipes to be connected to nearest sewers except for those along the Lurin River where they shall be connected to sludge drying basins to prevent water pollution.

For illustration, layout plan and longitudinal section of transmission line for Alternative Plan E1 are presented in FIGURE S-12.



| Plan | Phase I | Phase II |
|------|-------------------------|-------------------------|
| E1 | 2.0 m ³ /sec | 2.0 m ³ /sec |
| E2 | 1.0 m ³ /sec | 3.0 m ³ /sec |

THIS PLAN SHOWS THE CASE OF PLAN E1.

LEGEND

- Existing Interceptor
- Planned Interceptor (Phase I)
- Planned Interceptor (Phase II)
- Gravity Main
- Inverted Siphon
- Force Main
- Open Channel
- Intake Structure
- Diversion & Junction Structures
- Outfall
- Pumping Station
- Treatment Works

FIGURE S-12

SEDAPAL
 Servicio de Agua Potable y Alcantarillado de Lima
 FEASIBILITY STUDY ON IMPROVEMENT OF
 SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA
 TITLE: ALTERNATIVE - E
 PLAN E1
 LAYOUT PLAN
 LONGITUDINAL SECTION
 SCALE: 1/50,000 DATE: - - '90 DRAWING No.:
 JAPAN INTERNATIONAL COOPERATION AGENCY

| DIAMETER, LENGTH, TYPE OF FLOW | AV. CIRCUNVALACION | AV. AGUSTIN ROSA LOZAN ROY TIRADO | AV. MIGUEL IGLESIAS | AV. MICAELA BASTIDAS | AV. PASTOR SEVILLA | ARENAL DE PACHACAMAC | VALLE DE LURIN | FABRICA DE EXPLOSIVOS (LINDERO PARTE ALTA) |
|--------------------------------|-----------------------|-----------------------------------|-----------------------|----------------------|-----------------------|------------------------|----------------|--------------------------------------------|
| | +1000 L = 4,050m | +1105 L = 1,550m | +1400 L = 5,150m | +1150 L = 5,370m | +1200 L = 9,790m | +1080 x 950 L = 3,500m | | |
| | Inverted Siphon No. 1 | Gravity Flow No. 2 | Inverted Siphon No. 2 | Gravity Flow No. 3 | Inverted Siphon No. 3 | Gravity Flow No. 4 | | |

| FLOW CAPACITY | Q = 1.0 m ³ /sec | Q = 1.0 m ³ /sec | Q = 1.0 m ³ /sec | Q = 2.0 m ³ /sec | Q = 1.5 m ³ /sec | Q = 1.5 m ³ /sec | Q = 1.5 m ³ /sec |
|---------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|-----------------------------|
| Q Quantity | Q = 1.0 m ³ /sec | Q = 1.0 m ³ /sec | Q = 1.0 m ³ /sec | Q = 2.0 m ³ /sec | Q = 1.5 m ³ /sec | Q = 1.5 m ³ /sec | Q = 1.5 m ³ /sec |
| V Velocity | V = 2.83 m/sec | V = 1.27 m/sec | V = 1.41 m/sec | V = 1.30 m/sec | V = 1.35 m/sec | V = 1.35 m/sec | V = 0.99 m/sec |
| S Slope | S = 8.0 ‰ | S = 2.2 ‰ | S = 1.5 ‰ | S = 1.0 ‰ | S = 1.1 ‰ | S = 1.5 ‰ | S = 0.5 ‰ |

* For Phase I. Refer to the layout plan for Phase I.

