

7.3 Transmission Facility

The following matters are considered in the preparation of preliminary engineering design of transmission line in each alternative. Drawings for each alternative are presented in FIGURES 7-7 to 7-15.

(1) Design Sewage Flow

In designing the conduit, the planned intake flow of each alternative is used for determination of conduit section.

The fluctuation of intake amount (refer to subsection 7.2.3) was taken into consideration for the decision of diameter and slope of transmission pipe to convey the planned sewage amount without hindrance.

(2) Flow calculation

The Manning's formula is applied for the gravity flowing section with free water surface:

Manning's Formula: $Q = A \cdot V$
 $V = (1/N) R^{(2/3)} S^{(1/2)}$

where;

Q: Quantity of flow (m³/sec)

A: Flow area (m²)

V: Flow velocity (m/sec)

N: Coefficient of roughness


for Concrete Pipes - 0.013

R: Hydraulic radius (m) (=A/P)

P: Wetted perimeter

S: slope

On the other hand, the Hazen - Williams' Formula is applied to the pressurized flowing section such as inverted siphon sections and pressurized flow sections :



Plan	Phase I	Phase II
A1	4.0 m ³ /sec	—
A2	2.0 m ³ /sec	2.0 m ³ /sec
A3	1.0 m ³ /sec	3.0 m ³ /sec

THIS PLAN SHOW THE CASE OF PLAN A1

LEGEND

- Existing Interceptor
- Planned Interceptor (Phase I)
- Planned Interceptor (Phase II)
- Gravity Main
- Inverted Siphon
- Force Main
- Open Channel
- Intake Structure
- Diversion & Junction Structures
- Outfall
- Pumping Station
- Treatment Works

FIGURE 7-7


SEDAPAL
Servicio de Agua Potable y Alcantarillado de Lima

FEASIBILITY STUDY ON IMPROVEMENT OF
SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA

TITLE: ALTERNATIVE - A
PLAN A1
LAYOUT PLAN
LONGITUDINAL SECTION

SCALE: 1 / 50,000 DATE: - '90 DRAWING No.:

JAPAN INTERNATIONAL COOPERATION AGENCY




Plan	Phase I	Phase II
B1	4.0 m³/sec	—
B2	2.0 m³/sec	2.0 m³/sec
B3	1.0 m³/sec	3.0 m³/sec

THIS PLAN SHOW THE CASE OF PLAN B1.

LEGEND

- Existing Interceptor ———
- Planned Interceptor (Phase I) ———
- Planned Interceptor (Phase II) - - - - -
- Gravity Main ———
- Inverted Siphon - - - - -
- Force Main ———
- Open Channel ———
- Intake Structure [Symbol]
- Diversion & Junction Structures [Symbol]
- Outfall [Symbol]
- Pumping Station [Symbol]
- Treatment Works [Symbol]



DIAMETER, LENGTH	TYPE OF FLOW	DIAMETER, LENGTH	TYPE OF FLOW	DIAMETER, LENGTH	TYPE OF FLOW	DIAMETER, LENGTH	TYPE OF FLOW	DIAMETER, LENGTH	TYPE OF FLOW	DIAMETER, LENGTH	TYPE OF FLOW
φ 100 L: 1,100 m	Inverted Siphon	φ 1650 L: 2,150 m	Gravity	φ 2000 L: 4,525 m	Gravity	φ 1650 L: 3,600 m	Inverted Siphon	φ 1650 L: 2,250 m	Inv. Siphon	φ 1650 L: 2,750 m	Inv. Siphon
φ 100 L: 1,100 m	Inverted Siphon	φ 1650 L: 2,150 m	Gravity	φ 2000 L: 4,525 m	Gravity	φ 1650 L: 3,600 m	Inverted Siphon	φ 1650 L: 2,250 m	Inv. Siphon	φ 1650 L: 2,750 m	Inv. Siphon

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

Q = 0.9 m³/sec	V = 2.4 m/sec	S = 1.00 ‰
----------------	---------------	------------

FIGURE 7-8


SEDAPAL
Servicio de Agua Potable y Alcantarillado de Lima

FEASIBILITY STUDY ON IMPROVEMENT OF SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA

TITLE: ALTERNATIVE - B
PLAN B1
LAYOUT PLAN
LONGITUDINAL SECTION

SCALE: 1 / 50,000 DATE: - '90 DRAWING No.:

JAPAN INTERNATIONAL COOPERATION AGENCY



Plan	Phase I	Phase II
C1	2.33 m ³ /sec	1.67 m ³ /sec

LEGEND

- Existing Interceptor
- Planned Interceptor (Phase I)
- Planned Interceptor (Phase II)
- Gravity Main
- Inverted Siphon
- Force Main
- Open Channel
- Intake Structure
- Diversion & Junction Structures
- Outfall
- Pumping Station
- Treatment Works

FIGURE 7-9

SEDAPAL
 Servicio de Agua Potable y Alcantarillado de Lima
 FEASIBILITY STUDY ON IMPROVEMENT OF
 SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA
 TITLE: ALTERNATIVE - C
 PLAN C1
 LAYOUT PLAN
 LONGITUDINAL SECTION
 SCALE: 1 / 50,000 DATE: '90 DRAWING No.
 JAPAN INTERNATIONAL COOPERATION AGENCY

Q = 1.5 m ³ /sec V = 1.18 m/sec S = 0.8 ‰	Q = 1.5 m ³ /sec V = 1.23 m/sec S = 1.1 ‰	Q = 1.0 m ³ /sec V = 1.03 m/sec S = 0.9 ‰	Q = 1.83 m ³ /sec V = 1.33 m/sec S = 1.0 ‰	Q = 1.83 m ³ /sec V = 1.35 m/sec S = 1.0 ‰	Q = 1.83 m ³ /sec V = 1.33 m/sec S = 1.0 ‰	Q = 1.83 m ³ /sec V = 1.13 m/sec S = 0.8 ‰	Q = 1.83 m ³ /sec V = 1.33 m/sec S = 1.0 ‰	Q = 1.83 m ³ /sec V = 1.07 m/sec S = 0.5 ‰
--	--	--	---	---	---	---	---	---






FIGURE 7-10

SEDAPAL
Servicio de Agua Potable y Alcantarillado de Lima
FEASIBILITY STUDY ON IMPROVEMENT OF
SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA
TITLE: ALTERNATIVE - C
PLAN C2
LAYOUT PLAN
LONGITUDINAL SECTION
SCALE: 1 / 50,000 DATE: '90 DRAWING No.:
JAPAN INTERNATIONAL COOPERATION AGENCY





Plan	Phase I	Phase II
Cs	1.0 m ³ /sec	3.0 m ³ /sec

LEGEND

- Existing Interceptor
- Planned Interceptor (Phase I)
- Planned Interceptor (Phase II)
- Gravity Main
- Inverted Siphon
- Force Main
- Open Channel
- Intake Structure
- Diversion & Junction Structures
- Outfall
- Pumping Station
- Treatment Works

FIGURE 7-12

SEDAPAL
Servicio de Agua Potable y Alcantarillado de Lima
FEASIBILITY STUDY ON IMPROVEMENT OF
SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA

TITLE
ALTERNATIVE - C
PLAN C3
LAYOUT PLAN
LONGITUDINAL SECTION

SCALE: 1:50,000 DATE: 90 DRAWING No. JAPAN INTERNATIONAL COOPERATION AGENCY

DIAMETER, LENGTH	TYPE OF FLOW	SECTION	TYPE OF FLOW	SECTION	TYPE OF FLOW	SECTION	TYPE OF FLOW	SECTION	TYPE OF FLOW	SECTION	TYPE OF FLOW	SECTION	TYPE OF FLOW	SECTION	TYPE OF FLOW	SECTION
Ø 1000 L: 3,350 m	Inverted Siphon	TOMAS MARZANO	Ø 800 L: 1,110 m	Gravity	SAN JUAN DE MIRAFLORES	Ø 1000 L: 3,600 m	Inverted Siphon	LOMO DE CORVINA	Ø 1000 L: 3,900 m	Inverted Siphon	Ø 1000 L: 2,000 m	Inverted Siphon	Ø 1000 L: 3,000 m	Inverted Siphon	Ø 1000 L: 5,150 m	Inverted Siphon

Q = 0.5 m ³ /sec V = 1.19 m/sec S = 1.5 ‰	Q = 0.3 m ³ /sec V = 1.32 m/sec S = 1.8 ‰	Q = 1.0 m ³ /sec V = 1.37 m/sec S = 1.5 ‰	Q = 1.0 m ³ /sec V = 1.37 m/sec S = 1.5 ‰	Q = 1.0 m ³ /sec V = 1.37 m/sec S = 1.2 ‰	Q = 1.0 m ³ /sec V = 1.37 m/sec S = 1.5 ‰	Q = 1.0 m ³ /sec V = 1.37 m/sec S = 1.5 ‰	Q = 1.0 m ³ /sec V = 1.37 m/sec S = 1.5 ‰
Q = 0.5 m ³ /sec V = 1.23 m/sec S = 2.2 ‰	Q = 0.67 m ³ /sec V = 1.13 m/sec S = 1.8 ‰						






FIGURE 7-13



SEDAPAL.
Servicio de Agua Potable y Alcantarillado de Lima

FEASIBILITY STUDY ON IMPROVEMENT OF
SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA

TITLE: ALTERNATIVE - D
PLAN DI
LAYOUT PLAN
LONGITUDINAL SECTION

SCALE: 1 / 50,000 DATE: '90 DRAWING No.:

JAPAN INTERNATIONAL COOPERATION AGENCY



LEGEND


- Existing Interceptor (---)
- Planned Interceptor (Phase I) (—)
- Planned Interceptor (Phase II) (---)
- Gravity Main (—)
- Inverted Siphon (---)
- Force Main (—)
- Open Channel (—)
- Intake Structure (□)
- Diversion & Junction Structures (□)
- Outfall (—)
- Pumping Station (P)
- Treatment Works (□)

DIAMETER, LENGTH	TOMAS MARZANO	SAN JUAN DE MIRAFLORES	LOMO DE CORVINA	PACHACAMAC ZONA ARQUEOLOGICA	VALLE DE LURIN	PAMPA SAN BARTOLO
TYPE OF FLOW	Inverted Siphon	Gravity	Gravity	Inverted Siphon	Inverted Siphon	Gravity
	+1200 L: 3,350 m	+1100 L: 3,675 m	900 L: 2,500 m	900 L: 3,600 m	900 L: 2,250 m	+1000 L: 4,105 m
		300m				900 L: 2,300 m
						11400 x 700 L: 6,900 m

Q : 1.0 m ³ /sec V : 1.1 m/sec S : 0.8 ‰	Q : 1.0 m ³ /sec V : 1.14 m/sec S : 1.1 ‰	Q : 0.5 m ³ /sec V : 0.91 m/sec S : 0.9 ‰	Q : 0.5 m ³ /sec V : 1.03 m/sec S : 1.0 ‰	Q : 0.5 m ³ /sec V : 1.03 m/sec S : 1.0 ‰	Q : 0.5 m ³ /sec V : 0.91 m/sec S : 0.8 ‰	Q : 0.5 m ³ /sec V : 1.03 m/sec S : 1.0 ‰	Q : 0.5 m ³ /sec V : 0.81 m/sec S : 0.5 ‰
---	--	--	--	--	--	--	--

FIGURE 7-14

SEDAPAL
Servicio de Agua Potable y Alcantarillado de Lima
FEASIBILITY STUDY ON IMPROVEMENT OF
SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA
TITLE: ALTERNATIVE - D
PLAN D2
LAYOUT PLAN
LONGITUDINAL SECTION
SCALE: 1 / 50,000 DATE: '90 DRAWING No.:
JAPAN INTERNATIONAL COOPERATION AGENCY



Plan	Phase I	Phase II
E1	2.0 m ³ /sec	2.0 m ³ /sec
E2	1.0 m ³ /sec	3.0 m ³ /sec

THIS PLAN SHOWS THE CASE OF PLAN E1.

LEGEND

- Existing Interceptor
- Planned Interceptor (Phase I)
- Planned Interceptor (Phase II)
- Gravity Main
- Inverted Siphon
- Force Main
- Open Channel
- Intake Structure
- Diversion & Junction Structures
- Outfall
- Pumping Station
- Treatment Works

FIGURE 7-15

SEDAPAL
 Servicio de Agua Potable y Alcantarillado de Lima
 FEASIBILITY STUDY ON IMPROVEMENT OF
 SEWERAGE SYSTEM IN SOUTHERN PART OF LIMA
 TITLE: ALTERNATIVE - E
 PLAN E1
 LAYOUT PLAN
 LONGITUDINAL SECTION
 SCALE: 1:5000, DATE: 30, DRAWING No.:
 JAPAN INTERNATIONAL COOPERATION AGENCY

FLOW CAPACITY

Q Quantity	Q = 1.0 m ³ /sec	Q = 1.0 m ³ /sec	Q = 1.0 m ³ /sec	Q = 2.0 m ³ /sec	Q = 1.5 m ³ /sec	Q = 1.5 m ³ /sec	Q = 1.5 m ³ /sec
V Velocity	V = 2.63 m/sec	V = 1.24 m/sec	V = 1.41 m/sec	V = 1.30 m/sec	V = 1.30 m/sec	V = 1.33 m/sec	V = 0.99 m/sec
S Slope	S = 0.0 %	S = 2.2 %	S = 1.5 %	S = 1.9 %	S = 1.4 %	S = 1.5 %	S = 0.5 %

* For Phase I. Refer to the layout plan for Phase I.

Hazen - Williams' Formula: $Q = A \cdot V$
 $V = 0.35464 C D^{0.63} S^{0.54}$

where;

Q: Quantity of flow (m³/sec)
A: Flow area (m²)
V: Flow velocity (m/sec)
C: Coefficient of roughness 130
D: Diameter (m)
S: Hydraulic gradient

Note : SEDAPAL uses the Manning's Formula for open channel, and the Hazen-Williams' Formula for pipeline.

(3) Flow velocity

The following velocity range is basically applied based on the planned sewage flow:

a) Gravity flow

Minimum 0.6 m/sec
Maximum 3.0 m/sec

b) Pressurized flow

Minimum 1.0 m/sec
Maximum 2.0 m/sec

(4) Pipe Materials

Pipe materials planned for alternatives are as follows (refer to APPENDIX 16):

a) Gravity flow section:

External pressure pipe (Reinforced concrete pipe)

b) Inverted siphon:

Internal pressure pipe (Prestressed concrete pipe, and Ductile cast iron pipe)

c) Pumping flow section:

Ductile cast iron pipe

d) Open channel

Open channel with concrete lining on both sides and bottom.

(5) Inlet chamber of inverted siphon

The inverted siphon will be made up with an inlet chamber at the upstream side of the pipe, placing screens and grit chambers.

(6) Manhole

The manhole will be installed in places where there are changes in pipe diameter, unevenness of invert level, pipe junctions, as well as in places deemed necessary for maintenance. A pressure type manhole will be installed where necessary.

(7) Blow-off or Drain

Blow-off valve will be installed at appropriate interval in long-span of inverted siphon pipes. Drain pipe will be connected to the nearest existing sewer if possible. However, along the coast line and at the Lurin river, the drain pipes are connected to sludge drying basin to prevent water pollution.

(8) Air valve

Air valves will be provided at the places deemed necessary along the inverted siphon section.

(9) Materials of pipe fittings

Pipe fittings and equipment for the pipeline with high inner pressure are made of cast iron or steel.

(10) Hydraulic calculation

As an example, outline and hydraulic calculations for alternative plan E1 are presented in FIGURES 7-16 and 7-17 for Phase I and Phase II, respectively. The figures likewise present design values for the planned sewage flow, maximum capacity, and minimum flow for allowable minimum flow velocity. Allowable minimum flow velocity is set as follows:

Gravity flow pipe:	0.6 m/s
Gravity flow open channel:	0.6 m/s
Inverted siphon:	0.8 m/s

Rough sketches of various structures necessary for the transmission facility are shown in APPENDIX 18.

High Elevation Transmission Line




FIGURE 7-16 HYDRAULIC CALCULATION OF TRANSMISSION LINE (PLAN E, PHASE I)

Low Elevation Transmission Line

	A	B	C	D	E	F	G	H	I	J	
GROUND CONDITION	GROUND ELEVATION	81.08	77.34	74.37	83.30	88.18	62.09	56.07	52.20	46.98	
	ELEVATION BALANCE h (m)	5.95	5.79	2.97	(12.28)	(1.43)		5.02	3.87	3.25	Σ = 40.13 m
PLANNED SPARE AMOUNT	GRADIENT (%)	1.77	1.57	0.99		(1.43)		1.46	1.54	0.50	
	h/L										
MAXIMUM CAPACITY	Q _p (m ³ /S)	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	HH: Hazen-Williams c=130
	V (m/S)	1.29	1.29	1.13	1.29	1.29	1.29	1.35	1.30	1.04	K: Manning n=0.013
VELOCITY	I (%)	1.2	1.4	0.9	1.4	1.4	1.4	0.9	1.5	0.5	
	H _r (m)	4.02	5.15	2.70	(2.04)			3.69	3.75	3.25	Σ = 34.60 m
VELOCITY	H _r < h (check)	OK	OK	OK	OK	OK	OK	OK	OK	OK	
	Q _m (m ³ /S)	2.32	2.20	2.12	2.52	2.52	2.52	2.12	2.62	2.35	
VELOCITY	V (m/S)	1.51	1.43	1.20	1.64	1.64	1.64	1.20	1.70	1.07	
	I (%)	1.2	1.4	0.9	1.4	1.4	1.4	0.9	1.5	0.5	
VELOCITY	Q _m /Q _p	1.16	1.10	1.06	1.26	1.26	1.26	1.06	1.31	1.18	
	Q (m ³ /S)	1.229	0.052	0.095	1.229	1.229	1.229	0.095	1.233	0.349	
VELOCITY	V (m/S)	0.8	0.6	0.6	0.8	0.8	0.8	0.6	0.8	0.6	
	I (%)										

FIGURE 7-17 HYDRAULIC CALCULATION OF TRANSMISSION LINE (PLAN E., PHASE II)

7.4 Grit Chamber and Pumping Facility

7.4.1 Grit Chamber

(1) Basic Design Concept

- a. In the Grit chamber, inorganic solids and suspended coarse matters in the raw sewage are removed in order to prevent the sedimentation of sand and erosion or clogging in transmission pipeline, pumps and treatment plant, for smooth operation and maintenance works. Grit Chamber, in principle, is located at the diversion point and upstream of inverted siphon, transmission pump or treatment plant.
- b. Sedimented sand in the Grit Chamber is removed by manpower periodically after drainage of chamber. For this reason, more than two units of Grit Chamber are generally provided.
- c. Hand rake screen is provided in the Grit Chamber to remove the suspended coarse matters.

(2) Design Criteria

Type : Plug-Flow Rectangular Type
Water Surface Load : $S_1 = \text{Approx. } 1,800 \text{ m}^3/\text{m}^2/\text{day}$
Average Velocity : $V = \text{Approx. } 0.30 \text{ m/s}$
Detention Time : $T = 30 \text{ to } 60 \text{ sec.}$

(3) Outline of Structure

Outline of Grit Chamber structure is as follows:




FIGURE 7-18 Outline of Grit Chamber Structure

(4) Dimension of Grit Chamber

Dimensions of Grit Chamber for each design flow of Alternatives are shown in TABLE 7-2.

TABLE 7-2 Dimension of Grit Chamber

Type	Design Flow (m ³ /s)	Required Water Surface (m ²)	Dimension of Grit Chamber			No. of Com- partment
			Width (mm)	Length (mm)	Depth (mm)	
I	0.19	$0.19 \times 86,400 / 1,800 = 9.12$	1,000	9,500	600	1
	0.50	$0.50 \times 86,400 / 1,800 = 24$	1,400	8,600	600	2
II	1.00	$1.00 \times 86,400 / 1,800 = 48$	1,200	13,500	1,000	3
		$1.00 \times 86,400 / 3,600^* = 24$	1,500	9,500	1,300	2
	1.50	$1.50 \times 86,400 / 1,800 = 72$	1,400	18,000	1,200	3
III	2.00	$2.00 \times 86,400 / 1,800 = 96$	1,300	19,200	1,400	4
	2.50	$2.50 \times 86,400 / 1,800 = 120$	1,500	20,000	1,400	4
IV	3.00	$3.00 \times 86,400 / 1,800 = 144$	1,400	20,600	1,500	5
	3.50	$3.50 \times 86,400 / 1,800 = 168$	1,500	22,400	1,600	5
	4.00	$4.00 \times 86,400 / 1,800 = 192$	1,700	22,600	1,600	5

*: In case Water Surface Load is 3,600 m³/m²/day.

7.4.2 Pumping Facility

(1) Basic Design Concept

- a. The number of pumps to be installed must be as few as possible with each pump unit having the same capacity and performance for easier operation and maintenance.
- b. Installation number of pump based on "Guidelines and Explanation for Design of Sewage Facilities" (Japan Sewage Works Association, 1984) is as follows:

<u>Design Flow (m³/s)</u>	<u>Number of Pumps (set)</u>
under 0.5	3 (incl. 1 stand-by)
0.5 to 1.5	3 to 5 (incl. 1 stand-by)
above 1.5	4 to 6 (incl. 1 stand-by)

- c. Pump is of the vertical shaft centrifugal type because of less space, requirement and suitability to design flow and total head.

(2) Outline of Structure

Outline of pumping facility structure is as follows:




FIGURE 7-19 Outline of Pumping Facility Structure

(3) Capacity Calculations of Pump

a. Water Level Profile

Water level profile of the alternatives are as follows:




FIGURE 7-20 Water Level Profile of Pumping Facility
(Alternatives A1, A2 and A3)




FIGURE 7-21 Water Level Profile of Pumping Facility
(Alternatives C1, C2, D1 and D2)

b. Pump Capacity

Capacity calculations of pumps for each alternative are shown in TABLES 7-3 and 7-4.

c. Application to Present Project

Because provisions must be made for power cuts, bypass discharge for emergency shall be considered.

TABLE 7-3 Capacity Calculation of Pump (Alternative A)

Item	Alternative			A ₃ (Phase II)	
	A ₁ (Phase I)	A ₂ (Phase I)	A ₂ (Phase II)		
Design Flow	m ³ /s	2.6 (156 m ³ /min)	1.5 (90 m ³ /min)	1.1 (66 m ³ /min)	3.0 (1806 m ³ /min)
Diameter of Pipeline	mm φ	1,350	1,100	900	1,500
Length of Pipeline	m	1,770	1,770	1,770	1,770
Number of Pump ※1	sets	6 (1)	5 (1)	4 (1)	6 (1)
Capacity of Pump per 1 set	m ³ /min	156x1/5=31.2	90x1/4=22.5	66x1/3=22	180x1/5=36
Diameter of Pump	mm φ	500	450	450	600
Total Head	Actual Head	m	137.6-84.8=52.8	52.8	52.8
	Head Loss	m	5.9	5.8	7.9
	Total Head	m	58.7=59	58.6=59	60.7=61
Motor Shaft Power per 1 set	kW	1.0x31.2x59 0.163x ————— =375 0.8	1.0x22.5x59 0.163x ————— =274	1.0x22x61 0.163x ————— =277	1.0x36x58 0.163x ————— =421 0.81
Specification of Pump ※1		φ 500x31.2m ³ /minx59m x440kWx6set (1)	φ 450x22.5m ³ /minx59m x320kWx5set (1)	φ 450x22m ³ /minx61m x320kWx4set (1)	φ 600x36m ³ /minx58m x490kWx6set (1)

※1 : (1) means 1 stand-by set.

TABLE 7-4 Capacity Calculation of Pump (Alternative C or D)

Item	Alternative		C ₂ or D ₂ (Phase I)	C ₂ or D ₂ (Phase I)
	C ₁ or D ₁ (Phase I)	C ₁ or D ₁ (Phase I)		
Design Flow	m ³ /s	1.0 (60 m ³ /min)	0.5 (30m ³ /min)	
Diameter of Pipeline	mm φ	φ900	φ600	
Length of Pipeline	m	900	900	
Number of Pump ※1	sets	4 (1)	3 (1)	
Capacity of Pump per 1 set	m ³ /min	60x1/3=20	30x1/2=15	
Diameter of Pump	mm φ	400	350	
Total Head	Actual Head	85.0-57.9=27.1	27.1	
	Head Loss	4.3	7.0	
	Total Head	31.4=32	34.1=35	
Motor Shaft Power per 1 set	kW	$1.0 \times 20 \times 32 \times 0.163 = 134$ 0.78	$1.0 \times 15 \times 35 \times 0.163 = 113$ 0.76	
Specification of Pump ※1		φ400x20m ³ /minx32m x160kWx4set (1)	φ350x15m ³ /minx35m x130kWx3set (1)	

※1 : (1) means 1 stand-by set.

7.5 Sewage Treatment Plant

7.5.1 General

Important items to be considered in the selection of treatment method are as follows:

- a. Quantity and quality of sewage and their variation
- b. Conditions in the areas of discharge and water use
- c. Scale of treatment plant
- d. Location and environment of treatment plant
- e. Operation and maintenance organization
- f. Operation and maintenance cost

Investigations must be made on these items in relation to the present Project and the most suitable treatment method selected accordingly.

7.5.2 Requirements of the System

(1) Design Sewage Flow

From investigations in Section 5.2, the discharge from Colector Surco at present is estimated at 5.0 m³/s and is predicted to increase to around 6.5 m³/s in the year 2000.

From the discussions in Chapter 6, the design flow of sewage treatment plant in each proposed site for several given alternatives are summarized in TABLE 7-5.

TABLE 7-5 Design Flow for Sewage Treatment Plant in Each Proposed Site

(unit : m³/s)

Proposed Site	a. San Juan STP		b. San Juan		c. Villa El Salvador		e. & f. San Bartolo	
Alternatives	Ph-I	Ph-II	Ph-I	Ph-II	Ph-I	Ph-II	Ph-I	Ph-II
A1	-	-	-	-	0.5	-	3.5	-
A A2	-	-	-	-	0.5	-	1.5	2.0
A3	-	-	-	-	0.5	-	0.5	3.0
B1	-	-	-	-	0.5	-	3.5	-
B B2	-	-	-	-	0.5	-	1.5	2.0
B3	-	-	-	-	0.5	-	0.5	3.0
C1	0.5*1	-	1.0	-	0.83	-	-	1.67
C C2	-	-	1.0	-	0.83	-	-	2.17
C3	-	-	-	0.5	0.83	-	-	2.67
C3'	-	-	-	0.5	1.0	-	-	2.5
D D1	0.5*1	-	1.0	-	-	-	-	2.5
D2	-	-	1.0	-	-	-	-	3.0
E E1	-	-	-	-	0.5	-	1.5	2.0
E2	-	-	-	0.5	-	-	1.0	2.5

*1 0.5 m³/s is the increase in quantity by reconstruction.

(2) Influent Sewage Quality

From the investigation in Section 5.5, Projected Sewage Quality, the influent sewage quality values are as follows;

BOD5 : 250 mg/l
 SS : 250 mg/l

(3) Target Treated Water Quality

The primary purpose of this Project is to lower the contamination level of sea water in the coastal area of Metropolitan Lima. As a secondary purpose, it is aimed to reuse treated sewage for irrigation.

Target treated water quality must therefore be set in consideration of both purposes.

Based on the study in APPENDIX 19, target treated water quality is set as follows:

TABLE 7-6 Target Treated Water Quality

Site of Plan	Treatment Level	BOD ₅ (mg/l)	Fecal Coliforms (MPN/100ml)
On the west bank of Rio Lurin	3	35	1,000
In the San Bartolo	2	45	10,000

7.5.3 Treatment Method

(1) Basic Conception

As mentioned in APPENDIX 19, two main factors should be taken into account in this Project: namely, the land area and the operation and maintenance problem.

For the purpose of selecting alternatives, following aspects shall be considered in the evaluation :

<u>Land Requirement</u>	<u>Operation and Maintenance</u>
Large	Easy, low cost
Small	Slightly easy, slightly lower cost

(2) Treatment Method

Study on treatment method is discussed in detail in APPENDIX 19. From investigations on available area and required treated water quality of each proposed site, and operation and maintenance problems, treatment method in each proposed site is decided as follows;

<u>Proposed Site</u>	<u>Treatment Method</u>
a. San Juan STP	7
b. San Juan	----- Aerated Lagoon (AL)
c. Villa el Salvador	7
e & f. San Bartolo	----- Waste Stabilization Pond (WSP)

7.5.4 Design Criteria

Study on Design Criteria for each Treatment Method is discussed in detail in APPENDIX 20. Design Criteria on Waste Stabilization Pond and Aerated Lagoon (Dual Power system) is given in TABLES 7-7 and 7-8.

TABLE 7-7 Design Criteria of Waste Stabilization Ponds

Parameter	Symbol	Unit	Formula or Value	Application
<u>Primary Facultative Pond</u>				
• Water Temperature	T_w	°C	$T_w = 8.49 + 0.82 T_a$	$T_a = 15$ °C $T_w = 8.49 + 0.82 \times 15 = 20.8$ °C
• BOD ₅ Areal Loading	L_{d1}	kg-BOD/ha/d	under 400 $L_{d1} = 357.4 \times 1.085$	($T_w - 20$) $L_{d1} = 357.4 \times 1.085$ = 382
• Water Depth	D_1	m	1.3 - 1.6	1.5
• BOD ₅ Removal Rate	R_1	%	65 - 75	70
<u>Secondary Facultative Pond</u>				
• BOD ₅ Areal Loading	L_{d2}	kg-BOD/ha/d	40 - 210	200
• Water Depth	D_2	m	1.3 - 1.6	1.5
• BOD ₅ Removal Rate	R_2	%	30 - 40	35

TABLE 7-8 Design Criteria for Aerated Lagoon (Dual Power Aeration System)

Parameter	Symbol	Unit	Formula or Value	Application
<u>Complete Mixing Aerated Lagoon</u>				
. Detention Time	t*c	day	1.5 - 2.0	2.0
. Water Depth	Dc	m	3.0 - 4.0	3.0
. Number of Lagoon	Nc	-	1	1
. Oxygen Requirement	Ro	kg/hr	$Ro=6.24 \times 10^{-5} \times Q.Li$	Same as left
. Power Requirement for Mixing	pc	w/m ³	$pc>=6w/m^3$	6w/m ³
<u>Facultative Aerated Lagoon</u>				
. Detention Time for One-Cell	t*f	day	0.5 - 1.0	0.67
. Water Depth	Df	m	3.0 - 4.0	3.0
. Power Requirement for Partially Mixing	pf	w/m ³	$pf \geq 1 w/m^3$	1.0-1.5w/m ³
. Number of Lagoon	nf	-	1 - 3 (series)	3 cells
<u>Sedimentation Ponds</u>				
. Detention Time	t*s	day	1 - 2	1

7.5.5 Outline of Facility

Detailed capacity calculation for sewage treatment plant on each proposed site is given in APPENDICES 13 and 14. Outline of each facility is presented in this section.

(1) Possible Treatment Capacity in Proposed Site (a) San Juan STP.

a. Basic Concept for Reconstruction

Out of the two-series treatment consisting of Upper and Lower Battery facultative ponds, treatment method of Upper Battery will be changed to Aerated Lagoon system in order to increase treatment capacity.




FIGURE 7-22 Flow Diagram of San Juan STP

- b. Total treatment capacity in San Juan Sewage Treatment Plant after reconstruction

	Treatment Method	Possible Treatment Capacity	Total Treatment Capacity
Upper Battery (Reconstruction)	Aerated Lagoon	0.63 m ³ /s	
			0.75 m ³ /s
Lower Battery (Existing)	Facultative Pond	21,600 m ³ /day x 1/2 = 10,800 m ³ /day = approx. 0.12m ³ /s	(64,800 m ³ /day)

Present treatment sewage flow in San Juan Treatment Plant is around 0.25 m³/s. Therefore, increase in possible total treatment capacity is:

$$0.75 - 0.25 = 0.5 \text{ m}^3/\text{s}$$

(2) Aerated Lagoon in Proposed Site (b) and (c)

a. Planned Treated Water Quality

	BOD	SS
Removal Rate	88 %	76 %
Water Quality	30 mg/l	60 mg/l

b. Flow Diagram

Flow diagram is shown in FIGURE 7-23.




FIGURE 7-23 Flow Diagram for Aerated Lagoon (Dual Power) System

c. Outline of Aerated Lagoon System on Proposed Site (b) and (c)

Outline of facility for each design sewage flow is given in TABLE 7-9.

TABLE 7-9 Outline of Aerated Lagoon System on Proposed Site (b) and (c)

Design Flow	Qd avg = 0.5 m ³ /s = around 43,200 m ³ /day	Qd avg = 0.83 m ³ /s = around 71,700 m ³ /day	Qd avg = 1.0 m ³ /s = around 86,400 m ³ /s
1. Completely Mixing			
Aerated Lagoon			
- Dimension	100m x 48m x 3.0 mD x 14,400m ³ x 6 basins	105m x 45m x 3.0mD x 14,490m ³ x 10 basins	100m x 48m x 3.0mD x 14,400m ³ x 12 basins
- Detention Time	t*c= 2.0 days	t*c= 2.0 days	t*c= 2.0 days
- Aerator-I	30 kW x 12 sets 18.5 kW x 12 sets (Total 582 kW)	30 kW x 20 sets 18.5 kW x 20 sets (Total 970 kW)	30 kW x 24 sets 18.5 kW x 24 sets (Total 1,164 kW)
2. Partial			
Mixing Aerated Lagoon			
- Dimension	100m x 33m x 3.0 mD x 9,900m ³ x 9 basins (3 cell x 3 series)	71m x 46m x 3.0mD x 9,798m ³ x 15 basins (3 cell x 5 series)	100m x 33m x 3.0mD x 9,900m ³ x 18 basins (3 cell x 6 Series)
- Detention Time	t*c= 2.1 days	t*c= 2.0 days	t*p= 2.1 days
- Aerator-II	5.5 kW x 18 sets (Total 99 kW)	5.5 kW x 30 sets (Total 165 kW)	5.5 kW x 36 sets (Total 198 kW)
3. Chlorinator			
- Feeding rate	3.0 mg/l	3.0 mg/l	3.0 mg/l
- Chlorinator	10 kg-cl/hr x 2 sets (1 set-standby)	10 kg-cl/hr x 2 sets (1 set-standby)	15 kg-cl/hr x 2 sets (1 set-standby)

(3) Waste Stabilization Pond in Proposed Site (e) and (f)
(San Bartolo)

a. Planned Treated Water Quality

BOD₅ removal rate : 80 %
Effluent BOD₅ : Approx. 49 mg/l

b. Flow Chart




FIGURE 7-24 Flow Diagram for Stabilization Pond System

c. Outline of Waste Stabilization Pond System on Proposed Site (e) and (f)

Outline of facility for each design sewage flow is shown in TABLE 7-10.

TABLE 7-10 Outline of Waste Stabilization Pond System on Proposed Site (e) and (f)

Design Flow	Q (m ³ /S)	0.5	1.5	1.67	2.0	2.17	2.5	2.67	3.0	3.5
Primary Facultative Pond	Lil (kg-BOD/day)	10,800	32,400	36,072	43,200	46,872	54,000	57,672	64,800	75,600
	Ap (ha)	28.3	84.8	94.4	113.1	122.7	141.4	151.0	169.6	197.9
	Dp (m)	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
	Vp (m ³)	424,500	1,272,000	1,416,000	1,697,000	1,840,500	2,121,000	2,265,000	2,544,000	2,969,000
	t* _p (days)	9.8	9.8	9.8	9.8	9.8	9.8	9.8	9.8	9.8
Secondary Facultative Pond	As (ha)	16.2	48.6	54.1	64.8	70.3	81.0	86.5	97.2	113.4
	Ds (m)	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
	Vs (m ³)	243,000	729,000	811,500	972,000	1,054,500	1,215,000	1,298,000	1,458,000	1,701,000
	t* _s (days)	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6	5.6
Total Mid-Depth Water Surface Area: Ap + As (ha)		44.5	133.4	148.5	177.9	193.0	222.4	237.5	266.8	311.3
Total Detention Time: t* _p + t* _s (days)		15.4	15.4	15.4	15.4	15.4	15.4	15.4	15.4	15.4

7.6 Evaluation of Alternatives

7.6.1 Construction Cost

Estimated construction costs of each alternative are summarized in TABLES 7-11 and 7-12. For the estimation of construction cost, 30 % of direct construction cost were added as overhead expenses of treatment method (for details refer to APPENDIX 21).

Construction costs per cubic meter of sewage required for Phase I project of each alternative are summarized in TABLE 7-13.

TABLE 7-13 COMPARISON OF CONSTRUCTION COST

PLAN		CONSTRUCTION COST C (1,000US\$)	UNIT COST C/Q (US\$/m ³)	RATIO (%)	RANKING	REMARKS
A	A1	88,971	257	100	2	***
	A2	111,537	323	125	10	*
	A3	103,447	299	116	7	*
B	B1	77,704	225	87	1	***
	B2	97,314	282	109	5	**
	B3	94,780	274	107	3	***
C	C1	124,770	361	140	14	*
	C2	122,442	354	138	12	*
	C3	105,739	306	119	8	*
	C3'	122,539	355	138	12	*
D	D1	118,832	344	134	11	*
	D2	108,077	313	121	9	*
E	E1	98,301	284	110	6	**
	E2	95,905	278	108	4	**

NOTE:

- 1) Ratios are shown in comparison to the C/Q of plan A1 as 100%.
- 2) *** Superior, ** Intermediate, * Inferior
- 3) Q: 4 m³/s x 86,400 s/day = 345,600 m³/day

As a result, plans B1, A1 and B3 are judged as superior, with plans E2, B2 and E1 next to them.

TABLE 7-11 CONSTRUCTION COST (PHASE I)

Unit: US\$ 1,000, ¥1,000,000

Plan	Q'TY m ³ /s	Direct Cost							Indirect Cost			Total		
		Intake Facility	Pumping Facility		Con- duit	Treatment Facility		Sub- total	Over- head	Others ³	Sub- total	US \$	¥ (EQUIVA- LENT)	
			C & A ¹	Equip ²		C & A ¹	Equip ²							
A	A ₁	4.0	477	5,629	10,510	39,647	10,308	4,831	71,402	17,508	61	17,569	88,971	12,455
	A ₂	2.0	283	4,051	7,564	23,877	5,759	4,831	46,365	10,748	61	10,809	57,174	8,004
	A ₃	1.0	184	—	—	12,604	3,170	4,831	20,789	5,004	61	5,065	25,854	3,619
B	B ₁	4.0	477	—	—	45,035	10,308	4,831	60,651	16,963	90	17,053	77,704	10,878
	B ₂	2.0	283	—	—	27,113	5,759	4,831	37,986	10,163	90	10,253	48,239	6,753
	B ₃	1.0	184	—	—	15,513	3,170	4,831	23,698	5,877	90	5,967	29,665	4,153
C	C ₁	2.33	354	3,178	5,934	28,203	3,861	26,162	67,692	12,122	249	12,371	80,063	11,208
	C ₂	1.83	304	2,100	3,920	27,722	2,849	20,670	57,565	10,998	249	11,247	68,812	9,633
	C ₃	0.83	163	—	—	16,552	1,292	9,489	27,496	5,829	59	5,888	33,384	4,673
D	C ₃ '	1.0	184	—	—	23,090	1,557	11,180	36,011	7,952	65	8,017	44,028	6,163
	D ₁	1.5	191	3,178	5,934	23,682	2,569	16,673	52,227	9,903	191	10,094	62,321	8,724
	D ₂	1.0	141	2,100	3,920	16,914	1,557	11,180	35,812	6,892	191	7,083	42,895	6,005
E	E ₁	2.0	283	—	—	27,201	5,494	4,831	37,809	11,338	61	11,399	49,208	6,889
	E ₂	1.0	141	—	—	16,403	3,320	—	19,864	5,959	—	5,959	25,823	3,615

* 1 C & A: Construction Cost for Civil and Architectural Works.

* 2 Equip: Cost for Mechanical and Electrical Equipment.

* 3 Others: Cost for Plantation.

* 4 The Base Date of Cost Estimates is October 26, 1989.

* 5 Exchange Rate: 1/ 6,050.75 = US\$ 1.00, US\$ 1.00 = ¥ 140

TABLE 7-12 CONSTRUCTION COST (PHASE II)

Unit: US\$1,000, ¥1,000,000

Plan	Q'TY m ³ /s	Direct Cost						Indirect Cost			Total		Grand Total (I + II)		
		Intake Faci- lity	Pumping Facility		Con- duit	Treatment Facility		Sub- total	Over- head	Others ³	Sub- total	US \$	¥ (Equiva- lent)	US \$	¥ (Equiva- lent)
			C & A'	Equip ²		C & A'	Equip ²								
A ₁	—	—	—	—	—	—	—	—	—	—	—	—	88,971	12,455	
A ₂	2.0	283	3,366	6,283	27,143	5,976	—	43,051	11,312	—	11,312	54,363	7,610	111,537	15,614
A ₃	3.0	255	6,133	11,449	36,128	7,968	—	61,933	15,660	—	15,660	77,593	10,863	103,447	14,482
B ₁	—	—	—	—	—	—	—	—	—	—	—	—	—	77,704	10,878
B ₂	2.0	226	—	—	31,548	5,976	—	37,750	11,325	—	11,325	49,075	6,870	97,314	13,623
B ₃	3.0	255	—	—	41,866	7,968	—	50,089	15,026	—	15,026	65,115	9,116	94,780	13,269
C ₁	1.67	212	—	—	28,900	5,278	—	34,390	10,317	—	10,317	44,707	6,258	124,770	17,466
C ₂	2.17	246	—	—	34,534	6,474	—	41,254	12,376	—	12,376	53,630	7,508	122,442	17,141
C ₃	3.17	269	—	—	42,889	8,548	4,831	56,537	15,728	90	15,818	72,355	10,129	105,739	14,802
C _{3'}	3.0	255	—	—	48,103	8,083	4,831	61,272	17,149	90	17,239	78,511	10,991	122,539	17,154
D ₁	2.5	248	—	—	36,151	7,071	—	43,470	13,041	—	13,041	56,511	7,911	118,832	16,635
D ₂	3.0	255	—	—	41,917	7,968	—	50,140	15,042	—	15,042	65,182	9,125	108,077	15,130
E ₁	2.0	226	—	—	31,563	5,976	—	37,765	11,328	—	11,328	49,093	6,873	98,301	13,762
E ₂	3.0	255	—	—	41,619	8,083	4,831	54,788	15,204	90	15,294	70,082	9,811	95,905	13,427

* 1 C & A: Construction Cost for Civil and Architectural Works

* 2 Equip: Cost for Mechanical and Electrical Equipment.

* 3 Others: Cost for Plantation.

* 4 The Base Date of Cost Estimates is October 26, 1989.

* 5 Exchange Rate: 1/ 6,050.75 = US\$ 1.00, US\$ 1.00 = ¥ 140

7.6.2 Operation and Maintenance Cost

The operation and maintenance costs of each alternative are summarized in TABLE 7-14.

Bases of estimation are also presented in TABLES 7-15 to 7-21.

O&M costs per cubic meter of sewage required for facilities in Phase I of each alternative are shown in TABLE 7-22.

TABLE 7-22 COMPARISON OF O&M COST

PLAN	O&M COST Cm (US\$/year)	UNIT COST Cm/Q (10 ⁻³ US\$/m ³)	RATIO (%)	RANKING	REMARKS	
A	A1	562,250	4.46	100	11	*
	A2	594,115	4.71	106	12	*
	A3	616,752	4.89	110	14	*
B	B1	140,345	1.11	25	1	***
	B2	155,669	1.23	28	3	**
	B3	144,477	1.15	26	2	***
C	C1	598,050	4.74	106	13	*
	C2	437,063	3.46	78	9	*
	C3	293,577	2.33	52	7	*
	C3'	326,781	2.59	58	8	*
D	D1	446,782	3.54	79	10	*
	D2	282,520	2.24	50	6	*
E	E1	154,185	1.22	27	3	**
	E2	152,923	1.21	27	3	**

NOTE:

- 1) O&M cost is estimated for direct cost only.
- 2) Ratios are shown in comparison to the Cm/Q of plan A1 as 100%.
- 3) Q: 4m³/s x 86,400 s/day x 365 days/year = 126,144,000 m³/year

Therefore, plans B1 and B3 are judged to be superior, with plans B2, E1 and E2 next to them.

TABLE 7-14 OPERATION & MAINTENANCE COST

Unit: US \$ / year

Plan	P H A S E I										P H A S E II						Total		Remarks			
	Q'ty m ³ /s	Conduit			Pumping Facility			Treatment Facility			Q'ty m ³ /s	Sub- total	Conduit Labor	Pumping Facility		Treatment Facility		Sub- total		US \$ /Year	1,000 \$/year (Equiv.)	
		Labor	Power	Chemicals	Labor	Power	Chemicals	Labor	Power	Chemicals				Labor	Power	Chemicals						
																	Labor					Power
A ₁	4.0	3,084	410,625	48,048	89,261	(179,124)	89,261	89,261	(89,562)	89,261	89,261	(89,562)	89,261	181,989	29,952	—	—	—	—	562,250	78,715	
A ₂	2.0	2,048	240,024	32,572	89,261	(89,562)	89,261	89,261	(89,562)	89,261	89,261	(89,562)	89,261	181,989	29,952	—	—	—	—	594,115	83,176	
A ₃	1.0	1,368	—	—	18,096	(44,781)	89,261	89,261	(44,781)	89,261	89,261	(44,781)	89,261	460,995	33,696	—	—	—	—	616,752	86,345	
B ₁	4.0	3,036	—	—	48,048	(179,124)	89,261	89,261	(179,124)	89,261	89,261	(179,124)	89,261	—	—	—	—	—	—	140,345	19,648	
B ₂	2.0	2,000	—	—	32,572	(89,562)	89,261	89,261	(89,562)	89,261	89,261	(89,562)	89,261	—	29,952	—	—	—	—	155,669	21,793	
B ₃	1.0	1,320	—	—	18,096	(44,781)	89,261	89,261	(44,781)	89,261	89,261	(44,781)	89,261	—	33,696	—	—	—	—	144,477	20,225	
C ₁	2.33	2,244	88,038	6,240	445,802	(115,759) ^{*2}	445,802	445,802	(115,759)	445,802	445,802	(115,759)	445,802	—	26,582	—	—	—	—	598,050	83,727	
C ₂	1.83	1,972	49,494	3,744	327,022	(81,949)	327,022	327,022	(81,949)	327,022	327,022	(81,949)	327,022	—	30,451	—	—	—	—	437,063	61,188	
C ₃	0.83	1,188	—	—	13,728	(47,168)	148,500	148,500	(47,168)	148,500	148,500	(47,168)	148,500	—	38,688	89,261	89,261	89,261	89,261	293,577	41,100	
C _{3'}	1.0	1,464	—	—	13,728	(44,781)	178,522	178,522	(44,781)	178,522	178,522	(44,781)	178,522	—	41,558	89,261	89,261	89,261	89,261	326,781	45,749	
D ₁	1.5	1,612	88,038	6,240	18,720	(78,591) ^{*2}	297,302	297,302	(78,591)	297,302	297,302	(78,591)	297,302	—	32,822	—	—	—	—	446,782	62,549	
D ₂	1.0	1,232	49,494	3,744	13,728	(44,781)	178,522	178,522	(44,781)	178,522	178,522	(44,781)	178,522	—	33,696	—	—	—	—	282,520	39,532	
E ₁	2.0	1,888	—	—	31,200	(89,562)	89,261	89,261	(89,562)	89,261	89,261	(89,562)	89,261	—	29,952	—	—	—	—	154,185	21,585	
E ₂	1.0	1,286	—	—	18,720	(44,781)	—	—	(44,781)	—	—	(44,781)	—	—	41,558	89,261	89,261	89,261	89,261	152,923	21,409	

Note : * 1 Cost for Chemicals (for Chlorine) is not included.
 * 2 For total sewage amount of (a) San Juan S.T.P. (Q = 0.75m³/s)
 * 3 Exchange Rate : 1/ 6,050.75 = US\$ 1.00, US\$ 1.00 = ₱ 140

TABLE 7-15 OPERATION & MAINTENANCE COST FOR TRANSMISSION LINE
(LABOR COST FOR PHASE I)

Plan	① Intake Facility (persons/year)	② Gravity Flow Section (persons/year)	③ Inverted Siphon Section (persons/year)	Total			Remarks
				No. (persons)	Unit Cost US\$/person	Amount US\$/year	
A	A ₁ $(2.6 \text{ m}^3/\text{s} \times 0.74 + 0.9 \times 1.0 + 0.5 \times 1.3) \times 72 \text{ p/m} = 243$	$(4.0 \text{ m}^3/\text{s} \times 0.6) \times 200 = 480$	span p/span $4 \times 12 = 48$	771	4	3,084	
	A ₂ $(1.5 \times 0.9 + 0.5 \times 1.3) \times 72 = 144$	$(2.0 \times 0.8) \times 200 = 320$	$4 \times 12 = 48$	512	4	2,048	
	A ₃ $(0.5 \times 1.3 \times 2) \times 72 = 94$	$(1.0 \times 1.0) \times 200 = 200$	$4 \times 12 = 48$	342	4	1,368	
B	B ₁ $(2.6 \times 0.7 + 0.9 \times 1.0 + 0.5 \times 1.3) \times 72 = 243$	$(4.0 \times 0.6) \times 200 = 480$	$3 \times 12 = 36$	759	4	3,036	
	B ₂ $(1.5 \times 0.9 + 0.5 \times 1.3) \times 72 = 144$	$(2.0 \times 0.8) \times 200 = 320$	$3 \times 12 = 36$	500	4	2,000	
	B ₃ $(0.5 \times 1.3 \times 2) \times 72 = 94$	$(1.0 \times 1.0) \times 200 = 200$	$3 \times 12 = 36$	330	4	1,320	
C	C ₁ $(1.5 \times 0.9 + 0.5 \times 1.3 + 0.33 \times 1.3) \times 72 = 175$	$(2.33 \times 0.75) \times 200 = 350$	$3 \times 12 = 36$	561	4	2,244	
	C ₂ $(1.0 \times 1.0 + 0.5 \times 1.3 + 0.33 \times 1.3) \times 72 = 150$	$(1.83 \times 0.84) \times 200 = 307$	$3 \times 12 = 36$	493	4	1,972	
	C ₃ $(0.5 \times 1.3 + 0.33 \times 1.3) \times 72 = 78$	$(0.83 \times 1.1) \times 200 = 183$	$3 \times 12 = 36$	297	4	1,188	
D	C ₄ $(0.5 \times 1.3 + 0.17 \times 1.3 + 0.33 \times 1.3) \times 72 = 94$	$(1.0 \times 1.0) \times 200 = 200$	$6 \times 12 = 72$	366	4	1,464	
	D ₁ $(1.5 \times 0.9) \times 72 = 97$	$(1.5 \times 0.9) \times 200 = 270$	$3 \times 12 = 36$	403	4	1,612	
	D ₂ $(1.0 \times 1.0) \times 72 = 72$	$(1.0 \times 1.0) \times 200 = 200$	$3 \times 12 = 36$	308	4	1,232	
E	E ₁ $(1.0 \times 1.0 \times 2) \times 72 = 144$	$(2.0 \times 0.7) \times 200 = 280$	$4 \times 12 = 48$	472	4	1,888	
	E ₂ $(1.0 \times 1.0) \times 72 = 72$	$(1.0 \times 1.0) \times 200 = 200$	$4 \times 12 = 48$	320	4	1,280	

③ Inverted Siphon
Necessary working days per span : 3 days
No. of laborers per team : 4
Required No. of laborers per span is:
 $3 \times 4 = 12$ persons/span

② Gravity Flow Section
Assumption : Length: 15km, Manhole span: 100m,
No. of Manholes: 150,
Cleaning Frequency: every 3 years
No. of spans to be cleaned per year : $150 \div 3 = 50$ span/year
Required day for cleaning : 1 day/span.
No. of laborers per span : 4 persons/span
Annual labor requirement : 4 person · day/span x 50 span/year
x 1 day = 200 persons · day/year

① Intake Facility
Number of persons required for Intake facility per m^3/s is:
4 persons / facility x 3 days
x 6 times/year = 72 persons / m^3/s
In accordance with the scale of facility, following adjusting factors P are multiplied.
3 m^3/s P = 0.6
2 " P = 0.8
1 " P = 1.0

TABLE 7-16 OPERATION & MAINTENANCE COST FOR TRANSMISSION LINE
(LABOR COST FOR PHASE II)

Plan	① Intake Facility (persons / year)	② Gravity Flow Section (persons / year)	③ Inverted Siphon Section (persons / year)	Total		Remarks	
				No. (persons)	Unit Cost US\$/person		
A	A ₁						
	A ₂	$(1.1 \text{ m}^3/\text{s} \times 1.0 + 0.9 \times 1.0) \times 72 \text{ persons/m}^3/\text{s} = 144$	$2.0 \times 0.8 \times 200 = 320$	$\frac{\text{m}^3/\text{s}}{4 \times 12} = 48$	512	4	2,048
	A ₃	$(3.0 \times 0.6) \times 72 = 130$	$(3.0 \times 0.6) \times 200 = 360$	$3 \times 12 = 36$	526	4	2,104
B	B ₁						
	B ₂	$(2.0 \times 0.8) \times 72 = 115$	$(2.0 \times 0.8) \times 200 = 320$	$3 \times 12 = 36$	471	4	1,884
	B ₃	$(3.0 \times 0.6) \times 72 = 130$	$(3.0 \times 0.6) \times 200 = 360$	$3 \times 12 = 36$	526	4	2,104
C	C ₁	$(1.67 \times 0.85) \times 72 = 102$	$(1.67 \times 0.85) \times 200 = 284$	$3 \times 12 = 36$	422	4	1,688
	C ₂	$(2.17 \times 0.75) \times 72 = 117$	$(2.17 \times 0.75) \times 200 = 326$	$3 \times 12 = 36$	479	4	1,916
	C ₃	$(3.17 \times 0.6) \times 72 = 137$	$(3.17 \times 0.6) \times 200 = 380$	$3 \times 12 = 36$	553	4	2,212
D	C ₃ '	$(3.0 \times 0.6) \times 72 = 130$	$(3.0 \times 0.6) \times 200 = 360$	$6 \times 12 = 72$	562	4	2,248
	D ₁	$(2.5 \times 0.7) \times 72 = 126$	$(2.5 \times 0.7) \times 200 = 350$	$3 \times 12 = 36$	512	4	2,048
	D ₂	$(3.0 \times 0.6) \times 72 = 130$	$(3.0 \times 0.6) \times 200 = 360$	$3 \times 12 = 36$	526	4	2,104
E	E ₁	$(2.0 \times 0.8) \times 72 = 115$	$(2.0 \times 0.8) \times 200 = 320$	$3 \times 12 = 36$	471	4	1,884
	E ₂	$(3.0 \times 0.6) \times 72 = 130$	$(3.0 \times 0.6) \times 200 = 360$	$3 \times 12 = 36$	526	4	2,104

① Intake Facility
Number of persons required for Intake facility per 1m³/s is:
4 persons/facility × 3 days × 5 times/year = 72 persons/m³/s
In accordance with the scale of facility, following adjusting factors P are multiplied.
3 m/s P = 0.6
2 " P = 0.8
1 " P = 1.0
0.5 " P = 1.9

② Gravity Flow Section
Assumption : Length: 150m, Manhole span: 100m,
No. of Manholes: 150,
Cleaning Frequency: every 3 years
No. of Spans to be cleaned per year : $150 \div 3 = 50$ span/year
Required day for cleaning : 1 day per span.
No. of Laborers per span : 4 persons/span × 50 span/year
Annual labor requirement : 4 persons/span × 50 span/year × 1 day = 200 persons/year

③ Inverted Siphon
Necessary working days per span : 3 days
No. of laborers per team : 4
Required No. of laborers per span is:
 $3 \times 4 = 12$ persons/span

TABLE 7-17 OPERATION & MAINTENANCE COST FOR PUMPING STATION
(LABOR COST)

Plan	PHASE I				PHASE II				REMARKS
	Number of Persons *1	Operation Days *2	Unit Cost	Amount	Number of Persons *1	Operation Days *2	Unit Cost	Amount	
A ₁	m ³ /s 2.6 × 0.7 × 5 = 9 persons	312	US\$/person 4 /day	US\$/year 11,232	persons	day/year	US\$/person	US\$/year	
A	A ₂ : 1.5 × 0.9 × 5 = 7	312	4	8,736	1.1 × 1.0 × 5 = 6	312	4	7,485	
	A ₃ : _____	—	—	—	3.0 × 0.6 × 5 = 9	312	4	11,232	
B	B ₁ : _____	—	—	—	—	—	—	—	
	B ₂ : _____	—	—	—	—	—	—	—	
	B ₃ : _____	—	—	—	—	—	—	—	
C	C ₁ : 1.0 × 1.0 × 5 = 5	312	4	6,240	—	—	—	—	
	C ₂ : 0.5 × 1.3 × 5 = 3	312	4	3,744	—	—	—	—	
	C ₃ : _____	—	—	—	—	—	—	—	
	C ₃ ' : _____	—	—	—	—	—	—	—	
D	D ₁ : 1.0 × 1.0 × 5 = 5	312	4	6,240	—	—	—	—	
	D ₂ : 0.5 × 1.3 × 5 = 3	312	4	3,744	—	—	—	—	
E	E ₁ : _____	—	—	—	—	—	—	—	
	E ₂ : _____	—	—	—	—	—	—	—	

Note : * 1 Number of Persons per 1m³/s
Labor 3 + Elec. Tech. 1 + Mech. Tech. 1 = 5 persons/m³/s
* 2 Operation Days
6 day/week × 52 week/year = 312 day/year

TABLE 7-18 OPERATION & MAINTENANCE COST FOR TREATMENT FACILITY (LABOR COST)

Plan	PHASE I					PHASE II					Remarks
	No. of Persons		Operation Days	Unit Cost	Amount	No. of Persons		Operation Days	Unit Cost	Amount	
A	c ($0.5 \frac{m^2}{s}$)	$(3.5 \times 0.6) \times 15$	Total 38.5	$\frac{\$}{person}$ 4	$\frac{\$}{year}$ 48,048	persons	312	$\frac{\$}{person}$	$\frac{\$}{year}$		
	A ₁	$(1.5 \times 0.85) \times 15$	26.1	4	32,572	$(2.0 \times 0.8) \times 15 = 24.0$	312	4	28,952		
	A ₂	$(0.5 \times 1.0) \times 15$	14.5	4	18,096	$(3.0 \times 0.6) \times 15 = 27.0$	312	4	33,696		
B	b ($0.5 \frac{m^2}{s}$)	$(3.5 \times 0.6) \times 15$	38.5	4	48,048						
	B ₁	$(1.5 \times 0.85) \times 15$	26.1	4	32,572	$(2.0 \times 0.8) \times 15 = 24.0$	312	4	29,952		
	B ₂	$(0.5 \times 1.0) \times 15$	14.5	4	18,096	$(3.0 \times 0.6) \times 15 = 27.0$	312	4	33,696		
C	a	b	c	Total							
	C ₁	2 2 6 1 -0	1 1 1 1 -0	2 2 6 1 -0	14 22	22	312	4	27,456	$(1.67 \times 0.85) \times 15 = 21.3$	
	C ₂	2 2 6 1	1 1 1 1	2 2 6 1	12 2	18	312	4	22,464	$(2.17 \times 0.75) \times 15 = 24.4$	
D											
	D ₁	2 2 6 1 -0	1 1 1 1 -0	2 2 6 1 -0	11 15	11	312	4	13,728	$(2.67 \times 0.6) \times 15 = 24.0$	
	D ₂	2 2 6 1	1 1 1 1	2 2 6 1	11	11	312	4	13,728	$(2.5 \times 0.7) \times 15 = 26.3$	
E	c ($0.5 \frac{m^2}{s}$)	$(1.5 \times 0.8) \times 15 = 18.0$	25	4	31,200	$(2.0 \times 0.8) \times 15 = 24.0$	312	4	23,952		
	E ₂	$(1.0 \times 1.0) \times 15 = 15.0$	7	4	18,720	$(2.5 \times 0.7) \times 15 = 26.3$	312	4	41,558		

Operation Days : 6 days/week X 52 week = 312 days/year

Stabilization Pond	Mechanical	Electrical	Civil	Water Quality	Total	Remarks
Aerated	2	2	6	1	11	per 1.0m ² /s
Lagoon	1	1	4	1	7	per 0.5m ² /s

TABLE 7-19 OPERATION & MAINTENANCE COST FOR PUMPING STATION
(POWER COST)

Plan	PHASE I					PHASE II					Remarks
	Daily Electricity Consumption			Operation Days	Unit Cost	Amount	Daily Electricity Consumption		Operation Days	Unit Cost	
	kW	pumps	hrs.	kWh/day	day/year	US\$/kWh	US\$/year	kWh/day	day/year	US\$/kWh	US\$/year
A ₁	375 × 5	× 24	=	45,000	365	0.025	410,625	—	—	—	—
A ₂	274 × 4	× 24	=	26,304	365	0.025	240,024	277 × 3 × 24 =	19,944	0.025	181,989
A ₃	—	—	—	—	—	—	—	421 × 5 × 24 =	50,520	0.025	460,995
B ₁	—	—	—	—	—	—	—	—	—	—	—
B ₂	—	—	—	—	—	—	—	—	—	—	—
B ₃	—	—	—	—	—	—	—	—	—	—	—
C ₁	134 × 3	× 24	=	9,648	365	0.025	88,038	—	—	—	—
C ₂	113 × 2	× 24	=	5,424	365	0.025	49,494	—	—	—	—
C ₃	—	—	—	—	—	—	—	—	—	—	—
C ₃ '	—	—	—	—	—	—	—	—	—	—	—
D ₁	134 × 3	× 24	=	9,648	365	0.025	88,038	—	—	—	—
D ₂	113 × 2	× 24	=	5,424	365	0.025	49,494	—	—	—	—
E ₁	—	—	—	—	—	—	—	—	—	—	—
E ₂	—	—	—	—	—	—	—	—	—	—	—

TABLE 7-20 OPERATION & MAINTENANCE COST FOR TREATMENT FACILITY
(POWER COST)

Plan	PHASE I				PHASE II				REMARKS
	Daily Electricity Consumption	Operation Days	Unit Cost	Amount	Daily Electricity Consumption	Operation Days	Unit Cost	Amount	
A ₁	(d) 9,782	day/year 365	US\$/kWh 0.025	US\$/year 89,261	kWh/day	day/year	US\$/kWh	US\$/year	
A ₂	(d) 9,782	365	0.025	89,261					
A ₃	(d) 9,782	365	0.025	89,261					
B ₁	(d) 9,782	365	0.025	89,261					
B ₂	(d) 9,782	365	0.025	89,261					
B ₃	(d) 9,782	365	0.025	89,261					
C ₁	(a) 13,017 (b) 19,564 (c) 16,274	48,855	0.025	445,802					
C ₂	(b) 19,564 (c) 16,274	35,838	0.025	327,022					
C ₃	(c) 16,274		0.025	148,500	(d) 9,782	365	0.025	89,261	
C ₃ '	(c) 19,564		0.025	178,522	(d) 9,782	365	0.025	89,261	
D ₁	(a) 13,017 (b) 19,564	32,581	0.025	297,302					
D ₂	(b) 19,564	19,564	0.025	178,522					
E ₁	(d) 9,782	365	0.025	89,261					
E ₂					(d) 9,782	365	0.025	89,261	

(a) 0.63m³/s (b) 1.0m³/s (c) 0.80m³/s (d) 0.5m³/s

TABLE 7-21 OPERATION & MAINTENANCE COST FOR TREATMENT FACILITY
(CHEMICALS COST *1)

Plan	PHASE I					PHASE II					REMARKS
	Daily Chlorine Consumption *2	Operation Days	Unit Cost	Amount	Daily Chlorine Consumption	Operation Days	Unit Cost	Amount			
A ₁	$4.0 \times 86,400 \times 2 \times 10^{-3} = 691.2 \text{ kg/day}$	365	US\$/kg 0.71	US\$/year 179,124	—	—	—	—			
A ₂	$2.0 \times 86,400 \times 2 \times 10^{-3} = 345.6$	365	0.71	89,562	$2.0 \times 86,400 \times 2 \times 10^{-3} = 345.6 \text{ kg/day}$	365	0.71	89,562			
A ₃	$1.0 \times 86,400 \times 2 \times 10^{-3} = 172.8$	365	0.71	44,781	$3.0 \times 86,400 \times 2 \times 10^{-3} = 518.4$	365	0.71	134,343			
B ₁	$4.0 \times 86,400 \times 2 \times 10^{-3} = 691.2$	365	0.71	179,124	—	—	—	—			
B ₂	$2.0 \times 86,400 \times 2 \times 10^{-3} = 345.6$	365	0.71	89,562	$2.0 \times 86,400 \times 2 \times 10^{-3} = 345.6$	365	0.71	89,562			
B ₃	$1.0 \times 86,400 \times 2 \times 10^{-3} = 172.8$	365	0.71	44,781	$3.0 \times 86,400 \times 2 \times 10^{-3} = 518.4$	365	0.71	134,343			
C ₁	$2.585 \times 86,400 \times 2 \times 10^{-3} = 446.7$	365	0.71	115,759	$1.67 \times 86,400 \times 2 \times 10^{-3} = 238.6$	365	0.71	74,784			
C ₂	$1.83 \times 86,400 \times 2 \times 10^{-3} = 316.2$	365	0.71	81,949	$2.17 \times 86,400 \times 2 \times 10^{-3} = 375.0$	365	0.71	97,175			
C ₃	$0.83 \times 86,400 \times 2 \times 10^{-3} = 143.4$	365	0.71	37,168	$2.67 \times 86,400 \times 2 \times 10^{-3} = 461.4$	365	0.71	119,566			
C _{3'}	$1.0 \times 86,400 \times 2 \times 10^{-3} = 172.8$	365	0.71	44,781	$3.0 \times 86,400 \times 2 \times 10^{-3} = 518.4$	365	0.71	134,343			
D ₁	$1.755 \times 86,400 \times 2 \times 10^{-3} = 303.3$	365	0.71	78,591	$2.5 \times 86,400 \times 2 \times 10^{-3} = 432$	365	0.71	111,953			
D ₂	$1.0 \times 86,400 \times 2 \times 10^{-3} = 172.8$	365	0.71	44,781	$3.0 \times 86,400 \times 2 \times 10^{-3} = 518.4$	365	0.71	134,343			
E ₁	$2.0 \times 86,400 \times 2 \times 10^{-3} = 345.6$	365	0.71	89,562	$2.0 \times 86,400 \times 2 \times 10^{-3} = 345.6$	365	0.71	89,562			
E ₂	$1.0 \times 86,400 \times 2 \times 10^{-3} = 172.8$	365	0.71	44,781	$3.0 \times 86,400 \times 2 \times 10^{-3} = 518.4$	365	0.71	134,343			

* NOTE : 1) Chemicals cost is estimated for liquid chlorine for disinfection.
2) Average dosage rate is assumed to be 2 ppm.
3) Sewage quantity includes total amount of San Juan STP.

7.6.3 Technical Evaluation

(1) Alternative A (Pumping and Gravity Flow)

The disadvantages of this alternative are presented as follows:

Pump capacity required at Point B is $Q=2.6 \sim 1.1 \text{ m}^3/\text{s}$ with $H=59\text{m}$. This requirement is categorized under a specification of special pumps for wastewater use with a high pump head. Maintenance cost will, therefore, increase because of the necessity of importing spare parts. Moreover, power cost will be US\$ 460 ~ 400 thousand, which additional financial burden SEDAPAL have to shoulder.

On the other hand under Plan B treated sewage is pumped from elevation $H=+50\text{m}$ to $H=+100\text{m}$. However, at elevation $H=+50\text{m}$ where sewage transmitted by gravity is treated, half of the treated volume of sewage is reused for irrigation. Therefore, capacity necessary to pump treated sewage up to $H=+100\text{m}$ is half that of Plan A. Correspondingly, the required cost for power consumption will also be half.

It may be concluded that Plan A is inferior to alternative B from the view point of economy and finance due to higher construction and maintenance cost for pumps.




FIGURE 7-25 COMPARISON OF PUMP FACILITY IN PLAN A AND PLAN B

Conclusion:

This plan is not recommendable for Phase I because of high O & M (Power cost and repair cost) and replacement cost.

(2) Alternative B (Gravity Flow)

This plan seems to be an optimum plan because the sewage can be transmitted by gravity flow without pumps. However, disadvantages of this plan are as follows:

- a) Possibility of passage through the site of the Pachacamac Ruins has not been confirmed by the time of detailed investigation of Ruins.
- b) Possibility of passage through the site of the Explosives Plant (Explosivos S.A.) in San Bartolo has not been confirmed. According to SEDAPAL, there are possibilities of getting approval after the discussion with the superior authority.
- c) Effect of accident

The planned inverted siphon will traverse an 8 km stretch of the Panamerican Highway. In case an accident occurs along that stretch, damage on the transportation system will be serious.

Conclusion:

It is hard to adopt this plan for Phase I because of the dim possibility of getting approval for passage through the Pachacamac ruins.

However, if a detailed investigation in the future, reveals the possibility of passing through the ruins, this may prove to be an optimum plan in accordance with a selected pipe material.

(3) Alternative C (Gravity Flow + Pumping)

In this plan, the surrounding area will be developed first and then the San Bartolo Area will be developed in the future. This phased development plan is a distinct feature of alternative C in contrast with alternatives A and B which give priority to development of San Bartolo.

The advantages of this plan are as follows:

- a) It will contribute to the accelerated installation of sewerage system and improvement of environmental conditions in the area from San Juan to Villa El Salvador.
- b) It will enable the supply of 0.5 m³/s of treated sewage to Villa El Salvador area where raw sewage is utilized for irrigation at present.
- c) Even though a small amount of fund is invested, remarkable benefits are expected.

On the other hand, disadvantages of this plan are as follows:

- a) Same as in the case of alternative A, due to usage of pumps.
- b) Same as in item c) of alternative B regarding inverted siphon.
- c) It is hard to carry out improvement work on the San Juan STP from an emotional point of view because the STP has been in operation for about 20 years and it has become a symbol of environmental improvement projects in Peru.

Conclusion:

Plans C₁ and C₂ are inadequate for phase I because a pumping facility is necessary and it gives the same disadvantages as alternative A has.

Plan C₃ is not recommendable for phase I because of the need for passage through the Pachacamac Ruins.

In plan C₃', however, transmission of the treated sewage to the destination by gravity without a pumping facility is possible because of the high potential of proposed STP at the site of c).

The alternative plan with a proposed STP at c) is also optimum even though the project area is limited to the Villa El Salvador.

(4) Alternative D (Gravity Flow + Pumping)

Project scale and content during Phase I is almost the same as that of plans C1 and C2. Therefore, advantages and disadvantages of Plan D are almost the same as that of those plans because of the need for passage through the Pachacamac Ruins and necessity of pumping facilities.

(5) Alternative E (Gravity Flow)

The sewage can be transmitted to the destination by gravity flow and inverted siphon without pumps.

In Phase I, 2.0 m³/s of sewage (plan E1) will be transmitted through the same route as that of alternative A. Adoption of inverted siphon cannot be avoided due to topographic constraints. However, in case of accident, damage will be less than that which may be incurred under alternative A.

(6) Conclusion of Technical Evaluation

Comparison of technical evaluation of each alternative is shown in TABLE 7-23. Based on this Table, alternative E is judged to be superior.

TABLE 7-23 COMPARISON OF TECHNICAL EVALUATION

PLAN	PHASE I PLANNED SEWAGE QUANTITY (m ³ /s)	TECHNICAL EVALUATION	REMARKS
A	A1	4.0	*
	A2	2.0	*
	A3	1.0	*
B	B1	4.0	*
	B2	2.0	*
	B3	1.0	*
C	C1	2.33	*
	C2	1.83	*
	C3	0.83	*
	C3'	1.0	*
D	D1	1.5	*
	D2	1.0	*
E	E1	2.0	***
	E2	1.0	***

Legend : *** Superior ** Intermediate * Inferior

Considerations on Inverted Siphon Structure:

To convey the sewage generated in southern part of Lima to San Bartolo along the shortest way, 9.8 km long inverted siphon crossing the Rio Lurin shall be constructed. However, both in Peru and Japan, there is a few cases of long-span inverted siphon for transmission of sewage. Although both countries have experiences of the installation of short-span inverted siphon, there is no case with such a long inverted siphon for sewage works. Thus, following matters shall be considered deliberately prior to implementation of the Project to secure the safety from technical viewpoint:

- a) Study on another route which does not need inverted siphon

In this Project, transmission line of recommended plan runs outside of explosives plant site (75 m far away from foundry of the site due to a restriction of the explosives plant). If the passing through the site become possible, safer gravity flow plan will be possible.

- b) Pipe materials for inverted siphon

Study on optimum pipe materials for inverted siphon against corrosion and leakage, and on joint method against leakage and joint separation, and the like, shall be conducted.

- c) Maintenance of inverted siphon

Study on effective maintenance and reliability in the long run operation of grit chamber at inlet of inverted siphon and of blow-off facility shall be conducted, for instance, on measures for blowing-off of sewage, and on possibility of removal of grit and deposit in the sewer.

- d) Putrefaction of sewage during passage through the inverted siphon

Putrefaction of sewage is expected during the long period flowing down under the anaerobic condition. Thus investigations and study on following matters shall be conducted:

- Influence to structure by hydrogen sulfide gas generating from sewage.
- Influence to treatment efficiency by putrefaction of organic matter.

7.6.4 Selection of Optimum Plans

Construction cost, O&M cost and technical evaluation of each alternative are summarized in TABLE 7-24.

TABLE 7-24 COMPARISON OF EVALUATION

PLAN	PHASE I PLANNED SEWAGE Q'TY (M ³ /S)	CONSTRUCTION COST	O&M COST	TECHNICAL EVALUATION	COMPREHENSIVE EVALUATION	
A	A1	4.0	***	*	*	
	A2	2.0	*	*	*	
	A3	1.0	**	*	*	
B	B1	4.0	***	***	*	
	B2	2.0	**	**	*	
	B3	1.0	***	***	*	
C	C1	2.33	*	*	*	
	C2	1.83	*	*	*	
	C3	0.83	*	*	*	
	C3'	1.0	*	*	*	
D	D1	1.5	*	*	*	
	D2	1.0	*	*	*	
E	E1	2.0	**	**	***	***
	E2	1.0	**	**	***	**

Legend : *** Superior ** Intermediate * Inferior

The following are concluded from TABLE 7-24:

- (1) The alternatives with pumping facilities are not recommendable because O & M costs (power + repair) and replacement cost of pumps (25 to 30 years) are expensive.

- (2) The alternatives in which the transmission line will pass through the Pachacamac Ruins is not recommendable for Phase I. However, there may be possibilities of passing through the ruins after detailed investigations. Therefore, based on the discussions in Subsection 7.6.4, plan E₁ is selected as an optimum plan for further study.

The planned route and longitudinal section of plan E₁ are presented in attached FIGURES 7-26 to 7-28 as a recommended plan.

CHAPTER 8

POLLUTION ANALYSIS FOR THE COAST OF CHIRA

CHAPTER 8 POLLUTION ANALYSIS FOR THE COAST OF CHIRA

8.1 Introduction

Sea water pollution along the coastal areas of Metropolitan Lima had become severe by 1980. In 1984, the Direction Tecnica de Salud Ambiental (Environmental Health Technical Dept., hereinafter referred to as DITESA), Ministerio de Salud (Ministry of Health), started a survey and research project on these pollution problems.

The said investigation was carried out to determine measures to be taken against pollution in order to preserve the environment of coastal areas to ensure their safety for public use. Activities of the project staff consisted of a biological and physical survey and research covering the entire stretch of the Metropolitan Lima coastal area. An attempt was later on made to estimate the present and predict the future pollution levels using a newly developed computer-aided simulation model.

In this particular Study, biological, chemical and physical survey and research were undertaken of the sea area along the coast affected by sewage discharge from the Colector Surco.

Simulation model analysis was conducted also with the use of the above-mentioned model developed by DITESA in 1984, based on the results of measurements done in this Study, for prediction of future pollution levels in areas utilized for swimming. Actual computation for the simulation was performed by DITESA.

8.2 Present Sea Water Pollution Condition

8.2.1 Bacteria

In order to understand the present condition of sea water quality, analyses especially on bacteriological items, like Total Coliform, Fecal Coliform and Salmonella were conducted by SEDAPAL several times during the Study period at designated sampling stations shown in FIGURE 8-1. Results of analyses are summarized in TABLE 8-1 (refer to APPENDIX 22 for detail).




FIGURE 8-1 Location of Sampling Points

TABLE 8-1 Quality of Sea Water

Analysed Items, Date (1989)	Sampling Point No.																		
	1	1'	1A	1B	1C	2-0m	2-3m	2-5m	2a	3	4	5	6	7	8	9	10		
Total Coliform																			
5/15	—	—	—	—	—	7.5x10 ⁷	—	—	1.5x10 ³	—	—	2.1x10 ⁴	<1	—	—	—	2.1x10 ²	—	
5/23	—	—	—	—	—	1.1x10 ⁷	1.5x10 ⁵	<2.4x10 ³	—	—	—	7 x10	2.3x10	—	—	—	—	9	
5/29	—	4.3x10	—	—	—	2.4x10 ⁷	—	—	2.4x10 ⁷	2.4x10 ⁵	<2.4x10 ³	2.4x10 ⁴	2.3x10	>2.4x10 ³	4 x10	2.4x10 ²	>2.4x10 ²	9	15
6/5	3.9x10	—	—	—	—	2.4x10 ⁷	—	—	—	2.4x10 ⁵	4	2.4x10 ⁴	2.4x10 ²	4 x10	2.4x10 ²	2.4x10 ²	4.3x10	4.3x10	
6/12	—	—	—	—	—	1.1x10 ⁷	—	—	—	9.3x10 ⁵	1.5x10	2.4x10 ³	2.3x10	4 x10	7	—	—	2.3x10 ²	
10/16	—	—	—	—	—	2.3x10 ⁶	—	—	—	1.1x10 ⁶	1.1x10 ⁴	>2.4x10 ⁴	4.6x10 ²	4.6x10 ²	4.3x10	9	—	2.4x10	
10/23	—	—	—	—	—	9.3x10 ⁶	—	—	—	4 x10 ⁴	4 x10 ²	2.3x10 ⁴	1.1x10 ³	1.1x10 ³	1.1x10 ³	2.4x10 ²	2.4x10 ²	2.3x10	
10/30	—	—	4.6x10 ⁴	4	<1	4.3x10 ⁶	—	—	—	4 x10 ²	—	9.3x10 ³	4.6x10 ²	7.5x10	1.1x10 ⁴	—	—	—	
Fecal Coliform																			
5/23	—	—	—	—	—	4.6x10 ⁶	1.2x10 ⁵	<2.4x10 ²	—	—	—	7 x10	2.3x10	—	—	—	—	9	
5/29	—	2.3x10	—	—	—	1.1x10 ⁷	—	—	—	—	4.6x10 ⁵	<2.4x10 ³	<1	>2.4x10 ²	>2.4x10 ²	4	—	9	
6/5	2.3x10	—	—	—	—	2.4x10 ⁶	—	—	—	—	2.4x10 ⁵	4	4.6x10 ³	<1	4 x10	2.4x10 ²	2.4x10 ²	9	
6/12	—	—	—	—	—	2.4x10 ⁶	—	—	—	—	2.4x10 ⁴	4	2.4x10 ²	<1	4 x10	4	—	2.3x10	
10/16	—	—	—	—	—	2.3x10 ⁶	—	—	—	—	1.5x10 ⁵	1.1x10 ⁴	2.4x10 ²	4.6x10 ²	4.6x10 ²	4.3x10	<1	4	
10/23	—	—	—	—	—	4.3x10 ⁶	—	—	—	—	4 x10 ⁴	4 x10 ²	4.6x10 ²	1.1x10 ²	1.1x10 ²	4.3x10	4.3x10	<1	
10/30	—	—	4.6x10 ⁴	<1	<1	9 x10 ⁵	—	—	—	—	4 x10 ²	—	9.3x10 ³	4.6x10 ²	2.3x10	9.3x10 ²	—	—	
Salmonella Bacteria																			
6/12	—	—	—	—	—	2.4x10 ²	—	—	—	—	—	<1	—	—	—	—	—	—	
10/16	—	—	—	—	—	9.3	—	—	—	—	—	—	—	—	—	—	—	—	
10/30	—	—	2.1	<1	<1	—	—	—	—	—	—	—	—	—	—	—	—	—	

The concentration of coliform bacteria in the sea water varies widely with the location of sampling point and date of sampling. From the results of the analyses, it can be inferred that the sea water quality at Point Nos. 1A, 2, and 3 were seriously affected by the raw sewage discharged from the Surco Outfall, the Fecal Coliform level being measured at 10^7 to 10^5 MPN/100ml, which far exceeds the water quality standard. Point Nos. 4, 5, 7 and 8 also showed a rather high Fecal Coliform concentration of 10^4 to 10^2 MPN/100ml. On the other hand, at Point Nos. 2 and 9 the high Fecal Coliform concentration occurred occasionally. Traces of raw sewage discharge are very minimal at Point Nos. 1, 1', 1B, 1C and 10. Salmonella bacteria were also found at Point Nos. 1A, 2 and 3, where many commercial fishing boats gather and catch fish.

Although these analyses were conducted only during the winter season, it is inferred from the findings and observations that the raw sewage discharged from the Surco Outfall flows westward for some distance offshore then changes direction with the north treading sea current. It may therefore be, inferred that the coastal area south of the Surco Outfall is not affected by pollution caused by its raw sewage discharge.

In addition to the analyses by the Study team, CEPIS conducted a series of sea water quality analysis on Total and Fecal Coliform for 27 weeks from October 1986 to April 1987 (refer to APPENDIX 22). In the survey, sea water sampling was carried out once a week at 22 sites along the coast of Lima extending from south to north along the Pacific Ocean. Based on the results of that survey, the fecal coliform concentrations measured at sites near the sampling points of the JICA Study often exceed the desirable water quality standard. The survey was conducted in summer, during which period many people swim and surf in the vicinity of these points. Thus, the survey implies that measure against water pollution along these areas must be taken as soon as possible.

8.2.2 Heavy Metals

Concentrations of heavy metals, like Hg, Cu and Cd, in shell fish collected at Agua Dulce beach has been analyzed from 1985 to 1988 by engineers of UNEP in cooperation with CEPIS (refer to FIGURE 8-2).

Based on the results of this survey, mercury (Hg) and copper (Cu) levels were very much lower than the permissible limits of 500 µg/kg and 100 mg/kg, respectively.

Cadmium (Cd) content, however, was much higher than the limit of 0.05 mg/kg, and it is possible that the sewage from the Colector Surco including industrial wastewater influenced this high concentration.

On the other hand, copper and cadmium concentrations in the sea water around Callao Port were measured from 1974 to 1986 by IMARPE. Resulting values were 9.7 - 26.7 µg/l for copper and 1.58 - 51 µg/l for cadmium.

From the above data, it is apparent that heavy metals are observed in great concentrations by organisms from the surrounding water, although the sampling dates and locations were not exactly same.

It is necessary, therefore, that heavy metals originating from sewage including industrial wastewater be pressed down as low as possible. Decrease to some extent of heavy metal concentrations in sea organisms is expected even with a small reduction of the volume of sewage discharge from Colector Surco.




FIGURE 8-2 Hg, Cu, and Cd in Shell Fish

8.3 Computer Simulation

8.3.1 Adopted Parameter

Fecal coliform bacteria was used as a parameter in the simulation model, because it is one of the major parameters of water quality standard in Peru, and is judged to be directly related to the water pollution caused by sewage.

8.3.2 Outline of the Simulation Model

Box Mixing Model developed by DITESA in 1984 was used for this simulation. Outline of this simulation model is as follows:

(1) Assumptions

- a) Parameter does not vary with time; only spatial distribution varies.
- b) Since there were no vertical differences in temperature (no thermocline), the bacteria are assumed to be distributed only in the X and Y directions (horizontal).
- c) The survey area was divided into 77 segments, with smaller segments set near the Surco Outfall.
- d) Balance formula of the flowing seawater volume
 - 1) Volume of flowing seawater is balanced.
 - 2) At the segment where the sewage from Colector Surco flows into, the total volume is calculated as the sum of the sewage volume and the volume of flowing seawater.

e) Balance of coliform number in the segments

1) $Q_i \times C_i$: Balance formula

Q_i : Volume of flowing seawater between the segments

C_i : Coliform number in each segment

2) Boundary condition of each segment


(i) (Discharge volume of sewage) x (Fecal coliform number) is used for the coliform value from Collector Surco.

(ii) In segments 73, 75, 76 and 77, which are located on the part of the survey area from where the seawater flow comes, coliform numbers are calculated.

(2) Balance Formula

a) Balance of the flowing seawater volume

Flowing water volume : Q_1, Q_2, Q_3



1: $Q_4 = Q_3$ 1)


2: $Q_3 + q = Q_2$... 2)

3: $Q_2 = Q_1$ 3)

q : drained volume of sewage

b) Balance of substances

Balance of the flowing seawater volume x coliform concentration



1: $Q_4 C_4 = Q_3 C_3$ 4)

2: $Q_3 C_3 + q C_o = Q_2 C_2$... 5)

3: $Q_2 C_2 = Q_1 C_1$ 6)

If the values of Q_4 , C_4 , q and C_0 are known, the values of C_1 to C_3 and Q_1 to Q_3 are decided from equations 1) to 6).

If decreasing rate of C is known as K (mortality rate), then:

- 4) is $Q_4 C_4 = Q_3 C_3 + K.C_3$ 4')
- 5) is $Q_3 C_3 + q.C_0 = Q_2 C_2 + K.C_2$... 5')
- 6) is $Q_2 C_2 = Q_1 C_1 + K.C_1$ 6')

Velocity of seawater in the survey area is set this time at 0.125 knot, which was used in the analysis in 1984 by DITESA based on actual measurement.

FIGURE 8-3 shows the balance of flowing seawater volume in each segment calculated by DITESA using the measured values in the area.

8.4 Computation Results

8.4.1 Data for Simulation

(1) Coliform

Coliform numbers in the sewage discharging from the Surco Outfall are measured at three main sewers, namely Colector Surco, Colector Circunvalacion, and Colector Balnearios del Sur. Measurements are done three times generally at a frequency of every 15 minutes for 24 hours (refer to APPENDIX 5). Sewage flow measurement was performed simultaneously as described in section 5.2.

Since the fecal coliform numbers at the three spots were different and varied with time, the average coliform concentration was computed with reference to the above-mentioned variation in coliform concentration and the sewage flow of each main sewer. Analyses results are summarized in TABLES 8-2 to 8-4.




FIGURE 8 - 3 BALANCE OF SEAWATER FLOW BY SEGMENTS

TABLE 8-2 Coliform Number and Sewage Flow (May 31 - June 1)

	Main Sewer	Surco	Circun.	B. Sur	Total
Sewage Flow (m ³ /sec)	Maximum	4.929	1.454	0.305	6.569
	Minimum	2.769	0.839	0.082	3.756
	Average	4.058	1.134	0.178	5.370
Fecal Coliform (MPN/100ml)	Maximum	4.6x10 ⁷	4.6x10 ⁷	2.4x10 ⁷	4.5x10 ⁷
	Minimum	2.4x10 ⁷	2.4x10 ⁷	2.4x10 ⁷	2.4x10 ⁷
	Average	3.7x10 ⁷	3.4x10 ⁷	2.4x10 ⁷	3.6x10 ⁷

TABLE 8-3 Coliform Number and Sewage Flow (June 19 - June 20)

	Main Sewer	Surco	Circun.	B. Sur	Total
Sewage Flow* (m ³ /sec)	Maximum	4.929	1.454	0.305	6.569
	Minimum	2.769	0.839	0.082	3.756
	Average	4.058	1.134	0.178	5.370
Fecal Coliform (MPN/100ml)	Maximum	1.1x10 ⁸	4.6x10 ⁷	1.1x10 ⁸	9.7x10 ⁷
	Minimum	4.3x10 ⁶	9.3x10 ⁶	2.4x10 ⁷	6.3x10 ⁶
	Average	4.5x10 ⁷	3.9x10 ⁷	5.1x10 ⁷	4.4x10 ⁷

*: Sewage flow measured on May 31 to June 1 was applied.

TABLE 8-4 Coliform Number and Sewage Flow (Oct. 19 - Oct. 20)

	Main Sewer	Surco	Circun.	B. Sur	Total
Sewage Flow (m ³ /sec)	Maximum	4.477	1.612	0.296	6.324
	Minimum	2.313	0.841	0.076	3.240
	Average	3.625	1.157	0.181	4.963
Fecal Coliform (MPN/100ml)	Maximum	2.4x10 ⁸	2.4x10 ⁸	4.3x10 ⁷	1.9x10 ⁸
	Minimum	9.0x10 ⁶	4.0x10 ⁶	4.0x10 ⁶	7.5x10 ⁶
	Average	7.5x10 ⁷	9.6x10 ⁷	3.2x10 ⁷	7.8x10 ⁷

Based on the above tables, the concentration of fecal coliform in the raw sewage varies between the levels of 10⁶ to 10⁸ MPN/100ml. One of the reasons for the high value in October is surmised to be due to the stoppage of clear water intrusion coming from the irrigation canal. For the simula-

tion, fecal coliform concentration was decided as the average value of three measurements as follows:

$$\begin{aligned} \text{Average fecal coliform concentration} &= (3.6+4.4+7.8) \times 10^7 \div 3 \\ &= \text{approx. } 5 \times 10^7 \text{ MPN/100ml} \end{aligned}$$

(2) Sewage Flow

The average sewage flow discharged from the Surco Outfall was set at 5.0 m³/sec for the simulation based on discussions in section 5.2.

8.4.2 Simulation Results

FIGURE 8-4 shows the simulation results as contour lines of 1,000 MPN/100ml of fecal coliform concentration for various volumes of sewage ranging from 2.5 to 6.5 m³/s with an interval of 0.5 m³/s.

Fecal coliforms of 5.0×10^7 MPN/100ml and velocity of 0.125 knot are used for these simulations.

Based on the computation results, contamination caused by the raw sewage discharge from Surco Outfall spreads northward, and the contour line which can be perceived as the boundary of area affected by pollution reaches up to the Club Regatas at present discharge condition.




FIGURE 8-4 SIMULATED CONTOUR LINE OF FECAL COLIFORMS (1,000 MPN/100ml)