

APPENDIX A-4-4

Questionnaire Survey for Factories

APPENDIX A-4-4 QUESTIONNAIRE SURVEY IN PATUM THANI AND
PRACHATIPAT (INDUSTRIAL)

1 Objective

The door-to-door questionnaire survey was conducted to obtain the basic information on the factories' production conditions, water use patterns, responses to the municipal system and/or their own water sources and willingness for house-connection supply, and covered the area served or unserved by the municipal water supply system aside from that for residents.

2 Survey Area

Four (4) areas were selected for the questionnaire survey taking into account the location of factories as shown in Figure A1-2-1. All areas are at present fully or partially served by the municipal system or by the private water supply system.

3 Survey Item

The form used for the questionnaire survey was originally written by Thai and included the following items.

1. General

- 1.1 Name of Company
- 1.2 Address
- 1.3 Type of Factory
- 1.4 Annual Production
- 1.5 No. of Present Employees
- 1.6 Area of Factory

2. Water Consumption by Usage

- 2.1 Washing
- 2.2 Cooling
- 2.3 Raw Materials
- 2.4 Boiling
- 2.5 Re-use
- 2.6 Others

3. Wastewater Treatment Facility

4. Type of Water Supply

5. Conditions in case of Municipal system

- 5.1 Pressure
- 5.2 Quantity

6. Other Sources than Municipal System
 - 6.1 Type of Source
 - 6.2 Conditions in case of Groundwater
7. Potability
8. Water Quality
 - 8.1 Municipal System (Color, Smell and Turbidity)
 - 8.2 Other Sources (Color, Smell and Turbidity)
9. Willingness to Connect to the Municipal System
10. Willingness to Pay for Connection Fee
11. Willingness to Pay for Water Charge

4 Survey Method

The college students were employed as interviewers and engaged in the questionnaire survey after the guidance by the PWA Head Office staff. The survey was conducted to 11, 9, 21 and 15 factories in Ban Klang, Lad Lum Kaeo, the Nava Nakorn Industrial Estate and the FAC-GO Industrial Estate, respectively on September 13, 14 and 17, 1988 under the superintendence of the PWA Head Office staff.

5 Survey Results

The results of the questionnaire survey are summarized in Table A1-5-3.

1) General

A various type of factories such as food processing, chemical products, metal fabrication, machinery, textiles, construction materials, wooden products and others were in operation in the particular areas.

The average number of employees per factory was 165 persons and almost factories in Lad Lum Kaeo and FAC-GO were small with less than 100 employees

Area Name	No. of Employees						Un- known	Total
	<50	>50 <100	>100 <200	>200 <500	>500 <1000	>1000		
Ban Klang	1	4	1	3	1	-	1	11
Lad Lum Kaeo	3	3	3	-	-	-	-	9
Nava Nakhorn	1	6	8	5	-	1	-	21
FAC-GO	10	3	-	-	-	-	2	15
Total	15	16	12	8	1	1	3	56

The average area of factory was approximately 112,100 sq m, however excluding four (4) factories with an area of more than 100,000 sq m, it was 13,700 sq m.

Area Name	Area of Factory (thousand sq m)						Un- known	Total
	<2	>2 <5	>5 <10	>10 <50	>50 <100	>100		
Ban Klang	-	1	1	3	2	1	3	11
Lad Lum Kaeo	-	2	-	3	-	2	2	9
Nava Nakorn	1	3	6	7	-	1	3	21
FAC-GO	6	2	-	-	-	-	7	15
Total	7	8	7	13	2	4	15	56

2) Water Consumption by Usage

Only 6 out of 56 factories gave the breakdown of water consumption by usage. It suggests that it is difficult understand the actual status of water use in the factory.

3) Wastewater Treatment Facility

50.0%, or 28 out of 56 factories had their own wastewater treatment facilities, especially in Ban Klang and the Nava Nakorn Industrial Estate. However, in case of Nava

Nakorn, it may mean that they used the wastewater treatment facilities operated by the Nava Nakorn Co., Ltd, managing the Nava Nakorn Industrial Estate.

4) Type of Water Supply

There was some confusion in the questionnaire survey at the Nava Nakorn Industrial Estate. The factories in this area are at present supplied water by the Nava Nakorn Co., Ltd. of which the water sources are two deep wells. However, some factories answered that they used the municipal system and the others answered that they used the other source managed by the Nava Nakorn Co., Ltd. Such confusions are derived from the difference in interpretation and both the answers are same. Accordingly to distinguish the PWA municipal system from that of Nava Nakorn Co., Ltd, the answer that they used the municipal system were categorized in the other source.

23.2% used the municipal system only, 66.1% other sources than the municipal system and the remaining 10.7% the combination system of the municipal system and other sources.

In other sources, 51.1% or 22 out of 43 other sources were the groundwater only, 23.3% the rain/river water only and the remaining 25.6% the combined water source as shown below.

Area Name	Ban Klang	Lad Lum Kao	Nava Nakorn	FAC- GO	Total
Municipal System Only	2	-	-	11	13
Plus Rain/River	1	1	-	3	5
Plus Water Vendor	-	-	-	1	1
Well Only	3	3	16	-	22
Plus Pond/Reservoir	-	-	2	-	2
Plus Water Vendor	-	-	3	-	3
Rain/River Only	5	5	-	-	10
Total	11	9	21	15	56

Though enough information was not obtained from the questionnaire survey, factories in Ban Klang and Lat Lum Kao had deep wells with depths ranging between 200 and 400 m.

5) Conditions of Municipal System

Ban Klang and Lat Lum Kaeo is supplied water by the PWA Patum Thani Waterworks, while FAC-GO by the PWA Prachatipat Waterworks. The number of users of the municipal system was a few in the former area. In the latter area, the most users had complaints of low pressure, insufficient water, color, smell and turbidity.

6) Conditions of Other Sources

16.3% had a complaint of color, 20.9% of smell and 30.2% of turbidity. Among other sources, the water source for the Nava Nakorn Industrial Estate was comparatively blessed with water quality and only some users had complaints of low pressure, smell and turbidity.

7) Potability

14.3% used its water source for drinking and 17.9% for drinking and not-drinking. However, 60.7% used it for not drinking.

8) Willingness to Connect

The rates of the willingness-to-connect were high in all areas exclusive of FAC-GO already served. 75.0% was willing to connect to the municipal system in Ban Klang, 50.0% in Lat Lum Kaeo and 52.4% in Nava Nakorn in which 42.9% was unknown. Those factories wanted that the connection fee would be less than 5,000 Baht (47.6%) and the water charge less than 10,000 Baht (61.9%), although 38.1% was unknown in both.

Table A1-5-3 Summary of Questionnaire Survey in Patum Thani and Prachathipat (Industry)

ITEM	AREA	Ban Klang	Lad Lum	Nava Kaeo	Nakorn	FAC-GO	Total	Rate (%)
No. of Samples		11	9	21	15	56	-	
1. General								
1.1 Name of Factory								
1.2 Address								
1.3 Type of Factory								
1.3.1 Food Processing								
1.3.2 Chemical Product								
1.3.3 Metal Fabrication								
1.3.4 Electrical Appliance Parts								
1.3.5 Machinery (Transportation)								
(Others)								
1.3.6 Medical Equipment								
1.3.7 Precision Equipment								
1.3.8 Optical Equipment								
1.3.9 Textiles								
1.3.10 Construction Material								
1.3.11 Wooden Product								
1.3.12 Others								
1.4 Annual Production (mil. Baht)								
Present								
1991								
2001								
2011								
1.5 No. of Employees		2632	776	4908	428	8744		
(No. of Samples)		10	9	21	13	53		
(Average)		263	86	234	33	165		
1.6 Area of Factory (sq m)		437600	558400	1375200	16620	2387820		
(No. of Samples)		8	7	18	8	41		
(Average)		54700	79771	171900	2078	58240		
2. Water Consumption (cu m/mo)								
2.1 Washing		12	13	-	54	79		
2.2 Cooling		-	-	-	-	-		
2.3 Materials		-	43	-	50	93		
2.4 Boiling		-	10	-	-	10		
2.5 Re-use		30	-	-	-	30		
2.6 Others		37	-	-	-	37		
Total		79	66	-	104	249		
(No. of Samples)		1	2		2	5		
3. Wastewater Treatment Facility								
Yes		8	4	13	3	28	50.0	
No		2	5	7	12	26	46.4	
Unknown		1	-	1	-	2	3.6	
4. Type of Water Supply								
Municipal System		2	-	-	11	13	23.2	
Combined		1	1	-	4	6	10.7	
Other Sources		8	8	21	-	37	66.1	

Table A1-5-3 Summary of Questionnaire Survey in Patum Thani and Prachatipat (Industry) (Cont'd)

ITEM	AREA	Ban Klang	Lad Lum	Nava Kaeo	Nakorn	FAC-GO	Total	Rate (%)
5. Municipal System								
Pressure								
Low		3	1	-	-	12	19	65.5
High		-	-	-	-	1	6	20.7
Unknown		-	-	-	-	2	4	13.8
Quantity								
Sufficient		1	-	-	-	6	16	55.2
Not sufficient		2	-	-	-	9	12	41.4
Unknown		-	1	-	-	-	1	3.4
6. Other Sources								
Rain/River		6	6	-	-	3	15	
Pond/Reservoir		-	-	-	2	-	2	
Water Vendor		-	-	-	3	1	4	
Groundwater		3	3	21	-	-	14	
7. Potability								
Drinking		1	2	3	3	2	8	14.3
Not drinking		7	3	12	12	12	34	60.7
Both		2	2	5	5	1	10	17.9
Unknown		1	2	1	-	-	4	7.1
8. Water Quality								
8.1 Municipal System								
8.1.1 Color								
Yes		1	1	-	-	4	6	31.6
No		2	-	-	-	7	9	47.4
Unknown		-	-	-	-	4	4	21.0
8.1.2 Smell								
Yes		1	1	-	-	5	7	36.8
No		1	-	-	-	5	6	31.6
Unknown		1	-	-	-	5	6	31.6
8.1.3 Turbidity								
Yes		1	-	-	-	7	8	42.1
No		2	-	-	-	6	8	42.1
Unknown		-	1	-	-	2	3	15.8
8.2 Other Sources								
8.2.1 Color								
Yes		1	4	1	1	1	7	16.3
No		6	3	14	14	2	25	58.1
Unknown		2	2	6	6	1	11	25.6
8.2.2 Smell								
Yes		2	2	4	4	1	9	20.9
No		5	5	15	15	2	27	62.8
Unknown		2	2	2	2	1	7	16.3
8.2.3 Turbidity								
Yes		3	5	4	4	1	13	30.2
No		5	2	13	13	2	22	51.2
Unknown		1	2	4	4	1	8	18.6

Table A1-5-3 Summary of Questionnaire Survey in Patum Thani and Prachatipat (Industry) (Cont'd)

ITEM	AREA	Ban Klang	Lad Lum	Nava Kaeo	Nakorn	FAC-GO	Total	Rate (%)
:10 Willingness to Connect								
Yes		6	4	11			21	56.8
No		2	4	1			7	18.9
Unknown		-	-	9			9	24.3
:11. Willingness to Pay for Connection Fee								
< 2,000 (Baht)		1	2	3			6	28.5
2,001 - 3,000		-	1	1			2	9.5
3,001 - 5,000		1	-	1			2	9.5
5,001 - 7,000		-	1	-			1	4.8
7,001 - 10,000		-	-	1			1	4.8
10,001 - 15,000		-	-	-			-	-
15,001 - 20,000		-	-	1			1	4.8
20,000 <		-	-	-			-	-
Unknown		4	-	4			8	38.1
:12. Willingness to Pay for Water Charge								
< 1,000 (Baht/mo)		-	2	1			3	14.3
1,001 - 2,000		1	1	1			3	14.3
2,001 - 5,000		-	1	2			3	14.3
5,001 - 10,000		1	-	3			4	19.0
10,001 - 15,000		-	-	-			-	-
15,001 - 20,000		-	-	-			-	-
20,001 - 30,000		-	-	-			-	-
30,001 - 50,000		-	-	-			-	-
50,001 - 100,000		-	-	-			-	-
100,000 <		-	-	-			-	-
Unknown		4	-	4			8	38.1

APPENDIX A-4-5

Industrial Wastewater from Existing Factories

Table A4-5-1 Existing Industrial Water Consumption

NO.	FACT CODE	CATEG. CODE	SEWAGE WATER DISCHARGE	RATIO TO CAL. OF FRESH WATER	FRESH WATER CONSUMPTION	CODE
	(a)	(b)	(c)	(d)	(e)	
1	13	18	35	0.410	14	4.4
2	14	18	250	0.410	103	4.4
3	15	18	12	0.410	5	4.4
4	28	18	20	0.410	8	4.4
5	35	18	3	0.410	1	4.4
6	36	18	300	0.410	123	4.4
7	37	18	90	0.410	37	4.4
8	21	19	1,000	0.410	410	4.4
9	22	19	600	0.410	246	4.4
10	11	20	1,000	0.440	440	4.4
11	12	20	400	0.440	176	4.4
12	16	20	300	0.440	132	4.4
13	18	20	1,200	0.440	528	4.4
14	31	20	800	0.440	352	4.4
15	33	20	1,800	0.440	792	4.4
16	39	20	700	0.440	308	4.4
17	4	20	5	0.440	2	4.7
18	5	20	120	0.440	53	4.7
19	6	20	6,000	0.440	2,640	4.7
20	7	20	900	0.440	396	4.7
21	8	20	2,200	0.440	968	4.7
22	36	21	2,000	3.514	7,028	4.3
23	19	21	30	3.514	105	4.4
24	20	24	1,000	1.135	1,135	4.4
25	17	24	2,000	1.135	2,270	4.4
26	24	24	1,000	1.135	1,135	4.4
27	26	24	2,000	1.135	2,270	4.4
28	27	24	4,000	1.135	4,540	4.4
29	29	24	4,000	1.135	4,540	4.4
30	25	26	10	0.227	2	4.4
31	30	30	30	0.666	20	4.4
32	1	30	270	0.666	180	4.7
33	2	30	20	0.666	13	4.7
34	3	30	80	0.666	53	4.7
35	38	31	200	0.367	73	4.4
36	23		5	1.000	5	4.4
37	32		25	1.000	25	4.4
38	34		5	1.000	5	4.4
TOTAL			34,410	0.905	31,133	
31	40	NAVA	2,000	1.000	2,000	4.4

APPENDIX A-4-6

Data on Nava Nakorn Industrial Estate

Table A4-6-1 Water Consumption at Naba Nakorn Industrial Estate

FACTORY CODE	CATEGORY (CODE)	NO. OF EMP. (pers.) (a)	LAND AREA (ha) (b)=(e)*0.16	WATER CONSUMP. (cu m/m) (c)	Q/EMP. (d)/(a)	Q/AREA (d)/(b)	No.1	
							WATER CONSUMP. (cu m/d) (d)=(c)/30	LAND AREA (rai) (e)
1	12	8	0.33	284	1.18	28.69	9.47	2.09
2	20	28	0.31	179	0.21	19.25	5.97	1.95
3	13	35	0.18	2,380	2.27	440.74	79.33	1.12
4	29	23	0.18	9	0.01	1.67	0.30	1.12
5	29	252	0.43	562	0.07	43.57	18.73	2.70
6	30	220	2.53	6,387	0.97	84.15	212.90	15.84
7	20	25	0.36	163	0.22	15.09	5.43	2.22
8	20	30	0.26	215	0.24	27.57	7.17	1.65
9	22	64	0.40	226	0.12	18.83	7.53	2.49
10	17	57	0.54	229	0.13	14.14	7.63	3.37
11	32	5	0.37		0.00	0.00	0.00	2.30
12	17	22	0.37	57	0.09	5.14	1.90	2.33
13	32	745	0.87	1,637	0.07	62.72	54.57	5.46
14	12	60	1.07	1,804	1.00	56.20	60.13	6.71
15	22	293	1.07	1,056	0.12	32.90	35.20	6.70
16	26	33	0.43	426	0.43	33.02	14.20	2.69
17	20	33	0.43	426	0.43	33.02	14.20	2.69
18	31	28	0.85	543	0.65	21.29	18.10	5.34
19	12	41	0.95	4,551	3.70	159.68	151.70	5.92
20	13	60	0.94	2,370	1.32	84.04	79.00	5.85
21	34	75	0.81	788	0.35	32.43	26.27	5.05
22	23	52	0.45	637	0.41	47.18	21.23	2.80
23	23	45	0.45	579	0.43	42.89	19.30	2.80
24	30	73	0.45	462	0.21	34.22	15.40	2.84
25	17	125	0.45	420	0.11	31.11	14.00	2.82
26	29	45	0.49	419	0.31	28.50	13.97	3.05
27	28	135	0.50	1,221	0.30	81.40	40.70	3.10
28	20	18	0.39	139	0.26	11.88	4.63	2.45
29	30	620	1.63	9,829	0.53	201.00	327.63	10.17
30	28	282	0.40	1,350	0.16	112.50	45.00	2.53
31	17	140	0.40	956	0.23	79.67	31.87	2.53
32	20	7	0.46	132	0.63	9.57	4.40	2.85
33	20	25	5.45	133	0.18	0.81	4.43	34.04
34	15	360	0.51	1,878	0.17	122.75	62.60	3.17
35	13	120	0.48	1,145	0.32	79.52	38.17	3.00
36	20	19	0.41	88	0.15	7.15	2.93	2.57
37	25	67	0.39	641	0.32	54.79	21.37	2.43
38	30	40	0.40	253	0.21	21.08	8.43	2.51
39	17	361	0.38	1,310	0.12	114.91	43.67	2.40
40	26	398	3.69	10,239	0.86	92.49	341.30	23.09
41	20	20	0.15	135	0.23	30.00	4.50	0.94
42	26	50	0.15	62	0.04	13.78	2.07	0.93
43	14	250	0.45	388	0.05	28.74	12.93	2.81
44	31	40	0.45	1,753	1.46	129.85	58.43	2.81
45	22	42	0.45	497	0.39	36.82	16.57	2.79
46	12	20	0.22	220	0.37	33.33	7.33	1.40
47	22	20	0.21	135	0.23	21.43	4.50	1.31
48	12	37	0.51	1,278	1.15	83.53	42.60	3.16
49	12	55	0.49	782	0.47	53.20	26.07	3.08
50	14	72	0.22	758	0.35	114.85	25.27	1.39
51	14	107	0.28	558	0.17	71.54	18.60	1.62
52	13		0.25			0.00	0.00	1.54
53	32	420	0.32	771	0.06	80.31	25.70	1.97
54	20	20	0.32	195	0.33	20.31	6.50	1.97

Table A4-6-1 Water Consumption at Naba Nakorn Industrial Estate (cont'd)

FACTORY CODE	CATEGORY (CODE)	NO. OF EMP. (pers.) (a)	LAND AREA (ha) (b)=(e)*0.16	WATER CONSUMP. (cu m/m) (c)	Q/EMP. (d)/(a)	Q/AREA (d)/(b)	WATER CONSUMP. (cu m/d) (d)=(c)/30	No. 2	
								LAND AREA (rai) (e)	
55	20	14,700	3.58	4,988	0.01	46.44	166.27	22.40	
56	30	130	3.44	1,624	0.42	15.74	54.13	21.52	
57	30	1,025	6.90	5,871	0.19	28.36	195.70	43.10	
58	18	250	0.68	2,728	0.36	133.73	90.93	4.22	
59	31	90	0.73	1,085	0.40	49.54	36.17	4.59	
60	18	20	0.73	188	0.31	8.59	6.27	4.59	
61	20	80	1.48	2,628	1.10	59.19	87.60	9.22	
62	25	133	7.80	7,256	1.82	31.01	241.87	48.75	
63	14		0.99	307		10.34	10.23	6.20	
64		170	1.17	720	0.14	20.51	24.00	7.31	
65	31	460	1.92	4,875	0.35	84.64	162.50	12.00	
66	20	107	2.55	7,715	2.40	100.85	257.17	15.93	
67	17	120	0.95	579	0.16	20.32	19.30	5.93	
68		30	0.77	230	0.26	9.96	7.67	4.81	
69	23	500	0.40	1,047	0.07	87.25	34.90	2.47	
70		30	0.42	925	1.03	73.41	30.83	2.62	
71	22	12	0.57	89	0.25	5.21	2.97	3.58	
72	27	103	0.77	2,280	0.74	98.70	76.00	4.81	
73	20	30	0.43	173	0.19	13.41	5.77	2.71	
74	25		1.08	3,206		98.95	106.87	6.78	
75	15	250	0.44	481	0.06	36.44	16.03	2.78	
76	23		0.39			0.00	0.00	2.43	
77	15	240	0.81	325	0.05	13.37	10.83	5.09	
78			0.39			0.00	0.00	2.44	
79	18	190	5.10	1,395	0.25	9.12	46.50	31.88	
80	34	433	0.42	1,430	0.11	113.49	47.67	2.65	
81	22	21	0.42	194	0.31	15.40	6.47	2.65	
82	30	1,100	0.86	12,032	0.37	466.36	401.07	5.37	
83	29	30	0.40	115	0.13	9.58	3.83	2.47	
84	30	150	0.44	519	0.12	39.32	17.30	2.78	
85	24	380	0.44	2,672	0.23	202.43	89.07	2.74	
86	24	480	0.44	1,374	0.10	104.09	45.80	2.74	
87	34	1,073	0.88	2,785	0.09	105.49	92.83	5.48	
88	20	80	0.44	808	0.34	61.21	26.93	2.74	
89	30	12	0.44	165	0.46	12.50	5.50	2.74	
90	32	780	1.34	1,491	0.06	37.09	49.70	8.35	
91	20		0.44			0.00	0.00	2.72	
92	26	290	9.97	3,339	0.38	11.16	111.30	62.34	
93	28	70	0.81	3,306	1.57	136.05	110.20	5.05	
94	23	800	0.57	787	0.03	46.02	26.23	3.56	
95	14	30	0.51	132	0.15	8.63	4.40	3.20	
96	22		0.51			0.00	0.00	3.20	
97	20		1.09			0.00	0.00	6.80	
98	23	70	1.13	422	0.20	12.45	14.07	7.05	
99	12	85	0.77	1,261	0.50	54.59	42.03	4.80	
100	20	31	0.67	270	0.29	13.43	9.00	4.20	
101	28		0.74			0.00	0.00	4.62	
102	20	25	0.38	386	0.52	33.86	12.87	2.40	
103	30	360	3.22	150	0.01	1.55	5.00	20.11	
104	13	40	10.08	100	0.08	0.33	3.33	63.00	
105	27	500	24.14	3,771	0.25	5.21	125.70	150.87	
106	30	55	3.22	1,547	0.94	16.02	51.57	20.11	
107	34	75	1.60	605	0.27	12.60	20.17	10.00	
108	32	100	1.60		0.00	0.00	0.00	10.00	
109			0.40	453		37.75	15.10	2.50	

Table A4-6-1 Water Consumption at Naba Nakorn Industrial Estate (cont'd)

FACTORY CODE	CATEGORY (CODE)	NO. OF EMP. (pers.) (a)	LAND AREA (ha) (b)=(e)*0.16	WATER CONSUMP. (cu m/m) (c)	Q/EMP. (d)/(a)	Q/AREA (d)/(b)	No. 3	
							WATER CONSUMP. (cu m/d) (d)=(c)/30	LAND AREA (rai) (e)
110	34	120	0.40	269	0.08	22.42	8.97	2.50
111	34	123	3.25	446	0.12	4.57	14.87	20.31
112	30	800	0.40	2,321	0.10	193.42	77.37	2.47
113	23	30	0.40	131	0.15	10.92	4.37	2.50
114	28		0.40			0.00	0.00	2.50
115	12	80	0.40	300	0.13	25.00	10.00	2.50
116	15	60	0.40	3,333	1.85	277.75	111.10	2.50
117	15	60	0.40	223	0.12	18.58	7.43	2.50
118	18	180	0.80	437	0.08	18.21	14.57	5.00
119	32	75	1.60	234	0.10	4.88	7.80	10.00
120	30		0.80			0.00	0.00	4.97
121		35	0.80	529	0.50	22.04	17.63	5.00
122	25	500	0.80	1,315	0.09	54.79	43.83	5.00
123	23		0.80	1,534		63.92	51.13	5.00
124			1.60	1,063		22.15	35.43	10.00
125			1.60			0.00	0.00	10.00
126	30		0.80	699		29.13	23.30	4.97
127	17		1.03	199		6.44	6.63	6.44
128	18	280	2.35	1,641	0.20	23.28	54.70	14.67
129	31		2.35			0.00	0.00	14.70
130	34	220	4.70	2,067	0.31	14.66	68.90	29.40
131	31		2.35			0.00	0.00	14.70
132	34	150	1.96	586	0.13	9.97	19.53	12.25
133	22	50	1.80	751	0.50	13.91	25.03	11.26
134			13.12			0.00	0.00	82.03
135	30	450	3.12	1,510	0.11	18.13	50.33	19.47
136	31		1.55	328		7.05	10.93	9.69
137	30		7.00			0.00	0.00	43.72
138	30		7.19			0.00	0.00	44.93
139	32	113	3.25	480	0.14	4.92	16.00	20.33
140	27	240	1.47	723	0.10	18.40	24.10	9.21
141	30	48	1.44	300	0.21	6.94	10.00	9.00
142	20	50	1.44	500	0.33	11.57	16.67	9.00
143	30		2.88	740		8.57	24.67	17.97
144	30	200	2.96		0.00	0.00	0.00	18.47
145	30	407	1.18		0.00	0.00	0.00	7.40
146	30	167	1.18	810	0.16	22.88	27.00	7.40
147	34	150	2.96		0.00	0.00	0.00	18.50
148	28	229	2.84		0.00	0.00	0.00	17.75
149			8.47			0.00	0.00	52.92
150	27	200	4.57		0.00	0.00	0.00	28.56
151			12.54			0.00	0.00	78.40
152			0.83			0.00	0.00	5.20
153			0.40			0.00	0.00	2.50
154	30		0.40			0.00	0.00	2.50
155			0.48			0.00	0.00	3.00
156	22	22	0.48	72	0.11	5.00	2.40	2.97
157			2.93			0.00	0.00	18.30
158	23		2.35	1,594		22.61	53.13	14.66
159			13.42			0.00	0.00	83.88
160	32	450	7.40		0.00	0.00	0.00	46.27
161	32		1.52			0.00	0.00	9.50
162	32	300	6.15		0.00	0.00	0.00	38.46
163	32	60	1.86	623	0.35	11.17	20.77	11.60
164	27		2.71			0.00	0.00	16.92

Table A4-6-1 Water Consumption at Naba Nakorn Industrial Estate (cont'd)

FACTORY CODE	CATEGORY (CODE)	NO. OF EMP. (pers.) (a)	LAND AREA (ha) (b)=(e)*0.16	WATER CONSUMP. (cu m/m) (c)	Q/EMP. (d)/(a)	Q/AREA (d)/(b)	WATER CONSUMP. (cu m/d) (d)=(c)/30	No. 4
								LAND AREA (rai) (e)
165	30	440	6.40		0.00	0.00	0.00	40.00
166			7.12			0.00	0.00	44.48
167			0.80			0.00	0.00	5.00
168	20		0.95			0.00	0.00	5.96
169	20	30	0.80		0.00	0.00	0.00	5.00
170			1.03			0.00	0.00	6.46
171	30	230	3.30		0.00	0.00	0.00	20.60
172	32		0.85			0.00	0.00	5.30
173			1.17			0.00	0.00	7.30
174			5.58			0.00	0.00	34.89
175			1.31			0.00	0.00	8.20
176			1.56			0.00	0.00	9.76
		38,511.00	331.91	180,242.00	0.16	18.10	6,008.07	2,074.46

APPENDIX A-6-1

Construction Unit Cost

Unit Cost

Item	Material	Fitting	Labor	SubTotal	Transprt	Profit	Total 1	Pavement	Total 2
	(800km) etc.(21%)(w/10%cont)								
Pipeline									
	*****			P W A 's		Unit Rate (1987)		*****	
a. A/C Pipe(Normal Tytpe)	(25%)								
100 mm	85	21	56	162	6	35	224	140	364
150 mm	142	36	77	255	11	56	353	154	507
200 mm	255	64	90	409	19	90	569	166	735
250 mm	352	88	126	566	29	125	792	179	971
300 mm	507	127	167	801	40	177	1119	223	1342
400 mm	970	243	248	1461	80	324	2050	248	2298
500 mm	1362	341	278	1981	132	444	2812	283	3095
600 mm	1761	440	354	2555	161	570	3615	319	3934
b. Steel Pipe	(35%)								
150 mm	545	191	99	835	12	178	1127	140	1267
200 mm	720	252	111	1083	22	232	1471	154	1625
250 mm	1080	378	153	1611	38	346	2195	166	2361
300 mm	1330	465	202	1998	58	432	2736	179	2915
400 mm	1420	497	250	2167	80	472	2991	223	3214
500 mm	1785	625	361	2771	160	615	3901	248	4149
600 mm	2140	749	468	3357	264	760	4820	283	5103
700 mm	2495	873	582	3950	322	897	5686	319	6005

Unit Cost

For Transmission Pipeline (Transportation < 800 km)

Item	Material	Fitting (10%)	Labor	SubTotal	Transprt (800km)	Profit etc. (21%)(w/10%cont)	Total 1	Pavement	Total 2	Adopted (1988)		
<***** Unit Rate Based on Pipe Material Cost as of December, 1988 *****>												
a. A/C Pipe (Class 20 Normal type)												
	(10 %)											
100 mm	115	12	63	190	7	41	261	153	414	364	1.14	410
150 mm	189	19	87	295	12	64	408	168	577	507	1.14	580
200 mm	328	33	101	462	21	101	643	181	824	735	1.12	820
250 mm	454	45	142	641	32	141	895	196	1091	971	1.12	1,090
300 mm	643	64	188	895	44	197	1249	244	1493	1342	1.11	1,490
400 mm	1217	122	279	1618	87	358	2270	271	2541	2298	1.11	2,540
500 mm	1699	170	313	2182	144	488	3096	309	3405	3095	1.10	3,410
600 mm	2187	219	398	2804	176	626	3967	349	4315	3934	1.10	4,320
b. Steel Pipe												
	(15 %)											
150 mm	550	83	111	744	13	159	1008	168	1176	1267	0.93	1,270
200 mm	908	136	125	1168	24	250	1587	181	1769	1625	1.09	1,770
250 mm	1210	182	172	1564	42	337	2136	196	2332	2361	0.99	2,360
300 mm	1507	226	227	1960	63	425	2693	244	2937	2915	1.01	2,940
400 mm	1887	283	281	2451	87	533	3378	271	3649	3214	1.14	3,650
500 mm	2261	339	406	3006	175	668	4233	309	4542	4149	1.09	4,540
600 mm	2723	408	526	3657	288	829	5252	349	5600	5103	1.10	5,600
700 mm	3179	477	655	4311	352	979	6206	407	6612	6005	1.10	6,610
800 mm	4527	679	932	6138	460	1385	8781	465	9246			9,250
900 mm	5104	766	1051	6921	582	1575	9986	523	10508			10,510
1000 mm	6804	1021	1401	9225	718	2088	13234	581	13815			13,820
1100 mm	7926	1189	1632	10746	869	2439	15460	639	16099			16,100
1200 mm	9048	1357	1863	12268	1034	2793	17705	697	18402			18,400
1350 mm	11000	1650	2265	14915	1309	3407	21594	784	22378			22,380
1500 mm	12953	1943	2667	17563	1616	4027	25526	871	26398			26,400

*** Note: Pipe material prices are estimated from the contractor's purchasing price as of Dec. 1988

Unit Cost

For Distribution Pipeline (Transportation < 800 km)

Item	Material	Fitting	Labor	SubTotal	Transprt (<800km)	Profit etc.(21%)(w/10%cont)	Total 1	Pavement	Total 2	PKA Price (1987)	Ratio	Adopted (1988)
<p>***** Unit Rate Based on Pipe Material Cost as of December, 1988 *****</p>												
<p>a. A/C Pipe (Class 20 Normal type) (25 x)</p>												
100 mm	115	29	63	207	7	45	284	153	437	364	1.20	440
150 mm	189	47	87	323	12	70	446	168	614	507	1.21	610
200 mm	328	82	101	511	21	112	708	181	890	735	1.21	890
250 mm	454	113	142	709	32	155	986	196	1181	971	1.22	1,180
300 mm	643	161	188	991	44	217	1378	244	1621	1342	1.21	1,620
400 mm	1217	304	279	1801	87	397	2513	271	2784	2298	1.21	2,780
500 mm	1699	425	313	2437	144	542	3435	309	3744	3095	1.21	3,740
600 mm	2187	547	398	3132	176	695	4403	349	4752	3934	1.21	4,750
<p>b. Steel Pipe (35 x)</p>												
150 mm	550	193	111	854	13	182	1154	168	1322	1267	1.04	1,320
200 mm	908	318	125	1350	24	289	1829	181	2010	1625	1.24	2,010
250 mm	1210	424	172	1806	42	388	2459	196	2654	2361	1.12	2,650
300 mm	1507	527	227	2262	63	488	3095	244	3338	2915	1.15	3,340
400 mm	1837	660	281	2828	87	612	3880	271	4151	3214	1.29	4,150
500 mm	2261	791	406	3458	175	763	4835	309	5144	4149	1.24	5,140
600 mm	2723	953	526	4202	288	943	5977	349	6325	5103	1.24	6,330
700 mm	3179	1113	655	4946	352	1113	7052	407	7459	6005	1.24	7,460
800 mm	4527	1584	932	7043	460	1576	9986	465	10451			10,450
900 mm	5104	1786	1051	7941	582	1790	11344	523	11867			11,870
1000 mm	6804	2381	1401	10586	718	2374	15045	581	15626			15,630
1100 mm	7926	2774	1632	12332	869	2772	17570	639	18209			18,210
1200 mm	9048	3167	1863	14077	1034	3173	20113	697	20810			20,810
1350 mm	11000	3850	2265	17115	1309	3869	24522	784	25307			25,310
1500 mm	12953	4533	2667	20153	1616	4571	28974	871	29846			29,850

*** Note: Pipe material prices are estimated from the contractor's purchasing price as of Dec. 1988

Unit Cost

For Transmission Pipeline (Transportation >= 800 km)

Item	Material	Fitting (10%)	Labor	SubTotal	Transprt (>=800km)etc.	Profit (21%)(w/10%cont)	Total 1	Pavement	Total 2	Adopted (1988)		
<***** Unit Rate Based on Pipe Material Cost as of December, 1988 *****>												
a. A/C Pipe (Class 20 Normal type)												
	(10 %)											
100 mm	115	12	63	190	13	43	270	153	423	364	1.16	420
150 mm	189	19	87	295	24	67	424	168	593	507	1.17	590
200 mm	328	33	101	462	42	106	670	181	852	735	1.16	850
250 mm	454	45	142	641	63	148	937	196	1133	971	1.17	1,130
300 mm	643	64	188	895	87	206	1308	244	1551	1342	1.16	1,550
400 mm	1217	122	279	1618	175	377	2387	271	2658	2298	1.16	2,660
500 mm	1699	170	313	2182	288	519	3288	309	3597	3095	1.16	3,600
600 mm	2187	219	398	2804	352	663	4201	349	4549	3934	1.16	4,550
b. Steel Pipe												
	(15 %)											
150 mm	550	83	111	744	26	162	1025	168	1193	1267	0.94	1,270
200 mm	908	136	123	1168	48	255	1619	181	1801	1625	1.11	1,800
250 mm	1210	182	172	1564	83	346	2192	196	2387	2361	1.01	2,390
300 mm	1507	226	227	1960	127	438	2778	244	3022	2915	1.04	3,020
400 mm	1887	283	281	2451	175	551	3495	271	3766	3214	1.17	3,770
500 mm	2261	339	406	3006	350	705	4466	309	4775	4149	1.15	4,780
600 mm	2723	408	526	3657	577	889	5636	349	5984	5103	1.17	5,980
700 mm	3179	477	655	4311	704	1053	6674	407	7081	6005	1.18	7,080
800 mm	4527	679	932	6138	919	1482	9393	465	9857			9,860
900 mm	5194	766	1051	6921	1163	1698	10760	523	11283			11,280
1000 mm	6804	1021	1401	9225	1436	2239	14190	581	14771			14,770
1100 mm	7925	1189	1632	10746	1738	2622	16616	639	17256			17,260
1200 mm	9048	1357	1863	12268	2068	3011	19081	697	19778			19,780
1350 mm	11000	1650	2265	14915	2617	3682	23336	784	24120			24,120
1500 mm	12953	1943	2667	17563	3231	4367	27677	871	28548			28,550

*** Note: Pipe material prices are estimated from the contractor's purchasing price as of Dec. 1988

Unit Cost

For Distribution Pipeline (Transportation >= 800 km)

Item	Material	Fitting	Labor	SubTotal	Transprt (>=800km)	Profit etc.(21%)	Total 1 (w/10%cont)	Pavement		Total 2	Adopted (1988)	
<***** Unit Rate Based on Pipe Material Cost as of December, 1988 *****>												
a. A/C Pipe (Class 20 Normal type)												
	(25 %)											
100 mm	115	29	63	207	13	46	293	153	446	364	1.23	450
150 mm	189	47	87	323	24	73	462	168	630	507	1.24	630
200 mm	328	82	101	511	42	116	736	181	917	735	1.25	920
250 mm	454	113	142	709	63	162	1028	196	1223	971	1.26	1,220
300 mm	643	161	188	991	87	227	1436	244	1680	1342	1.25	1,680
400 mm	1217	304	279	1891	175	415	2630	271	2901	2298	1.26	2,900
500 mm	1699	425	313	2437	288	572	3627	309	3936	3095	1.27	3,940
600 mm	2187	547	396	3132	352	732	4637	349	4986	3934	1.27	4,990
b. Steel Pipe												
	(35 %)											
150 mm	550	193	111	854	26	185	1171	168	1340	1267	1.06	1,340
200 mm	908	318	125	1350	48	294	1861	181	2042	1625	1.26	2,040
250 mm	1210	424	172	1806	83	397	2514	196	2709	2361	1.15	2,710
300 mm	1507	527	227	2262	127	502	3179	244	3423	2915	1.17	3,420
400 mm	1887	660	281	2828	175	631	3997	271	4268	3214	1.33	4,270
500 mm	2261	791	406	3458	350	800	5068	309	5377	4149	1.30	5,380
600 mm	2723	953	526	4202	577	1004	6361	349	6709	5103	1.31	6,710
700 mm	3179	1113	655	4946	704	1187	7520	407	7927	6005	1.32	7,930
800 mm	4527	1584	932	7043	919	1672	10598	465	11062			11,060
900 mm	5104	1786	1051	7941	1163	1912	12118	523	12641			12,640
1000 mm	6804	2381	1401	10586	1436	2525	16001	581	16582			16,580
1100 mm	7926	2774	1632	12332	1738	2955	18726	639	19365			19,370
1200 mm	9048	3167	1863	14077	2068	3391	21490	697	22187			22,190
1350 mm	11000	3850	2265	17115	2617	4144	26264	784	27049			27,050
1500 mm	12953	4533	2667	20153	3231	4911	31125	871	31996			32,000

*** Note: Pipe material prices are estimated from the contractor's purchasing price as of Dec.1988

Unit Cost

Construction Works		Price in 3 Lowest Tenders (1988) (A)	Estimated Cost (A)*1.35	PWA's Unit Cost (for 1987)	Adopted Cost (1988)
Concrete Work (incl. Form Work, Scaffolding)	Baht	2,200 /cu m	Baht 2,970 /cu m	-	
Re-Bar	Baht	18 /kg	Baht 24 /kg	-	
Unit Concrete Cost (incl. Form Work, Scaffolding, Re-Bar(100kg/cu m concrete))			Baht 5,370 /cu m	-	5,400
Earth Work					
Excavation (with Backfill)		55 /cu m	79 /cu m	-	80
Soil Fill		53 /cu m	76		120 (From PWA Cost)
Architectural Works					
Administration Bldg.		4,515 /sq m	6,451 /sq m		
Head Quarter Bldg.		3,612	5,160		5,000
Chlorination House	Baht	2,830 /sq m	Baht 4,043 /sq m	3610 - 4300	3,800
Pump House (excl. pump pit)	Baht	1,860 /sq m	Baht 2,657 /sq m	3540 - 4200	3,600

Unit Cost

Construction Works	PWA's Cost (for 1987) (Baht 1000)	Unit Cost (Baht/cu m/h) (A)	Estimated Cost (for 1989) (A)+1.30	Adopted Cost (1988)
Treatment Facilities				
			Unit Cost (Baht/cu m/h)	Unit Cost (Baht/cu m/h)
Sedimentation Basin				
50 cu m/hr	1,310	26,200	34,100	34,000
100 cu m/hr	1,633	16,330	21,200	21,000
200 cu m/hr	3,136	15,680	20,400	20,000
250 cu m/hr	5,133	20,532	26,700	27,000
500 cu m/hr	7,708	15,416	20,000	20,000
1000 cu m/hr	17,723	17,723	23,000	23,000
Filters				
50 cu m/hr	588	11,760	15,300	15,000
100 cu m/hr	1,044	10,440	13,600	14,000
200 cu m/hr	2,227	11,135	14,500	15,000
250 cu m/hr	2,337	9,348	12,200	12,000
500 cu m/hr	4,674	9,348	12,200	12,000
1000 cu m/hr	11,356	11,356	14,800	15,000
Clear Water Reservoir				
			Unit Cost (Baht/cu m)	Unit Cost (Baht/cu m)
500 cu m	887	1,774	2,300	2,300
1000 cu m	1,628	1,628	2,100	2,100
1500 cu m	2,699	1,799	2,300	2,300
2000 cu m	2,803	1,402	1,800	1,800
2250 cu m	3,282	1,459	1,900	1,900
3000 cu m	6,633	2,211	2,900	2,900
3300 cu m	6,603	2,001	2,600	2,600
4000 cu m	7,730	1,933	2,500	2,500
5800 cu m	10,809	1,864	2,400	2,400
Elevated Tank				
			Cost (Baht 1000)	Cost (Baht 1000)
50 cu m	722		940	940
120 cu m	1,146		1,490	1,500
250 cu m	1,394		1,810	1,800

APPENDIX A-8-1

Details of Water Demand Prediction

Petee Thant & Prachetipat

Prediction of Service Population and Demand

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Population in Service Area by Tachon																						
Amphor Yasthon Class																						
1 Nueang																						
1 Med	0	0	0	0	0	9,498	10,056	10,614	11,173	11,731	12,290	12,848	13,406	13,964	14,522	15,080	15,638	16,196	16,754	17,312	17,870	18,428
2 Med	0	0	0	0	0	5,803	6,138	6,473	6,808	7,143	7,478	7,813	8,148	8,483	8,818	9,153	9,488	9,823	10,158	10,493	10,828	11,163
3 Med	0	0	0	0	0	3,183	3,299	3,415	3,531	3,647	3,763	3,879	3,995	4,111	4,227	4,343	4,459	4,575	4,691	4,807	4,923	5,039
4 Med	0	0	0	0	0	5,117	5,454	5,791	6,128	6,465	6,802	7,139	7,476	7,813	8,150	8,487	8,824	9,161	9,498	9,835	10,172	10,509
5 Med	0	0	0	0	0	1,829	1,895	1,961	2,027	2,093	2,159	2,225	2,291	2,357	2,423	2,489	2,555	2,621	2,687	2,753	2,819	2,885
6 Med	0	0	0	0	0	3,232	3,350	3,468	3,585	3,703	3,820	3,938	4,055	4,173	4,290	4,408	4,525	4,643	4,760	4,878	4,995	5,113
7 Med	0	0	0	0	0	5,447	5,788	6,129	6,471	6,812	7,154	7,495	7,837	8,178	8,519	8,860	9,201	9,542	9,883	10,224	10,565	10,906
8 Med	0	0	0	0	0	4,464	4,627	4,790	4,953	5,115	5,278	5,441	5,604	5,767	5,930	6,093	6,256	6,419	6,582	6,745	6,908	7,071
9 Med	0	0	0	0	0	5,391	5,706	6,021	6,336	6,651	6,966	7,281	7,596	7,911	8,226	8,541	8,856	9,171	9,486	9,801	10,116	10,431
10 Med	2,667	2,864	3,061	3,258	3,454	3,651	3,848	4,045	4,242	4,439	4,636	4,833	5,030	5,227	5,424	5,621	5,818	6,015	6,212	6,409	6,606	6,803
11 Med	1,964	2,131	2,298	2,465	2,632	2,799	2,966	3,133	3,300	3,467	3,634	3,801	3,968	4,135	4,302	4,469	4,636	4,803	4,970	5,137	5,304	5,471
12 HI	15,578	16,091	16,604	17,117	17,630	18,143	18,656	19,169	19,682	20,195	20,708	21,221	21,734	22,247	22,760	23,273	23,786	24,299	24,812	25,325	25,838	26,351
14 Med	0	842	2,189	3,491	4,824	6,152	7,479	8,825	10,167	11,509	12,851	14,193	15,535	16,877	18,219	19,561	20,903	22,245	23,587	24,929	26,271	27,613
2 San Nok	0	0	0	0	0	0	0	0	556	1,192	1,787	2,383	2,979	3,574	4,170	4,766	5,362	5,958	6,554	7,150	7,746	8,342
1 Low	0	0	0	0	0	0	0	0	386	772	1,158	1,544	1,930	2,316	2,702	3,088	3,474	3,860	4,246	4,632	5,018	5,404
2 Low	0	0	0	0	0	0	0	0	373	746	1,119	1,492	1,865	2,238	2,611	2,984	3,357	3,730	4,103	4,476	4,849	5,222
3 Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
4 Low	908	919	930	941	951	962	973	984	995	1,007	1,019	1,030	1,041	1,052	1,063	1,074	1,085	1,096	1,107	1,118	1,129	1,140
5 Low	1,376	1,392	1,408	1,425	1,441	1,458	1,474	1,491	1,508	1,525	1,543	1,560	1,576	1,593	1,609	1,626	1,642	1,659	1,675	1,691	1,708	1,724
6 Low	2,018	2,042	2,066	2,090	2,113	2,137	2,161	2,185	2,209	2,232	2,256	2,280	2,304	2,328	2,352	2,376	2,400	2,424	2,448	2,472	2,496	2,520
7 Low	5,564	6,631	6,638	6,756	6,833	6,901	6,968	7,035	7,103	7,170	7,238	7,305	7,373	7,440	7,508	7,575	7,643	7,710	7,778	7,845	7,913	7,980
8 Med	0	0	0	0	0	0	0	0	681	1,763	2,644	3,525	4,407	5,288	6,169	7,050	7,931	8,812	9,693	10,574	11,455	12,336
9 Med	0	0	0	0	0	0	0	0	438	876	1,315	1,753	2,191	2,629	3,067	3,505	3,943	4,381	4,819	5,257	5,695	6,133
10 Med	0	0	0	0	0	0	0	0	553	1,106	1,659	2,211	2,764	3,317	3,870	4,423	4,976	5,529	6,082	6,635	7,188	7,741
11 Med	43,205	46,321	48,437	52,553	55,668	58,784	61,900	66,054	70,221	74,391	78,554	82,718	86,883	91,047	95,211	99,375	103,539	107,703	111,867	116,031	120,195	124,359
12 Med	0	4,787	5,292	5,797	6,303	6,808	7,313	7,818	8,323	8,828	9,333	9,838	10,343	10,848	11,353	11,858	12,363	12,868	13,373	13,878	14,383	14,888
13 Med	16,172	16,302	17,432	18,063	18,693	19,324	19,954	20,702	21,451	22,199	22,948	23,696	24,445	25,193	25,942	26,690	27,439	28,187	28,936	29,684	30,433	31,181
14 Med	22,164	23,957	25,750	27,543	29,335	31,128	32,921	35,365	37,808	40,251	42,775	45,299	47,823	50,347	52,871	55,395	57,919	60,443	62,967	65,491	68,015	70,539
15 Med	0	0	1,419	2,839	4,258	5,678	7,097	8,517	9,937	11,356	12,775	14,194	15,613	17,032	18,451	19,870	21,289	22,708	24,127	25,546	26,965	28,384
16 Med	0	0	0	0	0	0	0	0	2,236	4,472	6,708	8,944	11,180	13,416	15,652	17,888	20,124	22,360	24,596	26,832	29,068	31,304
17 Med	0	0	0	0	0	0	0	0	2,191	4,382	6,574	8,765	10,956	13,147	15,338	17,529	19,720	21,911	24,102	26,293	28,484	30,675
18 Med	0	0	14,032	28,064	42,097	56,129	70,161	84,193	98,225	112,257	126,289	140,321	154,353	168,385	182,417	196,449	210,481	224,513	238,545	252,577	266,609	280,641
19 Med	0	0	0	0	0	0	0	0	1,092	3,784	5,676	7,568	9,460	11,352	13,244	15,136	17,028	18,920	20,812	22,704	24,596	26,488
20 Med	0	0	0	0	0	0	0	0	888	1,777	2,665	3,554	4,442	5,330	6,219	7,107	7,996	8,884	9,773	10,661	11,550	12,438
21 Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
22 Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
23 Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	112,636	124,719	140,577	172,375	196,173	224,940	251,083	281,690	340,281	376,885	405,482	431,079	456,676	482,273	507,870	533,467	559,064	584,661	610,258	635,855	661,452	687,049

Prediction of Service Population and Demand

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
Service Ratio (%)																							
Amphor Tambon																							
1 Huang																							
1 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
2 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
3 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
4 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
5 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
6 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
7 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
8 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
9 Med	0	5	5	7	8	9	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
10 Med	0	10	12	14	16	18	20	21	22	23	24	25	26	28	31	34	37	40	44	48	52	56	60
11 Med	0	10	12	14	16	18	20	21	22	23	24	25	26	28	31	34	37	40	44	48	52	56	60
12 HI	80	69	62	63	65	66	68	69	71	72	74	75	77	78	80	81	83	84	86	87	89	90	90
14 Med	0	0	2	4	6	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
2 Sae Nok																							
1 Low	0	0	0	0	0	0	0	4	8	12	16	20	23	26	29	32	35	38	41	44	47	50	
2 Low	0	0	0	0	0	0	0	4	8	12	16	20	23	26	29	32	35	38	41	44	47	50	
3 Low	0	0	0	0	0	0	0	4	8	12	16	20	23	26	29	32	35	38	41	44	47	50	
5 Low	10	12	14	15	17	18	20	20	20	20	20	20	23	26	28	32	35	38	41	44	47	50	
6 Low	10	12	14	15	17	18	20	22	24	26	28	30	31	32	33	34	35	36	41	44	47	50	
7 Low	10	12	14	15	17	18	20	22	24	26	28	30	31	32	33	34	35	36	41	44	47	50	
8 Med	10	12	14	15	17	18	20	22	24	26	28	30	31	32	33	34	35	40	45	50	55	60	
3 Lad Lue Kaeo																							
1 Low	0	0	0	0	0	0	0	0	0	0	10	20	23	26	29	32	35	38	41	44	47	50	
3 Low	0	0	0	0	0	0	0	0	0	0	10	20	23	26	29	32	35	38	41	44	47	50	
6 Low	0	0	0	0	0	0	0	0	0	0	10	20	23	26	29	32	35	38	41	44	47	50	
4 Thanaburi																							
1 HI	40	40	43	45	48	50	53	55	58	60	63	65	68	70	73	75	78	80	83	85	88	90	
2 Med	0	0	0	0	0	5	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
3 & 4 Med	10	10	13	16	19	22	25	26	27	28	29	30	32	34	36	38	40	44	48	52	56	60	
5 Lam Lata																							
1 Med	50	50	51	51	52	52	53	53	54	54	55	55	56	56	57	57	58	58	59	59	60	60	
2 Med	0	0	2	4	6	8	10	13	16	19	22	25	28	31	34	37	40	44	48	52	56	60	
3 Med	0	0	0	0	0	0	0	0	5	10	15	20	25	28	31	34	37	40	44	48	52	56	60
4 Med	0	0	0	0	0	0	0	0	5	10	15	20	25	28	31	34	37	40	44	48	52	56	60
6 Khlong Luang																							
1 Med	0	0	6	12	18	24	30	32	34	36	38	40	42	44	46	48	50	52	54	56	58	60	
2 Med	0	0	0	0	0	0	0	5	10	15	20	25	28	31	34	37	40	44	48	52	56	60	
3 Med	0	0	0	0	0	0	0	5	10	15	20	25	28	31	34	37	40	44	48	52	56	60	

Patum Thani & Prachathipat

Prediction of Service Population and Demand

Area	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
Served Population by Tambon																							
Aephor Tambon																							
1 Huang	0	0	0	0	0	415	1,006	1,360	1,768	2,229	2,704	3,212	3,725	4,265	4,833	5,428	6,050	6,696	7,368	8,056	8,756	9,451	10,142
Zone 6	0	0	0	0	0	298	615	844	1,093	1,362	1,652	1,963	2,276	2,607	2,953	3,317	3,697	4,089	4,494	4,912	5,343	5,787	6,243
Zone 5	0	0	0	0	0	159	330	444	563	693	828	970	1,114	1,265	1,422	1,585	1,754	1,928	2,107	2,291	2,480	2,673	2,870
Zone 4	0	0	0	0	0	306	645	893	1,140	1,418	1,716	2,034	2,356	2,694	3,050	3,421	3,806	4,204	4,615	5,039	5,475	5,924	6,384
Zone 3	0	0	0	0	0	190	255	325	398	476	558	641	727	817	911	1,008	1,108	1,210	1,314	1,421	1,531	1,644	1,760
Zone 2	0	0	0	0	0	162	325	451	574	704	840	985	1,131	1,284	1,444	1,609	1,780	2,004	2,235	2,475	2,722	2,978	3,244
Zone 1	0	0	0	0	0	272	579	797	1,025	1,264	1,574	1,874	2,176	2,484	2,829	3,181	3,549	4,025	4,524	5,044	5,587	6,151	6,734
Zone 6	0	0	0	0	0	223	463	623	792	972	1,161	1,360	1,563	1,775	1,994	2,223	2,460	2,763	3,086	3,419	3,761	4,115	4,484
Zone 5	0	0	0	0	0	485	571	783	1,014	1,264	1,533	1,820	2,111	2,417	2,738	3,075	3,427	3,883	4,359	4,856	5,374	5,912	6,468
Zone 4	0	286	367	466	553	657	770	864	963	1,067	1,177	1,293	1,506	1,731	1,970	2,220	2,483	2,823	3,179	3,552	3,942	4,348	4,768
Zone 3	0	213	273	340	412	489	573	643	717	796	878	964	1,053	1,291	1,489	1,656	1,852	2,106	2,372	2,650	2,941	3,244	3,558
Zone 2	9,341	9,555	10,228	10,917	11,423	12,046	12,655	13,358	14,048	14,755	15,479	16,219	16,966	17,729	18,510	19,307	20,121	20,902	21,699	22,508	23,333	24,172	25,024
Zone 1	0	0	43	140	289	308	748	1,025	1,326	1,651	2,000	2,373	2,751	3,148	3,565	4,001	4,458	5,049	5,667	6,311	6,981	7,678	8,391
2 Sam Kok																							
Zone 5	0	0	0	0	0	0	0	24	95	214	381	596	852	791	891	993	1,098	1,204	1,312	1,421	1,533	1,647	1,763
Zone 4	0	0	0	0	0	0	0	15	62	139	247	386	449	512	577	644	711	780	850	921	995	1,067	1,141
Zone 3	0	0	0	0	0	0	0	15	60	134	239	373	434	495	558	622	687	754	821	890	960	1,031	1,103
Zone 2	91	110	126	143	160	177	195	197	199	201	204	206	213	213	208	343	379	416	453	491	530	569	609
Zone 1	138	167	192	217	242	268	295	328	362	397	432	468	499	530	553	575	600	631	661	691	714	803	882
Zone 6	292	245	281	318	355	393	432	481	531	582	634	685	717	748	779	811	843	924	1,007	1,091	1,177	1,264	1,351
Zone 5	655	795	911	1,028	1,148	1,270	1,394	1,548	1,687	2,030	2,195	2,290	2,366	2,483	2,581	2,681	3,091	3,507	3,931	4,361	4,798	5,241	5,684
3 Lad Lam Kae																							
Zone 8	0	0	0	0	0	0	0	0	0	353	881	1,037	1,208	1,368	1,543	1,724	1,911	2,105	2,304	2,510	2,723	2,943	
Zone 7	0	0	0	0	0	0	0	0	0	175	428	516	596	680	767	857	950	1,046	1,146	1,248	1,354	1,464	
Zone 6	0	0	0	0	0	0	0	0	0	221	553	641	731	822	914	1,008	1,104	1,200	1,298	1,398	1,499	1,601	
4 Thanyaburi																							
Zone 1	17,282	18,528	21,060	23,754	26,609	29,621	32,807	36,599	40,591	44,783	49,175	53,767	58,138	62,680	67,393	72,216	77,331	82,351	87,529	92,654	98,358	104,009	109,701
Zone 2	0	0	0	0	0	340	731	1,051	1,417	1,830	2,288	2,794	3,284	3,808	4,356	4,935	5,578	6,380	7,226	8,117	9,052	10,031	11,054
Zone 3	1,517	1,680	2,266	2,890	3,552	4,351	4,839	5,383	5,792	6,216	6,655	7,109	7,790	8,498	9,229	9,988	10,772	12,134	13,567	15,012	16,529	18,097	19,711
5 Lan Lukha																							
Zone 4	11,082	11,919	13,029	14,102	15,195	16,311	17,448	18,895	20,352	21,849	23,355	24,881	26,212	27,565	28,941	30,340	31,761	33,093	34,439	35,801	37,178	38,570	39,984
Zone 3	0	0	28	114	255	484	710	994	1,312	1,662	2,046	2,462	2,876	3,315	3,779	4,269	4,784	5,468	6,146	6,878	7,642	8,443	9,278
Zone 2	0	0	0	0	0	0	0	113	461	1,015	1,805	2,820	3,230	3,655	4,095	4,551	5,022	5,636	6,271	6,926	7,601	8,296	9,021
Zone 1	0	0	0	0	0	0	0	110	438	986	1,753	2,739	3,107	3,550	3,977	4,420	4,877	5,473	6,089	6,725	7,381	8,057	8,754
6 Khlong Luang																							
Zone 2	0	0	842	3,368	7,517	13,471	21,046	24,213	27,598	31,203	35,029	39,074	41,599	44,178	46,811	49,499	52,241	55,037	57,888	60,793	63,752	66,765	69,834
Zone 1	0	0	0	0	0	0	0	95	318	851	1,514	2,365	2,732	3,117	3,519	3,940	4,370	4,946	5,539	6,155	6,794	7,458	8,147
Zone 3	0	0	0	0	0	0	0	44	178	400	711	1,111	1,256	1,426	1,591	1,761	1,936	2,165	2,403	2,641	2,879	3,117	3,355
Total																							
	40,415	43,659	49,648	57,605	67,172	82,527	99,556	120,484	126,913	142,933	161,263	181,529	197,205	213,450	230,293	247,704	265,993	286,452	307,889	330,002	353,792	376,270	400,000
Average Service Ratio(%)																							
	35.9	35.0	33.4	33.5	34.5	31.1	34.2	35.2	35.4	37.9	39.8	41.8	44.2	46.5	48.8	51.1	53.5	56.2	59.0	61.7	64.5	67.2	70.0

Palau Thani & Prachathipat

Prediction of Service Population and Demand

Year	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Zone 1 HI	17,282	18,528	21,000	23,754	26,609	29,827	32,807	36,599	40,591	44,783	49,175	53,767	58,558	63,593	67,393	72,216	77,331	82,351	87,529	92,954	98,358	104,309
Med	0	0	126	505	1,137	2,021	3,157	4,632	6,410	8,681	11,440	14,681	18,402	22,613	27,314	32,515	38,216	44,417	51,118	58,319	66,020	74,221
Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 2 HI	0	0	718	2,363	5,441	11,459	17,891	26,720	37,944	51,568	68,497	89,721	116,240	149,059	188,278	234,097	287,516	349,635	421,454	503,973	598,192	705,011
Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 3 HI	1,617	1,680	2,266	2,890	3,652	4,592	5,720	7,209	9,045	11,234	13,774	16,666	19,909	23,504	27,450	31,748	36,399	41,404	46,863	52,776	59,147	66,076
Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 4 HI	11,082	11,919	13,068	14,215	15,461	16,765	18,188	20,112	22,563	25,512	28,959	32,903	37,347	42,291	47,735	53,679	60,123	67,167	74,911	83,355	92,599	102,643
Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 5 HI	0	0	0	0	0	321	665	895	1,139	1,396	1,668	1,954	2,246	2,550	2,865	3,194	3,534	3,977	4,436	4,912	5,404	5,912
Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Zone 6 HI	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Zone 7 HI	9,347	9,655	10,238	10,917	11,423	12,046	12,665	13,358	14,048	14,755	15,479	16,219	16,966	17,720	18,510	19,307	20,121	20,962	21,838	22,568	23,333	24,133
Med	556	1,295	1,595	1,964	2,402	3,209	4,063	4,863	5,726	6,644	7,617	8,646	9,730	10,873	12,224	13,533	14,901	16,351	17,884	19,084	21,300	23,599
Low	430	522	599	677	757	838	922	1,005	1,092	1,180	1,269	1,359	1,445	1,531	1,618	1,707	1,797	1,870	1,947	2,021	2,093	
Zone 8 HI	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Med	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Low	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total	40,415	43,659	49,648	57,685	67,172	82,521	99,556	112,454	126,919	142,933	161,529	181,529	197,205	213,450	230,292	247,704	265,692	284,492	307,889	330,005	352,799	376,270

Unit Water Consumption (lpcd)

High Deas Area	167	170	173	176	179	182	185	188	191	194	197	200	203	206	209	212	215	218	221	224	227	230
Med Deas Area	95	100	104	108	112	116	120	124	128	132	136	140	142	144	146	148	150	152	154	156	158	160
Low Deas Area	77	80	83	85	89	92	95	98	101	104	107	110	113	116	119	122	125	128	131	134	137	140

Domestic Water Consumption by Zone

Zone 1	2,885	3,150	3,557	4,235	4,890	5,627	6,448	7,331	8,283	9,305	10,402	11,574	12,880	13,856	15,110	16,421	17,302	18,240	19,240	20,251	22,344	23,991
Zone 2	0	0	74	309	721	1,328	2,147	2,569	3,074	3,666	4,352	5,136	5,580	6,062	6,555	7,071	7,608	8,401	9,251	10,159	11,114	12,123
Zone 3	155	153	235	312	393	533	668	798	923	1,062	1,216	1,366	1,512	1,772	1,885	2,211	2,453	2,885	3,365	3,886	4,451	5,063
Zone 4	1,084	1,198	1,358	1,535	1,731	1,945	2,179	2,494	2,888	3,368	3,935	4,466	5,055	5,464	5,955	6,450	6,957	7,745	8,511	9,463	10,406	11,406
Zone 5	0	0	0	0	0	37	80	116	168	235	320	423	546	660	748	842	971	1,109	1,258	1,412	1,582	
Zone 6	0	0	0	0	0	192	420	593	799	1,073	1,500	1,800	2,097	2,405	2,735	3,086	3,633	4,231	4,283	5,591	6,382	
Zone 7	1,637	1,813	1,985	2,174	2,381	2,642	2,921	3,213	3,528	3,882	4,221	4,604	4,996	5,410	5,846	6,304	6,786	7,463	8,166	8,932	9,747	10,614
Zone 8	0	0	0	0	0	0	0	0	0	80	206	248	293	342	393	445	506	570	636	706	780	
Total	5,782	6,328	7,310	8,586	10,121	12,303	14,081	17,114	19,652	22,512	25,792	29,476	32,433	35,560	38,859	42,335	45,391	50,829	51,551	67,424	73,657	

Prediction of Service Population and Demand

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Water Consumption for Gov/Inst/Commercial (based on Population Ratio by Zone)																						
A. Government (unit consumption = 5 l/day/pop. in service area)	241	265	317	362	402	508	576	614	652	684	713	729	746	762	779	797	806	816	826	837	848	
Zone 1	0	0	11	43	93	184	282	330	366	402	439	446	453	460	467	474	479	485	490	495	501	
Zone 2	23	24	34	43	51	74	84	91	99	106	112	118	125	132	139	146	153	165	176	187	198	209
Zone 3	154	171	195	212	224	269	286	310	336	364	393	402	410	418	426	434	442	449	455	464	471	
Zone 4	0	0	0	0	0	5	10	13	19	25	32	40	43	47	50	53	56	60	63	66	69	72
Zone 5	0	0	0	0	0	27	51	88	85	101	117	132	144	157	169	181	192	207	221	235	249	263
Zone 6	145	164	186	201	211	258	273	286	296	306	314	319	325	331	338	344	351	354	361	374	384	393
Zone 8	0	0	0	0	0	0	0	0	0	0	9	22	25	27	29	32	34	35	37	38	40	41
Sub-Total	553	624	743	862	981	1,325	1,455	1,598	1,741	1,884	2,027	2,170	2,233	2,295	2,359	2,422	2,485	2,548	2,611	2,674	2,737	2,800

B. School (Number of Student = X % of population in service area)

Ratio (X) =	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
B-1 Number of student	3,633	10,591	12,681	14,658	16,063	20,320	21,031	22,874	24,551	26,085	27,372	28,517	29,559	29,232	30,002	31,173	31,862	32,237	32,534	33,051	33,455	33,935
Zone 1	0	0	428	1,711	3,729	7,352	10,462	11,781	13,181	14,647	16,082	17,546	17,828	18,113	18,399	18,685	18,973	19,174	19,382	19,597	19,818	20,045
Zone 2	901	960	1,356	1,727	2,056	2,946	3,345	3,658	3,957	4,243	4,497	4,735	5,015	5,294	5,570	5,844	6,117	6,527	7,045	7,496	7,937	8,371
Zone 3	6,177	6,347	7,815	8,496	8,945	10,764	10,618	11,435	12,384	13,454	14,563	15,733	16,061	16,387	16,715	17,045	17,375	17,665	17,958	18,256	18,556	18,858
Zone 4	0	0	0	0	0	206	329	540	744	994	1,275	1,533	1,731	1,871	2,005	2,133	2,256	2,369	2,516	2,639	2,752	2,874
Zone 5	0	0	0	0	0	1,055	2,045	2,718	3,388	4,047	4,688	5,261	5,770	6,286	6,732	7,228	7,697	8,285	8,858	9,420	9,970	10,512
Zone 6	5,816	6,558	7,435	8,043	8,442	10,333	10,328	10,932	11,453	11,907	12,253	12,542	12,770	13,069	13,257	13,512	13,774	14,169	14,561	14,952	15,341	15,728
Zone 7	0	0	0	0	0	0	0	0	0	0	317	895	994	1,087	1,116	1,261	1,343	1,411	1,475	1,539	1,606	1,659
Zone 8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	22,527	24,956	29,715	34,475	39,235	52,388	58,219	63,938	69,651	75,377	81,056	86,816	89,333	91,849	94,356	96,883	99,399	101,916	104,432	106,949	109,465	111,982

B-2 Water Consumption (unit consumption = 20 l/day/student)

Zone 1	193	212	254	290	321	406	421	457	491	522	547	570	583	596	610	623	637	645	653	661	670	679
Zone 2	0	0	9	34	75	141	209	236	264	293	322	351	357	362	368	374	379	383	388	392	396	401
Zone 3	18	19	27	35	41	59	67	73	79	85	90	95	100	106	111	117	122	132	141	150	159	167
Zone 4	124	137	155	170	179	215	212	229	248	269	291	315	321	328	334	341	348	353	359	365	371	377
Zone 5	0	0	0	0	0	4	8	11	15	20	26	32	35	37	40	43	45	48	50	53	55	57
Zone 6	0	0	0	0	0	21	41	54	68	81	93	105	115	125	135	145	154	165	177	185	199	210
Zone 7	116	131	149	161	169	207	207	229	238	245	251	255	260	265	270	275	283	291	299	307	315	315
Zone 8	0	0	0	0	0	0	0	0	0	0	8	18	20	22	24	25	27	28	30	31	32	33
Sub-Total	451	499	594	689	785	1,060	1,164	1,279	1,393	1,508	1,622	1,736	1,807	1,837	1,867	1,938	1,988	2,036	2,089	2,139	2,189	2,240

Patum Thanl & Prachathipat

Prediction of Service Population and Demand

Year	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
C. Hospital Use																						
	(unit consumption = 1.5 cu m/d/bed)																					
	(Population per bed = 345 person/bed)																					
Zone 1	265	230	276	315	349	442	457	497	534	567	595	620	634	646	663	672	693	701	709	719	728	738
Zone 2	0	0	9	37	81	160	227	256	287	318	350	381	388	394	400	406	412	417	421	425	431	436
Zone 3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 4	134	149	170	185	194	234	231	249	269	282	317	342	349	356	363	371	378	384	390	397	403	410
Zone 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 7	126	143	162	175	184	225	225	238	249	259	266	273	273	283	286	294	299	303	311	325	333	342
Zone 8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sub-Total	490	543	646	749	853	1,152	1,268	1,300	1,514	1,639	1,763	1,887	1,942	1,997	2,051	2,106	2,161	2,216	2,270	2,325	2,380	2,434
A-Per Total of Governmental/Institutional Consumption																						
Zone 1	643	707	846	968	1,072	1,356	1,404	1,527	1,639	1,741	1,827	1,903	1,946	1,990	2,035	2,080	2,125	2,161	2,178	2,206	2,235	2,265
Zone 2	0	0	29	114	249	491	638	766	880	978	1,074	1,171	1,190	1,208	1,228	1,247	1,265	1,280	1,294	1,308	1,323	1,338
Zone 3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 4	412	457	522	557	597	718	709	763	827	888	972	1,050	1,072	1,094	1,116	1,138	1,159	1,179	1,199	1,218	1,235	1,259
Zone 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 7	388	438	495	531	563	690	689	730	784	795	818	837	852	869	885	902	919	946	972	998	1,024	1,050
Zone 8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	1,503	1,666	1,903	2,301	2,518	3,355	3,885	4,267	4,649	5,031	5,412	5,794	5,962	6,130	6,298	6,466	6,634	6,802	6,970	7,138	7,306	7,474
Commercial Water Consumption																						
	(unit consumption = 10 l/day/pop in service area)																					
Zone 1	482	530	634	725	803	1,016	1,052	1,144	1,228	1,304	1,369	1,426	1,458	1,491	1,525	1,559	1,593	1,612	1,632	1,652	1,674	1,691
Zone 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 3	45	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48
Zone 4	309	342	391	425	447	536	531	572	619	673	728	787	803	819	835	852	869	883	898	913	928	943
Zone 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 7	291	328	372	402	422	517	516	547	573	595	613	627	639	650	663	676	689	708	728	743	767	786
Zone 8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	1,126	1,248	1,406	1,724	1,962	2,645	2,911	3,197	3,483	3,769	4,055	4,341	4,467	4,592	4,718	4,844	4,970	5,096	5,222	5,347	5,473	5,599

Prediction of Service Population and Demand

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
Zone 1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 2	0	0	0	0	3,184	3,278	3,372	3,467	3,561	3,656	3,750	3,844	3,939	4,033	4,128	4,222	4,317	4,411	4,506	4,600	4,695	0	0
Zone 3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 6	0	0	0	0	2,417	2,598	2,779	2,960	3,140	3,321	3,502	3,683	3,864	4,044	4,225	4,406	4,586	4,766	4,945	5,125	5,305	0	0
Zone 7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	5,601	5,876	6,151	6,426	6,702	6,977	7,252	7,527	7,802	8,078	8,353	8,628	8,902	9,177	9,451	9,725	10,000	0	0

Other Use (4.5 % of Domestic & Governmental Use)

Zone 1	162	177	207	239	274	321	381	407	456	508	553	620	673	729	789	851	917	984	1,055	1,129	1,206	1,282
Zone 2	0	0	5	19	45	84	131	154	182	214	250	290	312	334	358	383	408	446	485	527	572	619
Zone 3	10	11	15	20	25	34	42	48	55	62	70	78	88	98	108	120	132	153	176	202	229	259
Zone 4	68	76	86	97	107	123	133	150	171	196	226	260	281	303	325	349	374	411	450	491	536	583
Zone 5	0	0	0	0	0	2	5	7	10	14	19	24	28	32	36	41	46	52	59	66	74	82
Zone 6	0	0	0	0	0	12	26	36	47	59	72	87	101	116	131	146	166	193	222	254	288	325
Zone 7	94	104	114	125	135	153	166	181	197	214	232	250	263	289	313	331	354	385	420	457	495	537
Zone 8	0	0	0	0	0	0	0	0	0	5	12	14	14	17	19	22	25	27	31	34	37	41
Total	334	368	427	500	586	729	863	984	1,118	1,267	1,435	1,622	1,766	1,918	2,077	2,245	2,421	2,652	2,883	3,150	3,438	3,732

Patum Thani & Prachattipat

Prediction of Service Population and Demand

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Industrial Water Consumption																						
Mava Nakorn (Phase 1-3)	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720	18,720
Connection Ratio	0.00	0.00	0.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Mava Nakorn (Expansion)	0	936	1,872	2,808	3,744	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680	4,680
Connection Ratio	0.00	0.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Exis. Factory (Other than M.Nakorn)	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413	30,413
Connection Ratio	0.00	0.00	0.00	0.00	0.00	0.10	0.20	0.30	0.40	0.50	0.60	0.70	0.80	0.90	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
B.I.P.	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808	2,808
Connection Ratio	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Future (in DTCP Bangkok)	0	217	435	653	870	1,087	1,305	1,522	1,740	1,957	2,175	2,392	2,609	2,827	3,044	3,262	3,479	3,697	3,914	4,132	4,349	4,567
Connection Ratio	0.00	0.00	0.00	0.00	0.00	0.25	0.40	0.56	0.71	0.87	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Future (in DTCP Bangkok)	0	208	415	624	832	1,040	1,248	1,456	1,664	1,872	2,080	2,288	2,496	2,704	2,912	3,120	3,328	3,536	3,744	3,952	4,160	4,368
Connection Ratio	0.00	0.00	0.00	0.00	0.00	0.25	0.40	0.56	0.71	0.87	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Future (Other Area)	0	450	900	1,350	1,800	2,250	2,700	3,150	3,600	4,050	4,500	4,950	5,400	5,850	6,300	6,750	7,200	7,650	8,100	8,550	9,000	9,450
Connection Ratio	0.00	0.00	0.00	0.00	0.00	0.25	0.40	0.50	0.57	0.63	0.70	0.73	0.75	0.77	0.77	1.00	1.00	1.00	1.00	1.00	1.00	1.00
Service Status by Zone (1=Served, 0=Observed)																						
Zone 1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Zone 2	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Zone 3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Zone 4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Zone 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Zone 8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

Future Development in DTCP's Industrial Area (DTCP's Industrial Area: 720 ha (480ha x 50% at Thanyaburi + 480 ha at Bang Krabi) x 30 cu m/ha x 0.65)
 Future Development outside DTCP's Industrial Area (400 ha x 30 cu m/ha)

Ratio of Consumption by Zone

Zone	Mava Existing Factories	B.I.P. (Bang)	Future (Bang)	Future (Other)
Zone 1	0.00	0.301	0.00	0.00
Zone 2	1.00	0.144	0.00	0.00
Zone 3	0.00	0.000	0.00	0.17
Zone 4	0.00	0.000	0.00	0.04
Zone 5	0.00	0.264	0.00	0.00
Zone 6	0.00	0.105	1.00	0.00
Zone 7	0.00	0.186	0.00	0.21
Zone 8	0.00	0.000	0.00	0.33
	1.00	1.000	1.00	1.00

Petua Thani & Prachinburi

Prediction of Service Population and Demand

Item	1980	1981	1982	1983	1984	1985	1986	1987	1988	1989	1990	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Industrial Water Consumption (cu m/d)																						
Zone 1	0	0	0	0	0	1,123	2,247	3,370	4,494	5,617	6,741	7,864	8,987	10,111	11,234	12,356	12,274	12,422	12,690	12,892	13,106	13,314
Zone 2	0	0	0	0	0	22,039	24,351	24,426	25,302	25,777	26,253	26,728	27,204	27,679	28,154	28,304	28,342	28,379	28,417	28,454	28,492	28,529
Zone 3	0	0	0	0	0	75	150	225	300	375	450	525	600	675	750	1,050	1,125	1,200	1,275	1,350	1,425	1,500
Zone 4	0	0	0	0	0	37	34	51	68	84	101	118	135	152	169	236	253	270	287	304	321	338
Zone 5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Zone 6	0	0	0	0	0	574	1,148	1,723	2,297	2,871	3,445	4,019	4,593	5,167	5,741	6,315	6,889	7,463	8,037	8,611	9,185	9,759
Zone 7	0	0	0	0	0	555	1,319	1,978	2,638	3,297	3,957	4,616	5,275	5,935	6,594	7,253	7,913	8,572	9,231	9,891	10,550	11,210
Zone 8	0	0	0	0	0	0	0	0	0	0	0	300	1,050	1,200	1,350	2,100	2,350	2,400	2,550	2,700	2,850	3,000
Total	0	0	0	0	0	25,231	30,934	34,700	38,467	42,042	45,042	48,709	53,625	57,542	61,459	65,376	62,877	65,753	70,629	71,504	72,379	73,255

Prediction of Service Population and Demand

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
Total Daily Average Consumption by Zone (cc m/d)																						
Zone 1	4,173	4,564	5,344	6,167	7,040	8,443	11,511	13,179	15,069	16,416	20,001	23,367	25,753	28,163	30,633	32,918	34,712	35,410	38,305	40,219	42,213	44,238
Zone 2	0	0	129	328	1,201	26,393	31,128	32,298	33,563	34,928	36,388	37,953	39,600	40,128	41,249	42,067	42,195	43,187	44,833	45,934	47,092	48,307
Zone 3	210	291	409	533	662	805	1,269	1,498	1,739	1,994	2,261	2,542	2,846	3,163	3,493	3,833	4,183	4,543	4,913	5,293	5,683	6,083
Zone 4	1,853	2,073	2,357	2,624	2,882	3,341	3,585	4,029	4,572	5,219	5,968	6,822	7,785	8,862	10,055	11,362	12,782	14,315	15,962	17,723	19,599	21,491
Zone 5	0	0	0	0	0	906	1,815	2,113	2,173	2,334	2,541	2,793	3,091	3,435	3,825	4,260	4,740	5,265	5,835	6,450	7,110	7,815
Zone 6	0	0	0	0	0	3,320	4,431	5,447	6,463	10,364	11,455	12,571	13,668	14,764	15,921	17,122	18,382	19,699	21,075	22,512	23,914	24,315
Zone 7	2,430	2,682	2,957	3,238	3,502	4,061	5,611	6,649	7,459	8,764	9,940	10,934	12,031	13,152	14,291	15,482	16,811	18,289	19,919	21,699	23,534	25,415
Zone 8	0	0	0	0	0	0	0	0	0	1,029	1,373	1,576	1,767	1,998	2,663	2,850	3,100	3,323	3,550	3,781	4,015	4,253
Total	8,726	9,409	11,206	13,090	15,381	51,049	59,358	66,413	73,195	83,322	93,300	102,110	109,697	117,461	125,405	133,119	138,397	144,925	151,738	158,825	166,221	174,592

Unaccounted-for Water Ratio (%)

For Zone 1 and 7 only	26	26	26	26	25	25	25	25	24	24	23	23	23	22	22	21	21	21	21	20	20	20
For Other Zones	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20

Total Daily Average Demand by Zone (cc m/d)

Zone 1	5,639	6,167	7,202	8,289	9,437	12,625	15,349	18,275	21,239	24,247	27,285	30,373	33,273	35,231	39,249	41,957	43,539	45,049	48,243	50,535	52,838	55,360
Zone 2	0	0	161	560	1,502	35,491	38,910	40,372	41,954	43,660	45,405	47,141	48,787	50,160	51,584	52,984	54,374	56,042	57,418	58,265	60,384	62,844
Zone 3	338	364	511	667	828	1,232	1,906	1,872	2,174	2,493	2,826	3,178	3,557	3,953	4,367	4,799	5,229	5,653	6,049	6,499	6,999	7,499
Zone 4	2,316	2,592	2,946	3,280	3,602	4,176	4,381	5,037	5,715	6,524	7,457	8,527	9,457	10,501	11,281	12,027	13,110	14,263	15,487	16,785	18,159	19,599
Zone 5	0	0	0	0	0	1,132	2,260	3,391	4,542	5,720	6,926	8,160	9,332	10,509	11,692	12,214	12,451	12,700	12,963	13,238	13,528	13,828
Zone 6	0	0	0	0	0	4,150	5,538	6,809	8,112	12,955	14,319	15,714	17,065	18,480	19,951	21,904	24,223	25,735	27,215	28,767	30,394	32,094
Zone 7	3,224	3,624	3,999	4,352	4,695	6,231	7,482	8,818	10,155	11,591	12,846	14,200	15,544	16,965	18,263	19,316	20,014	21,023	22,089	23,214	24,400	25,648
Zone 8	0	0	0	0	0	0	0	0	0	1,286	1,716	1,973	2,234	2,498	3,326	3,500	3,675	4,154	4,467	4,726	5,019	5,309
Total	11,577	12,716	14,820	17,248	20,063	65,037	75,614	84,574	93,692	107,100	118,430	129,309	138,706	148,287	158,051	167,172	173,795	181,827	190,275	199,182	208,469	218,140

Total Daily Maximum Demand by Zone (cc m/d)

Peak Factor = 1.20	Zone 1	Zone 2	Zone 3	Zone 4	Zone 5	Zone 6	Zone 7	Zone 8	Total
Zone 1	6,767	7,400	6,643	9,947	11,324	15,150	18,418	21,330	25,481
Zone 2	0	0	194	793	1,802	42,590	46,892	48,447	50,345
Zone 3	408	435	514	600	994	1,418	1,903	2,247	2,800
Zone 4	2,779	3,110	3,535	3,936	4,323	5,011	5,378	6,044	6,858
Zone 5	0	0	0	0	0	1,359	2,722	4,070	5,450
Zone 6	0	0	0	0	0	4,980	6,645	8,171	9,734
Zone 7	3,941	4,349	4,798	5,222	5,633	7,477	8,910	10,582	12,188
Zone 8	0	0	0	0	0	0	0	0	1,543
Total	13,893	15,235	17,184	20,697	24,076	78,045	90,137	101,489	112,870

Treatment Plant Capacity (cc m/day)

Starting in 1995	Line 1	Line 2	Line 3	Line 4	Total Capacity
70,750	70,750	70,750	70,750	70,750	70,750
141,500	141,500	141,500	141,500	141,500	141,500
212,250	212,250	212,250	212,250	212,250	212,250
283,000	283,000	283,000	283,000	283,000	283,000
353,750	353,750	353,750	353,750	353,750	353,750
424,500	424,500	424,500	424,500	424,500	424,500
495,250	495,250	495,250	495,250	495,250	495,250
566,000	566,000	566,000	566,000	566,000	566,000
636,750	636,750	636,750	636,750	636,750	636,750
707,500	707,500	707,500	707,500	707,500	707,500
778,250	778,250	778,250	778,250	778,250	778,250
849,000	849,000	849,000	849,000	849,000	849,000
919,750	919,750	919,750	919,750	919,750	919,750
990,500	990,500	990,500	990,500	990,500	990,500
1,061,250	1,061,250	1,061,250	1,061,250	1,061,250	1,061,250
1,132,000	1,132,000	1,132,000	1,132,000	1,132,000	1,132,000
1,202,750	1,202,750	1,202,750	1,202,750	1,202,750	1,202,750
1,273,500	1,273,500	1,273,500	1,273,500	1,273,500	1,273,500
1,344,250	1,344,250	1,344,250	1,344,250	1,344,250	1,344,250
1,415,000	1,415,000	1,415,000	1,415,000	1,415,000	1,415,000
1,485,750	1,485,750	1,485,750	1,485,750	1,485,750	1,485,750
1,556,500	1,556,500	1,556,500	1,556,500	1,556,500	1,556,500
1,627,250	1,627,250	1,627,250	1,627,250	1,627,250	1,627,250
1,698,000	1,698,000	1,698,000	1,698,000	1,698,000	1,698,000
1,768,750	1,768,750	1,768,750	1,768,750	1,768,750	1,768,750
1,839,500	1,839,500	1,839,500	1,839,500	1,839,500	1,839,500
1,910,250	1,910,250	1,910,250	1,910,250	1,910,250	1,910,250
1,981,000	1,981,000	1,981,000	1,981,000	1,981,000	1,981,000
2,051,750	2,051,750	2,051,750	2,051,750	2,051,750	2,051,750
2,122,500	2,122,500	2,122,500	2,122,500	2,122,500	2,122,500
2,193,250	2,193,250	2,193,250	2,193,250	2,193,250	2,193,250
2,264,000	2,264,000	2,264,000	2,264,000	2,264,000	2,264,000
2,334,750	2,334,750	2,334,750	2,334,750	2,334,750	2,334,750
2,405,500	2,405,500	2,405,500	2,405,500	2,405,500	2,405,500
2,476,250	2,476,250	2,476,250	2,476,250	2,476,250	2,476,250
2,547,000	2,547,000	2,547,000	2,547,000	2,547,000	2,547,000
2,617,750	2,617,750	2,617,750	2,617,750	2,617,750	2,617,750
2,688,500	2,688,500	2,688,500	2,688,500	2,688,500	2,688,500
2,759,250	2,759,250	2,759,250	2,759,250	2,759,250	2,759,250
2,830,000	2,830,000	2,830,000	2,830,000	2,830,000	2,830,000
2,900,750	2,900,750	2,900,750	2,900,750	2,900,750	2,900,750
2,971,500	2,971,500	2,971,500	2,971,500	2,971,500	2,971,500
3,042,250	3,042,250	3,042,250	3,042,250	3,042,250	3,042,250
3,113,000	3,113,000	3,113,000	3,113,000	3,113,000	3,113,000
3,183,750	3,183,750	3,183,750	3,183,750	3,183,750	3,183,750
3,254,500	3,254,500	3,254,500	3,254,500	3,254,500	3,254,500
3,325,250	3,325,250	3,325,250	3,325,250	3,325,250	3,325,250
3,396,000	3,396,000	3,396,000	3,396,000	3,396,000	3,396,000
3,466,750	3,466,750	3,466,750	3,466,750	3,466,750	3,466,750
3,537,500	3,537,500	3,537,500	3,537,500	3,537,500	3,537,500
3,608,250	3,608,250	3,608,250	3,608,250	3,608,250	3,608,250
3,679,000	3,679,000	3,679,000	3,679,000	3,679,000	3,679,000
3,749,750	3,749,750	3,749,750	3,749,750	3,749,750	3,749,750
3,820,500	3,820,500	3,820,500	3,820,500	3,820,500	3,820,500
3,891,250	3,891,250	3,891,250	3,891,250	3,891,250	3,891,250
3,962,000	3,962,000	3,962,000	3,962,000	3,962,000	3,962,000
4,032,750	4,032,750	4,032,750	4,032,750	4,032,750	4,032,750
4,103,500	4,103,500	4,103,500	4,103,500	4,1	

APPENDIX A-8-2

Layout of the Distribution Reservoirs
in the Existing Waterworks




FIGURE
Existing Deep Well Plant
(Prachatipat -New) (Zone-1)




FIGURE
Existing Well Plant (Prachatipat Old)
(Zone-1)




FIGURE
Existing Well Plant (Thanyaburi)
(Zone-3)




FIGURE
Existing Well Plant (Lam Luka)
(Zone 4)




FIGURE
 Exis. Deep Well Plant
 (Patum Thani -New) (Zone-7)

APPENDIX A-8-3

Details of the Cost Comparison for the Alternatives

Alternative : 1-1

Facility	Ref.	Status	Capacity Q(E.Ave) (cu m/d)	Design Capa	Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)
Raw Water Intake Pumping Station							
	RO	Pro	312,000		66,915	1,600	2,000

Raw Water Pipe (1500 mm Steel Pipe)	From	To	Length (km)	H.Loss (m)	Unit Cost (Baht/m)	Cost	Land Area	Land Cost	
	Pro	261,888 Chaopraya River	T1	312,000	0.2	26,400	5,280	0	0

Treatment Plant	Q(D.max)	Cost	Land Area	Land Cost		
	T1	Pro	283,000	656,917	110,000	137,500

Distribution Reservoir	(cu m)	Cost	Land Area	Land Cost	
D1	Pro	18,000	152,700	0	0
D2	Pro	20,600	163,200	6,000	18,750
D3	Pro	2,600	16,900	0	0
D4	Pro	2,200	17,500	0	0
D6	Pro	8,800	67,000	6,000	18,750
D7	Pro	9,000	89,200	0	0
ED1	Ex	2,000	-	-	-
ED2	Ex	1,000	-	-	-
ED3	Ex	1,000	-	-	-
ED4	Ex	500	-	-	-
Sub-Total		65,100	506,500	12,000	37,500

Transmission/ Distribution Main	Pipe No.	From	To	Design Q (cu m/d)	Dia. (mm)	Length (km)	Material	Fric.Loss (m)	Unit Cost (Baht/m)	Cost (Baht1000)
	1	T1	D2	172,382	1000	5.5	S	35.2	13,820	76,610
	2	D2	1	194,120	1200	2.3	S	7.5	18,400	42,320
	3	1	N.Wakn	18,720	400	1.2	S	11.0	3,650	4,380
	4	1	2	175,400	1200	4.5	S	12.2	18,400	82,800
	5	2	3	18,840	500	6.0	S	18.7	4,540	27,240
	6	2	4	156,560	1200	8.0	S	17.6	18,400	147,200
	7	4	D1	88,223	700	0.7	S	7.4	6,610	4,627
	8	4	D3	11,699	400	2.0	S	7.7	3,650	7,300
	9	D1	7	108,153	800	2.7	S	21.6	9,250	24,975
	10	D3	5	15,208	500	12.0	S	25.2	4,540	54,480
	11	5	6	3,042	300	10.5	AC	13.5	1,490	15,645
	12	7	D4	21,791	600	8.5	S	14.3	5,600	47,800
	13	D4	8	28,329	500	5.8	S	38.5	4,540	26,332
	14	8	9	5,666	300	9.0	AC	36.6	1,490	13,410

Alternative : 1-1

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa				Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)
15	T1	10	94,376	1200	8.0	S	6.9	18,400	147,200	
16	10	D6	47,024	700	4.5	S	14.8	6,610	29,745	
17	D6	12	47,414	600	1.0	S	7.1	5,600	5,600	
18	12	13	15,865	500	5.5	S	12.4	4,540	24,970	
19	12	14	15,805	500	4.5	S	10.1	4,540	20,430	
20	12	15	15,805	400	1.0	S	6.7	3,650	3,650	
21	13	14	4,741	300	4.5	AC	13.2	1,490	6,705	
22	13	15	4,741	300	6.5	AC	19.0	1,490	9,685	
23	10	11	47,351	700	2.5	S	8.3	6,610	16,525	
24	11	16	4,221	250	1.0	AC	5.7	1,090	1,090	
25	11	D7	36,800	600	2.6	S	11.5	5,600	14,560	
26	D7	17	46,340	600	0.8	S	5.4	5,600	4,480	
27	17	18	4,001	300	5.8	AC	12.4	1,490	8,642	
28	17	19	42,339	600	2.0	S	11.5	5,600	11,200	
29	19	20	20,005	500	7.5	S	26.1	4,540	34,050	
30	19	21	17,832	500	5.0	S	14.1	4,540	22,700	
31	21	22	7,828	400	5.0	S	9.1	3,650	18,250	

Sub-total

146.4

953,801

Grand Total

Construction Cost

2,188,513

Land Cost

177,000

Total Construction Cost

2,365,513

Alternative : 1-2

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa	Cost (Ex1000)	Land Area (sq m)	Land Cost (Ex1000)				
Raw Water Intake											
Pumping Station											
	RO	Pro	312,000		68,915	1,600	2,000				
Raw Water Pipe											
(1500 mm Steel Pipe)			Q(D.Max)	From To	Length (km)	H.Loss (m)	Unit Cost (Baht/m)	Cost (Ex1000)	Land Area (sq m)	Land Cost (Ex1000)	
		Pro	261,888	Chaopraya River	TI	312,000	0.2	26,400	5,280	0	0
Treatment Plant											
			Q(D.max)								
		TI	Pro	283,000				656,017	110,000	157,500	
Distribution Reservoir											
			(cu m)								
D1		Pro	18,000					152,730	0	0	
D2		Pro	19,100					163,200	6,000	18,750	
D3		Pro	2,000					16,900	0	0	
D4		Pro	2,200					17,500	0	0	
D6		Pro	13,000					99,000	6,000	18,750	
D7		Pro	9,000					89,200	0	0	
ED1		Ex	2,000					-			
ED2		Ex	1,000					-			
ED3		Ex	1,000					-			
ED4		Ex	500					-			
Sub-Total			67,300					536,500	12,000	37,500	

Transmission/ Distribution Main	Pipe No.	From	To	Design Q (cu m/d)	Dia. (mm)	Length (km)	Material	Fric.Loss (m)	Unit Cost (Baht/m)	Cost (Ex1000)
	1	TI	1	172,382	1100	4.5	S	18.1	16,100	72,450
	2	1	D2	72,460	800	1.0	S	3.8	9,250	9,250
	3	1	D1	99,922	1000	14.0	S	32.7	13,820	193,480
	4	D2	2	94,199	1000	2.3	S	4.8	13,820	31,786
	5	2	NavHkn	18,720	400	1.2	S	11.0	3,650	4,380
	6	2	3	75,479	1000	4.5	S	6.3	13,820	62,190
	7	3	4	18,840	500	6.0	S	18.7	4,540	27,240
	8	3	5	23,550	600	5.5	S	10.7	5,600	30,800
	9	D1	6	86,361	600	0.7	S	15.0	5,600	3,920
	10	6	7	43,181	600	4.0	S	23.8	5,600	22,400
	11	D1	10	21,791	500	2.7	S	11.0	4,540	12,258
	12	D1	D3	11,699	300	2.7	AC	41.9	1,490	4,023
	13	10	D4	21,731	500	8.5	S	34.7	4,540	38,590
	14	D3	8	15,268	500	12.0	S	25.2	4,540	54,480

Alternative : i-2

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa				Cost (5x1000)	Land Area (sq m)	Land Cost (5x1000)
	15	8	9	3,042	300	10.5	AC	13.5	1,490	15,645
	16	D4	11	28,329	500	5.8	S	38.5	4,540	26,332
	17	11	12	5,666	300	9.0	AC	36.6	1,490	13,410
	18	T1	13	89,506	1000	10.5	S	20.0	13,820	145,110
	19	13	D6	52,706	600	2.0	S	17.2	5,600	11,200
	20	D6	14	21,103	500	0.2	S	0.8	4,540	908
	21	14	15	10,552	400	4.2	S	13.3	3,650	15,330
	22	D6	16	47,414	600	1.0	S	7.1	5,600	5,600
	23	16	17	15,805	500	5.5	S	12.4	4,540	24,970
	24	16	18	15,805	500	4.5	S	10.1	4,540	20,430
	25	16	19	15,805	400	1.0	S	6.7	3,650	3,650
	26	17	19	4,741	300	6.5	AC	19.0	1,490	9,685
	27	17	18	4,741	300	4.5	AC	13.2	1,490	6,705
	28	13	D7	35,300	500	2.6	S	25.9	4,540	11,804
	29	D7	20	46,340	600	0.8	S	5.4	5,600	4,480
	30	20	21	4,001	300	5.8	AC	12.4	1,490	8,642
	31	20	22	42,339	600	2.0	S	11.5	5,600	11,200
	32	22	23	20,005	500	7.5	S	26.1	4,540	34,050
	33	22	24	17,832	500	5.0	S	14.1	4,540	22,700
	34	24	25	7,829	400	5.0	S	9.1	3,650	18,250
Sub-Total						163.5	km		977,348	

Grand Total

Construction Cost
2,244,060Land Cost
177,000

Total Project Cost

2,421,060

Alternative : 2-1

Facility Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa		Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)			
Raw Water Intake Pumping Station										
RO	Pro	312,000			66,915	1,600	2,000			
Raw Water Pipe (1500 mm Steel Pipe)										
	Pro	261,888	From Chaopraya River	To TI	312,000	Length (km) 7.0	H.Loss (m) 26,400	Unit Cost (Baht/m) 184,800	0	0
Treatment Plant										
	TI	Pro			283,000			656,017	116,000	137,500
Distribution Reservoir										
		(cu m)								
D1	Pro	18,000						152,700	0	0
D2	Pro	20,600						163,200	6,000	18,750
D3	Pro	2,000						16,900	0	0
D4	Pro	2,200						17,500	0	0
D6	Pro	8,800						67,000	6,000	18,750
D7	Pro	9,000						89,200	0	0
ED1	Ex	2,000						-		
ED2	Ex	1,000						-		
ED3	Ex	1,000						-		
ED4	Ex	500						-		
Sub-Total		65,100						506,500	12,000	37,500

Transmission/ Distribution Main	Pipe No	From	To	Design Q (cu m/d)	Dia. (mm)	Length (km)	Material	Fric.Loss (m)	Unit Cost (Baht/m)	Cost (Baht 1000)
	1	TI	D2	172,382	1200	9.0	S	23.7	18,400	165,600
	2	D2	1	194,120	1000	0.5	S	4.0	13,320	6,910
	3	1	2	47,099	800	7.0	S	12.1	9,250	64,750
	4	1	3	18,840	500	6.0	S	18.7	4,540	27,240
	5	1	4	123,471	1000	8.0	S	27.6	13,820	110,560
	6	4	D1	88,223	800	0.7	S	3.8	9,250	6,475
	7	4	D3	11,699	400	2.0	S	7.7	3,650	7,300
	8	D1	7	108,153	800	2.7	S	21.6	9,250	24,975
	9	D3	5	15,208	500	12.0	S	25.2	4,540	54,480
	10	5	6	3,042	300	10.5	AC	13.5	1,490	15,645
	11	7	D4	21,791	600	8.5	S	14.3	5,600	47,800
	12	D4	8	28,329	500	5.8	S	38.5	4,540	26,332
	15	8	9	5,666	300	9.0	AC	36.6	1,490	13,410
	16	TI	10	94,376	900	3.0	S	10.5	10,510	31,530

Alternative : 2-1

Facility Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa					Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)
17	10	D6	47,024	700	6.5	S	21.4	6,610	42,965	
18	D6	12	47,414	600	1.0	S	7.1	5,600	5,600	
19	12	13	15,805	500	5.5	S	12.4	4,540	24,970	
20	12	14	15,805	500	4.5	S	10.1	4,540	20,430	
21	12	15	15,805	400	1.0	S	6.7	3,650	3,650	
22	13	14	4,741	300	4.5	AC	13.2	1,490	6,705	
23	13	15	4,741	300	6.5	AC	19.0	1,490	9,685	
24	10	11	47,351	700	2.5	S	8.3	6,610	16,525	
25	11	16	4,221	250	1.0	AC	5.7	1,090	1,090	
27	11	D7	36,800	500	2.6	S	28.0	4,540	11,304	
29	D7	17	46,340	600	0.8	S	5.4	5,600	4,480	
30	17	18	4,001	300	5.8	AC	12.4	1,490	8,642	
31	17	19	42,339	600	2.0	S	11.5	5,600	11,200	
32	19	20	20,005	500	7.5	S	26.1	4,540	34,050	
33	19	21	17,832	500	5.0	S	14.1	4,540	22,700	
34	21	22	7,829	400	5.0	S	9.1	3,650	18,250	
Sub-Total			Total		146.4 Km				845,553	

Grand Total

Construction Cost
2,259,785

Land Cost
177,000

Total Project Cost

2,436,785

Alternative : 2-2

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa	Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)				
Raw Water Intake Pumping Station											
	RO	Pro	312,000		66,915	1,600	2,000				
Raw Water Pipe (1500 mm Steel Pipe)			Q(D.Max)	From To	Length (km)	H.Loss (m)	Unit Cost (Babt/m)	Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)	
		Pro	261,888	Chaopraya River	T1	312,000	7.0	26,400	184,200	0	0
Treatment Plant				Q(D.max)							
		T1	Pro	283,000				656,017	110,000	137,500	
Distribution Reservoir			(cu m)								
D1		Pro	18,000					152,700	0	0	
D2		Pro	19,100					163,200	6,000	18,750	
D3		Pro	2,000					16,900	0	0	
D4		Pro	2,200					17,500	0	0	
D6		Pro	13,000					99,000	6,000	18,750	
D7		Pro	9,000					82,200	0	0	
ED1		Ex	2,000					-			
ED2		Ex	1,000					-			
ED3		Ex	1,000					-			
ED4		Ex	500					-			
Sub-Total			ERR					538,500	12,000	37,500	

Transmission/ Distribution Main	Pipe No.	From	To	Design Q (cu m/d)	Dia. (mm)	Length (Km)	Material	Pric. (m)	Loss (Babt/m)	Unit Cost (Bx1000)	Cost (Bx1000)
	1	T1	1	172,382	1600	2.5	S	16.0	13,820	34,550	
	2	1	D2	72,460	800	6.5	S	24.8	9,250	60,125	
	3	1	D1	99,922	900	7.0	S	27.3	10,510	73,570	
	4	D2	2	94,199	800	0.5	S	3.1	9,250	4,625	
	5	2	3	47,099	700	7.0	S	23.1	6,610	46,270	
	6	2	4	18,840	500	6.0	S	18.7	4,540	27,240	
	7	2	5	23,550	600	6.7	S	13.0	5,600	37,520	
	8	D1	6	86,361	600	0.7	S	15.0	5,600	3,920	
	9	6	7	43,181	600	4.0	S	23.8	5,600	22,400	
	10	D1	10	21,791	500	2.7	S	11.0	4,540	12,258	
	11	D1	D3	11,699	300	2.7	AC	41.9	1,490	4,023	
	12	10	D4	21,791	500	8.5	S	34.7	4,540	38,590	
	13	D3	8	15,208	500	12.0	S	25.2	4,540	54,480	
	14	8	9	3,042	300	16.5	AC	15.5	1,490	15,645	

Alternative : 2-2

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa				Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)
	15	D4	11	28,329	500	5.8	S	38.5	4,540	26,532
	16	11	12	5,666	300	9.0	AC	36.6	1,490	13,410
	17	T1	13	89,506	800	5.5	S	31.1	9,250	50,875
	18	13	D6	52,706	600	2.0	S	17.2	5,600	11,200
	19	D6	14	21,103	400	0.2	S	2.3	3,650	730
	20	14	15	10,552	400	4.2	S	13.3	3,650	15,530
	21	D6	16	47,414	600	1.0	S	7.1	5,600	5,600
	22	16	17	15,805	500	5.5	S	12.4	4,540	24,970
	23	16	18	15,805	500	4.5	S	10.1	4,540	20,430
	24	16	19	15,805	400	1.0	S	6.7	3,650	3,650
	25	17	19	4,741	300	6.5	AC	19.0	1,490	9,685
	26	17	18	4,741	300	4.5	AC	13.2	1,490	6,705
	27	13	D7	35,300	500	2.6	S	25.9	4,540	11,804
	28	D7	20	46,340	500	0.8	S	13.2	4,540	3,632
	29	20	21	4,001	300	5.8	AC	12.4	1,490	8,642
	30	20	22	42,339	600	2.0	S	11.5	5,600	11,200
	31	22	23	20,095	500	7.5	S	26.1	4,540	34,050
	32	22	24	17,832	500	5.0	S	14.1	4,540	22,700
	33	24	25	7,829	400	5.0	S	9.1	3,650	18,250
sub-Total						155.7	km			734,411

Grand Total

Construction Cost
2,180,643

Land Cost
177,000

Total Project Cost

2,357,643

Alternative : 3-1

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design	Capa	Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)
Raw Water Intake								
Pumping Station								
	RQ	Pro	312,000			66,915	1,600	2,000
Raw Water Pipe								
(1500 mm Steel Pipe)			Q(D.Max)	From	To	Length (km)	H.Loss (m)	Unit Cost (Baht/m)
		Pro	261,888	Chaopraya River	T1	0.2		26,400
								5,280
								0
Treatment Plant								
					Q(D.max)			
		T1	Pro		283,000			
								656,017
								110,000
								137,500
Distribution Reservoir								
			(cu m)					
D1		Pro	18,000					152,700
D2		Pro	20,600					163,200
D3		Pro	2,000					16,300
D4		Pro	2,200					17,500
D6		Pro	8,800					67,000
D7		Pro	9,600					89,200
ED1		Ex	2,000					-
ED2		Ex	1,000					-
ED3		Ex	1,000					-
ED4		Ex	500					-
Sub-Total			65,100					506,500
								12,000
								37,500

Transmission/ Distribution Main	Pipe No	From	To	Design Q (cu m/d)	Dia. (mm)	Length (km)	Material	Fric.Loss (m)	Unit Cost (Baht/m)	Cost (Baht 1000)
	1	T1	D2	172,382	1200	9.0	S	23.7	18,400	165,600
	2	D2	1	194,120	1000	0.5	S	4.0	13,820	6,910
	3	1	2	47,099	800	7.0	S	12.1	9,250	64,750
	4	1	3	18,840	500	6.0	S	18.7	4,540	27,240
	5	1	4	123,471	1000	8.0	S	27.6	13,820	110,560
	6	4	D1	88,223	800	0.7	S	3.8	9,250	6,475
	7	4	D3	11,699	400	2.0	S	7.7	3,650	7,300
	8	D1	7	108,153	800	2.7	S	21.6	9,250	24,975
	9	D3	5	15,208	500	12.0	S	25.2	4,540	54,480
	10	5	6	3,042	300	10.5	AC	13.5	1,490	15,645
	11	7	D4	21,791	600	8.5	S	14.3	5,600	47,600
	12	D4	8	28,329	500	5.8	S	38.5	4,540	26,332
	15	8	9	5,656	300	9.0	AC	36.6	1,490	13,410
	16	T1	10	34,376	900	3.0	S	10.5	10,510	31,536

Alternative : S-1

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa				Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)
	17	10	D6	47,024	700	6.5	S	21.4	6,610	42,965
	18	D6	12	47,414	600	1.0	S	7.1	5,600	5,600
	19	12	13	15,805	500	5.5	S	12.4	4,540	24,970
	20	12	14	15,805	500	4.5	S	10.1	4,540	20,430
	21	12	15	15,805	400	1.0	S	6.7	3,650	3,650
	22	13	14	4,741	300	4.5	AC	13.2	1,490	6,705
	23	13	15	4,741	300	6.5	AC	19.0	1,490	9,685
	24	10	11	47,351	700	2.5	S	8.3	6,610	16,525
	25	11	16	4,221	250	1.0	AC	5.7	1,090	1,090
	27	11	D7	36,800	500	2.6	S	28.0	4,540	11,804
	29	D7	17	46,340	600	0.8	S	5.4	5,600	4,480
	30	17	18	4,001	300	5.8	AC	12.4	1,490	8,642
	31	17	19	42,339	600	2.0	S	11.5	5,600	11,200
	32	19	20	20,005	500	7.5	S	26.1	4,540	34,050
	33	19	21	17,832	500	5.0	S	14.1	4,540	22,700
	34	21	22	7,829	400	5.0	S	9.1	3,650	18,250
Sub-Total				Total				146.4 Kw	845,553	

Grand Total

Construction Cost
2,080,265

Land Cost
177,000

Total Project Cost

2,237,265

Alternative : 3-2

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa	Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)				
Raw Water Intake											
Pumping Station											
	R0	Pro	312,000		66,915	1,500	2,000				
Raw Water Pipe											
(1500 mm Steel Pipe)			Q(D.Max)	From	To	Length (km)	H.Loss (m)	Unit Cost (Baht/m)	Cost	Land Area	Land Cost
	Pro		261,888	Chaopraya River	T1	0.2		26,400	5,280	0	0
Treatment Plant											
					Q(D.Max)						
	T1	Pro			283,000				656,017	110,000	137,500
Distribution Reservoir											
			(cu m)								
D1	Pro		18,000						152,700	0	0
D2	Pro		19,100						163,200	6,000	18,750
D3	Pro		2,000						16,900	0	0
D4	Pro		2,200						17,500	0	0
D6	Pro		13,000						99,000	6,000	18,750
D7	Pro		9,000						89,200	0	0
ED1	Ex		2,000						-		
ED2	Ex		1,000						-		
ED3	Ex		1,000						-		
ED4	Ex		500						-		
Sub-Total			67,800						538,500	12,000	37,500
Transmission/ Distribution Main											
	Pipe No.	From	To	Design Q (cu m/d)	Dia. (mm)	Length (Km)	Material	Fric.Loss (m)	Unit Cost (Baht/m)	Cost (Bx1000)	
	1	T1	1	172,382	1000	2.5	S	16.0	13,820	34,550	
	2	1	D2	72,460	800	6.5	S	24.8	9,250	60,125	
	3	1	D1	99,922	900	7.0	S	27.3	10,510	73,570	
	4	D2	2	94,199	800	0.5	S	3.1	9,250	4,625	
	5	2	3	47,099	700	7.0	S	23.1	6,610	46,270	
	6	2	4	18,840	500	6.0	S	18.7	4,540	27,240	
	7	2	5	23,550	600	6.7	S	13.0	5,600	37,520	
	8	D1	6	86,361	600	0.7	S	15.0	5,600	3,920	
	9	6	7	43,181	600	4.0	S	23.8	5,600	22,400	
	10	D1	10	21,791	500	2.7	S	11.0	4,540	12,258	
	11	D1	D3	11,699	300	2.7	AC	41.9	1,490	4,023	
	12	10	D4	21,791	500	8.5	S	34.7	4,540	38,590	
	13	D3	8	15,208	500	12.0	S	25.2	4,540	54,480	
	14	8	9	3,042	300	10.5	AC	13.5	1,490	15,645	

Alternative : 3-2

Facility	Ref.	Status	Capacity Q(D.Ave) (cu m/d)	Design Capa				Cost (Bx1000)	Land Area (sq m)	Land Cost (Bx1000)
	15	D4	11	28,329	500	5.8	S	38.5	4,540	26,332
	16	11	12	5,666	300	9.0	AC	36.6	1,490	13,410
	17	T1	13	89,506	800	5.5	S	31.1	9,250	50,875
	18	13	D6	52,706	600	2.0	S	17.2	5,600	11,200
	19	D6	14	21,103	400	0.2	S	2.3	3,650	730
	20	14	15	10,552	400	4.2	S	13.3	3,650	15,330
	21	D6	16	47,414	600	1.0	S	7.1	5,600	5,600
	22	16	17	15,805	500	5.5	S	12.4	4,540	24,970
	23	16	18	15,805	500	4.5	S	10.1	4,540	20,430
	24	16	19	15,805	400	1.0	S	6.7	3,650	3,650
	25	17	19	4,741	300	6.5	AC	19.0	1,490	9,685
	26	17	18	4,741	300	4.5	AC	13.2	1,490	6,705
	27	13	D7	35,300	500	2.6	S	25.9	4,540	11,804
	28	D7	20	46,340	500	0.8	S	13.2	4,540	3,632
	29	20	21	4,001	300	5.8	AC	12.4	1,490	8,642
	30	20	22	42,339	600	2.0	S	11.5	5,600	11,200
	31	22	23	20,005	500	7.5	S	26.1	4,540	34,050
	32	22	24	17,832	500	5.0	S	14.1	4,540	22,700
	33	24	25	7,829	400	5.0	S	9.1	3,650	18,250
Sub-Total						155.7	km			734,411

Grand Total

Construction Cost
2,001,123

Land Cost
177,000

Total Project Cost

2,178,123

Water Transmission/Distribution Cost - Patus Thani & Prachatiap

RAW WATER TRANSMISSION COST

Year	Planned Daily Average Water Demand: Q(zone i)DM (cu m/d)																					
	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011						
Zone 1 (Prachatiap)	5,639	6,167	7,202	8,289	9,437	12,625	15,349	18,275	21,239	24,247	27,285	30,373	33,273	36,251	39,249	41,957	45,939	46,048	48,243	50,576	52,598	55,360
Zone 2 (Rangsit)	0	0	161	660	1,502	35,491	38,910	40,372	41,954	43,660	45,485	47,441	48,787	50,160	51,561	53,584	55,494	54,734	56,042	57,418	58,685	60,384
Zone 3 (Thanyaburi)	338	364	511	667	828	1,232	1,586	1,872	2,174	2,495	2,826	3,178	3,557	3,953	4,367	5,079	5,529	6,263	7,049	7,891	8,796	9,719
Zone 4 (Lam Lukka)	2,316	2,592	2,946	3,280	3,602	4,176	4,481	5,037	5,715	6,524	7,457	8,527	9,157	9,815	10,501	11,281	12,027	13,110	14,263	15,481	16,785	18,159
Zone 5 (San Khok)	0	0	0	0	0	1,132	2,268	3,591	4,542	5,720	6,926	8,160	9,332	10,509	11,691	12,823	14,214	15,740	17,400	19,263	21,328	23,528
Zone 6 (Huamng)	0	0	0	0	0	4,130	5,538	6,809	8,112	12,955	14,319	15,714	17,005	18,480	19,901	21,904	22,977	24,323	25,735	27,215	28,767	30,374
Zone 7 (Munichip.)	3,284	3,624	3,999	4,352	4,695	6,231	7,482	8,818	10,156	11,501	12,846	14,200	15,544	16,905	18,283	19,316	20,014	21,023	22,089	23,214	24,400	25,648
Zone 8 (L-Lum Naeo)	0	0	0	0	0	0	0	0	0	1,286	1,716	1,975	2,234	2,498	3,328	3,600	3,875	4,154	4,437	4,726	5,019	5,312
Total (Zone 1)	11,577	12,746	14,820	17,248	20,063	65,037	75,614	84,574	93,892	107,100	119,430	129,309	138,708	148,287	158,051	167,472	175,795	181,827	190,275	197,152	208,469	218,240

B. Planned Daily Maximum Water Demand: Q(zone i)DM⁹ (cu m/d) Peak Factor = 1.20

Zone 1 (Prachatiap)	6,767	7,400	8,643	9,947	11,374	15,150	18,418	21,930	25,487	29,096	32,742	36,447	39,927	43,478	47,099	50,348	52,777	55,259	57,892	60,632	63,478	66,432
Zone 2 (Rangsit)	0	0	194	793	1,802	42,590	46,492	48,447	50,345	52,392	54,582	56,930	59,100	61,192	63,100	64,195	65,681	67,250	68,702	70,638	72,466	74,666
Zone 3 (Thanyaburi)	408	436	614	800	994	1,498	1,993	2,747	3,372	3,814	4,269	4,744	5,240	6,095	6,635	7,515	8,459	9,169	10,148	11,199	12,371	13,699
Zone 4 (Lam Lukka)	2,778	3,110	3,535	3,936	4,333	5,011	5,378	6,046	6,858	7,828	8,948	10,235	10,880	11,777	12,602	13,537	14,435	15,732	17,115	18,584	20,142	21,771
Zone 5 (San Khok)	0	0	0	0	0	1,359	2,722	4,070	5,450	6,864	8,311	9,791	11,198	12,610	14,029	14,658	14,941	15,240	15,555	15,836	16,232	16,732
Zone 6 (Huamng)	0	0	0	0	0	4,980	6,646	8,171	9,734	15,546	17,182	18,857	20,502	22,177	23,881	26,284	27,573	29,186	30,862	32,658	34,521	36,473
Zone 7 (Munichip.)	3,941	4,349	4,798	5,223	5,633	7,477	8,978	10,582	12,188	13,801	15,415	17,040	18,653	20,286	21,939	23,179	24,011	25,238	26,507	27,857	29,230	30,777
Zone 8 (L-Lum Naeo)	0	0	0	0	0	0	0	0	0	1,543	2,059	2,368	2,680	2,997	3,994	4,320	4,650	4,985	5,325	5,671	6,023	6,382
Total (Zone 1)	13,995	15,295	17,784	20,697	24,076	78,045	90,737	101,489	112,670	128,520	142,116	155,171	166,450	177,945	189,468	200,766	208,554	218,193	228,300	238,982	250,163	261,888

1. Transmission Pipe

Alternative	Design Flow Q 2011 (m ³ /s)	Flow L (km)	Head Loss for Q(2011) (m)	Loss (m/sec)
1-1 & 1-2	288.076	1,500	0.2	1.89
2-1 & 2-2	288.076	1,500	7.0	16.1
3-1 & 3-2	288.076	1,500	0.2	1.89

2. Required Pump Head and Flow Rate

Alternative	Total Flow in 2011 Head(m) (cu m/line)	Required Water Demand in Each Year (cu m/d)	Head Loss for Q(2011) (m)	Loss (m/sec)
1-1 & 1-2	0.5 200.1	78,045 90,737 101,489 112,670 128,520 142,116 155,171 166,450 177,945 189,468 200,766 208,554 218,193 228,300 238,982 250,163 261,888	0.2	1.89
2-1 & 2-2	16.1 200.1	78,045 90,737 101,489 112,670 128,520 142,116 155,171 166,450 177,945 189,468 200,766 208,554 218,193 228,300 238,982 250,163 261,888	7.0	16.1
3-1 & 3-2	0.5 200.1	78,045 90,737 101,489 112,670 128,520 142,116 155,171 166,450 177,945 189,468 200,766 208,554 218,193 228,300 238,982 250,163 261,888	0.2	1.89

3. Flow Rate in Daily Average Operation (cu m/d)

Alternative	Flow Rate
1-1 & 1-2	65,037 75,614 84,574 93,892 107,100 119,430 129,309 138,708 148,287 158,051 167,472 175,795 181,827 190,275 197,152 208,469 218,240
2-1 & 2-2	65,037 75,614 84,574 93,892 107,100 119,430 129,309 138,708 148,287 158,051 167,472 175,795 181,827 190,275 197,152 208,469 218,240
3-1 & 3-2	65,037 75,614 84,574 93,892 107,100 119,430 129,309 138,708 148,287 158,051 167,472 175,795 181,827 190,275 197,152 208,469 218,240

Water Transmission/Distribution Cost - Patun Ilami & Prachatipat

RAW WATER TRANSMISSION COST

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------

4. Pump Characteristics

Alternative	Dia (mm)	Motor Power (kw)	H (m)	Q (cu m/min/unit)	No. of Pump/unit
1-1 & 1-2	800	200	12.0	66.7	3 (excluding 1 unit stand-by)
2-1 & 2-2	800	400	21.6	66.7	3 (excluding 1 unit stand-by)
3-1 & 3-2	800	200	12.0	66.7	3 (excluding 1 unit stand-by)

5. No. of Operating Pumps

Alternative	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	
1-1 & 1-2	1	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
2-1 & 2-2	1	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
3-1 & 3-2	1	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2

6. Maximum Pump Capacity (cu m/s)

Alternative	96,025	96,025	96,025	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051
1-1 & 1-2	96,025	96,025	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051
2-1 & 2-2	96,025	96,025	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051
3-1 & 3-2	96,025	96,025	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051	192,051

7. Motor Output (kw) ** including output for a stand-by pump

Alternative	400	400	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800
1-1 & 1-2	400	400	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800
2-1 & 2-2	920	920	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360	1,360
3-1 & 3-2	400	400	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800	800

8. Energy Consumption (kwh/day) for Daily Average Demand

Alternative	3,251	3,251	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502
1-1 & 1-2	3,251	3,251	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502
2-1 & 2-2	7,477	7,477	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954	14,954
3-1 & 3-2	3,251	3,251	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502	6,502

Water Transmission/Distribution Cost - Petua Thani & Prechatsipat

RAW WATER TRANSMISSION COST

Item	Year												Total of 1995 - 2011 =											
	1970	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001		2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
9. Pump Operation Cost (Baht x1,000/year)																								
Alternative 1-1,1-2,3-1 & 3-2																								
Demand Charge	1,099	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	1,649	2,198	
Energy Charge	1,468	1,878	2,107	2,403	2,658	2,902	3,113	3,328	3,547	3,758	3,908	4,080	4,270	4,469	4,673	4,896	5,137	5,385	5,644	5,911	6,184	6,468	6,768	7,076
Total Cost	2,557	3,527	3,756	4,052	4,307	4,551	4,767	5,000	5,246	5,506	5,756	6,018	6,287	6,562	6,841	7,132	7,432	7,733	8,035	8,338	8,642	8,948	9,254	9,560
Alternative 2-1 & 2-2																								
Demand Charge	2,528	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	3,792	5,056
Energy Charge	3,357	4,365	4,846	5,328	5,810	6,291	6,771	7,251	7,731	8,211	8,691	9,171	9,651	10,131	10,611	11,091	11,571	12,051	12,531	13,011	13,491	13,971	14,451	14,931
Total Cost	5,885	8,157	8,638	9,120	9,601	10,082	10,563	11,044	11,525	12,006	12,487	12,968	13,449	13,930	14,411	14,892	15,373	15,854	16,335	16,816	17,297	17,778	18,259	18,740
Total of 1995 - 2011 = 85,944																								

Note: Pumps is designed for Qda (Daily Maxima Demand) times 1.1
 8. Energy Consumption (kWh) = No. of Pumps x Motor Output (kW) x 24 h/day x (actual daily demand)/(max. capacity of pump)
 9. Demand Charge = Baht 229 /kWh/ton x 12 ton/year x Motor Demand KW
 Energy Charge = Baht 1.23 /kWh x Energy Consumption kWh/day x 365 days/year
 Design Pump Head=(head Loss of Pipeline)+(Actual Head, = 10 m)/(Pump Loss 1.5 m)
 Electricity Fee = Rate of Provincial Electricity Authority (PEA) as of January, 1989.

Year	1,989	1,990	1,991	1,992	1,993	1,994	1,995	1,996	1,997	1,998	1,999	2,000	2,001	2,002	2,003	2,004	2,005	2,006	2,007	2,008	2,009	2,010	2,011
Operation Cost	0	0	0.0	0.0	0.0	0.0	2.6	2.8	3.5	3.8	4.1	4.3	4.6	4.8	5.0	5.2	6.0	6.1	6.3	6.5	6.7	6.9	7.1
Alt. 1-1,1-2,3-1 & 3-2	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Alt. 2-1 & 2-2	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Discount Rate	9.00 %																						
NPV	72.85 Million Baht																						
Alt. 1-1,1-2,3-1 & 3-2	46.16 Million Baht																						
Alt. 2-1 & 2-2																							

Water Transmission/Distribution Cost - Patun Thani & Prachatiapat

Alternative : I-1

Item	Year												Loss (ft/sec)	Loss (ft)																																
	1970	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001			2002	2003	2004	2005	2006	2007	2008	2009	2010	2011																						
1. Transmission Pipe : (*****)) shows a starting year of water transmission																																														
No	From	To	Q 2011 (cu ft/d)	Design flow Dia (in)	L (ft)																			Y	Loss																					
1	11	02	172,392	1,000	5.5																			1.94	35.2																					
2	02	1	194,120	1,200	2.3																			1.99	7.5																					
3	1	R>Main	18,720	400	1.2																			1.72	11.9																					
4	1	2	175,400	1,200	4.5																			1.77	12.2																					
5	2	3	18,840	500	5.0																			1.11	19.7																					
6	2	4	158,560	1,200	8.0																			1.60	17.6																					
7	4	01	88,223	700	0.7																			2.65	1.4																					
8	4	03	11,619	400	2.0																			1.05	7.7																					
9	01	7	108,153	800	2.7																			2.19	21.5																					
10	03	5	15,208	500	12.0																			0.90	25.2																					
11	5	6	3,042	300	10.5																			0.59	13.5																					
12	7	04	21,791	400	8.5																			0.83	14.3																					
13	04	8	28,329	500	5.8																			1.87	35.5																					
14	8	9	5,666	300	9.0																			0.75	36.0																					
15	11	10	94,376	1,200	8.0																			0.77	6.9																					
16	10	06	47,024	700	4.5																			1.41	14.8																					
17	06	12	47,414	600	1.0																			1.94	7.1																					
18	12	13	15,805	500	5.5																			0.95	12.4																					
19	12	14	15,805	500	4.5																			0.95	10.1																					
20	12	15	15,805	400	1.0																			1.46	6.7																					
21	13	14	4,741	300	4.5																			0.78	15.2																					
22	13	15	4,741	300	6.5																			0.78	19.0																					
23	10	11	47,351	700	2.5																			1.42	8.3																					
24	11	16	4,221	250	1.0																			1.00	5.7																					
25	11	07	36,800	600	2.6																			1.51	11.5																					
26	07	17	46,340	600	0.8																			0.66	12.4																					
27	17	18	4,001	300	5.8																			0.66	12.4																					
28	17	19	42,339	600	2.0																			1.73	51.5																					
29	19	20	20,005	500	7.5																			1.18	26.1																					
30	19	21	17,432	500	5.0																			1.05	14.1																					
31	21	22	7,829	400	5.0																			0.72	9.1																					
																							Total			146.4																				

Water Transmission/Distribution Cost - Patun Itani & Prachhatipat

Alternative : I-1

Item	Required Pump Head and Flow Rate																					
	1990	1991	1992	1993	1994	1995	1996	1997	1998	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
Routing Total																						
Pipe No.																						
1																						
15-23-25																						
9-12																						
2-4-6-8																						
10-11																						
13																						
(05)																						
17-18																						
26-28-30-31																						
(08)																						

3. Flow Rate in Daily Average Operation (cu m/d)

Routing	Flow in 2011 CMD (cu m/d)	Required Water Demand in Each Year (cu m/d)
1	119.7	64,229 72,391 78,667 85,298 92,308 99,665 107,423 113,779 120,191 126,814 133,081 137,988 144,166 150,716 157,537 164,896 172,382
15-23-25	65.5	14,224 19,162 24,043 29,007 38,271 44,945 50,685 56,080 61,537 67,096 72,214 74,943 78,487 82,186 86,062 90,123 94,378
9-12	75.1	17,184 22,224 27,739 33,608 39,615 45,985 52,427 58,162 64,042 70,070 76,085 80,613 86,082 91,834 97,873 104,211 110,851
2-4-6-8	134.8	77,006 86,399 93,201 100,402 108,026 116,039 124,502 131,292 138,249 145,576 152,011 157,745 163,890 170,891 178,257 185,977 194,120
10-11	10.6	1,921 2,474 2,921 3,392 3,889 4,409 4,958 5,549 6,167 6,812 7,474 8,625 9,170 10,997 12,309 13,712 15,208
13	19.7	6,515 6,991 7,857 8,916 10,177 11,633 13,302 14,284 15,311 16,382 17,598 18,763 20,452 22,250 24,160 26,185 28,329
(05)		
17-18	32.9	6,474 8,639 10,522 12,654 20,210 22,337 24,514 26,653 28,830 31,045 34,170 35,845 37,344 40,146 42,456 44,877 47,414
26-28-30-31	32.2	8,220 10,172 12,258 14,344 16,441 20,546 23,329 25,827 28,356 30,918 33,025 35,339 37,344 39,439 41,637 43,936 46,340
(08)		

4. Pump Characteristics

Flow Rate	Motor Power (kw)	H (m)	Q (cu m/hr/unit)	No. of Pump(unit)
11 for Zone 1-4	470	46.7	39.9	3 (excluding 1 unit stand-by)
11 for Zone 5-8	210	33.3	21.8	3 (excluding 1 unit stand-by)
01	300	47.4	25.0	3 (excluding 1 unit stand-by)
02	640	56.3	44.9	3 (excluding 1 unit stand-by)
03	70	50.2	5.3	2 (excluding 1 unit stand-by)
04	130	50.0	9.8	2 (excluding 1 unit stand-by)
(05)				
06	90	31.0	11.0	3 (excluding 1 unit stand-by)
07	150	54.5	10.7	3 (excluding 1 unit stand-by)
(08)				

Water Transmission/Distribution Cost - Fatun Ohami & Prachinipat

Alternative : 1-1

Year	Alternative																				
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010

5. No. of Operating Pumps

	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
T1 for Zone 1-4	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
T1 for Zone 5-8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
D3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(D5)																						
B6	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
B7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(D8)																						

6. Maximum Pump Capacity (cu s/d)

T1 for Zone 1-4	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921
T1 for Zone 5-8	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459
D1	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051
D2	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413
D3	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604
D4	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164
(D5)																						
B6	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805	15,805
B7	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447
(D8)																						

7. Motor Output (Hr)

T1 for Zone 1-4	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940	940
T1 for Zone 5-8	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210	210
D1	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300
D2	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280	1,280
D3	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70
D4	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
(D5)																						
B6	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90
B7	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
(D8)																						
Total	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170	3,170

Water Transmission/Distribution Cost - Patun Thani & Prachathipat

Alternative :	Y																							
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011		
8. Energy Consumption (kwh/day) for Daily Average Demand																								
I1 for Zone 1-4	3,017	10,507	11,842	12,869	13,954	15,101	16,304	17,573	18,605	19,662	20,746	21,773	22,573	23,587	24,656	25,780	26,961							
I1 for Zone 5-8	752	1,845	2,449	3,047	3,654	4,835	5,468	6,375	7,039	7,711	8,391	9,063	9,421	9,981	10,362	10,867	11,396							
D1	2,770	3,601	4,277	5,030	5,817	6,443	7,503	8,406	9,484	9,986	10,808	11,447	12,282	13,066	13,891	14,760	15,672							
B2	3,648	12,705	14,320	15,561	16,873	18,240	19,715	21,230	22,497	23,776	25,086	26,325	27,296	28,522	29,314	31,173	32,401							
B3	272	350	414	480	551	624	702	786	873	965	1,122	1,222	1,384	1,557	1,743	1,942								
B4	795	928	987	1,109	1,259	1,437	1,643	1,878	2,017	2,162	2,313	2,485	2,649	2,868	3,147	3,431	3,597							
(05)	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0							
B6	1,094	1,452	1,744	2,055	2,367	2,680	3,094	3,709	4,063	4,461	4,843	5,278	5,504	5,863	6,116	6,445	6,788							
B7																								
(08)																								
Total	12,014	31,303	35,910	40,885	44,465	49,507	54,751	62,039	66,546	71,156	75,871	80,684	84,087	88,454	93,056	97,898	102,989							
9. Pump Operation Cost (Baht xl,000/year)																								
Demand Charge	8,711	8,711	8,711	10,772	10,772	10,772	12,088	14,180	15,169	16,433	16,433	16,433	16,433	16,433	16,433	16,433	17,257							
Energy Charge	5,421	14,053	16,149	17,996	19,936	22,226	24,580	27,053	29,876	31,945	34,062	36,223	37,751	39,732	41,777	43,951	46,237							
Total Cost	14,132	22,765	24,860	28,768	30,708	32,998	35,553	40,741	44,055	47,114	50,495	52,656	54,185	56,145	58,210	60,384	63,494							
Total (1991-2011) =																								715,003

Note: Pumps is designed for QH (Daily Maximum Demand) for transmission, and for QH (Hourly Maximum Demand) for distribution.
 10. Energy Consumption (kwh) = No. of Pumps x Motor Output (kW) x 24 h/day x (actual daily demand(Qda))/max.capacity of pump
 11. Demand Charge = Baht $\frac{229}{kWh/year} \times 12 \text{ month/year} \times \text{Motor Demand kW}$
 Energy Charge = Baht $\frac{1.23}{kWh} \times \text{Energy Consumption kWh/day} \times 365 \text{ days/year}$
 Design Pump Head=(Head Loss of Pipeline)+(Actual Head, =0)+(Residual Head 10.0 m)/(Pump Head 1.5 m)
 QA : Daily Average
 QH : Daily Maximum
 RH : Hourly Maximum
 Electricity Fee = Rate of Provincial Electricity Authority(PEA) as of January, 1989.

Year	1,989	1,990	1,991	1,992	1,993	1,994	1,995	1,996	1,997	1,998	1,999	2,000	2,001	2,002	2,003	2,004	2,005	2,006	2,007	2,008	2,009	2,010	
Operation Cost	0	0	0.0	0.0	0.0	0.0	14.1	22.8	24.9	26.7	30.7	33.0	35.4	40.7	44.1	47.1	50.5	52.7	54.2	56.1	58.2	60.4	
Discount Rate	10.00 %																						
NPV	160.80 x Million Baht																						

Water Transmission/Distribution Cost - Patna Ihani & Prachhalpat

Alternative : 1-2

Item	Design Flow		Dia (mm) L (km)	Head Loss for Q(2011) (m)												Loss (m)															
	No	To		1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001		2002	2003	2004	2005	2006	2007	2008	2009	2010	2011					
1. Transmission Pipe : ***** shows a starting year of water transmission																															
No	From	To	Q (cu m/d)																									V (m/sec)	Loss (m)		
1	11	1	172,382	1,100	4.5																									2.10	18.1
2	1	02	72,469	800	1.0																									1.67	3.8
3	1	01	99,922	1,000	14.0																									1.47	37.7
4	02	2	94,199	1,000	2.3																									1.39	4.8
5	2	Navin	18,720	400	1.2																									1.72	11.0
6	2	3	75,479	1,000	4.5																									1.11	6.3
7	3	4	18,840	500	6.0																									1.11	18.7
8	3	5	25,550	600	5.5																									0.96	10.7
9	01	6	86,361	600	0.7																									3.54	15.0
10	6	7	45,181	800	4.0																									1.77	23.8
11	01	10	21,791	500	2.7																									1.78	11.0
12	01	03	11,699	300	2.7																									1.92	41.9
13	10	04	21,771	500	8.5																									1.28	36.7
14	03	8	15,208	500	12.0																									0.90	23.2
15	8	9	5,042	300	10.5																									0.50	13.5
16	04	11	28,329	500	5.8																									1.67	32.5
17	11	12	5,666	300	9.0																									0.93	35.6
18	11	13	89,586	1,000	10.5																									1.32	20.0
19	13	06	52,706	600	2.0																									2.16	17.2
20	06	14	21,103	500	0.2																									1.24	0.8
21	14	15	10,552	400	4.2																									0.97	13.3
22	06	16	47,414	600	1.0																									1.94	7.1
23	16	17	15,805	500	5.5																									0.93	12.4
24	16	18	15,805	500	4.5																									1.46	6.7
25	16	19	15,805	400	1.0																									2.58	19.0
26	17	19	4,761	300	6.5																									2.59	13.2
27	17	18	4,741	300	4.5																									2.08	25.9
28	13	07	35,300	500	2.6																									1.90	5.4
29	07	20	46,349	600	0.8																									0.66	12.4
30	20	21	4,001	300	5.8																									1.75	11.5
31	20	22	42,339	600	2.0																									1.18	26.1
32	22	23	20,085	500	7.5																									1.05	14.1
33	22	24	17,832	500	5.0																									0.72	9.1
34	24	25	7,829	600	5.0																										
			Total			143.5 Km																									

Alternative : 1-2

Item	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
Required Pump Head and Flow Rate																							
Routing Pipe No.	Total Loss (ft)	Required Water Demand in Each Year (cu m/d)																					
T1 1-3	50.8	119.7	64,229	72,371	78,667	85,798	92,308	99,165	107,423	115,779	124,814	133,901	143,988	144,186	150,716	157,587	164,806	172,382					
T1 18-28	45.9	42.2	13,816	18,346	22,872	27,372	36,212	42,432	47,148	52,721	57,353	62,847	67,865	70,366	74,007	77,614	81,395	85,357					
B1 9-10	38.8	60.0	10,895	14,944	19,308	24,133	29,825	33,585	38,381	42,905	47,529	52,729	56,452	59,345	62,835	66,260	69,821	73,521					
B1 11-13 (Zone4)	45.7	15.1	5,011	5,378	6,044	6,858	7,828	8,940	10,233	10,968	11,717	12,602	13,537	14,433	15,232	16,115	18,384	20,142					
B1 12 (Zone-3)	41.9	8.1	1,478	1,903	2,247	2,609	2,991	3,392	3,814	4,269	4,744	5,240	6,075	6,655	7,515	8,459	9,469	10,548					
D2 4-6-7	29.8	65.4	55,367	60,700	62,980	65,440	68,110	70,957	74,008	76,108	78,250	80,436	82,030	83,850	85,385	87,425	89,572	91,829					
B3 14-15	38.7	10.6	1,921	2,474	2,921	3,392	3,889	4,409	4,958	5,548	6,167	6,812	7,924	8,425	9,770	10,991	12,309	13,712					
B4 16	38.5	19.7	6,515	6,991	7,857	8,916	10,177	11,633	13,302	14,284	15,311	16,382	17,536	18,765	20,452	22,250	24,160	26,185					
(05)			8,241	12,178	15,913	19,739	29,134	33,142	37,243	41,210	45,223	49,283	52,926	54,898	57,368	59,959	62,677	65,528					
D6 22-23	19.5	41.6	8,220	10,172	12,256	14,344	16,441	20,546	23,329	25,827	28,356	30,918	33,825	35,339	37,341	39,439	41,637	43,936					
D7 29-31-32	45.0	32.2																					
(08)																							

3. Flow Rate in Daily Average Operation (cu m/d)

T1 for Zone 1-4	53,524	60,326	65,556	71,082	76,923	83,054	89,519	94,774	100,159	105,679	110,908	114,900	120,155	125,597	131,322	137,338	143,652						
T1 for Zone 5-8	11,514	15,208	19,019	21,810	24,810	29,790	34,934	40,128	45,376	50,790	56,372	62,121	68,045	74,151	80,448	86,937	93,620						
B1 for Distribution	12,625	15,349	18,275	21,239	24,247	27,285	30,315	33,215	36,231	39,249	41,957	45,939	48,243	50,526	52,898	55,360	58,159						
B1 for Transmission for Zone-4	4,176	4,481	5,037	5,715	6,524	7,527	8,751	10,501	11,281	12,027	13,110	14,263	15,487	16,785	18,159	9,749							
B1 for Transmission for Zone-3	1,232	1,566	1,872	2,174	2,493	2,876	3,178	3,557	3,953	4,367	5,079	5,829	6,265	7,049	7,891	8,790	9,749						
D2	35,491	38,910	40,372	41,934	43,660	45,485	47,441	48,787	50,160	51,561	52,984	54,734	56,042	57,418	58,865	60,384							
D3	1,232	1,566	1,872	2,174	2,493	2,876	3,178	3,557	3,953	4,367	5,079	5,829	6,265	7,049	7,891	8,790	9,749						
B4	4,176	4,481	5,037	5,715	6,524	7,527	8,751	10,501	11,281	12,027	13,110	14,263	15,487	16,785	18,159								
(05)																							
D6	5,283	7,806	10,201	12,633	18,676	21,245	23,874	26,417	28,899	31,597	33,927	35,191	36,374	38,435	40,178	42,005	43,922						
D7	6,231	7,482	8,818	10,136	11,501	12,846	14,200	15,544	16,995	18,283	19,316	20,014	21,023	22,089	23,214	24,400	25,648						
(08)																							

4. Pump Characteristics

	Dis (mm)	Motor Power (kw)	H (m)	Q (cu m/min/unit)	No. of Pump/unit)
T1 for Zone 1-4	400	630	82.3	39.9	3 (excluding 1 unit stand-by)
T1 for Zone 5-8	500	300	57.4	20.7	3 (excluding 1 unit stand-by)
B1 for Distribution	400	260	50.3	20.0	3 (excluding 1 unit stand-by)
B1 for Transmission for Zone-4	400	220	57.2	15.1	1 (excluding 1 unit stand-by)
B1 for Transmission for Zone-3	300	110	53.4	8.1	1 (excluding 1 unit stand-by)
D2	500	230	41.3	21.8	2 (excluding 1 unit stand-by)
D3	300	70	50.2	5.3	3 (excluding 1 unit stand-by)
B4	300	130	50.0	9.8	2 (excluding 1 unit stand-by)
(05)					
D6	400	130	31.0	15.9	3 (excluding 1 unit stand-by)
D7	300	150	34.5	10.7	3 (excluding 1 unit stand-by)
(08)					

Alternative : 1-2

Item	Year																					
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
5. No. of Operating Pumps																						
T1 for Zone 1-4	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
T1 for Zone 5-8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D1 for Distribution	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D1 for Transmission for Zone-4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D1 for Transmission for Zone-3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
D3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(05)																						
D6	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
D7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(08)																						
6. Maximum Pump Capacity (cu m/d)																						
T1 for Zone 1-4	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921
T1 for Zone 5-8	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835
D1 for Distribution	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787
D1 for Transmission for Zone-4	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791
D1 for Transmission for Zone-3	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699
D2	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799
D3	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604
D4	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164
(05)																						
D6	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839	22,839
D7 for Distribution	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447	15,447
(08)																						
7. Motor Output (Kw)																						
T1 for Zone 1-4	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260	1,260
T1 for Zone 5-8	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300
D1 for Distribution	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240	240
D1 for Transmission for Zone-4	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220
D1 for Transmission for Zone-3	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110
D2	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460	460
D3	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
D4	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
(05)																						
D6	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
D7	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150	150
(08)																						
Total	3,070	3,070	3,320	3,320	4,160	4,160	4,290	4,920	5,500	5,570	5,830	5,830	5,830	5,830	5,830	5,830	5,830	5,830	5,830	5,830	5,830	5,830

Water Transmission/Distribution Cost - Patus Ithani & Prechatipt

Alternative : 1-2

Item	Year																						
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
8. Energy Consumption (kWh/day) for Daily Average Demand																							
T1 for Zone 1-4	14,084	15,874	17,250	18,704	20,241	21,854	23,556	24,238	26,356	27,898	29,182	30,258	31,617	33,049	34,556	36,139	37,800						
T1 for Zone 5-8	2,779	3,689	4,590	5,505	7,282	8,537	9,602	10,602	11,614	12,639	13,652	14,191	14,885	15,609	16,369	17,166	18,000						
01 for Distribution	2,737	3,327	3,961	4,604	5,256	5,914	6,584	7,212	7,854	8,508	9,095	9,574	9,982	10,457	10,952	11,466	12,000						
01 for Transmission for Zone-4	1,012	1,086	1,220	1,385	1,581	1,807	2,066	2,219	2,378	2,544	2,733	2,914	3,177	3,456	3,753	4,067	4,400						
01 for Transmission for Zone-3	278	358	422	491	563	638	717	803	892	985	1,066	1,248	1,413	1,571	1,781	1,984	2,200						
02	734	788	885	1,005	1,147	1,311	1,499	1,610	1,725	1,846	1,983	2,114	2,305	2,507	2,723	2,951	3,192						
03	350	414	480	551	624	702	786	873	965	1,064	1,172	1,288	1,384	1,557	1,743	1,942	2,154						
04	920	987	1,109	1,259	1,437	1,643	1,878	2,017	2,162	2,313	2,485	2,649	2,888	3,142	3,411	3,697	4,000						
(05)																							
06	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0						
07	1,452	1,744	2,055	2,367	2,680	2,994	3,310	3,623	3,940	4,261	4,592	4,908	5,251	5,609	5,988	6,388	6,800						
(08)																							
Total	23,995	28,203	31,907	35,799	40,738	45,323	49,914	57,419	61,755	66,185	70,535	73,593	77,571	81,767	86,186	90,836	95,724						

9. Pump Operation Cost (Baht x1,000/year)																							
Demand Charge	8,491	8,491	9,123	9,123	11,432	11,432	11,432	11,789	13,520	15,114	15,306	16,021	16,021	16,021	16,021	16,021	16,021						
Energy Charge	10,773	12,662	14,325	16,072	18,289	20,348	22,409	25,778	27,375	29,714	31,667	33,039	34,826	36,769	38,493	40,781	42,975						
Total Cost	19,264	21,153	23,448	25,195	29,721	31,779	33,841	37,567	41,245	44,839	46,973	49,660	50,846	52,738	54,714	56,802	58,996						
Total (1991-2011) =																						678,163	

Note: Pumps is designed for QM (Daily Maximum Demand) for transmission, and for QM (Hourly Maximum Demand) for distribution.

10. Energy Consumption (kWh) = No. of Pumps x Motor Output(kW) x 24 h/day x (actual daily demand(Qa)/max.capacity of pump)

11. Demand Charge = Baht $229 / \text{KWh/mon} \times 12 \text{ mon/year} \times \text{Motor Demand kW}$

Energy Charge = Baht $1.73 / \text{kWh} \times \text{Energy Consumption kWh/day} \times 365 \text{ days/year}$

Design Pump Head=(Head Loss of Pipeline)/(Actual Head, -0) (Pump Loss 1.5 %)

DA : Daily Average

DM : Daily Maximum

HM : Hourly Maximum

Electricity Fee = Rate of Provincial Electricity Authority(PEA) as of January, 1989.

Year	1,989	1,990	1,991	1,992	1,993	1,994	1,995	1,996	1,997	1,998	1,999	2,000	2,001	2,002	2,003	2,004	2,005	2,006	2,007	2,008	2,009	2,010	2,011
Operation Cost	0	0	0	0	0	0	17.3	21.2	23.4	25.2	27.7	31.8	33.0	37.6	41.2	44.8	47.0	49.1	50.8	52.7	54.7	56.8	
Discount Rate	10.00 %																						
HPY	154.31 x Million Baht																						

Water Transmission/Distribution Cost - Palue Thani & Prechatipol

Alternative : 2-1 & 3-1

Item	Year																						Loss (m)		
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011			
1. Transmission Pipe																									
No From To	Design flow (cu m/d)																						Head Loss for Q(2011)DR (m)		
1 12 02	172,382	1,200	9.0																				1.76	23.7	
2 02 1	194,120	1,000	8.5																					2.66	4.0
3 1 2	47,899	800	7.0																					1.08	12.1
4 1 3	18,840	500	6.0																					1.11	18.7
5 1 4	123,471	1,000	8.0																					1.82	27.6
6 4 01	88,223	800	6.7																					2.03	3.8
7 4 05	11,699	400	2.0																					1.08	7.7
8 01 7	108,153	800	2.7																					2.49	21.6
9 03 5	15,208	500	12.0																					0.90	25.2
10 5 6	3,042	300	10.5																					0.50	13.5
11 7 04	21,791	600	8.5																					0.89	14.3
12 04 8	28,329	500	5.8																					1.67	38.5
15 8 9	5,666	300	9.0																					0.97	36.5
16 11 10	94,376	900	3.0																					1.72	16.5
17 10 06	47,024	700	6.5																					1.41	21.4
18 08 12	47,414	600	1.0																					1.94	7.1
19 12 13	15,805	500	5.5																					0.93	12.4
20 12 14	15,805	500	4.5																					0.53	10.1
21 12 15	15,805	400	1.0																					1.46	6.7
22 13 14	4,741	300	4.5																					0.78	13.2
23 13 15	4,741	300	6.5																					0.78	19.0
24 10 11	47,351	700	2.5																					1.42	8.3
25 11 16	4,221	250	1.0																					1.00	5.7
27 11 07	36,800	500	2.6																					2.17	28.0
29 07 17	46,340	600	0.8																					1.90	5.4
30 17 18	4,001	300	5.8																					0.66	12.4
31 17 19	42,339	600	2.0																					1.73	11.5
32 19 20	20,005	500	7.5																					1.13	26.1
33 19 21	17,852	500	5.0																					1.05	14.1
34 21 22	7,829	400	5.0																					0.72	9.1
Total																						146.4 km			

Water Transmission/Distribution Cost - Petus Ihami & Prachinbat

Alternative : 2-1 & 3-1

Item	Year																				
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010

2. Required Pump Head and Flow Rate

Routing Pipe No.	Total Loss (ft)	Flow in 2011		Required Water Demand in Each Year (cu m/d)
		Q (m ³ /min)	Head (m)	
11	1	23.7	119.7	64,229
11	14-22-24	46.8	65.5	14,274
01	8-11	35.9	75.1	17,184
02	2-5-7	43.1	134.8	71,006
05	9-10	38.7	10.4	1,921
04	12	38.5	19.7	6,515
(05)				6,474
06	16-17	19.5	32.9	8,220
07	25-27-28	45.0	32.2	
(08)				

3. Flow Rate in Daily Average Operation (cu m/d)

Item	Q (cu m/min/unit)	H (m)	Motor Power (kw)	No. of Pump (unit)
11 for Zone 1-4	39.9	35.2	360	3 (excluding 1 unit stand-by)
11 for Zone 5-8	21.8	58.3	320	3 (excluding 1 unit stand-by)
01	25.0	47.4	300	3 (excluding 1 unit stand-by)
02	44.9	54.6	620	3 (excluding 1 unit stand-by)
03	5.3	50.2	70	2 (excluding 1 unit stand-by)
04	9.8	50.0	130	2 (excluding 1 unit stand-by)
(05)				
06	16.5	31.0	130	2 (excluding 1 unit stand-by)
07	16.1	54.5	220	2 (excluding 1 unit stand-by)
(08)				

4. Pump Characteristics

Item	Q (cu m/min/unit)	H (m)	Motor Power (kw)	No. of Pump (unit)
11 for Zone 1-4	39.9	35.2	360	3 (excluding 1 unit stand-by)
11 for Zone 5-8	21.8	58.3	320	3 (excluding 1 unit stand-by)
01	25.0	47.4	300	3 (excluding 1 unit stand-by)
02	44.9	54.6	620	3 (excluding 1 unit stand-by)
03	5.3	50.2	70	2 (excluding 1 unit stand-by)
04	9.8	50.0	130	2 (excluding 1 unit stand-by)
(05)				
06	16.5	31.0	130	2 (excluding 1 unit stand-by)
07	16.1	54.5	220	2 (excluding 1 unit stand-by)
(08)				

Alternative : 2-1 & 3-1

Year	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------	------

5. No. of Operating Pumps

Zone	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
T1 for Zone 1-4	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
T1 for Zone 5-8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(01)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(02)	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
(03)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(04)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(05)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(06)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(07)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(08)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

6. Maximum Pump Capacity (cu w/c)

T1 for Zone 1-4	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971	114,971
T1 for Zone 5-8	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459	31,459
(01)	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051	36,051
(02)	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413	129,413
(03)	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604
(04)	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164	14,164
(05)	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707	25,707
(06)	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170
(07)	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170
(08)	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170

7. Motor Output (kw)

T1 for Zone 1-4	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770	770
T1 for Zone 5-8	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320	320
(01)	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300	300
(02)	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240	1,240
(03)	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70
(04)	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
(05)	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
(06)	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220
(07)	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220
(08)	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220	220
Total	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130	3,130

Item	Year																						
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
8. Energy Consumption (kWh/day) for Daily Average Demand																							
T1 for Zone 1-4	8,048	9,071	9,857	10,688	11,566	12,488	13,460	14,251	15,060	15,890	16,675	17,290	18,067	18,285	19,745	20,551	21,690						
T1 for Zone 5-8	2,411	3,732	4,443	5,567	7,367	8,636	9,714	10,726	11,749	12,786	13,811	14,358	15,056	15,790	16,559	17,365	18,209						
01	3,601	4,277	5,030	5,817	6,843	7,503	8,404	9,184	9,986	10,908	11,647	12,282	13,066	13,891	14,760	15,672	16,630						
02	12,308	13,873	15,015	16,346	17,689	19,099	20,586	21,794	23,033	24,302	25,505	26,443	27,631	28,882	30,199	31,582	33,034						
03	272	350	414	480	551	624	702	786	873	965	1,122	1,222	1,384	1,537	1,743	1,942	2,154						
04	920	987	1,109	1,259	1,437	1,643	1,878	2,017	2,162	2,313	2,485	2,649	2,888	3,142	3,411	3,697	4,000						
(05)																							
06	546	729	896	1,068	1,705	1,884	2,068	2,249	2,432	2,619	2,885	3,024	3,201	3,387	3,582	3,786	4,000						
07	1,420	1,705	2,009	2,314	2,621	3,220	3,627	3,972	4,361	4,756	5,160	5,381	5,674	5,980	6,301	6,637	6,988						
(08)																							
Total	29,977	34,774	39,834	43,541	49,580	55,099	60,439	64,998	69,657	74,419	79,286	82,648	86,946	91,515	96,302	101,533	106,616						

Item	Year																						
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
9. Pump Operation Cost (Bant x1,000/year)																							
Demand Charge	8,601	8,601	8,601	8,601	10,305	10,305	11,267	13,328	14,317	15,196	16,213	16,213	16,213	16,213	16,213	16,213	16,213	16,213	16,213	16,213	16,213	16,213	
Energy Charge	13,436	15,589	17,524	19,548	22,259	24,737	27,134	29,181	31,273	33,419	35,595	37,105	39,043	41,066	43,235	45,493	47,865						
Total Cost	22,037	24,191	26,125	28,149	32,564	35,042	38,401	42,509	45,590	48,807	51,809	53,318	55,257	57,279	59,448	61,707	64,983						
Total (1991-2011) =																							746,955

Note: Pumps is designed for QM (Daily Maximum Demand) for transmission, and for QM (Hourly Maximum Demand) for distribution.

10. Energy Consumption (kWh) = No. of Pumps x Motor Output (kW) x 24 h/day x (actual daily demand(qls))/max.capacity of pump

11. Demand Charge = Bant x 229 /kW/ann x 12 mon/year x Motor Demand kW

Energy Charge = Bant x 1.23 /kWh x Energy Consumption kWh/day x 365 days/year

Design Pump Head=(Head Loss of Pipeline)+(Actual Head, =0)+(Residual Head 10.0 m)-(Pump Loss 1.5 m)

Da : Daily Average

DH : Hourly Maximum

HS : Hourly Maximum

Electricity fee = Rate of Provincial Electricity Authority (PEA) as of January, 1989.

Year	1,989	1,990	1,991	1,992	1,993	1,994	1,995	1,996	1,997	1,998	1,999	2,000	2,001	2,002	2,003	2,004	2,005	2,006	2,007	2,008	2,009	2,010	2,011
Operation Cost	0	0	0.0	0.0	0.0	0.0	22.6	24.2	26.1	28.1	32.6	35.6	38.4	42.5	45.6	48.6	51.8	53.3	55.3	57.3	59.4	61.7	
Discount Rate	10.00 %																						
NPV	171.17 x Million Bant																						

Water Transmission/Distribution Cost - Patan Thani & Prechatapet

Alternative : 2-1 & 3-2

Item	Year												Loss (%)																															
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001		2002	2003	2004	2005	2006	2007	2008	2009	2010	2011																					
1. Transmission Pipe : ***** shows a starting year of water transmission																																												
Design Flow																																												
No	From	To	Q 2011	Dia (mm)	L (km)																			Loss																				
			(cu m/d)																					(%)																				
1	11	1	172,382	1,000	2.5																			2.54																				
2	1	02	72,160	800	6.5																			1.67																				
3	1	01	99,922	900	7.0																			1.82																				
4	02	2	94,199	800	0.5																			2.17																				
5	2	3	47,999	700	7.0																			1.42																				
6	2	4	18,840	500	6.0																			1.11																				
7	2	5	23,550	600	6.7																			0.96																				
8	01	6	86,361	600	0.7																			3.54																				
9	6	7	43,181	600	4.0																			1.77																				
10	01	10	21,791	500	2.7																			1.28																				
11	01	03	11,699	300	2.7																			1.92																				
12	10	04	21,791	500	8.5																			1.28																				
13	03	8	15,208	500	12.0																			0.90																				
14	8	9	3,042	300	10.5																			0.50																				
15	04	11	28,379	500	5.8																			1.47																				
16	11	12	5,666	300	9.0																			0.93																				
17	11	13	89,506	800	5.5																			2.06																				
18	13	06	52,706	600	2.0																			2.16																				
19	06	14	21,103	400	0.2																			1.94																				
20	14	15	10,552	400	4.2																			0.97																				
21	06	16	67,414	600	1.0																			1.94																				
22	16	17	15,805	500	5.5																			0.93																				
23	16	18	15,805	500	4.5																			0.93																				
24	16	19	15,805	400	1.0																			1.46																				
25	17	19	4,741	300	6.5																			2.59																				
26	17	18	4,741	300	4.5																			2.99																				
27	13	07	35,300	500	2.6																			2.08																				
28	07	20	46,340	500	0.8																			2.73																				
29	20	21	4,001	300	5.8																			0.66																				
30	20	22	42,339	600	2.0																			1.73																				
31	22	23	20,005	500	7.5																			1.18																				
32	22	24	17,832	500	5.0																			1.05																				
33	24	25	7,829	400	5.0																			0.72																				
																							Total																					155.7

Alternative : 2-2 & 3-2

Item	Year																					
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011
2. Required Pump Head and Flow Rate																						
Routing	Required Water Demand in Each Year (cu m/d)																					
Pipe No.	Total Flow in 2011																					
	Loss (gpm) (cu m/min)																					
T1 3-3	43.3 119.7																					
T1 17-27	51.6 62.2																					
O1 8-9	38.8 60.0																					
O1 11 (Zone-3)	41.9 8.1																					
O1 10-12 (Zone-4)	45.7 15.1																					
O2 4-5	26.2 65.4																					
O3 13-14	38.7 10.6																					
O4 15 (05)	38.5 19.7																					
O6 21-22	19.5 47.6																					
O7 28-30-31 (08)	50.8 32.2																					

3. Flow Rate in Daily Average Operation (cu m/d)

T1 for Zone 1-4	53,524	60,326	65,556	71,082	76,923	83,054	89,519	94,774	100,119	105,677	110,900	114,790	120,155	125,597	131,322	137,338	143,652					
T1 for Zone 5-8	11,514	15,288	19,019	22,810	26,177	35,376	39,790	43,934	48,118	52,372	56,571	58,805	61,672	64,678	67,829	71,131	74,588					
O1 for Distribution	12,625	15,349	18,275	21,379	24,747	27,285	30,373	33,213	35,231	39,219	41,957	43,939	46,048	48,245	50,526	52,878	55,360					
O1 for Transmission for Zone-3	1,232	1,586	1,872	2,174	2,493	2,826	3,178	3,557	3,953	4,367	4,799	5,079	5,263	5,491	5,770	6,049	6,328					
O1 for Transmission for Zone-4	4,176	4,481	5,037	5,715	6,524	7,457	8,527	9,157	9,915	10,501	11,281	12,027	13,110	14,263	15,487	16,785	18,157					
O2	35,491	38,910	40,372	41,954	43,660	45,485	47,441	48,787	50,160	51,561	52,984	53,494	54,734	56,042	57,418	58,865	60,384					
O3	1,232	1,586	1,872	2,174	2,493	2,826	3,178	3,557	3,953	4,367	4,799	5,079	5,263	5,491	5,770	6,049	6,328					
O4	4,176	4,481	5,037	5,715	6,524	7,457	8,527	9,157	9,915	10,501	11,281	12,027	13,110	14,263	15,487	16,785	18,157					
(05)																						
O6	5,283	7,806	10,281	12,653	18,478	21,245	23,874	26,417	28,989	31,592	35,927	35,191	36,774	38,435	40,178	42,005	43,922					
O7	6,231	7,482	8,818	10,156	11,501	12,846	14,208	15,544	16,905	18,283	19,316	20,014	21,023	22,089	23,214	24,400	25,648					
(08)																						

4. Pump Characteristics

	Dia (mm)	Motor Power(kw)	H (m)	Q (cu m/min/unit)	No. of Pump(unit)
T1 for Zone 1-4	600	550	54.8	39.9	3 (excluding 1 unit stand-by)
T1 for Zone 5-8	500	360	68.5	20.7	3 (excluding 1 unit stand-by)
O1 for Distribution	400	260	50.3	28.0	3 (excluding 1 unit stand-by)
O1 for Transmission for Zone-3	300	110	53.4	8.1	1 (excluding 1 unit stand-by)
O1 for Transmission for Zone-4	400	220	57.2	15.1	1 (excluding 1 unit stand-by)
O2	500	210	37.7	21.8	3 (excluding 1 unit stand-by)
O3	300	70	50.2	5.3	2 (excluding 1 unit stand-by)
O4	300	130	50.6	9.8	2 (excluding 1 unit stand-by)
(05)					
O6	500	190	31.0	23.8	2 (excluding 1 unit stand-by)
O7	400	260	62.3	16.1	2 (excluding 1 unit stand-by)
(08)					
Total					22

Water Transmission/Distribution Cost - Patun Thani & Prachathipat

Alternative : 2-2 & 3-2

Item	Year										2011										
	1970	1971	1972	1973	1974	1975	1976	1977	1978	1979		2000	2001	2002	2003	2004	2005	2006	2007	2008	2009
5. No. of Operating Pumps																					
T1 for Zone 1-4	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
T1 for Zone 5-8	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
O1 for Distribution	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
O1 for Transmission for Zone-3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
O1 for Transmission for Zone-4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
B2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2
B3	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
B4	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(05)																					
B6	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
B7	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
(08)																					
6. Maximum Pump Capacity (cu s/d)																					
T1 for Zone 1-4	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921	114,921
T1 for Zone 5-8	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835	29,835
O1 for Distribution	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787	28,787
O1 for Transmission for Zone-3	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699	11,699
O1 for Transmission for Zone-4	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791	21,791
B2	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799	62,799
B3	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604	7,604
B4	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364	14,364
(05)																					
B6	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259	34,259
B7	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170	25,170
(08)																					
7. Motor Output (hp)																					
T1 for Zone 1-4	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109	1,109
T1 for Zone 5-8	360	360	360	360	360	360	360	360	360	360	360	360	360	360	360	360	360	360	360	360	360
O1 for Distribution	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260
O1 for Transmission for Zone-3	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110	110
O1 for Transmission for Zone-4	230	230	230	230	230	230	230	230	230	230	230	230	230	230	230	230	230	230	230	230	230
B2	420	420	420	420	420	420	420	420	420	420	420	420	420	420	420	420	420	420	420	420	420
B3	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70	70
B4	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130	130
(05)																					
B6	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190	190
B7	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260	260
(08)																					
Total	3,120	3,120	3,330	3,330	3,950	4,400	4,510	5,080	5,440	5,310	5,770	5,770	5,770	5,770	5,770	5,770	5,770	5,770	5,770	5,770	5,770

Water Transmission/Distribution Cost - Patun Thani & Prachinburi

Alternative : 2-2 & 3-2

Item	Year										Total (1991-2011)													
	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999		2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	
8. Energy Consumption (kwh/day) for Daily Average Demand																								
I1 for Zone 1-4	32,296	13,858	15,060	16,329	17,671	19,079	20,565	21,772	23,007	24,277	25,476	26,416	27,602	28,852	30,168	31,550	33,000							
I1 for Zone 5-8	3,334	4,427	5,908	6,606	8,739	10,245	11,523	12,723	13,937	15,167	16,382	17,029	17,666	18,730	19,643	20,599	21,600							
O1 for Distribution	2,137	3,327	3,961	4,604	5,256	5,914	6,384	7,212	7,854	8,508	9,095	9,524	9,982	10,457	10,952	11,466	12,000							
O1 for Transmission for Zone-3	278	358	422	491	563	638	717	803	892	985	1,146	1,248	1,413	1,591	1,781	1,984	2,200							
O1 for Transmission for Zone-4	1,012	1,086	1,220	1,385	1,581	1,807	2,066	2,219	2,378	2,544	2,733	2,914	3,177	3,456	3,753	4,067	4,400							
O2	670	719	808	917	1,047	1,197	1,369	1,470	1,575	1,686	1,811	1,931	2,104	2,289	2,486	2,694	2,915							
O3	350	414	480	551	624	702	786	876	965	1,072	1,222	1,384	1,557	1,743	1,942	2,154	2,388							
O4	920	987	1,109	1,259	1,437	1,643	1,878	2,017	2,162	2,313	2,485	2,649	2,838	3,142	3,411	3,677	4,000							
(O5)																								
O6	703	1,039	1,358	1,684	2,486	2,878	3,178	3,859	4,205	4,516	4,684	4,895	5,116	5,348	5,591	5,846	6,207							
O7	1,678	2,015	2,375	2,735	3,097	3,460	3,824	4,186	4,553	4,924	5,202	5,390	5,662	5,949	6,252	6,571	6,907							
(O8)																								
Total	73,628	28,167	30,235	36,490	42,427	47,434	52,405	56,703	61,092	65,573	69,769	73,007	76,366	81,140	85,536	90,151	95,072							
9. Pump Operation Cost (Baht x1,000)/year																								
Demand Charge	8,574	8,574	9,151	9,151	10,855	10,855	12,091	12,448	13,960	14,949	15,141	15,856	15,856	15,856	15,856	15,856	15,856							
Energy Charge	10,408	12,646	14,472	16,382	19,048	21,296	23,327	25,457	27,427	29,439	31,412	32,777	34,354	36,478	38,461	40,478	42,660							
Total Cost	19,181	21,219	23,623	25,533	29,902	32,150	35,619	37,905	41,387	44,388	46,554	48,633	50,410	52,284	54,257	56,334	58,516							
Total (1991-2011) =																						677,896		

Note: Pumps is designed for QM (Daily Maximum Demand) for transmission, and for QM (Hourly Maximum Demand) for distribution.

10. Energy Consumption (kWh) = No. of Pumps x Motor Output (kW) x 24 h/day x (actual daily demand(Qda)/max.capacity of pump)

11. Demand Charge = Baht $\frac{729 \text{ kWh/ton} \times 12 \text{ month/year} \times \text{Motor Demand MW}}{365 \text{ days/year}}$

Energy Charge = Baht $1.23 \text{ kWh} \times \text{Energy Consumption kWh/day} \times 365 \text{ days/year}$

Design Pump Head = (Head loss of Pipeline) + (Actual Head, = 0) + (Residual Head 10.0 m) + (Pump Loss 1.5 m)

DA : Daily Average

DM : Daily Maximum

HM : Hourly Maximum

Electricity fee = Rate of Provincial Electricity Authority (PEA) as of January, 1989.

Year	1,989	1,990	1,991	1,992	1,993	1,994	1,995	1,996	1,997	1,998	1,999	2,000	2,001	2,002	2,003	2,004	2,005	2,006	2,007	2,008	2,009	2,010	2,011	
Operation Cost	0	0	0.0	0.0	0.0	0.0	19.2	21.2	23.6	25.5	29.9	32.2	35.6	37.9	41.4	44.4	46.6	48.6	50.4	52.3	54.3	56.3	58.5	
Discount Rate	9.00 %																							
NPV	176.93 x Million Baht																							

APPENDIX A-8-4

Capacity Calculation for the Water Treatment Plant
and Distribution Reservoirs

Distribution Reservoir Capacity

Item	Alternative	
	1-1 2-1 3-1	1-2 2-2 3-2

1. D-1		
a. Zone-1 Demand (Daily Max)	75,501	75,501
b. Zone-3 Demand (Daily Max)	11,699	11,699
c. Zone-4 Demand (Daily Max)	12,722	12,722
* Required reservoir volume = a*6hrs+(b+c)* 0.5 hr	19,384	19,384
** Proposed Reservoir **		
a. D-1 at exis.new Plant exis. Reservoir 2,000 + New construction 5,000)	7,000	7,000
b. D-1 at old Plant New construction 13,000)	13,000	13,000

Total	20,000	20,000

2. D-2		
a. Zone-2 Demand (Daily Max)	74,074	74,074
b. Zone-1 Demand (Daily Max)	75,501	75,501
c. Zone-3 Demand (Daily Max)	11,699	11,699
d. Zone-4 Demand (Daily Max)	12,722	12,722
* Required reservoir volume = a*6hrs+(b+c+d)* 0.5hr	20,600	
= a*6hrs		19,019
** Proposed Reservoir **		
New Construction	20,600	19,100

3. D-3		
a. Zone-3 Demand (Daily Max)	11,699	11,699
* Required reservoir volume = a*6hrs	2,925	2,925
** Proposed Reservoir **		
a. D-3 at exis.Plant exis. Reservoir 1,000 + New construction 2,000)	3,000	3,000

Distribution Reservoir Capacity

Item	Alternative	
	1-1	1-2
	2-1	2-2
	3-1	3-2

4. D-4		
a. Zone-4 Demand (Daily Max)	12,722	12,722
* Required reservoir volume = a*6hrs	3,181	3,181
** Proposed Reservoir **		
a. D-4 at exis.Plant exis. Reservoir 1,000 + New construction 2,200)	3,200	3,200

5. D-6		
a. Zone-5 Demand (Daily Max)	16,233	16,233
b. Zone-6 Demand (Daily Max)	34,859	34,859
* Required reservoir volume = b*6hrs	8,715	
= (a+b)*6hrs		12,773
** Proposed Reservoir **		
New Construction	8,800	13,000

6. D-7		
a. Zone-7 Demand (Daily Max)	30,777	30,777
b. Zone-8 Demand (Daily Max)	6,023	6,023
* Required reservoir volume = (a+b)*6hrs	9,200	9,200
** Existing Reservoir Volume		
a. D-7 at exis.new Plant exis. Reservoir 500 + New construction 9,000)	9,500	9,500

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
Planned Flow (Daily Max)	Q= 283,000 cu m/d = 11,792 cu m/hr = 196.5 cu m/min = 3.275 cu m/sec	Q= 141,500 cu m/d = 5,896 cu m/hr = 98.3 cu m/min = 1.638 cu m/sec
No. of Treatment Line	4 Lines 70,750 cu m/d x 4 lines	2 Lines 70,750 cu m/d x 2 lines
(1) Receiving Well		
Criteria	T= 1.5 min d= 5 m	T= 1.5 min d= 5 m
No.	1 unit	1 unit
Dimension	Circular Dia 9 m v= 318 cu m t= 1.6 min	Circular Dia 9 m v= 318 cu m t= 3.2 min
(2) Mixing Tank		
Criteria	T= 1.0 min	T= 1.0 min
Dimension	Square x 4 units L m x W m x D m x units 4.0 4.0 3.0 4	Square x 2 units L m x W m x D m x units 4.0 4.0 3.0 2
	v = 192 cu m t = 1.0 min	v = 96 cu m t = 1.0 min
Mixer	Mechanical Flush Mixer	Mechanical Flush Mixer

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
:(3) Coagulant Mixer		
Coagulant	Solid Aluminum Sulphate (Al ₂ (SO ₄) ₃) containing 15 % Al ₂ O ₃	Solid Aluminum Sulphate (Al ₂ (SO ₄) ₃) containing 15 % Al ₂ O ₃
Dosage Rate	: 20-50 mg-solid alum/l Average 25 mg/l	: 20-50 mg(Al ₂ O ₃)/l Average 25 mg/l
Coagulant Solution	: 5 % solution	: 5 % solution
Dosage Amount	: 7,075 kg-Alum/day	: 3,538 kg-Al ₂ O ₃ /day
Coagulant Solution (5 % solution)	: = 142 cu m/day	: Coagulant Solution (5 %) = 71 cu m/day
No. of Mixer	: 8 units	: 4 units
Type	: Batch Type Mixing	: Batch Type Mixing
Capacity	: 17.7 cu m/unit	: 17.7 cu m/unit
Dimension	: Square x 8 units : L m x W m x D m x units : 3.0 3.0 2.0 8	: Square x 4 units : L m x W m x D m x units : 3.0 3.0 2.0 4
	: v = 18.0 cu m/unit	: v = 18.0 cu m/unit
	: Total V = 144.0 cu m	: V = 72.0 cu m

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
(4)		
Flocculator		
Type	Mechanical Flocculator	Mechanical Flocculator
No.	N = 4 lines x 4 units = 16 units	N = 2 lines x 4 units = 8 units
Unit Flow	q = 12.28 cu m/min/unit	q = 12.28 cu m/min/unit
Criteria	T = 30 min n = 3 stages	T = 30 min n = 3 stages
Dimension	W m x L m x D m x n stages 10 3.6 3.6 3	W m x L m x D m x n stages 10 3.6 3.6 3
	v = 389 cu m/unit	v = 389 cu m/unit
	t = 31.7 min	t = 31.7 min

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
(5)		
Sedimentation Basin		
Type	Rectanglar, Horizontal Flow	Rectanglar, Horizontal Flow
No.	N = 4 line x 4 basins = 16 basins	N = 2 line x 4 basins = 8 basins
Unit Flow	q = 737.0 cu m/hr/basin	q = 737.0 cu m/hr/basin
Criteria	Retention Time T = 4 hours	Retention Time T = 4 hours
Dimension	W m x L m x D m x N 12 50 5.0 16	W m x L m x D m x N 12 50 5.0 8
	v = 3,000 cu m/basin	v = 3,000 cu m/basin
	t = 4.1 hours	t = 4.1 hours
Flow velocity	v = 20.5 cm/min	v = 20.5 cm/min
Surface Load	a = 29.5 m ³ /m ² /day	a = 29.5 m ³ /m ² /day
Sludge Removal	Mechanical Scraper	Mechanical Scraper
Sludge Amount		
Solid Amount (ton-DS)	$S_o = Q(K(T_1 - T_2) + 0.16 \times B) \times 10^{-6}$ where S_o : Sludge dry weight (ton) Q : Treated water amount (m ³ /d) K : Coefficient converting turbidity to SS (0.8-1.5 -> 1.2) T_1 : Turbidity in raw water (ave 57) T_2 : Turbidity after Sedimentation (ave = 7) B : Alum dosage rate (ave. = 25 mg/l)	
	$S_o = 18.11$ ton-DS/day	$S_o = 9.06$ ton-DS
Water Contents of Drained Sludge	w = 99.5 %	w = 99.5 %
Sludge Volume	v = 3,622 cu m/d	v = 1,811 cu m/d

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
(6)		
Rapid Sand Filter		
Type	Down Flow, Single Media	Down Flow, Single Media
No.	N = 4 lines x 4 units = 16 units	N = 2 lines x 4 units = 8 units
Unit Flow	q = 17,688 cu m/day/unit	q = 17,688 cu m/day/unit
Criteria	Surface Load 120 - 150 m ³ /m ² /day	Surface Load 120 - 150 m ³ /m ² /day
Dimension	W m x L m x N units 10 15.0 16 a = 150 sq m/unit	W m x L m x N units 10 15.0 8 a = 150 sq m/unit
Surface Load	La = 117.9 m ³ /m ² /day	La = 117.9 m ³ /m ² /day
Filter Washing		
Frequency	Once a day for each filter	Once a day for each filter
Rate	Surface Washing 0.2 m ³ /m ² /min x 5 min Backwashing 0.6 m ³ /m ² /min x 10 min	Surface Washing 0.2 m ³ /m ² /min x 5 min Backwashing 0.6 m ³ /m ² /min x 10 min
Water Amount required	Surface Washing v = 150 sq m/unit x 16 units x 0.2 m ³ /m ² /min x 5 min = 2,400 cu m/day Backwashing v = 150 sq m/unit x 16 units x 0.6 m ³ /m ² /min x 10 min = 14,400 cu m/day	Surface Washing v = 150 sq m/unit x 8 units x 0.2 m ³ /m ² /min x 5 min = 1,200 cu m/day Backwashing v = 150 sq m/unit x 8 units x 0.6 m ³ /m ² /min x 10 min = 7,200 cu m/day
	Total q = 16,800 cu m/day	Total q = 8,400 cu m/day

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
Solid Amount in Wastewater		
Solid Amount (ton-DS)	$So = Q * K * (T1 - T2) * 10^{-6}$ <p>where So: Sludge dry weight (ton) Q : Treated water amount (m³/d) K : Coefficient converting turbidity to SS (0.8-1.5 ->> 1.2) T1 : Turbidity before filter (ave 7) T2 : Turbidity after filter (ave = 0) B : Alum dosage rate (ave. = 25 mg/l)</p>	
	So = 2.38 ton-DS/day	So = 1.19 ton-DS
SS Contents	s = 142 mg/l	s = 142 mg/l

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
:(7)		
:Clear Water Reservoir		
No.	N = 2 units	N = 1 units
Criteria	Retention Time	Retention Time
	T = 3 hours	T = 3 hours
Required Volume	V = 35,375 cu m	V = 17,688 cu m
Dimension	L m x W m x D m x N units	L m x W m x D m x N units
	60 60 5 2	60 60 5 1
	Total Volume	Total Volume
	v = 36,000 cu m	v = 18,000 cu m
Retention Time	t = 3.1 hours	t = 3.1 hours
:(8)		
:Chlorination Equipaent		
Injection Point	at the Inlet of Clear Water Reservoir	at the Inlet of Clear Water Reservoir
Dosage Rate	2.0 ppm	2.0 ppm
Type	Liquid Chlorine (1-ton cylinder)	Liquid Chlorine (1-ton cylinder)
Amount	566 kg- Cl gas/day	283 kg- Cl gas/day
Injector	Vacuum Type Injector	Vacuum Type Injector
	No. of unit 4 units (excl. 2 units stand-by)	No. of unit 2 units (excl. 1 units stand-by)
	Rate 5.90 kg/h/unit	Rate 5.90 kg/h/unit
	Capacity 10 kg/h/unit	Capacity 10 kg/h/unit
Storage	1 month	1 month
Storage Amount	566 kg /day x 30 day = 16,980 kg = 17 cylinders	283 kg /day x 30 day = 8,490 kg = 9 cylinders

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
(9)		
Sludge Lagoon		
Filter Washing Water	ql = 16,800 cu m/day	ql = 8,400 cu m/day
Retention Time	T = 1.0 day	T = 1.0 day
Required Volume	v = 16,800 cu m	v = 8,400 cu m
No of Lagoon	n = 2 units	n = 2 units
Dimension	(Bottom) L m x W m x D m x H 68 33 3.0 2	(Bottom) L m x W m x D m x H 68 33 3 2
	(Top) L m x W m 80 45	(Top) L m x W m 80 45
	v = 17,532 cu m	v = 17,532 cu m
Side Slope	s = 1 : 2.0	s = 1 : 2.0
Retention Time	t = 1.04 Day	t = 2.09 Day

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
(10) Sludge Drying Bed		
Drain Water from Sedimentation Basin		
Volume :	v1 = 3,622 cu m/d	v1 = 1,811 cu m/d
Solid :	s1 = 18.1 ton-DS/d	s1 = 9.1 ton-DS/d
Drain Water from Sludge Lagoon (Thickened backwash water)		
Solid :	s1 = 2.4 ton-DS/d	s1 = 1.2 ton-DS/d
Water Contents :	w = 99.0 %	
Volume :	v = 238 cu m/d	
Total Solid :	s = s1 + s2 = 20.5 ton-DS/d	s = s1 + s2 = 10.2 ton-DS/d
Water Contents of Dried Sludge :	w = 55 %	w = 55 %
Sludge Thickness :	d = 60 cm after dried	d = 60 cm
Drying Period :	t = 30 day	t = 30 day
Required Area :	a = 2,277 sq m	a = 1,138 sq m
No of Unit :	n = 4 units	n = 2 units
Type :	Rectangular, Concrete Made	
Dimension :	L x W x D x N	(Bottom) L x W x D x N
	30 x 20 x 1 x 4	30 x 20 x 1 x 2
Surface Area :	a = 2,400 sq m at Bottom	a = 1,200 sq m at Bottom

Capacity Calculation for Treatment Plant

Item	Total System (for 2011)	Phase 1 (for 2001)
:(11) Clear Water Pump		
:for Zone 1-4		
No.	: N = 3 units + 1 stand-by	: N = 2 units + 1 stand-by
Flow per unit	: q = 40.4 cu m/min/unit	: q = 40.4 cu m/min/unit
Diameter	: D = 600 mm	: D = 600 mm
Head	: H = 50 m	: H = 50 m
Motor output	: P = 560 KW	: P = 560 KW
Total Capacity	: Q = 174,528 cu m/day	: Q = 116,352 cu m/day
:for Zone 5-8		
No.	: N = 3 units + 1 stand-by	: N = 1 units + 1 stand-by
Flow per unit	: q = 21.3 cu m/min/unit	: q = 21.3 cu m/min/unit
Diameter	: D = 400 mm	: D = 400 mm
Head	: H = 72 m	: H = 72 m
Motor output	: P = 300 KW	: P = 300 KW
Total Capacity	: Q = 92,016 cu m/day	: Q = 30,672 cu m/day
:(12) Sludge Lagoon Drain Pump		
No.	: N = 2 units + 1 stand-by	: N = 2 units + 1 stand-by
Quantity drained	: Q = 16,800 cu m/day	: Q = 8,400 cu m/day
Draining Time	: t = 12.0 hours	: t = 12.0 hours
Pump Flow	: q = 11.7 cu m/min/unit	: q = 11.7 cu m/min/unit
Diameter	: D = 300 mm	: D = 300 mm
Head	: H = 10 m	: H = 10 m
Motor output	: P = 30 KW	: P = 30 KW