

5.2.20 Paper Products Factory (B)

- 1) Name of facility surveyed                      Boiler (No. 1)
- 2) Specification of facility
- |                       |  |
|-----------------------|--|
| Model                 | Water-tube type package boiler                               |
| Capacity              | 9.5 ton/hr   |
| Draft and ventilation | Forced draft   |
| Size of furnace       | 1,428 <sup>W</sup> x 3,612 <sup>D</sup> x 2,553 <sup>H</sup> |
| Number of burner      | 1 unit (heavy oil burner)                                    |
| Furnace pressure      | Unknown  |
| Ancillary facility    | None   |
- 3) Specification of burner
- |                    |                                  |
|--------------------|----------------------------------|
| Model              | Steam atomization type           |
| Type of fuel       | Heavy oil                        |
| Fuel consumption   | 870 l/hr (estimated)             |
| Fuel pressure      | 6.0 kg/cm <sup>2</sup> g         |
| Atomizing pressure | 7.3 kg/cm <sup>2</sup> g (steam) |

4) Analytical data of flue gas

(Stack sampling data)                      13:00/Load at 80% of rating

NO <sub>x</sub> (ppm)*	204	Particulate matter (g/Nm <sup>3</sup> )	0.034
O <sub>2</sub> (%)	6.6	Flue gas temperature (°C)	345
CO (%)	<0.05	Combustion chamber outlet O <sub>2</sub> (%)	-
CO <sub>2</sub> (%)	9.6		

(Emission)

	kg/hr
NO <sub>x</sub>	2.5
SO <sub>2</sub> **	45
Particulate	0.23

\* Converted to oxygen concentration of 5%

\*\* Calculated from analytical value of fuel

5) Observation

This boiler is used to generate steam to heat drums for production of corrugated fiberboard. The boiler is operated from 10:00 on Monday to 14:00 on Saturday continuously with total 124 hours per week.

Two units of the water-tube package boiler made by Combustion Engineering were installed in 1963, and are operated alternately by the 3-months period.

Water supply to the boilers are made directly from the hot-water tank, and air preheaters are not provided.

This plant is one of a few plants having the Orsat analyzer for measurement of CO, O<sub>2</sub>, and CO<sub>2</sub> among those surveyed in this Study. The plant seemed to be highly concerned with heat control

The steam atomization type burner is used, and its performance is satisfactory during normal operation with no stack smoke observed. The NO<sub>x</sub> concentration was 204 ppm as converted to 5% O<sub>2</sub>, which is considered standard for a burner without NO<sub>x</sub> control.

The O<sub>2</sub> content was slightly high at 6.5 - 6.8% in the normal operation. As a result of closing of air damper to set the O<sub>2</sub> content to 5.0 - 5.4%, the NO<sub>x</sub> concentration became 188 ppm, about 7% down. Because of burner and boiler construction, the air ratio could not be decreased further.

As NO<sub>x</sub> reduction measures, the use of low-NO<sub>x</sub> burner to decrease the air ratio and the use of desulfurized heavy oil to reduce the SO<sub>x</sub> and fuel NO<sub>x</sub> generation are recommended.

## 6) Countermeasures

### i) Retrofitting of the boiler

- (a) Low air ratio combustion through continuous monitoring of the flue gas O<sub>2</sub>
- (b) Installation of low NO<sub>x</sub> burners

### ii) Fuel change

- (a) Mixed combustion with 50% heavy oil and 50% diesel or natural gas up to the supply start of desulfurized heavy oil
- (b) When supply of desulfurized heavy oil is started, it should be used exclusively (100%)
- (c) Emulsified combustion of desulfurized heavy oil should be taken into consideration after thorough demonstration tests.

7) Expenses for boiler retrofitting

Retrofitting for low NOx burner installation, low air ratio combustion, and for mixed combustion of heavy oil and diesel

i) Foreign portion

		(US\$)
(a) Survey and design	1 set	5,400
(b) Burners (900 l/hr)	1 set	70,000
(c) Combustion control system and electric instrumentation	1 set	23,100
(d) Package and freight	1 set	11,300
(e) Travelling	1 set	4,400
(f) <u>Unexpected expenses (5% of the above)</u>		<u>5,710</u>
Sub-total		119,910

ii) Local portion

(g) Burner removal and installation	1 set	1,600
(h) Local installation on-site supervision	1 set	1,600
(i) Test operation and adjustment	1 set	800
(j) Electric instrumentation installation work	1 set	4,700
(k) Customs and other taxes	1 set	29,410
(l) Warehouse, customs clearance, and land freight (incl. IVA)	1 set	1,810
(q) <u>IVA (15% excl. k + l)</u>		<u>1,890</u>
Sub-total		41,810

Total US\$ 161,720

Note: There is one more boiler which is the similar type as the boiler No. 1 burning the same fuel. The similar retrofitting works are considered necessary for this boiler..

8) Summary of control measures

Table 5.2.20 summarizes the control measures for the Paper Products Factory (B).

Table 5.2.20 Summary of Control Measures for the Paper Products Factory (B)

		Current Status	Control measures		
			A	B	C
Fuel type		Heavy oil	Heavy oil 50% Diesel 50%	Desulfurized heavy oil 100%	Desulfurized heavy oil 100%
Combustion method		-	-	-	Emulsified combustion
Fuel Consumption	Heavy oil (10 <sup>3</sup> m <sup>3</sup> /yr)	2.844	1.422	2.844	2.844
	Diesel (10 <sup>3</sup> m <sup>3</sup> /yr)		1.422		
Emission (ton/yr)	NOx	1.27	0.71	0.91	0.71
	SO <sub>2</sub>	170.64	99.54	45.29	45.39
	PM	0.839	0.671	0.671	0.503
Reduction ratio (%)	NOx		44	28	44
	SO <sub>2</sub>		41	73	73
	PM		20	20	40
Equipment cost	Furnace retrofit, etc.		323.44	323.44	323.44
	NOx, SO <sub>2</sub> telemeter		-	-	-
Running cost (approx.)(1,000US\$/yr)					
Facility depreciation (15 yrs)			21.6	21.6	21.6
Interest (first 5 yrs: 8%)			25.9	25.9	25.9
Maintenance cost (5%)			16.2	16.2	16.2
Heavy oil		220.6	110.3	-	-
Diesel		-	292.6	-	-
Desulfurized heavy oil		-	-	309.6	-
Desulfurized heavy oil emulsion		-	-	-	377.3
Total (1,000 US\$/yr)		220.6	466.6	373.3	441.0

Alternative B: Applicable after the start of supplying desulfurized heavy oil.

Alternative C: Emulsified combustion should be taken into consideration after thorough demonstration tests.

5.2.21 Metal Products Factory (A)

1) Name of facility surveyed Heating furnace for casting billet

2) Specification of facility

Model	Pusher furnace
Capacity	4.7 ton/hr
Draft and ventilation	Forced draft
Size of furnace	2,560 <sup>W</sup> x 10,550 <sup>D</sup> x 1,200 <sup>H</sup>
Number of burners	Two units (natural gas burner)
Furnace pressure	Approx. atmospheric pressure
Furnace temperature	1,100 ~ 1,300°C
Ancillary facility	None

3) Specification of burner

Model	Cone mix type
Type of fuel	Natural gas
Fuel consumption	1,000 m <sup>3</sup> /hr
Fuel pressure	0.8 kg/cm <sup>2</sup> g

4) Analytical data of flue gas

(Stack sampling data) 12:00/Normal operation

NO <sub>x</sub> (ppm)*	130	Particulate matter (g/Nm <sup>3</sup> )	-
O <sub>2</sub> (%)	3.4	Flue gas temperature (°C)	925
CO (%)	<0.05	Combustion chamber outlet O <sub>2</sub> (%)	-
CO <sub>2</sub> (%)	9.3		

(Emission)

	kg/hr
NO <sub>x</sub>	0.85
SO <sub>2</sub> **	-
Particulate	-

NO<sub>x</sub> at rated operation is estimated to be 200 ppm (1.31 kg/hr).

\* Converted to oxygen concentration of 5%

\*\* Calculated from analytical value of fuel

5) Observation

This is a pusher-type heating furnace for hot rolling of billets (80x80x2,000 mm) to produce bar steels for reinforcement. Advance of the billets and flow of combustion gas from two burners are in opposite direction. Loading and unloading with the pusher are made manually.

Operation is intermittent, at 16.5 hours per day, with breaks for meals. There is an opening for inspection and cleaning in the wall opposite to the opening for unloading. Manipulation of the former opening causes a substantial change in the air ratio. The furnace wall is made of refractories with thickness of 350 - 400 mm. Though the temperature of the outer wall surface is low at 43 - 47°C, the loss of accumulated heat is very large in this type of furnace operating intermittently. The heat accumulation amount under the steady-state temperature is calculated to be equivalent to over 1,000 hours of fuel gas input. Operation of 16.5 hours a day will not bring about a steady-state temperature of the furnace wall. But reduction of the weight of the furnace wall may achieve a considerable degree of energy saving. It is also possible to shorten the start-up period in the morning.

The flue gas was discharged with a high temperature of 930°C. In this case also, energy saving of 20 - 30% may be easily achieved by installing the simple recuperator.

Introduction of draft control will also prove effective in preventing air intrusion from the above mentioned opening for inspection and cleaning.

Though assessment of the furnace alone is impossible due to the connection with the rolling mill, not only degradation of heating efficiency, but also increase in the scale loss is possibly induced by the multiplying effect of the unnecessarily high furnace temperature and the excessively high O<sub>2</sub> content due to the air intrusion.

The unit fuel consumption of this furnace is approximated at  $1,400 \times 10^3$  kcal/ton though this value may not be accurate because of inadequacies in fuel gas measurement and heat control data. It is evident from comparison with the unit fuel consumption in Japan for wire rod heating furnaces being around  $300 \times 10^3$  kcal/ton (Iron and Steel Handbook) that the heating efficiency of this furnace is low.

The NO<sub>x</sub> concentration was 130 ppm as converted to 5% O<sub>2</sub>, which is considerably low due to lack of air preheating. No particular NO<sub>x</sub> reduction measure seems to be necessary, but employment of some energy saving measures will lead to reduction of fuel consumption and reduction of NO<sub>x</sub> emissions. It is therefore recommended that the two-stage combustion type

low-NOx burner and the heat exchanger for waste heat recovery be adopted in combination.

6) Countermeasures

(a) Installation of the two-stage combustion type low NOx burners

(b) Installation of a heat exchangers for waste heat recovery

7) Expenses for facility retrofitting

Installation of two stage combustion type low NOx burners and a heat exchanger for waste heat recovery.

i) Foreign portion

		(US\$)
(a) Survey and design	1 set	19,300
(b) Low-NOx burner	2 units	58,500
(c) Waste heat recovery heat exchanger (incl. heat-resistant piping, and expansion joint)	1 set	153,900
(d) Local work on-site supervision	1 set	23,100
(e) On-site instruction for test operation	1 set	7,700
(f) Package and freight	1 set	6,000
(g) Travelling	1 set	17,200
(h) Unexpected expenses (5% on above)		<u>14,300</u>
Sub-total		300,000

ii) Local portion

		(US\$)
(i) Burner removal and installation	1 set	800
(j) Duct fabrication	1 set	7,700
(k) Duct installation	1 set	2,000
(l) Air heater foundation work (steel frame, concrete, steel bar)	1 set	6,200
(m) Test operation and adjustment	1 set	800
(n) Customs and other taxes	1 set	61,320
(o) Warehouse, customs clearance, and land freight (incl. IVA)	1 set	8,130

(p) Duct, etc. freight, crane rental	1 set	2,000
(q) IVA (15% excl. n + o)		3,000
Sub-total		91,950
Total		US\$ 391,950

Note: In this factory, there is another heating furnace of the similar type and capacity using the same fuel as the surveyed furnace, and the same countermeasures are considered to be required.

9) Summary of control measures

Table 5.2.21 summarizes the control measures for Metal Products Factory (A).

Table 5.2.21 Summary of Control Measures for Metal Products Factory (A)

		Current Status	Counter measures
Fuel type		Natural gas	Natural gas
Fuel Consumption	Natural gas (10 <sup>6</sup> m <sup>3</sup> /yr)	7.07	5.66
Emission (ton/yr)	NOx	7.7	5.4
	PM	- (1)	
Reduction ratio (%)	NOx		30
	PM		20
Equipment cost (1,000 US\$)			783.9 (2)
Running cost (approx.)(1,000 US\$/yr)			
Facility depreciation (15 yrs)			52.3
Interest (first 5 yrs: 8%)			62.7
Maintenance cost (5%)			39.2
Natural gas		589.2	471.7
Total (1,000 US\$/yr)		589.2	625.9

Note: (1) Measurement was not possible because of the high temperature of the exhaust gas.

(2) Installation expenses (US\$ 391,950) for low NOx burners and heat exchanger for waste heat recovery for the two heating furnaces.



## 5.2.22 Metal Products Factory (B)

- 1) Name of facility surveyed Aluminum melting furnace
- 2) Specification of facility
- |                       |  |
|-----------------------|--|
| Model                 | Reverberatory furnace  |
| Capacity              | 20 ton/hr  |
| Draft and ventilation | Forced draft   |
| Size of furnace       | 3,960 <sup>W</sup> x 3,860 <sup>D</sup> x 1,715 <sup>H</sup> |
| Number of burner      | One unit (natural gas burner)                                |
| Furnace pressure      | -1 ~ -2 mmH <sub>2</sub> O                                   |
| Furnace temperature   | 820°C  |
| Ancillary facility    | None   |

### 3) Specification of burner

- |                  |                                     |
|------------------|-------------------------------------|
| Model            | Cone mix                            |
| Type of fuel     | Natural gas                         |
| Fuel consumption | 264 m <sup>3</sup> /hr (estimated)  |
| Fuel pressure    | 4.75 kg/cm <sup>2</sup> g (primary) |

### 4) Analytical data of flue gas

(Stack sampling data) 15:30/Load at 75% of rating				(Emission)	
NOx (ppm)*	32	Particulate matter (g/Nm <sup>3</sup> )	0.13		kg/hr
O <sub>2</sub> (%)	6.8	Flue gas temperature (°C)	890	NOx	0.10
CO (%)	<0.05	Combustion chamber outlet O <sub>2</sub> (%)	-	SO <sub>2</sub> **	-
CO <sub>2</sub> (%)	7.3			Particulate	0.22

\* Converted to oxygen concentration of 5%

\*\* Calculated from analytical value of fuel

### 5) Observation

This is a reverberatory type aluminum melting furnace with a natural gas burner. Aluminum ingot produced in this furnace is annealed and withdrawn to manufacture aluminum sashes. The plant is confident about competitiveness of the quality of their product in the international market.

The process from loading of raw materials to casting of ingots is completed in about eight hours. The NOx concentration in the flue gas was nearly

constant although there were some variations in the furnace operation. During certain operation stages such as loading of raw materials and addition of additives for sludge removal, smoke and soot were generated due to impurities from scrap materials and additives, deteriorating the neighboring and working environment. In this sense, control measures against smoke and soot are more necessary than NOx reduction measures.

6) Countermeasures

- (a) Installation of a hood on the furnace opening
- (b) Installation of a a bag filter or an EP on the furnace flue outlet

7) Expenses for installation of bag filter

i) Foreign portion

		(US\$)
(a) Survey and design	1 set	5,400
(b) Bag filter	1 set	65,400
(c) Blower	1 set	12,300
(d) Local work on-site supervision	1 set	3,100
(e) On-site instruction for test operation	1 set	3,100
(f) Travelling	1 set	10,000
(g) Unexpected expenses (5% on above)		<u>5,000</u>
Sub-total		104,300

ii) Local portion

		(US\$)
(h) Duct fabrication	1 set	7,700
(i) Foundation work	1 set	600
(j) Installation work	1 set	4,700
(k) Test operation and adjustment	1 set	800
(l) Work vehicles	1 set	1,600
(m) Customs and other taxes	1 set	22,000
(n) IVA (15% excl. m)		<u>2,200</u>
Sub-total		38,900
Total		US\$ 143,200

Note: Since freightage for bag filters differs with freight package conditions, their freightage from the shipping place to the destination and customs expenses are not estimated here.

8) Reduction ratio

Fuel consumption : 10%  
 NOx : 5%  
 PM : 50%

9) Summary of control measures

Table 5.2.22 summarizes the control measures for Metal Products Factory (B).

Table 5.2.22 Summary of Control Measures for Metal Products Factory (B)

		Present Status	Control measures
Fuel type		Natural gas	Natural gas
Equipment		-	- Hood on the opening - Bag filter
Fuel Consumption	Natural gas (10 <sup>6</sup> m <sup>3</sup> /yr)	2.97	2.83 (10% fuel saving)
Emission (ton/yr)	NOx	1.0	0.95
	PM	2.2	1.1
Reduction ratio (%)	NOx		5
	PM		50
Equipment cost (1,000 US\$)			143.20
Running cost (approx.)(1,000US\$/yr)			
Facility depreciation (15 yrs)			9.5
Interest (first 5 yrs: 8%)			11.5
Maintenance cost (5%)			7.2
Natural gas		247.5	235.8
Total (1,000 US\$/yr)		247.5	264.0

### 5.2.23 Food Products Factory

1) Name of facility surveyed                      Boiler for processing (No. 2)

2) Specification of facility

Model    Water-tube boiler  
 Capacity                                        45.4 ton/hr  
 Draft and ventilation                      Forced draft type  
 Structure and size of furnace            1,920<sup>W</sup> x 5,310<sup>D</sup> x 3,600<sup>H</sup>  
 Number and layout of burner            1 unit (heavy oil burner)  
 Furnace pressure                            100 mmAq  
 Ancillary facility                            Air preheater

3) Specification of burner

Model    Steam pressure atomization type (Y-jet)  
 Type of fuel                                    Heavy oil  
 Fuel consumption                            3,400 l/hr (estimated)  
 Fuel pressure                                 13 kg/cm<sup>2</sup>g  
 Atomizing pressure                         12 kg/cm<sup>2</sup>g (steam)

4) Analytical data of flue gas

(Stack sampling data)		14:30/Load at 80% of rating		(Emission)	
NOx (ppm)*	202	Particulate matter (g/Nm <sup>3</sup> )	0.21		kg/hr
O <sub>2</sub> (%)	4.8	Flue gas temperature (°C)	235	NOx	10
CO (%)	<0.05	Combustion chamber outlet O <sub>2</sub> (%)	--	SO <sub>2</sub> **	260
CO <sub>2</sub> (%)	11.5			Particulate	4.9

NOx at rated operation is estimated to be 220 ppm (11.0 kg/hr).

\* Converted to oxygen concentration of 5%

\*\* Calculated from analytical value of fuel

5) Observation

Two boilers are used in parallel for generation of process steam. A drain recovery system is attached. The load during normal operation is low at about 50%. The boiler has an air preheater and the flue gas temperature was 205°C at the normal load and 262°C at the 80% load.

The burner is the steam-atomization type and the NOx concentration, as converted to 5% O<sub>2</sub>, was 180 - 190 ppm. When measurement was made at the 100% load while shutting down one boiler, the NOx concentration at 5% O<sub>2</sub> was 202 ppm.

NOx reduction measures to be considered include (1) operation with maintaining the appropriate O<sub>2</sub> level and (2) use of flue gas recirculation or low-NOx burner.

#### 6) Countermeasures

##### i) Retrofitting of the boiler

- (a) Automatic control of air ratio
- (b) Installation of flue gas fan for flue gas recirculation and installation of low NOx burners

##### ii) Fuel change

- (a) Mixed combustion with 50% heavy oil and 50% diesel or natural gas up to the supply start of desulfurized heavy oil
- (b) When supply of desulfurized heavy oil is started, it should be used exclusively (100%)
- (c) Emulsified combustion of desulfurized heavy oil should be taken into consideration after thorough demonstration tests.

##### iii) Continuous monitoring of the flue gas by installing the NOx, SO<sub>2</sub> telemeters

#### 7) Expenses for boiler retrofitting

Retrofitting for flue gas recirculation, low NOx burner installation, and for automatic control of air ratio

##### i) Foreign portion

		(US\$)
(a) Survey and design	1 set	19,300
(b) Burners (3,000 l/hr)	1 set	103,900
(c) Flue gas recirculation fan (120 m <sup>3</sup> )	1 set	25,400
(d) Combustion control system and		

electric instrumentation	1 set	77,000
(e) Automatic air ratio controller	1 set	46,200
(f) Local joint work	1 set	23,100
(g) On-site instruction for test operation	1 set	7,700
(h) Package and freight	1 set	13,500
(i) Travelling	1 set	17,200
(j) <u>Unexpected expenses (5% of the above)</u>		<u>16,700</u>
Sub-total		350,000

ii) Local portion

(k) Burner removal work	1 set	1,600
(l) Duct fabrication	1 set	53,900
(m) Burner, duct, fan installation	1 set	7,300
(n) Trial operation on-site attendance	1 set	800
(o) Customs and other taxes	1 set	76,300
(p) Warehouse, customs clearance, and land freight (incl. IVA)	1 set	5,420
(q) <u>IVA (15% excl. o + p)</u>		<u>9,540</u>
Sub-total		154,860

Total US\$ 504,860

8) Installation of the NO<sub>x</sub>, SO<sub>2</sub>, O<sub>2</sub> telemeter

Expenses for telemeter instrumentation system on the flues of No. 1 and No. 2 boilers

i) Foreign portion

		(US\$)
(a) Survey and design	1 set	6,200
(b) NO <sub>x</sub> , SO <sub>2</sub> , O <sub>2</sub> instrumentation	2 sets	118,600
(c) Auxiliary units	2 sets	41,100
(d) Data logger	1 set	17,900
(e) Installation work on-site supervision	1 set	8,500
(f) On-site instruction for test operation	1 set	4,700
(g) Package and freight	1 set	25,900

(h) Travelling	1 set	11,900
(i) Unexpected expenses (5% of the above)		11,740
Sub-total		246,540

ii) Local portion

		(US\$)
(j) Materials	1 set	4,200
(k) Survey assistant	1 set	1,300
(l) Installation expenses	1 set	4,400
(m) Trial operation on-site adjustment	1 set	1,400
(n) Vehicle rental	1 set	2,200
(o) Customs and other taxes	1 set	41,690
(p) Warehouse, customs clearance, and land freight	1 set	3,250
(q) IVA (15% excl. o + p)		2,030
Sub-total		60,470

Total US\$ 307,010

(Telephone installation work and central reception system are not included.)

9) Summary of control measures

Table 5.2.23 summarizes the control measures for the Food Products Factory.

Table 5.2.23 Summary of Control Measures for the Food Products Factory

		Current Status	Control measures		
			A	B	C
Fuel type		Heavy oil	Heavy oil 50% Diesel 50%	Desulfurized heavy oil 100%	Desulfurized heavy oil 100%
Combustion method		-	-	-	Emulsified combustion
Fuel	Heavy oil (10 <sup>3</sup> m <sup>3</sup> /yr)	17.4	8.7	17.4	17.4
Consumption	Diescl (10 <sup>3</sup> m <sup>3</sup> /yr)	0.91	9.61	0.91	0.91
Emission (ton/yr)	NOx	63	36	46	36
	SO <sub>2</sub>	1,062	634	300	300
	PM	21.9	17.5	17.5	13.1
Reduction ratio (%)	NOx	-	43	27	43
	SO <sub>2</sub>	-	40	72	72
	PM	-	20	20	40
Equipment cost (1,000US\$)	Furnace retrofit, etc.		1,009.72	1,009.72	1,009.72
	NOx, SO <sub>2</sub> telemeter		307.01	307.01	307.01
Running cost (approx.)(1,000 US\$/yr)					
Facility depreciation (15 yrs)			87.8	87.8	87.8
Interest (first 5 yrs: 8%)			105.3	105.3	105.3
Maintenance cost (5%)			65.8	65.8	65.8
Heavy oil		1,349.4	674.7	-	-
Diesel		187.3	1,977.6	187.3	187.3
Desulfurized heavy oil		-	-	1,893.9	-
Desulfurized heavy oil emulsion		-	-	-	2,308.2
Total (1,000 US\$/yr)		1,536.7	2,911.2	2,311.1	2,754.4

Alternative B: Applicable after the start of supplying desulfurized heavy oil.

Alternative C: Emulsified combustion should be considered adoption after thorough demonstration tests.

Note: (1) Boiler loading rate is assumed to be 50%.

(2) Facility retrofitting cost is for 2 boilers.



5.2.24 Alcoholic Drinks Factory

- 1) Name of facility surveyed Power generation boiler (No. 2)
- 2) Specification of facility
- |                             |  |
|-----------------------------|--|
| Model                       | Water-tube boiler (tangential firing)                        |
| Capacity                    | 63 ton/hr  |
| Draft and ventilation       | Forced draft   |
| Size of boiler              | 4,700 <sup>W</sup> x 4,156 <sup>D</sup> x 8,534 <sup>H</sup> |
| Number and layout of burner | 4 (one each at boiler corners)                               |
| Furnace pressure            | +150 mmAq  |
| Ancillary facility          | Air preheater (30 → 200°C)                                   |

- 3) Specification of burner
- |                    |  |
|--------------------|--|
| Model              | Gas-Oil mixed combustion;<br>Gas: lance type,<br>Heavy oil: Y-jet type |
| Type of fuel       | Heavy oil (only heavy oil is used at present)                          |
| Fuel consumption   | 5,400 l/hr   |
| Fuel pressure      | 5 kg/cm <sup>2</sup> g   |
| Atomizing pressure | 6 kg/cm <sup>2</sup> g (steam)   |

4) Analytical data of flue gas

(Stack sampling data) 15:30/Load is approx. 97% of rating				(Emission)	
NOx (ppm)*	232	Particulate matter (g/Nm <sup>3</sup> )	0.41		kg/h
O <sub>2</sub> (%)	4.3	Flue gas temperature (°C)	178	NOx	31
CO (%)	<0.05	Combustion chamber outlet O <sub>2</sub> (%)	2.5	SO <sub>2</sub> **	310
CO <sub>2</sub> (%)	12.0			Particulate	25

\* Converted to oxygen concentration of 5%.

\*\* Calculated from analytical value of fuel

5) Observation

This is a beer brewery of the largest beer manufacturer in Mexico. Because of its proximity to the center of the metropolitan area, its pollutant emission must be given serious attention; its emissions of both NOx and particulate matter are quite large. In addition to this boiler burning heavy

oil, there are also two natural gas burning boilers (100 ton/hr and 27 ton/hr) in operation for power generation, and one 80 ton/hr boiler under construction; the total fuel consumption of all these boilers is quite large.

All the boilers in this plant are of the tangential firing type, in which one burner each is installed at the four corners of the boiler. This creates a swirling fire ball in the combustion chamber. Thus it is nicknamed the fireball combustion system. Generally, this combustion method gives lower NOx generation than the front-firing method. Inspection is required on leaks within the air preheater. The combustion chamber load is relatively high at 540,000 kcal/m<sup>3</sup>hr. Judging from the low O<sub>2</sub> concentration of 2.5% at the outlet of the combustion chamber, this boiler is operated under the nearly optimum level of air ratio.

#### 6) Countermeasures

##### i) Retrofitting of the boiler

(a) Air preheater repair

(b) Continuous monitoring of the flue gas O<sub>2</sub> for low air ratio combustion

##### ii) Fuel change

Change of heavy oil to natural gas

iii) Continuous monitoring of the flue gas by installing NOx, SO<sub>2</sub>, O<sub>x</sub> telemeters.

#### 7) Expenses for boiler retrofitting

Retrofitting for flue gas recirculation, low air ratio combustion, and for air repair

##### i) Foreign portion

		(US\$)
(a) Survey and design	1 set	15,400
(b) Flue gas recirculation fan	1 set	30,000
(c) Combustion control system and electric instrumentation	1 set	46,200

(d) Local work on-site supervision	1 set	23,100
(e) On-site instruction for test operation	1 set	7,700
(f) Package and freight	1 set	11,900
(g) Travelling	1 set	17,200
(h) Unexpected expenses (5% on above)		7,600
Sub-total		159,100

ii) Local portion

		(US\$)
(i) Dust fabrication (incl. heat insulation)	1 set	115,400
(i) Duct and fan installation	1 set	30,800
(k) Electrical instrumentation work	1 set	11,500
(l) Trial operation on-site attendance	1 set	2,300
(m) Customs and other taxes	1 set	22,500
(n) Warehouse, customs clearance, and land freight (incl. IVA)	1 set	2,360
(o) Duct, etc. freight, crane car rental	1 set	2,000
(p) IVA (15% excl. m + n)		24,300
Sub-total		211,180

Total US\$ 370,280

8) Installation of the NO<sub>x</sub>, SO<sub>2</sub>, O<sub>2</sub> telemeters for constant monitoring of the flue gas

Expenses for telemetric monitoring of NO<sub>x</sub> and O<sub>2</sub> for No. 1, 3, 4 boilers and SO<sub>2</sub>, NO<sub>x</sub> and O<sub>2</sub> for No.2 boiler

i) Foreign portion

		(US\$)
(a) Survey and design	1 set	9,400
(b) NO <sub>x</sub> , SO <sub>2</sub> , O <sub>2</sub> instrumentation	4 sets	162,300
(c) Auxiliary units	1 set	79,000
(d) Data logger	1 set	17,900
(e) Installation work on-site instruction	1 set	8,500
(f) On-site instruction for trial operation	1 set	4,700
(g) Package and freight	1 set	51,800

(h) Travelling	1 set	12,400
(i) Unexpected expenses (5% on above)		17,300
Sub-total		363,300

ii) Local portion

		(US\$)
(j) Materials	1 set	8,400
(k) Survey assistant	1 set	1,800
(l) Installation expenses	1 set	8,200
(m) Trial operation and adjustment	1 set	2,400
(n) Vehicle rental	1 set	3,300
(o) Customs and other taxes	1 set	70,760
(p) Warehouse, customs clearance, and land freight	1 set	5,810
(q) IVA (15% excl. o + p)		3,620
Sub-total		104,290
Total		US\$ 467,590

(Telephone installation work and central reception system are not included.)

9) Summary of control measures

Table 5.2.24 summarizes the control measures for Alcoholic Drinks Factory.

Table 5.2.24 Summary of Control Measures for Alcoholic Drinks Factory

		Present Status	Control measures
Fuel type		Heavy oil	Natural gas
		Natural gas	
Combustion mode		Mixed combustion	
Fuel	Heavy oil (10 <sup>3</sup> m <sup>3</sup> /yr)	40.6	0
Consumption	Natural gas (10 <sup>6</sup> m <sup>3</sup> /yr)	54.0	86.4
Emission (ton/yr)	NOx	408.1	217.2
	SO <sub>2</sub>	2,436	0
	PM	136.1	0
Reduction ratio (%)	NOx		47
	SO <sub>2</sub>		100
	PM		100
Equipment cost (1,000 US\$)	Facility retrofitting		1,110.84 (Note)
	Nox, SO <sub>2</sub> telemeter		467.59
Running cost (approx.)(1,000 US\$/yr)			
	Facility depreciation (15 yrs)		105.2
	Interest (first 5 yrs: 8%)		126.3
	Maintenance cost (5%)		78.9
	Heavy oil	3,148.6	-
	Natural gas	4,499.8	7,200.0
Total (1,000 US\$/yr)		7,648.4	7,510.4

Note: Retrofitting expenss (US\$ 740,560) for the 100-ton/hr boiler (30-year old) and the 27-ton/hr boiler (36-year old) are included.

### 5.2.25 Public Bathhouse

- 1) Name of facility surveyed                      Boiler (No. 1)
  
- 2) Specification of facility
 

Model	Flue and smoke tube type
Capacity	1.56 ton/hr
Draft and ventilation	Natural draft
Size of furnace	610 $\phi$ x 3,000 <sup>L</sup>
Number of burner	One unit (heavy oil burner)
Furnace pressure	-1 ~ -2 mmH <sub>2</sub> O
Ancillary facility	None
  
- 3) Specification of burner
 

Model	Steam atomization burner
Type of fuel	Heavy oil
Fuel consumption	100 l/hr
Fuel pressure	Unknown
Atomizing pressure	5.2 kg/cm <sup>2</sup> g

#### 4) Analytical data of flue gas

(Stack sampling data)                      13:30/Load at 80% of rating

NO <sub>x</sub> (ppm)*	190	Particulate matter (g/Nm <sup>3</sup> )	0.15
O <sub>2</sub> (%)	10.5	Flue gas temperature (°C)	170
CO (%)	0.25	Combustion chamber outlet O <sub>2</sub> (%)	—
CO <sub>2</sub> (%)	6.0		

(Emission)

	kg/hr
NO <sub>x</sub>	0.41
SO <sub>2</sub> **	5.8
Particulate	0.24

NO<sub>x</sub> at rated operation is estimated to be 200 ppm (0.43 kg/hr).

\* Converted to oxygen concentration of 5%

\*\* Calculated from analytical value of fuel

#### 5) Observation

This smoke tube boiler for public bathhouse is operated daily from 6:00 to 20:00. As the steam atomization burner is operated manually, black smoke is generated at the times of ignition and change in combustion load. The combustion chamber load was small and the NO<sub>x</sub> concentration was high despite the high air ratio. This may be due to faulty atomization by the burner. Employment of automatic control is recommended because

reduction of smoke and soot rather than NOx is necessary. It can be done at the time of renewal of boiler in the future since it is very old.

#### 6) Countermeasures

- i) Regular monitoring of the O<sub>2</sub> level with a portable O<sub>2</sub> meter for operation at the appropriate air ratio.
- ii) Fuel change
  - (a) Mixed combustion with heavy oil and 50% diesel or natural gas up to the supply start of desulfurized heavy oil
  - (b) When supply of desulfurized heavy oil is started, it should be used exclusively (100%)
  - (c) Emulsified combustion of desulfurized heavy oil should be taken into consideration after through demonstration tests.

#### 7) Expenses

O<sub>2</sub> meter : US\$ 2,400

(This amount does not include the customs duty, customs clearance expenses, domestic freight, etc.)

#### 8) Reduction ratio

- i) Before supply of desulfurized heavy oil (50% heavy oil and 50% diesel)
  - NOx : 30%
  - SO<sub>2</sub> : 41%
  - PM : 20%
- ii) When desulfurized heavy oil is exclusively used
  - NOx : 10%
  - SO<sub>2</sub> : 73%
  - PM : 20%
- iii) Emulsified combustion of desulfurized heavy oil
  - NOx : 44%
  - SO<sub>2</sub> : 73%
  - PM : 40%

### 5.3 Summary

#### 5.3.1 Outlines of Proposed Measures

Equipment-related control measures proposed based on the diagnostic survey are summarized in Table 5.3.1

Table 5.3.1 Equipment Related Control Measures Proposed

Control Measure	Number of establishments (facilities) applied	
Reduction of combustion chamber loading	3	(8)
Burner nozzle renewal	1	(1)
Low-NOx burners	10	(25)
Exhaust gas recirculation	11	(25)
Tow-stage combustion	2	(5)
Off-stoichiometric combustion	3	(6)
In-furnace denitration combustion	2	(8)
Installation of precalciner	1	(2)
Heat insulation of furnace ceiling	3	(8)
Bag filter	2	(4)
Electrostatic precipitator (EP)	4	(10) *
Air preheater	1	(2)
Combustion control instruments	8	(18)
HC reduction measures	1	
Simple repair by owner	2	
Automatic O <sub>2</sub> analyzer	9	
Portable O <sub>2</sub> analyzer	5	
Others	2	

Note: \* Excludes 8 boilers in 2 power plants.

For fuel change or improvement in the facilities using heavy oil exclusively, the following 3 cases are considered.

Case A: Mixed burning with diesel or natural gas in the 50:50 ratio:

Until the supply start of desulfurized heavy oil

Case B: Use of desulfurized heavy oil:

After the supply start of desulfurized heavy oil and when its emulsification is not feasible.

Case C: Use of desulfurized and emulsified heavy oil:

After the supply start of desulfurized heavy oil and when its emulsification is feasible, except glass plants remaining in Case B



### 5.3.2 Effects and Costs

The pollutant reduction effects by introduction of desulfurized heavy oil and its emulsion are assumed to be as shown in Table 4.4.3.

The estimated pollutant reduction to be achieved through the combined effect of the fuel change and facility improvements at the 25 object establishments are summarized in Table 5.3.2.

Table 5.3.2 Pollutant Reduction Effects in the 25 Establishments

			NOx	SO <sub>2</sub>	PM
Present emission (1,000 ton/yr)			11.1	44.1	7.3
Emission after implementation of proposed measures (1,000 ton/yr)	Fuel improvement case	A	6.6	29.2	2.5* <sub>1</sub>
		B	6.8	14.0	0.7* <sub>1</sub>
		C	5.8	14.9	1.6* <sub>1</sub>
Reduction ratio (%)	Fuel improvement case	A	40	34	66
		B	39	68	90* <sub>2</sub>
		C	48	66	78

Note: \*<sub>1</sub>: Reduction of PM by 3,400 ton/yr by the proposed relocation of one factory is accounted.

\*<sub>2</sub>: EPs are installed in Power Plant (A).

As shown in the Table, the combination of the transient fuel change and facility improvement in Case A is expected to reduce NOx emission by 40%, SO<sub>2</sub> emission by 34%, and PM emission by 66%. In Case B, use of desulfurized heavy oil and installation of EPs in Power Plant (A) will reduce the SO<sub>2</sub> and PM emissions further. But the NOx emission will rather increase above the level of Case A. In Case C, where desulfurized and emulsified heavy oil is used, some more reduction is expected in NOx at 48%.

The expenses for the facility improvements are estimated to be as follows, excluding unestimative expenses such as in-house works, autonomous improvements and factory relocation.

Case A: NOx reduction measures and others

US\$ 86,449,000

Case B: Installation of EPs in Power Plant (A)

US\$ 77,381,000

Case C: Installation of heavy oil emulsifier in Power Plant (A)

US\$ 2,113,000

**CHAPTER 6 AIR POLLUTION CONTROL PLANNING  
FOR OTHER STATIONARY SOURCES**



**CHAPTER 6 AIR POLLUTION CONTROL PLANNING  
FOR OTHER STATIONARY SOURCES**

**6.1 Sources Investigated by the Detailed On-Site Questionnaire**

**6.1.1 Object Establishments and Facilities**

Among the 97 establishments surveyed through the detailed on-site questionnaire, the 72 which remained after the study covered in Chapter 5 are the objects in this section. The breakdown by their types of industry is as shown in Table 6.1.1.

Table 6.1.1 Breakdown of the 72 Establishments by Types of Industry

Type of industry	Number
Food	8
Leather	1
Paper and its products	8
Chemical products	13
Petrochemical products	4
Coal and petroleum products	1
Rubber and plastic products	4
Non-metallic mineral products	6
Basic metals	7
Metal products	3
Transportation equipment	1
Other manufacture	1
Public bath	10
Sports center	1
Hospital	1
Hotel	2
Total	72

Broadly classified, 58 are factories, and 14 are service and commercial establishments. There are 180 furnaces covered by the survey as shown in Table 6.1.2. And there were additionally 16 electric furnaces operated in 6 establishments.

Table 6.1.2 Facilities Investigated by Detailed On-site Questionnaire

Type of Furnace	Capacity				Total
	Large	Medium	Small	Micro	
Industrial boiler	6	19	46	44	115
Dryer	3	0	9	6	18
Metal melting	1	0	1	1	3
Metal heating	0	5	4	0	9
Ceramic	2	3	10	0	15
Glass melting	6	5	0	0	11
Aggregate dryer	0	0	0	2	2
Heating	1	0	2	2	5
Others	0	2	0	0	2
Total	19	34	72	55	180

### 6.1.2 Planning Approach

#### (1) Selection of Survey Objects

In the detailed on-site questionnaire survey, the following features were examined through the simple measurement of the operational status of the combustion facility and the visual inspection of its appearance, with reference made to specifications and operation control records of the facility including fuel consumption, as prepared by the surveyed establishments.

- (a) Is the fuel consumption appropriate to the rated capacity of the facility?
- (b) Is the facility equipped with operation control instruments?
- (c) Is the air ratio proper?
- (d) Is the smoke and soot concentration in the flue gas controlled at an appropriate level?
- (e) Is the generated heat effectively utilized?
- (f) Is there any structural defect harmful to (d) and (e)?

On the basis of the survey results, control measures were studied for 48 establishments, after eliminating 64 furnaces in a total of 24 establishments: 13 establishments that need no measure, 4 under relocation plan, 3 under facility retrofitting or change, 2 in that no measure is possible, and 2 with no reliable data.

(2) Control Measures to be Applied

Control measures are selected from those applied to the sources subjected to the diagnostic survey considering similarity in type of combustion facilities, fuel used, facility size, and operation conditions. As the types of facility not covered by the diagnostic survey program, there are 15 kilns in 4 establishments and 2 gas turbines in 1 plant, and they are all among the eliminated 24 establishments.

Considering that there are many small to medium sized establishments, efforts have been made to select measures that give high pollutant reduction at limited facility investment costs, with emphasis given to the rationalization of operation control.

With respect to fuel change, it is assumed that the current heavy oil is replaced by the desulfurized heavy oil after the start of its supply.

### 6.1.3 Control Measures

(1) Outline of Control Measures

The twelve measures, as shown in Table 6.1.3, are selected as facility improvement measures for the object facilities.

Table 6.1.3 Facility Improvement Measures

Kind of facility improvement measure	Number of establishments applied (number of facilities)	Unit Cost (US\$)
Reduction of combustion chamber loading	3	-
Steam atomizing system	3 (3)	2,200
Burner nozzle renewal	3 (6)	4,700
Fuel preheater	3 (5)	200
NOx measurement device	3	13,600
Combustion control instruments	1 (2)	52,000
In-furnace denitration and flue gas recirculation	1 (2)	66,000
Thermometer for air preheating	1	1,500
HC removal system	1 (paint factory)	63,000
Increase of fuel atomizing air pressure	1	-
Simple repair by owner	4	-
Portable O <sub>2</sub> meter	33	2,400

For fuel change or improvement in the facilities using heavy oil exclusively, the following 3 cases are considered.

A: Mixed burning of heavy oil and diesel or natural gas in the 50:50 ratio:

Until the supply start of desulfurized heavy oil

B: Exclusive burning of desulfurized heavy oil:

After the supply start of desulfurized heavy oil and when its emulsification is not feasible

C: Emulsified combustion of desulfurized heavy oil:

After the supply start of desulfurized heavy oil and when its emulsification is feasible, except glass plants remaining in the case B

The pollutant reduction effects by introduction of desulfurized heavy oil and its emulsion are assumed to be as shown in Table 6.1.4.

Table 6.1.4 Pollutant Reduction Effects of Desulfurized Heavy Oil

	NO <sub>x</sub> (%)	SO <sub>2</sub> (%)	PM (%)
Current heavy oil	0	0	0
Desulfurized heavy oil	10	73	20
Desulfurized & emulsified heavy oil	30	73	40

In addition to the above concrete measures in improvement of facility and fuel, future measures at the time of facility renewal and recommendation for operational control are also taken into consideration. These are summarized in Tables 6.1.5 (1) through (12) for each establishment.



Table 6.1.5 (1) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 1

Name of Establishment Type of Industry (Products)	Visit No.	Facility Name	Facility Rating capacity (ton/hr)	Material	Consumption of Fuel		Pollution Countermeasures	Investment Individual (US\$)	Reduction Ratio (%) (Est. method)
					N-gas (m <sup>3</sup> /hr)	Heavy oil (l/hr)			
Chemical Products Factory (A) (detergent, cooking oil, soap)	1-1	Water tube boiler	15	Steam	1,400		Diagnostic survey conducted. See Sec. 5.2.4.		
	1-2	Water tube boiler	15	Steam	1,190				
	1-3	Water tube boiler	20	Steam	1,725				
	1-4	Water tube boiler	6	Steam	416				
	1-5	Water tube boiler	5	Steam	382				
	1-6	Heat medium boiler	3.5	Oil	122				
	1-7	Heat medium boiler	35	Oil	45				
	1-8	Heat medium boiler	12	Oil	336				
	1-9	Heat medium boiler	5	Oil	45				
	1-10	Heat medium boiler	1.5	Oil	56				
	1-11	Dryer	10	Detergent	350				
	1-12	Dryer	10	Detergent	350				
	1-13	Dryer	60	Detergent	182				
POLAQUIMA, S.A. DE C.V. Chemical (herbicide, insecticide, glycol ester)	2-1	Water tube boiler	3.3	Steam	272		1) Modification of combustion facility 2) Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. It should be done simultaneously with 2), since smoking takes place even at an O <sub>2</sub> concentration of 5.2 %. 3) Since the boiler is outworn and no new low NOx burner can be installed, a steam injection should be employed. 6,800.00 - 30 -		
	2-2	Water tube boiler	4	Steam	227				
	2-3	Heat medium boiler	Small capacity	Oil	47				
PROCTOR & GAMBLE DE MEXICO, S.A. DE C.V. Chemical (detergent, soap)	3-1	Water tube boiler	22.7	Steam		1,125			
BANOS RIO BLANCO Bathroom	4-1	Smoke tube boiler		Steam	Alter-		1) Modification of combustion facility 2) Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 3) Replacement of the burner nozzle for optimum atomization and reduction of Ph. 11,800 - 40 -		
	4-2	Smoke tube boiler		Steam	nate use				
BARINAS Y GRASAS XALOSTOC, S.A. Food (feeds : processed bone, blood and grease of animals)	5-1	Water tube boiler	2.5	Steam		250	1) Modification of combustion facility 2) Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 3) Repair of the boiler front door to prevent heat loss by tertiary air entry. 2) Fuel change 3) Use of heavy oil 50% + diesel 50% mixture. 4) Use of desulfurized heavy oil. 5) Use of emulsified and desulfurized heavy oil. None		
	5-2	Water tube boiler			Spare				
POLIESTERES BAYER, S.A. Petrochemical (polyester, agricultural chemicals)	6-1	Heat medium boiler	700,000 kcal/hr	Oil		40			
	7-1	One-through bit.	1.5	Steam		92	1) Modification of combustion facility 2) Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 2,400 2,400 35 18 0 18 Self-repair 30 41 20 - 10 73 20 - 44 73 40 -		
	7-2	One-through bit.	1.5	Steam		80			
	7-3	One-through bit.	1.0	Steam		40			
7-4	One-through bit.	0.5	Steam		1-2 of 4 operating				
Petrochemical Products Factory (B) (polyester fiber, nylon)	8-1	Water tube boiler	40	Steam	Spare	3,142	Diagnostic survey conducted. See Sec. 5.2.10.		
	8-2	Water tube boiler	40	Steam		3,142			
	8-3	Smoke tube boiler	13	Steam		416			

Table 6.1.5 (2) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 2

Name of Establishment Type of Industry (Products)	Visit No.	Facility		Consumption of Fuel		Pollution Countermeasures	Investment Indi- vidual (US\$)	Reduction Ratio (%) (Estimated)
		Name	Rating capacity (ton/hr)	Material	N-gas (m <sup>3</sup> /hr) (Alternate use)			
BANDOS COSTA-DEL SOL Bathroom	9-1	Smoke tube boiler		Steam		107	2,400	
	9-2	Smoke tube boiler		Steam		107		
BANDOS COACALCO Bathroom	10-1	Water tube boiler		Steam		11	2,400	20
							2,800	30
Asphalt Plant (asphalt mix)	11-1	Rotary kiln	250	Aggregate		1,380		
	11-2	Rotary kiln	250	Aggregate		1,380		
	11-3	Rotary kiln	200	Aggregate		1,000		
	12-1	Smoke tube boiler	2.55	Steam		28.4	2,400	20
VIDRIERA MEXICO, S.A. Non-metallic mineral product (glass bottle)	13-1	Glass melting furnace tank oven	8.6	Glass Cullet 75%	1,282			
	13-2	Glass melting furnace tank oven	8.6	Glass Cullet 75%	1,282			
	13-3	Glass melting furnace tank oven	8.6	Glass Cullet 75%	1,282			
	13-4	Glass melting furnace tank oven	8.6	Glass Cullet 75%	1,282			
	13-5	Glass melting furnace tank oven	8.6	Glass Cullet 75%	1,282	Not operating		
Rubber Products Factory (tire)	14-1	Water tube boiler	10	Steam		500		
	14-2	Water tube boiler	6.4	Steam		Not operating		
	14-3	Hot water boiler	0.1	Hot water		Diesel		
CENTRO DEPORTIVO CHAPULTEPEC, A.C. Public sports center (polyester, nylon)	15-1	Water tube boiler	9.0	Steam	13hr/dry	307	2,400	20
	15-2	Water tube boiler	5.0	Steam	3hr/dry	185		
Petrochemical Products Factory (A) (polyester fiber, nylon)	16-1	Water tube boiler	14	Steam				
	16-2	Water tube boiler	14	Steam				
	16-3	Water tube boiler	28	Steam				
	16-4	Water tube boiler	41	Steam				

Table 6.1.5 (3) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 3

Name of Establishment Type of Industry (Products)	Visit No.	Facility Name	Rating capacity (ton/hr)	Material	Consumption of Fuel		Pollution Countermeasures	Investment		Reduction Ratio (%) (Estimated)	
					N-gas (m <sup>3</sup> /hr)	Diesel oil (L/hr)		Indi- vidual (US\$)	Total (US\$)		
INDUSTRIAS RESISTOL, S.A. (ABS resin, latex, sodium phosphate)	17-1	Water tube boiler	11.8	Steam	200		Factory relocated by the administrative order.				
	17-2	Water tube boiler	12.5	Steam	Not operating						
NOVAQUIN, S.A. (Chemical (oxidation inhibitor, stabilizer))	18-1	Smoke tube boiler	4.7	Steam	Alternate use	168	1) Modification of combustion facility 2) The structure permits no retrofitting. 3) Fuel change 4) Use of heavy oil 50% + diesel 50% mixture. 5) Use of desulfurized heavy oil. 6) Use of emulsified and desulfurized heavy oil. Diagnostic survey conducted. See Sec. 5.2.22.				
	18-2	Smoke tube boiler	4.7	Steam		168					
Metal Products Factory (B) (aluminum sash, racket, tube)	19-1	Melting furnace	20	Aluminum	227		Factory to be relocated.				
	19-2	Melting furnace	1.75	Aluminum	20						
	19-3	Melting furnace	1.75	Aluminum	20						
	19-4	Melting furnace	1.75	Aluminum	20						
	19-5	Melting furnace	1.75	Aluminum	20						
	19-6	Heat treating foe.	36	Aluminum	36						
	19-7	Heat treating foe.	36	Aluminum	36						
	19-8	Heat treating foe.	36	Aluminum	36						
	19-9	Heat treating foe.	36	Aluminum	36						
	19-10	Heat treating foe.	36	Aluminum	36						
FUNDICION CHORNE Basic metals (cast iron)	20-1	Cupola	1.5	Scrap iron		Coke: 500 kg/day					
BANOS TACUBAYA Bathroom	21-1	Smoke tube boiler	1.27	Steam	Alternate use	170	1) Modification of combustion facility 2) Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 3) Fuel change 4) Use of heavy oil 50% + diesel 50% mixture. 5) Use of desulfurized heavy oil. 6) Use of emulsified and desulfurized heavy oil.	2,400	2,400	85	
	21-2	Smoke tube boiler	1.27	Steam		170					18
BANOS NAUCALPAN Bathroom	22-1	Smoke tube boiler	0.6	Steam	Alternate use	80	1) Modification of combustion facility 2) Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 3) Fuel change 4) Use of heavy oil 50% + diesel 50% mixture. 5) Use of desulfurized heavy oil. 6) Use of emulsified and desulfurized heavy oil.				
	22-2	Smoke tube boiler	0.6	Steam		80			2,400	2,400	15
Glass Factory (C) (Glass bottle)	23-1	Glass melting furnace tank oven	16.7	Glass	2,160		Diagnostic survey conducted. See Sec. 5.2.16.				
	23-2	Glass melting furnace tank oven	8.3	Glass	1,500						
	23-3	Glass melting furnace tank oven	8.3	Glass	800						
	23-4	Decorating furnace		Glass							
	23-5	Annealing furnace (17 furnaces)		Glass	2,980						
Chemical Products Factory (D) (NaOH, Cl <sub>2</sub> , NaClO)	24-1	Water tube boiler	7.7	Steam	363		Diagnostic survey conducted. See Sec. 5.2.7.				
	24-2	Water tube boiler	7.7	Steam	363						
	24-3	Smoke tube boiler	3.8	Steam	Spare						
	24-4	Smoke tube boiler	3.8	Steam	Spare						
GENERAL PRODUCTOS CO., S.A. DE C.V. Chemical (Na <sub>2</sub> S <sub>2</sub> O <sub>4</sub> , ZnO, SO <sub>2</sub> Soln.)	25-1	Smoke tube boiler	7.8	Steam	686	13 of 4 operating	None				
	25-2	Smoke tube boiler	7.8	Steam	686						
	25-3	Smoke tube boiler	4.7	Steam	208						
	25-4	Smoke tube boiler	3.1	Steam	208						

Table 6.1.5 (4) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 4

Name of Establishment Type of Industry (Products)	Visit No.	Facility		Consumption of Fuel		Pollution Countermeasures	Investment Individual (US\$)	Reduction Ratio (%) (Estimated)
		Name	Rating capacity (ton/hr)	Material	N-gas (m <sup>3</sup> /hr)			
IDEAL STANDARD, S.A. Non-metallic mineral product (Sanitation porcelain)	26-1	Tunnel kiln	403,200 #	Ceramic	245			
	26-2	Tunnel kiln	403,200 #	Ceramic	245			
	26-3	Tunnel kiln	296,000 #	Ceramic	180			
	26-4	Tunnel kiln	296,000 #	Ceramic	180			
	26-5	Downdraft kiln	453,600 #	Ceramic	500			
	26-6	Infrared burner	30,200-60,600	kcal/hr		800 burners		
FCA DE PAPEL SAN RAFAEL Paper & its product (paper)	27-1	Black liquor boiler	12.5	Steam	Black liquor	3,280		
	27-2	Black liquor boiler	20.5	Steam	Black liquor	4,480		
	27-3	Water tube boiler	34.0	Steam		2,017		
	27-4	Water tube boiler	60.0	Steam		3,600		
	27-5	Water tube boiler	60.0	Steam		3,500		
FCA DE PAPEL MEXICO Paper & its product (recycled paper)	28-1	Water tube boiler	20.8	Steam		1,250		
	28-2	Water tube boiler	20.8	Steam		1,250		
HACO MEXICANA, S.A Chemical(Fe2O3)	29-1	Smoke tube boiler	3.8	Steam		266		
	29-2	Roasting furnace		Pigment				
	29-3	Drying furnace		Pigment				
	29-4	Drying furnace		Pigment				
	29-5	Drying furnace		Pigment				
	29-6	Drying furnace		Pigment				
Paper Factory	30-1	Water tube boiler	16	Steam		750		
	30-2	Water tube boiler	14	Steam		600		
Glass Factory (B) (glass wool, glass fiber)	31-1	Melting furnace	1.3	Glass	535.6			
	31-2	Melting furnace	0.9	Glass	495.2			
	31-3	Melting furnace	0.7	Glass	569.1			
	31-4	Water tube boiler	3.1	Steam	2,300			
	31-5	Water tube boiler	3.1	Steam	2,300	Total alternate use		

Table 6.1.5 (5) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 5

Name of Establishment (Type of Industry (Products))	Visit No.	Facility Name	Flaring capacity (ton/hr)	Material	Consumption of Fuel		Pollution Countermeasures	Investment		Reduction Ratio (%) (Estimated)
					W-gas (m <sup>3</sup> /hr)	Heavy oil (l/hr)		Indi- vidual (US\$)	Total (US\$)	
PASTEURIZADORA LA LAGUNA Food (dairy products, milk, yogurt)	32-1	Smoke tube boiler	2.6	Steam	42	42	1) Modification of combustion facility ① Since PH generation is expected due to defective fuel atomization, the burner nozzle should be renewed. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil. 1) Modification of combustion facility ① When NOx concentration is high, the volumetric furnace load should desirably be reduced. (around 70,000 kcal/m <sup>3</sup> hr. when heat amount is insufficient for the intended process, electric heater free from NOx generation can be used as a supplement.) ② Combustion control to prevent abnormally high NOx concentration using a NOx meter. Diagnostic survey conducted. See Sec. 5.2.19.	4,700x2	0	0
	32-2	Smoke tube boiler	2.6	Steam						
VIDRIO PLANO DE MEXICO, S.A. Non-metallic mineral product (plate glass, glass for automobile)	33-1	Glass melting furnace tank oven	3.3	Glass Cullet 30%	2,050		1) Modification of combustion facility ① When NOx concentration is high, the volumetric furnace load should desirably be reduced. (around 70,000 kcal/m <sup>3</sup> hr. when heat amount is insufficient for the intended process, electric heater free from NOx generation can be used as a supplement.) ② Combustion control to prevent abnormally high NOx concentration using a NOx meter. Diagnostic survey conducted. See Sec. 5.2.19.	3,600	13,600	30
	33-2	Glass melting furnace tank oven	15.8	Glass Cullet 30%	3,618					
Paper Products Factory (A) (Recycled paper)	34-1	Water tube boiler	9.4	Steam	902	Not operating	1) Modification of the crucible furnace ① Repair of the damaged hood to improve the efficiency of recuperator.	Self-repair		
	34-2	Smoke tube boiler	7.8	Steam	283					
	34-3	Smoke tube boiler	7.8	Steam	283					
	34-4	Smoke tube boiler	7.8	Steam	283					
	34-5	Smoke tube boiler	7.8	Steam	283					
METALURGICA ALMENA Basic metals (copper, brass, bronze castings)	35-1	Crucible furnace	600 #	Scrap & ingot	18,300		1) Modification of the combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil. 1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. ② Because the fuel temperature is low, a fuel preheater should be installed. (A ribbon heater with thermometer and thermostat is also usable.) 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil.	2,400	2,400	9
	35-2	Electric furnace	600 #	ingot						
	35-3	Electric furnace	600 #	*:kg/charge						
	35-4	Electric furnace	600 #	Electric						
	35-5	Electric furnace	600 #	Electric						
BANDS LA NARANJA Bathroom	36-1	Smoke tube boiler	0.8	Steam	55		None			
	36-2	Smoke tube boiler	0.8	Steam	55					
	36-3	Hot water boiler		Hot water use						
	36-4	Hot water boiler		Hot water						
	36-5	Hot water boiler		Hot water						
	36-6	Hot water boiler		Hot water						
BANDS XOLALPA Bathroom	37-1	Smoke tube boiler	1.0	Steam	130		1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil.	2,400	2,400	9
	37-2	Smoke tube boiler	0.8	Steam	130					
BANDS GABIS Bathroom	38-1	Smoke tube boiler	0.4	Steam	51		1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. ② Because the fuel temperature is low, a fuel preheater should be installed. (A ribbon heater with thermometer and thermostat is also usable.) 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil.	2,400		
	38-2	Smoke tube boiler	0.6	Steam	51					
MEDIDORES AZTECA, S.A. Basic metals (brass cast.	39-1	Electric furnace	69	Ingot	1.2	kwh/kg	None			

Table 6.1.5 (6) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 6

Name of Establishment (Products)	Visit No.	Facility		Consumption of fuel		Pollution Countermeasures	Investment Individual (US\$)	Reduction Ratio (%) (Estimated)
		Name	Rating capacity (ton/hr)	Material	N-gas (m <sup>3</sup> /hr) (1/hr)			
SALICILATOS DE MEXICO (Precision instruments (medical supplies))	40-1	Water tube boiler	7.6	Steam		311		None; relocation currently planned.
Cement Factory (portland cement)	41-1	Rotary kiln	96	Cement		9,000		Diagnostic survey conducted. See Sec. 5.2.13.
	41-2	Rotary kiln	96	Cement		9,000		
	41-3	Rotary kiln	25	Cement		2,250		
	41-4	drying furnace	180	Cement				
	41-5	drying furnace	180	Cement				
	41-6	drying furnace	45	Cement				
	41-7	Heat medium boiler	1.3	Oil	H.oil			
	41-8	Heat medium boiler	1.3	Oil	H.oil			
	41-9	Hot water boiler	1.3	Hot water	H.oil			
PAPELERA ATLAS Paper & its product (Recycled paper)	42-1	Water tube boiler	9.6	Steam		400		1) Modification of combustion facility ① Since PM generation is expected due to defective fuel atomization, the burner nozzle should be renewed. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil.
	42-2	Smoke tube boiler	6.4	Steam		270		
	42-3	Smoke tube boiler	2.4	Steam	Spare		4,700x2	
BANOS LUPITA Bathroom	43-1	Smoke tube boiler	0.6	Steam	Alternate use	83		1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O2 meter. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil.
	43-2	Smoke tube boiler	0.5	Steam	Alternate use	83	2,400	
PORCELANITE, S.A. Non-metallic mineral product (tile for building)	44-1	Tunnel kiln	108,000 #	Ceramic		100		None
	44-2	Tunnel kiln	108,000 #	Ceramic		100		
	44-3	Tunnel kiln	108,000 #	Ceramic		100		
	44-4	Tunnel kiln # # : hearth, roller type	875,000 #	Ceramic		145.7		
PRODUCTOS SAN CRISTOBAL Paper & its product (tissues, toilet etc.)	45-1	Water tube boiler	18	Steam	Not operating			1) Modification of the water tube boilers ① Regular combustion control to secure operation at optimum air ratio. ② Installed of a preheated air thermometer for enforced combustion control.
	45-2	Water tube boiler	35	Steam	1,681			
	45-3	Water tube boiler	45	Steam	2,162			
	45-4	Dryer		Paper	383			
	45-5	Dryer		Paper	250			
	45-6	Dryer		Paper	242			
	45-7	Dryer		Paper	467		1,500	
	45-8	Dryer		Paper	854		1,500	
CIA. RULERA TORNEL Rubber & plastic product (tyre, tube)	46-1	Smoke tube boiler	2.6	Steam		180		1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O2 meter. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil.
	46-2	Smoke tube boiler	1.6	Steam		112		
	46-3	Smoke tube boiler	1.3	Steam		Diesel		
	46-4	Smoke tube boiler	0.8	Steam		Diesel		
	46-5	Heat medium boiler	5.04	Oil	Not oper			
Alcoholic Drinks Factory (beer)	47-1	Water tube boiler	100	Steam	Mixed combust.	3,333		Diagnostic survey conducted. See Sec. 5.2.24.
	47-2	Water tube boiler	63	Steam	6,250			
	47-3	Water tube boiler	27	Steam	2 of 3 operating			
	47-4	Water tube boiler	82	Steam	Not operating			
BANOS TACIBA Bathroom	48-1	Smoke tube boiler	0.6	Steam	Alternate use	43		1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O2 meter. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Use of emulsified and desulfurized heavy oil.
	48-2	Smoke tube boiler	0.3	Steam	Alternate use	27	2,400	

Table 6.1.5 (7) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 7

Name of Establishment (Type of Industry)	Visit No.	Facility Name	Rating capacity (ton/hr)	Material	Consumption of Fuel			Pollution Countermeasures	Investment Individual (US\$)	Reduction Ratio (%) (Estimated)	
					H-gas (m <sup>3</sup> /hr)	Diesel (l/hr)	Heavy oil (l/hr)				
CARTONAJES ESTRELLA Paper & its product (carton)	49-1	Water tube boiler	35	Steam	Not operating			None			
	49-2	Water tube boiler	60	Steam	Not operating						
	49-3	Water tube boiler	112	Steam	8,500						
	50-1	Heating furnace	10	Bitliet	539			1) Modification of combustion facility ① The factory has a furnace retrofitting plan for energy saving. (When a recuperator is adopted.)		0	0
	50-2	Heating furnace	6	Bitliet			400 H-oil	1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O2 meter. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. ③ Diagnostic survey conducted. See Sec. 5.2.25.	2,400	2,400	55
ACEROS AHUERBUETES Basic metals (steel bar)	51-1	Heating furnace		Steam							
	51-2	Smoke tube boiler		Steam							
Public Bathhouse	52-1	Smoke tube boiler	1.3	Steam	Alternate use	71					
	52-2	Smoke tube boiler	1.3	Steam		71					
	53-1	Heating furnace	12	Bitliet	610						
ACEROS CORSA Basic metals (steel for sash)	53-2	Electric furnace	30	Scrap							
	54-1	Smoke tube boiler	4.6	Steam	360	Alternate use					
DU PONT Chemical (Freon 11, 12, 22)	54-2	Smoke tube boiler	4.6	Steam	360						
	55-1	Heating furnace	10	Bitliet	634						
	55-2	Heating furnace	8	Bitliet	634						
Metal Products Factory (A)	55-3	Electric furnace	25 #	Scrap	Elec. 7,500 kWh/charge						
	56-1	Heating furnace	6	Scrap		360					
FUNDICIONES FIERRO-MEX Basic metals (bar steel, angle steel)	56-2	Heating furnace	4.5	Scrap		320					
	57-1	Water tube boiler	56	Steam	1,880-2,700	353-450		1) Modification of combustion facility ① Adoption of a recuperator desirable at the time of the furnace renewal. 2) Fuel change ① Use of heavy oil 50% + diesel 50% mixture. ② Use of desulfurized heavy oil. Diagnostic survey conducted.		30	41
Petroleum Refinery	57-2	5 units Water tube boiler	120	Steam	6,000	783		All refining operations were closed on March 18, 1991 by the Executive Order. See Sec. 5.2.3.		30	41
	57-3	Package boiler	55	Steam	2,080	273				30	41
	57-4	CO boiler	124	Steam	4,530	1,055				30	41
	57-5	Heating furnace	117	Petroleum	4,270					30	41
	57-6	Heating furnace	59	Petroleum	2,140					30	41
	57-7	Heating furnace	45	Petroleum	1,600					30	41
	57-8	Heating furnace	4.3	Petroleum	140					30	41
	57-9	Heating furnace	12	Petroleum	400					30	41
	57-10	Heating furnace	14	Petroleum	470					30	41
	57-11	Heating furnace	49	Petroleum	810					30	41
	57-12	Heating furnace	29	Petroleum	270					30	41
	57-13	Heating furnace	31	Petroleum	810					30	41
	57-14	Heating furnace	19	Petroleum	780					30	41
	57-15	Heating furnace	50	Petroleum	4,050					30	41
	ANDERSON CLAYTON, S.A. Food (dressing, etc.)	58-1	Water tube boiler	0.9	Steam	Alter- mate use	27		1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O2 meter.		2,400
58-2		Water tube boiler	0.4	Steam	L.P.G	7	l/hr			2,400	2,400
58-3		Drying oven	400	kg/hr	L.P.G	8	l/hr			2,400	2,400
58-4		Drying oven	450	kg/hr	L.P.G	8	l/hr			2,400	2,400

Table 6.1.5 (8) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 8

Name of Establishment (Products)	Visit No.	Facility		Material	Consumption of fuel			Pollution Countermeasures	Investment Total (US\$)	Reduction Ratio (%) (Estimated)	
		Name	Rating capacity (ton/hr)		N-gas (m <sup>3</sup> /hr)	Diesel (l/hr)	Heavy oil (l/hr)				
FUNDICIONES DE HIERRO Y ACERO Metal product (wheel truck for railroad)	59-1	Electric furnace	15 *	Scrap	Elec. 859 kWh/charge			None			
	59-2	Electric furnace	4 *	Scrap	Elec. 800 kWh/charge						
	59-3	Electric furnace	4 *	Scrap	Elec. 300 kWh/charge						
	59-4	Annealing furnace	* ton/charge	Casting	420						
	59-5	Heating furnace	4.4	of iron	Not operating						
	59-6	Oferta			Not operating						
	60-1	Electric furnace	2.5 *	Scrap	Elec. 500 kWh/charge				1) Modification the annealing furnaces 2) Repair of the furnace door to reduce energy loss by tertiary air entry.  The quantitative evaluation of the fuel saving effect by prevention of tertiary air entry is difficult. Assuming a combustion efficiency of 50%, the reduction of oxygen concentration from 8.5% to 2.1% will result in 11% saving.		
	60-2	Electric furnace	6.0 *	Scrap	Elec. 500 kWh/charge						
	60-3	Electric furnace	3.5 *	Scrap	Elec. 500 kWh/charge						
60-4	Electric furnace	6.0 *	Scrap	Elec. 500 kWh/charge							
60-5	Electric furnace	2.5 *	Scrap	Elec. 500 kWh/charge							
60-6	Electric furnace	6.5 *	Scrap	Elec. 500 kWh/charge							
60-7	Annealing furnace	40 *	Casting	459.7							
60-8	Annealing furnace	20 *	of iron	554.5							
60-9	Annealing furnace	4 *	Casting	173.5							
FOND MOTOR COMPANY Transportation equipment (vehicle engine, car body assembly)	61-1	Drying furnace	0.8-3.2	Hot	50-60			1) Reduction of hydrocarbon 2) Hydrocarbon vapor generated from the painting process, should be ducted for direct burning treatment. (The volume is assumed to be 5,000m <sup>3</sup> /hr) A burner, temperature controller and a blower should be installed. (Since prices for incinerator and duct vary widely depending on the installation site, they are excluded from the estimate.) Other combustion facilities are satisfactorily controlled, and no special measure is needed. Diagnostic survey conducted. See Sec. 5.2.5.			
	61-2	Hot water boiler	1-3.5	Hot water	16-88						
	61-3	Air heater	8	Air	80						
	61-4	Electric furnace		Scrap	Elec. 500 kWh/charge						
	61-5	Annealing furnace		Casting							
Chemical Products Factory (8) (agricultural chemicals, etc.)	62-1	Smoke tube boiler	2-6	Steam			84				
	62-2	Heating furnace	100,000kcal/hr	Oil			10				
INDUSTRIAS UNIDAS, S.A. Insulator (ceramics) Non-metallic mineral product (ceramics, wire- less telephone, electric parts)	63-1	Electric furnace	0.25	Brass				Since no data were available from the factory, no detail is known.			
	63-2	Electric furnace	0.25	Brass							
	63-3	Hardening kiln	0.50	Brass							
	63-4	Tunnel kiln	0.33	Ceramic	N-gas 132						
	63-5	Tunnel kiln	0.33	Ceramic	132						
	63-6	Tunnel kiln	0.17	Ceramic	70						
SM DE MEXICO, S.A. Others (sponge, brush)	64-1	Smoke tube boiler	12	Steam			330				
	64-2	Smoke tube boiler	9	Steam			Spare				
Food Products Factory (Cooking oil, pasta, shortening)	65-1	Water tube boiler	45.4	Steam				1) Modification of combustion facility 2) Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 3) Fuel change 4) Use of heavy oil 50% + diesel 50% mixture. 5) Use of desulfurized heavy oil. Diagnostic survey conducted. See Sec. 5.2.23.			
	65-2	Water tube boiler	45.4	Steam							
	65-3	Heat medium boiler	504,000 #	Oil							
	65-4	Heat medium boiler	504,000 #	Oil							
ESMALTES Y COLORANTES, S.A. Non-metallic mineral product (Glaze for tile, pigment)	66-1	Melting furnace	0.42	Glass	139			Note: relocation currently planned.			
	66-2	Melting furnace	0.42	Glass	139						
	66-3	Drying furnace		Pigment							
	66-4	Spray type dryer		Butane	25kl/mbn total						
	66-5	Baking furnace	200kg/charge		Under testing						



Table 6.1.5 (9) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 9

Name of Establishment Type of Industry (Products)	Visit No.	Facility		Consumption of fuel		Pollution Countermeasures	Investment Individual (US\$)	Reduction Ratio (%) (Estimated) (by 50% PFUE)
		Name	Rating capacity (ton/hr)	Material	N-gas (m <sup>3</sup> /hr)			
Chemical Products Factory (E) (plant oil, soap) Glass Factory (A) (glass bottle, crystal glass, amber glass)	87-1	Water tube boiler	3.8	Steam		208		
	87-2	Water tube boiler	2.6	Steam		Spare		
	87-3	Heat medium boiler		Oil		175		
	88-1	Glass melting furnace tank oven	12	Glass Cullet 55%		1,350		
Thermoelectric Power Plant (A)	88-2	Glass melting furnace tank oven	12	Glass Cullet 55%		1,350		
	88-3	Glass melting furnace tank oven			Under repair	H-oil		
	88-4	Glass annealing furnace			L.P.G.	625 l/hr		
	89-1	Water tube boiler No.1	476	Steam	1,717	1,950		
Thermoelectric Power Plant (B)	89-2	Water tube boiler No.2	503.5	Steam	1,998	2,450		
	89-3	Water tube boiler No.3	503.5	Steam	1,959	2,000		
	89-4	Water tube boiler No.4	900	Steam	5,600	3,125		
	70-1	Water tube boiler	150	Steam		10,246		
FUNDICION DE FIERRO Y METALES Basic metals (cast iron)	70-2	Water tube boiler	150	Steam	2,278	26,400		
	70-3	Water tube boiler	350	Steam	23,480			
	70-4	Water tube boiler	350	Steam				
	71-1	Cupola	800 #	Scrap	Coke	1,285 kg/day		
Chemical Products Factory (C) (paint) ORGANIZACION QUIMICA MEXICANA Food (food additives, zinc chloride)	72-1	Smoke tube boiler	2.35	Steam	110	Alternate use		
	72-2	Smoke tube boiler	1.58	Steam	100			
	73-1	Smoke tube boiler	1.3	Steam		18.0		
	73-2	Smoke tube boiler	1.6	Steam		19.4		
PRODUCTOS NUTRICIONALES Food (food additives)	74-1	Smoke tube boiler	0.63	Steam		28		
	74-2	Smoke tube boiler	0.63	Steam		28		
POLIMEROS (POLIESPUMAS DE MEXICO) Petrochemical (styrol polymer container, build- ing material)	75-1	Smoke tube boiler	7.6	Steam		350		
	75-2	Smoke tube boiler	5.1	Steam		100		
Paper Products Factory (B)	76-1	Water tube boiler	9.5	Steam		440		
	76-2	Water tube boiler	8.2	Steam		440		

Table 6.1.5 (10) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 10

Name of Establishment Type of Industry (Products)	Visit No.	Facility		Consumption of fuel		Pollution Countermeasures	Investment		Reduction Ratio (%) (Estimated)	
		Name	Rating capacity (ton/hr)	Material	N-gas (kg/hr)		Diesel oil (l/hr)	Individual (US\$)		Total (US\$)
SILICATOS Y DERIVADOS, S.A. Chemical (Sodium silicate, potassium silicate, etc.)	77-1	Glass melting furnace tank oven	8.33	Glass	988	Not operating	1) Modification of the glass melting furnace ① When NOx concentration is high, the volumetric furnace load should desirably be reduced. (around 70,000 kcal/m <sup>3</sup> hr. when heat amount is insufficient for the intended process, electric heater free from NOx generation can be used as a supplement.) ② Combustion control to prevent abnormally high NOx concentration using a NOx meter.	13,600	30	0
	77-2	Glass melting furnace tank oven	3.33	Glass	Not operating					
	77-3	Glass melting furnace tank oven	0.17	Glass	Not operating					
	77-4	Smoke tube boiler	7.60	Steam	Total #250					
	77-5	Smoke tube boiler	5.10	Steam	#417					
	77-6	Smoke tube boiler	3.80	Steam	# Heavy oil use in summer					
CANADEROS PRODUCTORES DE LECHE PURA Food (dairy products)	78-1	Smoke tube boiler	4.7	Steam	109	Not operating	1) Modification of combustion facility ① Periodical combustion control for operation at the appropriate air ratio with a portable O <sub>2</sub> meter. 2) Fuel change ③ Use of heavy oil 50% + diesel 50% mixture. ④ Use of desulfurized heavy oil. ⑤ Use of emulsified and desulfurized heavy oil.	2,400	25	4
	78-2	Smoke tube boiler	4.7	Steam	109					
	78-3	Smoke tube boiler	4.7	Steam						
HOSPITAL 20 DE NOVIEMBRE ISSSTE Hospital	79-1	Smoke tube boiler	12.8	Steam	145					
	79-2	Smoke tube boiler	12.8	Steam	145					
	79-3	Incinerator	0.2-0.25	Steam	Diesel					
	79-4	Incinerator	< 0.1	Steam	Diesel					
HOTEL DEL ANGEL Hotel	80-1	Smoke tube boiler	0.47	Steam	Alternate use					
	80-2	Smoke tube boiler	0.47	Steam	17					
MARIA ISABEL SHERATON Hotel	81-1	Smoke tube boiler	6.3	Steam	Alternate use					
	81-2	Smoke tube boiler	6.3	Steam	171					
	81-3	Smoke tube boiler	6.3	Steam	171					
SOSA TEXOCO, S.A. Chemical (Na2O3S, NaCl)	82-1	Water tube boiler	20	Steam						
	82-2	Water tube boiler	20	Steam						
	82-3	Water tube boiler	20	Steam						
	82-4	Water tube boiler	36	Steam						
	82-5	Water tube boiler	50	Steam	Total 13,688					
	82-6	Water tube boiler	50	Steam						
	82-7	Water tube boiler	30	Steam						
	82-8	Water tube boiler	60	Steam						
	82-9	Water tube boiler	50	Steam						
	82-10	Roasting furnace	9.2	Lime stone	Coke 1,250kg/hr					
	82-11	Roasting furnace (8 furnaces)	4.2	Lime stone	500					
	82-12	Drying furnace (2 furnaces)		Algae	63					
AMERICAN TEXTIL, S.A. DE C.V. Petrochemical (Synthetic fiber)	83-1	Heat medium boiler	6,000	Oil	Not operating					
	83-2	Heat medium boiler	1,000	Oil	Not operating					
	83-3	Heat medium boiler	1,000	Oil	Not operating					
83-4	Smoke tube boiler	6	Steam	Alternate use						
	83-5	Smoke tube boiler	5	Steam	153					
	83-6	Iron			L.P.G small amount					

Table 6.1.5 (11) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 11

Name of Establishment Type of Industry (Products)	Visit No.	Name	Facility		Consumption of Fuel			Investment Individual (US\$)	Reduction Ratio (%) (Estimated)
			Rating capacity (ton/hr)	Material	N-gas (m <sup>3</sup> /hr)	Diesel oil (L/hr)	Heavy oil (L/hr)		
MANUFACTURAS GARGO, S.A. DE C.V. Paper & its product (carton)	84-1	Water tube boiler	13.6	Steam	Propane : 741/hr	825			
	84-2	Gas burner	625,000 # \$:kcal/hr	Paper					80 0 10 -
INDUSTRIAL PAVIMENTADORA, S.A. Coal and petroleum prod- uct (asphalt mix)	85-1	Rotary kiln	55	Aggregate		135			
	85-2	Rotary kiln	75	Aggregate		135			
	85-3	Heat medium boiler	504,000 # \$:kcal/hr	Oil		38.6			30 41 20 -
	85-4	Heat medium boiler	630,000 # \$:kcal/hr	Oil		38.6			10 73 20 -
HOLE INDUSTRIAL, S.A. Rubber & plastic product (rubber packing)	86-1	Smoke tube boiler	0.77	Steam		62			44 73 40 -
	86-2	Smoke tube boiler	0.77	Steam		62			
Petrochemical Products Factory (C) (phenol)	87-1	Smoke tube boiler	1.92	Steam	Not operating	53		2,400	2,400 35 1.8 1.0 8
	87-2	Smoke tube boiler	1.92	Steam		53			
AGA DE MEXICO, S.A. DE C.V. Chemical (O <sub>2</sub> , N <sub>2</sub> , Ar, N <sub>2</sub> O, welding rod)	88-1	Gas turbine	4,250 Hp		800				
	88-2	Gas turbine	4,250 Hp		800				
	88-3	Drying furnace	2.5ton/5.5hr						
	88-4	Drying furnace	2.5ton/5.5hr						
	88-5	Drying furnace	2.5ton/5.5hr						
	88-6	Drying furnace	10ton/5.5hr						
TAMM Y CIA, S.A. DE C.V. Petrochemical (acrylic, cotton)	88-7	Annealing furnace	0.85ton/3hr		Alternate use	78			
	89-2	Smoke tube boiler	4.5 3.2 Steam			78		2,400	2,400
CIA. HULLRA ATLAS, S.A. Rubber & plastic product (rubber for automobile)	89-1	Smoke tube boiler	1.28	Steam		64			
	89-2	Smoke tube boiler	3.2	Steam					
CORRUGADO Y FIBRA, S.A. Paper & its product (carton)	90-1	Smoke tube boiler	1.02	Steam					
	91-1	Smoke tube boiler	3.2	Steam		39.7			
SALES INDUSTRIALES DE MEXICO Chemical (ammonium chloride, zinc chloride, etc.)	92-1	Smoke tube boiler	1.02	Steam		48.7			

Table 6.1.5 (12) Control Measures for Sources Investigated by Detailed On-site Questionnaire - No. 12

Name of Establishment Type of Industry (Products)	Visit No.	Facility		Consumption of Fuel			Investment Facility Total (US\$)	Reduction Ratio (%) (Estimated)
		Name	Raising capacity (ton/hr)	Material	N-gas (kg/hr)	Diesel oil (l/hr)		
TENERIA TENOLA, S.A. DE C.V. Leather (leather for shoes)	83-1	Smoke tube boiler	3.2	Steam	16hr/dky	122	2,400	
	83-2	Smoke tube boiler	0.8	Steam	3hr/dky	48		
	83-3	Smoke tube boiler	0.8	Steam	Share	48		
SABRITAS, S.A. DE C.V. Food (potato chips, snacks)	84-1	Frying oven	0.47	Food	60		2,200	20
	84-2	Frying oven	0.47	Food	60			
	84-3	Smoke tube boiler	2.6	Steam	195-227			
	84-4	Smoke tube boiler	1.3	Steam	120			
	84-5	Smoke tube boiler	1.3	Steam	120			
	84-6	Oven		Food	N. GAS			
LA HACIENDA, S.A. DE C.V. Feed (livestock feed)	85-1	Smoke tube boiler	1.9	Steam		70	2,400	20
ENPAQUES Y CARTON CORRUGADO, S.A. Paper & its product (carton)	86-1	Water tube boiler	6.4	Steam		550	2,400	4
	86-2	Water tube boiler	3.8	Steam		H.oil		
DOW QUIMICA MEXICANA, S.A. Chemical (insecticide)	87-1	Smoke tube boiler	3.8	Steam				
	87-2	Smoke tube boiler	1.3	Steam		329 Not operating		

(2) Effects and Expenses

The estimated pollutant reduction to be achieved through the combined effect of the fuel change and facility improvements at the object establishments are summarized in Table 6.1.6.

Table 6.1.6 Pollutant Reduction Effects of the Control Measures for the 48 Establishments

			NOx	SO <sub>2</sub>	PM
Present emission (1,000 ton/yr)			4.7	11.2	2.6
Emission after implementation of proposed measures (1,000 ton/yr)	Fuel improvement case	A	3.5	6.5	2.4
		B	3.7	3.2	2.4
		C	3.6	3.2	2.4
Reduction ratio (%)	Fuel improvement case	A	25	42	7
		B	21	71	7
		C	23	71	7

As can be seen, the combination of the transient fuel change (mixed burning with 50% current heavy oil and 50% diesel or natural gas) and facility improvement in the case A is expected to reduce NOx emission by 25%, SO<sub>2</sub> emission by 42%, and PM emission by 7%. When desulfurized heavy oil is exclusively used, although the SO<sub>2</sub> emission will decrease by 71%, NOx will rather increase above the level of the case A, while PM will remain unchanged. When desulfurized and emulsified heavy oil is used, some more reduction is expected in NOx at 23%.

The expenses for these measures are estimated at approximately \$460,000 (March 1991 price), excluding those unspecifiable portions of facility improvements resulting from in-house work, autonomous improvement and relocation plan.

## 6.2 Other Pollution Sources

### 6.2.1 Object Establishments and Facilities

The establishments for which control measures have been studied so far are mostly large ones covered by the detailed on-site questionnaire and the diagnostic survey. In this section, the establishments not included in the above surveys will be considered. They consist of some 7,000 establishments, broken down as shown below, accounting for 25% each of the total consumption of heavy oil and natural gas at stationary emission sources in AMCM.

- 1) Establishments surveyed by SEDUE as a part of the present Study; 969 firms, 3,336 furnaces,
- 2) Establishments included in the SEDUE's existing data base; 371 firms excluding those covered by 1)
- 3) Establishments covered by the DDF's past survey; 6,070 firms, excluding those covered by the detailed on-site questionnaire and 4)
- 4) Bathhouses surveyed by the National Bathhouse Association; 203 bathhouses

Among these, 1) and 2) are mostly factories, and 3) and 4) are service and commercial establishments. Two thirds (2/3) of the combustion facilities for the group 1) are industrial furnaces and 1/3 are boilers. Assuming the same ratio for the group 2), the total number of industrial furnaces is 2,400. Assuming that all of the facilities in the groups 3) and 4) are boilers, the total number of boilers is over 7,500.

### 6.2.2 Planning Approach

The establishments covered in this Section are large in number but their size and the fuel consumption are relatively small. For this reason, the combustion facility improvement measures are not expected to bring about marked pollutant reduction effect, despite considerable amount of work required.

Therefore, facility improvement measures are to be applied to relatively

large establishments only, and the measures having wide applicability are selected from those measures proposed to the establishments covered by the detailed on-site questionnaire. Therefore, the overall effect of the pollutant emission reduction is largely dependent on the supply of desulfurized heavy oil.

There are 10 relatively large establishments (all covered by the SEDUE's surveys) that are next to the top 20 in the pollutant emission (Figure 3.5.5) subjected to the on-site or the diagnostic survey.

The measure most widely proposed for the on-site surveyed establishments is the introduction of a portable oxygen meter, being proposed to 33 firms among the 48 for which control measures were proposed. The real purpose of this measure is to control the generation of NO<sub>x</sub> by maintaining appropriate air ratio in combustion. For similar purposes, introduction of other simple equipment and simple facility improvement measures are also taken into consideration.

### 6.2.3 Control Measures

#### (1) Outline of Control Measures

The simple facility improvement measures for operation control effective in reducing pollutant emission are listed in Table 6.2.1.

Table 6.2.1 Simple Facility Improvement Measures

Measures to be applied	Unit Price (US\$)
Steam atomizing system	2,200
Fuel preheater	200
Thermometer for air preheating	1,500
Portable O <sub>2</sub> meter	2,400
Simple repair by owner	-

Fuel change is limited to the heavy oil burning facilities as in the case of large factories. But since majority of the firms are of small size, no transitory stage is considered, and the following two cases

B: Exclusive use of desulfurized heavy oil:

After the supply start of desulfurized heavy oil and when its emulsification is not feasible.

C: Emulsified combustion of desulfurized heavy oil:

After the supply start of desulfurized heavy oil and when its emulsification is feasible.

(2) Effects and Expenses

Since the pollutant reduction effects by simple facility improvement measures are not quantifiable unless the actual situation is known, overall effects of fuel change only are shown in Table 6.2.2

Table 6.2.2 Pollutant Reduction Effects by Fuel Change in 7,600 Establishments

			NOx	SO <sub>2</sub>	PM
Present emission (1,000 ton/yr)			5.0	21.0	1.4
Emission after fuel change (1,000 ton/yr)	Fuel change	B	4.8	7.7	1.2
	case	C	4.1	7.7	1.0
Reduction ratio (%)	Fuel change	B	4	63	14
	case	C	18	63	28

The pollutant reduction effects by changing to desulfurized heavy oil in the heavy oil burning facilities are 4% for NOx, 63% for SO<sub>2</sub>, and 14% for PM. When emulsified combustion is adopted in addition, more reduction is expected: 18% for NOx and 28% for PM.

Among expenses required to bring about the above effects, the total expenses for facility improvement measures can be estimated to be within US\$ 25,000, assuming that one of the measures shown in Table 6.2.1 is applied to the 10 firms.





**CHAPTER 7 PLAN FOR CONTROL OF STATIONARY AIR POLLUTION  
SOURCES IN THE METROPOLITAN AREA**



## CHAPTER 7 PLAN FOR CONTROL OF STATIONARY AIR POLLUTION SOURCES IN THE METROPOLITAN AREA

### 7.1 Outline of the Plan

#### 7.1.1 Object Sources for air Pollution Control

According to "Integrated Program Against Atmospheric Pollution in the Mexico City Metropolitan Zone - A Common Agreement, October 1990", the stationary air pollution sources in the metropolitan area account for nearly 3/4 of the total emission of SO<sub>2</sub>, and 1/4 of that of NO<sub>x</sub> as shown in Figure 7.1.1.




Figure 7.1.1 Shares of Stationary Sources in Emission of NO<sub>x</sub> and SO<sub>2</sub>

These pollutants are emitted mainly through fuel combustion. Fuel consumption and the pollutant emission from stationary combustion facilities obtained through this Study's investigation and the SEDUE's past investigation are summarized in Table 7.1.1

Table 7.1.1 Fuel consumption and Pollutant Emission in Stationary Air Pollution Sources (1990)

Fuel Consumption	Heavy oil	(10 <sup>3</sup> m <sup>3</sup> /yr)	1,100
	Natural gas	(10 <sup>6</sup> /m <sup>3</sup> /yr)	3,300
Pollutant Emission	NO <sub>x</sub>	(10 <sup>3</sup> ton/yr)	21
	SO <sub>2</sub>	(10 <sup>3</sup> ton/yr)	76
	PM	(10 <sup>3</sup> ton/yr)	11

A total of about 8,000 establishments are covered by the present Study including 1,400 factories, nearly all the factories having air pollutant emitting facilities in the metropolitan area, and about 70% of the service and commercial establishments in the area having such facilities.

With the large scale establishments preferentially included in the investigation, these 8,000 establishments are considered to represent sufficiently the overall situation of stationary pollution sources in the metropolitan area.

Table 7.1.2 shows the annual emission of NO<sub>x</sub> and SO<sub>2</sub> from the top ranked 10 establishments covered by the present Study. They are all factories, and the emissions from the top 5 are particularly large.

Table 7.1.2 Large Individual Emission Sources of NO<sub>x</sub> and SO<sub>2</sub>

NO <sub>x</sub> Emission			SO <sub>2</sub> Emission		
Rank	Source	Nox (ton/yr)	Rank	Sources	SO <sub>2</sub> (ton/yr)
1	Power plant (A)	5,219	1	Power plant (A)	17,460
2	Cement	1,365	2	Cement	12,383
3	Glass sheet	1,154	3	Paper	5,830
4	Power Plant (B)	1,044	4	Power Plant (B)	3,409
5	Glass bottle	1,043	5	Petrochemical (B)	1,803
6	Glass (C)	809	6	Alcoholic drinks	1,747
7	Petroleum refinery	742	7	Petroleum refinery	1,432
8	Paper	533	8	Paper	1,310
9	Glass (B)	471	9	Glass (A)	1,274
10	Chemical	346	10	Petrochemical (A)	1,092

## 7.1.2 Fuel Improvement Measures

### (1) On-going Oil Desulfurization Project

PEMEX has a plan of constructing a hydro-desulfurization plant for heavy oil in the Tula refinery near the metropolitan area. When this project is implemented, a low sulfur heavy oil (S: 0.8%) will be supplied in AMCM and supply of the current heavy oil (S: 3.0 - 3.5%) will be ceased.

This project is one of the themes that were presented in the "Integrated Program Against Atmospheric Pollution in the Mexico City Metropolitan

Zone - A Common Agreement" published in October 1990, and is underway with the common agreement among the authorities concerned including the energy, finance and environmental sectors of the Government. Produced desulfurized heavy oil (DHO) is expected to be used as an effective means of stationary pollution source control, by making available to all consumers including small-to-medium-sized establishments under the present system of fuel supply in Mexico which is unitarily carried out by PEMEX.

When the fuel demand at the time of the operation start of the projected desulfurization plant is assumed to be unchanged from 1990 and the composition of fuel kinds is also assumed to remain unchanged, and the currently used heavy oil is totally replaced by desulfurized heavy oil (DHO), the amount of pollutant emission is estimated to be as shown in Table 7.1.3.

Table 7.1.3 Pollutant Emission Reduction by Changing Current Heavy Oil to Desulfurized Heavy Oil

Pollutant	Emission from stationary sources (1,000 ton/yr)		Reduction ratio (%)	
	Present	Future	Stationary sources	All Sources
NOx	20.8	20.1	5	1
SO <sub>2</sub>	76.3	23.2	70	55
PM	11.3	10.3	9	-

The above reduction ratios are based on the assumption that the improvement in the quality of heavy oil will reduce SO<sub>2</sub> emission by 73%, NOx emission by 10%, and PM emission by 20% per unit amount of heat. The total SO<sub>2</sub> emission is expected to decrease to a half.

## (2) Fuel Change

The replacement of heavy oil with DHO is postulated as the mainstay in this Study in the medium to long-term fuel improvement measures, while the pollution reduction effect, fuel cost and the PEMEX's policy of natural gas usage are taken into consideration. And the change to diesel or natural gas is limited to special cases. However, since the use of DHO is directed to the reduction of SO<sub>2</sub>, and not sufficient in reducing NOx and PM, additional measures are required. As a measure to reduce NOx and SO<sub>2</sub> emissions through fuel improvement, the emulsification of heavy oil is considered.

However, since the effect of this measure is basically dependent on the quality of the oil used and method of combustion, and there are not many examples of practical application in Japan, the result of the principle test conducted in the present Study should be further verified by the commercial scale test in order to assure the effectiveness when applied to Mexican heavy oil.

Since the supply of DHO will start in 1995 according to the current schedule, partial replacement of the current heavy oil by diesel or natural gas is proposed as an interim measure. This means the replacement of the combustion facilities for heavy oil by those for mixed combustion of heavy oil and diesel or natural gas. Therefore, the applicable facilities are limited to relatively large ones. Specifically, this measure is proposed to those establishments where the diagnostic survey or the detailed on-site questionnaire was conducted.

Other fuel change patterns are also considered depending on the situation of individual sources such as that where mixed combustion of heavy oil and natural gas is currently practiced. Specific proposals in fuel change are given in Table 7.1.4.

### 7.1.3 Managerial Measures

#### (1) Factory Relocation

Among the 97 establishments surveyed by the diagnostic survey program and/or by the on-site questionnaire program, shut-down of one factory and relocation of one factory were determined through the administrative order. Voluntary relocation is planned by three factories. Although relocation means only the displacement of pollution sources and not reduction of pollutant emission, it is an effective measure for improvement of air quality in AMCM.

In addition, when a huge cost is required in air pollution control by extensive modification of old facilities, renewal of facilities associated with relocation can be more positively evaluated in economical viewpoint. In such a case, factory relocation is a good alternative in air pollution control, and therefore taken into consideration.

Table 7.1.4 Proposed Fuel Change Patterns

Fuel change pattern	Category of applicable pollution sources	Applicable pollution source (Visit No.)
From HO to Case A: HO 50% + D or NG 50% Case B: DHO Case C: DEHO	Establishments surveyed by the diagnostic survey or the detailed on-site questionnaire	40 establishments of the visit number: (3, 5, 8, 9, 10, 12, 14, 15, 16, 18, 21, 22, 28, 29, 30, 32, 34, 37, 38, 42, 43, 48, 52, 65, 67, 68, 73, 75, 76, 78, 81, 83, 84, 87, 89, 91, 92, 93, 95, 96)
From HO to Case A: HO 50% + D or NG 50% Case B and C: DHO	Ditto	Paper (27) Basic metals (51, 56) Other Manufacture (64)
From HO to Case A: HO 50% + NG 50% Case B and C: DHO 50% + NG 50%	Ditto	Cement (41)
From HO to Case A, B, C: D or NG	Ditto	Chemicals B (62)
From NG 80% + HO 20% to Case A: same as present Case B: NG 50% + DHO 50% Case C: NG 50% + DEHO 50%	Ditto	Power Plant A (69)
From NG 80% + HO 20% to Case A: same as present Case B: NG 80% + DHO 20% Case C: NG 80% + DEHO 20%	Ditto	Power Plant B (70)
From HO to Case A: HO (same as present) Case B: DHO Case C: DEHO	Others	Many

- Note: 1) HO = heavy oil, D = diesel, NG = natural gas  
DHO = desulfurized heavy oil, DEHO = desulfurized and emulsified heavy oil  
2) Case A applies for the period before the start of supply of DHO.  
3) Case B or Case C is applied after the start of supply of DHO.  
4) Case C requires verification of effects of DEHO.

(2) Operation Management

The first effective step in the NO<sub>x</sub> control is to maintain an appropriate air ratio in combustion. It must be fully understood by operation managers and operators. It is necessary that the administrative authority and company managers cooperate in establishing a guidance system for the dissemination of usage of measuring instruments and the methods of combustion control based on the measurements.



## 7.1.4 Facility Improvement Measures

### (1) Combustion Facilities

The following 23 measures are proposed for facility improvement to the establishments covered by the diagnostic survey or the detailed on-site questionnaire survey, and these measures are also proposed to other pollution sources where the effects are expected.

#### 1) Introduction of operation control and monitoring devices

- Portable oxygen meter (38 establishments)
- NO<sub>x</sub> meter (3 establishments)
- Automatic oxygen meter (9 establishments)
- Thermometer for air preheating (1 establishments)
- Combustion control meters  
(installation or improvement) (11 establishments)
- Telemeter for flue gas monitoring (10 establishments)

#### 2) Improvement of combustion system for NO<sub>x</sub> control

- Low-NO<sub>x</sub> burner (11 establishments)
- Flue gas recirculation (13 establishments)
- Two-stage combustion (2 establishments)
- Off-stoichiometric combustion (3 establishments)
- In-furnace denitration combustion (3 establishments)
- Steam injection (2 establishments)
- Burner nozzle replacement (4 establishments)
- Reduction of volumetric load  
of combustion chamber (6 establishments)
- Installation of precalciner (1 establishment)
- Increase of fuel atomizing air pressure (2 establishments)

#### 3) Improvement of combustion efficiency

- In-house repair (5 establishments)
- Improvement of heat insulation  
of furnace ceiling (3 establishment)
- Installation of fuel preheater (4 establishments)
- Installation of air preheater (1 establishment)
- Installation of recuperator (2 establishments)

4) Flue gas treatment

- Bag filter ( 2 establishments)
- Electrostatic precipitator ( 4 establishments)

(2) Pollution Sources Other Than Combustion Facilities

As pollution control measures for non-combustion facilities, hydrocarbon removal measures are proposed to Chemical Products Factory (C) which has been covered by the diagnostic survey. The measures consist of a hydrocarbon incinerator and a leak prevention measure by cooling.

7.1.5 Effects of Control Measures

The proposed measures for fuel improvement and facility improvement for all the stationary sources are summarized in Table 7.1.5.

Table 7.1.5 Summary of Fuel and Equipment Improvement Plans

Case	Power Plant (A)		Other Sources		
	Fuel use		Equipment improvement	Fuel use	Equipment improvement
Present	HO 20%	NG 80%	None	Various	None
A	same as above		Low-NOx measures	A in Table 7.1.4	Low-NOx measures and others
B	DHO 50%	NG 50%	Low-NOx measures + EP	B in Table 7.1.4	
C	DEHO 50%	NG 50%	Low-NOx measures	C in Table 7.1.4	

- Note: (1) HO = current heavy oil, DHO = desulfurized heavy oil  
 DEHO = desulfurized and emulsified heavy oil  
 NG = natural gas
- (2) Case A applies to the period up to the start of supplying DHO.  
 (3) Case B or Case C applies after the start of supplying DHO.  
 (4) Case C requires verification of effects of DEHO.

Table 7.1.6 shows the pollutant reduction effect in Power Plant (A) and all the stationary sources for each of the above cases.

Table 7.1.6 Effect of Pollution Control Plans

Source	Case	Pollutant emission (1,000 ton/yr)			Reduction ratio (%)		
		NOx	SO <sub>2</sub>	PM	NOx	SO <sub>2</sub>	PM
Power Plant (A)	Present	5.2	17.6	2.1	0	0	0
	A	3.6	17.6	2.1	30	0	0
	B	3.8	9.6	0.3	27	45	87.5
	C	3.0	10.6	1.3	42	40	37.5
All stationary sources	Present	20.8	76.3	11.3	0	0	0
	A	15.1	56.7	6.4*	27	26	43
	B	15.3	24.9	4.4*	26	67	61
	C	13.5	25.8	5.1*	35	66	55

Note : \* Includes the reduction of 3,400 ton/yr at one factory for which plant relocation is proposed.

In the transient Case A, although the emissions of SO<sub>2</sub> and PM can not be reduced in the Power Plant (A), NOx is expected to decrease by 30%, and all the three pollutants are expected to decrease in all the stationary sources combined by at least one-fourth. After the start of supply of DHO, Case C is more advantageous in the reduction of NOx, and Case B brings about more reduction of PM than Case C. Case C requires verification of reduction effect and cost effectiveness of emulsified combustion of DHO, therefore, thorough considerations should be made.

## 7.2 Capital Requirements and Implementation Schedule

### 7.2.1 Equipment Investment

#### (1) Investment Amount

The total amount of investments for facility improvements proposed to the establishments investigated through the diagnostic survey and/or the detailed on-site questionnaire is shown in Table 7.2.1 for the two cases described previously: Case B and Case C.

Table 7.2.1 Investment Amount for Facility Improvements

	Case C : DEHO in Power Plant (A)		Case B : EP in Power Plant (A)	
	Investment (million US\$)	Ratio (%)	Investment (million US\$)	Ratio (%)
Foreign portion	28.208	33	26.611	16
Local portion	58.241	67	135.106	84
Total	86.449	100	161.717	100

Note: Emulsification of desulfurized heavy oil to make DEHO for the Power Plant (A) is assumed to be carried out by the plant itself in Case C.

The investment amounts shown in Table 7.2.1 are the totals of the estimations for individual establishments for each of which control measures are proposed to each of the surveyed combustion facilities. There are 19 establishments where the estimated investment exceeds US\$ 100,000, and 11 establishments, as shown in Table 7.2.2, where the amount exceeds US\$ 1 million. As indicated, the establishments where a large investment is required are also emitters of large amount of pollutants.

In the case when EPs are installed in Power Plant (A), the additional investment is about US\$ 76 million, making the total for the plant close to US\$ 90 million. There considered to be some more establishments, besides those subjected to the detailed on-site questionnaire and the diagnostic survey, where facility improvement is possible and effective. But since they are considered to be rather small establishments, operation improvements by introduction of operation monitoring instruments are more suitable than substantial equipment improvements. Because such improvements require only minor equipment investment, the total investment amount for all the stationary pollution sources is not expected to exceed US\$ 100 - 200 million.

Table 7.2.2 Establishments With Facility Investment Exceeding US\$ One Million

Rank	Establishments (Visit No.)	Investment (million US\$)	Rank in emission		
			NOx	SO <sub>2</sub>	PM
1	Cement (41)	45.082	2	2	4
2	Power Plant (A) (69)	13.043	1	1	2
3	Power Plant (B) (70)	6.778	4	4	8
4	Glass (C) (23)	5.819	6	-	11
5	Glass (A) (68)	3.009	13	9	9
6	Glass (B) (31)	2.522	9	-	13
7	Alcoholic Drinks (47)	1.578	11	6	10
8	Chemicals (A) ( 1)	1.420	21	-	22
9	Petrochemicals (B) ( 8)	1.350	14	5	19
10	Foods (65)	1.317	32	12	30
11	Petrochemicals (A)(16)	1.058	15	10	29

Note: The investment amount in Power Plant (A) corresponds to the case when emulsification of desulfurized heavy oil is carried out by the plant itself.

## (2) Evaluation of Scale of Equipment Investment

To evaluate the scale of the proposed equipment investment, first, the amount of national fixed capital formation was extracted from the economic statistics in Mexico, and then, its equipment investment portion was compared with the amount estimated in this Study for the proposed pollution control measures.

The latest statistic figure for the GDP in Mexico is 494,054,824 million pesos in 1989 according to the temporary report of INEGI, or about US\$ 200 billion, as converted by the average exchange rate of that year, i.e. 2,453.2 pesos/US\$. Since the figure for the fixed capital formation in that year was not available, its ratio to GDP at 18.9% in 1987, with 13.4% for private and 5.5% for government, was used to estimate the national fixed capital formation in 1989 to be about US\$ 38.0 billion.

The breakdown of this fixed capital formation is estimated based on the statistics in 1983 - 1984 as follows:

Domestic : 91.8%

Construction : 63.2%

Transportation equipment : 8.9%

General equipment : 19.7%

Import : 8.2%

Transportation equipment : 1.0%

General equipment : 7.2%

The investment in air pollution control belongs to the general equipment sector whose share in the total fixed capital formation is 26.9% by adding the domestic and the import portions. The amount in the equipment sector is therefore, US\$ 38.0 billion x 26.9% = US\$ 10.2 billion or about US\$ 10 billion.

Of this amount, the total pollution control investment as estimated previously at US\$ 100 - 200 million constitutes only 1 - 2%.

For reference, Table 7.2.3 shows the ratios of the investment in air pollution control to the total equipment investment in Japan based on the data from the Ministry of International Trade and Industry (MITI).

Table 7.2.3 Percentage of Air Pollution Control Investment  
in Total Equipment Investment in Japan (1972 - 1984)

Year	All sectors	Iron & Steel	Petro-leum	Thermal power	Paper & pulp	Non-ferrous metal	Chemical	Machines	Petro-chemical	Textile	Cement	Ceramic
1972	4.7	8.1	8.4	19.9	3.2	7.3	3.9	0.6	3.1	3.0	12.7	6.7
1973	5.8	9.9	15.2	20.8	4.8	9.6	5.2	1.0	6.1	4.0	11.5	12.1
1974	9.8	11.1	30.9	30.2	7.7	8.6	6.0	2.0	10.1	8.0	19.2	9.4
1975	10.5	13.4	26.9	42.9	6.5	8.9	7.1	1.3	10.6	9.0	13.9	7.3
1976	9.4	15.7	18.6	38.9	4.8	7.0	6.8	1.0	7.4	3.2	8.8	6.1
1977	5.1	8.0	3.9	27.7	2.5	7.2	5.0	1.0	6.1	1.5	6.4	7.1
1980	2.5	2.1	4.5	27.0	1.4	1.0	0.4	0.2	0.4	0.7	3.2	2.0
1981	3.3	1.8	2.8	32.8	2.1	0.8	0.5	0.2	0.6	0.5	8.0	1.1
1982	4.3	2.1	3.1	37.4	1.1	0.4	1.9	0.2	1.6	0.8	2.7	1.5
1983	5.7	1.8	3.7	49.4	0.8	0.7	0.8	0.2	0.7	3.0	3.2	0.9
1984	3.6	1.8	1.3	36.7	1.3	0.2	0.7	0.2	0.4	1.7	2.9	1.1

Source: MITI, Japan, "Report of Survey on Equipment Investment for Industrial Pollution Control", 1972-1984.

In Japan, the emission standards for air pollutants were promulgated in August 1973 as required by the Air Pollution Control Law. From that year, equipment investments in air pollution control increased rapidly, and the

percentage of such investments in the total equipment investment was maintained at around 10% for three years. Although the percentage dropped below 5% subsequently, and has been remaining in that level ever since, the thermal power generation sector is an exception, maintaining the high percentage to date.

### 7.2.2 Organization for Implementation

The control measures recommended in this Study can be broadly classified into the following three categories, all requiring human resources and capital investments.

- 1) Management improvement measures
- 2) Fuel change measures
- 3) Equipment improvement measures

The main responsibility in implementing these measures should naturally be assumed by the enterprisers who own and operate combustion facilities, and the extra expenses for implementing air pollution control measures should be considered as a part of the production or service cost.

In the case of private establishments, however, they may not be positive in implementing the measures because higher cost means lower competitiveness. Considerable amounts of investment proposed to certain types of industry may be heavy financial burdens to them at least temporality. In addition, there are not sufficient number of experts in the air pollution control technology, and individual establishments may not be able to secure these experts by themselves.

To overcome these difficulties, it is desirable to make organizational arrangements that induce enterprisers to make unified efforts and facilitate procurement of equipment funds and introduction of air pollution control technologies. Such organizational function may be assumed by existing associations such as the National Bathhouse Association (CANAIBAL), or if possible, new organizations may be established.

The role of administrative authorities include provision of subsidiary measures in the both aspects of human resources and capital resources to promote implementation of the control measures by enterprisers and to bring about sustained effects of those measures.

As economic incentive measures, the tax reduction systems for plant relocation and acquisition of pollution control equipment were introduced in Mexico and carried into effect for a certain period of time in the past. Recently, a low-interest financing program for such activities has been started and implemented for some types of industry. As additional measures to develop human resources and air pollution control technologies, the following are recommended:

- 1) Training for combustion control
- 2) Training for air pollution control
- 3) Consultation for equipment improvement
- 4) Training for exhaust gas measurement
- 5) Leasing of exhaust gas measuring instruments
- 6) Interest subsidy and favorable taxation on pollution control investment

### 7.2.3 Time schedule for Implementation

Because the proposed air pollution control measures are classified into two groups, i.e., those to be carried out by the initiative of individual establishments, and those whose implementation is dependent on the availability of desulfurized heavy oil, the overall implementation schedule is proposed to be as follows:

Phase 1 : up to 1995

- 1) Installation of basic combustion control instruments
- 2) Training of combustion and air pollution control engineers and technicians
- 3) Transient fuel change



- 4) Provision of stimulative measures such as low-interest loans and favorable tax system
- 5) Installation or leasing of exhaust gas measuring instruments
- 6) Plant relocation
- 7) Implementation of the facility improvement measures including low-NOx measures
- 8) Verification of new control technologies
- 9) Consolidation of the administrative organizations

Phase 2 : after 1995

- 1) Fuel change
- 2) Consolidation of the stimulative measures
- 3) Implementation of advanced measures for improvement of combustion facilities and combustion methods

### 7.3 Recommendation

For the effective implementation of the proposed plan for controlling stationary sources of air pollution in the Metropolitan Area of the City of Mexico, the following actions are highly recommended.

#### (1) Installation of Basic Measuring Instruments in Combustion Facilities

Virtually all of combustion facilities in AMCM are not equipped with a fuel flow meter which is an indispensable tool for effective combustion control. Installation of the flow meter should be made obligatory.

Other basic instruments that are usually not provided include the pressure gauges and the thermometers for fuel and combustion air and the pressure gauge for fuel atomizing steam. If provided, most of them employ percent-scale indicators rather than indicating actual values, making operation monitoring difficult.

Installation of these gauges and meters should also be made obligatory with the indicators showing actual values compensated for barometric pressure.

#### (2) Provision of Exhaust Gas Measuring Instruments for Monitoring of Pollutant Emitting Facilities

Factories having pollutant emitting facilities of large capacity should be obliged to install continuous measuring devices for the flue gas velocity and concentration of pollutants in the flue gas including CO, CO<sub>2</sub>, NO<sub>x</sub>, smoke and soot, and NO<sub>x</sub>. A telemetric monitoring system should be established through which the measured data are transferred to a monitoring center of SEDUE.

Establishments having pollutant emitting facilities of small-to-medium capacities should have a flue gas oxygen analyzer for routine measurement. Concentration of CO<sub>2</sub>, CO, smoke and soot, and NO<sub>x</sub> in the flue gas should be also measured at an appropriate interval. The results should be periodically submitted to the responsible government agency.

### (3) Guidance for Combustion Control

Guidance should be given to the engineers in stationary sources by the combustion technology specialists on the control of pollutant generation and emission from combustion facilities and on the methods of energy saving. As a first step, importance of the appropriate air-fuel ratio in combustion should be realized by the engineers at the sources. It can be realized through such a practice as measuring concentration of CO, NO<sub>x</sub> and smoke and soot in the flue gas at varying concentration of oxygen and constructing a chart showing their relationship. Early conduct of this practice with obligatory submission of the result is highly recommended.

### (4) Technical Consolidation in the Administrative Sector

#### 1) Establishment of Industrial Pollution Control Assistance Center

It is desirable to establish an "Industrial Pollution Control Assistance Center (IPCAC: tentative name)" attached to SEDUE which assumes a leading role in implementation of the activities stated above by extending assistances and guidances to concerned sectors in control of industrial pollution.

The Government of Mexico has a plan to establish an "Environmental Research and Training Center (ERTC: tentative name)" which deals with various environmental problems including air quality, water quality, solid wastes and hazardous wastes. If ERTC is to be established, IPCAC may be positioned as a part of ERTC.

Functions of IPCAC concerning air pollution include the following:

- i) inspection and authorization, selling, renting and leasing of exhaust gas measuring instruments, and technical training for the measurement
- ii) technical guidance for industrial pollution control
- iii) training of the experts who assume the above roles

#### 2) Fosterage of Personnel for Exhaust Gas Inspection

It is highly important for the administrative sector to know technical realities concerning emissions of pollutants at stationary sources.

Accordingly, it is indispensable for the relevant sections of SEDUE, DDF, and GEM to have competent technical personnel for inspection of the emissions at stationary sources. These personnel should be fostered and reasonably treated, desirably as permanent employees, so that the technical knowledge in this field is accumulated within the administrative sector.

### 3) Consolidation of Emission Inventory

The existing inventory data for stationary air pollution sources in AMCM are considered to be not adequate in terms of the number of sources covered, data items, and accuracy of the data. Preparation of a comprehensive emission inventory of the Metropolitan Area under cooperation of SEDUE, DDF and GEM is recommended.

### (5) Practical Application of Stationary Source Control Technologies

The control technologies of stationary pollution sources proposed in this Study include 1) two-stage combustion type low-NO<sub>x</sub> burners for heavy oil, and 2) emulsified heavy oil combustion, as well as others including exhaust gas recirculation, two-stage combustion, off-stoichiometric combustion, in-furnace denitration combustion, and burners atomized with natural gas for furnaces with particularly high NO<sub>x</sub> concentration such as glass melting tank ovens.

Since the desulfurized heavy oil scheduled to be supplied from 1995 will have still a high content of nitrogen, combination of the measures for reducing fuel NO<sub>x</sub> and thermal NO<sub>x</sub> is indispensable.

The two-stage combustion type low-NO<sub>x</sub> burner is effective in reducing fuel NO<sub>x</sub>, and therefore, its early development is recommended.

Effects of emulsified combustion as a measure to reduce thermal NO<sub>x</sub> and smoke and soot are technically recognized. But since there are not many practical examples in Japan, a careful study is necessary on the applicability of this technology to the Mexican heavy oil. A laboratory-scale test conducted in the present Study confirmed the effects of this technology. In order to apply the emulsified combustion of the Mexican heavy oil to industrial boilers and furnaces in Mexico, it is necessary to carry out a feasibility study including a pilot-scale test and practical application tests.

(6) Economic Incentives for Pollution Control Investment

Since investments in environmental pollution control generally do not bring about economic benefits to business establishments, it is desirable to introduce economic measures such as financial assistance and tax incentives that indirectly promote such investment. It is desirable that the favorable taxation system once adopted in Mexico be re-introduced and the existing low-interest credit system be consolidated.

(7) Control of Stationary Sources and Mobile Sources

This Study has been concerned with the control of stationary air pollution sources, and priorities have been given to the reductions of NOx and PM emissions. The amount of emission of NOx from mobile sources is said to make up three-quarters of the total emission in AMCM. Against this situation, the Mexican Government has established an emission control program applicable to new automobiles of respective models. Long-term effects are expected if this program is implemented steadily. On the other hand, implementation of the control measure for stationary sources brings about immediate effects although the total NOx emission is smaller than that from mobile sources. Therefore, early implementation of stationary source control measures is highly desirable.



JICA