

No.

THE UNITED MEXICAN STATES

THE STUDY ON THE AIR POLLUTION CONTROL PLAN
OF STATIONARY SOURCES
IN
THE METROPOLITAN AREA OF THE CITY OF MEXICO

FINAL REPORT
APPENDIX

SEPTEMBER 1991

JAPAN INTERNATIONAL COOPERATION AGENCY

MP I
CR(5)
91-108

RY

JICA LIBRARY



1093183(0)

22793

THE UNITED MEXICAN STATES

**THE STUDY ON THE AIR POLLUTION CONTROL PLAN
OF STATIONARY SOURCES
IN
THE METROPOLITAN AREA OF THE CITY OF MEXICO**

**FINAL REPORT
APPENDIX**

SEPTEMBER 1991

JAPAN INTERNATIONAL COOPERATION AGENCY

国際協力事業団

22793

Table of Contents

1. Results of Detailed On-site Questionnaire at 97 Establishments	1
2. Results of Flue Gas Measurement in Diagnostic Survey at 25 Establishments	103
3. Results of Combustion Test of Low-NOx Burners in the 18 de Marzo Refinery	158
4. Result of Questionnaire Survey on Enterprisers' Minds Toward Environmental Pollution	168
5. Emulsion Combustion	175

**1. Results of Detailed On-site Questionnaire
at 97 Establishments**

1. Results of Detailed On-site Questionnaire at 97 Establishments

(1) Objectives

A total of 97 establishments were selected for the no-site questionnaire survey: 82 factories, 11 bathhouses, 2 hotels, one sports center, and one hospital. Breakdown of the 82 factories by types and scales is shown in Table 1.1.

Table 1.2 (1) and 1.2 (2) show the names of the 97 establishments with the date of visit for survey.

(2) Results

The results of the survey are presented in the following tables by each establishment in the order of the visit.

Table 1.1 Number of Establishments Surveyed by Types and Scales

Type of Industry	Number of Establishments by Scale			
	Large	Medium	Small	Total
Food	5	1	3	9
Drinks	1	-	-	1
Leather	-	1	-	1
Paper and its products	5	6	-	11
Chemical products	9	5	4	18
Petrochemical products	4	1	2	7
Petroleum refinery	1	-	-	1
Coal and petroleum products	1	-	1	2
Rubber and plastic products	2	2	1	5
Non-metallic mineral products	9	-	1	10
Basic metals	1	3	3	7
Metal products	2	3	-	5
Transportation equipment	1	-	-	1
Precision instruments	-	1	-	1
Other manufacture	1	-	-	1
Electric power	2	-	-	2
Factories Total	44	23	15	82
Public bathhouse		11		11
Sports center		1		1
Hotel		2		2
Hospital		1		1
Service and Commerical Total		15		15
Total				97

Table 1.2 (1) Names of Establishments for On-site Questionnaire (No.1)

Visit No.	Name of Establishment	Type of Industry	Date of Vist
1	FCA. DE JABON LA CORONA, S.A.	Chemical	June 12, 1990
2	POLAQUIMIA, S.A. DE C.V.	Chemical	
3	PROCTOR & GAMBLE DE MEXICO, S.A. DE C.V.	Chemical	
4	BANOS RIO BLANCO	Bothhouse	
5	HARINAS Y GRASAS XALOSTOC, S.A.	Food	June 13, 1990
6	POLIESTERES BAYER, S.A.	Petrochemical	
7	CIBA GEIGY MEXICANA, S.A. DE C.V.	Chemical	
8	FIBRAS SINTETICAS, S.A. DE C.V.	Petrochemical	
9	BANOS COSTA DEL SOL	Bathhouse	
10	BANOS COACALCO	Bathhouse	
11	PLANTA DE ASFALTO D.D.F.	Coal/petroleum product	June 14, 1990
12	INDUSTRIAS DE HULE GALGO	Rubber/plastic	
13	VIDRIERA MEXICO, S.A.	Non-metallic mineral	
14	UNIROYAL, S.A. DE C.V.	Rubber/plastic	
15	CENTRO DEPORTIVO CHAPULTEPEC, A.C.	Sport center	
16	KIMEX, S.A. DE C.V.	Petrochemical	June 15, 1990
17	INDUSTRIAS RESISTOL, S.A.	Chemical	
18	NOVAQUIM, S.A.	Chemical	
19	ALCOMEX, S.A. DE C.V.	Metal product	
20	FUNDICION CHORNE	Basic metal	June 18, 1990
21	BANOS TACUBAYA	Bathhouse	
22	BANOS NAUCALPAN	Bathhouse	
23	NUEVA FABRICA NACIONAL DE VIDRIO	Non-metallic mineral	
24	PENNWALT, S.A. DE C.V.	Chemical	June 19, 1990
25	GENERAL PRODUCTOS CO., S.A. DE C.V.	Chemical	
26	IDEAL STANDARD, S.A.	Non-metallic mineral	
27	FCA. DE PAPEL SAN RAFAEL	Paper	June 20, 1990
28	FCA. DE PAPEL MEXICO	Paper	
29	HACO MEXICANA, S.A.	Chemical	
30	CIA. PAPELERA EL FENIX, S.A.	Paper	
31	VITRO FIBRAS, S.A.	Non-metallic mineral	June 21, 1990
32	PASTEURIZADORA LA LAGUNA	Food	
33	VIDRIO PLANO DE MEXICO, S.A.	Non-metallic mineral	
34	PAPELERA IRUNA, S.A.	Paper	June 22, 1990
35	METALURGICA ALMENA	Basic metal	
36	BANOS LA NARANJA	Bathhouse	
37	BANOS XOLALPA	Bathhouse	
38	BANOS GABIS	Bathhouse	
39	MEDIDORES AZTECA, S.A.	Basic metal	June 25, 1990
40	SALICILATOS DE MEXICO	Precision instrument	
41	CEMENTOS ANAHUAC, S.A.	Non-metallic mineral	
42	PAPELERA ATLAS	Paper	
43	BANOS LUPITA	Bathhouse	
44	PORCELANITE, S.A.	Non-metallic mineral	June 26, 1990
45	PRODUCTOS SAN CRISTOBAL	Paper	
46	CIA. HULERA TORNEL	Rubber/plastic	
47	CERVECERIA MODELO, S.A. DE C.V.	Drinks	
48	BANOS TACUBA	Bathhouse	

Table 1.2 (2) Names of Establishments for On-site Questionnaire (No.2)

Visit No.	Name of Establishment	Type of Industry	Date of Vist
49	CARTONAJES ESTRELLA	Paper	June 27, 1990
50	FUNDIDORA Y LAMINADORA ANAHUAC	Basic metal	
51	ACEROS AHUEHUETES	Basic metal	
52	BANOS SANTIAGO	Bathroom	
53	ACEROS CORSA	Metal product	June 28, 1990
54	DU PONT	Chemical	
55	INDUSTRIAS NYLBO	Metal product	
56	FUNDICIONES FIERRO-MEX	Metal product	
57	REFINERIA 18 DE MARZO	Petroleum refinery	June 29, 1990
58	ANDERSON CLAYTON, S.A.	Food	
59	FUNDICIONES DE HIERRO Y ACERO	Metal product	
60	FUNDIDORA DE ACEROS TEPEYAC	Basic metal	
61	FORD MOTOR COMPANY	Transport equipment	July 2, 1990
62	QUIMICA LUCAVA, S.A.	Chemical	
63	INDUSTRIAS UNIDAS, S.A.	Non-metallic mineral	
64	3M DE MEXICO, S.A.	Other	
65	ANDERSON CLAYTON & COMPANY, S.A. DE C.V.	Food	July 3, 1990
66	ESMALTES Y COLORANTES, S.A.	Non-metallic mineral	
67	ACEITES Y JABONES, S.A.	Chemical	
68	VIDRIERA ORIENTAL, S.A. DE C.V.	Non-metallic mineral	
69	TERMOELECTRICA DEL VALLE DE MEXICO	Electric power	July 4, 1990
70	TERMOELECTRICA JORGE LUQUE	Electric power	
71	FUNDICION DE FIERRO Y METALES	Basic metal	
72	P.P.G. INDUSTRIAS DE MEXICO	Chemical	
73	ORGANIZACION QUIMICA MEXICANA	Food	July 5, 1990
74	PRODUCTOS NUTRICIONALES	Food	
75	POLIMEROS (POLIESPUMAS DE MEXICO)	Petrochemical	
76	EMPAQUES DE CARTON UNITED	Paper	
77	SILICATOS Y DERIVADOS, S.A.	Chemical	July 6, 1990
78	GANADEROS PRODUCTORES DE LECHE PURA	Food	
79	HOSPITAL 20 DE NOVIEMBRE ISSSTE	Hospital	
80	HOTEL DEL ANGEL	Hotel	
81	MA. ISABEL SHERATON	Hotel	
82	SOSA TEXCOCO, S.A.	Chemical	July 9, 1990
83	AMERICAN TEXTILE, S.A. DE C.V.	Petrochemical	
84	MANUFACTURAS GARGO, S.A. DE C.V.	Paper	
85	INDUSTRIAL PAVIMENTADORA, S.A.	Coal/petroleum product	
86	HULE INDUSTRIAL, S.A.	Rubber/plastic	July 10, 1990
87	POLIRESINAS HUETTENES ALBERTOS, S.A.	Petrochemical	
88	AGA DE MEXICO, S.A. DE C.V.	Chemical	
89	TAMM Y CIA, S.A. DE C.V.	Petrochemical	
90	CIA. HULLRA ATLAS, S.A.	Rubber/plastic	July 11, 1990
91	CORRUGADO Y FIBRA, S.A.	Paper	
92	SALES INDUSTRIALES DE MEXICO	Chemical	
93	TENERIA TEMOLA, S.A. DE C.V.	Leather	
94	SABRITAS, S.A. DE C.V.	Food	
95	LA HACIENDA, S.A. DE C.V.	Food	July 12, 1990
96	EMPAQUES Y CARTON CORRUGADO, S.A.	Paper	
97	DOW QUIMICA MEXICANA, S.A.	Chemical	

Name of Establishment	FABRICA DE JABON LA CORONA, S.A.				
Type of Industry (Product)	Chemical (soap, detergent, cooking oil)				
Scale of Factory	Large	Number of Employees		2,777	
Annual Sales or Production	570,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Natural gas (211.3 pesos/m ³) 6,440,000 m ³ /mon 1,360,770,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Water tube boiler	15 ton/hr	Natural gas	1,400 m ³ /hr		3 units
Water tube boiler	15 ton/hr	Natural gas	1,130 m ³ /hr		2 units
Water tube boiler	20 ton/hr	Natural gas	1,725 m ³ /hr		
Water tube boiler	6 ton/hr	Natural gas	416 m ³ /hr		
Water tube boiler	5 ton/hr	Natural gas	382 m ³ /hr		
Heat medium boiler	3.5 ton/hr	Natural gas	112 m ³ /hr		4 units
Heat medium boiler	35 ton/hr	Natural gas	45 m ³ /hr		
Heat medium boiler	12 ton/hr	Natural gas	336 m ³ /hr		
Heat medium boiler	5 ton/hr	Natural gas	45 m ³ /hr		
Heat medium boiler	1.5 ton/hr	Natural gas	56 m ³ /hr		
Dryer	10 ton/hr	Natural gas	350 m ³ /hr		
Dryer	10 ton/hr	Natural gas	350 m ³ /hr		2 units
Dryer	60 ton/hr	Natural gas	182 m ³ /hr		

Outline of the Facility Surveyed	Heat Medium Boiler	3.5 ton/hr
Capacity of the facility	: 3.5 ton/hr	
Fuel consumption	: 112 m ³ /hr	
Heat Medium and temperature	: Oil, 260 - 280 °C	
Fuel temperature	: Normal	
Combustion air temperature	: Normal	
Operating time	: 24 hr/day, 144 hr/week	
Stack diameter and height	: 0.4 mφ x 15 m	
Remarks	: Most of combustion facilities are aged ones.	

Outline of Survey Result	
Present pollution control measures	: Cyclones attached to dryers. Natural gas used.
Future plan for pollution control	: None
Present energy-saving measures	: None

1. This is a large plant having many thermal units. These units are installed closely to each others. Therefore, there are little space secured for reconstruction or grading up. All thermal units use natural gas.
2. Exhaust gas analysis was made on a heat medium boiler of around 1 million kcal/hr among a total of 19 thermal units. The O₂ content was relatively high at 8.8% and the exhaust gas temperature also high at 330°C. Namely, the efficiency was around 76% and may be increased to 82% by means of combustion control (i.e., by setting the O₂ concentration to 3 - 4%). Since natural gas was burnt, no soot was generated.

Name of Establishment	CIBA GEIGY MEXICANA, S.A. DE C.V.				
Type of Industry (Product)	Chemical (medicines, dyeing agent, insecticide)				
Scale of Factory	Large	Number of Employees		1,200	
Annual Sales or Production					
Kind of Fuel, Consumption and Price	Diesel (513 pesos/l) 18,900 l/mon 9,700,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Once-through boiler	1.5 ton/hr	Diesel	92 l/hr		
Once-through boiler	1.5 ton/hr	Diesel	92 l/hr		1 - 2 units in operation
Once-through boiler	1.0 ton/hr	Diesel	80 l/hr		
Once-through boiler	0.5 ton/hr	Diesel	40 l/hr		
Outline of the Facility Surveyed					
		Once-through boiler	1.5 ton/hr (steam)		
Evaporation rate	: Rating: 1.5 ton/hr, Normal: 92 l/hr				
Steam pressure	: 9.0 kg/cm ² g				
Fuel consumption	: Rating: 92 l/hr, Normal: 92 l/hr				
Fuel pressure	: 15 kg/cm ² g				
Temperature	: Normal				
Combustion air temperature	: Normal				
Combustion exhaust gas composition	: O ₂ - 13.6%, CO ₂ - 10 to 12%, CO - 0.005% (as measured by the plant)				
Exhaust gas temperature	: 300°C (as measured by the plant)				
Stack	: 0.4mφ x 15m				
Operating hours	: 16 hr/day, 96 hr/week				
Outline of Survey Result					
Present pollution control measures	: None				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
<p>1. The factory is kept clean. No particular offensive odor was detected.</p> <p>2. This is a vertical once-through boiler and the combustion air fan is also driven by a diesel engine. Vibration of the boiler is high. The exhaust gas O₂ content was 10.1%, with the exhaust gas temperature being at 250°C to indicate excess air combustion. The efficiency was relatively low at 79%. As the Bacharach value was No. 3, reducing the O₂ content slightly may achieve the efficiency of 80% or more.</p>					

Name of Establishment	PLANTA DE ASFALTO D.D.F.				
Type of Industry (Product)	Coal and petroleum product (asphalt mix)				
Scale of Factory	Large	Number of Employees			
Annual Sales or Production					
Kind of Fuel, Consumption and Price	Diesel 21.76 kl/day				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1 Rotary kiln	250 ton/hr	Diesel	1,360 l/hr		
2 Rotary kiln	250 ton/hr	Diesel	1,360 l/hr		
3 Rotary kiln			1,000 l/hr		

Outline of the Facility Surveyed	Rotary kiln for aggregate
Rating	: 250 ton/hr, Normal: 200 ton/hr
Fuel consumption	: Rating: 1,360 l/hr : Normal: 800 - 1,000 l/hr
Temperature of object to be heated	: 140°C
Fuel pressure	: 2.8 - 3.5 kg/cm ² g
Fuel temperature	: Normal
Atomizing medium pressure	: 800 - 155 mmAq
Combustion air pressure	: 1.7 kg/cm ² g
Combustion air temperature	: Normal
Stack	: 1.7 m x 0.8 m x 9.8 m

Outline of Survey Result	
Present pollution control measures	: Fuel change, dust collection with bag filter/scrubber
Future plan for pollution control	: None
Present energy-saving measures	: None

- Problems of plant location**
This plant is in a hollow place of several ten thousand square meter, which is the remain of mining of igneous rocks, a raw material for asphalt concrete. The stack height is only 9.8m for this low place. The location is a basic mistake in view of dispersion of air pollutants and environmental protection.
- Outline of the process**
93% of sand, crushed igneous rocks, and cement are dried (direct drying with 900°C flame and combustion exhaust gas) in a rotary kiln. 7% of asphalt No. 6 is mixed to make product.
- Combustion conditions**
The burner was of a low-pressure atomization type. The O₂ content of stack sample was said to be 12.5% and this value needs to be reevaluated because it appears to be affected by air intrusion. (Not necessarily air excess in combustion)
- Present state of air pollution control**
Dust collection is made with bag filter for one kiln and with scrubber for another. Judging from visually observed dust emission from the stack, the efficiency was not satisfactory.

Name of Establishment	UNIROYAL, S.A. DE C.V.				
Type of Industry (Product)	Rubber and plastic product (tire)				
Scale of Factory	Large	Number of Employees		530	
Annual Sales or Production					
Kind of Fuel, Consumption and Price	Heavy oil (L) (175.6 pesos/l) 308,600 l/mon 54,190,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Water tube boiler	10 ton/hr	Heavy oil (L)	500 l/hr	18	
Water tube boiler	6.4 ton/hr	Heavy oil (L)		18	Not used
Hot water boiler	0.5 ton/hr	Diesel			For shower

Outline of the Facility Surveyed	Water tube boiler 10 ton/hr (steam)				
Evaporation rate	: Rating: 10 ton/hr, Normal: 6 ton/hr				
Steam pressure	: 21 kg/cm ² g				
Fuel consumption	: Rating: 803 l/hr Normal: 600 l/hr				
Fuel pressure	: 3 kg/cm ² g, Temperature: 104°C				
Atomizing steam pressure	: 4.3 kg/cm ² g, Temperature: 120°C				
Combustion air temperature	: Normal				
Combustion exhaust gas composition	: O ₂ - 3.4%, CO ₂ - 12.4% (as measured by the plant)				
Combustion exhaust gas temperature	: 320°C (as measured by the plant)				
Stack	: 1.68 mφ x 37.8 m				
Operating hours	: 24 hr/day, 144 hr/week				

Outline of Survey Result	
Present pollution control measures	: None
Future plan for pollution control	: None
Present energy-saving measures	: None

1. Tires are produced and steam used for heating during molding.
2. The O₂ content was 10.1% and the exhaust gas temperature was as high as 289 - 304°C, with the boiler efficiency as poor as 76%. Besides, the Bacharach value was No. 9 or more indicating soot generation. Smoke emission from the stack was visually observed.
3. The steam pressure at the burner inlet was 4.3 kg/cm²g and the oil pressure was 3.0 kg/cm²g, with ΔP=1.3 kg/cm²g. Atomization was also considered appropriate. It is therefore necessary to carry out fundamental burner checks (air intake method, etc.).

Name of Establishment	ALCOMEX, S.A. DE C.V.				
Type of Industry (Product)	Metal product (Al sash, Al racket, tube)				
Scale of Factory	Large	Number of Employees		400	
Annual Sales or Production	33,319,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Natural gas (211.3 pesos/m ³) 247,265 m ³ /mon 52,250,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Melting furnace	20 ton/hr	Natural gas	227 m ³ /hr		Batch type
Melting furnace	1.75 ton/hr	Natural gas	20 m ³ /hr		Batch type
Melting furnace	1.75 ton/hr	Natural gas	20 m ³ /hr		Batch type
Melting furnace	1.75 ton/hr	Natural gas	20 m ³ /hr		Batch type
Melting furnace	1.75 ton/hr	Natural gas	20 m ³ /hr		Batch type
Heat treating furnace		Natural gas	36 m ³ /hr		
Heat treating furnace		Natural gas	36 m ³ /hr		
Heat treating furnace		Natural gas	36 m ³ /hr		
Heat treating furnace		Natural gas	36 m ³ /hr		
Heat treating furnace		Natural gas	36 m ³ /hr		

Outline of the Facility Surveyed	Melting furnace	20 ton/hr (Aluminum)
Capacity	: 80 ton/4 hr (1 batch)	
Fuel consumption	: 227 m ³ /hr	
Fuel pressure	: 600 mmAq	
Combustion air pressure	: 300 mmAq, Temperature: Normal	
Stack	: 0.6 mφ x 15 m	
Operating hours	: 16 hr/day (4 batches/day), 96 h/week (24 batches/week)	

Outline of Survey Result	
Present pollution control measures	: Natural gas used
Future plan for pollution control	: None
Present energy-saving measures	: None

- The working environment was relatively good.
- Measurement was made at the end of batch operation, with the low combustion load. The result was generally satisfactory with the O₂ content at 4.6 - 6.8%. The exhaust gas temperature was 205°C, which is very low considering the high temperature within the furnace at 800°C. It indicates that the heat equivalent to the exhaust gas of 500 - 600 °C may be escaping. Installation of a recuperator is recommended.

		No. 23	Date of Visit	Jun. 18, 1990	
Name of Establishment	NUEVA FABRICA NACIONAL DE VIDRIO				
Type of Industry (Product)	Non-metallic mineral product (glass bottle)				
Scale of Factory	Large	Number of Employees		2,100	
Annual Sales or Production	(Capital: 500,000,000 pesos)				
Kind of Fuel, Consumption and Price	Natural gas (211.3 pesos/m ³) 5,415,000 m ³ /mon 1,144,000,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Glass melting furnace tank oven	16.7 ton/hr	Natural gas	2,160 m ³ /hr	4	Cullet 55%
Glass melting furnace tank oven	8.3 ton/hr	Natural gas	1,500 m ³ /hr	5	Cullet 55%
Glass melting furnace tank oven	8.3 ton/hr	Natural gas	800 m ³ /hr	0	Cullet 55%
Decorating furnace (12 units)		Natural gas	Total		
Annealing furnace (17 units)		Natural gas	2,980 m ³ /hr		
Outline of the Facility Surveyed	Glass melting furnace tank oven (Glass)				
Capacity of the facility	: 16.7 ton/hr (glass)				
Unit consumption	: 1,302,000 kcal/ton (glass)				
Fuel consumption	: 2,160 m ³ /hr				
Glass melting temperature	: 1,500°C				
Fuel pressure	: 300 mmAq				
Combustion air pressure	: Several mmAq				
Combustion air temperature	: 1,350 °C				
Combustion exhaust gas composition	: O ₂ - 6.95% CO ₂ - 8.90% (as measured by the plant)				
Combustion exhaust gas temperature	: Regenerator inlet - 1,440 °C Outlet - 466 °C (as measured by the plant)				
Stack	: 3.6 mφ x 88 m				
Operating hours	: 24 hr/day, 168 hr/week				
Regenerator	: 15-minute changeover (automatic) Burner: 24 pcs Air port: 12pcs				
Outline of Survey Result					
Present pollution control measures	: Stress on fine dust prevention measures, natural gas used				
Future plan for pollution control	: None				
Present energy-saving measures	: Regenerator installed				
<ol style="list-style-type: none"> This is a leading glass maker. Efforts are made to prevent dust generation. The O₂ content was 2.2% and controlled to a reasonable level. In spite of natural gas burning, smoke emission (thin purple) was observed from the stack. The Bacharach value was No.3 - 4, which is due to faulty construction of the burner which should be changed. Heat insulation of the furnace was generally satisfactory and the unit fuel consumption was rather low at 1.3 million kcal/ton (with cullet at 55%). 					

		No. 25	Date of Visit	Jun.19, 1990	
Name of Establishment	GENERAL PRODUCTOS CO., S.A. DE C.V.				
Type of Industry (Product)	Chemical (Na ₂ S ₂ O ₄ , ZnO, SO ₂ solution)				
Scale of Factory	Large	Number of Employees		320	
Annual Sales or Production	30,000,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Natural gas (211.3 pesos/m ³) 1,137,600 m ³ /mon 240,400,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	7.8 ton/hr	Natural gas	686 m ³ /hr	4	Three of four units in operation
Smoke tube boiler	7.8 ton/hr	Natural gas	686 m ³ /hr	4	
Smoke tube boiler	4.7 ton/hr	Natural gas	208 m ³ /hr	4	
Smoke tube boiler	3.1 ton/hr	Natural gas	208 m ³ /hr	3	
Outline of the Facility Surveyed					
		smoke tube boiler	7.8 ton/hr (steam)		
Evaporation rate	:	Normal: 7.8 ton/hr			
Steam pressure:	:	8 kg/cm ² g			
Fuel consumption	:	Normal: 686 m ³ /hr			
Fuel pressure	:	250 mmAq			
Combustion air temperature	:	Normal			
Combustion exhaust gas composition	:	O ₂ - 4.3% CO ₂ - 8.4% CO - 17 ppm (as measured by the plant)			
Combustion exhaust gas temperature	:	204°C (as measured by the plant)			
Stack	:	0.6 mφ x 7.3 m			
Operating hours	:	24 hr/day, 168 hr/week			
Outline of Survey Result					
Present pollution control measures	:	Natural gas used			
Future plan for pollution control	:	None			
Present energy-saving measures	:	None			
<ol style="list-style-type: none"> The work environment was poor with ammonium and sulfur odor detected. The O₂ content was 1.7% and Bacharach value No.1, thus combustion control was extremely good. The flue gas measurement is carried out once a week using the Teledyne gas analyzer. The exhaust gas temperature was also satisfactory at 209°C, with the boiler efficiency at 88%. 					

Name of Establishment	IDEAL STANDARD, S.A.				
Type of Industry (Product)	Non-metallic mineral product (sanitary porcelain)				
Scale of Factory	Large	Number of Employees		600	
Annual Sales or Production	860,000 pieces/yr				
Kind of Fuel, Consumption and Price	Natural gas 712,300 m ³ /day (207.36 pesos/m ³) 4,431,075,840 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1. Tunnel kiln	403,200 kcal/hr	Natural gas	245 m ³ /hr	6	
2. Tunnel kiln	403,200 kcal/hr	Natural gas	245 m ³ /hr	6	
3. Tunnel kiln	296,000 kcal/hr	Natural gas	180 m ³ /hr	3 4	
4. Tunnel kiln	296,000 kcal/hr	Natural gas	180 m ³ /hr	3 4	
5. Downdraft kiln	453,600 kcal/hr	Natural gas	500 m ³ /hr	3	
Infrared burner	30,200-60,600 kcal/hr				800 units
Outline of the Facility Surveyed					
Tunnel kiln for sanitation fixture					
Heat quantity	: 403,200 kcal/hr				
Fuel consumption	: Rating : 245 m ³ /hr Normal 200 m ³ /hr				
Temperature of an object to be heated	: 1,225°C				
Fuel pressure	: 50 mmAq				
Combustion air temperature	: Normal				
Combustion exhaust gas composition	: O ₂ - 2.09%, CO ₂ - 10.59% (as measured by the plant)				
Exhaust gas temperature	: 275°C (as measured by the plant)				
Operating hours	: 24 hr/day, 168 hr/week				
Outline of Survey Result					
Present pollution control measures	: Fuel changed to natural gas				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> 1. There was no door at inlet and outlet of the tunnel kiln for kiln car and large quantity of air was entering. Consequently, the exhaust gas of stack on the side of the preheating zone contained O₂ at 12.9% and the temperature was 275°C. As the exhaust gas temperature is expected to rise by installing the door to the kiln, the use of air preheater becomes possible. 2. Kiln measuring instruments and automatic control equipment were well controlled except for part of equipment. 3. Under the present economic situation, this plant is refraining from investment for pollution control. 					

Name of Establishment	FCA. DE PAPEL SAN RAFAEL				
Type of Industry (Product)	Paper and its product (paper)				
Scale of Factory	Large	Number of Employees		1,023	
Annual Sales or Production	50,000 ton/yr				
Kind of Fuel, Consumption and Price	Black liquor 5,590 kl/mon Heavy oil (H) 6,846 kl/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1. Black liquor boiler	12.5 ton/hr	Black liquor	3,280 l/hr	-	
2. Black liquor boiler	20.5 ton/hr	Black liquor Heavy oil (H)	4,480 l/hr 416 l/hr	15	Superheater
3. Water tube boiler	34.0 ton/hr	Heavy oil (H)	2,017 l/hr	-	
4. Water tube boiler	60.0 ton/hr	Heavy oil (H)	3,600 l/hr	-	
5. Water tube boiler	60.0 ton/hr	Heavy oil (H)	3,500 l/hr	15	Superheater

Outline of the Facility

1. Black liquor boiler	: 20.5 ton/hr (steam)	
Evaporation rate	: Rating: 20.5 ton/hr	Normal: 18 ton/hr
Fuel consumption	: Normal: Black liquor 4,480 l/hr	Heavy oil (H) 416 l/hr
Steam pressure	: 30 kg/cm ²	Temperature : 235 °C
Fuel pressure	: Black liquor 3.0 kg/cm ² g	Heavy oil 2.0 kg/cm ² g
Temperature	: Black liquor 110°C	Heavy oil 105°C
Combustion air temperature	: 120°C	
Combustion exhaust gas composition	: O ₂ - 3.0% CO ₂ - 14% (as measured by the plant)	
Exhaust gas temperature	: 140°C (as measured by the plant)	
Stack	: 2.7 mφ x 51.5 m	
Operating time	: 24 hr/day, 168 hr/week	
2. Water tube boiler	: 60 ton/hr (steam), with recuperator	
Evaporation rate	: Rating: 60 ton/hr	Normal: 45 ton/hr
Fuel consumption	: Normal: Heavy oil (H) 3,500 l/hr	
Steam pressure	: 30kg/cm ² g	
Steam temperature	: 235°C	
Fuel pressure and temperature	: 3,000 mmAq, 105°C	Atomizing steam pressure: 5.0 kg/cm ²
Combustion air temperature	: 130°C	
Exhaust gas composition	: O ₂ - 3.2%, CO ₂ - 14% (as measured by the plant)	
Exhaust gas temperature	: Recuperator inlet : 300°C, Outlet: 130°C (as measured by the plant)	
Stack	: 2 mφ x 15.2m	
Operating time	: 24 hr/day, 168 hr/week	

Outline of Survey Result

Present pollution control measures	: Electric precipitator, bag filter
Future plan for pollution control	: None
Present energy-saving measures	: Economizer, recuperator

Black liquor boiler

1. Composition of the black liquor: Water: 40%, C: 38.3%, H₂: 3.7%, S: 3.5%, and 3,408kcal/kg
2. Black liquor is sprayed and burnt in the boiler by means of a splash type burner and NaOH is recovered by sumelt. Heavy oil (H) is auxilliarily used at 5%.
3. Electric precipitator is used, with white smoke generated due to water content in black liquor. Smoke changes black when the precipitator is stopped.
4. The O₂ content in exhaust gas was 10.5% and the temperature 165°C at the economizer outlet.
5. Instruments of boilers are well serviced.

Water tube boiler

1. Measurement result of exhaust gas was as follows:
 Recuperator inlet - Temperature 360°C, O₂ - 5.5%
 Recuperator outlet - Temperature 150°C, O₂ - 9 - 11%, Bacharach No.3

O₂ content was increasing at the recuperator outlet

Name of Establishment	HACO MEXICANA, S.A.				
Type of Industry (Product)	Chemical (Fe ₂ O ₃ , FeSO ₄ , i.e.. paint materials)				
Scale of Factory	Medium	Number of Employees		142	
Annual Sales or Production	4,560,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Heavy oil (L) (192.65 pesos/l) 25,500 l/mon 46,810,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	3.8 ton/hr	Heavy oil (L)	266 l/hr	6	
Roasting furnace	Unknown	Diesel	83 l/hr	15	2 day/week
Drying furnace	Unknown	Heavy oil (L)	Drying furnace total 88 l/hr	50	
Drying furnace	Unknown	Heavy oil (L)		50	
Drying furnace	Unknown	Heavy oil (L)		50	
Drying furnace	Unknown	Heavy oil (L)		50	
Outline of the Facility Surveyed					
Smoke tube boiler 3.8 ton/hr (steam)					
Evaporation rate	: Rating : 3.8 ton/hr Normal : 2.9 ton/hr				
Steam pressure	: 5 kg/cm ² g				
Fuel consumption	: Rating : 340 l/hr Normal : 266 l/hr				
Fuel pressure	: 9 kg/hr Temperature : 120°C				
Atomizing steam pressure	: 4.2 kg/cm ² g Temperature : 120°C				
Combustion air temperature	: Normal				
Stack	: 0.6 mφ x 15 m				
Operating time	: 24 hr/day, 168 hr/week				
One boiler will be added in the near future for alternate use.					
Outline of Survey Result					
Present pollution control measures	: None				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> This is an old plant. Inside of the plant is totally yellow. The O₂ content was 10.2% and the Bacharach value No. 8, with combustion control unsatisfactory. Carbon deposit was also observed in the boiler. The exhaust gas temperature was relatively satisfactory at 251°C. As only one boiler was used for 24-hour operation, it had to be operated continuously without maintenance. As another boiler will be added in one month, operation control is said to be planned. 					

		No. 31	Date of Visit	Jun. 21, 1990	
Name of Establishment	VITRO FIBRAS, S. A.				
Type of Industry (Product)	Non-metallic mineral product (glass wool, glass fiber)				
Scale of Factory	Large	Number of Employees		671	
Annual Sales or Production	79,554,800,000 pesos/yr 950 ton/yr				
Kind of Fuel, Consumption and Price	Natural gas 1,448,000 m ³ /mon (211.19 pesos/m ³) 305,803,120 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1. Melting furnace	1.3 ton/hr	Natural gas	535.6 m ³ /hr	4	Glass wool
2. Melting furnace	0.9 ton/hr	Natural gas	495.2 m ³ /hr	5	Glass fiber
3. Melting furnace	0.7 ton/hr	Natural gas	569.1 m ³ /hr	6	Glass fiber
4. Water tube boiler	3.1 ton/hr	Natural gas	2,300 m ³ /hr	10	Alternate use by every six months
5. Water tube boiler	3.1 ton/hr	Natural gas	2,300 m ³ /hr	5	Alternate use by every six months
Outline of the Facility Surveyed	Melting furnace		0.9 ton/hr (glass)		
Rating	: 0.9 ton/hr (glass)				
Fuel consumption	: Rating : 916 m ³ /hr Normal : 450 m ³ /hr				
Temperature of object to be heated	: 1,350°C				
Fuel pressure	: 40 mmAq				
Combustion air temperature	: 730°C With recuperator				
Combustion exhaust gas composition	: O ₂ - 1.5% CO - 0.05%				
Temperature	: 1,250°C at recuperator inlet 900°C at outlet (as measured by the plant)				
Stack	: 1.68 mφ x 21 m				
Operating time	: 24 hr/day, 168 hr/week				
Outline of Survey Result					
Present pollution control measures	: Change of fuel to natural gas				
Future plan for pollution control	: None				
Present energy-saving measures	: Recuperator				
<ol style="list-style-type: none"> The melting furnace is renewed as a whole every five years because of high operating emperature at 1,500°C. Instruments and automatic control system necessary for operation of the furnace are complete. There are two stacks for the furnace. The stack on the melting room side discharges 3/4 of total exhaust gas, with temperature at 1,250°C while that on the extractor side dischargesz 1/4 with the temperature at 1,000°C. A part of waste heat is recovered for drying of units. Further utilization of waste heat is necessary. For example, waste heat may be used for a boiler. This furnace has a gap in a part of the wall. Air-tightening is necessary. 					

		No. 33	Date of Visit	Jun. 21, 1990	
Name of Establishment	VIDRIO PLANO DE MEXICO, S.A.				
Type of Industry (Product)	Non-metallic mineral products (plate glass, glass for automobile)				
Scale of Factory	Large	Number of Employees		1,480	
Annual Sales or Production	210,000,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Natural gas (211.3 pesos/m ³) 5,380,630 m ³ /mon 1,232,010,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Glass melting furnace tank oven	3.3 ton/hr Cullet 30%	Natural gas	2,050 m ³ /hr	22	6,210,000 kcal/ton
Glass melting furnace tank oven	15.8 ton/hr Cullet 30%	Natural gas	3,618 m ³ /hr	20	2,290,000 kcal/ton
Outline of the Facility Surveyed	Glass melting furnace		15.8 ton/hr (Glass)		
Capacity of facility	: 15.8 ton/hr (Glass)				
Unit consumption	: 2,290,000 kcal/ton (Glass)				
Fuel consumption	: 3,618 m ³ /hr Glass melting temperature : 1,450°C				
Fuel pressure	: 245 - 2,450 mmAq				
Combustion air pressure	: a few mmAq				
Combustion exhaust gas composition	: O ₂ - 9.39%, CO ₂ - 11.17%, H ₂ O - 7.35% (as measured by the plant)				
Combustion exhaust gas temperature	: Regenerator inlet : 1,560°C, Outlet : 521°C (as measured by the plant)				
Stack	: 3.9 mφ x 81 m				
Operating time	: 24 hr/day, 168 hr/week				
Regenerator	: 20-minute changeover (automatic) Cullet : 30%				
Outline of Survey Result					
Present pollution control measures	: Fuel changed to natural gas				
Future plan for pollution control	: None				
Present energy-saving measures	: Regenerator installed				
<p>The O₂ content was 7% because of unsatisfactory sampling position. Although control is made to prevent leak in the furnace up to the regenerator, air leak is permitted after this regenerator (about 2.9% in the regenerator). The flame was satisfactory and no smoke generated. The fuel consumption per unit product was 2.29 million kcal/ton, with cullet of around 30%.</p>					

Name of Establishment	PAPELERA IRUNA, S. A.				
Type of Industry (Product)	Paper and its product (recycled paper)				
Scale of Factory	Medium	Number of Employees		250	
Annual Sales or Production	72,000 ton/yr				
Kind of Fuel, Consumption and Price	Heavy oil (L) 913.8 kl/mon (255 pesos/l) 233,019,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1. Water tube boiler	9.4 ton/hr	Heavy oil (L)	902 l/hr	30	Not operating
2. Smoke tube boiler	7.8 ton/hr	Heavy oil (L)		17	
3. Smoke tube boiler	7.8 ton/hr	Heavy oil (L)	283 l/hr	15	
4. Smoke tube boiler	7.8 ton/hr	Heavy oil (L)	283 l/hr	12	
5. Smoke tube boiler	7.8 ton/hr	Heavy oil (L)	283 l/hr	10	

Outline of the Facility Surveyed Smoke tube boiler 7.8 ton/hr (steam)

Evaporation rate	: Rating : 7.8 ton/hr	Normal : 6.4 ton/hr
Fuel consumption	: Rating : 566 l/hr	Normal : 283 l/hr
Steam pressure	: 8 kg/cm ² g	Temperature : 170°C
Fuel pressure	: 3.5 kg/cm ² g	Temperature : 110°C
Atomizing pressure	: 1.75 kg/cm ² g	
Combustion air temperature	: Normal	
Combustion exhaust gas composition	: O ₂ - 5.5%, CO ₂ - 13.0% (as measured by the plant)	
Temperature	: 200°C (as measured by the plant)	
Stack	: 0.61 mφ x 7 m	
Operating time	: 24 hr/day, 168 hr/week	

Outline of Survey Result

Present pollution control measures	: Exhaust gas measured while making effort to improve combustion.
Future plan for pollution control	: None
Present energy-saving measures	: None

1. This boiler is compact and the control of steam pressure - air/fuel ratio is made. Atomized air is manual adjusted, and well serviced as a whole.
2. Analysis of exhaust gas is entrusted to a professional firm, but the result contained some theoretical errors.
3. The O₂ content was 9.5%, temperature 211°C, and the Bacharach value of No. 5. It was advised that the O₂ content be reduced to 4% and the atomization ratio be increased while checking the flame state.

Name of Establishment	METALURGICA ALMENA				
Type of Industry (Product)	Basic metals (copper, brass, bronze castings)				
Scale of Factory	Medium	Number of Employees		170	
Annual Sales or Production	17,616,145,000 pesos/yr				
Kind of Fuel, Consumption and Price	Natural gas 21,156,000 m ³ /mon (211.19 pesos/m ³) 4,467,935,640 pesos/mon Kerosin 6,000 kl/mon (630.00 pesos/l) 3,780,000,000 pesos/mon Electricity 10,640 kwh/mon (171.19 pesos/kwh) 1,773,528 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1. Crucible furnace	600 kg/charge	Natural gas	48,300m ³ /hr	35	
2. Electric furnace	600 kg/charge	Electricity	11 kw/hr	11	
3. Electric furnace	600 kg/charge	Electricity	11 kw/hr	11	
4. Electric furnace	600 kg/charge	Electricity	11 kw/hr	11	
5. Electric furnace	600 kg/charge	Electricity	11 kw/hr	11	
Outline of the Facility Surveyed	Crucible furnace 600 kg/charge (brass etc.)				
Rating	: 600 kg/charge Normal : 360 kg/charge				
Fuel consumption	: Normal : 48,300 m ³ /hr				
Temperature of object to be heated	: 912 - 1,100°C				
Combustion air temperature	: 500°C with recuperator				
Stack	: 0.41 mφ x 10 m				
Operating time	: 12 hr/day, 60 hr/week, 2 - 3 charge/day				
Outline of Survey Result					
Present pollution control measures	: Fuel changed to natural gas				
Future plan for pollution control	: None				
Present energy-saving measures	: Radiation type recuperator				
<p>1. Air is entering from the wide gap between the crucible furnace and hood. As a result, the exhaust gas temperature was measured to be low at 840°C. Repair of hood is necessary to enhance the efficiency of the recuperator. Measures against dust must also be taken.</p> <p>2. There is no engineer with expertise on the combustion facilities in this plant. No detailed explanation was given concerning the facilities.</p>					

		No. 36	Date of Visit	Jun. 22, 1990	
Name of Establishment	BANOS LA NARANJA				
Type of Industry (Product)	Bathhouse				
Scale of Factory	Small	Number of Employees		4	
Annual Sales or Production	73,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Diesel (478.26 pesos/l) 3,300 l/mon 1,580,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	0.8 ton/hr	Diesel	55 l/hr	15	Alternate use
Smoke tube boiler	0.8 ton/hr	Diesel	55 l/hr	25	
Hot water boiler	Unknown	Diesel		25	used as required
Hot water boiler	Unknown	Diesel		25	used as required
Hot water boiler	Unknown	Diesel		25	used as required
Hot water boiler	Unknown	Diesel		25	used as required
Outline of the Facility Surveyed	Smoke tube boiler 0.8 ton/hr (steam)				
Evaporation rate	: Rating : 0.8 ton/hr Normal : 0.6 ton/hr				
Steam pressure	: 6 kg/cm ² g				
Fuel consumption	: Rating : 70 l/hr Normal : 55 l/hr				
Fuel pressure	: 7 kg/cm ² g Temperature : Normal				
Combustion air temperature	: Normal				
Stack	: 0.3 mφ x 15 m				
Operating time	: 2 hr/day, 14 hr/week				
Outline of Survey Result					
Present pollution control measures	: Due attention paid on prevention of smoke generation				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> 1. Considerable attention is paid on smoke generation. Diesel oil is used, though quite exceptional for the bathhouse. 2. The O₂ content was 7.3% and the Bacharach value No. 0. Combustion was satisfactory and control superior, except that the O₂ content was slightly high. The exhaust gas temperature was in an average at 203°C and the boiler efficiency was satisfactory at 85%. 					

Name of Establishment	BANOS XOLALPA				
Type of Industry (Product)	Bathroom				
Scale of Factory	Small	Number of Employees			3
Annual Sales or Production					
Kind of Fuel, Consumption and Price	Heavy oil (L) (163.48 pesos/l) 11,700 l/mon 1,910,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	1.0 ton/hr	Heavy oil (L)	130 l/hr	4 4	Steam and hot water
Smoke tube boiler	0.8 ton/hr	Heavy oil (L)	130 l/hr	4 4	Spare

Outline of the Facility Surveyed Smoke tube boiler 1.0 ton/hr (steam)

Evaporation rate	: Rating : 1.0 ton/hr	Normal : 1.0 ton/hr
Steam pressure	: 5 kg/cm ² g	
Fuel consumption	: Rating : 130 l/hr	Normal : 130 l/hr
Fuel pressure	: Unknown	Temperature : 40°C
Atomizing steam pressure and temperature	: Unknown	
Combustion air pressure	: Natural draft	Temperature : normal
Stack	: 0.4 mφ x 15 m	
Operating time	: 3 hr/day, 21 hr/week	

Outline of Survey Result

Present pollution control measures	: None
Future plan for pollution control	: None
Present energy-saving measures	: None

1. The boiler is more than 40 years old and manually operated by the intuition of the operator.
2. Control was extremely poor with the O₂ content at 13.3% and the Bacharach value at No. 8, and smoke generation was observed. The exhaust gas temperature was in an average at 205°C, but the boiler efficiency was 77% because of large amount of exhaust gas.
3. Renewal of equipment is recommended.

		No. 41	Date of Visit	Jun. 25, 1990	
Name of Establishment	CEMENTOS ANAHUAC, S.A.				
Type of Industry (Product)	Non-metallic mineral product (Portland cement)				
Scale of Factory	Large	Number of Employees		755	
Annual Sales or Production	209,909,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Heavy oil (H) (152.17 pesos/l), Natural gas (211.3 pesos/m ³) Heavy oil (H) 14,580,000 l/mon, 1,690,000,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Rotary kiln	96 ton/hr	Heavy oil (H)	9,000 l/hr	19	
Rotary kiln	96 ton/hr	Heavy oil (H)	9,000 l/hr	18	
Rotary kiln	25 ton/hr	Heavy oil (H)	2,250 l/hr	20	
Drying furnace	180 ton/hr	Natural gas		15	
Drying furnace	180 ton/hr	Natural gas		15	
Drying furnace	45 ton/hr	Natural gas		20	
Heat medium boiler	1.3 ton/hr	Heavy oil (H)		15	
Heat medium boiler	1.3 ton/hr	Heavy oil (H)		15	
Hot water boiler	1.3 ton/hr	Heavy oil (H)		20	
Outline of the Facility Surveyed	Rotary kiln		96 ton/hr (cement)		
Capacity of facility	: Rating : 96 ton/hr				
Cement heating temperature	:				
Fuel consumption	: Normal : 9,000 l/hr				
Unit consumption	: 870 - 890 kcal/kg (cement)				
Fuel pressure	: 35 kg/cm ² g		Temperature : 120°C		
Combustion air pressure	: 600 - 800 mmAq		Temperature : 1,000 - 1,100°C		
Combustion exhaust gas composition	: O ₂ - 8 - 9%, CO ₂ - 18 - 20% (as measured by the plant)				
Fuel proportion between primary and secondary burners	: 90% : 10%				
Operating time	: 24 hr/day, 168 hr/week				
Outline of Survey Result					
Present pollution control measures	: Electrostatic precipitator installed				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> 1. This is the sole cement plant located in the metropolitan area of Mexico City. Though it is said that attention is paid on pollution control, dust collection is not effective. 2. As the measured result of SO₂ content in summer of 1989 was said to be relatively low, fuel was changed from heavy oil (L) to heavy oil (H) under consent of SEDUE. The heavy oil preheating temperature was 135 - 140°C. The unit fuel consumption was 8.7 million kcal/kg of clinker which is higher than that in Japan by 1.0 - 1.3 million kcal/kg. 3. The instrument installed in site indicated 5.5% for O₂ and 0.05% for CO at the rear of the kiln. 					

Name of Establishment	PAPELERA ATLAS				
Type of Industry (Product)	Paper and its product (Recycled paper)				
Scale of Factory	Medium	Number of Employees	200		
Annual Sales or Production	14,400,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Heavy oil (H) (163.48 pesos/l) 480,000 l/mon 78,470,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Water tube boiler	9.6 ton/hr	Heavy oil (H)	400 l/hr	19	
Smoke tube boiler	6.4 ton/hr	Heavy oil (H)	270 l/hr	6	
Smoke tube boiler	2.4 ton/hr	Heavy oil (H)		5	Spare

Outline of the Facility Surveyed	Water tube boiler		9.6 ton/hr (steam)		
Evaporation rate	: Rating: 9.6 ton/hr	Normal : 5.0 ton/hr			
Steam pressure	: 5 - 6 kg/cm ²				
Fuel consumption	: Normal : 400 l/hr				
Fuel pressure	: 4.7 kg/cm ² g	Temperature : 108°C			
Atomizing steam pressure	: 4.8 kg/cm ² g				
Temperature	: Saturated steam temperature				
Combustion air temperature	: Normal				
Combustion exhaust gas temperature	: 275°C (as measured by the plant)				
Stack	: 1 mφ x 10 m				
Operating time	: 24 hr/day, 168 hr/week				

Outline of Survey Result

Present pollution control measures	: None
Future plan for pollution control	: None
Present energy-saving measures	: None

1. This plant produces corrugated fiber board paper from used paper and cellulose and uses the boiler for drying. The stack is provided with a sampling port.
2. The exhaust gas O₂ content was relatively satisfactory at 3.9 - 4.0%. But the Bacharach value was high at No. 9 because of the use of heavy oil (H). The exhaust gas temperature was 268°C and the boiler efficiency 84%

Name of Establishment	BANOS LUPITA				
Type of Industry (Product)	Bathhouse				
Scale of Factory	Small	Number of Employees		5	
Annual Sales or Production	200,750,000 pesos/yr				
Kind of Fuel, Consumption and Price	Heavy oil (L) (175.65 pesos/l) 15,000 l/mon 3,320,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	0.6 ton/hr	Heavy oil (L)	83 l/hr	25	Alternate use
Smoke tube boiler	0.5 ton/hr	Heavy oil (L)	83 l/hr	25	

Outline of the Facility Surveyed	Smoke tube boiler		0.6 ton/hr (steam)		
Evaporation rate	: Rating : 0.6 ton/hr	Steam pressure : 6 kg/cm ² g			
Fuel consumption	: Normal : 83 l/hr				
Fuel pressure	: Unknown	Temperature : 55°C			
Atomizing steam pressure and temperature	: Unknown				
Combustion air pressure	: Natural draft	Temperature : normal			
Stack	: 0.25 mφ x 15 m				
Operating time	: 6 hr/day, 42 hr/week				

Outline of Survey Result	
Present pollution control measures	: None
Future plan for pollution control	: None
Present energy-saving measures	: None

1. Two units of natural draft boiler (25 years old) are operated alternately.
2. The exhaust gas O₂ content was 10.3%, indicating excess air intake. The Bacharach value was No. 9, with thin smoke observed from the stack. The exhaust gas temperature was 233°C and the boiler efficiency 80%.
3. The facility is old as a whole and equipment renewal is advisable.

Name of Establishment	CIA, HULERA TORNEL				
Type of Industry (Product)	Rubber and plastic product (tire, tube)				
Scale of Factory	Large	Number of Employees	475		
Annual Sales or Production	Capital: 54,967,000,000 pesos				
Kind of Fuel, Consumption and Price	Diesel (478.026 pesos/l) 182,000 l/mon 87,000,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	2.6 ton/hr	Diesel	180 l/hr	9	
Smoke tube boiler	1.6 ton/hr	Diesel	112 l/hr	10	
Smoke tube boiler	1.3 ton/hr	Diesel		19	Not operating
Smoke tube boiler	0.8 ton/hr	Diesel		22	Not operating
Heat medium boiler	5,040 kcal/hr	Diesel			Intermittent operation

Outline of the Facility Surveyed	Smoke tube boiler		2.6 ton/hr (steam)		
Evaporation rate	: Rating : 2.6 ton/hr	Normal : 2.1 ton/hr			
Steam temperature	: 160°C				
Fuel consumption	: Rating : 221 l/hr	Normal : 180 l/hr			
Fuel pressure	: 1.8 kg/cm ² g	Temperature : normal			
Atomizing air pressure	: 0.7 kg/cm ² g	Temperature : normal			
Combustion air temperature	: Normal				
Combustion exhaust gas temperature	: 200°C (as measured by the plant)				
Stack	: 0.41 mφ x 9.6 m				
Operating time	: 24 hr/day, 144 hr/week				

Outline of Survey Result	
Present pollution control measures	: None
Future plan for pollution control	: None
Present energy-saving measures	: None

- Boiler steam is used for heating during molding of rubber tire. Odor producing ingredients of rubber is evaporated and the plant is filled with odor.
- The exhaust gas O₂ content was 6.5% and air was in excess for the use of diesel oil. The Bacharach value was Nos. 1 - 2, without soot generation. The exhaust gas temperature was low at 175°C, with the boiler efficiency satisfactory at 87%.

		No. 47	Date of Visit	Jun. 26, 1990		
Name of Establishment	CERVECERIA MODELO, S.A. DE C.V.					
Type of Industry (Product)	Drinks (beer)					
Scale of Factory	Large	Number of Employees		6,500		
Annual Sales or Production	Capital : 111,817,563,000 pesos					
Kind of Fuel, Consumption and Price	Heavy oil (H) (175.6 pesos/l), 4,700,000 l/mon Natural gas (211.3 pesos/m ³) 4,500,000 m ³ /mon					
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks	
Water tube boiler	100 ton/hr	Heavy oil (H)	3,333 l/hr	30	Two of three units in operation	
Water tube boiler	63 ton/hr	Mixed burning of heavy oil (H) and natural gas	6,250 m ³ /hr	16		
Water tube boiler	27 ton/hr			36	Not operating	
Water tube boiler	82 ton/hr					
Outline of the Facility Surveyed Water tube boiler for power generation 100 ton/hr (steam)						
Evaporation rate	: Rating : 100 ton/hr Normal : 70 ton/hr					
Steam pressure	: 30 kg/cm ² g					
Fuel consumption	: Rating : 10,000 m ³ /hr Normal : 6,000 m ³ /hr					
Fuel pressure	: 0.8 kg/cm ² g					
Combustion air	: Pressure: 340 mmAq Temperature : 180°C					
Stack	: 4.1 mφ x 75 m					
Operating time	: 24 hr/day, 168 hr/week					
* Only natural gas was burnt on the day of the visit.						
* The steam used for power generation is supplied to production processes.						
* A new boiler is under construction.						
Outline of Survey Result						
Present pollution control measures	: None					
Future plan for pollution control	: None					
Present energy-saving measures	: Recuperator installed					
<ol style="list-style-type: none"> 1. This is the largest company specialized in beer production in Mexico. The boiler is used for independent power generation, with remaining steam used for brewery. Mixture of heavy oil and natural gas is usually burnt. But, at the time of the measurement of exhaust gas, only natural gas was burnt. 2. The exhaust gas O₂ content was 2.5% and air-fuel ratio satisfactory. The burner combustion state was good. 3. The Bacharach value was Nos. 2 to 3, slightly high for gas burning. The exhaust gas temperature was 320°C at the inlet of the air preheater and the temperature at the outlet is estimated at 140°C. 						

Name of Establishment	BANOS TACUBA				
Type of Industry (Product)	Bathhouse				
Scale of Factory	Small	Number of Employees		10	
Annual Sales or Production	5,400,000,000 pesos/yr				
Kind of Fuel, Consumption and Price	Heavy oil (L) (175.65 pesos/l) 18,000 l/mon 3,160,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	0.6 ton/hr	Heavy oil (L)	43 l/hr	30	Selected depending on the situation
Smoke tube boiler	0.3 ton/hr	Heavy oil (L)	27 l/hr	30	
Outline of the Facility Surveyed					
Smoke tube boiler 0.6 ton/hr (steam)					
Evaporation rate	: Rating : 0.6 ton/hr	Normal : 0.5 ton/hr			
Steam pressure	: 3 kg/cm ² g				
Fuel consumption	: Rating : 54 l/hr	Normal : 43 l/hr			
Fuel temperature	: Unknown				
Atomizing steam pressure and temperature	: Unknown				
Combustion air pressure	: Natural draft	Temperature : Normal			
Stack	: 0.3 mφ x 18 m				
Operating time	: 14 hr/day, 98 hr/week				
Outline of Survey Result					
Present pollution control measures	: None				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> The boiler is 30 years old. The exhaust gas O₂ content was 7.0 - 9.5%, indicating excess air combustion. The Bacharach value was No. 9 with considerable soot generation. The exhaust gas temperature was relatively low at 214°C and the boiler efficiency 84%. 					

Name of Establishment	CARTONAJES ESTRELLA				
Type of Industry (Product)	Paper and its product (carton)				
Scale of Factory	Large	Number of Employees			1,050
Annual Sales or Production	20,000,000,000 pesos/yr 99,000 ton/yr				
Kind of Fuel, Consumption and Price	Natural gas 3,500,000 m ³ /mon (211 pesos/m ³) 738,500,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1. Water tube boiler	35 ton/hr	Natural gas	Not operating	17	Superheater
2. Water tube boiler	60 ton/hr	Natural gas	Not operating	12	Superheater
3. Water tube boiler	112 ton/hr	Natural gas	8,500 m ³ /hr	9	Superheater

Outline of the Facility Surveyed	Water tube boiler		112 ton/hr (steam)		
Evaporation rate	: Rating : 112 ton/hr	Normal : 60 ton/hr			
Fuel consumption	: Rating : 8,500 m ³ /hr	Normal : 4,300 m ³ /hr			
Steam pressure	: 42 kg/cm ²	Temperature : 450°C			
Fuel pressure	: 1.0kg/cm ²				
Combustion air temperature	: Normal				
Stack	: 1.3 mφ x 24.5 m				
Operating time	: 24 hr/day, 168 hr/week				

Outline of Survey Result	
Present pollution control measures	: Fuel changed to natural gas
Future plan for pollution control	: None
Present energy-saving measures	:

1. The exhaust gas at the boiler outlet showed the O₂ content of 2.4% and temperature of 249°C, indicating satisfactory combustion state. Note that the operation was at 50% of the rating.
2. It is recommended to change the scale of instruments indicating the operation state from percent to actual value.
3. Efficiency may be higher when a 60 ton/hr boiler is operated at rating than when a 112 ton/hr boiler is operated at 50% of the rating.
4. The plant was kept tidy and in good order and engineers seemed eager to improve the combustion state.

		No. 50	Date of Visit	Jun.27, 1990	
Name of Establishment	FUNDIDORA Y LAMINADORA ANAHUAC				
Type of Industry (Product)	Basic metals (angle steel, channel steel)				
Scale of Factory	Medium	Number of Employees		110	
Annual Sales or Production	19,230 ton/yr				
Kind of Fuel, Consumption and Price	Natural gas 174,668 m ³ /mon (211.3 pesos/m ³) 3,690,703 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Heating furnace	10 ton/hr	Natural gas	539 m ³ /hr	30	
Outline of the Facility Surveyed					
	Heating furnace		10 ton/hr (billet)		
Rating	: 10 ton/hr	Normal : 8 ton/hr			
Fuel consumption	: Normal : 539 m ³ /hr				
Temperature of object to be heated	: 1,100°C				
Fuel pressure	: 4 kg/cm ²				
Combustion air temperature	: Normal				
Stack	: 0.5 m x 2.55 m x 3.5 m				
Operating time	: 13 hr/day, 76 hr/week				
Outline of Survey Result					
Present pollution control measures	: Fuel changed to natural gas				
Future plan for pollution control	: Energy saving through furnace improvement				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> 1. Billets of 127 x 127 x 2,400 mm are heated to 1,050 to 1,100°C. The fuel consumption per unit product is around 43,000 kcal/ton and the heating rate in hearth 439 kg/m²h. 2. As the natural gas is used, the combustion state is satisfactory. But the furnace outlet temperature is as high as 750°C, and installation of a recuperator is recommended. 3. There is a plan in future to save energy through furnace reconstruction, to improve environment in line with energy saving, and automation of current manual rolling process. 					

		No. 52	Date of Visit	Jun. 27, 1990	
Name of Establishment	BANOS SANTIAGO				
Type of Industry (Product)	Bathhouse				
Scale of Factory	Small	Number of Employees		6	
Annual Sales or Production					
Kind of Fuel, Consumption and Price	Heavy oil (L) (175.65 pesos/l) 21,400 l/mon 4,740,000 pesos/mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Smoke tube boiler	1.3 ton/hr	Heavy oil (L)	71 l/hr	22	Alternate use
Smoke tube boiler	1.3 ton/hr	Heavy oil (L)	71 l/hr	22	
Outline of the Facility Surveyed					
		Smoke tube boiler	1.3 ton/hr (steam)		
Evaporation rate	: Rating : 1.3 ton/hr	Normal : 0.9 ton/hr			
Steam pressure	: 6 kg/cm ² g				
Fuel consumption	: Rating : 110 l/hr	Normal : 71 l/hr			
Fuel pressure	: Unknown	Temperature : 45 - 50°C			
Combustion air pressure	: Natural draft	Temperature : normal			
Stack	: 0.3 mφ x 12 m				
Operating time	: 10 hr/day, 70 hr/week				
Outline of Survey Result					
Present pollution control measures	: None				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> Two 22-year old boilers are installed on the second floor of the bathhouse and used alternately. The exhaust gas O₂ content was 10.4%, indicating excess air combustion. The Bacharach value was also high at No. 9, with considerable soot generation. The exhaust gas temperature was relatively high at 289°C, and the boiler efficiency was not satisfactory at 76%. Because the boilers are very old, their renewal is recommended. 					

Name of Establishment	INDUSTRIAS NYLBO, S.A. DE C.V.				
Type of Industry (Product)	Metal product (bar steel, angle steel)				
Scale of Factory	Medium	Number of Employees		185	
Annual Sales or Production	25,000,000,000 pesos/yr		36,000 ton/yr		
Kind of Fuel, Consumption and Price	Natural gas 589,452 m ³		(211.3 pesos/m ³)		124,551,207 pesos/mon
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1. Heating furnace	10 ton/hr	Natural gas	634 m ³ /hr	45	
2. Heating furnace	8 ton/hr	Natural gas	634 m ³ /hr	45	
3. Electric furnace	25 ton/charge	Electricity	7,500 kwh/charge		
Outline of the Facility Surveyed					
Heating furnace 10 ton/hr (billet)					
Rating	: Rating : 10 ton/hr		Normal : 6 ton/hr		
Fuel consumption	: Normal : 634 m ³ /hr				
Temperature of object to be heated	: 1,200°C				
Combustion air temperature	: Normal				
Stack	: 0.6 m x 0.6 m x 2.0 m				
Operating time	: 15.5 hr/day, 93 hr/week				
Outline of Survey Result					
Present pollution control measures	: Fuel changed to natural gas				
Future plan for pollution control	: Improvement of fuel consumption per unit product				
Present energy-saving measures	: None				
<ol style="list-style-type: none"> 1. Billets of 75 x 75 x 2,000 mm are heated to 1,100 - 1,170°C. Natural gas consumption per unit product is planned to be improved from present 80 m³/ton to 40 m³/ton. 2. The furnace is the inclined type, with opening at billet extraction port and furnace wall, thereby causing drop of the inside temperature. Automation of discharge (currently executed manually) is recommended while repairing openings and increasing the size of billet. As the exhaust gas temperature is high (740°C), the use of recuperator should be considered. 3. Since this plant has a Japanese-made continuous casting equipment, continuous operation from casting to rolling is possible. 					

No. 57-2	Date of Visit	Jun.29, 1990
----------	---------------	--------------

Name of Establishment	REFINERIA 18 DE MARZO				
Type of Industry (Product)	Petroleum refinery				
Scale of Factory	Large	Number of Employees			
Annual Sales or Production					
Kind of Fuel, Consumption and Price	Natural gas				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Heating furnace	117 ton/hr	Natural gas	4,270 m ³ /hr	50	AA-F1,2
Heating furnace	59 ton/hr	Natural gas	2,140 m ³ /hr	50	AA-F3
Heating furnace	45 ton/hr	Natural gas	1,600 m ³ /hr	50	AR-H7,8,9
Heating furnace	4.3 ton/hr	Natural gas	140 m ³ /hr	50	AF-H1,2
Heating furnace	12 ton/hr	Natural gas	400 m ³ /hr	50	RV-H1,2
Heating furnace	14 ton/hr	Natural gas	470 m ³ /hr	50	AW-H1
Heating furnace	49 ton/hr	Natural gas	810 m ³ /hr	50	RE-H9
Heating furnace	29 ton/hr	Natural gas	270 m ³ /hr	50	RE-H10
Heating furnace	31 ton/hr	Natural gas	810 m ³ /hr	50	AR-H1
Heating furnace	19ton/hr	Natural gas	780 m ³ /hr	50	AU-H1
Heating furnace	50 ton/hr	Natural gas	4,050 m ³ /hr	50	AI-H1
Heating furnace	10ton/hr	Natural gas	250 m ³ /hr	50	AQ-H1

Outline of the Facility Surveyed

The fuel consumption of the plant as a whole is large. Diagnostic survey is necessary on boilers and heating furnaces of the plant.

Outline of Survey Result

- Present pollution control measures :
- Future plan for pollution control :
- Present energy-saving measures :

Name of Establishment	ANDERSON CLAYTON, S.A.				
Type of Industry (Product)	Food (dressing, peanut butter, jelly, cake mix)				
Scale of Factory	Large	Number of Employees		450	
Annual Sales or Production	Capital : 585,000,000 pesos				
Kind of Fuel, Consumption and Price	L.P.G. (180.36 pesos/l),	4,000 l/mon	721,440 pesos/mon		
	Diesel (408.67 pesos/l),	11,000 l/mon	4,495,370 pesos/mon		
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Water tube boiler	0.9 ton/hr	Diesel	27 l/hr	10	Alternate use
Water tube boiler	0.4 ton/hr	Diesel	27 l/hr	9	
Drying oven	400 kg/hr	L.P.G.	7 l/hr	10	
Drying oven	450 kg/hr	L.P.G.	8 l/hr	10	

Outline of the Facility Surveyed	Water tube boiler	0.9 ton/hr (steam)
Evaporation rate	: Rating : 0.9 ton/hr	Normal : 0.4 ton/hr
Steam pressure	: 7 kg/cm ² g	
Fuel consumption	: Rating : 80 l/hr	Normal : 27 l/hr
Fuel pressure	: 7 kg/cm ² g	Temperature : normal
Combustion air temperature	: Normal	
Exhaust gas temperature	: 201°C (as measured by the plant)	
Stack	: 0.3 mφ x 8 m	
Operating time	: 12 hr/day, 63 hr/week	

Outline of Survey Result	
Present pollution control measures	: Use of diesel oil and L.P.G.
Future plan for pollution control	: None
Present energy-saving measures	: None

1. This water tube boiler is rare for small size. The exhaust gas O₂ content was 8.0 - 8.7%, indicating excess air combustion. The Bacharach value was No. 0 - 1, without soot generation. The exhaust gas temperature was high at 370°C and the boiler efficiency was low at 74%. It is recommended to reduce the exhaust gas O₂ content to 3 - 4%. Then, the efficiency may rise to around 80%.

		No. 60	Date of Visit	July 29, 1990	
Name of Establishment	FUNDIDORA DE ACEROS TEPEYAC.				
Type of Industry (Product)	Basic Metals (Cast iron)				
Scale of Factory	Large	Number of Employees		815	
Annual Sales or Production	4,800 ton/yr				
Kind of Fuel, Consumption and Price	Natural gas	86,560 m ³ /mon	(211.304 pesos/m ³)	18,290,474 pesos/mon	
	Electricity	1,506,000 kwh/mon	(165.50 pesos/kwh)	249,243,000 pesos/mon	
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1 Electric furnace	2.5 ton/charge	Electricity	500 kw/h	25	
2 Electric furnace	6.0 ton/charge	Electricity	500 kw/h	30	
3 Electric furnace	3.5 ton/charge	Electricity	500 kw/h	35	
4 Electric furnace	6.0 ton/charge	Electricity	500 kw/h	20	
5 Electric furnace	2.5 ton/charge	Electricity	500 kw/h	15	
6 Electric furnace	6.5 ton/charge	Electricity	500 kw/h	8	
7 Annealing furnace	40 ton/charge	Natural gas	459.7m ³ /hr		
8 Annealing furnace	20 ton/charge	Natural gas	554.5m ³ /hr		
9 Annealing furnace	4 ton/charge	Natural gas	173.5m ³ /hr		
There are 16 units of annealing furnace in addition to above.					
Outline of the Facility Surveyed	Annealing furnace		40 ton/charge		
Capacity	: Normal : 40 ton/charge				
Fuel consumption	: 459.7 m ³ /hr				
Temperature of object to be heated	: 1,200°C				
Combustion air temperature	: Normal				
Operating time	: 20 hr/day				
Outline of Survey Result					
Present pollution control measures	: Fuel changed to natural gas, use of bag filter				
Future plan for pollution control	: None				
Present energy-saving measures	: None				
1. There are six small electric furnaces (2.5 - 6.5 ton/charge) and 19 annealing furnaces (4 - 40 ton/charge) in this plant.					
2. Due to secular change, the annealing furnace has gaps. These must be repaired and utilization of high-temperature exhaust gas should be pushed forward.					
3. For NOx problem, the low NOx burner may be an economical solution.					

Name of Establishment	FORD MOTOR COMPANY				
Type of Industry (Product)	Transportation equipment (Vehicle engine, car body assembly)				
Scale of Factory	Large	Number of Employees			4,175
Annual Sales or Production	65,000 units/yr				
Kind of Fuel, Consumption and Price	Natural gas 292,000 m ³ /mon				
Type of Combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
1 Drying furnace	0.6 - 3.2 ton/hr	Natural gas	50 - 60 m ³ /hr	10	3 units
2 Hot water boiler	1 - 3.5 ton/hr	Natural gas	16 - 88 m ³ /hr	26	13 units
3. Air heater		Natural gas	80 m ³ /hr	10	1 unit
4 Electric furnace	8 ton/hr	Electricity	600 kw/hr	26	4 units
5 Annealing furnace		Natural gas		26	1 unit
Outline of the Facility Surveyed					
	Drying furnace		1.5 ton/hr (mold)		
Normal	: 1.5 ton/hr (mold)				
Fuel consumption	: Normal: 60 m ³ /hr				
Temperature of object to be heated	: 260°C				
Combustion air temperature	: Normal				
Combustion exhaust gas composition	: O ₂ - 14%, CO ₂ - 0.4%, CO - 0.0013% (as measured by the plant)				
Temperature	: 130°C (as measured by the plant)				
Operating time	: 16 hr/day, 80 hr/week				
Outline of Survey Result					
Present pollution control measures	: Transfer to natural gas				
Future plan for pollution control	: None in particular				
Present energy-saving measures	: None in particular				
<ol style="list-style-type: none"> The foundry is well maintained. About 66 kl of organic solvent is discharged annually into atmosphere during painting of the car body. For the NO_x problem, the low NO_x burner may be an economical solution. It is said that the bag filter with 99.5% efficiency is installed to collect dust generated during production of castings. 					

Name of Establishment	INDUSTRIAS UNIDAS, S.A.				
Type of Industry (Product)	Non-metallic mineral product (ceramics, wireless telephone, electric parts)				
Scale of Factory	Large	Number of Employees			1,600
Annual Sales or Production	Capital: 398,403,200,000 pesos				
Kind of Fuel, Consumption and Price	Natural gas (211.3 pesos/m ³) 380,000 m ³ /mon 80,300,000 pesos/mon				
Type of combustion Facility	Capacity	Kind of Fuel	Fuel consumption	Age	Remarks
Electric furnace	0.25 ton/h	-		39	Melting
Electric furnace	0.25 ton/hr	-		25	Hardining
Hardening kiln	0.50 ton/hr	Natural gas		25	Pipe
Tunnel kiln	0.33 ton/hr	Natural gas	132 m ³ /hr	35	Ceramic
Tunnel kiln	0.33 ton/hr	Natural gas	132 m ³ /hr	40	Ceramic
Tunnel kiln	0.17 ton/hr	Natural gas	70 m ³ /hr	45	Ceramic

Outline of the Facility Surveyed	Hardening tunnel kiln	0.33 ton/hr (ceramic)
Capacity of facility	: 0.33 ton/hr	
Heating temperature	: 1,270°C	
Fuel consumption	: 132 m ³ /hr	
Combustion air temperature	: Normal	
Combustion exhaust gas composition	: O ₂ - 10%, CO ₂ - 11% (as measured by the plant)	
Exhaust gas temperature	: 200 - 300°C (as measured by the plant)	
Operating time	: 24 hr/day, 144 hr/week	
* There are other combustion facilities in addition to above, but a sufficient information was not provided by the plant.		

Outline of Survey Result	
Present pollution control measures	: Natural gas used
Future plan for pollution control	: None
Present energy-saving measures	: None

This company produces insulator for power transmission lines and wireless telephone sets and belongs to the IUSA group. The plant within the Mexico City area is moving to the industrial complex (outside the survey area). The existing insulator baking furnace (tunnel kiln) remains in this plant in the Mexico City area, but we were refused to visit and to measure exhaust gas.