

KINGDOM OF THAILAND

FEASIBILITY STUDY
ON
LAM TA KHONG PUMPED STORAGE
DEVELOPMENT PROJECT

FINAL REPORT
SUMMARY

NOVEMBER, 1991

JAPAN INTERNATIONAL COOPERATION AGENCY

M	P	N
J		R
91 - 117		

KINGDOM OF THAILAND

**FEASIBILITY STUDY
ON
LAM TA KHONG PUMPED STORAGE
DEVELOPMENT PROJECT**

**FINAL REPORT
SUMMARY**

JICA LIBRARY



1094317(3)


23070

NOVEMBER, 1991

JAPAN INTERNATIONAL COOPERATION AGENCY

国際協力事業団



23070



LAM TA KHONG PUMPED STORAGE PROJECT



LAM TA KHONG PUMPED STORAGE PROJECT




LEGEND

- International boundary
- Railway
- Main road

0 100 200 km

LAM TA KHONG
PUMPED STORAGE PROJECT

KEY AND LOCATION MAP



LAM TA KHONG
PUMPED STORAGE PROJECT
DETAIL LOCATION MAP

Photo-1 Upper Reservoir Site (View from West)




Photo-2 Tailrace Site




Photo-3 Route of Waterway (View from Upper Reservoir)



Photo-4 Route of Waterway (View from Tailrace Site)



CONTENTS

	<u>Page</u>
1. INTRODUCTION	1
2. CONCLUSIONS AND RECOMMENDATIONS	8
3. LOAD FORECAST	12
4. POWER DEVELOPMENT PLAN	17
5. HYDROLOGY	22
6. GEOLOGY, CONSTRUCTION MATERIALS AND SEISMICITY	28
7. ENVIRONMENTAL IMPACT	36
8. DEVELOPMENT PLAN	39
9. POWER TRANSMISSION PLAN AND POWER SYSTEM ANALYSIS	49
10. PRELIMINARY DESIGN	54
11. CONSTRUCTION PLANNING AND COST ESTIMATE	67
12. ECONOMIC EVALUATION AND FINANCIAL ANALYSIS	77

UNITS AND GLOSSARIES

(1) Units

mm	:	Millimeter
cm	:	Centimeter
m	:	Meter
km	:	Kilometer
cm ²	:	Square centimeter
m ²	:	Square meter
km ²	:	Square kilometer
m ³	:	Cubic meter
MCM	:	Million cubic meter (for development planning)
kg	:	Kilogram
t	:	Metric ton
m ³ /s	:	Cubic meter per second
kW	:	Kilowatt
kWh	:	Kilowatt hour
MW	:	Megawatt
GWh	:	Gigawatt hour
kV	:	Kilovolt
kVA	:	Kilovolt-Ampere
MVA	:	Megavolt-Ampere
MCM	:	Thousands of circular mils (for transmission line)
rpm	:	Revolutions per minutes
Hz	:	Hertz (cycles per second)
El.	:	Elevation
°C	:	Degree in centigrade
mb	:	Millibar
%	:	Percentage
Lu	:	Lugeon value (rate of water loss from a drillhole)
ℓ	:	Liter
1 MW	:	1,000 kW
1 GWh	:	1,000,000 kWh
1 barrel	:	159 ℓ
1 rai	:	1,600 m ²
gal	:	cm/sec ² (acceleration of earthquake motion)
kine	:	cm/sec

(2) Glossaries

(i) Terms

NIWL	:	Normal High Water Level
LWL	:	Low Water Level
TWL	:	Tail Water Level
US\$:	U.S. dollar
฿	:	Baht
MB	:	Million Baht
hrs	:	Hours
yr	:	Year
ea.	:	Each
Max.	:	Maximum
Min.	:	Minimum
cct	:	Circuit
a.c.	:	Alternative current
ACSR	:	Aluminum Conductor Steel Reinforced
ASTM	:	American Standard for Testing and Materials
CA	:	Catchment Area
FY	:	Fiscal Year
GDP	:	Gross Domestic Product
M _B	:	Body Wave Magnitude
M _S	:	Surface Wave Magnitude
IRR	:	Internal Rate of Return
EDR	:	Equalizing Discount Rate
PAX	:	Private Automatic Exchanger
PMF	:	Probable Maximum Flood
PMP	:	Probable Maximum Precipitation
UHF	:	Ultra High Frequency
VHF	:	Very High Frequency
B-C	:	Net Present Value of Surplus Benefit
B/C	:	Benefit Cost Ratio

(ii) Agencies

AIT : Asian Institute of Technology
EGAT : Electricity Generating Authority of Thailand
EPDC : Electric Power Development Co., Ltd.
JICA : Japan International Cooperation Agency
Lao PDR : Lao People Democratic Republic
MEA : Metropolitan Electricity Authority
NEA : National Energy Administration
NEPO : National Energy Policy Office
NESDB : National Economic and Social Development Board
NIDA : National Institute of Development Administration
OPEC : Organization of Petroleum Exporting Countries
PEA : Provincial Electricity Authority
RID : Royal Irrigation Department
TDRI : Thailand Development Research Institute
IBRD : International Bank for Reconstruction and
Development

List of Tables

Table 1-1	General Project Description of Lam Ta Khong Pumped Storage Project
Table 3-1	Power Demand Forecast in Thailand
Table 3-2	Forecast of Energy Consumption in Thailand
Table 3-3	Load Forecast by Thai Organization
Table 4-1	Power Development Plan in Thailand (EGAT's PDP 90-03)
Table 5-1	Climatological Data for the Period 1956-1985
Table 5-2	Estimated Inflow at Lam Ta Khong Dam
Table 6-1	Stratigraphy and Properties of Rocks in Project Area
Table 8-1	Comparison of Development Methods
Table 8-2	Description of Adopted Development Plan
Table 11-1	Project Cost of Development Plan
Table 11-2	Economic Cost of Development Plan
Table 11-3	Annual Expenditure
Table 12-1	Cost Flow and Benefit Flow of the Adopted Development Plan
Table 12-2	Sensitivity Analysis (1,000 MW Pumping, 1,000 MW Generating)
Table 12-3	Cost Flow and Flow of Revenue of Adopted Development Plan
Table 12-4	Repayment Schedule of Debt
Table 12-5	Statement of Profit and Loss
Table 12-6	Cash Flow
Table 12-7	Calculation of Debt Service Ratio

List of Figures

- Fig. 5-1 Location of Rainfall Station and Gauging Station
- Fig. 5-2 Inflow, Water Level and Rainfall of Lam Ta Khong Dam
- Fig. 7-1 Watershed Classification in Project Area
- Fig. 8-1 Development Cases of 1000 MW
- Fig. 8-2 Position of Lam Ta Khong Power Plant in Load Duration Curve
- Fig. 9-1 Power Flow Diagram 1997 Peak
- Fig. 9-2 Power Flow Diagram 1997 Night
- Fig. 11-1 Construction Schedule of Lam Ta Khong Project
- Fig. 12-1 Sensitivity Analysis on Installation of Units 3 and 4
- Fig. 12-2 Sensitivity Analysis (Construction Cost)

List of Drawings

DWG. 6-1	Geologic Plan of Project Area
DWG. 6-2	Geologic Profile of Waterway
DWG. 7-1	Watershed Classification in Project Area
DWG. 8-1	General Plan (Case-1)
DWG. 8-2	General Plan (Case-2)
DWG. 8-3	General Plan (Case-3,4) (Case-4; Adopted)
DWG. 10-1	General Plan
DWG. 10-2	Water Way Profile and Section
DWG. 10-3	Powerhouse Section
DWG. 10-4	Switchyard Plan and Section
DWG. 10-5	Watershed Classification in Project Area
DWG. 10-6	Powerhouse Bird's-Eye View

1. INTRODUCTION

This report concerns the feasibility study of the Lam Ta Khong Pumped Storage Development Project. The feasibility study has been conducted from 1990 to 1991 by the Japan International Cooperation Agency (JICA) under a technical cooperation program of the Government of Japan.

(1) Background of the Project

Thailand's economic growth rate in 1989 was marked at 11%, being prominent among Asian developing nations. Particularly, the growth of its industrial sector was significant.

The installed capacity of electric power generating facilities in Thailand was 8,314 MW in 1989. Composition of power sources consisted of 2,271 MW in hydro plants (27.3%) and 6,043 MW in thermal plants (72.7%).

The rates of average annual increase of EGAT's power and energy generation for the five years from 1986 to 1990 were 12.9% and 13.2% respectively. The rates increased in 1990 by 13.8% and 18.5% respectively. The rates of increase of future demand will decrease gradually to be 7.6% and 8.3% in 1995, and 6.2% and 7.2% in 2000. After 1995, the annual increase of demand is considered to be about 900 MW and about 6,100 GWh respectively. Therefore, new power plants having a capacity of 900 MW should be implemented every year.

The Thai Government has a policy of utilizing indigenous energy sources such as natural gas, lignite, hydropower, etc., while suppressing the increase of oil importation as much as possible.

Under such circumstances, keen attention has been focussed recently on the Lam Ta Khong Pumped Storage Project which is close to Bangkok metropolitan area, the biggest demand area of electricity in Thailand.

In order to cope with the high growth of electricity demand, especially peak demand, a feasibility study on the Lam Ta Khong Pumped Storage Project was requested to the Japanese Government by the Thai Government in 1988.

(2) Outline of the Project

The Lam Ta Khong Pumped Storage Project is to be carried out on the Lam Ta Khong River, a tributary of the Mun River of the Mekong River system, 200 km northeast of the capital Bangkok.

The project features are shown on the table "General Project Description on Lam Ta Khong Pumped Storage Project".

(3) Provision of Equipments

To promote the study of the Project the following equipments were provided to the EGAT, and the EGAT carried out the investigation works listed below.

Equipments Provided and Investigation Works

Equipments	Investigation Works
FRP Boat (MODEL W-198F) and Accessories Depth Recorder (MODEL RS-61S)	Sounding survey in the Lam Ta Khong reservoir
Rotary Boring Machine (MODEL YBM-3JES) and Accessories	Drilling at upper pondage, waterway and powerhouse site

(4) Technology Transfer to the Counterparts

The technology transfer to the counterparts from the EGAT was done during the study period as follows:

- Counterpart Mr. Prakit Pooviboonsuk
(December 2, 1990 - February 7, 1991)

 Mr. Pote Angwatanapanich
(October 7, 1991 - December 4, 1991: Scheduled)

 Mr. Suvit Kritdum
(October 7, 1991 - December 4, 1991: Scheduled)

- Schedule

- . Technology transfer and discussions on the feasibility-grade design of the Project
- . Inspections at factories of turbines and generators
- . Inspections at pumped storage power stations under construction or in operation

Table 1-1 General Project Description of Lam Ta Khong Pumped Storage Project (1/4)

Project Name		Lam Ta Khong Pumped Storage		
		Upper Reservoir	Lower Reservoir	
1.	LOCATION			Lam Ta Khong River Tributary of Mun River
		District, Pak Chong Sikhiu	District, Pak Chong Sikhiu	
		Province: Nakhon Ratchashima	Province: Nakhon Ratchashima	
2.	PURPOSE	Power Generation	Multi purpose (Existing)	
3.	HYDROLOGY			
	Catchment Area	km ²	0.4	1,430
	Period of Runoff Analysis	yrs.	-	28
	Average Annual Inflow	MCM	-	261
	Design Flood	m ³ /sec	-	2,130
4.	RESERVOIR			
	Normal High Water Level (NHHL)	m.MSL.	660.0	277.0
	Low Water Level	m.MSL.	620.0	261.0
	Total Storage Capacity	MCM	10.3	310
	Effective Storage Capacity	MCM	9.9	290
	Surface Area at NHHL	km ²	0.3	44
5.	DAM			
	Type		Rockfill Dam with Asphalt Facing	Homogeneous Earth-fill Dam
	Dam Height	m	60	40.3
	Crest Elevation	m.MSL.	662.50	282.3
	Crest Length	m	2,210	527
	Dam Volume	10 ³ m ³	6,190	853
	Upstream Face Slope	-	1 : 2.5	1 : 3.0 - 5.0
	Downstream Face Slope	-	1 : 2.5	1 : 2.5

General Project Description of Lam Ta Khong Pumped Storage Project (2/4)

	Project Name		Lam Ta Khong Pumped Storage
6.	INTAKE Type Size Number	 m set	Morning-glory (18.0 - 5.8) ^D x 51 2
7.	PENSTOCK Type Number Inner Diameter Length	 - - m m	Inclined Shaft Embedded Steel 2 - 4 5.8 - 2.6 690
8.	TAILRACE TUNNEL Type Number Inner Diameter Length	 - - m m	Concrete Lined Pressure Type 4 - 2 4.90 - 6.60 1,470
9.	SURGE CHAMBER Type Number Dimension - Main Body - Chamber	 - - m m	Chamber Surge Tank 2 Inside 8.90 Height 107.0 Inside 10.00 x 10.00 Length 35.0
10.	OUTLET Type Number Size	 - - m m m	4 Continuous Box Culvert 2 Width 6.6 - 30.0 Height 6.6 - 10.0 Length 55.0

General Project Description of Lam Ta Khong Pumped Storage Project (3/4)

	Project Name		Lam Ta Khong Pumped Storage
11.	POWER HOUSE Type Size (Width x Length x Height) Draft Gate - Type - Number Tailrace Gate - Type - Number	- m - set	Underground type 22 x 117 x 45.7 Bonnet Type Gate 4 Roller Gate 2
12.	TURBINE/PUMP (Turbine) Type Number of Units Max. Gross Head Rated Intake Water Level Rated Tail Water Level Gross Head Normal Effective Head Max. Power Discharge Rated Output Revolving Speed (Pump) Max. Pump Head Max. Pump Input Max. Pump Discharge Revolving Speed	unit m m.MSL. m.MSL. m m m ³ /sec MW rpm m MW m ³ /sec rpm	Vertical Shaft Francis type reversible pump turbine 4 401 653 276 377 357 82.5 255 375 409 277 71.4 375
13.	GENERATOR/MOTOR Type Number of Units Rated Output Voltage Power Factor Frequency Revolving Speed	unit MVA kV - Hz rpm	3-phase AC Synchronous Generator-Motor 4 278 16.5 Generator 0.9 (Lag) Motor 0.98 (Lead) 50 375

General Project Description of Lam Ta Khong Pumped Storage Project (4/4)

	Project Name		Lam Ta Khong Pumped Storage
14.	MAIN TRANSFORMER		
	Number of Units	unit	4
	Type	-	Special 3-phase in door forced oil water cooled type with on load tap changer
	Capacity	MVA	290
	Voltage	kV	230/16.5
15.	SWITCHYARD		
	Type	-	SF ₆ Gas Insulated Switchgear Type
	Nominal Voltage	kV	230
	Number of Circuits	cct	8
16.	TRANSMISSION LINE		
	Connection	-	To Saraburi 2 - Nakhon Rachasima 2 To Thalan 3 Existing 230 kV Line
	Nominal Voltage	kV	230
	Number of Circuits	cct	2
	Length	km	15
17.	POWER GENERATION		
	Max. Power Discharge	m ³ /sec	340 (4 units)
	Normal Effective Head	m	357
	Installed Capacity	MW	1,000
	Annual Operating hours	hrs	800
	Generating Capability of Continuous Operation	hrs	8
18.	PROJECT COST	M฿ (MUS\$)	16,674 (641)
19.	ECONOMIC COST	M฿ (MUS\$)	11,254 (433)
20.	ECONOMICS		
	B - C	M฿	1,504
	B / C	-	1.16
	EDR	%	17.4
21.	CONSTRUCTION PERIOD	yrs.	5
22.	COMMISSIONING		1997

2. CONCLUSIONS AND RECOMMENDATIONS

The Lam Ta Khong Pumped Storage Project is situated on the Lam Ta Khong River, a tributary of the Mun River of the Mekong River system, 200 km northeast of the capital, Bangkok. This Feasibility Study reveals that the project is feasible from technical, environmental and economic points of view. An outline of the conclusions and recommendations are given below.

Conclusions

- (1) Electric power demand in Thailand recorded an annual growth rate of 14 percent in 1990 as a result of rapid industrialization. It is predicted that demand will grow at an annual rate of approximately 16 percent in 1991 and 7 percent in 1997. The peak power demand in 1990 of 7,094 MW is estimated to become about 13,000 ~ 14,000 MW in 1997. Therefore, there will be a necessity to construct new facilities of approximately 900 MW every year.
- (2) At present, only a few power source exist to meet the rapid increase of peak power demand. In order to supply reliable electric power in the future corresponding to the rapid industrialization of Thailand, it is necessary to develop hydroelectric power plants capable of coping with the peak load. The Lam Ta Khong project is extremely promising as a power source to cope with the above-mentioned increase in demand and as a power source to supply peak loads of Thailand.
- (3) The optimum scale of development of the Lam Ta Khong pumped storage power plant is 1,000 MW having the capability of 8 hours' continuous operation (storage capacity of upper reservoir). It is desirable to commence operation of the project at the earliest, and it is considered that this is in the year 1997. In the case that the development of the project is divided into two stages and that the unit 3 and 4 (250 MW x 2 units) are installed later than 1997, it is recommended that the units 3 and 4 shall be installed by the year of 2002 from an economic point of view.

- (4) The power system stability poses a limitation of plant operation. The 1,000 MW generation will be possible in 1997, however, pumping at off-peak time will have to be restricted to 500 MW at most from the stand point of the power system stability.
- (5) In addition to the function of power supply capability the Lam Ta Khong power plant will provide the following benefits to EGAT's system. The project will have quick load following characteristics corresponding to load fluctuation, regulating the system frequency and voltage, reserve capacity in case of failure of other power plants, and reducing the frequency of start-and-stop of thermal power plants thereby enabling high efficiency operation of thermal power plants.
- (6) Civil structures including surface membrane fill dam for upper reservoir, underground powerhouse, penstock and tailrace tunnel were designed taking into consideration topography, geology, availability of construction materials, earthquakes and environmental aspect.

Bedrock of the upper reservoir, the waterway and the underground powerhouse is composed of sedimentary rock of Mesozoic era, and remarkable faults or other problems were not found judging from the results of in situ rock tests. There are no technical problems which would influence the realization of this project.

- (7) The project area is located in an environmental area where development is restricted by the Thai government. Construction of structures on the surface are prohibited in a part of the area. In order to evade the restricted area, underground structures are adopted in this project.

There are no people living in the project area, so there will be no resettlement problem.

Since the project is designed considering the environment, it is feasible from an environmental point of view.

- (8) The estimated project cost including import duty, interest during construction and escalation up to 1997 is 16,674 million Baht (US\$641 million).

- (9) The present value of surplus benefit (B - C), benefit-cost ratio (B/C), and equalizing discount rate (EDR) of the project obtained from economic comparison of the Lam Ta Khong power plant and an alternative thermal plant are 1,504 million Baht, 1.16 and 17.4 percent, respectively. These values indicate that the development of the project is economically feasible.

Recommendations

- (1) It is necessary to proceed to the stage of definite study as soon as possible in order that the project is completed and commissioned as scheduled in the year 1997.
- (2) The following additional investigations and studies are recommended:
 - Exploratory adit should be excavated as soon as possible in order to design the powerhouse and study its construction method. In situ rock tests should be carried out in order to understand the physical properties of the bedrock.
 - Along with the definite study of the project development, it is necessary to study reinforcing the power system in future, especially to study installing facilities to supply reactive power for the purpose of holding voltage of 230 kV bus at each substation at the appropriate level. It is particularly important to hold the voltages at Saraburi 2 and Nakhon Ratchasima 2 substations during Lam Ta Khong's pumping.
 - In order that the power sources in the northern area can be developed on schedule and the Lam Ta Khong power station and other power stations can be properly operated without limitations it is necessary to reinforce the power system in and after the end of 1990's when power system stability at pumping hours will become critical. The power system reinforcement should be studied including the possibility of pumping by three or four units of the Lam Ta Khong power station.

3. LOAD FORECAST

3.1 Result of Load Forecast

Power demand forecast by the JICA Team are shown in Table 3-1 and Table 3-2. Future values on these tables were forecasted based on such data of Thailand as actual energy consumption, past GDP, GDP and population in future predicted by the Thai government agencies.

(1) Energy Consumption

The JICA Team forecasted that the energy consumption would increase at the average growth rate of 13.01% from about 31,500 GWh in 1989 to about 39,400 GWh in 1991, 9.52% from 1992 to 1996 and 7.36% from 1997 to 2001, and in 2000 it will be about 82,800 GWh, which is about 2.6 times as much as that in 1989.

Energy consumption per capita in 2000 is predicted to be 1286 kWh, which is about 2.26 times as much as 568 kWh at the present time.

(2) Energy Demand and Maximum Power Demand

The energy demand at generating end is predicted to increase at an average rate of about 8.93% per year from the current about 36,500 GWh to about 97,000 GWh in 2000.

The annual load factor at generating end is predicted to decrease gradually in future from current 68% to 63.3% in 2000.

The maximum power demand at generating end is predicted to grow at a rate of 9.42% per year on average and to be about 17,400 MW in 2000.

(3) Comparison between the Load Forecasts Made by the JICA Team and Thai Organization

Load forecast formulated by Thai organization is shown in table 3-3. The difference between the above two is exceedingly small in the energy demand at generating end, although the JICA forecast is a little bit lower than the High Case forecast by the Thai organization. They can be regarded as almost the same.

As for the maximum power demand, each forecast predicts that it will grow almost in the same way until 1995 or 1996, but after that the values predicted by the JICA Team surpass those predicted by the Thai organization due to the different prediction for the future annual load factors.

Table 3-1 POWER DEMAND FORECAST IN THAILAND

Year	Generating				Sending				Transmission & Distribution Losses		Energy Consumption (GWH)
	Energy (GWH)	KWH Station Losses (GWH)	Maximum Power (MW)	Load Factor (%)	Energy (GWH)	Maximum Power (MW)	Load Factor (%)	Energy (GWH)	Maximum Power (MW)	Load Factor (%)	
1980	14,753.73	590.45	2,417.40	69.7	14,163.28	2330.4	69.4	1,156.31	2330.4	69.4	13,006.97
1981	15,959.97	612.29	2,588.70	70.4	15,347.68	2499.3	70.1	1,455.16	2499.3	70.1	13,892.52
1982	16,881.95	602.49	2,838.00	67.9	16,279.46	2746.8	67.7	1,507.29	2746.8	67.7	14,772.17
1983	19,066.30	659.05	3,204.30	67.9	18,407.25	3104.6	67.7	1,951.28	3104.6	67.7	16,455.97
1984	21,066.44	830.10	3,547.30	67.8	20,236.34	3421.5	67.5	2,196.89	3421.5	67.5	18,039.45
1985	23,356.57	1,022.61	3,878.40	68.7	22,333.76	3725.5	68.4	2,519.57	3725.5	68.4	19,814.19
1986	24,779.53	1,010.03	4,180.90	67.7	23,769.50	4027.5	67.4	2,755.66	4027.5	67.4	21,013.84
1987	28,193.16	1,154.68	4,733.90	68.0	27,038.48	4559.4	67.7	2,867.63	4559.4	67.7	24,170.85
1988	31,996.00	1,265.89	5,444.00	67.1	30,730.11	5250.2	66.8	3,165.26	5250.2	66.8	27,564.85
1989	36,457.09	1,532.22	6,232.70	66.8	34,924.87	5996.9	66.5	3,429.77	5996.9	66.5	31,495.10
1990	41,256	1,735	7,074	66.6	39,522	6,806	66.3	4,190	6,806	66.3	35,332
1991	45,961	1,954	7,916	66.3	44,007	7,613	66.0	4,576	7,613	66.0	39,431
1992	50,953	2,189	8,815	66.0	48,764	8,474	65.7	5,116	8,474	65.7	43,648
1993	56,132	2,438	9,754	65.7	53,694	9,373	65.4	5,699	9,373	65.4	47,995
1994	61,476	2,698	10,731	65.4	58,778	10,307	65.1	6,240	10,307	65.1	52,538
1995	66,987	2,971	11,746	65.1	64,017	11,277	64.8	6,781	11,277	64.8	57,236
1996	72,699	3,257	12,805	64.8	69,441	12,289	64.5	7,307	12,289	64.5	62,134
1997	78,189	3,539	13,835	64.5	74,650	13,271	64.2	7,775	13,271	64.2	66,875
1998	84,118	3,846	14,952	64.2	80,272	14,337	63.9	8,346	14,337	63.9	71,926
1999	90,392	4,175	16,141	63.9	86,217	15,470	63.6	8,972	15,470	63.6	77,245
2000	97,012	4,525	17,404	63.6	92,487	16,673	63.3	9,679	16,673	63.3	82,808
2001	103,921	4,896	18,730	63.3	99,025	17,936	63.0	10,390	17,936	63.0	88,635
2002	110,571	5,260	19,940	63.3	105,312	19,087	63.0	11,059	19,087	63.0	94,253
2003	117,549	5,646	21,199	63.3	111,903	20,282	63.0	11,752	20,282	63.0	100,151
2004	124,933	6,058	22,530	63.3	118,875	21,547	63.0	12,471	21,547	63.0	106,404
2005	132,760	6,499	23,942	63.3	126,261	22,887	63.0	13,230	22,887	63.0	113,031
2006	141,061	6,970	25,439	63.3	134,091	24,308	63.0	14,036	24,308	63.0	120,055

Table 3-2 FORECAST OF ENERGY CONSUMPTION IN THAILAND

Year	Energy Consumption *1		GDP in 1972 Price *2		Energy Consumption Per GDP		Population *2		kWh Per Capita	
	GWh	Growth Rate (%)	M Baht	Growth Rate (%)	Wh/Baht	Growth Rate (%)	Thousand	Growth Rate (%)	kWh	Growth Rate (%)
1980	13,006.97		299,472		43.4		46,961		277.0	
1981	13,692.52	6.8	318,440	6.3	43.6	0.4	47,875	0.4	290.2	4.8
1982	14,772.17	6.3	331,379	4.1	44.6	2.2	48,847	2.2	302.4	4.2
1983	16,455.97	11.4	355,411	7.3	46.3	3.9	49,515	3.9	332.3	9.9
1984	18,039.45	9.6	380,739	7.1	47.4	2.3	50,583	2.3	356.6	7.3
1985	19,814.19	9.8	394,113	3.5	50.3	6.1	51,796	6.1	382.5	7.3
1986	21,013.84	6.1	411,813	4.5	51.0	1.5	52,969	1.5	396.7	3.7
1987	24,170.85	15.0	446,361	8.4	54.2	6.1	53,973	6.1	447.8	12.9
1988	27,564.85	14.0	495,378	11.0	55.6	2.8	54,961	2.8	501.5	12.0
1989	31,495.10	14.3	542,706	9.6	58.0	4.3	55,448	4.3	568.0	13.3
1990	35,332	12.2	589,370	8.6	59.9	3.3	56,340	3.3	627.1	10.4
1991	39,431	11.6	637,964	8.2	61.8	3.1	57,199	3.1	689.4	9.9
1992	43,648	10.7	686,300	7.6	63.6	2.9	58,041	2.9	752.0	9.1
1993	47,995	10.0	734,802	7.1	65.3	2.7	58,876	2.7	815.2	8.4
1994	52,538	9.5	783,975	6.7	67.0	2.6	59,693	2.6	880.1	8.0
1995	57,236	8.9	834,063	6.4	68.6	2.4	60,508	2.4	945.9	7.5
1996	62,134	8.6	885,081	6.1	70.2	2.3	61,311	2.3	1013.4	7.1
1997	66,875	7.6	932,103	5.3	71.7	2.2	62,100	2.2	1076.9	6.3
1998	71,926	7.6	981,893	5.3	73.3	2.1	62,879	2.1	1143.9	6.2
1999	77,245	7.4	1,033,820	5.3	74.7	2.0	63,640	2.0	1213.8	6.1
2000	82,808	7.2	1,087,614	5.2	76.1	1.9	64,390	1.9	1286.0	6.0
2001	88,635	7.0	1,143,570	5.1	77.5	1.8	65,182	1.8	1359.8	5.7
2002	94,253	6.3	1,195,714	4.6	78.8	1.7	66,012	1.7	1427.8	5.0
2003	100,151	6.3	1,249,304	4.5	80.2	1.7	66,803	1.7	1499.2	5.0
2004	106,404	6.2	1,305,113	4.5	81.5	1.7	67,594	1.7	1574.2	5.0
2005	113,031	6.2	1,363,229	4.5	82.9	1.7	68,385	1.7	1652.9	5.0
2006	120,055	6.2	1,423,742	4.4	84.3	1.7	69,176	1.7	1735.5	5.0

Note : *1. The values for the year of 1990 onward were predicted by the JICA Team.

*2. The values for the year of 1990 onward were predicted by the Office of National Economic and Social Development Board, and National Energy Policy Office in Thailand.

Table 3-3 Load Forecast by Thai Organization
(High Case)

Fiscal Year	Peak Generation			Energy Generation			Load Factor %
	MW	Increase		GWh	Increase		
		MW	%		GWh	%	
			<u>Actual</u>				
1979	2,255.00	154.40	7.35	13,964.55	1,592.88	12.88	70.69
1980	2,417.40	162.40	7.20	14,753.73	789.18	5.65	69.67
1981	2,588.70	171.30	7.09	15,959.97	1,206.24	8.18	70.38
1982	2,838.00	249.30	9.63	16,881.95	921.98	5.78	67.91
1983	3,204.30	366.30	12.91	19,066.30	2,184.35	12.94	67.92
1984	3,547.30	343.00	10.70	21,066.44	2,000.00	10.49	67.79
1985	3,878.40	331.10	9.33	23,356.57	2,290.13	10.87	68.75
1986	4,180.90	302.50	7.80	24,779.53	1,422.96	6.09	67.66
1987	4,733.90	553.00	13.23	28,193.16	3,413.63	13.78	67.99
1988	5,444.00	710.10	15.00	31,996.00	3,812.84	13.49	67.09
1989	6,232.70	788.70	14.49	36,457.09	4,461.09	13.94	66.59
<u>Average Growth</u> 1980-1989	—	397.77	10.70	—	2,249.25	10.07	—
			<u>Forecast</u>				
1990	7,168.00	935.30	15.00	42,203.00	5,745.91	15.76	67.21
1991	8,028.00	860.00	12.00	48,013.00	5,810.00	13.77	68.27
1992	8,911.00	883.00	11.00	53,760.00	5,747.00	11.97	68.87
1993	9,802.00	891.00	10.00	59,470.00	5,710.00	10.62	69.26
1994	10,689.00	887.00	9.47	65,113.00	5,643.00	9.92	69.54
1995	11,498.00	809.00	7.57	70,505.00	5,392.00	8.28	70.00
1996	12,335.00	837.00	7.28	76,113.00	5,608.00	7.95	70.44
1997	13,190.00	855.00	6.93	81,674.00	5,561.00	7.31	70.69
1998	14,093.00	903.00	6.85	87,931.00	6,257.00	7.66	71.23
1999	15,009.00	916.00	6.50	94,167.00	6,236.00	7.09	71.62
2000	15,946.00	937.00	6.24	100,951.00	6,784.00	7.20	72.27
2001	16,916.00	970.00	6.04	108,041.00	7,090.00	7.02	72.91
2002	17,842.00	926.00	5.47	114,096.00	6,055.00	5.60	73.00
2003	18,777.00	935.00	5.24	120,075.00	5,979.00	5.24	73.00
2004	19,681.00	904.00	4.81	125,856.00	5,781.00	4.81	73.00
2005	20,593.00	912.00	4.63	131,688.00	5,832.00	4.63	73.00
2006	21,499.00	906.00	4.40	137,482.00	5,794.00	4.40	73.00
<u>Average Growth</u>							
1987-1991	—	769.42	13.94	—	4,646.69	14.14	—
1992-1996	—	861.40	8.97	—	5,620.00	9.65	—
1997-2001	—	916.20	6.52	—	6,385.60	7.26	—
2002-2006	—	916.60	4.91	—	5,960.20	4.94	—

4. POWER DEVELOPMENT PLAN

4.1 Power Development Plan of EGAT

The power supply capability of EGAT as of September, 1990 is as follows:

	Installed (MW)	Dependable (MW)
Hydro	2249.2	1908.9
Thermal	4306.5	4220.4
Combined	1176.6	1153.0
Gas Turbine	238.0	202.3
Total	7970.3	7484.6

The main part of EGAT's power development plan is occupied by the development of thermal power which comprises combined cycle, lignite fired and coal fired thermal power plants.

There are some development plans of hydro power and pumped storage, but the ratio of their total capacity to the entire development capacity by 2006 is only 6.5 percent or so.

Total developed capacity added to the above by 2006 is 19,934 MW, but some of old gas turbines and thermal power plants are planned to be retired, so the total capacity in 2006 is supposed to be 24,974.2 MW.

Table 4-1 shows the power development plan in Thailand (EGAT's PDP 90-03).

4.2 Balance of Power Supply and Demand

Reserve margin was estimated by combining the load forecast by the JICA Team with the power development plan of EGAT.

It is noted that the estimated reserve margin is 18 percent in 1993 but it becomes smaller yearly to nearly zero in 2004.

A power system must have operating reserve or extra generating capacity available to cope with emergencies such as unexpected interruption of plant operation, decrease in output power due to shortage of water or unforeseen increase of power demand.

The appropriate amount of operating reserve must be studied in conjunction with power supply reliability.

If Japan's reliability target, LOLE 0.3 days per month, is applied to Thailand, reserve margin of at least 15 to 16 percent would be required, which means about 800 MW must be added to the capacity developed in 1997 to 1998 based on the present power development plan.

4.3 Significance of Lam Ta Khong Project

A hydro power plant has a swift responsive performance for the requirement of power generation. It takes charge of the peak portion of load curve and is used as spinning reserve where the power can be called upon very rapidly following any unexpected loss of generating capacity.

However, future development of hydro power in Thailand will be greatly hampered by the lack of sites to be economically developed and troubles on environmental concerns. As a result, the ratio of power supply taking charge of peak load and power system frequency control will decrease gradually.

When sites for hydro power development becoming scarce, the development of pumped storage power will become an effectual alternative.

Because of its functional feature like general hydro power plant, a pumped storage power plant is used to secure supply capability to meet power demand as operating reserve and to control the frequency and voltage of the power system. It is also made use of for economical operation of thermal power plants.

In Japan, the appropriate development capacity of pumped storage power is said to be between 15 to 20 percent of increased demand, though it somewhat varies according to a power system.

Taking account of the situation of future hydro power supply, EGAT should develop Lam Ta Khong project as early as possible (in fiscal 1997 as the present power development plan).

EGAT should start to study reinforcement of the power system and development of power sources to secure sufficient supply capability after the end of nineteen-nineties.

In this connection, it is particularly important to study the development of peak load power stations including pumped storage power

plants in respect of power system frequency control and economical operation of power system.

Table 4-1

Power Development Plan in Thailand (EGAT's PDP 90-03)

Power Plant	Fuel Type	Unit Number	Rating (MW)	Total (MW)	Commissioning Date	
Under Construction	Rayong CC 1 (GT)	Gas	1-2	103	206	November 1990
	Nam Phong CC 1 (GT)	Gas	1-2	121	242	December 1990
	Rayong CC 2 (GT)	Gas	1-2	103	206	December 1990
	Rayong CC 3 (GT)	Gas	1-2	103	206	March 1991
	Srinagarind	Hydro	5	180	180	April 1991
	Bang Pakong CC 3 (ST)	-	1	99	99	March 1991
	Bang Pakong CC 4 (ST)	-	1	99	99	July 1991
	Rayong CC 1 (ST)	-	1	102	102	August 1991
	Rayong CC 2 (ST)	-	1	102	102	September 1991
	Nam Phong CC.1 (ST)	-	1	113	113	November 1991
	Mae Moh	Lignite	10	300	300	November 1991
	Rayong CC 3 (ST)	-	1	102	102	December 1991
	Bang Pakong Thermal	Oil/Gas	3	600	600	March 1992
	Mae Moh	Lignite	11	300	300	May 1992
	Bang Pakong Thermal	Oil/Gas	4	600	600	May 1993
	Pak Mun	Hydro	1-4	34	136	Jun 94 - Nov 94
	Bhumibol Renovation	Hydro	1	(70)	(70)	June 1992
	Nam Phong CC 2 (GT)	Gas	1-2	121	242	January 1993
	Bhumibol Renovation	Hydro	2	(70)	(70)	January 1993
	Rayong CC 4 (GT)	Gas	1-2	100	200	March 1993
South Bangkok CC 1 (GT)	Gas	1-2	100	200	April 1993	
Khanom CC1(GT)	Gas	1-2	100	200	December 1993	
Nam Phong CC 2 (ST)	-	1	113	113	January 1994	
Sirikit	Hydro	4	125	125	February 1994	
Rayong CC 4 (ST)	Gas	1	100	100	March 1994	
South Bangkok CC 1 (ST)	-	1	100	100	April 1994	
Khanom CC 2. (GT)	Gas	1-2	100	200	April 1994	
Wang Noi Gas Turbine	Gas	1-2	100	200	November 1994	
Khanom CC 1 (ST)	-	1	100	100	December 1994	
Kaeng Krung	Hydro	1-2	40	80	December 1994	
Bhumibol	Hydro	8	175	175	January 1995	
Wang Noi Gas Turbine	Gas	3-4	100	200	April 1995	
Khanom CC 2 (ST)	-	1	100	100	April 1995	
Mae Moh	Lignite	12	300	300	April 1996	
Ao Phai	Coal	1	700	700	August 1996	
Mae Moh	Lignite	13	300	300	October 1996	
Lam Takhong	Hydro	1-4	150	600	Dec 96 - Jun 97	
Ao Phai	Coal	2	700	700	April 1997	
Ao Phai	Coal	3	700	700	April 1998	
Mae Taeng	Hydro	1-2	18+8	26	June 1998	
Nam Khek	Hydro	1	50	50	December 1998	
Lampang	Lignite	1	300	300	January 1999	
Mae Lama Luang	Hydro	1-3	80	240	January 1999	
Lampang	Lignite	2	300	300	July 1999	
Nam Ngao	Hydro	1-2	70	140	January 2000	
Lampang	Lignite	3	300	300	January 2000	
Saba Yoi	Lignite	1	300	300	April 2000	
Lampang	Lignite	4	300	300	July 2000	
Saba Yoi	Lignite	2	300	300	October 2000	
Lampang	Lignite	5	450	450	January 2001	
New Gas Turbine	Gas	1-2	100	200	April 2001	
Lampang	Lignite	6	450	450	July 2001	
Ao Phai	Coal	4	700	700	October 2001	
Saba Yoi	Lignite	3	300	300	April 2002	
New Thermal	1/	1	1,000	1,000	October 2002	
New Thermal	1/	2	1,000	1,000	April 2003	
Sin Pun	Lignite	1	75	75	April 2003	
New Gas Turbine	Gas	3-4	100	200	May 2003	
New Thermal	1/	3	1,000	1,000	January 2004	
Sin Pun	Lignite	2	75	75	April 2004	
New Thermal	1/	4	1,000	1,000	January 2005	
New Thermal	1/	5	1,000	1,000	October 2005	
New Thermal	1/	6	1,000	1,000	April 2006	

Existing Capacity by September 1990	=	7,970.3	MW
Total Added Capacity (Up to 2006)	=	19,934.0	MW
Plant Retirement	=	2,930.1	MW
Total Capacity by Year 2006	=	<u>24,974.2</u>	MW

Note : 1/ Type of fuel will be determined later on.

5. HYDROLOGY

The Lam Ta Khong River, about 170 kilometers in length, is one of the major tributaries of the Mun River. It flows generally north and eastward passing the city of Nakhon Ratchasima to its confluence with the Mun River at Ban Tha Chang about 20 kilometers east of the city.

The Lam Ta Khong River basin originates in the high mountainous area on the southwest corner of the Khorat Plateau and lies on the northern slopes of the divide between the provinces of Nakhon Nayok and Nakhon Ratchasima.

The rainfall in the project area mainly depends on the Southwest Monsoon and the depression that originates from the South China Sea then passes through Vietnam and moves toward the northeast of Thailand.

The drainage basin of the Lam Ta Khong River lies in the area of less rainfall. This is because the mountain ranges along the western end of the Plateau act as high barriers against the Southwest Monsoon.

The average annual rainfall in the project area is between 900 mm and 1,100 mm. The annual rainfall as low as 500 ~ 600 mm may be expected in dry years, while 1,500 mm in wet years.

About 80% of the annual rainfall occurs during the months of May through October, and maximum monthly rainfall of 200 ~ 250 mm occurs in September.

The annual mean temperature is 26.5°C, and the extreme highest and lowest temperatures are recorded 42.7°C in April and 6.2°C in December.

The annual mean relative humidity is 72.2%, and the monthly mean relative humidity is as high as 94.7% in September and as low as 84.8% in March.

The annual evaporation is 1,879.2 mm, and the maximum is 192.1 mm in April.

The climatological data at the station of Nakhon Ratchasima is tabulated on Table 5-1.

Data on stream flows on the Lam Ta Khong River upstream of the Lam Ta Khong dam are available at five gauging stations. The station M38C near the Lam Ta Khong dam has recorded since 1962, but the flow data since July, 1968 are the outflows from the Lam Ta Khong dam. Locations of rainfall stations and gauging stations are shown in Fig. 5-1.

The monthly reservoir inflows of the Lam Ta Khong dam are tabulated on Table 5-2. The natural annual reservoir inflow is 258.94 MCM (8.21 m³/sec) on the average, 110.00 MCM in the driest year (1968) and 495.00 MCM in the wettest year (1972).

The reservoir water levels of the Lam Ta Khong dam are illustrated in Fig. 5-2.

Table 5-1 Climatological Data for the Period 1956 - 1985

Station: Nakhon Ratchasima (EL. 187 m)
Lat, 14°58'N, Long, 102°05'E

	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Total
<u>Rainfall (mm)</u>													
Mean	4.8	22.7	43.9	68.3	145.2	111.6	132.6	130.4	261.5	154.1	30.0	3.6	1,108.7
Mean rainy days	1.0	2.9	5.6	8.0	13.4	14.1	13.4	16.4	19.7	12.3	4.0	0.9	115.7
Greatest in 24 hr.	71.2	59.7	57.3	91.5	73.8	114.8	104.1	72.3	143.7	136.0	84.3	20.6	143.7
<u>Temperature (°C)</u>													
Mean	23.0	25.9	28.3	29.2	28.5	28.2	27.7	27.4	26.7	26.0	24.4	22.7	26.5
Mean Max.	30.7	33.5	36.0	36.5	35.1	34.1	33.4	33.0	31.9	30.8	29.7	29.5	32.9
Mean Min.	16.3	19.7	22.2	23.8	24.2	24.1	23.7	23.6	23.2	22.4	19.9	16.9	21.7
Ext. Max.	37.8	40.6	42.3	42.7	41.4	40.1	40.0	38.1	38.0	35.3	35.3	35.8	42.7
Ext. Min.	6.7	11.4	11.6	16.9	20.7	21.1	21.1	20.5	19.7	16.2	9.1	6.2	6.2
<u>Relative Humidity (%)</u>													
Mean	65.8	63.6	62.8	66.8	74.4	74.5	75.8	77.0	82.4	80.3	75.3	67.6	72.2
Mean Max.	87.5	85.3	84.8	86.1	90.3	90.0	90.6	91.3	94.7	93.8	91.2	89.1	89.6
Mean Min.	41.7	40.2	38.3	43.4	52.3	54.0	55.7	57.8	63.2	62.0	55.6	47.3	51.0
Ext. Min.	22.0	14.0	12.0	19.0	23.0	23.0	35.0	35.0	41.0	31.0	27.0	20.0	12.0
<u>Evaporation (mm)</u>													
Mean - Pan	140.6	149.7	190.8	192.1	176.1	170.9	168.1	158.2	131.3	135.7	130.0	137.7	1,879.2
<u>Cloudiness (0-10)</u>													
Mean	3.4	4.2	4.6	5.5	7.1	7.9	8.5	8.5	8.1	6.5	4.9	3.9	6.1
<u>Sunshine Duration (hr)</u>													
Mean	283.0	244.5	249.0	245.0	244.5	207.2	194.2	185.4	165.1	225.1	257.8	276.0	2,776.8

Table 5-2 Estimated Inflow At Lam Ta Khong Dam: Unit (MCM)

YEAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	JAN	FEB	MAR	TOTAL
1962	-	-	-	37.00	20.00	73.00	56.00	10.00	5.00	3.00	2.00	3.00	-
1963	3.00	3.00	4.00	17.00	30.00	57.00	87.00	25.00	10.00	7.00	4.00	3.00	250.00
1964	3.00	53.00	19.00	23.00	23.00	50.00	112.00	23.00	9.00	6.00	6.00	6.00	335.00
1965	4.00	9.00	22.00	31.00	6.400	81.00	69.00	20.00	10.00	6.00	5.00	4.00	325.00
1966	5.00	26.00	14.00	22.00	49.00	34.00	19.00	10.00	6.00	4.00	4.00	4.00	197.00
1967	5.00	15.00	15.00	16.00	22.00	22.00	49.00	7.00	4.00	3.00	2.00	3.00	163.00
1968	4.00	24.00	8.00	11.00	12.00	16.00	18.00	5.00	2.00	4.00	2.00	4.00	110.00
1969	2.00	1.00	19.00	38.00	33.00	110.00	38.00	15.00	8.00	7.00	6.00	8.00	285.00
1970	8.00	7.00	14.00	22.00	17.00	36.00	40.00	9.00	9.00	5.00	5.00	4.00	176.00
1971	6.00	14.00	11.00	23.00	15.00	28.00	18.00	6.00	6.00	2.00	7.00	6.00	142.00
1972	5.00	0.0	6.00	17.00	24.00	192.00	168.00	33.00	15.00	13.00	13.00	9.00	495.00
1973	12.00	16.00	11.00	12.00	19.00	70.00	47.00	6.00	6.00	5.00	10.00	16.00	230.00
1974	15.00	18.00	18.00	19.00	22.00	32.00	75.00	46.00	13.00	11.00	10.00	11.00	290.00
1975	8.00	19.00	38.00	39.00	39.00	92.00	107.00	18.00	10.00	10.00	12.00	8.00	400.00
1976	13.00	20.00	24.00	30.00	59.00	82.00	99.00	43.00	15.00	6.00	6.00	10.00	407.00
1977	10.00	16.00	11.00	28.00	22.00	35.00	20.00	7.00	7.00	4.00	5.00	6.00	171.00
1978	14.00	10.00	19.00	35.00	36.00	39.00	57.00	8.00	4.00	5.00	3.00	2.00	232.00
1979	7.00	10.00	9.00	24.00	29.00	61.00	53.00	7.00	6.00	4.00	4.00	3.00	217.00
1980	5.90	5.50	24.80	19.60	18.10	41.90	84.80	17.40	5.70	4.40	3.80	2.00	233.90
1981	11.00	16.10	22.60	27.50	31.80	43.60	33.80	27.20	4.60	0.0	3.00	5.30	226.50
1982	4.40	6.40	8.80	21.70	28.70	70.20	38.90	11.40	4.80	4.20	2.30	0.60	202.40
1983	1.60	4.50	7.50	12.90	46.50	58.90	231.40	30.00	16.00	10.40	14.20	7.20	451.10
1984	11.70	8.20	8.40	24.50	32.10	41.50	83.60	15.80	7.50	8.50	4.20	1.50	247.50
1985	9.20	26.70	30.80	32.30	31.20	45.80	51.00	16.70	6.60	5.90	2.00	4.40	262.60
1986	11.10	24.30	10.20	15.00	14.60	29.90	77.90	11.00	5.60	1.80	3.70	1.80	206.90
1987	7.90	12.80	10.70	8.90	12.20	73.90	44.80	17.00	5.10	5.80	7.10	2.90	209.10
1988	5.50	22.60	16.60	14.30	29.70	87.40	103.80	15.60	9.70	7.50	4.90	7.40	327.00
1989	1.60	20.10	7.70	8.90	9.80	-	-	-	-	-	-	-	-
TOTAL	193.90	408.20	410.10	631.60	789.70	1603.10	1884.00	470.10	210.60	153.50	151.20	143.10	6792.00
NUMBER	27	27	27	28	28	27	27	27	27	27	27	27	28
AVERAGE	7.18	15.12	15.19	22.56	28.20	59.37	69.78	17.41	7.80	5.69	5.60	5.30	261.32
MAX	15.00	53.00	38.00	39.00	64.00	192.00	231.40	46.00	26.00	13.00	14.20	16.00	495.00
MIN	1.60	0.0	4.00	8.90	9.80	16.00	18.00	5.00	2.00	0.0	2.00	0.60	110.00




Fig.5-1 Location of Rainfall Station and Gauging Station




Fig.5-2 Inflow, Water Level and Rainfall of Lam Ta Khong Dam

6. GEOLOGY, CONSTRUCTION MATERIALS AND SEISMICITY

6.1 Geology

(1) Outline of Geology

As shown in DWG. 6-1 and 6-2, the bedrock of the project area is composed of the Phu Kradung formation which consists of siltstone, fine-grained sandstone, and partly conglomerate and the Phra Wihan formation which consists of coarse-grained sandstone, claystone, alternation of fine-grained sandstone and siltstone. In terms of hardness of rock, the sandstones are generally massive and hard while the degree of consolidation of siltstone is slightly low and that of claystone is low. The relations between the layers are conformable and the strikes of the layers are $N30^{\circ} W$ to $N70^{\circ}$ and the dips 5° to 10° (average 6°) NE. Residual soil with a thickness of several meters covers the bedrock at the upper reservoir site. Colluvial deposit and Talus deposit which attain 30 m in thickness are distributed in the slope above the waterway tunnel. Outlines of the bedrocks constituting the project sites and the main values of physical properties of each bed are given in Table 6-1.

In this area no fault was found in the outcrop, however, the drilling resulted in small-scaled faults being found. Also, in aerophotographs several lineaments which may indicate the existence of faults could be found.

(2) Engineering Geological Evaluation of Main Structure Sites

(a) Upper Reservoir Site

The foundation rock consists of weathered coarse-grained sandstone and claystone. The former has enough strength and the latter also can be used for the foundation rock of the dam. The residual soil distributed at the ground surface with the thickness under about 5 m is necessary to be removed by excavation since its strength is not enough.

(b) Intake and Headrace Tunnel Site

The bedrock consists of coarse-grained sandstone, alternation of fine-grained sandstone and siltstone. Although the bedrock may be partly weathered and there is a fault shear zone with the apparent width of approximately 4 m, there will be no problem about the construction of the structures.

(c) Penstock and Underground Powerhouse Site

The bedrock consists of alternation of fine-grained sandstone and siltstone, coarse-grained sandstone, siltstone and fine-grained sandstone. It is not weathered and has few faults, so the geologic conditions of the site are mostly good.

Although the conditions of siltstone observed in drill cores look bad due to slaking, the geologic conditions of bedrock are presumably not so bad from the result of drill hole deformation tests. Siltstone is judged to be capable of the construction of tunnel, however, it will be necessary to spray concrete as soon as possible after the excavation in order to prevent the deterioration of bedrock.

Although the fine-grained sandstone distributed in the underground powerhouse site is very stiff, the treatment for spring may be necessary as its permeability is high.

(d) Tailrace Tunnel and Outlet Site


The bedrock is as similar as that of the underground powerhouse site except that it is softened by weathering near the outlet site since the depth from the ground surface is shallow.


The colluvial and talus deposit of the slope over the tailrace tunnel is highly likely to have been formed by the landslide acted in the past. At present no particular phenomenon

indicating current activities can be observed, however, attention should be paid to the point that the excavation for outlet, switchyard and access road in the slope may eventually cause a damage to the stability of the slope.

Table 6-1 Stratigraphy and Properties of Rocks in Project Area

Era	Period	Formation (Geologic Unit)	Lithology	Thickness (m)		Distribution	Compressive Strength (kgf/cm ²)	Deformation Modulus (kgf/cm ²)	Remarks	
				Unit bed	Total					
CENozoic	Quaternary	Colluvial Deposit Talus Deposit	Sandstone fragments and soil material: poorly sorted, including boulders	—	0~30	Slope over waterway	—	—		
		Residual Soil	Lateritic red soil: silty gravel~sandy clay rich in oxides of iron	—	0~4	Upper Reservoir	—	—	N-value:50<	
MESozoic	Jurassic	Phra Wihan Formation	Claystone: Massive, light-gray, silty	5<, 5-15 , 1-3	60<	Upper Reservoir, Intake	20-30	—	weathered	
				25, 30-40						500-800
		Phra Wihan Formation	Alternation of sandstone and siltstone: Fine-grained sandstone; light-gray, calcareous, Siltstone and sandy siltstone; Reddish-purple to greenish-gray, calcareous	—	200	Headrace, Penstock	500-1,100 Siltstone 200-300	Fine-grained sandstone 50,000-80,000	—	fresh RQD = 75 %
				5, 25						
		Phu Kradung Formation	Siltstone and sandy siltstone: Reddish-purple to greenish-gray, calcareous, intercalated light-gray fine-grained calcareous sandstone	—	180	Penstock, Powerhouse	200-300 (sandy part : 500-800)	11,000-25,000	—	fresh RQD = 79 %
				—						
Phu Kradung Formation	Siltstone and sandy siltstone: Reddish-purple to greenish-gray, calcareous	—	130<	Powerhouse, Tailrace, Outlet	700-1,100	9,000-80,000	—	partly weathered RQD = 79 %		
		2-20, 20, 10							—	—
Phu Kradung Formation	Fine-grained sandstone: light-gray, calcareous, locally intercalated greenish-gray very coarse- grained sandstone and conglomerate	—	130<	Powerhouse, Tailrace, Outlet	700-1,100	9,000-80,000	—	partly weathered RQD = 79 %		
		2-20, 20, 10							—	—





LEGEND



- Colluvial Deposit, Talus Deposit
- Claystone
- Coarse-Grained Sandstone (partly including claystone patch)
- Alternation of Fine-Grained Sandstone and Siltstone
- Siltstone, Sandy Siltstone (with thin sandstone beds) (K) : Phu Kradung Formation
- Fine-Grained Sandstone (with thin siltstone beds)
- Geologic Boundary (-----: concealed part)
- Strike and Dip of Bed
- Strike and Dip of Joint
- Inferred Weak Line (by aerophoto)
- DHU-1 Drill Hole
- PU-1 Test Pit
- GU-1 Geophysical Prospecting
- Cross Section
- Spring
- Stream

0 500m

LAM TA KHONG PUMPED STORAGE PROJECT

**GEOLOGIC PLAN
OF
PROJECT AREA**

DWG. 6-1



Korat Group (Jurassic)

Phu Kradung Formation

Phra Winan Formation

D

L

①

③


④

⑤

⑥

⑦


LAI



LEGEND

- Colluvial Deposit, Talus Deposit
- Claystone
- Coarse-Grained Sandstone (partly including claystone patch)
- Alternation of Fine-Grained Sandstone and Siltstone
- Siltstone, Sandy Siltstone (with thin fine-grained sandstone beds) (K): Phu Krading Formation
- Fine-Grained Sandstone (with thin siltstone beds)
- Highly Weathered Rock (W ≥ 3-4)
- Geologic Boundary (---: inferred)
- Inferred Weak Line (by aerophoto)
- Ground Water Table

DHU-1 Drill Hole
 L. 50m E.L. : Elevation
 L. : Length



①	②	③	④	⑤	⑥	⑦
Log	RQD	CL	RC	RE	L-P	
0	100	0	W1	H1	0.1	5.00
10	100	0	W1	H1	0.1	5.00
20	100	0	W1	H1	0.1	5.00
30	100	0	W1	H1	0.1	5.00
40	100	0	W1	H1	0.1	5.00
50	100	0	W1	H1	0.1	5.00
60	100	0	W1	H1	0.1	5.00
70	100	0	W1	H1	0.1	5.00
80	100	0	W1	H1	0.1	5.00
90	100	0	W1	H1	0.1	5.00
100	100	0	W1	H1	0.1	5.00
110	100	0	W1	H1	0.1	5.00
120	100	0	W1	H1	0.1	5.00
130	100	0	W1	H1	0.1	5.00
140	100	0	W1	H1	0.1	5.00
150	100	0	W1	H1	0.1	5.00
160	100	0	W1	H1	0.1	5.00
170	100	0	W1	H1	0.1	5.00
180	100	0	W1	H1	0.1	5.00
190	100	0	W1	H1	0.1	5.00
200	100	0	W1	H1	0.1	5.00
210	100	0	W1	H1	0.1	5.00
220	100	0	W1	H1	0.1	5.00
230	100	0	W1	H1	0.1	5.00
240	100	0	W1	H1	0.1	5.00
250	100	0	W1	H1	0.1	5.00
260	100	0	W1	H1	0.1	5.00
270	100	0	W1	H1	0.1	5.00
280	100	0	W1	H1	0.1	5.00
290	100	0	W1	H1	0.1	5.00
300	100	0	W1	H1	0.1	5.00
310	100	0	W1	H1	0.1	5.00
320	100	0	W1	H1	0.1	5.00
330	100	0	W1	H1	0.1	5.00
340	100	0	W1	H1	0.1	5.00
350	100	0	W1	H1	0.1	5.00
360	100	0	W1	H1	0.1	5.00
370	100	0	W1	H1	0.1	5.00
380	100	0	W1	H1	0.1	5.00
390	100	0	W1	H1	0.1	5.00
400	100	0	W1	H1	0.1	5.00
410	100	0	W1	H1	0.1	5.00
420	100	0	W1	H1	0.1	5.00
430	100	0	W1	H1	0.1	5.00
440	100	0	W1	H1	0.1	5.00
450	100	0	W1	H1	0.1	5.00
460	100	0	W1	H1	0.1	5.00
470	100	0	W1	H1	0.1	5.00
480	100	0	W1	H1	0.1	5.00
490	100	0	W1	H1	0.1	5.00
500	100	0	W1	H1	0.1	5.00

① Depth (m) ② Geologic Column
 ③ RQD: Rock Quality Designation (%)
 CL: Core Loss (%)
 ④ RC: Rock Classification
 W: Weathering, 1 (very fresh) - 5 (extremely weathered)
 H: Hardness, 1 (very hard) - 5 (soft)
 C: Joint Interval, 1 (over 30cm) - 5 (under 1cm)
 ⑤ RE: Rock Evaluation
 H: Hard Rock, S: Soft Rock, 1 (good) - 3 (bad)
 ⑥ L-P: Lugeon Value (Lu) or Permeability Coefficient (cm/s)
 * : Converted Lugeon Value, E-6 : × 10⁻⁶
 ⑦ 5.00 : Final Water Level (m)
 < 60,000 : Deformation Modulus (kgf/cm²)

LAM TA KHONG PUMPED STORAGE PROJECT

GEOLOGIC PROFILE OF WATERWAY (A-A)

DWG. 6-2

6.2 Construction Materials

(1) Embankment Materials for Upper Dam

As for embankment materials for the upper dam, it will be possible to utilize residual soil, claystone and coarse-grained sandstone obtained by excavation of the upper reservoir. There will be no problem about the utilization of coarse-grained sandstone for the embankment material judging from the results of the drill core test and the concrete aggregate test. According to the material test results, residual soil and claystone are suitable for impervious material, however, it is sufficiently possible to use them for the embankment materials after adequate mixing with coarse-grained sandstone.

(2) Concrete Aggregate

It is hard to collect the river bed gravel in the area around the project site so that it is necessary to collect aggregate at quarries. As quarry sites the following two sites may be proposed: the one is the site where limestone of the Ratburi group is distributed about 12 km to the southwest of Pak Chong (about 30 km to the southwest of the project site) and the other is the site where coarse-grained sandstone is distributed about 1.5 km to the northeast of the upper reservoir.

The limestone of the existing quarry comes up to the standard in ASTM and JIS (Japan Industrial Standards). The rock, however, contains dolomite component which may be noxious for concrete because of alkali-carbonate reaction. Therefore the detailed tests should be carried out hereafter to clarify the suitability.

As for the coarse-grained sandstone, the value of dry density, about 2.35 g/cm^3 is under that of the standard (2.50 g/cm^3) in JIS and the other test results satisfy the standard. As the standard value of density is considered not to be absolute, synthetic

examination considering design condition, economics and so forth is necessary for the selection of concrete aggregate.

6.3 Seismicity

Judging from the wide standpoint of view, it can be clearly said that Thailand is an aseismic country except its northern part. Seismic activity of Thailand is remarkably low compared with the adjacent countries, or Myanmar, India, China, Nepal, Japan and so forth. The Lam Ta Khong project site is located in the stable Khorat Plateau which has no fold and the influence of metamorphism. No active fault or no large fault has been reported in and around the site.

On retrieval from the earthquake data files of NOAA (National Oceanic and Atmospheric Administration) with regard to earthquakes in which tremors were felt in the project area, the results obtained were zero times within a radius of 200 km from the Lam Ta Khong upper reservoir site, 8 times within 500 km, and 543 times within 1,000 km.

As is clearly indicated by this, it may be considered that there has been no historical earthquake at this project site from 1959 to 1987 which should be considered in design of the dam and other structures. The maximum acceleration of seismic oscillation was estimated at 20 gal at most at the Lam Ta Khong Upper Reservoir Site, according to the results of earthquake risk evaluated based on earthquakes in history. According to the estimated value, the design seismic intensity at the project site has been adopted 0.05 in consideration of importance of the key structures.

Since the clear location of active faults near the project site have never been reported, the design seismic intensity (0.05) is regarded as appropriate.